

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: ACRS 716TH MEETING

Docket Number: N/A

Location: Rockville, Maryland

Date: 06-05-2024

Work Order No.: NRC-2884

Pages 1-120

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

716TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

JUNE 5, 2024

+ + + + +

The Advisory Committee met via teleconference at 8:30 a.m., Walter L. Kirchner, Chair, presiding.

COMMITTEE MEMBERS:

- WALTER L. KIRCHNER, Chair
- GREGORY H. HALNON, Vice Chair
- DAVID A. PETTI, Member-at-Large
- RONALD G. BALLINGER, Member
- VICKI M. BIER, Member
- VESNA B. DIMITRIJEVIC, Member
- JOSE A. MARCH-LEUBA, Member
- ROBERT MARTIN, Member
- THOMAS ROBERTS, Member
- MATTHEW W. SUNSERI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANT:

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

KENT HOWARD

P R O C E E D I N G S

(8:30 a.m.)

CHAIR KIRCHNER: Good morning. The meeting will now come to order. This is the first day of the 716th meeting of the Advisory Committee on Reactor Safeguards.

I am Walt Kirchner, Chair of the ACRS. Other members in attendance are Ron Ballinger, Vicki Bier, Vesna Dimitrijevic, Greg Halnon. Expect Jose March-Leuba to join us; Robert Martin, David Petti, Thomas Roberts, and Matt Sunseri. We also have our consultant Steve Schultz on the line virtually.

I know we have a quorum today. The committee is meeting in person and virtually.

The ACRS was established by the Atomic Energy Act and is governed by the Federal Advisory Committee Act, FACA. The ACRS section of the U.S. NRC public website provides information about the history of this committee and documents such as our charter, by-laws, Federal Register Notices for meetings, letter reports, transcripts of full and subcommittee meetings, including all slides presented at the meetings.

The committee provides its advice on safety matters to the Commission through its publicly-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 available letter reports. Comments by individual
2 members do not represent Committee decisions. The
3 Commission speaks only through its published letter
4 reports.

5 The Federal Register Notice announcing
6 this meeting was published on May 10th, 2024. This
7 announcement provided a meeting agenda, as well as
8 instructions for interested parties to submit written
9 documents or requests for opportunities to address the
10 committee.

11 The Designated Federal Officer for today's
12 meeting is Kent Howard.

13 A communications panel has been opened to
14 allow members of the public to monitor the open
15 portions of the meeting. The ACRS is inviting members
16 of the public to use the MS Teams link to view slides
17 and other discussion materials during these open
18 sessions.

19 The MS Teams link information was placed
20 on the agenda on the ACRS public website.
21 Periodically the meeting will be open to accept
22 comments from members of the public listening to our
23 meeting.

24 Written comments may be forwarded to Mr.
25 Kent Howard, today's Designated Federal Officer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 A transcript of the presentation portions
2 of the meeting is being kept. And it is requested
3 that speakers identify themselves and speak with
4 sufficient clarity and volume so they can be readily
5 heard.

6 Additionally, participants and members of
7 the public should mute themselves when not speaking,
8 including cell phones, please.

9 During today's meeting the committee will
10 consider the following topics: TerraPower Sodium
11 Topical Reports on Principal Design Criteria, and Fuel
12 and Control Assembly Qualification.

13 And we may get to commission meeting
14 preparations.

15 At this time I'd like to ask other members
16 if they have any opening remarks. Members? No?

17 I'm not hearing or seeing any.

18 And with that, I'm going to turn to Tom
19 Roberts to lead us on in our first topic for today's
20 meeting.

21 Tom.

22 MEMBER ROBERTS: Thank you, Chair
23 Kirchner.

24 Good morning. Today we'll follow up on
25 two nature and topical reports that were reviewed in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the subcommittee meeting on May 15th.

2 I'll lead a discussion on the topical
3 report for the principal design criteria. And my
4 colleague Dave Petti will lead the discussion on the
5 fuel and control assembly qualification topical
6 report.

7 This was a pretty thorough review in
8 subcommittee. Today we will hear a high level
9 overview and then focus on residual questions from
10 that meeting.

11 For the PDC topical report we'll focus on
12 technical justification for the approach's plan for
13 functional containment and the application of the
14 SARRDL, or specified acceptable radionuclide release
15 design limit concepts, since both of these seem to be
16 major departures from past practice for Sodium Gas
17 Reactors.

18 For the fuel qualification topical report
19 we reviewed the major pieces of the qualification
20 report and discussed how to support functional
21 containment and the other safety functions of the
22 design.

23 This morning's schedule allows for part of
24 the meeting to be closed to protect TerraPower
25 proprietary and export controlled information pursuant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to 5 U.S.C. 552(b)(c)(4). If we need to do this,
2 which I don't expect at this time but we'll find out
3 depending on the discussion, we will close the public
4 portion of the meeting and then restart the meeting.

5 I'll now turn it over to Candace de
6 Messieres from the NRC staff for any opening comments
7 she might have.

8 MS. DE MESSIERES: Good morning. And
9 thank you for the opportunity to present today.

10 I am Candace de Messieres, chief of
11 Technical Branch 2 in the Division of Advanced
12 Reactors and Non-Power Production and Utilization
13 Facilities in the Office of Nuclear Reactor
14 Regulation, or NRR.

15 Today representatives from TerraPower and
16 the NRC staff will continue discussions from the May
17 15th ACRS Kairos subcommittee meeting on TerraPower's
18 principal design criteria, or PDC, and fuel and
19 control assembly topical reports.

20 Both of these reports are used in
21 reference in the construction permit application for
22 the Sodium Reactor design for Kemmerer Power Station
23 Unit 1 that was recently accepted for detailed
24 technical review by the NRC staff on May 21st.

25 TerraPower's overall licensing approach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for the Sodium design follows the Licensing
2 Modernization Project, or LMP, methodology. The
3 Kemmerer Power Station Unit 1 construction permit
4 application represents the first implementation of
5 such an approach in licensing.

6 The PDC topical report describes the
7 result of TerraPower's process to develop PDCs for
8 Sodium using Regulatory Guide 1.232, Guidance for
9 Developing Principal Design Criteria for Non-Light
10 Water Reactors. The topical report was submitted in
11 January 2023, was accepted for detailed technical
12 review in March of 2023, and was the subject of an
13 audit from September to October 2023.

14 The NRC staff's draft safety evaluation
15 was issued on April 12th, 2024.

16 During today's presentation you will hear
17 a summary of key design and regulatory features
18 associated with TerraPower's PDC development approach,
19 including context on the use of a functional
20 containment and specified acceptable system
21 radionuclide release design limits, or SARRDLs.

22 The fuel and control assembly
23 qualification topical report provides TerraPower's
24 plan to qualify fuel and control assemblies for the
25 Sodium Reactor design. The topical report identifies

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 acceptance criteria for fuel qualification and
2 presents select fuel qualification results, in
3 addition to ongoing and planned fuel qualification
4 activities.

5 The topical report was submitted in
6 January 2023, was accepted for detailed technical
7 review in March of 2023, and was the subject of an
8 audit from June through August 2023.

9 The NRC staff's draft safety evaluation
10 was issued on March 20th, 2024.

11 Thank you again for your time and
12 consideration. And we look forward to the discussion
13 today.

14 MEMBER ROBERTS: Thank you.

15 George, are you going to start it?

16 MR. WILSON: We greatly appreciate -- I'm
17 George Wilson, Vice President, TerraPower. We greatly
18 appreciate the time of the ACRS to present on our two
19 topical reports for Fuel Qualification and Principal
20 Design Criteria.

21 And with that, I'll turn it over to Ian
22 Gifford.

23 MR. GIFFORD: Thank you very much.

24 My name is Ian Gifford. I'm a licensing
25 manager on the Sodium Project. We'll start today's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discussion with the fuel and control assembly
2 qualification presentation by Dr. James Vollmer. He
3 is participating remotely.

4 James, are you able to hear us?

5 MR. VOLLMER: Yes. I hear you fine.

6 Ready for me to start?

7 MR. GIFFORD: Yes, please.

8 MR. VOLLMER: I think most of you already
9 saw this, so I'll go fairly quickly.

10 MEMBER ROBERTS: Just to clarify, it's
11 fine, our intent was to have TerraPower present and
12 then the staff respond. If you care us to go in a
13 different order and present the fuel qualification
14 first, just -- we'll cover both before we turn it over
15 to staff. Is that right?

16 Okay, thank.

17 MR. VOLLMER: So, I'm James Vollmer from
18 TerraPower. I'll provide a quick overview of the fuel
19 and control assembly qualification topical report.
20 I'll go fairly quickly since I think most of you have
21 seen this before. But feel free to slow me down or
22 stop me if I'm going too fast.

23 Next slide, please.

24 So, this is a brief high level overview of
25 the Sodium Reactor. Some key features we want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 call out.

2 That we are using metallic fuel that has
3 been used historically, especially within the DOE
4 program, for Sodium Fast Reactors.

5 Has very high compatibility between the
6 metallic fuel and sodium. Good retention properties
7 of the metallic fuel matrix to retain fission products
8 within the matrix itself.

9 Good compatibility between the two. If
10 there were to be a breach, large thermal inertia for
11 the large sodium pool within the reactor itself to
12 help promote cooling of the reactor with natural
13 convection.

14 And then we also have an additional air
15 cooling passive system for the old reactor vessel to
16 help maintain coolability of the reactor under all
17 conditions, accident scenarios.

18 Likewise, for the control assemblies they
19 are gravity-driven. But then we also have a motor-
20 driven control rod runback and scram follow feature as
21 well.

22 And just inherently stable core with
23 increased power or temperature.

24 We will rely heavily on our program from
25 the historic U.S. SFR experience, EBR-I, EBR-II, FFTF.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And then we will use, rely on the TREAT tests that
2 were done historically, as well as perform the tests
3 in this reactor.

4 Next slide, please.

5 This is a brief overview on our approach.
6 So, actually, we started our fuel qualification
7 efforts engagement with the NRC in 2019 through a DOE
8 grant, regulatory assistance grant.

9 As part of that, we were relying heavily
10 on NUREG-0800. And interpreted how it applies to
11 Sodium Fast Reactors with metallic fuel. Adapted the
12 requirements specifically to -- well, we're directly
13 applicable to metallic fuel, which are not some that
14 were not identified that were, we though, were needed
15 for metallic fuel systems and Sodium Fast Reactors.
16 So, we call these Regulatory Acceptance Criteria.

17 We did submit three White Papers and
18 received feedback from the NRC as part of this
19 process.

20 Next slide, please.

21 So, given the large amount of pre-
22 engagement we already had and have our test programs
23 aligned with this, that was the overall structure we
24 used with the topical report since NUREG-2246 actually
25 came out fairly late in our process. But we did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 include a section directly mapping between our
2 approach and NUREG-2246 to show that we meet all the
3 assessment framework goals identified, except for the
4 one that was not directly addressed was G2.2.1,
5 radionuclide retention requirements.

6 And that was specifically addressed by
7 separate submittal from TerraPower's Radiological
8 Source Term Methodology Report.

9 Next slide, please.

10 So, just a high level overview of the
11 methodology.

12 So, as I mentioned, we identified the
13 regulatory acceptance criteria. For each one of those
14 acceptance criteria we made sure we have a design
15 criteria and the basis for that.

16 And then we included a fuel system
17 description to make sure we can define the fuel system
18 in enough detail that a regulatory can understand the
19 overall design. And that's the basis of our analyses.

20 The design evaluation includes historic
21 operating experience, testing, as well as methods.

22 And then we also included brief sections
23 on testing and inspection of the fuel as well as an
24 ongoing surveillance program within the reactor plant.

25 Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 A key aspect of it is we did perform PIRT
2 analysis to identify for each individual design
3 criteria. What were the key phenomena that we needed
4 to understand well to ensure that we met the
5 associated limits?

6 So, here are some examples:

7 Thermal creep strain in the cladding is an
8 actual failure criteria that we used. Its purpose is
9 to prevent cladding rupture or coolant flow blockage.

10 And then kind of the key phenomena that
11 influence that criteria:

12 So, the HT9 cladding properties in this
13 particular model. Fuel-cladding chemical interaction,
14 cladding wastage since that thins the cladding wall,
15 and then the fission gas release within the fuel
16 itself because the more the fission gas retained
17 within the fuel matrix and the strain or the stress on
18 the cladding is higher for even more strain.

19 And, likewise, we have the total strain
20 limit that includes the impacts of irradiation and
21 creep swelling on the cladding itself. And, again,
22 that's mainly to preserve coolant channels between the
23 fuel pins.

24 We also have fuel temperature peak fuel
25 cladding or peak cladding temperature, and then an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 overall cladding wastage criteria.

2 Next slide, please.

3 So, here's just an overview of our fuel
4 design.

5 So, the center image is the Type 1 fuel
6 pin cross section. So, the green represents the U 10
7 weight percent zirconium that has been tested
8 extensively within the DOE program.

9 The yellow represents the sodium bond
10 between the fuel and the cladding. That's
11 intentional, to provide space between the fuel and the
12 cladding so the fuel during irradiation can swell
13 outward and get interconnected porosity that promotes
14 release of the fission gas up to the fuel plenum. So,
15 the sodium is simply there to conduct the heat out
16 until the fuel expands outward to touch the cladding.

17 On the right you see an axial cross
18 section of the fuel pin. So, you have an axial shield
19 slug below the fuel slug. And then the sodium bond
20 actually comes up above the fuel column at the
21 beginning of life. And the fuel expands radially and
22 axially with irradiation. And then the sodium will
23 start backfilling within the fuel once that porosity
24 interconnects.

25 MEMBER PETTI: James.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. VOLLMER: Yes?

2 MEMBER PETTI: Just a question.

3 That cross section labeled Type 1, that's
4 not to scale, is it?

5 MR. VOLLMER: Not for actual dimensions.

6 MEMBER PETTI: Right.

7 MR. VOLLMER: But to relative scale it is,
8 yes.

9 MEMBER PETTI: Oh. So, like, the yellow
10 is the sodium is as thick as the cladding?

11 MR. VOLLMER: At the beginning of life,
12 yes.

13 MEMBER PETTI: It is. Okay, good. Thank
14 you.

15 MR. VOLLMER: And then here's the
16 hexagonal --

17 CHAIR KIRCHNER: May I follow up, James?
18 This is Walt Kirchner.

19 MR. VOLLMER: Yep. Go ahead.

20 CHAIR KIRCHNER: Yeah. So, just give us
21 a feeling for the performance. When do you expect
22 nominally the fuel expansion to displace the sodium
23 and make contact and then --

24 MR. VOLLMER: Typically -- Go ahead, sir.

25 CHAIR KIRCHNER: And then just explain a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 little bit further about how the expansion is
2 accommodated as it goes from radial to axial. Could
3 you just talk through the fuel on this?

4 MR. VOLLMER: Yep.

5 Yeah, so, roughly kind of 2 percent burnup
6 is kind of typical where the fuel contacts the
7 cladding. So, that would be within our first
8 irradiation cycle in the reactor. The fuel would
9 expand radially and make contact.

10 And, again, it also expands axially not
11 exactly at the same ratio but close to the same ratio.
12 And as soon as the fuel makes clad -- contact with the
13 cladding its axial expansion slows down and basically
14 stops at that point. So, limited axial expansion past
15 that initial growth point.

16 And it is largely driven to irradiation
17 growth within the metal, which itself involves fission
18 gas -- excuse me, fission gas pressurizing the fuel.
19 And it really is kind of opposite of Light-Water
20 Reactor fuels where the fuel is very soft, the
21 cladding is very hard so the fuel does behave much
22 more like a putty almost, if you will, to some extent.

23 Does that address your question?

24 CHAIR KIRCHNER: Once you make contact
25 then the, then the further expansion is taking up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 axially?

2 MR. VOLLMER: It is. But it's actually
3 pretty limited because by that point you have a full
4 connect network of porosity within the fuel so that
5 the gas is released to the plenum at that point in
6 time. So, your driving force to expand is reduced.
7 So, it doesn't keep growing axially typically beyond
8 that point.

9 CHAIR KIRCHNER: Thank you.

10 MR. VOLLMER: Yep.

11 Next slide.

12 So, these images, again, are attempted to
13 be to scale to each other. So, it kind of shows the
14 EBR-II cross section of the fuel pin. The larger
15 metallic fuel, the MFF fuel assemblies, and FFTF, and
16 then the Natrium Type 1 fuel.

17 And, so you do see the Type 1 is slightly
18 larger than the MFF fuel but it is within what has
19 been tested historically in other metallic fuel test
20 designs.

21 You also see here's a cross section on the
22 right side of height between the different fuel
23 assemblies. You do see that the FFTF fuel column is
24 much taller than the EBR-II. And although the Natrium
25 Type 1 overall fueling fuel column, fuel -- sorry,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 fuel assembly link is much taller, the fuel height is
2 actually almost exactly the same as the FFTF fuel
3 column. And that was intentional that we did not want
4 to extrapolate beyond what was tested for the overall
5 fuel height.

6 Next slide, please.

7 So, from a fuel system design evaluation,
8 we are relying heavily on the historic operating
9 experience because there are no longer any Fast-
10 Operating Reactors in the U.S., plus there is a wealth
11 of historic data that we were able to rely on. So, we
12 have been working for many years with the DOE labs to
13 obtain legacy fuel data as well as qualify it.

14 Not only does this include full fuel pin
15 irradiation tests but also has fuel, and material
16 properties and transient and accident tests that we
17 were able to use.

18 We do have several other test activities
19 in progress or planned, including, so the FFTF fuels
20 are most reflective of our fuel design. Most of those
21 were not looked at after irradiation. So, we have
22 sponsored additional post-irradiation exams to address
23 some of the gaps in the historic database and just
24 demonstrate its performance relative to the EBR-II
25 fuels to get a fuller picture and understanding.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Also, transient testing of fuel pins. So,
2 the TREAT reactor in Idaho was specifically designed
3 for severe accident testing of fuels to test to
4 failure. That has been re-started recently, so we do
5 plan on testing full length irradiated metallic fuel
6 pins from the FFTF reactor, and then also additional
7 furnace tests to just better characterize the
8 transient behavior in severe accidents.

9 We have fuel and absorber property tests,
10 including we created metallic SIMFUEL, so we simulate
11 burnup in the fuels by adding representative fission
12 product species to it.

13 We have a host of HT9 materials tests.

14 And then core assembly and mechanical
15 tests as well.

16 Next slide, please.

17 So, for our materials test programs we
18 actually kicked these off 2011 time frame. Our first
19 step was actually to get HT9 materials. So, we
20 actually worked with multiple suppliers and got three
21 unique heats of HT9 just to characterize the bounds of
22 the specification, as well as understanding the
23 impacts to performance.

24 We actually chose those compositions based
25 on the historic operating experience of the DOE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 materials and looking at those materials.

2 Some of the key gaps we felt from the
3 historic database was expanding the time at
4 temperature for those. We did an extensive thermal
5 aging program up to 50,000 hours just to understand
6 are there any microstructural changes in it just due
7 to time at temperature?

8 And then doing microstructural
9 characterization and mechanical testing on those.

10 Again, we did actually make new heats of
11 HT9 material just because we wanted to verify how it
12 performed relative to historic HT9s. We have side-by-
13 side irradiations of that material with some of the
14 legacy DOE material in the BOR-60 reactor in Russia,
15 and have it irradiated up to about 85 dpa for that.

16 We also have planned irradiation tests on
17 welds and coatings, and some advanced materials. This
18 is on the High FIR Reactor in Oak Ridge National Lab.

19 And then thermal creep testing is another
20 kind of long time at temperature phenomena we were
21 concerned about. So, we have tested up to 70,000
22 hours for thermal creep testing for HT9. And then
23 also have axial tube creep underway and biaxial tube.

24 And really the purpose of these tests is
25 to help us refine our overall response models for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 HT9 behavior.

2 MEMBER PETTI: James, in terms of the
3 radiations in BOR-60.

4 MR. VOLLMER: Yep.

5 MEMBER PETTI: They're complete? Are the
6 samples back in the States yet?

7 MR. VOLLMER: Not yet. We are close to
8 shipping them back. I think they're in the process of
9 packing and queuing them up right now.

10 MEMBER PETTI: Okay. That's good.

11 I remember when it started in the DOE
12 program.

13 MR. VOLLMER: Yeah. Yeah, it's been a bit
14 of a journey to get them back.

15 MEMBER PETTI: A long time coming.

16 MR. VOLLMER: Yes, yes. But we're close.

17 MEMBER PETTI: Good.

18 MR. VOLLMER: Next slide.

19 So, this is just a brief overview of some
20 of our fuel performance tools at TerraPower. So, from
21 a fuel pin performance point of view.

22 So, we have two codes crucible. It's a
23 fast-running code that's actually integrated with our
24 overall core design software, the ARMI software. And
25 it really is aimed at the key phenomena that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 tightly coupled with neutronic responses for, like,
2 the fission gas release, the sodium-bond,
3 infiltration, fuel axial growth.

4 But we also do have some of the fuel
5 performance phenomena like cladding wasting --
6 cladding wastage, clad temperatures, cladding strain.
7 So, as they are iterating the core, they can verify
8 the ARMI where we expect to meet our fuel's design
9 criteria as part of that process.

10 But once they have the overall core
11 designs that they think meets all those goals, then
12 they will give us individual assembly fuel pin
13 histories so that we can perform our detail analysis
14 with our ALCHEMY Package, which is a finite element
15 base method.

16 On the right is an example of a cladding
17 tube where you can see the different finite elements
18 and the actual predicted strains along that fuel pin.

19 Again, it is a high-fidelity model.
20 Captures all the phenomena we think are key for
21 modeling metallic fuel behavior, fission gas release,
22 FCCI, thermal conductivity. But then, in addition to
23 fuel, we are able to adapt models for the boron
24 carbide as well, so we can use the same tool for our
25 absorber predictions as well as our fuel predictions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And then we also have models specifically
2 designed to support our ongoing irradiation tests so
3 we can pre-test predictions ahead of time, run the
4 actual tests, and then analyze the results and
5 compare. So, it helps validate the model in the
6 process as well.

7 Also, the ALCHEMY Package is used as kind
8 of the structural material models for the ATR material
9 that are used at our higher linked scales, in
10 particular OXBOW for our full fuel assembly models and
11 for restraint system. And the materials come from
12 ALCHEMY for those.

13 Next slide, please.

14 So, I mentioned OXBOW. That's our primary
15 core mechanical performance tool. Can do single
16 assembly just to verify kind of the amount of
17 distortion anticipated within a fuel for core
18 assembly. And then prediction, kind of withdrawal and
19 insertion tech loads based on those distortions. But
20 then also from a core-wide, core lockup response as a
21 function of thermal or irradiation behavior, can use
22 the same tool.

23 And then also perform it for seismic
24 analysis as well.

25 We also have a module within OXBOW that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 also do control assembly scram under seismic tech
2 response and assembly drop times, control assembly
3 drop time. And then bundle-duct interactions as well.

4 Next slide, please.

5 We have extensive testing underway for our
6 core assembly response. On the right side this is
7 actually a fixture we use for the mechanical testing.
8 We can actually fit multiple fuel assemblies within
9 that.

10 In the center picture, that's actually
11 within our Bellevue Lab of a pit with that inside of
12 it where full length fuel assemblies can be distorted,
13 put in there, measure the withdrawal insertion loads
14 to pull them in and out.

15 Likewise, we can load multiple assemblies,
16 apply thermal gradients, verify the bending response
17 of them.

18 On the bottom right shows a sample of kind
19 of a bundle compression test just to look at how does
20 the bundle redistribute with loads applied from given
21 bases of the assembly.

22 Have a whole host of kind of single
23 assembly, multiple assembly, and then these bundle-
24 duct type interaction tests as well.

25 And then we also have worked with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 international community to benchmark against historic
2 codes as well as historic databases for operating Fast
3 Reactors.

4 MEMBER PETTI: Then, James, just a
5 question on that.

6 MR. VOLLMER: Yes.

7 MEMBER PETTI: The rest of the world is in
8 oxide space.

9 MR. VOLLMER: Yes.

10 MEMBER PETTI: Is it still valuable? I
11 mean, you've got then the metal system vs. the oxide
12 system?

13 MR. VOLLMER: Yeah, very much so, that the
14 thermal gradients within the fuel assemblies are
15 largely the same and have the exact same radiation
16 effects. And I did see DOE HT9 material, so it was
17 actually an oxide fuel assembly achieved the highest
18 DPA on. So, we've been using that assembly
19 extensively for benchmarking for the dilation and
20 whatnot due to radiation performance.

21 So, it's very relevant overall.

22 MEMBER PETTI: Okay. Thanks.

23 MR. VOLLMER: Yeah.

24 Next slide, please.

25 Kind of really the last piece of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 qualification program is our fuel surveillance
2 program.

3 So, we did actually design Type 1 fuel to
4 be very conservative relative to its historic designs.
5 And believe there is enough margin in lifetime we can
6 connect it to an additional cycle. But we've
7 restrained it to what the historic operating
8 experience was just to verify we are bound by history.

9 But we do have special fuel assemblies, we
10 call them our Lead Demonstration Assemblies, that do
11 have pins that we can remove in these, the X fuel
12 handling to pull them out for expedite post-
13 irradiation exams. So, that way we can constantly
14 monitor performance throughout lives.

15 So, after each cycle be able to pull pins
16 out, do visual exams on them, measure them, send them
17 off for extensive post-irradiation exams or structural
18 exams just to make sure that the fuel is behaving as
19 predicted based on the historic operating experience.

20 We will be targeting a subset of them to
21 actually have accelerated burnup so we'll actually
22 maximize the enrichment of those pins so that they are
23 dating the rest of the core as far as burnup.

24 And then also trying to target bounding
25 conditions for some of them as well just to verify

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that we are bounding the entire performance of the
2 reactor.

3 Next slide, please.

4 Yeah, I think that's it for me. So, any
5 questions?

6 MEMBER ROBERTS: Yes, a question.

7 If you can go back to slide 6. This slide
8 is a, it's how the PIRT Evaluation Identifies Fuel
9 Phenomena.

10 MR. VOLLMER: Yes.

11 MEMBER ROBERTS: And it appears to be a
12 list of design limits --

13 MR. VOLLMER: Yes.

14 MEMBER ROBERTS: -- on the fuel.

15 MR. VOLLMER: Yes.

16 MEMBER ROBERTS: Such that when you do the
17 analysis, either safety analysis or steady state, you
18 would go verify those five limits are met. Is that
19 right?

20 MR. VOLLMER: Correct. Correct.

21 MEMBER ROBERTS: So, that sounds like you
22 would transition to the PD2. It sounds like a SAFDL.

23 MR. VOLLMER: That's correct.

24 MEMBER ROBERTS: Just wanted to understand
25 what the difference was. If you intended to meet all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 these five limits and then call that a SARRDL, I'm
2 just trying to understand what the, what the overall
3 intent is.

4 Because it sounds like your intent is for
5 the design to meet these five limits.

6 MR. VOLLMER: That's we do design to them
7 and then what happens then goes off to SARRDL space.
8 So, that's where we have our damage criteria. That
9 would be basically to say that's when the fuel's
10 reached its effective lifetime. So, if you go through
11 an AOO, and then beyond that we can see the fuel
12 damage, you would not reuse the fuel past that point.

13 But then we do have failure criteria. So,
14 if you did exceed that, we would say the fuel has been
15 failed. And then that would go over to SARRDL space
16 for them to propagate what's the impact of that
17 failure.

18 MEMBER ROBERTS: So, for normal operation
19 AOOs, which is what the JDC or PDC states, you would
20 expect to have a zero release by having met these five
21 criteria? Is that what would be here?

22 MR. VOLLMER: Exactly.

23 MEMBER ROBERTS: Okay.

24 MR. VOLLMER: Exactly, yep.

25 MEMBER ROBERTS: And then for more severe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 events you would simply calculate the amount of
2 damage. That's not a SARRDL, right, that's a design
3 basis calculation of what the consequence is; is that
4 right?

5 MR. VOLLMER: So, I think both. We
6 basically calculate how many fuel pins are potentially
7 failed. And then it would go on the SARRDL space to
8 understand what would be the dose potentially released
9 from that.

10 MEMBER ROBERTS: Right. Release in a
11 containment and then the whole, you know, down in
12 those type conditions.

13 Okay, thanks.

14 MR. VOLLMER: Any others?

15 MEMBER PETTI: So, just to make sure I'm
16 clear. Then you really have both SAFDLs and SARRDLs,
17 depending on the space of the, of the accident domain,
18 if you will.

19 MR. WILSON: This is George Wilson from
20 TerraPower.

21 We'll discuss this more in the PDCs. So,
22 if you'll wait till we get to the PDCs --

23 MEMBER PETTI: Perfect.

24 MR. WILSON: -- and ask additional
25 questions we'll go into a little more detail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: I have another. I have a
2 question on the surveillance stuff, which I think was
3 really good.

4 How often do you anticipate pulling the
5 pin out of that test assembly?

6 MR. VOLLMER: For the initial cycle --

7 MEMBER PETTI: Right.

8 MR. VOLLMER: -- through the entire fuel
9 lifetime, every cycle we'll be pulling a subset of
10 pins out. And I guess just to clarify, we're not
11 putting the fuel assembly back in after we pull it
12 out.

13 MEMBER PETTI: Back in, right. I figured
14 that, not replacing it.

15 MR. VOLLMER: Yes.

16 MEMBER PETTI: But do you have to put
17 something back in the core, though? Just, or there
18 would just be a hole?

19 MR. VOLLMER: Well, just replace it with
20 a fresh fuel assembly.

21 MEMBER PETTI: Oh, you put it back.
22 Right. Got you.

23 Okay. Thanks.

24 MR. VOLLMER: Yep.

25 CHAIR KIRCHNER: Jim, just on that topic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Will those be wire wrapped or they'll be kind of a
2 straight pin? How do you compensate for the non-
3 prototypicality that you get out of those?

4 Is there any issues that you are seeing of
5 not, not having that pin that you removed wire
6 wrapped?

7 MR. VOLLMER: They will still have the
8 neighbors will have wire wraps. So, they will still
9 have the support. It will be a small perturbation.
10 And we are doing thermal hydraulics testing just to
11 verify what it is. But we do anticipate it would be
12 a fairly small difference on it.

13 If anything, they'll likely have a little
14 more propensity to move. So, a little more spreading
15 type interaction.

16 CHAIR KIRCHNER: Right.

17 MR. VOLLMER: But, again, we expect it to
18 be very small, just that the bundle is so tight that
19 there really is not much room for movement.

20 Yeah, we're doing harmonic testing to
21 verify that.

22 CHAIR KIRCHNER: Okay, thank you.

23 MR. VOLLMER: Yep.

24 MEMBER PETTI: Just another question comes
25 to mind.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 What irradiation testing of the welds, --

2 MR. VOLLMER: Yes.

3 MEMBER PETTI: -- coatings, and like,
4 you're not going to get the DPA. Is there some
5 historic data so that you can kind of make
6 correlations based on, you know, this stuff looks as
7 good as the old stuff, so we can use the old, the old
8 stuff?

9 MR. VOLLMER: Yeah. We do. There's a lot
10 of kind of TIG welding I think historically was
11 primarily used. We are wanting to use a different
12 welding process. But it should have a smaller heat-
13 affected zone and whatnot.

14 But also, the welds typically are out of
15 the high flux area.

16 MEMBER PETTI: True. Yeah, right.

17 MR. VOLLMER: They don't receive much of
18 the dose as well.

19 MEMBER PETTI: What sort of dose are you
20 going to get?

21 MR. VOLLMER: For the welds?

22 MEMBER PETTI: Yes.

23 MR. VOLLMER: For most of them it will be,
24 I think, less than 5 gpa, as I recall.

25 MEMBER PETTI: That's my guess. That is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 what I guessed. Okay.

2 MR. VOLLMER: The control assemblies, that
3 is the one where it will actually be in the higher
4 flux region of the core. So, that was kind of the
5 area we want to make sure we do a bound aspect of it.

6 CHAIR KIRCHNER: Jim, what do you think --
7 this is Walt again -- what do you think of your list
8 of parameters you're testing for, what do you feel is
9 the kind of the limit for your, you know, your fuel
10 design for this, for this application?

11 MR. VOLLMER: So, FCCI is kind of the
12 most, like, limiting in our experience, continues kind
13 of the hot channel factors. So, that's why we spent
14 the most effort for our post-irradiation exams we are
15 doing on the FFTF pin, but specifically looking at the
16 FCCI response which we think that is, again, likely to
17 limit.

18 Because the DOE fuels were high enriched,
19 so they would be higher linear power since they're
20 lifetime faster. So, kind of the time at temperature
21 combination. So, that's really what we want to make
22 sure we understand that phenomenon well.

23 CHAIR KIRCHNER: Thank you.

24 MR. VOLLMER: Yep.

25 MEMBER PETTI: Just one more since you've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 got such a wealth of knowledge.

2 All of the out of trial thermist tests
3 that I remember reading the report that gives you the
4 rate of attack, if you will, in that plot I can
5 remember, does the in-pile stuff agree generally well
6 with the out-of-pile there, I mean given all the
7 uncertainties?

8 MR. VOLLMER: For the FCCI, the historic
9 models found no effect of irradiation. We've actually
10 for our SIMFUEL stuff we found the out-of-pile to be
11 more aggressive than the in-pile, but we believe
12 that's just because we haven't been able to recreate
13 the mixture of the fuel products quite like was the
14 actual irradiated fuel itself.

15 MEMBER PETTI: So, it's going to serve it?

16 MR. VOLLMER: Right.

17 MEMBER PETTI: I mean, there are examples
18 in LWR space where they tried to make fuel, simulated
19 fuel, and it was found to be grossly over-conservative
20 than --

21 MR. VOLLMER: Yes.

22 MEMBER PETTI: -- what you see in-pile.
23 But, you know, that took two years to get there. And
24 look back and that was a really dumb idea, you know.
25 You understand why we do it, because it's easier. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you run that risk.

2 Okay, good.

3 MR. VOLLMER: Yeah, we're relying strictly
4 on the in-pile data for our FCCI correlation. The
5 out-of-pile is more to try to understand
6 mechanistically if we can refine the model, or just to
7 give us more insight into how to model the data.

8 So, yeah, we kind of gave up on using it
9 from a purely mechanistic under pure correlation.
10 Just want to do more just a qualitative insight of the
11 behavior from our out-of-pile tests.

12 It's time for me to turn it over to Ian.

13 MR. GIFFORD: Thank you, Jim.

14 So, I'll provide a brief overview of the
15 methodology that was used to develop the principal
16 design criteria for the Sodium Advanced Reactor. And
17 then I'll turn it over to Eric Williams, who is our
18 senior vice president and design authority, for a
19 focused discussion on SARRDL and functional
20 containment.

21 The approach to PDC development was
22 discussed with NRC staff during public meetings in
23 December of 2021, and November of 2022. And the PDC
24 topical report was submitted in January of 2023.

25 In accordance with 10 C.F.R. 50.34,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Principal Design Criteria were also included in the
2 construction permit application, Section 5.3.

3 Regulatory Guide 1.332 provides guidance
4 for Non-Light Water Reactors to develop principal
5 design criteria for Non-Light Water Reactor design.
6 The Reg Guide acknowledges that different requirements
7 may need to be adapted for Non-Light Water Reactor
8 designs, and that the PDC in 10 C.F.R. Part 50,
9 Appendix A, are you regulatory requirements for Non-
10 Light Water Reactor designs, but they provide
11 guidance in establishing the PDC for Non-Light Water
12 Reactor designs.

13 Ultimately, it's the responsibility of the
14 applicant to development PDC for its facility based on
15 the specifics of its unique design.

16 Applicants are allowed to use the Reg
17 Guide to develop all or part of the principal design
18 criteria, and are free to choose amongst the Advanced
19 Reactor design criteria, Sodium-Cooled Fast Reactor
20 design criteria, or Modular High Temperature Gas
21 Reactor design criteria to develop each piece.

22 PDC were developed starting with the
23 SFRDC. And in Appendix D of Reg Guide 1.232, first
24 discussion was whether the PDC applied. And if it did
25 it was assessed for whether it could be adopted as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 written.

2 If it could be adopted as written, it was
3 accepted as an initial Natrium PDC.

4 If it was needed to be modified, we first
5 reviewed the ARDCs and the MHARDCs for language that
6 may be more applicable to our design. And we also
7 left open the option that we may in fact have to draft
8 new PDCs for Natrium.

9 I want to focus a little bit on the box
10 here. So, we have the initial Natrium PDC list and
11 then the box that says "perform the iterative LMP
12 process."

13 So, the LMP is an iterative process
14 throughout the design phase. NEI 18-04, states that
15 Reg Guide 1.232 should be used as an input by
16 designers to initially establish principal design
17 criteria for the facility based on the specifics of
18 the design

19 And then, as part of the LMP process, PRA
20 safety functions are identified that are necessary and
21 sufficient to meet the frequency consonance target for
22 all design basis events and high consequence beyond
23 design basis events to conservatively ensure that 10
24 C.F.R. 50.34 dose requirements can be met.

25 The PRA safety func -- these PRA safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 functions are then defined as required safety
2 functions, or RSFs. RSFs are used to develop required
3 functional design criteria, RFDCs, that establish
4 reactor-specific functional criteria that are
5 necessary and sufficient to meet the required safety
6 functions.

7 NEI 18-04 states that the required
8 functional design criteria, RFDCs, are defined to
9 capture design-specific criteria that may be used to
10 supplement or modify the applicable GDCs or ARDC in
11 the formulation of principal design criteria.

12 The Sodium Project has undergone a
13 complete iteration of LMP to include a thorough review
14 by the Integrated Decision Making Process Panel. In
15 accordance with NEI 18-04, the Sodium LMP Design
16 Criteria Report includes a complete mapping of LMP
17 evaluated functions.

18 RFDCs developed from the LMP are all
19 mapped to at least one principal design criteria,
20 demonstrates that the PDCs are complete with the
21 current Sodium design. No RFDCs were found that
22 would require a new or expanded principal design
23 criteria.

24 As we progress the design and continue
25 with LMP, the completeness of the PDC will continually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 be revisited. Significant changes to the principal
2 design criteria are not expected, but should they be
3 needed it would be appropriately communicated to the
4 NRC.

5 MEMBER MARCH-LEUBA: This is Jose.

6 Let me emphasize what you just said I'm
7 100 percent I'm in agreement with. But when during
8 that slide it says we are starting with a set of
9 design concepts, and then we remove the ones that
10 don't apply.

11 We need to see is there something special
12 with my system that requires a new one. The thing
13 that comes to mind is now they're available to us
14 through the source.

15 So, I'd like it that you're seeking that
16 one.

17 MR. GIFFORD: Appreciate the comment.
18 Thank you.

19 MEMBER PETTI: So, then it's fair to say
20 that the PDC Report that we're reviewing represents
21 the final PDCs in the bottom box or the initial PDCs?
22 Or are they the same based on where you are?

23 MR. GIFFORD: They are the same based on
24 where we are.

25 MEMBER PETTI: Great.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: I have a similar
2 question, is the topical report doesn't have those
3 bottom two boxes. And there is a limitation in
4 condition in the safety evaluation that does tie to
5 that a little bit. It says that the NRC acceptance is
6 based on an understanding you are using LMP process,
7 so that pretty well drives what you just said.

8 Is there an intent to change the topical
9 report or is the reference from the SCR considered to
10 be sufficient to ensure that a future user does what
11 you just said and not what the topical report says?

12 Let me pull this up. It has this figure
13 without those bottom two boxes. And there's no
14 discussion, at least that I recall, in the report
15 itself of that LMP iteration.

16 I believe I think it's very important.
17 And it sounds that you do, too. So, it's just a
18 matter of making sure whoever uses the topical report
19 understands what you just said.

20 MR. GIFFORD: Yes. The intention would be
21 whoever uses this topical report would be using NEI
22 18-04. And so, following 18-04 would require that an
23 applicant would go through those iterative steps.

24 I think the intention of the figure in the
25 topical report is to show how the PDC were developed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 at the time that the topical report was submitted in
2 January 2023. And then we have subsequently followed
3 the LMP process and moved that into the construction
4 permit application.

5 MEMBER ROBERTS: Okay, thanks.

6 MR. GIFFORD: At this time I will turn it
7 over to Eric Williams for a discussion on SARRDLs and
8 functional containment.

9 MR. WILLIAMS: All right, thank you.

10 So, my name is Eric Williams, Senior Vice
11 President and Design Authority, TerraPower.

12 I was, you know, reflecting on the
13 questions that were asked in the last meeting and
14 trying to, you know, come up with the best approach to
15 try and get some clarity behind these issues. And,
16 you know, coming at it from the design perspective I
17 first just wanted to mention a couple of the new
18 things that TerraPower is doing in the design of
19 Sodium I think are incorporating a lot of this new
20 material on SARRDLs and functional containment.

21 So, you know, using the LMP approach is
22 the first thing, you know, that's sort of new here,
23 following the risk-informed performance-based
24 approach. And then the use of something like a SARRDL
25 becomes really integrated closely with that approach.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so, talking about them in separate conversations
2 becomes really hard.

3 We're also following a systems engineering
4 approach to design. So that means that we're trying
5 to rigorously set functional design requirements at
6 the beginning, including safety requirements that all
7 of these things factor into so that the designers can
8 have clear requirements as they go through their
9 iterations and know that they're meeting an acceptable
10 design.

11 And then, finally, we're using the IAEA
12 framework that calls out defense line functions where
13 it allows us to look at design requirements in each of
14 those defense lines, so that as the designer is moving
15 through their work they can also be evaluating
16 defense-in-depth adequacy as well.

17 And then, of course, through the
18 Integrated Decision Making Process Panel that's part
19 of LMP, we get a chance as a group to review that
20 defense-in-depth and how we're meeting the frequency
21 consequence limits with margin in the design.

22 So, what you get out of that is a really
23 great integrated set of design and safety
24 requirements. But it also means that these things are
25 hard to pull apart from each other.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, that's kind of the framework that
2 we're applying. And so, I'll start by talking about
3 SARRDLs first and then that will roll into functional
4 containment. And they're really closely connected.

5 So, we've already talked a little bit
6 about SARRDLs.

7 So, what is a SARRDL? First thing we do
8 is we look at all the systems and components that are
9 containing radionuclide inventory in the plant.
10 Sometimes storing it, sometimes circulating it during
11 operation. And we're trying to set clear limits on
12 potential releases for that circulating radionuclide
13 inventory during normal operations or AOOs.

14 So, we look at each one of those
15 radionuclide-containing systems. And if it has the
16 potential to violate a release limit, then it gets a
17 SARRDL. And that SARRDL is usually in the form of a
18 volumetric leakage rate that can happen from that
19 system.

20 And so what it allows us to do is set a
21 clear design requirement on those SSCs that get the
22 SARRDLs so the designers can use those in design and
23 know that they're meeting the requirements.

24 It's also very convenient to establish
25 design -- or analysis assumptions. So, when you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 looking for the worst case initial condition to
2 initiate, say, a DBA analysis, you can initiate it
3 assuming that you're at the SARRDL limit in that
4 system.

5 So, that's a convenient way. And it makes
6 me think back to Light Water Reactors that may assume
7 you're at your worst case tech spec limit of primary
8 system activity when you initiate an accident. So,
9 that's a really convenient way to do it.

10 And then, in the end those SARRDLs get
11 incorporated into the frequency consequence curves
12 that you see with LMP that ultimately show with
13 specific PRA datapoints showing up on the F-C curve
14 with uncertainties identified that shows that you have
15 margin to the F-C curve limits.

16 And that ultimately is a practical way to
17 demonstrate the PDC 10 compliance where the SARRDLs
18 are mentioned.

19 So, that's how the SARRDLs are used. And,
20 you know, the SECY paper 18-0096 talks about how those
21 are closely linked with functional containment because
22 they express the limits at a performance criteria for
23 functional containment for the AOOs.

24 So, we can talk a little bit more about
25 functional containment now. And I wanted to kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 start with a couple of the design features because I
2 know one of the questions was really talking about the
3 rationale --

4 MEMBER ROBERTS: Excuse me, Eric.

5 MR. WILLIAMS: Oh, sure.

6 MEMBER ROBERTS: GDC 10, just to
7 understand how that works with the SARRDL concept.

8 What we heard in the previous presentation
9 is the fuel limits are going to be tracked as design
10 limits. So, essentially you have no release from fuel
11 during normal operation or AOOs. But then you said
12 that the SARRDLs become other circulating activity and
13 other radiation-containing systems, --

14 MR. WILLIAMS: Yes.

15 MEMBER ROBERTS: -- not the fuel.

16 MR. WILLIAMS: Uh-huh.

17 MEMBER ROBERTS: That seems like a
18 different interpretation of that PDC -- or GDC. The
19 purpose of that GDC seems to be that you not have any
20 challenge to radionuclide release from AOOs or normal
21 operation by keeping all the circulating activity
22 within the fuel.

23 Sounds like you're doing exactly that.
24 But then you've added, because of, I guess, the LMP
25 and the need to have a downwind dose reduced in normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 operations and AOs, expanding what GDC 10 is, PDC 10
2 currently says to include circulating activity. Is
3 that the right interpretation?

4 MR. WILLIAMS: Let me try and think about
5 that.

6 MEMBER ROBERTS: Because it seems like the
7 intent of that PDC is to not have release from fuel
8 during normal operation or AOs.

9 MR. WILLIAMS: It's really to not have any
10 releases that violate the 10 C.F.R. 20 limits that are
11 imposed on normal operation and AOs by establishing
12 clear requirements for all the radionuclide-containing
13 systems.

14 If we meet the fuel design limits
15 perfectly, then there won't be any from the primary
16 system.

17 There can also be, you know, radionuclide
18 inventories within systems like sodium processing
19 systems, sodium cover gas from some prior failed fuel
20 that occurred, you know, even just randomly. So, you
21 have to look at those.

22 You have refueling systems that have to be
23 looked at, too, because they contain fuel at times.

24 And so, the SARRDLs look at all of those
25 systems and incorporate these limits, not just in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 primary system.

2 But we do use the design limits, as James
3 was pointing out. We look at those in terms of the
4 mechanistic source term methodology. So, it would
5 determine the failed fuel fractions that would get
6 incorporated into mechanistic source term.

7 But the real intent of the SARRDL is to
8 capture what is really the phenomena that is really
9 important for a Sodium Fast Reactor. Since there's
10 not a direct, as direct coupling from fuel fraction,
11 fuel failure fraction to radionuclide release, because
12 we have all these extra systems that act to, you know,
13 attenuate radionuclide release, we have to incorporate
14 all of that. And the SARRDL does that.

15 And so, it's really a better metric of
16 what is happening in a Sodium Fast Reactor. And
17 that's kind of the intent of this is to address it
18 directly on what's happening.

19 But we're still using the fuel design
20 limits, like you said, as part of the mechanistic
21 source term process.

22 MEMBER MARTIN: Eric, this is Member
23 Martin.

24 You know, what you describe doesn't sound
25 any really different than what we've always done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 It's always been a kind of analytical defense-in-
2 depth. You know, the ultimate metric is the SARRDL;
3 right? We're interested in doses and its comparison
4 to 10 C.F.R. 100.

5 That's backstop. In fact we can
6 demonstrate the SAFDLs. We have high confidence on
7 dose. And then those SAFDLs are backed up by tests.
8 We've always done it that way.

9 I guess I'm not seeing something new here,
10 except for maybe a documentation emphasis in SARRDLs.
11 And maybe, and that's consistent with LMP, no doubt.
12 But in practice, which I think makes LMP practical, is
13 that it's not a big departure from what we do.
14 Obviously, LMP brings in a lot of the risk aspects.

15 And so, it's another way of defending any
16 kind of engineering judgment, you know.

17 MR. WILLIAMS: Yeah.

18 MEMBER MARTIN: But I'm not really seeing
19 anything new here.

20 MR. WILLIAMS: Yeah.

21 I don't think of it as that new, other
22 it's more integrated because in the LMP approach
23 you're going to see all of the results together in
24 this frequency consequence curve. And the SARRDLs are
25 consistent with the way DBAs are also looked at, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 DBEs are looked at.

2 So, it all forms this, like, self-
3 consistent way of talking about the narrative of
4 safety and showing the margin that we have in design
5 safety. And it retains a significant amount of
6 margin, too, and it shows you where that margin is.
7 Right?

8 It's not new but it's a new way of talking
9 about it. Hence, the reason for this.

10 MEMBER MARTIN: All right. It sounds like
11 the key is the predicate of the SARRDL is to meet the
12 fuel limits. And so, that gets you basically
13 unchanged from existing Sodium Fast Reactors or even
14 Light-Water Reactors. And by whatever technology,
15 high temperature gas we had to do it a little
16 different.

17 MEMBER PETTI: Yeah. I think that's in my
18 mind the difference because there are no SARRDLs
19 because it's difficult in that system to take because
20 it's not a clad, pin and clad system.

21 So, basically, you know, even though the
22 SARRDL is there and it's to demonstrate margin against
23 top 20, there's even more margin when one looks at the
24 design limits that you have that you're going to say
25 zero.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. WILLIAMS: Uh-huh.

2 MEMBER PETTI: Or some very low number

3 But we're going to analyze it up here with
4 SARRDLs and it will be higher, there's even more
5 numbers.

6 MR. WILLIAMS: Right. Exactly.

7 MEMBER PETTI: And once you get beyond AOO
8 space and it's a, it's a calculation based on fuel
9 performance leading to the larger source term, if you
10 will.

11 MR. WILLIAMS: Right.

12 MEMBER PETTI: Okay.

13 MR. WILLIAMS: Yep.

14 MEMBER ROBERTS: Is that different than
15 other reactor types? That sounds like the same thing
16 with Light-Water Reactors as when you get into, say,
17 LOCA space you've got to go calculate what their
18 relief fractions are or bound it conservatively.

19 It sounds are you doing anything different
20 there?

21 MR. WILLIAMS: I think, I think the
22 difference is in there you're going to have a lot of
23 additional features coming into play through the
24 mechanistic source term analysis than a traditional
25 Light-Water Reactor would have. I think more recent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Light-Water Reactor applications have looked at, you
2 know, fission product deposition and containment,
3 crediting additional things like that.

4 We're doing something like that, plus a
5 lot more because of the Sodium Fast Reactor features
6 and the lack of the pressurized system.

7 MEMBER PETTI: I think if you went back
8 in, you know, in the olden days, you know, with the
9 TID source term, that was just sort of an analysis.
10 But the 1.183 that we just looked at really is a
11 culmination of LWR source term that has more
12 mechanistic stuff behind it.

13 MR. WILLIAMS: Right.

14 MEMBER PETTI: But the reactivity events
15 do this, the LOCAs do this, and it was a way to
16 capture all of that. So, you're basically kind of
17 doing the same thing with the SARRDLs, the technology
18 is the same.

19 MR. WILLIAMS: Yeah, yeah.

20 MEMBER ROBERTS: Right. More mechanistic.
21 And just taking the worst of all accidents and finding
22 them.

23 MEMBER PETTI: Right.

24 MEMBER ROBERTS: But, fundamentally it's,
25 it's you go run your analysis, figure out what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 release is because you violated the fuel limits
2 because of the nature of the accident. And then you
3 figure out what that is and you proceed with a
4 calculation.

5 MR. WILLIAMS: Yeah. We are still
6 demonstrating that we need the functional containment
7 performance criteria with an assumed major accident.
8 So, we are still doing that even though it's probably
9 in the -- beyond the cutoff frequency in the PRA.

10 So, we are still taking that step. But we
11 are crediting all of the design features that we have
12 that are technology specific.

13 MEMBER ROBERTS: Sure. And that's
14 consistent with Sodium Fast Reactors in the past;
15 right? They looked at the protected loss of flow, and
16 your protected transient input powers, and those are
17 probably extremely low in frequency space.

18 MR. WILLIAMS: Right.

19 MEMBER ROBERTS: I'm sorry. I guess
20 you'll get to that, your plan is to look at
21 unprotected?

22 MR. WILLIAMS: Yes.

23 MEMBER ROBERTS: Okay, great. Thanks.

24 MR. WILLIAMS: Yes. Yeah.

25 MEMBER MARTIN: So, Eric, when you mention

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that, you know, your analysis shows you this large
2 margin but with the, you know, mechanistic solution,
3 of course we've not seen that. Right?

4 MR. WILLIAMS: Right.

5 MEMBER MARTIN: And I'm not sure where it
6 is in submittal and review space. You know, we can
7 only judge on what we've seen; right?

8 And traditionally DBCs have reason to fall
9 back on. But the idea is that it comes first and, you
10 know, and justification comes later, typically.

11 Now, in contrast, like the HTGR, you know,
12 they had the advantage of all the, all the testing
13 that was done at Idaho and kind of coincident with the
14 writing of the Reg Guide. Of course, there was a, you
15 know, fair amount of knowledge about how well TRISA
16 performed. And that insight kind of fed the writing
17 of that, of the Reg Guides. I'm tracking it a little
18 bit.

19 But, you know, in other conversations I've
20 had my understanding is that it influenced how, how
21 that was written. With the SFRs you don't have enough
22 read out there doing all this wonderful work for you.
23 You don't have that kind of in the, in the, you know,
24 public domain or, you know, working through it or see.
25 It's all just to say justification hasn't come to us,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and so it makes it very difficult for us to depart
2 from what the Reg Guide says.

3 You know, and that was kind of the
4 criticism that came up during the subcommittee. So,
5 that's our, our perspective.

6 MR. WILLIAMS: We have some -- I mean,
7 I'll point you to the Argonne National Lab did a trial
8 mechanistic source term project in the ANL-ART series
9 of documents. RT-3 is essentially a PIRT on
10 mechanistic source term for Sodium Fast Reactor with
11 metal fuel.

12 TerraPower participated with them in that,
13 as well as other, other vendors. And we're heavily
14 leveraging that work.

15 In fact, it talks a lot about the
16 fundamental safety of metal fuel under, you know, a
17 sub-cooled pool of sodium, and how it behaves, and the
18 retention of fission products within the fuel matrix,
19 the retention of fission products in the liquid
20 sodium, and how all of that behaves. And adds a
21 tremendous level of margin to safety.

22 And so, that's something in the public
23 domain that I think is really good background to read.
24 And then I think all of this will come together in the
25 mechanistic source term topical report. So, that I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 think is coming up, so, can have a lot more discussion
2 about that.

3 MEMBER MARTIN: I think you might get a
4 different response if that came first.

5 MR. WILLIAMS: Yeah.

6 MEMBER MARTIN: Right? And it goes
7 through the process, the sausage-making.

8 MR. WILLIAMS: Yeah.

9 MEMBER MARTIN: But in contrast, you
10 brought this first. And so, it looks like the Reg
11 Guide strictly applies without any further
12 justification.

13 MR. WILLIAMS: Yeah. I can appreciate
14 that.

15 MEMBER PETTI: I said it in subcommittee,
16 you're not the first where because things are done
17 sequentially, we're trying to see the whole elephant
18 and all we see is a piece.

19 With other applicants, it wasn't until we
20 got to the PSAR, where there's numbers in there and I
21 went, oh. And the lightbulb goes off because you can
22 finally see all the pieces come together.

23 And it's like, God, I ask all these stupid
24 questions. I wish I knew this number when we started.
25 It'd be more efficient in the overall process.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 When we did this in NGMP, we asked a
2 source to -- it was a white paper at the time -- and
3 the fuel quality be done together, for exactly this
4 chicken-and-egg problem, when you're dealing with new
5 technology that's about a different education by --
6 it's just inherent in the new technology, I think.

7 MR. WILLIAMS: Yeah, these things used to
8 be historically very separate conversations you could
9 have. They were disjointed. And now, they're coming
10 together with LMP, which is a benefit. But we have to
11 have these integrated discussions a little bit better
12 now.

13 All right, I'll talk a little bit about --

14 MEMBER ROBERTS: Probably leads to what
15 you're about to say. One big-picture question comes
16 up with the Reg Guide at 1.232 and the fifteen-
17 containment criteria, that resulted from decades of
18 progression -- if you look back at history, I'm sure
19 you're versed in all of this -- but going back in time
20 to S-PRISM, PRISM, IFR, go back, and all the different
21 developments in studying past reactors, there was a
22 1993 proposal to ease up on some of the requirements,
23 and you could argue that the results of that led to a
24 risk-informed, performance-based, set of containment
25 criteria for an SFR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And that's all got codified in Reg
2 Guide 1.232. So, it's kind of hard to see the case
3 for diversion from that given all the history, and the
4 fact that your client looks a lot like PRISM.

5 So, the accumulated judgment of all those
6 different generations of designers, led to those
7 criteria. So, maybe you can lead into your discussion
8 here with that as the starting point, is that when you
9 make what might be radical changes -- and that's my
10 question would be, are they really radical changes,
11 because I'm not quite sure they are -- but what appear
12 to be radical changes, then the justification overall
13 for what's different now, than what was in the
14 previous designers' minds, all those generations of
15 SFR developments, is kind of a question.

16 The second question is are you really
17 being different, because there are aspects of your
18 design that look a lot like the containment approach
19 for PRISM.

20 And so, it seems like you're actually
21 including the structures that PRISM had to meet their
22 containment objectives. And so, if that's the case,
23 then what's the implication of changing the criteria?

24 MR. WILLIAMS: Okay. Yeah, that's a great
25 segue. I was going to talk through some of the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 features that are different. There's essentially five
2 areas that I wanted to bring up and just talk through
3 a little bit.

4 And some of these are radical departures
5 from historical sodium-fast reactor designs. I'll try
6 and highlight those in particular.

7 But first of all, this is not a departure.
8 But just the use of sodium coolant, of course, is just
9 a huge benefit in terms of having a low-pressure
10 system that doesn't have the forcing function for
11 radionuclide releases through the functional
12 containment, the maintenance of highly sub-cooled
13 sodium within the reactor vessel to retain fission
14 products -- also very important, so that's a part of
15 all sodium-fast reactors.

16 The fact that it's a full metal-fueled
17 core is also a departure. I think we are the first
18 fully metal-fueled core. So, that takes away a couple
19 of things that were being looked at from the
20 hypothetical standpoint, that involved core
21 disruption-type accidents.

22 So, oxide fuel behaves very differently in
23 severe accident space than metal fuel. And of course,
24 having an integrated reactor vessel with a large pool
25 of sodium also makes the bulk boiling of the sodium an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 incredible event.

2 So, that, the maintenance of a highly
3 coolable geometry for metal fuel, that's one of the
4 departures.

5 The metal fuel also retains the fission
6 products in fuel matrix -- certain categories of the
7 fission produces, I should say.

8 And then having a pool reactor is another
9 big one. Because it drastically reduces the amount of
10 sodium piping that you have for the potential of
11 sodium fire.

12 So, keeping all of the primary system
13 piping inside the integrated reactor vessel, you've
14 removed the fundamental hazard, which is the best
15 thing you can do.

16 Then, what you're left with is the sodium
17 processing system, which is small-bore piping that is
18 contained within the functional containment boundary.
19 And I'll explain in a little bit how we address sodium
20 fires in a different way there too.

21 Because the bulk boiling is not a credible
22 event, what we are looking at is the potential of gas
23 bubbles in the fuel channel from fission product
24 release from a failed fuel pin. So, we have to look
25 at that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We're looking at potential entrainment of
2 cover gas as a way to get bubbles into the core. I
3 think that's highly unlikely to happen in such a large
4 pool reactor, but we are addressing that as well.

5 And when we look at that in our analysis,
6 we really don't see anything that would propagate fuel
7 pin failures within the assembly.

8 So, when you have a fission gas bubble
9 going up through the channel, the temperature of the
10 neighboring fuel pins barely increases. So, that is
11 looking to be a really good analysis.

12 So, we're not seeing any way for voids to
13 cause a large energetic release. So, that's all
14 coming from the fact that there's a pool reactor here.

15 And then one of the really big departures
16 is that there's no longer a sodium water steam
17 generator. So, that was one of the huge sources of
18 energetic release that pressure-retaining containments
19 had to address.

20 And so, by having molten salt energy
21 storage and having an intermediate sodium system,
22 we've eliminated that hazard from the design. So,
23 that's a key one.

24 We're also excluding any kind of water
25 suppression systems from inside the functional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 containment, and being very careful not to introduce
2 water even in that space. So, addressing it there.

3 And then in terms of sodium fires, a lot
4 of other designs have used what appears to be similar
5 design features -- guard pipes, and things like that,
6 around sodium pipes -- but we have addressed that
7 entirely for the functional containment space, by
8 having a secondary barrier around all sodium piping
9 within the functional containment barrier, even the
10 intermediate sodium piping that's in that space above
11 the reactor. So, we're addressing that.

12 And then we have the guard vessel that
13 surrounds the reactor vessel. So, even an unlikely
14 leak from the reactor vessel would be contained in an
15 iterative space there.

16 So, by addressing these features in the
17 design, we've essentially eliminated those large
18 energy releases from the functional containment. And
19 as it talks about in the SECY paper, we really have
20 all of those conditions that would make a functional
21 containing approach fit.

22 We have a new coolant, we have a new
23 operating state, a close-to-atmospheric pressure, and
24 we've removed a lot of the major accidents, like
25 seeing generator and sodium water interactions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, that kind of covers the design
2 features. And then talking a little bit more about
3 how the process looks when you're designing the
4 functional containment and setting the performance
5 criteria to take all these things into account, like
6 I said, it's really integrated together with LMP and
7 with SARDLs.

8 Because, essentially, the LMP is used to
9 establish the LBE categories that you're looking at.
10 And then the functional containment performance
11 criteria is established for each of those LBE
12 categories.

13 So, that includes the SARDLs. The SARDLs
14 are included for the normal and AOOs, 10 CFR 5034 for
15 the d/b/a's, etc.

16 And then what you do is you establish
17 clear barrier performance criteria for all the SSEs in
18 the functional containment. So, again, that goes back
19 to the design process and integrating the safety
20 requirements with the design from the beginning, and
21 being able to review those over and over again as you
22 go through the LMP process.

23 And then we do demonstrate that those
24 performance criteria met with a major accident. And
25 if you want to reference back to the July 2023 meeting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we had with the NRC staff, they addressed SARDLs,
2 functional containment, and the major accident, and
3 kind of laid out the different major accidents we
4 would be using, and some of the main assumptions going
5 into those.

6 And then finally, the mechanistic source
7 term then pulls from all of these areas, to actually
8 go through and demonstrate the safety margin.

9 And then what you see, like I said before,
10 the specific PRA results on a frequency consequence
11 curve.

12 So, that's how functional containment
13 works with all the other elements of the LMP.

14 MEMBER ROBERTS: I have two questions of
15 what you just now laid out. Of all the features, it
16 seemed like all of them are also characteristic of
17 PRISM, except for the steam generator they moved
18 outside of the containment.

19 So, is there enough of a difference from
20 PRISM that the thought process that went into the
21 PRISM containment approach is no longer needed?

22 MR. WILLIAMS: In my opinion, yes. I
23 think we've also gone further with the sodium fire
24 protection within the functional containment space,
25 than was done in PRISM. I'd have to go back and check

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that.

2 But the steam generator removal is a
3 pretty huge one, I think. And I think applying it
4 with LMP is also different, because the LMP gives you
5 the hooks, if you will, to demonstrate functional
6 containment, along with all the other safety features,
7 throughout the design process.

8 MEMBER ROBERTS: If you look at the
9 approach PRISM used to containment, it was a guard
10 vessel, and I guess they call it the containment dome,
11 which is the equivalent of your -- area access
12 enclosures, as I read it.

13 And looking at the PSAR that staff just
14 accepted a couple of weeks ago, one of the criteria
15 that you list is maintain at least one barrier between
16 the clotting, piping, or vessel, containment-ready
17 nuclide source to withstand all the design basis
18 access conditions, and whose leakage is specified by
19 design requirements for testing, which sounds a lot
20 like the PDCs are going to take them out.

21 To have a containment structure, to have
22 leak testing, design requirements that ensure that the
23 leakage rates are met, that seems a lot like the
24 containment requirements that are in the SFR design
25 criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Again, that's not to say -- it's just a
2 very radical change. You talked about having some
3 sort of containment around the intermediate sodium
4 piping. Is that the head area access, or is that
5 something else?

6 MR. WILLIAMS: Yeah, essentially, for the
7 core, the primary safety-related boundary essentially
8 is the reactor coolant boundary. And then the
9 secondary barrier is essentially the guard vessel and
10 the head access area combined.

11 So, those are the boundaries that you
12 think of for functional containment. And so,
13 essentially, what we would do is meet that criteria
14 through the GDZs on the primary coolant boundary, that
15 are essentially very similar to that.

16 MEMBER ROBERTS: All right. So, as it
17 seems almost like rearranging the deck chairs, that
18 either you have the same containment capability, it
19 seems like that S-PRISM, PRISM, the plants that were
20 the foundation of the SFR design criteria, you have
21 that, you're going to have to have design criteria to
22 show you meet them, which it seems like those are the
23 design criteria that are specified for SFR design
24 criteria in the appendix of the Reg Guide.

25 So, again, I'm just trying to understand,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are you really doing something radical, or is this
2 really just making the terminology map up with LMP?

3 MR. WILLIAMS: I don't think the head
4 access area is a pressure-retaining containment. So,
5 the fact that we don't have the sodium water reaction
6 in that space to require that is probably the main
7 difference there.

8 MEMBER ROBERTS: Right. And if I remember
9 at the SFR design criteria, it allows you to figure
10 out what relatively low pressure you would need for
11 that pressure-retaining containment.

12 So, that's already one of the performance-
13 based allowances in the Reg Guide. Again, maybe it
14 requires some more thought, but it seems like what
15 you're doing isn't necessarily, from a design
16 perspective, much of a change from PRISM and what the
17 SFR design criteria are trying to push.

18 In which case, maybe you'll end up putting
19 them back in. I don't know, I'm just trying to
20 understand. But seems like you would need testing
21 requirements for leakage if you have a requirement,
22 self-imposed, that you have leakage specified by the
23 time requirements for testing.

24 MR. WILLIAMS: Yeah, I assume we would be
25 meeting all of those requirements and demonstrating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that anyway, even without the criteria in there.

2 MEMBER ROBERTS: Okay. Yeah, I think that
3 makes sense. Thanks.

4 MEMBER PETTI: I just think LMP provides
5 a structure.

6 MR. WILLIAMS: Yeah. Mm-hmm.

7 MEMBER PETTI: That if you develop these
8 design criteria, let's say from the bottom up and
9 years of experience, LMP gives you kind of a top-down
10 way to look at it and make sure you meet in the
11 middle.

12 And we kind of assure you there's
13 designers early in the process, that the requirements
14 have the right, the requirements at a broad system
15 level, that in principle, going bottoms-up you could
16 miss something. Right? And then go, oh yeah, down
17 here we got to go backtrack.

18 LMP, if it's done iteratively, like it
19 says, prevents or minimizes that sort of backtracking.

20 MR. WILLIAMS: Yeah. Yeah, that's right.

21 MEMBER PETTI: Yeah.

22 MR. WILLIAMS: That's right. I think it
23 makes the conversation clearer, and I think there's a
24 lot of value in that.

25 MEMBER ROBERTS: Did we already cover what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you planned to present?

2 MR. WILLIAMS: Yes, yes, we did, I think.

3 MEMBER ROBERTS: Okay, great.

4 MR. WILLIAMS: Yeah, we did.

5 MEMBER ROBERTS: Very helpful.

6 CHAIR KIRCHNER: Could you just flesh out
7 for us an example -- let's pick on something that you
8 already identified as one of your design features and
9 one of your barriers. What would the performance
10 criteria look like for the guard vessels?

11 MR. WILLIAMS: Yes. So, there's a couple
12 of key criteria on the guard vessels. So,
13 essentially, a postulated leak from the reactor vessel
14 has to be contained within the guard vessel, and the
15 gap within the guard vessel is a size such that it
16 remains above the heat exchangers and the reactor
17 vessel and the pumps so you can continue to provide
18 aquicore cooling.

19 Yeah, it has a function there. It also
20 carries a radionuclide retention function as a
21 secondary barrier for the functional containment, the
22 primary barrier being the reactor vessel.

23 So, if you assume the fuel pins have
24 failed -- and we assume all the fuel pins have
25 failed -- and demonstrating this, we assume the failed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 barrier there, if you also have a failure in the
2 reactor vessel barrier, then the guard vessel is there
3 to prevent further leakage.

4 CHAIR KIRCHNER: So, effectively, when you
5 implement these requirements, you're going to have
6 something that -- don't like to use the LWR
7 terminology -- and essentially leaked barrier about,
8 if not even a more demanding requirement, regardless
9 of the fact that you have sodium --

10 MR. WILLIAMS: In some cases it is more
11 demanding, because we're trying to prevent the sodium
12 from contacting air as well. Yeah.

13 CHAIR KIRCHNER: Members?

14 MEMBER ROBERTS: Okay, it sounds like
15 we've no more questions. So, thank you very much for
16 your presentation, TerraPower, and I guess we'll
17 switch to the NRC staff now.

18 (Off-mic comments.)

19 MEMBER ROBERTS: Then let's take a break
20 until ten o'clock, giving the staff a chance to set
21 up.

22 CHAIR KIRCHNER: So, for those online
23 listening in, we're going to take a break until ten
24 o'clock, Eastern Time.

25 (Whereupon, the above-entitled matter went

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 off the record at 9:50 a.m. and resumed at 10:01 a.m.)

2 CHAIR KIRCHNER: Okay, we're back in
3 session. And I just want to go ahead and turn it back
4 to Tom. Go ahead, introduce the NRC.

5 MEMBER ROBERTS: Thank you all. And I'm
6 just going to go ahead and pass it over to the NRC
7 staff. Mallecia, are you going to start? Or
8 Stephanie?

9 PARTICIPANT: Actually, we're going to
10 have Reed start it.

11 MEMBER ROBERTS: Reed start it. All
12 right.

13 MR. ANZALONE: I'm just going to take it
14 from the beginning.

15 MEMBER ROBERTS: All right, go ahead. Go
16 ahead, Reed. Thanks.

17 MR. ANZALONE: Thank you, Member Roberts.
18 So, I will jump straight into it. We had most of the
19 members for the subcommittee meeting. So, I think the
20 goal is just to try to cover the key points from that
21 subcommittee meeting. And I think TerraPower did a
22 good job of laying out a lot of the technical aspects
23 related to PDC. So, we're going to basically just
24 focus on our approach for the review.

25 So, I'll briefly cover the purpose of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 topical report and our strategy for the review, talk
2 a little bit about the regulatory requirements, give
3 a real brief overview of the PDCs, and then jump into
4 key topics from the subcommittee meeting, which are
5 functional containment SARDLs and the limitations and
6 conditions. And the slides aren't advancing.

7 Okay. So, the purpose of the topical,
8 like TerraPower talked about, was to describe the
9 process for developing PDCs, and then actually give us
10 those PDCs. And that's partially to address
11 compliance with 10 CFR 5034.

12 They also wanted to describe their
13 rationale for meeting the intent of PDC 26. I'm
14 actually not going to talk about that today, just to
15 be clear, to focus on the topics from the subcommittee
16 meeting.

17 And then our strategy for the review was
18 to review the PDC's conformance with the Reg Guide
19 group and evaluate the deviations from the Reg Guide,
20 considering the key design features.

21 And really, our scope, we wanted to -- and
22 this is something that we struggle with a little bit
23 as the staff for PDCs, because it's very easy to get
24 into the technical details of how you're going to
25 comply with the PDCs -- we wanted to focus on whether

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the PDCs themselves were acceptable.

2 And the design is an appropriate and
3 necessary context for that, but we didn't want to get
4 too into the weeds on how they were going to meet
5 them.

6 Part of our review then also was
7 identifying the interaction between the Reg
8 Guide 1.232 approach and the LMP, which TerraPower
9 talked about a little bit today. And then the PDC 26
10 rationale was a specific subject that we tackled,
11 that, again, I'm not going to talk about really today.
12 Apparently, I don't know how to move the slides
13 forward.

14 All right. Okay. So, the regulations, I
15 already mentioned that 5034 requires the CP applicant
16 to include the PDCs. TerraPower had the topical
17 report, which I believe is incorporated by reference
18 in the PSAR, but then they also put the PDCs into the
19 PSAR as well. But this was submitted well in advance
20 of the construction permit application.

21 And then Part 50, Appendix A, which has
22 the general design criteria, provides requirements on
23 the scope and content of PDCs, for all reactors,
24 including non-light water reactors. So, that first
25 bullet there talks about what the PDCs need to be able

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to do.

2 And then the second bullet is really sort
3 of more guidance saying that the GDCs that are in
4 Appendix A provide guidance for how the PDCs should
5 look.

6 So, TerraPower developed their PDCs, like
7 they mentioned, based on Reg Guide 1.232. Most of
8 their PDCs were directly based on the SFRDC, which
9 were in Appendix B of that Reg Guide.

10 Some PDCs were based on the modular high-
11 temperature gas reactor design criteria, which are in
12 Appendix C, and those were generally used to implement
13 functional containment, or reflect the use of SARDLs.

14 Most of the PDCs were modified in one way
15 or another from the base design criteria in the Reg
16 Guide, and we kind of circled around it a little bit
17 in the conversation earlier with TerraPower.

18 But there are no design criteria for those
19 numbers down there, due to the use of functional
20 containment. Talk about that a little bit in the next
21 couple of slides.

22 So, these were the general changes to PDCs
23 that I laid it out in subcommittee meeting. We're
24 going to focus on those two today, just for the sake
25 of keeping things a little tighter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, starting with functional containment,
2 so, obviously, discussions on containment -- I think
3 members have mentioned this earlier in the meeting --
4 the discussions about containment and functional
5 containment, and what's appropriate for NSFR
6 containment, have been going on for a long time.

7 Part of that discussion is Reg
8 Guide 1.232, which has containment criteria in it for
9 SFRs and for MHTGRs.

10 But one thing I will say is that Reg
11 Guide 1.232 came out, and then SECY 1896 came out,
12 which actually sort of codified the functional
13 containment approach.

14 And so, I'll talk about that more on the
15 next slide, our take on that SECY paper and the
16 associated SRM.

17 But sort of even at a high level, Reg
18 Guide 1.232 talks about functional containment. Yes,
19 it's in the MHTGR DC, and I think a lot of the impetus
20 for developing that concept came from the HTGR world
21 and TRISO fuel.

22 But the approach is technology-inclusive.
23 And the Reg Guide says it's applicable to advanced
24 non-light water reactors without a pressure-retaining
25 containment structure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, our thinking -- and I'll go to the
2 next slide to talk a little bit about the SECY
3 paper -- is that from the get go as part of the
4 current conversation on functional containment, the
5 idea is that it is technology-inclusive, risk-
6 informed, and performance-based approach to
7 containment design criteria.

8 The SECY paper, which was approved by the
9 Commission, gives a methodology for determining
10 functional containment performance. That developed
11 into LMP, and it was developed in parallel with the
12 Reg Guide, which noted that some of the stuff still
13 needed to be approved by the Commission.

14 MEMBER ROBERTS: Maybe you could comment
15 on -- I'm going to make an assertion and you can tell
16 me where I'm wrong.

17 It seems like the Appendix B -- SFR design
18 criteria for containment -- are technology-inclusive
19 for an SFR, risk-informed, performance-based, because
20 if you look at the history, it seems like the NRC took
21 a turn at that probably 30 years ago, and said, we
22 need to go revise the GDC that are derived from light
23 water reactors, because they don't really apply to
24 this technology, and what's left there does have some
25 aspects of at least performance-based and, I'd expect,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 risk-informed.

2 So, is it fair to say that the existing
3 SFR design criteria for containment are risk-informed,
4 performance-based?

5 MR. ANZALONE: I would say that that's
6 true to a degree. And I think I -- and maybe it's the
7 next slide -- I'm going to talk a little bit more
8 about the specific SFR design criteria, which do have
9 kind of notes in them about, this would apply under
10 these certain situations.

11 But at the same time, if you go back and
12 look at the SECY paper, I had the benefit of going
13 through the transcripts from the ACRS meeting and your
14 letter on this, and I think sort of conceptually, the
15 thing that functional containment as an approach does,
16 is it's capable of encapsulating all of the possible
17 different approaches.

18 So, if you look at SECY, I think it's
19 93092, which might have been what you were talking
20 about 30 years ago.

21 There's a bunch of different containment
22 designs that are referenced in that. There's the
23 MHTGR, which is sort of a pure functional containment
24 along these lines.

25 There's the PRISM reactor, and I think it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 was the OR S design. That all have kind of varying
2 degrees of containment, leak tightness, and different
3 containment designs.

4 And if you look back at the SECY paper and
5 sort of -- a bunch of the discussion around that, the
6 idea was that functional containment performance could
7 be, you could define a generic functional containment
8 criteria that could encapsulate all of that.

9 So, I think the approach that was in
10 SEC 1896, is intended to kind of wrap around all of
11 them. And I think the letter that the ACRS wrote at
12 the time actually kind of explicitly says, hey, maybe
13 the staff should go back and revise Reg Guide 1.232 to
14 say, hey, this concept could apply across the board.

15 So, that was part of our consideration
16 here in thinking through does functional containment
17 make sense for TerraPower?

18 CHAIR KIRCHNER: Reed, let me help you
19 here. I have the letter.

20 (Laughter.)

21 CHAIR KIRCHNER: And it goes on to say
22 that the containment criteria in Appendices A, B, and
23 C of the draft Reg Guide are logically inconsistent.
24 So yes, there was this thought that they should be
25 technology-inclusive.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So it wasn't clear at the time whether the
2 staff would go back and revisit the Reg Guide. I
3 think there was a pointer there that the sets of
4 criteria weren't, as we stated, logically consistent.

5 MEMBER ROBERTS: Yeah, and we're 30 years
6 later and this is Natrium, not PRISM, and there's a
7 lot of development of risk-informed thought processes.
8 And that can certainly result in another term.

9 But it seemed to me, I'd want to see, get
10 your reaction, that the existing Reg Guide Appendix B
11 is risk-informed, performance-based for that specific
12 technology. And that doesn't mean that's set in
13 stone, because there are changes to, you know, from
14 PRISM to Natrium, and there are changes in thought
15 processes, or risk-informed space.

16 And it seems like okay, an unfair
17 statement to say this is the addition of a functional
18 containment thought process, because you could argue,
19 you know, that term wasn't used. This was essentially
20 a functional containment for and SFR developed 30
21 years ago, just not using that term. Is that fair?

22 MR. ANZALONE: Yeah, and I can -- I just
23 moved on to the next slide, because I think this sort
24 of talks about what you're getting at. There are
25 certain of the SFRDC that talk about, you know, how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 they would be applicable if certain approaches to
2 containment were taken or might not be -- like maybe
3 you would have the SFRDC, but it wouldn't actually be
4 applicable to any structures at the plant, which is
5 kind of an odd thing.

6 So that's the, basically I think it's,
7 yeah, 39 -- 38, 39, 40, and 50-57 are all sort of in
8 that space where, you know, you could maybe make the
9 argument, okay, we don't need this structure, even
10 though we have these criteria. But it, to me, it's
11 not, that's not like a clean approach. That's messy.

12 And I understand that, you know, the SFR
13 or the functional containment criteria is itself a
14 little bit messy because we kind of get everything at
15 once with the demonstration of functional containment
16 performance. But the criterion itself is more
17 straightforward, and you don't have to make these
18 arguments about how we have these criteria but they're
19 not actually applicable.

20 So like for example, if they didn't need
21 heat removal in the containment, then they wouldn't do
22 anything with 38, 39, or 40. But then why do you have
23 them at all? And to me, it makes more sense to apply
24 like a sort of more straightforward performance-based
25 criterion that encapsulates everything.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So our take is that it's, you know,
2 appropriate to apply the functional containment
3 criterion for TerraPower. And I'll, I guess I'll go
4 onto the next slide.

5 Because you know, the SECY paper talks
6 about it being acceptable for non-light water
7 reactors. We do think, and TerraPower I think laid
8 these out very well, there are attributes of the
9 reactor design that are necessary to be able to, you
10 know, effectively actually use a functional
11 containment approach.

12 But that functional containment
13 performance still needs to be demonstrated, and that's
14 part of our review in the construction permit
15 application. And you know, based on what I read in
16 the transcripts and the discussion surrounding this
17 issue back when ACRS reviewed it back in 2018, there
18 were a few sort of thoughts about, you know, defense-
19 in-depth and how you would go about actually analyzing
20 those.

21 So I just wanted to throw these points in
22 here that LMP is really like a key part of this. And
23 it's part of why we have that limitation condition
24 that says thou shall use LMP is you're going to apply
25 this approach. It implies that you're going to have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a PRA and a mechanistic source term. It gives you
2 criteria that you need to meet.

3 You have to explicitly consider
4 uncertainties. And you have to do this risk-informed,
5 performance-based, defense-in-depth adequacy
6 evaluation that's in NEI 18-04. So you know,
7 functional containment doesn't mean no containment, it
8 means you evaluate all of the barriers that are in the
9 way of the release of radionuclides.

10 So if we were going through TerraPower's
11 evaluation in our review and we came across something
12 that we felt like releases weren't being appropriately
13 addressed, that's something that we would bring up
14 during our review.

15 Okay, any questions? Because I'll be
16 moving on to SARDLs, which that's a pretty brief
17 discussion.

18 So SARDLs were initially identified for
19 TRISO fuel for the MHTGR. They're for normal
20 operations in AOOs, and they need to be established so
21 the Part 20 limits aren't exceeded. But the SECY
22 paper on functional containment performance criteria
23 does pretty much say SARDLs are intertwined with
24 functional containment performance criteria.

25 And so, you know, I think the concept that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we understood from talking with TerraPower about this
2 is that the impetus for SARDLs is that use of
3 functional containment, which is also all intertwined
4 with LMP.

5 And so that first bullet here on this
6 slide is that we -- our view is that SARDLs are
7 appropriate (audio interference) and consistent with
8 a performance-based evaluation.

9 We already talked about fuel design limits
10 that can be used to help evaluate those SARDLs. And
11 I'm really glad that Eric touched on it during his
12 presentation. I think one of the key things is that
13 SARDLs are a useful tool for looking at ex-vessel
14 events and sources of radionuclides other than just
15 the fuel inside the reactor.

16 And he mentioned that ANL art series of
17 reports looking at mechanistic source terms. One of
18 the things that ANL has found, and I think
19 TerraPower's assessment also agrees with this, the
20 things that drive the plant risk are not the in-vessel
21 events. They're all of the issues in these like
22 auxiliary systems and fuel-handling accidents.

23 So having SARDLs to evaluate those events
24 actually helps a lot. Part of SARDLs is that you
25 would need to include a means of monitoring activity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in these systems, so that's something that we'll
2 evaluate as we look at their plant design.

3 And the SARDLs need to still be proposed
4 and evaluated, and we did discuss them. Eric
5 mentioned the July public meeting, where we had some
6 example SARDLs that we talked about with them.

7 Moving on to the scope and applicability
8 of PDCs, and really this I just wanted to say, you
9 know, we talked about possible changes to the
10 limitation 2 and RSE. As of right now, we haven't
11 identified any changes, and so we didn't pass along to
12 the ACRS. So that's why I wanted to bring that up
13 again in this meeting. So that limitation 2 really is
14 focused on the use of LMP.

15 And these are the same conclusions from
16 the subcommittee meeting, so I won't reiterate them in
17 the interest of trying to get us closer to the
18 schedule in the agenda, so. Anyway, happy to take any
19 questions that you may have. If not, then we can --

20 CHAIR KIRCHNER: Reed, when you went
21 through this, okay, so you accept the premise. Did
22 you systematically look at the implications of
23 expunging, or maybe a better way to say it is to
24 divert from the ensuing GDCs that are containment-
25 related? See where I'm going with this?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 If you say 16 is now functional
2 containment rather than containment, then do you still
3 systematically look at all those other GDCs that
4 support containment? Because what they by and large
5 do is protect that fission product barrier in once
6 sense or other. So was that --

7 MR. ANZALONE: So yeah, there a couple --

8 CHAIR KIRCHNER: What you're thinking?

9 MR. ANZALONE: Yes, and there are a couple
10 of PDCs that TerraPower added back that talk about the
11 performance of the reactor building envelope and stuff
12 like that are -- that are necessary when you use a
13 functional containment approach.

14 CHAIR KIRCHNER: You feel that you've got
15 a complete set and that would address those other
16 functions that, how should I say this, that the
17 containment building structure provided, went beyond
18 just fission product release. Either they were
19 protecting the building de facto for a LWR becomes the
20 major protection against external events, or many
21 external events, etc.

22 So the containment function goes beyond
23 just fission product barrier purposes.

24 MR. ANZALONE: Yeah.

25 CHAIR KIRCHNER: Protecting against

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 internal, external events, flooding, fires. So when
2 the staff did its review, you felt there was a
3 complete set of those other functional attributes that
4 go into -- unfortunately, containment for an LWR is a
5 multipurpose --

6 MR. ANZALONE: Right.

7 CHAIR KIRCHNER: Function. So you're
8 satisfied that they address those -- their thing.

9 MR. ANZALONE: Yeah.

10 CHAIR KIRCHNER: So when we come back and
11 look at an actual detailed design and look at, let me
12 pick one of the things that's always problematical
13 with containment is double isolation valves, inside,
14 outside, and so on.

15 You still feel that the functional
16 equivalent of those containment-like criteria would
17 still be applied when you reviewed individual fission
18 product barriers, i.e., a guard vessel?

19 MR. ANZALONE: Yes.

20 CHAIR KIRCHNER: Think someone was just
21 unmuted there. Okay.

22 MR. ANZALONE: But yes.

23 CHAIR KIRCHNER: All right, thank you.

24 MEMBER ROBERTS: Yeah, I guess I thought
25 of it a little bit differently. Because the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 functional containment is not entirely defined yet, if
2 it's defined as the PSAR indicates with containment
3 structures and leak test requirements, and the like,
4 you would add back in criteria as the design of the
5 containment would like more and more like a classic
6 SFR containment or light water reactor containment.

7 That, that was my interpretation as you
8 got the big picture, you know, this is a functional
9 containment, we're going to figure out what it means.
10 But then when it looks like a more conventional
11 containment, you have to look at putting back in these
12 kind of design criteria.

13 Whether they're called PDCs or what you
14 call them I don't know, but I would think you'd still
15 want to make sure the requirements for leak testing or
16 the requirements for double valve isolation, whatever
17 they happen to be, are met once the containment
18 structure looks like a structure that these were
19 applied to.

20 MR. ANZALONE: I'm not sure I followed.

21 MEMBER ROBERTS: Yeah, that's still
22 puzzling me a little bit. The proposed containment
23 for the PSAR is to have a structure, right. So there
24 is a structure around each boundary that contains
25 reactor material, which ends up looking a lot like,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you know, a PRISM containment.

2 And so it looks like a PRISM containment,
3 then the requirements that were based on PRISM
4 containment will seem to be met in some form or have
5 to be met.

6 And so whether you call those PDCs or call
7 them design requirements or tech specs or whatever
8 they happen to be, once you -- once they go back to
9 the design looks like PRISM, then the requirements are
10 imposed in PRISM structure would seem to be evaluated,
11 need to be evaluated for applicability and things like
12 leak test capability would seem to need to be a
13 requirement. Just like PDC-52.

14 MEMBER ROBERTS: So some of those detailed
15 design requirements would, you know, depending on the
16 specific design of the system would I would expect
17 sort of flow down from the high level performance
18 requirement in the PDCs.

19 CHAIR KIRCHNER: So where I was coming
20 from is if you were to go back and look at that -- and
21 I'm sure you have -- the staff's work on functional
22 containment, they point to additional sets of
23 functional containment performance standards, like
24 protecting other risk-significant SSCs.

25 MR. ANZALONE: Yeah.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Support of them,
2 occupational radiation exposure, removing heat,
3 physical protection, like security for external
4 events, etc. So that's where I was going.

5 MR. ANZALONE: Yeah, that's what I
6 understood from you. From Member Roberts, I thought
7 you were talking about sort of more detailed criteria
8 for specific system designs. Is that correct?

9 MEMBER ROBERTS: Yeah, I'm thinking if
10 these 15 criteria that are in Appendix B or based on
11 the characteristics of a PRISM containment structure,
12 and if the nature of a containment structure looks
13 like a PRISM containment structure, then the same 15
14 requirements would seem to need to apply in some form.

15 Whether you call them derived requirements
16 or principal design requirements or whatever, if the
17 containment structure requires them to meet its
18 function, then they would need to be tracked I would
19 think in some form.

20 MR. ANZALONE: Well, I guess I would say
21 that with that high-level performance-based
22 requirement, you know, TerraPower would look at their
23 design and they would look at the releases and the
24 doses, and they would figure out which of those kinds
25 of criteria would need to be looked at.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So if you look at like double isolation
2 across containment, I don't -- I don't think that
3 something like that is part of TerraPower's design.
4 I don't know for certain, and I'm sure it would depend
5 on the specific system. So that's maybe an example of
6 where like using a performance-based criterion would
7 buy you something in design space.

8 MEMBER ROBERTS: And if just folks want an
9 example, Criterion 52 says a reactor containment
10 structure and other equipment that may be subjected to
11 containment test conditions shall be designed so the
12 periodic integrated leak rate testing can be conducted
13 to demonstrate resistance and containment design
14 pressure.

15 So if their design is going to have a low
16 leakage, you know, structure for the -- the head
17 access area, and their intent is to verify that by
18 test, then why wouldn't 52 apply?

19 MR. ANZALONE: Because it's encompassed by
20 this functional containment performance criterion.

21 MEMBER ROBERTS: So it ends up being a
22 derived --

23 MR. ANZALONE: Yeah.

24 MEMBER ROBERTS: Not a principal design
25 requirement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. ANZALONE: I would agree with that.

2 MEMBER ROBERTS: Okay. But in some form,
3 it would seem like your review of that system, once
4 it's concluded that it looks like PRISM --

5 MR. ANZALONE: We would --

6 MEMBER ROBERTS: You would --

7 MR. ANZALONE: We would want to make sure
8 that it met its performance requirements. That the
9 performance requirements made sense and that it met
10 them. But that is all down the road as part of our
11 construction permit application review.

12 VICE CHAIR HALNON: But so -- this is Greg.
13 Those performance requirements, I mean, to your point,
14 if it's not required for part of the functional
15 containment definition of whatever that SSC, if you
16 would, then you wouldn't have to do the leak testing.
17 This really doesn't apply.

18 MR. ANZALONE: Right.

19 VICE CHAIR HALNON: It's not part of the
20 basis for that containment. I mean, so it's not
21 really "containment structure." That's the way I'm
22 reading that. I don't have a conflict here.

23 I see it -- see what -- the functional
24 containment, you could look at that as an SSC, even
25 though it's distributed amongst things. This is not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 part of that SSC. That's the way I'm looking at it.
2 So I don't see a conflict in my mind.

3 MEMBER ROBERTS: It depends what is in the
4 system to meet the functional containment
5 requirements.

6 VICE CHAIR HALNON: Right. So if that
7 vessel, guard vessel, you say is not supposed to be,
8 you know, a gaseous leak-tight, if you would. It's
9 sodium leak-tight. It doesn't make -- in my mind,
10 it's just not part of that functional containment
11 requirement. So there's no -- 52 wouldn't apply.
12 Even though you say it's derived, it's sort of
13 derived. But it's not part of the SSC for functional
14 containment.

15 I'm not looking at specifically design,
16 I'm looking at conflict. I understand how 52 would
17 not be part of this because it's not part of the SSC
18 of functional containment, in a classic sense.

19 Anyway, I just wanted to make sure that I
20 understood why you said it was derived. No leak test
21 is required because it's not part of the SSC.

22 MEMBER ROBERTS: Yeah, it depends on the
23 functional containment model on what they've got in
24 there. Well, what they say in PSAR is to have these
25 structures surrounding the vessels and pipes and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 like that contain radioactive material. And they plan
2 to leak-test everything that's in that.

3 So the question would be whether that
4 derived requirement ends up being something that the
5 NRC staff would validate because that's part of the
6 approach taken to containment that looks like PRISM,
7 or something that's just part of developing the
8 functional containment model and whether or not it's
9 derived from that.

10 I'm not sure that distinction is clear,
11 but if the structural containment looks like PRISM and
12 it's credited, you know, similar to the way it was
13 operated in PRISM, then the requirements there were
14 applied to PRISM would seem to apply also.

15 VICE CHAIR HALNON: Unless they're subsumed
16 into something bigger.

17 MEMBER ROBERTS: Yep.

18 Any other questions for Reed on this
19 subject?

20 CHAIR KIRCHNER: Reed, at some risk I'm
21 going to bring up PDC-26. I didn't want you to get
22 off that easily. Can you just for the record, since
23 this is full committee, give us your evaluation of the
24 proposal for PDC-26?

25 MR. ANZALONE: Yeah, sure. So, and we did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cover this at the -- I don't think I'm going to say
2 anything different than I said at the subcommittee.

3 CHAIR KIRCHNER: I don't expect that.

4 MR. ANZALONE: For the record, you know,
5 TerraPower proposed that they would essentially adopt
6 the SFRDC-26 with some conforming changes about safety
7 significance that are consistent with LMP that are
8 applied to all the different PDCs. So it's
9 essentially, I would say it's essentially unchanged
10 from SFRDC-26 in like a meaningful way.

11 And so then they proposed that they would
12 meet that by essentially showing they have two
13 different -- two different control rod designs that
14 mitigate common cause failures between the different
15 control rod designs.

16 And so they were intending to show that
17 there was sufficient diversity and independence
18 between the different control rod design. And there's
19 a different means of control rod insertion. So they
20 wanted to show that in a sort of risk-informed manner,
21 that that would be independent and diverse enough to
22 meet Criterion 26.

23 CHAIR KIRCHNER: But the staff position,
24 as I understand it now, is you basically accept that,
25 but it's TBD --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. ANZALONE: Exactly.

2 CHAIR KIRCHNER: D being demonstrated by
3 design that they're not going to be subject to a
4 common cause failure.

5 MR. ANZALONE: Correct.

6 CHAIR KIRCHNER: Seismic misalignment such
7 that you can't insert either set of control rods. So
8 this, I'm just flagging this because it's a major
9 departure from what in the past had been the
10 definition of diverse, looking at two diverse or
11 similar systems for that function.

12 MR. ANZALONE: Yep. One thing I will say
13 fortunately that SFRs buy you, and I know this was
14 mentioned during the subcommittee meeting, you know,
15 you can fail a lot of control rods and still get
16 enough negative reactivity insertion to shut down the
17 reactor. So I think that would help with the overall
18 demonstration, that there's enough diversity there.

19 CHAIR KIRCHNER: Perhaps the exponents of
20 the opposite take would say with an SFR, you can get
21 a significant reactivity insertion event.

22 MR. ANZALONE: Absolutely, and that's
23 something we're going to be really focused on in our
24 review.

25 CHAIR KIRCHNER: Yeah. Because the one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thing, if we're here I'll just state this, is that
2 we're now at a size for a fast reactor design like
3 this, that you're at the edge of where you can rely on
4 the leakage as a negative feedback mechanism. So I
5 expect that when we review the PSAR, that this will be
6 looked at very carefully when we're considering the
7 PDC-26 as well.

8 MR. ANZALONE: Absolutely, absolutely, I
9 totally agree.

10 MEMBER ROBERTS: Any other questions from
11 the members or consultants on the PDC? Now we can
12 move on to the fuel qualification report.

13 MS. DE MESSIERES: Actually, this is
14 Candace de Messieres from the NRC.

15 So I just wanted to make one clarifying
16 point for the record as it relates to L&C No. 2, that
17 at the highest level, that L&C has to do with the
18 synergy between the frameworks between PDC and LMP.
19 And that the staff continues to work to ensure
20 clarification at a generic level on that issue.

21 So I just wanted to make that note for the
22 record. Thank you.

23 MEMBER ROBERTS: Thank you.

24 MR. ANZALONE: Okay, so moving on to fuel
25 and control assembly qualification. So we started

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 with fuel and we'll end with -- we'll let fuel take us
2 out.

3 This is a, I would say, more just
4 relatively straightforward truncation of my
5 presentation at the subcommittee, so I can go through
6 this as quickly or as slowly as we want. So I'll talk
7 a little bit about, again, the topical report purpose
8 and our strategy in the review. I'll talk a little
9 bit about the regulatory requirements in the guidance.

10 And part of what we used a lot in our
11 review was this NUREG-CR 7305 for giving us technical
12 information that we could use to help evaluate
13 TerraPower's fuel. Then I'll go through a brief
14 overview of our safety evaluation and the overall
15 conclusions.

16 So the purpose of the topical report was
17 to provide a plan to qualify Sodium Type 1 fuel,
18 which as TerraPower talked about, is a U-10Zirc
19 metallic fuel in HT9 cladding. And they're control
20 assemblies. And it requested NRC review and approval
21 of a bunch of different items that essentially are the
22 fuel qualification plan.

23 And it provides some fuel qualification
24 results and talks about their ongoing plan of fuel
25 qualification activities.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So our strategy in the review was to
2 review the scope and adequacy of the plan in the
3 context of NUREG-2246, which was released after
4 TerraPower had started developing this topical report.
5 So they included a crosswalk that sort of referenced
6 their criteria that they came up with against NUREG-
7 2246.

8 And then we also reviewed it, as I
9 mentioned, against NUREG-CR 7305, which you know, I
10 should say is not, it's not -- it doesn't have like
11 the status of guidance, right. It's not a reg guide.
12 But it is additional technical information that we had
13 contractors from several different national labs put
14 together to help us look at metallic fuel.

15 So the regulatory requirements. And
16 NUREG-2246 I think does a pretty good job of laying
17 out the landscape of how fuel qualification works in
18 terms of regulatory requirements. It provides a lot
19 of the technical basis for how you would show that you
20 meet the regulatory requirements.

21 But there aren't necessarily a ton of
22 regulatory requirements that directly apply to fuel
23 qualification as a process. But 50.43E requires your
24 safety features to be supported by analysis testing
25 operating experience of a combination thereof. And it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 requires there to be sufficient data to exist to
2 assess your analytical tools.

3 And then 5034 requires applicants to
4 evaluate a postulated of fission probabilities from
5 the core in the containment. Part of that is the
6 fuel's performance. And as TerraPower mentioned, that
7 is something that they are doing with their major
8 accident as part of their construction permit
9 application.

10 And it requires the principal design
11 criteria to be submitted. Some of the PDCs have to
12 fuel, so.

13 So then the guidance, there's NUREG-2246,
14 which provides general guidance on fuel qualification
15 for non-light water reactors in the form of this fuel
16 qualification assessment framework. And I'll be kind
17 of stepping through that a little bit today.

18 And that kind of, that draws on a lot of
19 the experience from the staff evaluating both light
20 water and non-light water reactor fuels. And then
21 also we have this NUREG-CR 7305, which was developed
22 by staff from, I think it was INL, Los Alamos, and
23 ANL, giving us some insights into metallic fuel
24 systems.

25 And it did that in the NUREG-2246

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 framework and identified an operating and low-key
2 behaviors and phenomena and provided a review of the
3 data that was available and discussed a little bit the
4 current state of fuel-performed follow-up.

5 And some of the key conclusions from the
6 NUREG-CR, I won't go through the whole thing in detail
7 because I did that during the subcommittee, and it
8 took a solid 20 minutes. But for fuel with geometry
9 and operating conditions consistent with the previous
10 operating experience, so that's really EBR-II and the
11 FFTF, MFF fuel, the metallic fuel that was operated at
12 FFTF.

13 The life-limiting and safety-related fuel
14 behaviors and well known and predictable, up to around
15 10 percent burnup. And that's not really a hard
16 limit, that's a, you know, we think it's well-
17 characterized up to this limit. Somewhere beyond
18 that point, the behaviors are less predictable. And
19 so if you wanted to go much beyond that, you would
20 need to do a more thorough job of characterizing it
21 than has been done previously.

22 Fuel constituent redistribution is one of
23 the behaviors that is present in the data that does
24 affect fuel properties and other things. That's
25 captured in the existing empirical models that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 based on this fuel operating experience. The life-
2 limiting phenomenon is fuel cladding chemical
3 interaction, which TerraPower mentioned as being their
4 main issue that they're dealing with.

5 And fuel cladding mechanical interaction
6 is not really a concern. But again, that's really
7 specific to, you know, similar geometry to what the
8 previous operating experience was, and but the lower
9 end of the burnups that were operated.

10 Transient data would help to establish
11 safety margins. TerraPower talked about doing
12 additional transient testing. And that if you wanted
13 to use a highly mechanistic model, you would need to
14 do more work to qualify that. So for example, you
15 know, what effect does fuel constituent redistribution
16 have. That's something that you would need to study
17 a little bit more closely.

18 So the Sodium fuel assembly design, it's
19 very similar to the EBR tool and that MFF fuel from
20 FFTF. It's a U-10Zirc peak enrichment less than 20%,
21 so it's HALEU. Seventy-five percent smear density.
22 These are all essentially the same characteristics
23 that are discussed in the NUREG-CR.

24 TerraPower showed the assembly overview.
25 You saw the hexagonal fuel assembly. And then they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 applying this limited free bow core restraint system,
2 which was sort of tried at FFTF. Or I guess was, you
3 could say was tried at FFTF. So there is some
4 information that they can validate against there.

5 Now, I'll just start walking through the
6 fuel qualification big framework from NUREG-2246. So
7 just it has this top level goal that fuel is qualified
8 for use, and that's supported by all of these
9 different subgoals. So Goal 1.1 and 1.2, or really
10 all of Goal 1 is talking about the fuel manufacturing
11 and whether that's in an appropriately controlled and
12 understood process.

13 Our take on all of this was that the TR
14 either includes or refers to design documents that
15 TerraPower has that have this information to we think
16 an appropriate degree. They did mention in their
17 topical report that there's the potential for fuel --
18 or for materials other than U-10Zirc or HT-9 to be
19 part of the fuel system.

20 We included a limitation and condition on
21 there to essentially say if you are going to use these
22 materials, you need to describe them a little bit
23 more. But I will say that all the materials that they
24 mentioned in the topical report are, you know, code-
25 qualified materials that are generally used in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 industry in these kind of applications. So they're
2 not things that we're particularly concerned about.

3 One thing that's important for fuel is,
4 you know, making sure that the end-state attributes
5 from the manufacturing process are appropriately
6 captured. And we thought that TerraPower did that
7 well enough in the topical report.

8 So Goal 2 talks about margin to safety
9 limits, and that's supported by design limits for
10 normal operation of AOOs and then also for accidents.
11 Part of that is defining the fuel performance envelope
12 that you want to be working in. TerraPower provided
13 those in a pin and assembly damage criteria that they
14 flashed on the screen earlier, and that was consistent
15 with the key mechanisms that we saw from the NUREG.

16 We haven't seen specific limits on any of
17 those criteria yet, so that's something that we would
18 need to better understand before the fuel is
19 considered to be fully qualified. And I'll talk a
20 little about how their operating envelope compares to
21 the historical operating experience later.

22 And one thing here I grayed out evaluation
23 model is available. They included a discussion on
24 evaluation models. So we know that they have
25 analytical methods to assess the fuel. We didn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 really review them in this topical report.

2 We think that the methods that they have
3 look like they have what they need, you know, in terms
4 of geometry and fields and stuff like that to be able
5 to model the fuel. But it's not like this topical
6 report had a validation of those methods, because that
7 data is still being collected. So that's something
8 that we're going to have to deal with later on.

9 So we already talked about 211 on the
10 previous slide. Then this talks about these, so these
11 are the release limits under accident conditions. And
12 I just wanted to mention here these two bullets that
13 I wanted to highlight really relate to limitation and
14 condition 5, and that's the specifying the retention
15 and release requirements.

16 TerraPower said that those -- that was
17 going to be done in the mechanistic source term
18 topical report. So it was outside the scope of the
19 fuel topical report review. And so we are actively
20 reviewing that topical report.

21 And here I will talk about the safety
22 limits for accidents and -- transients and accidents.
23 So the fuel failure criteria that TerraPower came up
24 with were we thought consistent with the key
25 mechanisms that we identified for metallic fuel. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 coolable geometry criteria was also consistent.

2 There was a discussion in the NUREG-CR
3 about ejection of molten debris from the fuel. They
4 -- we thought that those were precluded by having a
5 limit against fuel melt. If you're not going to melt
6 the fuel, there isn't really a mechanism to eject much
7 debris from the fuel. There's a lot of run beyond
8 cladding breach testing that shows that the fuel just
9 kind of sits there and nothing really happens to it.

10 The negative reactivity insertion criteria
11 we thought were adequate. But again, as with the
12 discussion on AOOs and normal operation, we would
13 still need to understand what the specific limits
14 would be on these criteria.

15 I already touched on the evaluation model,
16 so I'll just skip through this slide. Data, so there
17 is, as TerraPower mentioned, a lot of historical data
18 out there. We focused in our safety evaluation on the
19 scope and applicability of the previous data and how
20 that data supports TerraPower's acceptance criteria,
21 which I will say they did a really good job of laying
22 out in the topical report, you know, how --what
23 testing supports each criterion.

24 The type I fuel design and geometry that
25 they have is generally consistent with metallic fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that was operated at EBR-II and FFTF. It's a little
2 bit fatter than the EBR-II fuel, a little, just a tiny
3 bit fatter than the FFTF fuel. You saw the length of
4 the fuel columns is about the same as FFTF.

5 A significantly larger plenum, which is
6 good for accommodating fission gas release. So those
7 differences we think are either beneficial in terms of
8 the plenum. And I think the fuel cladding is slightly
9 thicker too. Or aren't expected to have much impact
10 on the applicability of the historical data. They're
11 small deltas.

12 The fuel operating parameters were also
13 generally consistent with the past operating
14 experience. Some of those parameters are at or maybe
15 slightly beyond the historic database. But those
16 deltas we think are small, and they're not expected to
17 have a lot of effect. They would be addressed by the
18 surveillance program or are covered by testing that
19 TerraPower proposed to do.

20 And our overall conclusion is that the new
21 data collection, so basically the historical data is
22 generally applicable. Where there are gaps, the new
23 data collection that TerraPower proposed is
24 appropriate to fill those gaps.

25 Shifting gears a little bit to talk about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the control assembly, so they're boron carbide pellets
2 in a plenum that looks a little, or in a fuel --
3 control rod, not a fuel rod, that looks a little bit
4 more sort of like an LWR rod, where it's got a plenum
5 with a hold-down spring.

6 But they also are clad in HT-9 with an HT-
7 9 wire wrap, like the fuel rods are. And they're in
8 that sort of tight, hexagonal arrangement.

9 The one thing that is important about the
10 control rod design that isn't necessarily super
11 obvious from the discussions that we've had already is
12 that each control assembly occupies its own space in
13 the core with its own duct. There is then a control
14 rod duct inside that duct that moves up and down.

15 And so they, as we talked about during the
16 previous meeting, you know, there's primary and
17 secondary control assemblies to try to meet that PDC-
18 26 criterion. The differences are really the number
19 of absorber pins and the dimensions of the control
20 assembly.

21 And then I just have I think a single
22 slide on qualification of the control assemblies. But
23 you know, sort of boiling down the NUREG-2246 criteria
24 aren't exactly applicable to a control assembly
25 because it has different safety functions. But you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 kind of think of analogous criteria, at least at a
2 high level.

3 So you know, are there are appropriate
4 controls on manufacturing? Yeah, we looked at what
5 they provided in the topical report and what they
6 referenced in terms of design documents. We got to
7 look at those in an audit. We think that they've
8 appropriately specified what the manufacturing looks
9 like to, at least to the degree that it needs to be.

10 The design criteria we thought were all
11 appropriate to make sure that the control rods could
12 fill -- fulfill their safety function.

13 For evaluation model, kind of similar
14 story as with the fuel rods where the codes we think
15 have the ability to do what they need to do, but
16 there's some validation that still needs to happen.
17 And essentially I think that, as was mentioned during
18 the TerraPower's meeting, it's the same codes, but
19 they wanted -- they added boron carbide models.

20 For data, there is some historical data
21 from past operating fast reactors for different
22 control rod performance that TerraPower was able to
23 draw on. I would say there's no exact one-to-one
24 match for control rods in terms of like materials.
25 And but there are -- there are some that use different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 combinations.

2 So we thought that the data that
3 TerraPower was able to assemble looked like it covered
4 the spectrum well enough. And they have planned
5 testing again to fill gaps in this historical
6 database.

7 Talked briefly about fuel surveillance and
8 LDAs and LTAs, TerraPower touched on this. There's a
9 notional surveillance plan for the first several
10 cycles of irradiation in the topical report. The LDAs
11 and LTAs are designed with removable pins to
12 facilitate close irradiation examination.

13 There's significant precedent for a
14 program like that, LDAs and LTAs, based on the
15 operating fleet. We do want to see eventually more
16 detail on how those leak demonstration, leak test
17 assemblies will be evaluated.

18 To the point that you brought up, you
19 know, the removable pins won't have wire wrap. So how
20 does that affect the performance of those pins and how
21 do you evaluate it? That's something that wasn't
22 necessarily clear from the topical report. So that's
23 something we're going to dig into as we go forward.

24 Limitations and conditions. So the first
25 one really is, you know, this is a good plan. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that does -- it's a plan and you still need to execute
2 it. The second one is the point that I touched on
3 about use of materials other than U-10Zirc and HT-9 in
4 fuel. If you are going to use those, we need to talk
5 more about it.

6 The topical report, sorry, the third
7 criterion here relates to the relationship between the
8 fuel design limits and the SRDLs. Essentially this is
9 good fuel design limits that provides good context for
10 evaluating the SRDLs. But you have to actually
11 evaluate the SRDLs for like stochastic failures of
12 fuel pins or whatever.

13 For number 4, and I can talk more about
14 this if we want to have a closed session, but I did
15 cover it during the subcommittee meeting. There were
16 some documents that TerraPower referred to in the
17 topical report for helping develop their design
18 criteria that hadn't yet been the subject of NRC
19 reviews. So we just wanted to point that, that
20 criterion there or that L&C there.

21 And limitation 5 really relates to the
22 retention of radionuclides. And we think that it's
23 okay to push that off to a different topical report,
24 we just wanted to put this limitation to make it clear
25 what the scope of this topical is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And our overall conclusion is that the
2 topical report was acceptable and provided an overall
3 acceptable approach for qualifying fuel and control
4 assemblies.

5 And the one thing I will say, and this did
6 come up last time, part of that is the monitoring and
7 surveillance program we think is a really important
8 part of the overall fuel qualification effort.

9 CHAIR KIRCHNER: Go back to No. 5, please.

10 So you would expect the actual performance
11 would be in the mechanistic source term report?

12 MR. ANZALONE: So we left it open. I
13 don't think we said this has to be in the mechanistic
14 source term. But I think TerraPower has said that
15 it's covered by the mechanistic source term topical
16 report.

17 CHAIR KIRCHNER: Just always a little bit
18 on guard, so to speak, when you have statements like
19 are expected to remain within the fuel, etc. So this
20 implies that they're going to demonstrate that or make
21 the case somewhere else.

22 MR. ANZALONE: Yeah, in their evaluation
23 of the source term, they would have to justify
24 whatever is happening to the radionuclides. If
25 they're crediting retention, say, like I think we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a reasonable expectation that a lot of radionuclide,
2 especially solid fission products are going to be
3 retained within the fuel matrix. So that's just based
4 on, you know, the data that's out there.

5 But if TerraPower wants to credit that in
6 their mechanistic source term analysis, that's
7 something that they're going to have to talk about at
8 that point. That's what this limitation --

9 CHAIR KIRCHNER: Yeah.

10 MEMBER PETTI: It doesn't imply that there
11 isn't any release from cladding breach. Some fission
12 products are coming out into the sodium, sure.

13 MR. ANZALONE: Yeah.

14 MEMBER PETTI: This data. Yeah, but
15 there's a lot of other fission products --

16 MR. ANZALONE: Exactly.

17 CHAIR KIRCHNER: Steve, you have your hand
18 up.

19 DR. SCHULTZ: Yes, thank you. Reed, you
20 mentioned as you described the -- in particular the
21 methodologies that are being used to evaluate the
22 control rod performance, control element performance.

23 Do you -- can you expand on that, what
24 you're looking for in terms of what additional work
25 needs to be done there and when we can expect that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 information to come forward? Is it benchmarking, or
2 something more than that?

3 MR. ANZALONE: So that's a good question.
4 I think in general, like we -- I'm comfortable with
5 the state of things as far as having like preliminary
6 analyses to support the PSAR. I think we would want
7 the sort of more full qualification to be done before
8 the operating license, by the operating license.

9 I don't know if that answers your
10 question, though.

11 DR. SCHULTZ: Well, you specifically
12 mentioned that the methodologies would need additional
13 attention. And is that what you're referring to
14 there, that --

15 MR. ANZALONE: Yeah, yeah, that we would
16 -- that we would need to have some way of validating,
17 right, that. So say, you know, you -- there's going
18 to be a pressurization of the control rods as you, you
19 know, burn up the boron, for lack of a better word.
20 So you would want to be able to make sure that those
21 aren't going to break open and spill out all of their
22 poison.

23 So we would need to be able to see
24 eventually an evaluation of that and have some
25 confidence that the models were validated for that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: Also I would think the
2 dimensional change --

3 MR. ANZALONE: Yep.

4 MEMBER PETTI: Because of this in the past
5 some either fuel or control assemblies stick and --

6 DR. SCHULTZ: Yes.

7 MR. ANZALONE: Yeah.

8 MEMBER PETTI: There's those issues that
9 --

10 MR. ANZALONE: No, there are a lot --
11 there are a lot of different issues, yeah, absolutely.
12 I was just giving that as an example.

13 DR. SCHULTZ: Thank you, that's helpful.
14 Appreciate it.

15 MR. ANZALONE: But yeah, I think the big
16 one is like dimensional change. And you can think
17 about that either at like a pin level, right, you have
18 swelling of the pin, and then maybe that stops there
19 being appropriate cooling of the adjacent pins in the,
20 you know. They have essentially subchannels too, like
21 the fuel does. Or, at the assembly level you get
22 deformation that stops it from being able to insert.

23 So that's definitely something that we
24 want to pay attention to, because we think it's --
25 that's the key thing that drives the control rod

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 insertability, is the assembly-level deformation.

2 DR. SCHULTZ: We talked in detail about
3 the fuel, the fuel assembly qualification, fuel rod
4 qualification program that's been proposed. Are you
5 comfortable with what has been proposed with respect
6 control rod?

7 MR. ANZALONE: Yeah. And I just didn't
8 talk about it in as much detail in this presentation.
9 I would say because the criteria are different, it's
10 -- they're a little less tight because of the nature
11 of control rods and their design function. But I
12 would say that there's basically just as much in the
13 topical report about control assembly qualification as
14 there is fuel.

15 DR. SCHULTZ: Good, thank you.

16 MEMBER PETTI: So we, I know we talked
17 about this in subcommittee. The whole qualification
18 runs through all these codes. A heck of a lot of
19 computer codes need a lot of data validation. And
20 that always makes me a little bit nervous.

21 MR. ANZALONE: Yeah.

22 MEMBER PETTI: What I'm hoping is that the
23 margin that, from an engineering gut feel that you
24 have when you look at these designs, you look at
25 performance, that that can translate through those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 codes to give you the analytical margins that you need
2 when you have to go 95% confidence and stack up all
3 these (audio interference).

4 That's the one thing that it's hard to
5 see, the report doesn't really get into that at all.
6 But it's the one thing that I worry about that when
7 you get -- you don't know until you get --

8 MR. ANZALONE: Well, so it's on our minds
9 too. I will say that that is one of the things that
10 we're focused on looking at. Not this specific -- I
11 mean, it's a through line for this topical report,
12 right.

13 But it's as we're looking at like their
14 design basis accident analysis methodologies, you
15 know, we're thinking about what are their criteria
16 that are in there for fuel failure and how are they
17 actually evaluating that. So you're going to see more
18 of that as we come through the reviews.

19 MEMBER PETTI: So you know, I went back
20 and read the SER on PRISM, and there's an appendix
21 that they did, the staff had some of our labs do
22 calculations. And frankly the results, we're talking
23 1990s, really quite good comparing GE and lab tools.
24 Granted, on reactivity they used the same reactivity
25 coefficients, but still the results were really,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 really quite good.

2 But it never got into the details of fuel
3 model.

4 MR. ANZALONE: Sure.

5 MEMBER PETTI: And, you know, there's
6 always such a mixture of empiricism and semi-
7 empiricism. And now there's better models, but it
8 remains to be seen that the sharper pencil gets you
9 the answer you want.

10 This has always been one of my concerns
11 about these really cool advanced models. Hopefully
12 they verify your engineering judgment. But that all
13 of that effort gets you margin and all of that in the
14 end you stack it all together.

15 MR. ANZALONE: Yeah, totally agree. I'm
16 100% aligned on that.

17 MEMBER PETTI: Good.

18 MR. ANZALONE: And you know, one thing
19 I'll say is that we're talking to the Office of
20 Research about ways in which they can support us with
21 doing confirmatory analyses and stuff like that, as
22 was done for the PRISM review.

23 Some of those I think would use our codes,
24 some of those might use, depending on where things go,
25 you know, the NEAMS codes like BISON or what have you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for fuel performance, so.

2 MEMBER PETTI: There's some good
3 publications already out there on BISON, the amount of
4 fuel, that I found really helpful.

5 MR. ANZALONE: And I think one thing that
6 I am trying to be cognizant of when we have those
7 conversations is, you know, to what degree are --
8 because this is something that was brought up in that
9 NUREG-CR, to what degree are those mechanistic models
10 actually well-validated and is there the data to
11 support them. I think that it kind of remains to be
12 seen a little bit.

13 But TerraPower, I think that their
14 approach that they're taking is solid, so, not too
15 concerned with their modeling approach here.

16 MEMBER ROBERTS: If there's no more
17 questions from members or consultants? I guess it's
18 time now to go out for public comments.

19 If there's any members of the public who'd
20 like to make a comment, please go ahead and unmute
21 yourself, state your name and affiliation if there is
22 one, and then state your comment, please.

23 Hearing none, guess I'll turn the meeting
24 back over to Chair Kirchner.

25 CHAIR KIRCHNER: Thank you, Tom and Dave.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Thank you to the presenters, both staff and Applicant,
2 thank you.

3 And at this point, we're actually a little
4 ahead of schedule for quite a change. And so we've
5 set aside a period now to have committee deliberation
6 on what we heard on both of these topical reports.
7 And then we can proceed at this point with our letter
8 writing.

9 So, Jose, would you like to make a
10 comment?

11 MEMBER MARCH-LEUBA: Court reporter, is he
12 needed the rest of the week?

13 CHAIR KIRCHNER: Let me confer with Larry.
14 Do, at this point do we need the court reporter
15 further?

16 MR. BURKHART: I think we're going into
17 deliberation and letter writing. We can let the court
18 reporter loose.

19 CHAIR KIRCHNER: Looking at the schedule
20 for today and tomorrow, and --

21 MR. BURKHART: It is all we have left,
22 yes.

23 CHAIR KIRCHNER: We P&P tomorrow, and so
24 we --

25 MR. BURKHART: Correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Don't normally record
2 that, correct?

3 MR. BURKHART: We don't, no.

4 CHAIR KIRCHNER: With that, okay.

5 For the court reporter, thank you. I
6 don't believe that we'll need your services for the
7 rest of this meeting and this week.

8 (Whereupon, the above-entitled matter went
9 off the record at 11:11 a.m.)

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Staff Review of NATD-FQL-PLAN-0004, “Fuel and Control Assembly Qualification”

Reed Anzalone, Senior Nuclear Engineer

Mallecia Sutton, Senior Project Manager

Office of Nuclear Reactor Regulation

Division of Advanced Reactors and
Non-Power Production and Utilization Facilities

Agenda

- Topical report (TR) purpose and review strategy
- Regulatory requirements and guidance
- Overview of NUREG/CR-7305
- Safety evaluation (SE) overview
 - Fuel assembly design and qualification
 - Control assembly design and qualification
 - Surveillance, lead demonstration / lead test assemblies (LDAs/LTAs)
 - Limitations and conditions
- Conclusions

TR Purpose

- Provides plan to qualify Sodium Type 1 fuel (uranium-zirconium alloy in HT9 cladding) and Sodium control assemblies
- Requests NRC review and approval of the following:
 - Acceptance criteria are adequate to support fuel qualification
 - Identified key manufacturing parameters are adequate to support fuel qualification
 - Evaluation methods and models are adequate to support fuel qualification
 - Use of legacy data and planned testing are adequate to provide necessary information for qualification of the fuel
 - Planned use of pins outside the performance envelope of the bulk of the core or that advanced design features are acceptable
- Presents select fuel qualification results and ongoing and planned qualification activities

TR Review Strategy

- Review scope and adequacy of fuel qualification plan in the context of NUREG-2246, “Fuel Qualification for Advanced Reactors” (ML22063A131)
- Review technical details of fuel and qualification efforts against information in NUREG/CR-7305, “Metal Fuel Qualification: Fuel Assessment Using NRC NUREG-2246, ‘Fuel Qualification for Advanced Reactors’” (ML23214A065)

Regulatory Requirements

- 10 CFR 50.43(e)
 - Requires safety features to be supported by analysis, testing, operating experience, or a combination thereof.
 - Requires sufficient data exists to assess analytical tools
- 10 CFR 50.34
 - Requires applicants to evaluate a postulated fission product release from the core into containment
 - Requires principal design criteria (PDCs) to be submitted

NUREG-2246: Fuel qualification provides a means to identify safety criteria for the fuel, which then are used to establish performance criteria for facility structures, systems, and components (SSCs). Facility safety is then addressed by description and analyses of these SSCs.

Guidance

- NUREG-2246, “Fuel Qualification for Advanced Reactors”
 - Provides general guidance on fuel qualification for non-light water reactors (non-LWRs) in the form of a Fuel Qualification Assessment Framework (FQAF)
- NUREG/CR-7305 “Metal Fuel Qualification: Fuel Assessment Using NRC NUREG-2246, ‘Fuel Qualification for Advanced Reactors’”
 - Provides a generic response to NUREG-2246 for a uranium-zirconium metal fuel system, including
 - Identification of an operating envelope and key behaviors/phenomena
 - Review of available data
 - Discussion of current state of fuel performance modeling

NUREG/CR-7305 – Key Conclusions

- For fuel with geometry and operating conditions consistent with previous operating experience, “life-limiting and safety-related fuel behaviors are well known and predictable” up to 10 atom-% burnup
 - Fuel constituent redistribution is captured in data
 - FCCI is life-limiting phenomenon
 - FCMI is not a concern
- Additional transient data would help to establish safety margins
- More work is needed to qualify mechanistic models

Sodium Fuel Assembly Design

- Very similar to EBR-II fuel and metallic fuel operated at the Fast Flux Test Facility (FFTF)
- Pin characteristics:
 - Metallic uranium alloyed with 10 weight-% zirconium (U-10Zr)
 - Peak enrichment < 20%
 - 75% smear density
 - Sodium bond
 - HT9 cladding
 - Axial shield slug
 - Large plenum
 - HT9 wire wrap
- Assembly characteristics
 - Pins arranged in tight triangular pitch in hexagonal bundle
 - Hexagonal duct, inlet nozzle, handling socket
- Limited free bow core restraint system

NUREG-2246 FQAF

- G1. Fuel is manufactured in accordance with a specification
 - G1.1 Key dimensions and tolerances of fuel components are specified
 - G1.2 Key constituents are specified with allowance for impurities
 - TR includes/refers to adequate design information
 - L&C #2 covers use of materials other than U-10Zr/HT9
 - G1.3 End state attributes for materials within fuel components are specified or otherwise justified.
 - Adequate end state attributes provided

NUREG-2246 FQAF

- G2. Margin to safety limits can be demonstrated.
 - G2.1 Margin to design limits can be demonstrated under conditions of normal operation and AOOs.
 - G2.1.1 Fuel performance envelope is defined
 - Pin and assembly damage criteria consistent with key mechanisms from NUREG/CR-7305
 - Specific limits must be provided before fuel is considered qualified (L&C #1)
 - Comparison to fuel operating experience discussed later
 - G2.1.2 Evaluation model is available

NUREG-2246 FQAF

- G2. Margin to safety limits can be demonstrated.
 - G2.2 Margin to radionuclide release limits under accident conditions can be demonstrated.
 - G2.1.1 Fuel performance envelope is defined
 - G2.2.1 Radionuclide retention requirements are specified
 - Addressed in separate TR; L&C #5
 - G2.2.2 Criteria for barrier degradation and failure are suitably conservative
 - G2.2.3 Radionuclide retention and release from fuel matrix are modeled conservatively
 - Addressed in separate TR; L&C #5

NUREG-2246 FQAF

- G2. Margin to safety limits can be demonstrated.
 - G2.2 Margin to radionuclide release limits under accident conditions can be demonstrated.
 - G2.2.2 Criteria for barrier degradation and failure are suitably conservative
 - G2.3 Ability to achieve and maintain safe shutdown is assured.
 - G2.3.1 Coolable geometry is ensured
 - G2.3.2 Negative reactivity insertion can be demonstrated
- Fuel failure criteria consistent with key mechanisms from NUREG/CR-7305
- Coolable geometry criteria are consistent with NUREG/CR-7305, except molten debris ejection which is precluded by preventing fuel melt
- Negative reactivity insertion criteria are adequate
- Specific limits must be provided before fuel is considered qualified (L&C #1)

Evaluation Models

- Separate EM assessment framework in NUREG-2246
- TR does not contain detailed information on fuel performance models, staff did not fully assess against NUREG-2246 framework
- Codes discussed in TR appear to provide the capabilities needed to support fuel qualification efforts
- Additional effort is needed to demonstrate that the proposed EMs contain all necessary material and physics models, verify the EMs, and validate them against experimental data.
 - EMs will be evaluated in future revision of this TR or in a separate TR specifically covering fuel performance

Data

- Because evaluation of historical data and data collection is ongoing, focus in SE is on scope and applicability of historical data, how data supports TerraPower's acceptance criteria, and plans for future testing
- Type 1 fuel design geometry is generally consistent with metallic fuel operated at EBR-II and FFTF
 - Differences either beneficial or not expected to have much impact on applicability of historical data
- Fuel operating parameters also generally consistent with EBR-II/FFTF
 - Some parameters are at or slightly beyond historical database
 - Deltas are small, and are not expected to have much effect, will be addressed by TerraPower's planned surveillance program, and/or will be the subject of proposed testing discussed in the TR
- New data collection appropriate to fill gaps

Control Assembly Designs

- Pin characteristics
 - Natural boron carbide pellets
 - Plenum with spring
 - HT9 cladding
 - HT9 wire wrap
- Assembly characteristics
 - Triangular pitch in hexagonal lattice
 - Upper guide plate with coupling head
 - Control rod duct that moves up and down inside control assembly duct
- Primary/secondary control assembly differences
 - Number of absorber pins
 - Dimensions, including space between inner control rod duct and control assembly duct

Control Assembly Qualification

- Manufacturing
 - Control assembly manufacturing appropriately specified
- Design criteria
 - Damage, failure, and insertability criteria adequate to ensure control rods can fulfil their safety function
- Evaluation model
 - Same codes as fuel assemblies with changes for control assemblies
 - Codes appear capable but more work is needed
- Data
 - Historical data from EBR-II, FFTF, Joyo
 - Planned testing to fill gaps in historical data

Fuel Surveillance, LDAs, and LTAs

- TR presents notional surveillance plan for first several cycles
- LDAs and LTAs designed with removable pins to facilitate post-irradiation examination (PIE)
- Significant precedent for LDA/LTA program based on operating fleet
- Additional detail required on how LDAs/LTAs will be evaluated and how uncertainties in performance will be captured in analyses

L&Cs

- 1. This TR represents an acceptable approach for qualifying Sodium Type 1 fuel and control assemblies for use in a reactor but does not in and of itself demonstrate that the fuel and control assemblies are qualified. Additional activities, including those discussed in the NRC staff's SE, must be completed to execute this plan and appropriately justify that the fuel and control assemblies are qualified.
- 2. This TR addresses the material properties and performance of U-10Zr and HT9 in fuel. If other materials are used in the fuel system in licensing applications, the applicant or licensee must demonstrate that they are manufactured according to standard specifications and used consistent with their qualification under relevant NRC-accepted codes and standards, or otherwise appropriately justified.

L&Cs

- 3. This TR does not provide a means for demonstrating that proposed SARRDLs are satisfied during normal operations and AOOs for the Sodium plant. The role of the fuel acceptance criteria is to demonstrate that the fuel system is not damaged as a result of normal operations and AOOs; if these criteria are satisfied, then the fuel system need not be further assessed against the SARRDLs. However, the SARRDLs must still be evaluated against other sources of radionuclides, including circulating radionuclides resulting from an appropriate number of random fuel failures.
- 4. The [[]] have not been subject to previous NRC review or approval. If they are to be used to develop design criteria and associated limits that support fuel assembly acceptance criteria, these design criteria and associated limits must be appropriately justified.

L&Cs

- 5. This TR does not address the extent to which the fuel system is expected to retain radionuclides following a cladding breach. If an applicant or licensee wishes to qualify Sodium Type 1 fuel with an expectation that radionuclides are expected to remain within the fuel following a cladding breach, models for fuel system radionuclide retention and release must be proposed and appropriately justified by comparison to experimental data.

Conclusions

TR is acceptable for referencing in future licensing submittals, subject to limitations and conditions.

- The NRC staff determined that the TR provides an acceptable approach for qualifying fuel and control assemblies for the Sodium reactor based on
 - (1) the inclusion of sufficient information to demonstrate that fuel and control assemblies are manufactured in a process that provides adequate control over key parameters,
 - (2) the identification of appropriate safety criteria for both fuel and control assemblies,
 - (3) the development and justification of a significant applicable historical test database,
 - (4) the development of a test plan that appropriately fills gaps in the historical test database, and
 - (5) a robust fuel monitoring program, subject to the limitations and conditions discussed above. Accordingly, the NRC staff concludes that the qualification plan provided in the TR can be used to support compliance with 10 CFR 50.43(e) and proposed Sodium PDCs.

Abbreviations

ACCI – Absorber-cladding chemical interaction	PIE – Post-irradiation examination
AOO – Anticipated operational occurrence	Pu – Plutonium
CFR – <i>Code of Federal Regulations</i>	RAC – Regulatory Acceptance Criteria
EBR-II – Experimental Breeder Reactor-II	SARRDL – Specified acceptable radionuclide release design limit
EM – Evaluation model	SE – Safety evaluation
FCCI – Fuel-cladding chemical interaction	SSC – Structure, system, or component
FCMI – Fuel-cladding mechanical interaction	TR – Topical report
FFTF – Fast flux test facility	TRISO – Tri-structural Isotropic
FQAF – Fuel qualification assessment framework	U – Uranium
LDA – Lead demonstration assembly	Zr - Zirconium
LTA – Lead test assembly	
Non-LWR – Non-Light Water Reactor	
PDC – Principal design criterion	

Review Chronology


- January 25, 2023: Submittal of TR “Fuel and Control Assembly Qualification Plan,” Revision 0 (ML23025A409)
- March 21, 2023: Pre-Application Public Meeting (ML23157A332)
- March 31, 2023: TR accepted for review by the NRC staff (ML23086C087)
- April 18, 2023: Submittal of correction to TerraPower Fuel and Control Assembly Qualification Topical Report (ML23109A099)
- June, July, and August 2023: Audit Conducted (ML24043A155)
- March 20, 2024: Draft SE Issued (ML24079A118)

NUREG-2246 FQAF

G. Fuel is qualified for use.	G1. Fuel is manufactured in accordance with a specification.	G1.1 Key dimensions and tolerances of fuel components are specified.	
		G1.2 Key constituents are specified with allowance for impurities.	
		G1.3 End state attributes for materials within fuel components are specified or otherwise justified.	
	G2. Margin to safety limits can be demonstrated.	G2.1 Margin to design limits can be demonstrated under conditions of normal operation and AOOs.	G2.1.1 Fuel performance envelope is defined
			G2.1.2 Evaluation model is available
		G2.2 Margin to radionuclide release limits under accident conditions can be demonstrated.	G2.1.1 Fuel performance envelope is defined
			G2.2.1 Radionuclide retention requirements are specified
			G2.2.2 Criteria for barrier degradation and failure are suitably conservative
		G2.3 Ability to achieve and maintain safe shutdown is assured.	G2.2.3 Radionuclide retention and release from fuel matrix are modeled conservatively
			G2.3.1 Coolable geometry is ensured
		G2.3.2 Negative reactivity insertion can be demonstrated	


NUREG/CR-7305 Design Parameters

- Uranium-10 weight% zirconium alloy fuel
- 75% smear density
- 1.4 plenum to fuel volume ratio
- Sodium bond
- HT9 cladding
- Fuel dimensions from Experimental Breeder Reactor-II (EBR-II)




NUREG/CR-7305 – Fuel Geometric Evolution

- Fuel swells axially and radially until cladding contact
- Porosity interconnects and gaseous fission products are released to the plenum
- Solid fission product build up
- At >10 atom% burnup, fission gas flow through pores becomes constrained and fuel begins to swell again





NUREG/CR-7305 – Fuel Constituent Redistribution



- Thermal gradient in fuel drives redistribution of U and Zr in fuel
- Higher operating temperatures and linear heat rates drive more redistribution
- Potentially affects fuel properties, local power density
- Accounted for in experimental data below 10% burnup

NUREG/CR-7305 – Cladding Integrity/Barrier Degradation


- Fuel-cladding mechanical interaction (FCMI) not a concern below 10% burnup for fuels with 75% smear density
- Fission gas release not a concern with appropriately sized plena
- Fuel-cladding chemical interaction (FCCI) is primary source of cladding degradation and fuel failure
 - Thins cladding due to formation of low-melting point eutectics at fuel-cladding interface
 - U-Fe but also contributed to by lanthanides, which tend to migrate down thermal gradient
 - Measurable thinning at $\sim 725^{\circ}\text{C}$, NUREG/CR recommends steady-state limit of 650°C



NUREG/CR-7305 – Fuel Properties

- Porosity and redistribution evolution affect properties
- Significant margin to solidus temperature (>1100°C); bulk fuel melting is not a concern and FCCI region provides limit for fuel temperature
- Limited thermal conductivity data but favorable compared to UO₂
- Limited irradiated mechanical properties but below 10% burnup, empirical models adequately predict fuel swelling and cladding strains

NUREG/CR-7305 – Transients



- Transient testing (in-pile and out-of-pile) has been done and identified FCCI to be the primary failure mode
- Additional transient testing is needed to characterize operating envelope

G1.1 & G1.2 – Key Dimensions & Constituents

- TR refers to design drawings and materials specifications
- TR also includes details on HT9 and U-10Zr composition
- Staff audited referenced documents and found that they contained appropriate information.
- Use of materials other than U-10Zr and HT9 not clear – Limitation and Condition (L&C) 2

G1.3 – End-State Attributes

- NUREG/CR-7305 provides details on manufacturing process and important end-state attributes for U-10Zr, summarized as:
 - Injection molding with controls on formation of oxides and fuel density
 - Limited voids in sodium bond and appropriate amount of sodium
 - Fuel rod plenum sized appropriately
- Manufacturing process discussed at high level in TR, with references to specifications, including fabrication process
- Consistent with end-state attributes discussed in NUREG/CR

G2.1.1 – Fuel Performance Envelope

- TerraPower developed Regulatory Acceptance Criteria (RAC) for different mechanisms to provide an envelope in which fuel damage can be precluded
- “Damage”: Fuel has not failed but may have reduction in functional capability (i.e., outside of safety analysis assumptions)

G2.1.1 – Fuel Performance Envelope

- Pin Damage Criteria

- Stress, strain, loading
- Fatigue
- Fretting wear
- Erosion and corrosion
- Cladding damage due to FCCI
- Dimensional changes (rod bowing or swelling)
- Pin internal pressure
- Fuel and cladding temperatures

- Assembly Damage Criteria

- Stress, strain, loading
- Fatigue
- Fretting wear
- Erosion and corrosion
- Dimensional changes (duct bowing and dilation)
- Hydraulic loads exceeding hold-down
- Assembly component temperatures

G2.1.1 – Fuel Performance Envelope

- Damage mechanisms presented are consistent with key phenomena and properties from NUREG/CR-7305
- Staff did not evaluate specific limits to prevent damage, which are expected to be under development as part of fuel qualification plan (L&C 1)
- Operating envelope and comparison to historical data is discussed in more detail in experimental data assessment framework

G2.1.1 – Fuel Performance Envelope (Accidents)

- TerraPower developed separate RAC for accidents; these are assessed under separate goals for barrier failure, radionuclide retention and release, coolable geometry, and negative reactivity insertion

G2.2.1 – Radionuclide retention requirements

G2.2.3 – Radionuclide release modeling

- Addressed in separate TR (source term methodology)
- L&C 5

G2.2.2 – Barrier Degradation & Failure Criteria

- Barrier degradation criteria covered under G2.1.1
- Pin failure criteria include:
 - Cladding and slug overheating
 - For gross melting but also rapid eutectic penetration
 - Cladding deformation due to mechanical loads
 - Fuel system mechanical fracturing from externally applied forces
 - Cladding wastage (including wear, erosion, corrosion, FCCI, eutectics)
- Consistent with discussion in NUREG/CR-7305
- Future work to establish appropriate limits (L&C 1)
- Supporting data discussed in separate framework

G2.3.1 – Coolable Geometry

- TerraPower developed separate RAC related to coolable geometry:
 - Stress and strain limits to ensure coolability
 - Cladding and fuel temperatures below melting point
 - Coolability evaluations must include cladding ballooning
 - Structural deformation of fuel assemblies cannot prevent core cooling
 - Hydraulic loads cannot unseat assemblies such that flow is reduced enough to prevent assembly cooling
- Generally consistent with NUREG/CR-7305, except debris ejected from failed fuel assemblies not explicitly addressed
 - Based on historical data, preventing fuel melt precludes this issue

G2.3.2 – Negative Reactivity Insertion

- Negative reactivity insertion sensitive to control assembly distortion, unseating of control assemblies
- TerraPower developed separate RAC related to reactivity insertion:
 - Structural deformation of control assemblies will not prevent the ability to insert control rods during accidents
 - Hydraulic loads will not unseat control assemblies in a way that prevent insertion during accidents
- Other RAC also help ensure insertability:
 - Fuel and control assembly distortion
 - Fuel and absorber pin internal pressure
 - Hydraulic loading on control assemblies
 - Mechanical/neutronic design of control assemblies
- Criteria address possible mechanisms

NRC Staff Review of the Topical Report “Principal Design Criteria for the Sodium Advanced Reactor,” Revision 1

Stephanie Devlin-Gill, Senior Project Manager

Reed Anzalone, Senior Nuclear Engineer

Office of Nuclear Reactor Regulation

Division of Advanced Reactors and
Non-Power Production and Utilization Facilities

Agenda

- Topical Report (TR) purpose and review strategy
- Regulatory requirements
- Sodium principal design criteria (PDC) overview
- Key topics from ACRS subcommittee meeting
 - Functional containment
 - Specified acceptable system radionuclide release design limits (SARRDLs)
 - Limitations and conditions

TR Purpose and Review Strategy

- Purpose of TR:
 - Describe TerraPower's process for developing PDCs
 - Provide PDCs to address compliance with Title 10 of the *Code of Federal Regulations* (10 CFR) 50.34(a)(3)(i) for Construction Permit (CP) applications
 - Describe rationale for meeting the intent of Natrium PDC 26, "Reactivity Control Systems"
- Review strategy
 - Review Natrium PDC conformance with Regulatory Guide (RG) 1.232; group and evaluate deviations, considering key design features
 - Identify interaction between RG 1.232 approach and Licensing Modernization Project (LMP)
 - Review PDC 26 rationale

Regulations

- 10 CFR 50.34(a)(3)(i) requires an applicant for a CP to include the PDCs for the facility in the preliminary safety evaluation report (PSAR)
- 10 CFR 50, Appendix A provides requirements on the scope and content of PDCs for non-light water reactors (non-LWRs):
 - “The principal design criteria establish the necessary design, fabrication, construction, testing, and performance requirements for structures, systems, and components important to safety; that is, structures, systems, and components that provide reasonable assurance that the facility can be operated without undue risk to the health and safety of the public.”
 - “These General Design Criteria establish minimum requirements for the principal design criteria for water-cooled nuclear power plants similar in design and location to plants for which construction permits have been issued by the Commission. The General Design Criteria are also considered to be generally applicable to other types of nuclear power units and are intended to provide guidance in establishing the principal design criteria for such other units.”

Sodium PDC Overview

- TerraPower developed PDCs based on RG 1.232, “Guidance for Developing Principal Design Criteria for Non-Light-Water Reactors” (ML17325A611)
- Most PDCs based on SFR-DC (Appendix B of RG 1.232)
 - 1-12, 14, 15, 17-19, 21-24, 26, 28-37, 44-46, 60-64, and 70-79
- Some PDCs based on MHTGR-DC (Appendix C of RG 1.232)
 - 13, 16, 20, 25, 80, 81, and 82
 - Used to implement functional containment or reflect use of SARRDLs
- Most PDCs are modified from the RG 1.232 DC
- No DC for 38-43, 50-57 due to use of functional containment

General Changes to PDCs

- A. Use of the term “safety-significant”
- B. Use of graded approach to coolant boundary quality
- C. Use of specified acceptable system radionuclide release design limit
- D. Use of functional containment concept
- E. Minor generic changes

Functional Containment Overview (1)

- RG 1.232, Appendix C, MHTGR-DC 16 (ML17325A611):
 - “The term ‘functional containment’ is applicable to advanced non-LWRs without a pressure retaining containment structure. A functional containment can be defined as ‘a barrier, or set of barriers taken together, that effectively limit the physical transport and release of radionuclides to the environment across a full range of normal operating conditions, AOOs, and accident conditions.’”

Functional Containment Overview (2)

- SECY-18-0096 (ML18115A157) documents approach to determining functional containment performance criteria
 - Technology-inclusive, risk-informed, performance-based
 - Methodology later developed into LMP
 - Developed in parallel with RG 1.232
- **SRM-SECY-18-0096 (ML18338A502) documents the Commission's approval of the NRC staff's approach to determining functional containment performance criteria for non-LWRs.**

Non-Applicability of Containment Criteria

- TerraPower did not adopt DC 38, 39, 40, 41, 42, 43, 50, 51, 52, 53, 54, 55, 56, 57
- MHTGR-DC rationales note that these criteria are not applicable because there is not a “pressure containing reactor containment structure”
- Some relevant SFR-DC note that they would not be applicable if alternate approaches to containment were taken:
 - SFR-DC 38: “‘...as necessary...’ is meant to condition an SFR-DC 38 application to designs requiring heat removal for conventional containments that are found to require heat removal measures.”
 - SFR-DC 39 and 40 directly support 38
 - SFR-DC 50 references a containment structure; 51-57 support 50 and state they are applicable to designs employing containment structures.

Sodium Functional Containment Considerations

- SECY-18-0096 and associated SRM indicates that functional containment concept is acceptable for non-LWRs
- Staff's finding is that certain reactor attributes are necessary for functional containment approach to be viable for Sodium; actual functional containment performance remains to be demonstrated
- Use of LMP implies method used to demonstrate functional containment performance:
 - PRA and mechanistic source term analyses will be performed and must meet criteria (discussed in NEI 18-04, consistent with SECY-18-0096)
 - Analyses will explicitly consider uncertainties
 - Plant design will be evaluated for defense-in-depth adequacy per NEI 18-04

SARRDLs

- Initially identified in RG 1.232, Appendix C, MHTGR-DC 10 for TRISO
- SARRDLs are for normal operation and AOOs, are established so 10 CFR Part 20 limits are not exceeded
- SECY-18-0096, Enclosure 2 (ML18115A367):
 - “Defining SARRDLs for specific designs is intertwined with functional containment performance criteria and would be developed by reactor designers as part of the integrated approach described in this enclosure.”

Sodium SARRDL Considerations

- Staff's view is that SARRDLs are appropriate to use with functional containment and are consistent with a performance-based evaluation of releases
 - TerraPower's fuel includes fuel design limits that can be used to help evaluate compliance with SARRDLs
 - SARRDLs can be a useful tool for looking at ex-vessel events
- Means of monitoring would need to be included as part of design
- TerraPower must still propose and evaluate SARRDLs
 - SARRDLs were discussed with TerraPower in a July 11, 2023, public meeting. Closed discussion included examples.

Scope and Applicability of PDCs

- Proposed PDCs are based on RG 1.232 (traditional framework) but applied to licensing under NEI 18-04 (risk-informed, performance-based framework)
- RG 1.253 provides guidance on scope of PDCs for LMP applications: “proposed PDC will need to address the functions provided by both SR and NSRST [non-safety related with special treatment] SSCs”
- Proposed limitation 2 addresses potential gaps
 - Will be addressed in CP application

Proposed Limitations and Conditions (L&Cs)

The NRC staff imposes the following L&Cs regarding the TR:

1. An applicant or licensee referencing this TR must propose a design that is substantially similar to the Sodium design as discussed in SE Section 1, or otherwise justify that any departures from these design features do not affect the conclusions of the TR and this SE.
2. The use of this TR is restricted to those applicants using the risk-informed, performance-based licensing process described in NEI 18-04, Revision 1, as endorsed by RG 1.233. Because the proposed PDCs may not fully address all performance requirements for SSCs defined as safety-significant under the NEI 18-04 process, applicants or licensees referencing this TR must augment the PDC in the TR with appropriate PDC for any SR or NSRST SSCs whose safety function relates to BDBEs, or NSRST SSCs needed for DID adequacy, or otherwise justify that the Sodium PDCs as described in the subject TR are adequate.

Conclusions

- TerraPower considered each of the design aspects presented in RG 1.232.
- TerraPower provided a sufficient set of PDCs for the Sodium design, subject to the L&Cs.
- The PDCs (subject to the L&Cs) establish the necessary design, fabrication, construction, testing, and performance DC for safety significant SSCs to provide reasonable assurance that the Sodium reactor could be operated without undue risk to the health and safety of the public.
- The TR is suitable for referencing in future licensing applications for the Sodium advanced reactor.

Abbreviations

ARDC – Advanced reactor design criteria

AOO – Anticipated operational occurrence

BDBE – Beyond design basis event

CFR – *Code of Federal Regulations*

CP – Construction permit

DANU - Division of Advanced Reactors and
Non-Power Production and Utilization Facilities

DC – Design criterion

DBA – Design basis accident

DBE – Design basis event

GDC – General design criterion

L&C – Limitation and/or condition

LWR – Light water reactor

MHTGR – Modular high temperature gas
reactor

NEI – Nuclear Energy Institute

NRR - Office of Nuclear Reactor Regulation

NSRST – Non-safety related with special
treatment

NST – Non-safety related with no special
treatment

PDC – Principal design criterion

PSAR – Preliminary safety evaluation report

QA – Quality assurance

RAC – Reactor air cooling system

RG – Regulatory guide

SAFDL – Specified acceptable fuel design limit

SARRDL – Specified acceptable system
radionuclide release design limit

SFR – Sodium fast reactor


SSC – Structure, system, or component

SE – Safety evaluation

SR – Safety related

TR – Topical report

Natrium Functional Containment




**Sub-compartments additional confinement*

Sodium SSCs Associated with Functional Containment Strategy

- Metallic fuel matrix and cladding
- Reactor enclosure system, head access area, and primary coolant boundary
- Sodium processing system
- Sodium cover gas system
- Intermediate heat transport system
- Reactor building
- Reactor auxiliary building
- Water pool fuel handling system
- Ex-vessel fuel handling system
- In-vessel fuel handling system
- Nuclear island heating, ventilation, and air conditioning system
- Gaseous radwaste processing system

Source: Kemmerer Unit 1 PSAR (ML24088A065)

TerraPower Approach to PDC Development



¹ Use language from GDC, ARDC or MHTGR-DC, if applicable.

Topical Report Figure 1, “PDC Development Flowchart”

Natrium PDC – I. Overall Requirements

Criterion	Title	Basis DC	Modified?
1	Quality standards and records.	SFR-DC 1	Y – safety-significant
2	Design bases for protection against natural phenomena.	SFR-DC 2	Y – safety-significant
3	Fire protection.	SFR-DC 3	Y – safety-significant
4	Environmental and dynamic effects design bases.	SFR-DC 4	Y – safety-significant
5	Sharing of structures, systems, and components	SFR-DC 5	Y – safety-significant, safe shutdown

Natrium PDC – II. Multiple Barriers

Criterion	Title	Basis PDC	Modified?
10	Reactor design.	SFR-DC 10	Y – SARRDLs
11	Reactor inherent protection.	SFR-DC 11	N
12	Suppression of reactor power oscillations.	SFR-DC 12	Y – SARRDLs
13	Instrumentation and control.	MHTGR-DC 13	Y – coolant boundary
14	Primary coolant boundary.	SFR-DC 14	Y – coolant boundary
15	Primary coolant system design.	SFR-DC 15	Y – coolant boundary
16	Containment design.	MHTGR-DC 16	Y – safety-significant
17	Electric power systems.	SFR-DC 17	Y – safety-significant, SARRDLs
18	Inspection and testing of electric power systems.	SFR-DC 18	Y – safety-significant
19	Control room.	SFR-DC 19	Y – safe shutdown

Natrium PDC – III. Reactivity Control

Criterion	Title	Basis PDC	Modified?
20	Protection system functions	MHTGR-DC 20	Y – safety-significant
21	Protection system testability and reliability.	SFR-DC 21	N
22	Protection system independence.	SFR-DC 22	N
23	Protection system failure modes.	SFR-DC 23	N
24	Separation of protection and control systems.	SFR-DC 24	N
25	Protection system requirements for reactivity control malfunctions.	MHTGR-DC 25	N
26	Reactivity control systems.	SFR-DC 26	Y – SARRDLs
27	[None - incorporated into 26 consistent with RG 1.232]	N/A	N/A
28	Reactivity limits.	SFR-DC 28	Y – coolant boundary
29	Protection against anticipated operational occurrences.	SFR-DC 29	N

Natrium PDC – IV. Fluid Systems (1)

Criterion	Title	Basis PDC	Modified?
30	Quality of primary coolant boundary.	SFR-DC 30	Y – coolant boundary
31	Fracture prevention of primary coolant boundary.	SFR-DC 31	Y – coolant boundary
32	Inspection of primary coolant boundary	SFR-DC 32	Y – coolant boundary
33	Primary coolant inventory maintenance.	SFR-DC 33	Y – SARRDLs
34	Residual heat removal.	SFR-DC 34	Y – SARRDLs
35	Emergency core cooling.	SFR-DC 25	N
36	Inspection of emergency core cooling system.	SFR-DC 36	N
37	Testing of emergency core cooling system.	SFR-DC 37	Y – leaktight

Natrium PDC – IV. Fluid Systems (2)

Criterion	Title	Basis PDC	Modified?
38	[Not used – functional containment]	N/A	N/A
39	[Not used – functional containment]	N/A	N/A
40	[Not used – functional containment]	N/A	N/A
41	[Not used – functional containment]	N/A	N/A
42	[Not used – functional containment]	N/A	N/A
43	[Not used – functional containment]	N/A	N/A
44	Structural and equipment cooling.	SFR-DC 44	Y – safety-significant
45	Inspection of structural and equipment cooling systems.	SFR-DC 45	N
46	Testing of structural and equipment cooling systems.	SFR-DC 46	Y – leaktight

Natrium PDC – V. Reactor Containment

Criterion	Title	Basis PDC	Modified?
50	[Not used – functional containment]	N/A	N/A
51	[Not used – functional containment]	N/A	N/A
52	[Not used – functional containment]	N/A	N/A
53	[Not used – functional containment]	N/A	N/A
54	[Not used – functional containment]	N/A	N/A
55	[Not used – functional containment]	N/A	N/A
56	[Not used – functional containment]	N/A	N/A
57	[Not used – functional containment]	N/A	N/A

Natrium PDC – VI. Fuel and Reactivity Control

Criterion	Title	Basis PDC	Modified?
60	Control of releases of radioactive materials to the environment.	SFR-DC 60	N
61	Fuel storage and handling and radioactivity control.	SFR-DC 61	Y – safety-significant
62	Prevention of criticality in fuel storage and handling.	SFR-DC 62	N
63	Monitoring fuel and waste storage.	SFR-DC 63	N
64	Monitoring radioactivity releases.	SFR-DC 64	Y – functional containment

Natrium PDC – VII. Additional PDC

Criterion	Title	Basis PDC	Modified?
70	Intermediate coolant system.	SFR-DC 70	N
71	Primary coolant and cover gas purity control.	SFR-DC 71	N
72	Sodium heating systems.	SFR-DC 72	Y – safety-significant
73	Sodium leakage detection and reaction prevention and mitigation.	SFR-DC 73	Y – safety-significant
74	Sodium/water reaction prevention/mitigation.	SFR-DC 74	N
75	Quality of the intermediate coolant boundary.	SFR-DC 75	Y – safety-significant
76	Fracture prevention of the intermediate coolant boundary.	SFR-DC 76	Y – coolant boundary
77	Inspection of the intermediate coolant boundary.	SFR-DC 77	Y – safety-significant
78	Primary coolant system interfaces.	SFR-DC 78	Y – safety-significant, SARRDLs
79	Cover gas inventory maintenance.	SFR-DC 79	N
80	Reactor vessel and reactor system structural design basis.	MHTGR-DC 70	N
81	Reactor building design basis.	MHTGR-DC 71	Y – MHTGR-specific language
82	Provisions for periodic reactor building inspection.	MHTGR-DC 72	Y – MHTGR-specific language

A. Use of the term “safety-significant”

- Change: *Replace “important to safety” from RG 1.232 DC with “safety-significant” to align with language from NEI 18-04*
- RG 1.233: “Applicants referencing this RG are expected to use the terminology in NEI 18-04”
- DANU-ISG-2022-01, “Review of Risk-Informed, Technology-Inclusive Advanced Reactor Applications—Roadmap” (ML23277A139) identified that there may be some SSCs that may be “important to safety” but not “safety-significant” per NEI 18-04 process
 - No gap because of use of RG 1.232 DC (e.g., those related to managing and monitoring effluents resulting from normal operations)

B. Use of graded approach to coolant boundary quality

- Change: *Modified to indicate “safety-significant elements” of the primary or intermediate coolant boundary*
- Consistent with NEI 18-04 approach, not all elements of primary coolant boundary are considered safety-related (SR) *a priori*
 - Proper application of NEI 18-04 would appropriately classify structures, systems, and components (SSCs), resulting in quality, design, and performance requirements commensurate with safety significance
- SE notes that if primary coolant boundary components are not SR, an exemption may be needed from regulations

C. Use of SARRDLs

- Change: *SARRDLs used instead of specified acceptable fuel design limits (SAFDLs)*
- SARRDLs are compatible with Sodium design/licensing approach
 - High-reliability metallic fuel chemically compatible with coolant
 - Can establish fuel design limits as surrogates for SARRDLs
- SARRDLs are consistent with NEI 18-04 process that requires mechanistic source term evaluations
- SARRDLs provide appropriate performance-based approach to determining functional containment performance criteria
- Same basis as SARRDLs in RG 1.232
- **No staff determination on specific SARRDLs**

D. Use of functional containment concept

- *Change: Adoption of functional containment DC and non-inclusion of containment building DC*
- Per previous discussion on SARRDLs, functional containment is also compatible with Sodium design and NEI 18-04 process
 - Low-pressure operation
 - Margin to coolant boiling
 - Chemical compatibility between fuel and coolant
 - Lack of sodium-water interaction
- **No staff determination on specific functional containment barriers or performance**

E. Other generic changes

- Change: *Adoption of MHTGR-DC without MHTGR-specific language*
 - MHTGR language related to helium removed; no helium in Sodium
- Change: *Use of the term “safe shutdown”*
 - Sensitivity to “cold shutdown” for SFRs, coolant freezes at ambient temp
 - Change is consistent with RG 1.232, SECY-94-084, and NEI 18-04/RG 1.233
- Change: *Leak-tightness of cooling systems*
 - Anticipated in RG 1.232
 - Natural draft air circulation system used for emergency core cooling
 - Some amount of leakage not anticipated to impact ability of system to perform safety function