



July 30, 2024

L-2024-121

U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001  
ATTN: Document Control Desk

SUBJECT: St. Lucie Units 1 and 2  
DOCKET NO: 50-335 and 50-389

St. Lucie Unit 1 Subsequent License Renewal Commitment #30 Revision

References:

1. Safety Evaluation Report, Revision 1, "Related to the Subsequent License Renewal of St. Lucie Plant, Units 1 and 2," September 2023 (ADAMS Accession No. ML23219A003)
2. Florida Power & Light Company letter L-2021-142, Application for Subsequent Renewed Facility Operating Licenses (ADAMS Package Accession No. ML21215A314)

Florida Power & Light Company (FPL) hereby submits this notification of a regulatory commitment change for St. Lucie Units 1 and 2. Reference 1 Section 3.0.3.3.23 documented that Appendix A1 – Unit 1 Updated Final Safety Analysis Report Supplement in Reference 2 provided commitments, i.e., Table 19-3, List of Unit 1 SLR Commitments and Implementation Schedule. Commitment #30 regarding Buried and Underground Piping and Tanks included a schedule to install cathodic protection systems no later than 10 years prior to the subsequent period of extended operation (SPEO) (03/01/2026).

St. Lucie Unit 1 cathodic protection systems will be installed and operational by the end of 2029; consequently, Buried and Underground Piping and Tanks Program inspections will be delayed to the end of 2029. FPL is revising the Implementation Schedule of Commitment #30 to read,

"Program inspections begin 6 years before the SPEO. Inspections that are to be completed prior to the SPEO are completed 6 months prior to the SPEO or no later than the last refueling outage prior to the SPEO. Install cathodic protection systems at least 6 years before the SPEO. Program and SLR enhancements are implemented 6 months prior to the SPEO, i.e.: PSL1: 09/01/2035"

Should you have any questions regarding this submission, please contact Mr. Kenneth Mack, Senior Manager, Licensing and Regulatory Compliance at 561-904-3635.

Sincerely,



---

Paul Rasmus  
General Manager, Regulatory Affairs

cc: USNRC Regional Administrator, Region II  
USNRC Project Manager, St. Lucie Nuclear Plant, Units 1 and 2  
USNRC Senior Resident Inspector, St. Lucie Nuclear Plant, Units 1 and 2  
Mr. John Williamson, Florida Department of Health