



Global Nuclear Fuel

Global Nuclear Fuel

Scott P. Murray
Manager, Facility Licensing

3901 Castle Hayne Road
P.O. Box 780
Wilmington, NC 28402
USA

T (910) 819-5950
scott.murray@ge.com

M240162

August 6, 2024

Attn: Document Control Desk
Director, Office of Nuclear Material Safety and Safeguards
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Subject: GNF-A Semi-Annual Effluent Monitoring Report

References: 1) NRC License SNM-1097, Docket 70-1113
2) NRC Regulation 10 CFR 70.59

Dear Sir or Madam:

With respect to activities authorized by NRC License SNM-1097, the Global Nuclear Fuel-Americas, L.L.C. (GNF-A) facility in Wilmington, North Carolina hereby submits the semi-annual effluent monitoring report required by 10 CFR 70.59 for the period of January through June 2024.

If you have any questions regarding this report, please contact me at (910) 819-5950.

Sincerely,


Scott Murray, Manager
Facility Licensing

Attachment: 1) Semi-Annual Effluent Monitoring Report (January- June 2024)

cc: NRC Region II Administrator, Atlanta, GA
J. Rowley, USNRC/NMSS/DFM/FFLB
C. Ubben, USNRC/RII/DFFI
J. Hall, NCDHHS
D. Crowley, NCDHHS
S. Breitmaier, ANI
SPM 24-036

SEMI-ANNUAL EFFLUENT REPORT

Global Nuclear Fuel - Americas, LLC
Wilmington, North Carolina

January 2024 - June 2024

NRC License SNM 1097, Docket # 70-1113

Fiscal Weeks 1-26

I. GASEOUS EFFLUENT-PARTICULATE

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	¹ APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE mrem	CDE (Lung) mrem
U234	9.15E-06	5.17E-15	5 E-12	0.10%	2.58E-02	2.17E-01
U235	3.83E-07	2.05E-16	6 E-12	0.00%	8.60E-04	7.16E-03
U236	1.79E-09	1.01E-18	6 E-12	0.00%	4.23E-06	3.53E-05
U238	1.21E-06	6.84E-16	6 E-12	0.01%	2.87E-03	2.39E-02
TOTAL	1.07E-05	---	---	---	2.96E-02	2.48E-01

EXHAUST VOLUME = 1.77E+15 (cc)

² Nuclide	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	¹ APPENDIX B Limit (uCi/cc)	% of LIMIT	CEDE (mrem)
H-3	4.19E-03	4.43E-11	1E-05	0.00%	1.11E-04

EXHAUST VOLUME = 9.44E+13 (cc)

II. LIQUID EFFLUENT

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	¹ APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE (mrem)	CDE (Lung) (mrem)	CDE (Bone Surface) (mrem)
U234	6.83E-03	3.04E-08	3 E-07	10.12%	2.22E-06	1.40E-06	3.22E-05
U235	2.71E-04	1.20E-09	3 E-07	0.40%	1.25E-07	7.94E-08	1.81E-06
U236	1.33E-06	5.93E-12	3 E-07	0.00%	4.09E-10	2.61E-10	5.93E-09
U238	9.04E-04	4.02E-09	3 E-07	1.34%	2.65E-07	1.69E-07	3.85E-06
TOTAL U	8.01E-03	---	---	---	2.61E-06	1.65E-06	3.78E-05

TOTAL VOLUME OF LIQUID EFFLUENT = 2.25E+08 (liters)

III. ABNORMAL RELEASES

	Air	Water	Total
# Releases	0	0	0
Activity Released (Ci)	0	0	0

IV. SUMMARY

	³ Max Release (uCi/cc)	CEDE, total (mrem)	CDE (Lung), total (mrem)
Value	3.04E-08	2.97E-02	2.48E-01
Limit	3.00E-07	25	25
% of Limit	10.12%	0.12%	0.99%

¹ Limit from 10 CFR 20 Appendix B, Table 2, Columns 1 and 2. Air limit adjusted to reflect NRC License SNM-1097, Section 1.3.9.

² This nuclide is included due to the the neutron generator licensed by the State of North Carolina.

³ From nuclide with release that is the largest percentage of its release limit.

Notes:

Air sampling is continuous. H-3 gaseous effluent is calculated. Water samples analyzed are representative, continuous composite samples of the process effluent stream.

Reported effluent concentration values are representative of the effluent concentration at the point of release and do not consider effects of dilution from point of release to the plant site boundary.