



BWX Technologies, Inc.

August 16, 2024
24-041

ATTN: Document Control Desk
Director, Office of Nuclear Material Safety & Safeguards
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Reference: License No. SNM-42, Docket 70-27

Subject: Semi-Annual Effluent Monitoring Report

Dear Sir or Madam:

The Semi-Annual Effluent Report for the BWXT Nuclear Operations Group, Inc., Lynchburg (NOG-L) facility covering the first semi-annual effluent monitoring period for 2024 is enclosed. This report is being submitted in accordance with the requirements of 10 CFR 70.59.

If you have questions or require additional information, please contact Daniel Ashworth, Manager of Licensing and Safety Analysis, at dashworth@bwxt.com or 434-522-5472.

Sincerely,

Richard J. Freudenberger
Manager, Environment, Safety, Health & Safeguards
BWXT Nuclear Operations Group, Inc. – Lynchburg

Enclosure

cc: NRC, Region II
NRC, Resident Inspector

IE 48
NMSS20
NMSS

ENCLOSURE

7 pages

I. GASEOUS EFFLUENTS (Continuously Sampled Stacks)

Reporting Period: 1/1/24 to 6/30/24 (Weeks Ending 1/7/24 to 6/30/24)

Stack: WASTE MGMT CENTER (# 39)

Average Flow Rate: 1.34 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	0.0E+00	0.0E+00

Stack: 2A STACK (# 23)

Average Flow Rate: 1.09 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	1.0E-14	1.0E-14	3.0E-14	1.9E-01	1.0E-04

Stack: 2A PRODUCTION SUPPORT (# 44)

Average Flow Rate: 1.00 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	1.00E-14	1.0E-02	5.4E-06

Stack: 1A MAINTENANCE (# 43)

Average Flow Rate: 4.03 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	3.0E-02	1.6E-05

I. GASEOUS EFFLUENTS (Continuously Sampled Stacks)

Reporting Period: 1/1/24 to 6/30/24 (Weeks Ending 1/7/24 to 6/30/24)

Stack: 3A PHARMACY (# 24)

Average Flow Rate: 1.25 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	1.0E-14	4.0E-02	2.2E-05

Stack: NMC STORAGE (# 42) or Bay 17

Average Flow Rate: 0.76 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	2.0E-02	9.6E-06

Stack: MET LAB (# 26)

Average Flow Rate: 4.63 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	2.3E-01	1.2E-04

Stack: 3A Stack (# 18)

Average Flow Rate: 1.33 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	1.0E-14	1.0E-14	3.0E-14	2.4E-01	1.3E-04

I. GASEOUS EFFLUENTS (Continuously Sampled Stacks)
 Reporting Period: 1/1/24 to 6/30/24 (Weeks Ending 1/7/24 to 6/30/24)

Stack: U-MOL (# 45)
 Average Flow Rate: 5.17 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	3.0E-02	1.5E-05

Stack: RTRT (# 16)
 Average Flow Rate: 6.60 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	1E-14	<1.0E-14	<1.0E-14	6.1E-01	3.0E-04

Stack: SFF (# 11)
 Average Flow Rate: 8.64 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	1.00E-14	<1.0E-14	1.0E-14	7.1E-01	4.2E-04

Stack: 13A/14A/15A DRY (# 38)
 Average Flow Rate: 16.20 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	1.0E-14	1.0E-14	2.0E-14	2.6E+00	1.5E-03

Stack: CHEM LAB SCRUBBER (# 37)
 Average Flow Rate: 11.00 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	1.0E-14	<1.0E-14	1.0E-14	1.5E+00	8.7E-04

I. GASEOUS EFFLUENTS (Continuously Sampled Stacks)

Reporting Period: 1/1/24 to 6/30/24 (Weeks Ending 1/7/24 to 6/30/24)

Stack: 14A MAINTENANCE (# 35)

Average Flow Rate: 2.97 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	1.0E-14	3.0E-14	1.1E-01	6.5E-05

Stack: RECOVERY (# 15)

Average Flow Rate: 9.56 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (F)	1.40E-13	2.00E-14	6.00E-14	2.18E+01	1.50E-04

Stack: LAUNDRY STACK (# 30)

Average Flow Rate: 3.04 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	3.0E-14	1.0E-14	3.0E-14	1.5E+00	9.4E-04

Stack: COMPACTOR (# 32)

Average Flow Rate: 1.79 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	3.0E-02	1.9E-05

Stack: RETENTION TANKS (# 36)

Average Flow Rate: 0.63 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	2.0E-02	1.3E-05

I. GASEOUS EFFLUENTS (Continuously Sampled Stacks)

Reporting Period: 1/1/24 to 6/30/24 (Weeks Ending 1/7/24 to 6/30/24)

Stack: WT SCRUBBER (# 31)

Average Flow Rate: 1.13 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	4.00E-13	2.00E-14	3.00E-14	7.16E+00	4.40E-03

Stack: DECON (# 33)

Average Flow Rate: 1.84 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-234 (S)	<1.0E-14	<1.0E-14	<1.0E-14	7.0E-02	4.4E-05

Stack: LTC 50 METER STACK

Average Flow Rate: 16.64 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
U-238 (S)	<1.00E-14	<1.00E-14	<1.00E-14	1.40E-02	1.00E-06
H-3 (V)	4.63E-12	4.08E-13	<1.00E-14	1.21E+03	* Note
Th-230 (S)	<1.00E-14	<1.00E-14	<1.00E-14	6.91E-03	* Note

* Note: Th-230 & H-3 activity is included in the Comply Calculated Dose of 1.00E-6 mRem

Stack: LTC ACL STACK

Average Flow Rate: 1.44 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
N/A	N/A	N/A	N/A	N/A	0.00E+00

Stack: LTC RCL STACK

Average Flow Rate: 1.64 cubic meters/second

Radionuclide	Concentration ($\mu\text{Ci/ml}$)	Error Estimate ($\mu\text{Ci/ml}$)	MDC ($\mu\text{Ci/ml}$)	Quantity Released (μCi)	Off-Site Dose (mrem)
N/A	N/A	N/A	N/A	N/A	0.00E+00

I. GASEOUS EFFLUENTS (Continuously Sampled Stacks)

Reporting Period: 1/1/24 to 6/30/24 (Weeks Ending 1/7/24 to 6/30/24)

NOTES:

- (1) The total exposure from all stacks is 0.0091 mrem. Doses were determined using the EPA COMPLY code. Actual stack and building heights were used. A distance from source to receptor of 540 meters was used, with wind blowing towards the receptor at a speed of 2 meters/sec, 25% of the time. Other default parameters such as temperature were used if prompted. Comply itself is conservative.
- (2) All alpha activity is conservatively reported as U-234 for the NOG-L Stacks as this is the predominant uranium nuclide and has the most conservative dose conversion factor of the various uranium isotopes. No nuclides other than Uranium were found in the NOG-L Stack Semi-Annual Composite Samples. For the LTC Stacks each nuclide above MDC is reported.
- (3) Beta/Gamma nuclides are not reported unless they exceed the respective MDC based on isotopic analysis.
- (4) Average concentrations, errors and MDCs are quoted as $1\text{E-}14$ $\mu\text{Ci/ml}$ for stacks when these values are between $5\text{E-}15$ $\mu\text{Ci/ml}$ and $1\text{E-}14$ $\mu\text{Ci/ml}$, and they are quoted as $<1\text{E-}14$ $\mu\text{Ci/ml}$ when the values are less than $5\text{E-}15$ $\mu\text{Ci/ml}$.
- (5) Activities are quoted as $1\text{E-}02$ μCi when these values are between $5\text{E-}03$ μCi and $1\text{E-}02$ μCi , and they are quoted as $<1\text{E-}02$ μCi when the values are less than $5\text{E-}03$ μCi . $5\text{E-}03$ μCi is conservatively used to calculate the offsite dose when the activity is $<1\text{E-}02$ μCi .
- (6) The error estimate is the daily error at the 95% confidence interval propagated over the six month period.
- (7) Quantity released (μCi) is the sum of the activities calculated daily based on the calculated daily concentration for all concentrations > 0 .
- (8) Twenty three (23) stacks were monitored during this monitoring period.
- (9) Average concentrations, errors and MDCs are quoted to one significant digit except for the Recovery, Waste Treatment, and three LTC stacks.

II. LIQUID EFFLUENT

A. Reporting Period: 01/01/24 to 06/30/24

B. Location of Sample: Collection Prior to Discharge into the James River.

C. Total Liquid Flow: 3.45E+08 liters

D. Sample Collection: Batch composite sampler.

Radionuclide	Concentration (pCi/l)	Error Estimate (±pCi/l)	MDC (pCi/l)	Quantity	
				Released (μCi)	Total Dose (mrem)
U-234	5.29E+01	1.05E+01	1.72E-01	18,233.29	1.71E-01
U-235	1.52E+00	8.09E-01	1.25E-01	523.51	4.62E-03
U-236	5.02E-01	4.64E-01	1.37E-01	173.18	1.54E-03
U-238	9.55E-01	6.20E-01	1.42E-01	329.38	2.78E-03

Total 1.80E-01

NOTES:

- (1) The total dose calculated for liquid release uses a dilution factor of 18:1. Regulatory Guide 1.109 was used as guidance, with conservative assumptions to estimate the exposure.
- (2) The semi-annual concentration reported above is a volume-weighted average for the six months and may be less than the averaged MDC for the same period.
- (3) Isotopic analysis is performed on the monthly composite samples for the most commonly utilized beta/gamma nuclides such as Sr-90, Tc-99 and Cs-137. The analysis of these nuclides typically indicates results less than minimum detectable concentration (MDC). No nuclide with a concentration above the respective MDC was reported.