

September 17, 2024

Attn: Document Control Desk
 U.S. Nuclear Regulatory Commission (NRC)
 Washington, D.C. 20555-0001
 Fax: (301) 816-5151

Subject: RSCC Wire & Cable LLC – Interim update to Part 21 Retraction of Final Notification

Dear Sir or Madam,

This letter to the Nuclear Regulatory Commission (NRC) is an interim update to the shipment of non-compliant material in accordance with 10 CFR 21.21(d)(4).

On September 6, 2024 RSCC submitted a retraction of Final Notification request.

In the interim, RSCC has completed the corrective actions originally outlined in our August 23, 2024 letter which included implementing electronic HOLD processes in our ERP system for work orders with applied nonconformances(s), adding verifications that all applicable nonconformance(s) are resolved prior to shipment, and additional independent verification at final document review. We have also scheduled (first week October) a third-party review of our Off Standard Reporting (non-conforming product) and Release for Shipment Processes that encompass the above-listed corrective actions.

Our containment activities are ongoing, and we estimate completion for September 30th. We have identified one additional customer that received non-compliant material, and this customer was immediately notified.

RSCC Sales Order Number	Customer	Plant	Customer PO Number	Part Number	Ship Date	Quantity - FT
139430	Curtiss - Wright Nuclear Division	Middleburg Heights, OH	3220543	C530070	3/29/2024	100

Upon completion, it is our intention to update and re-submit our Attachment 1: Customer Exhibit (which lists all impacted customers and products) and Attachment 2: Transfer of Information per 10 CFR 21.21(d)(4) documents.

If you have any questions related to this issue, the evaluation, and/or corrective action(s), please contact me at the number listed below my name.

Sincerely,

Phillip Sargenski
 Quality Assurance Manager
 Direct: 860-653-8376
 Phillip.sargenski@marmoniei.com