TERRAPOWER, LLC - AUDIT SUMMARY REPORT, TOPICAL REPORT "NATRIUM HUMAN FACTORS ENGINEERING PROGRAM PLAN AND METHODOLOGIES," REVISION 0

Applicant:	TerraPower, LLC
Applicant Address:	15800 Northup Way, Bellevue, WA 98008
Plant Name:	Natrium
Project No.:	99902100

#### 1.0 BACKGROUND

By letter dated April 26, 2023, TerraPower, LLC (TerraPower) submitted topical report (TR) NAT-2965, "Natrium Human Factors Engineering Program Plan and Methodologies" Revision 0 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML23116A225), to the U.S. Nuclear Regulatory Commission (NRC) staff. The TR describes the Natrium Human Factors Engineering (HFE) Program Plan (HFEPP), including related methodologies, and requests that the NRC staff review and approve to support referencing of the report in future licensing submittals. By email dated June 21, 2023, the NRC staff informed TerraPower that the TR provided sufficient information for the NRC staff to conduct a detailed technical review (ML23167A476).

TerraPower's overall licensing approach for the Natrium reactor design follows the Licensing Modernization Project (LMP) methodology described in Nuclear Energy Institute (NEI) 18-04, Revision 1, "Risk-Informed Performance-Based Technology Inclusive Guidance for Non-Light Water Reactor Licensing Basis Development" (ML19241A472). Regulatory Guide (RG) 1.233, "Guidance for a Technology-Inclusive, Risk-Informed, and Performance-Based Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light Water Reactors," Revision 0 (ML20091L698) endorses the LMP methodology described in NEI 18-04.

The NRC staff provided its audit plan for the subject TR to TerraPower dated on May 28, 2024 (ML24137A289). The audit was conducted virtually from June 13, 2024, through August 6, 2024, using TerraPower's electronic reading room (ERR). The NRC staff held an audit exit meeting with TerraPower on August 6, 2024. By letter dated September 17, 2024, TerraPower submitted a revision to the subject TR, NAT-2965, "Natrium Human Factors Engineering Program Plan and Methodologies," Revision 1 (ML24261B926), which is a result of the audit discussions between the NRC staff and TerraPower, as summarized below.

#### 2.0 AUDIT REGULATORY BASES

The basis for the NRC staff audit includes the following key regulations, guidance, and standards (which are also referenced by TerraPower in the TR):

• Title 10 of the *Code of Federal Regulations* (10 CFR) 50.34(f)(2)(ii), which states, in part, "establish a program, to begin during construction and follow into operation, for integrating and expanding current efforts to improve plant procedures. The scope of the **OFFICIAL USE ONLY – PROPRIETARY INFORMATION** 

- 2 -

program shall include emergency procedures, reliability analyses, [HFE], crisis management, operator training..."

- 10 CFR 50.34(f)(2)(iii), which states, in part, "provide, for Commission review, a control room design that reflects state-of-the-art human factor principles prior to committing to fabrication or revision of fabricated control room panels and layouts."
- NUREG-0700, "Human-System Interface Design Review Guidelines," Revision 3 (ML20162A214)
- NUREG-0711, "[HFE] Program Review Model," Revision 3 (ML12324A013)
- NUREG-1764, "Guidance for the Review of Changes to Human Actions," Revision 1 (ML072640413)

## 3.0 AUDIT PURPOSE AND OBJECTIVES

The purpose of the audit was for the NRC staff to gain a more detailed understanding of the Natrium HFEPP and how the HFEPP will support or demonstrate compliance with NRC regulations as discussed below. In section 2.0 of the TR, "Requirements and Technical Basis," TerraPower states that the HFEPP creates an HFE program that is compliant with the requirements of 10 CFR 50.34(f)(2)ii and 50.34(f)(2)iii. TerraPower states in the TR that the HFEPP considers relevant practices provided in NUREG-0711. A secondary purpose of the audit was to identify any information that will require docketing to support the NRC staff's safety evaluation (SE).

## 4.0 SCOPE OF THE AUDIT AND AUDIT ACTIVITIES

The audit followed the guidance in the Office of Nuclear Reactor Regulation's Office Instruction LIC-111, "Regulatory Audits," Revision 1 (ML19226A274). Audit activities included virtual meetings to discuss questions and review of files in the ERR.

Members of the audit team included the NRC staff Jesse Seymour (Senior Reactor Engineer (Examiner), Audit Lead) and Stephanie Devlin-Gill (Senior Project Manager, Audit Manager).

The participants from TerraPower for this audit were Patrick Alexander, Patrick Donnelly, Timothy Enfinger, Stephanie Foerester, Jamie Getchius, Jeffrey Grogan, Kenny Grover, Nick Kellenberg, Daniel Laughman, Gabrielle Schreier, and Mark Verbeck.

On August 6, 2024, the NRC staff held an audit exit meeting with TerraPower and summarized the audit purpose, activities, and high-level results, including the NRC staff's plan to include limitations and conditions (L&C) in the NRC staff's SE regarding various topics discussed during the audit. The NRC staff did not acquire any documents during the audit. The NRC staff reviewed the following document during the audit using TerraPower's ERR:

• ADI-RMD-102, "Procedure Writer's Manual" (Revision 1), dated June 13, 2024

#### 5.0 SUMMARY OF OBSERVATIONS

As indicated in the NRC staff's audit plan, the audit was focused on specific inquiries pertaining to the content of the TR. The NRC staff reviewed information through the TerraPower ERR and held discussions with TerraPower to understand and resolve questions. The table below replicates the transmitted audit questions and summarizes the resolution of the questions.

- 4 -

Number	Question	Resolution of Question
	TR section 1, "Introduction"	1.a: TerraPower clarified that staffing assumptions were
	a. Criterion 2.4.1(2): The design assumptions and	included in the "Natrium "Human Factors Engineering
	constraints of the HFE program (i.e., aspects of the	Concept of Operations" white paper (WP)
	design that are inputs to the HFE program) are not	(ML23125A328) and that the staffing is both assumed
	described. The NRC staff request that TerraPower	to meet the requirements of 10 CFR 50.54(m) and
	identify these design assumptions and constraints.	expected to align with what will be included in the
	b. Criterion 2.4.1(3): The duration of the HFE program	Operating License Application (OLA). Additionally,
	is not described. The NRC staff request that	TerraPower confirmed that no other assumptions or
	TerraPower clarify whether the HFE program will	constraints have been identified that apply to the
1	be in effect from the start of the design cycle	general HFE program. TerraPower agreed to address
	through completion of the initial plant startup test	this item via changes incorporated into a revision of the
	program.	TR.
	c. Criterion 2.4.1(4): The Energy Island (EI) is not	
	addressed within the programmatic scope	1.b: TerraPower agreed to address this item via
	discussion (i.e., only a Nuclear Island (NI) control	changes incorporated into a revision of the TR.
	room is discussed). The NRC staff request that	
	TerraPower clarify whether a separate control room	1.c: TerraPower agreed to address this item via
	will exist for the EI and whether it will be included	changes incorporated into a revision of the TR.
	within the scope of the HFEPP.	
	Criterion 2.4.1(6): section 5.4, "Staffing," of the TR	TerraPower clarified that they will request an exemption
	describes that a staffing analysis process systematically	in conjunction with the OLA to omit the STA, with HFE
	determines the minimum staff complement. However,	program activities under the HFEPP serving to provide
2	the TR does not include discussion of the Shift Technical	support for the justification of this requested exemption.
	Advisor (STA) role. The NRC staff request that	The NRC staff have identified this area as being the
	TerraPower clarify whether the HFEPP is intended to be	subject of a potential L&C for the TR in the NRC staff's
	utilized in conjunction with a future justification for	SE.
	omission of the STA from the staffing model.	
	Criterion 2.4.2(2): section 4.0, "Human Factors	lerraPower clarified that their organization will use
	Engineering Organization," of the TR provides a	established processes and procedures to identify,
	description of the HFE organization. However, details	understand, and resolve issues relating to the HFE
3	related to the organizational relationships, reporting	scope. TerraPower described that GE Hitachi Nuclear
	relationships, and lines of communication associated	Energy (GE Hitachi) statts the core HFE team, to
	with this team are unclear. The NRC staff requests that	
	I erraPower clarify how the HFE team will have the	Technical Lead coordinates design activities with the
	authority and appropriate organizational placement to	I erraPower HFE Program Owner who, in turn, provides

- 5 -

Number	Question	Resolution of Question
	assure that its areas of responsibility can be completed, to identify problems in establishing the overall HFE plan, and to control further processing, delivery, installation, or use of HFE products until any nonconformances, deficiencies, or unsatisfactory conditions have been adequately resolved.	oversight. The TerraPower HFE Program Owner is described as having responsibility for ensuring the communication, reporting, and processing of HFE concerns is advocated and resolved through the TerraPower design organization. The TerraPower HFE Program Owner reports to the Manager, Plant Maintenance and Operational Design Integration who, in turn, reports to the Senior Manager, Integrated Pant and Structure. The Senior Manager, Integrated Plant and Structure, serves as the technical design authority and senior-level advocate for HFE and reports to the Vice President of Plant Delivery. TerraPower agreed to address this item via changes incorporated into a revision of the TR.
4	<ul> <li>Criterion 2.4.2(3): section 4.1.1, "Roles," of the TR describes the roles and qualifications of the HFE team and states that this definition of roles is based on NUREG-0711. However, the description provided in the HFEPP does not fully conform to the guidance of NUREG-0711 in this area and clarification is needed regarding how the HFEPP addresses the following aspects of team roles and qualifications from the NUREG-0711 appendix, "Composition of the HFE Design Team":</li> <li>The typical contribution of Nuclear Engineering to "provide knowledge of the processes involved in controlling reactivity and generating power."</li> <li>The minimum qualifications of Instrumentation and Control (I&amp;C) Engineering to have "familiarity with the theory and practice of software quality assurance programs."</li> </ul>	<ul> <li>TerraPower provided the following clarifications:</li> <li>TerraPower considered "that knowledge of the processes involved in controlling reactivity and generating power" would be part of the aggregate knowledge of plant operations provided in the HF Operations/Maintenance role included in section 4.1.1, sub-bullet C, "HF Operations/Maintenance," of the TR. TerraPower agreed to address this item via changes incorporated into a revision of the TR.</li> <li>TerraPower did not include statements around software quality assurance and control because, though the importance is recognized, it is not a point of collaboration with the core HFE team for the HFE program.</li> <li>TerraPower did not specify qualification requirements for the extended team, such as Architect Engineering, because TerraPower considered to be beyond the purview of the HFE program. It was further discussed that the qualification process is expected to be defined and implemented through the applicable performer's</li> </ul>

- 6 -

Number	Question	Resolution of Question
	<ul> <li>The minimum qualification of Architect Engineering to have "4 years of experience in the design of power plant control rooms."</li> <li>The minimum qualifications of Computer System Engineering, including degree and experience requirements.</li> <li>The minimum qualifications of Plant Procedure Development to have "4 years of experience in developing procedures for nuclear power plants," and the expected typical contributions of the position.</li> <li>The minimum qualifications of Personnel Training to have "4 years of experience in developing personnel training programs for power plants" and "experience in applying the systems approach to training," in addition to the expected typical contributions to "develop content and format of personnel training programs for licensed and non-licensed plant personnel" and to "coordinate training issues arising from activities."</li> </ul>	<ul> <li>quality programs. TerraPower agreed to address this item via changes incorporated into a revision of the TR.</li> <li>TerraPower clarified that it does not have a separate Computer System Engineering team, as the capabilities are included with I&amp;C Engineering. TerraPower further clarified that they did not specify qualification requirements for the extended team as those qualification processes are defined and implemented through the applicable performer's quality programs. TerraPower agreed to address this item via changes incorporated into a revision of the TR.</li> <li>TerraPower clarified that plant procedures are not being developed by the core HFE team or by engineering, so the related qualifications and contributions were not included. Instead, TerraPower stated that plant procedure development will be performed by the US SFR Owner, LLC (USO) in accordance with the administrative procedures described in the Construction Permit Application for the Natrium Reactor Plant, Kemmerer Power Station (Kemmerer), Unit 1, Preliminary Safety Analysis Report (PSAR) section 11.1.4, "Operating Organization and Technical Support" (ML2408A065). TerraPower agreed to address this item via changes incorporated into a revision of the TR.</li> <li>Personnel training is not being developed by the core HFE team or by engineering, so the related qualifications and technical Support" (ML2408A065). TerraPower agreed to address this item via changes incorporated into a revision of the TR.</li> <li>Personnel training is not being developed by the core HFE team or by engineering, so the related qualifications and contributions were not included. Personnel training as discussed in PSAR section 11.1.5.2, "Training of Personnel," will be developed and implemented by the USO in accordance with</li> </ul>

- 7 -

Number	Question	Resolution of Question
		the administrative procedures described in PSAR section 11.1.4. TerraPower agreed to address this item via changes incorporated into a revision of the TR.
5	<ul> <li>TR section 4.1.2, "Responsibilities"</li> <li>a. Criterion 2.4.2(4): The NRC staff requests TerraPower further describe assignments of tasks to personnel, such as assignments of individual core team members and extended team members for various tasks and within HFE program elements.</li> <li>b. Criterion 2.4.3(1): The NRC staff requests TerraPower also identify the process through which the team will execute its responsibilities, including procedures for the following: <ul> <li>assigning HFE activities to individual team members</li> <li>governing the internal management of the team</li> <li>making decisions on managing the HFE program</li> <li>making HFE design decisions</li> <li>controlling changes in design of equipment</li> <li>reviewing of HFE products</li> </ul> </li> </ul>	<ul> <li>5.a: TerraPower clarified that their organization will use established processes and procedures to identify, understand, and resolve issues relating to the HFE scope. TerraPower described that GE Hitachi staffs the core HFE team, to include the HFE Technical Lead role. This HFE Technical Lead coordinates design activities with the TerraPower HFE Program Owner who, in turn, provides oversight. The TerraPower HFE Program Owner is described as having responsibility for ensuring the communication, reporting, and processing of HFE concerns is advocated and resolved through the TerraPower design organization. The TerraPower HFE Program Owner reports to the Manager, Plant Maintenance and Operational Design Integrated Plant and Structure. The Senior Manager, Integrated Plant and Structure, serves as the technical design authority and senior-level advocate for HFE and reports to the Vice President of Plant Delivery.</li> <li>5.b: TerraPower clarified that they will generate the procedures for execution of the Natrium design for Kemmerer Unit 1. These procedures will include the process for design and project decisions, inclusive of HFE. The procedures also address the design change control process and acceptance of engineering products from suppliers. These procedures are governed by TP-QA-PD-0001, Revision 14-A, "TerraPower [Quality Assurance] Program Description" (ML23213A199). TerraPower further clarified that companies supporting Natrium HFE work under their</li> </ul>

Number	Question	Resolution of Question
		respective programs, plans, and procedures. For the
		core HFE team, this includes procedures for workforce
		planning, scheduling, and project management.
		TerraPower also stated that there are procedures
		addressing personnel qualification, technical training,
		and proficiency, that support making resource
		assignments. For HFE work performed by GE Hitachi,
		these procedures are governed by NEDO-11209A, "GE
		Hitachi Nuclear Energy Quality Assurance Program
		Description" (ML21348A339 and ML22278A214).
		TerraPower stated that technical reviews are conducted
		per the performer's specific procedures for design and
		review for engineering products and for HFE work
		performed by GE Hitachi, these procedures are also
		governed by NEDO-11209A. TerraPower agreed to
		address this item via changes incorporated into a
		revision of the TR.
	Criterion 2.4.3(5): The TR describes HFE	TerraPower clarified that the retention of engineering
	Implementation Plans that will be used to subsequently	documentation for HFE is completed as required by the
	develop Results Summary Reports (RSRs). However,	performer's plans and procedures and that for HFE
	procedures for the retention of HFE documentation	work performed by GE Hitachi, these procedures are
	items (such as RSRs and their supporting materials) and	governed by NEDO-11209A. TerraPower plans to
6	for making them available to the NRC staff for review are	develop RSRs addressing at least the minimum
	not described within the TR. The NRC staff request that	information stipulated in NUREG-0711. The RSRs and
	TerraPower make these procedures (or a summary of	supporting documentation will be retained as required
	their scope and content) available.	by the performer's quality assurance program.
		TerraPower will provide the RSRs for INRC staff review.
		TerraPower agreed to address this item via changes
	Criterian 2.4.2/6/2 The TD does not discuss the here the	Terro Dever elerified that contractors and
	Unterior 2.4.3(0): The TR does not discuss the now the	renarrower claimed that contractors and
	subcontractors that are ongoged in UEE related work	Natrium HEE program through soveral different means
7	The NPC staff requests Torre Device slorify how UCC.	TorraPower stated that first the preject uses a
	requirements will be included in contracts and	requirements based approach to inform design, with
	subcontracts that contribute to the UEE program how	these requirements being flowed down though the
		inose requirements being nowed down though the

- 9 -

Number	Question	Resolution of Question
	contractor and subcontractor compliance with HFE	procurement process and NI-related contracts
	requirements will be verified, and what milestones and	reference either NUREG-0700 or specific requirements
	the methods will be used for this verification.	from the Natrium requirements database that originate
		from NUREG-0700. TerraPower stated that these are
		work activities to allow the HFE team to be part of the
		feedback process for HFE-related work done through
		the contractors or subcontractors. In some
		circumstances, such as the digital control system which
		houses the majority of human-system interfaces (HSIs),
		TerraPower stated that the HFE team will provide the
		vendor with system-specific design specifications
		developed through HFE task analysis. Finally,
		TerraPower stated that an HSI style specification is
		being developed to implement many of the HFE
		requirements into a relevant format and that the HSI
		style specification will be used by the different vendors
		as applicable to maintain a consistent look/feel for the
		HSIs. TerraPower stated that through a combination of
		factory acceptance testing and through the HFE
		Verification and Validation (V&V) process, compliance
		with the HFE requirements will be ensured, with the
		equipment and interfaces provided by contractors and
		subcontractors being part of the sampling population to
		perform HEE V&V and potentially Integrated System
		Validation (ISV) TerraPower stated HFF V&V will be an
		ongoing activity that will be performed independently
		and will start with the receipt of the first deliverable from
		the digital control system vendor. TerraPower agreed to
		address this item via changes incorporated into a
		revision of the TR
	Criterion 2.4.4(2): In section 8.2 "Criteria for Prioritizing	TerraPower agreed to address this item via changes
	Human Factors Engineering Issues and Human	incorporated into a revision of the TR.
8	Engineering Discrepancies," of the TR. TerraPower	
	discusses the methodology for prioritizing HFE issues	
	and Human Engineering Discrepancies (HEDs).	

- 10 -

Number	Question	Resolution of Question
	However, the TR does not appear to specify that those	
	HEDs categorized at Priority 1 (i.e., highest) and Priority	
	2 (high) must be resolved, as well as when such HEDs	
	must be resolved by during the design lifecycle and	
	licensing process. The NRC staff request that	
	TerraPower clarify how the resolution of Priority 1 and 2	
	HEDs will be ensured by the HFE program.	
	section 5.1, "Operating Experience Review"	9.a: TerraPower clarified that they will conduct a review
	a. Criterion 3.4.1(2): The TR does not appear to	of NUREG/CR-6400 with consideration of the Natrium
	address the consideration of relevant HFE issues	design and will identify any operating experience that
	from NUREG/CR-6400, "[HFE] Insights for	needs to be addressed. TerraPower also indicated that
	Advanced Reactors Based Upon Operating	they will add to section 5.1 of the TR that NUREG/CR-
	Experience," (ML063480112) (e.g., generic safety	6400 will be addressed in the OER and will evaluate
	issues, Three Mile Island (TMI) issues, NRC	removing this information from Kemmerer Unit 1 PSAR
	generic letters and information notices, etc.) within	section 11.2.2.2.4 "Recognized Industry Issues," to
	the Operating Experience Review (OER) process	avoid duplication.
	scope. The NRC staff requests TerraPower clarify	
	how the information in NUREG/CR-6400, where	9.b: TerraPower indicated that the operating experience
	appropriate, is considered within the OER process.	that has been gathered to support the Natrium HFE
	b. Childholf 3.4.2(1). The TR does not discuss the	design was collected over many years of new nuclear
9	design and construction evaluating operating,	design enores and will also be updated with new sodium
	onsuring that applicable important inductor	activities. Torra Dower further stated that they will
	ensuring that applicable important industry	develop a separate report which will detail how the HEE
	those designing and constructing the plant. The	operating experience was collected and evaluated (i.e.
	NRC staff request that TerraPower provide details	the OFR RSR)
	regarding how the OER process will account for	
	evaluation of operating experience	9 c. TerraPower clarified that as of the time of this audit
	c Criterion 3.4.2(4): The TR does not describe how	discussion operating experience issues with relevance
	operating experience issues determined to be	to the HEE design which remain to be addressed are
	relevant to the design, but not vet addressed, will	not vet being formally tracked However TerraPower
	be documented within an issue-tracking system.	confirmed that they will establish formal tracking of such
	The NRC staff requests TerraPower describe the	issues within the Human Factors Engineering Issue
	mechanism by which this tracking will be	Tracking System and that this will be added to section
	accomplished.	5.1 of the TR.

- 11 -

Number	Question	Resolution of Question
	Criterion 4.4(2): TR section 5.3, "Allocation of Function," and appendix A, "[HFE] Allocation of Function and Task Grading Methodology," describe the Allocation of Function (AOF) process. However, the TR does not appear to discuss whether the function allocation will be performed iteratively to keep it current throughout the facility lifecycle. The NRC staff request that TerraPower clarify how the AOF process will maintain the function allocation current.	TerraPower clarified that section 5.3 of the TR describes that the AOF is iterated upon as necessary as the design progresses. TR section A.2.2, "Allocation of Function Evaluation," and figure A.2-2 "Allocation of Function Evaluation Process." also include a <b>II</b>
10		<b>]].</b> TerraPower also confirmed that, once the plant is turned over to the licensee, any evaluations or changes in the AOF would be implemented using the administrative procedures described in PSAR section 11.1.4
11	Criterion 5.4(1): In section B.1.2, "Scope," of TR appendix B, "[HFE] Task Analysis and [HSI] Design Methodology," TerraPower states that the task analysis (TA) process addresses human interactions with NI plant systems. However, it is not clear whether the TA and HSI design HFE elements will be applied within the scope of EI functions as well. The NRC staff request that TerraPower clarify whether the TR addresses any EI tasks that may be important to plant safety during maintenance, tests, inspections, and surveillances, in addition to those EI tasks with potential concerns for personnel safety.	TerraPower agreed to address this item via changes incorporated into a revision of the TR.
12	Criterion 6.4(2): TR section 5.4, "Staffing," and appendix C, "[HFE] Staffing Analysis Plan," describe the staffing analysis process. However, the TR does not address the regulatory requirements of 10 CFR 50.54(k), 50.54(I),	TerraPower clarified that the requirements of 10 CFR 50.54(k) through (m) will be addressed by the OLA and, furthermore, that TerraPower will seek an exemption via the OLA for the omission of the STA role. The NRC

- 12 -

Number	Question	Resolution of Question
	and 50.54(m) for licensed operator staffing. Additionally,	staff have identified this area as being the subject of a
	the IR does not describe how it is intended to address	potential L&C for the TR in the NRC staff's SE.
	the STA role. The NRC staff request that TerraPower	
	clarify both now 50.54(k) through (m) and the STA role	
	Will be addressed by the TR.	Town Down owned to address this item via above as
	Criteria 8.4.3(1)-(5): The TR references the development	incorrected into a revision of the TD
	and application of an HFE style guide. However, this	incorporated into a revision of the TR.
13	The NPC staff request that TerrePower make the HEE	
	The NRC stall request that TerraPower make the HFE	
	TerroDower's EPP	
	Criterion 9.4.4.1(7): The TP does not address the	TerreDower elerified that, and the plant is turned over
	change process that is expected to be used for HSIs in	to the licensee, any modification or undates to the HSIs
	the operating plant. The NRC staff request that	will be in accordance with the administrative procedures
14	TerraPower describe how in the operating plant. HSIs	described in the PSAR
14	will be modified and undated temporary HSI changes	described in the F SAR.
	will be made, and personnel-defined HSIs will be	
	created	
	Criteria 8.4.4.2(1-3), (5-7), and (10–11): The TR does not	TerraPower agreed to address this item via changes
	appear to address the post-TMI HSI inventory requirements of	incorporated into a revision of the TR.
	10 CFR 50.34(f)(2)(iv), (v), (xi), (xvii), (xviii), (xix), (xxvi), and	
	(xxvii). The NRC staff request that TerraPower describe how	
	the HSI design process of the HFEPP will ensure that the	
	technologically relevant aspects of, at a minimum, the	
	design.	
15	$\circ$ 50.34(f)(2)(iv) - Safety parameters display system	
	$\circ$ 50.34(f)(2)(v) - Status of safety systems	
	$\circ$ 50.34(f)(2)(xi) - Relief and safety value indication	
	<ul> <li>50.34(f)(2)(xvii) - Containment related indications</li> </ul>	
	<ul> <li>50.34(f)(2)(xviii) - Core cooling indications</li> </ul>	
	<ul> <li>50.34(f)(2)(xix) - Instrumentation to monitor post-accident</li> </ul>	
	plant conditions	
	$\sim 50.34(f)(2)(xxvii)$ - Rediation monitoring	
	TR section 5.7. "Human-System Interface Design." and	16.a: TerraPower agreed to address this item via
16	appendix B describe the HSI design process.	changes incorporated into a revision of the TR.

- 13 -

Number	Question	Resolution of Question
	a. Criterion 8.4.4.2(12): The TR does not appear to	TerraPower also clarified that PSAR section 4.2,
	address how the HSI design process will account for	"Defense-in-Depth," includes the defense-in-depth
	the manual initiation of protective actions. The NRC	(DID) process description.
	staff request that TerraPower describe how it will be	
	ensured that the HSI design will support the manual	16.b: TerraPower agreed to address this item via
	initiation of protective actions at the system level for	changes incorporated into a revision of the TR.
	those safety systems otherwise initiated	TerraPower also clarified that DID functions are
	automatically.	classified as either safety-related (SR), non-safety-
	b. Criterion 8.4.4.2(13): The TR does not appear to	related with special treatment (NSRST), or non-safety-
	cover how the HSI design process will address the	related no special treatment (NST) using the safety
	manual initiation of systems associated with critical	classification process described in PSAR section 5.1,
	safety functions. The NRC staff request that	"Safety Classification of SSCs." TerraPower indicated
	rerrapower describe now the HSI design process	that there are currently no SR manual actions and that
	for the manual actuation of critical actaty function	none are expected and that the NSRST and NST
	related eveteme, as well as for monitoring these	independent HSL as described in DSAD section 7.6.2.4
	nerameters that support them. Additionally, the NPC	"Operator Interface " and the ISC architecture is
	staff request that TerraPower describe how these	illustrated in figure 5-1 "Overall I&C Architecture
	displays and controls will be independent of and	Diagram " of NAT-4950 "[I&C] Architecture and Design
	different from the normal instrumentation and	Basis [TR] " Revision 1 (MI 240684186)
	controls otherwise used	
	c Criterion 8 4 4 5(2). The TR does not discuss how	16 c <sup>.</sup> TerraPower agreed to address this item via
	consistency will be achieved between those HSIs	changes incorporated into a revision of the TR.
	which are in the control room and those located	TerraPower also clarified that consistency between the
	outside of it. The NRC staff request that TerraPower	HSIs of the Remote Shutdown Complex (formerly the
	discuss how it will be ensured that the HSIs of the	Remote Shutdown Facility) and like HSIs in the MCR
	Remote Shutdown Facility are consistent with those	will be ensured through the use of the same style
	in the main control room (MCR).	specification for the HSIs.
	d. Criterion 8.4.4.6(2): The TR also does not appear to	
	address how consistency will be achieved between	16.d: TerraPower agreed to address this item via
	the design of HSIs for local control stations and	changes incorporated into a revision of the TR.
	those in the control room. The NRC staff requests	TerraPower also clarified that consistency between
	TerraPower describe how HFE will be incorporated	HSIs for local control stations and the MCR is facilitated
	into the HSIs for local control stations to ensure both	by developing a style specification and providing it to
	that they are consistent with those in the MCR and	the various vendors. Where there are commercial-off-

- 14 -

Number	Question	Resolution of Question
	that personnel can easily understand and use the HSIs.	the-shelf considerations for applied HSI designs and compliance with the style specification, HFE evaluates
	e. Criteria 8.4.5(1 – 4): The NRC staff note that an HSI	and collaborates with the designer to develop a
	design process should address considerations related to the following as they relate to HSI failures and degradations:	solution, or a justification of acceptability as provided within TR section 5.7.5 "Detailed [HSI] Design."
	<ul> <li>the effects of HSI failures and degradations,</li> <li>the alarms and indications needed for timely detection,</li> <li>back-up systems to ensure that important personnel tasks can be completed, and</li> <li>compensatory actions (as well as supporting procedures) to ensure that personnel effectively manage degradations and transitions to back-up systems.</li> <li>While the TR addresses HSI failures during ISV activities (with identified issues generally being expected to be addressed via the iterative HFE process), the NRC staff also note that ISV only samples a subset of the possible I&amp;C and HSI degradations that can impact personnel task performance. The NRC staff request that TerraPower clarify how the HFEPP processes for HSI design, TA, procedures, and HFE V&amp;V will, in aggregate, adequately address the impact of automation failures, I&amp;C degradations, and HSI degradations and task performance.</li> </ul>	16.e: TerraPower agreed to address this item via changes incorporated into a revision of the TR. TerraPower also clarified that PSAR section 4.2 includes the DID process description.
	TR section 5.8, "Procedure Development"	17.a: TerraPower clarified that they are currently in the
17	a. Criterion 9.4(1): The TR does not describe the development of Generic Technical Guidelines (GTG) within the Procedure Development Plan. The NRC staff request that TerraPower clarify whether GTGs will be included in the procedure development program.	process of obtaining vendor support for the development of the emergency operating procedures (EOPs) and that technical guidelines will be produced for the EOPs. However, TerraPower indicated that a decision has not yet been made regarding whether site- specific or GTGs will be developed for the EOPs and that this decision is not expected to be made until

- 15 -

Number	Question	Resolution of Question
	<li>b. Criterion 9.4(4): The NRC staff request that</li>	approximately one year from the present time. The
	TerraPower make the procedure writer's guide	NRC staff have identified this area as being the subject
	available for review so that the adequacy of its	of a potential L&C for the TR in the NRC staff's SE.
	content can be verified. Specifically, confirmation is	
	needed that procedures developed using this guide	17b: During the audit, a copy of ADI-RMD-102,
	will contain the following elements, as applicable:	"Procedure Writer's Manual" (Revision 1). was available
	<ul> <li>title and identifying information</li> </ul>	in the ERR for the NRC staff to audit. <b>II</b>
	<ul> <li>statement of applicability and purpose</li> </ul>	
	<ul> <li>prerequisites</li> </ul>	
	<ul> <li>precautions</li> </ul>	
	<ul> <li>important human actions</li> </ul>	
	<ul> <li>limitations and actions</li> </ul>	
	<ul> <li>acceptance criteria</li> </ul>	
	<ul> <li>check off lists, and</li> </ul>	
	<ul> <li>reference material</li> </ul>	
	c. Criterion 9.4(8): The TR does not specifically	
	address the plan for maintaining procedures and	]].
	controlling updates. Clarification is needed	
	regarding how the procedure plan will address both	17.c: TerraPower confirmed that they will conform to the
	maintaining procedures and controlling procedure	requirements in NQA-1-2015, "Quality Assurance
	updates.	Requirements for Nuclear Facility Applications," and
	d. Criterion 9.4(9): The TR does not appear to describe	ANSI/ANS-3.2-2012, "Managerial, Administrative, and
	the physical means by which personnel will access	Quality Assurance Controls for the Operational Phase
	and use procedures, particularly during operational	of Nuclear Power Plants," (with the exception that the
	events. However, the NRC staff noted that the	2015 version of NQA-1 will be used instead of the 2008
	"TerraPower [HFE] Concept of Operations White	version referenced in ANSI/ANS-3.2-2012) for
	Paper" (ML23125A328), section 3.5 "Procedures,"	procedure maintenance and development. TerraPower
	describes that the HSIs in the nuclear control room	also clarified its commitment to conform to the
	are designed to support use of computer-based	requirements of NQA-1-2015 is contained in section 5
	procedures and, furthermore, that storage space is	"Instructions, Procedures and Drawings," of TP-QA-PD-
	provided in the nuclear control room and remote	0001, Revision 14-A. A description of the USO
	shutdown facilities for hardcopy sets of operating	Operating Organization conformance to ANSI/ANS-3.2-
	procedures to support required operation. The NRC	2012 is contained in section 11.1.4 of the PSAR. If
	staff request that equivalent information to what is	additional detail on conformance to NQA-1-2015 and
	described in the WP regarding procedure	

- 16 -

Number	Question	Resolution of Question
	accessibility also be included within the TR or	ANSI/ANS-3.2-2012 is needed, TerraPower will provide
	otherwise docketed.	this as part of the PSAR.
		17.d: TerraPower agreed to address this item via
		changes incorporated into a revision of the TR.
	TR section 5.9, "Training and Qualification Program	18.a: TerraPower clarified that compliance with 10 CFR
	Development"	50.120, "Training and qualification of nuclear power
	a. Criterion 10.4.1(2): section 5.9 does not specify	plant personnel," will be addressed in the PSAR. The
	whether the categories of personnel covered by 10	NRC staff have identified this area as being the subject
	CFR 50.120, "Training and qualification of nuclear	of a potential L&C for the TR in the NRC staff's SE.
	power plant personnel," are within the scope of the	
	Systems Approach to Training (SAT)-based training	18.b: TerraPower clarified that they intend to obtain
	program. The NRC staff request that TerraPower	accreditation of their training program through the
	clarify what specific categories of personnel that will	Institute of Nuclear Power Operations. Additionally,
	be trained under the training program.	TerraPower indicated that they plan to achieve training
	b. Criterion 10.4.2(1): The NRC staff note that the TR	program accreditation within 18 months of initial fuel
	does not define organizational roles related to	load. The NRC staff have identified this area as being
	training program development. The NRC staff	the subject of a potential L&C for the TR in the NRC
	requests TerraPower describe the organizational	staff's SE.
18	roles for developing training requirements, training	
	information sources, and training materials, as well	18.c: TerraPower confirmed that they plan to establish a
	as for implementing the training program.	full-scope, plant-referenced simulator. The NRC staff
	c. Criterion 10.4.2(3): The TR does not appear to	have identified this area as being the subject of a
	describe the facilities and resources that will be	potential L&C for the TR in the NRC staff's SE.
	needed to satisfy the requirements of the training	19 dy TorreDower electified their intention for the
	define these personal facilities and resources	incluster facility to model the MCD design initially and
		simulator facility to model the MCR design initially and,
	(e.g., a plant-referenced, full-scope simulator).	plana for simulator training to include demonstrations
	u. Chienon 10.4.4(2). The TR does not specify	training scenarios, job performance measures (IDMs)
	PC 1 1/0 "Nuclear Power Plant Simulation	and evaluated sceparios. TerraPower planned training
	Facilities for use in Operator Training License	and evaluated scenarios. Terrar ower planned training
	Examinations and Applicant Experience	emergency scenarios with the design and development
	Requirements " nor does the TR provide a	of simulator training being conducted using a $S\Delta T_{-}$
	description of either the simulator facility or the	based process. TerraPower anticipates that the

- 17 -

Number	Question	Resolution of Question
	program for simulator training. The NRC staff	simulator portion of licensed operator training will take
	requests TerraPower clarify whether the simulation	approximately 10 months, with the duration being
	facility will conform to RG 1.149 (including revision	modified based upon the finalized design, as well as
	number), provide the details of the program for	upon programmatic evaluation and experience.
	simulator training (including length of time), and	TerraPower intends for the operating test to be
	describe the simulation facility as required by 10	accomplished per 55.45(b)(2) using a plant walkthrough
	CFR 55.45(b), "ImplementationAdministration,"	and in a plant-referenced simulator. Based upon
	and 10 CFR 55.46, "Simulation facilities."	construction status, TerraPower stated that the
		alternatives or additions to the plant walkthrough
		portion, including models or mockups, may be desired
		to provide enough JPMs for the operating exam.
		TerraPower stated it intends for the training simulator to
		comply with the requirements of 55.46 as they relate to
		plant-referenced simulators and continued assurance of
		simulator fidelity. Furthermore, TerraPower indicated
		that they will review their system design and ability to
		conform to RG 1.149 Revision 4. TerraPower stated
		that they plan to engage with the NRC on potential
		exceptions to this RG of on the possible use of newer
		standards at an appropriate point in the design and that
		iney understand the benefit of phontizing this
		being the subject of a potential L&C for the TP in the
		NPC stoff's SE
	Criterion 11 4 3 5 $1(4)$ : TR section D 6 7 5 "Situation	TerraPower agreed to address this item via changes
	Awareness " discusses how situational awareness (SA)	incorporated into a revision of the TR
	is assessed during V&V activities. This section proposes	
	to use traditional three-level SA measures in which in	
	part participants answer SA questions during freezes in	
19	scenarios. The NRC staff note that this type of SA	
	measure was originally developed for measuring SA	
	during tasks that demand guick reactions and	
	predictions in rapidly changing aviation situations. The	
	NRC staff request that TerraPower clarify the basis for	
	the selected methodology and whether other SA	

# **OFFICIAL USE ONLY - PROPRIETARY INFORMATION**

- 18 -

Number	Question	Resolution of Question
	measurement approaches were considered. Additionally, while section D.6.7.5 discusses the use of	
	Situation Awareness Global Assessment Technique, it is	
	unclear whether this method will only be used during	
	early validation work, or if it will also be applied during	
	ISV. If other methodologies (e.g., Situation Awareness	
	Rating Technique) will be utilized as well, then that should also be clarified.	
	Criterion 11.4.3.5.1(5): TR section D.6.7.6, "Workload,"	TerraPower agreed to address this item via changes
	states that cognitive workload will be measured during	incorporated into a revision of the TR.
	ISV using the National Aeronautics and Space	
20	Administration's Task Load Index. Please explain how	
20	cognitive workload will be assessed. Clarification is	
	needed both regarding whether other cognitive workload	
	measurement approaches were considered and the	
	rationale for the selected assessment methodology.	
	TR section 5.12, "Human Performance Monitoring"	TerraPower clarified that the aspects of the Human
	a. Criterion 13.4(1): TR section 5.12 does not address	Performance Monitoring element that are covered by
	how the human performance monitoring program	these criteria are outside of the scope of TR and that a
	will address future plant changes/modifications and	future report will be provided in conjunction with OLA
	their potential effects on human performance. The	that addresses these items. The NRC staff have
	scope of the performance monitoring program	identified this area as being the subject of a potential
	should provide assurance that personnel can use	L&C for the TR in the NRC staff's SE.
21	the design effectively, changes/modifications do	
	not adversely affect numan performance, important	
	numan actions can be accomplished within the	
	criteria for time and performance, and that an	
	Acceptable level of performance is maintained. The	
	NRC stall requests reframewer describe how the	
	numan performance monitoring program will	
	ensure that plant changes do not adversely allect	
	human performance.	
	b. Onenon 13.4(2). It is unclear whether the numan	
	performance monitoring program will be in effect	
	beginning at the mitial loading of plant fuel. A	

# **OFFICIAL USE ONLY - PROPRIETARY INFORMATION**

- 19 -

Number	Question	Resolution of Question
	human performance monitoring program should, in	
	part, begin at initial loading of the plant's fuel and	
	trend human performance after the plant is	
	operational. The NRC staff request that	
	TerraPower clarify at what point the human	
	performance monitoring program will commence.	
	c. Criterion 13.4(3): TR section 5.12 does not address	
	whether the human performance monitoring	
	program will be informed, in part, by deterministic	
	safety insights or whether the plan will ensure that	
	degradations and corrective actions are promptly	
	addressed. A human performance monitoring	
	program should be, in part, structured such that the	
	monitoring of human actions is commensurate with	
	their safety importance, while facilitating the	
	detection and correction of degradations in	
	performance before they compromise plant safety.	
	Clarification is needed regrading whether the	
	numan performance plan will be informed by	
	deterministic safety insignts in conjunction with risk	
	that degradations and corrective patients are	
	addrossed in a timely manner	
	d Criterion 13 $I/I$ : TP section 5 12 does not discuss	
	the potential use performance data approximations	
	for circumstances in which plant or personnel	
	performance under actual design basis conditions	
	might not be readily measurable. Such	
	approximations of performance data should be	
	used when the performance of the plant or	
	personnel under actual design basis conditions	
	may not be readily measurable. The NRC staff	
	request that TerraPower clarify whether it is	
	intended to use approximations of performance	
	data within such contexts.	

### 6.0 REQUESTS FOR ADDITIONAL INFORMATION RESULTING FROM AUDIT

As a result of the audit, the NRC staff did not identify any requests for additional information related to this TR.

### 7.0 OPEN ITEMS AND PROPOSED CLOSURE PATHS

There are no open items resulting from this audit.