

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 X-Energy Xe-100 Design-Centered
 Subcommittee
 Open Session

Docket Number: N/A

Location: teleconference

Date: 08-21-24

Work Order No.: NRC-0017

Pages 1-134

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

X-ENERGY XE-100 DESIGN-CENTERED SUBCOMMITTEE

+ + + + +

WEDNESDAY

AUGUST 21, 2024

+ + + + +

The Subcommittee met via Teleconference,
at 8:30 a.m. EDT, Robert P. Martin, Chair, presiding.

COMMITTEE MEMBERS:

- ROBERT P. MARTIN, Chair
- RONALD G. BALLINGER, Member
- VICKI M. BIER, Member
- VESNA B. DIMITRIJEVIC, Member
- CRAIG A. HARRINGTON, Member
- GREGORY H. HALNON, Member
- WALTER L. KIRCHNER, Member
- SCOTT P. PALMTAG, Member
- THOMAS E. ROBERTS, Member
- MATTHEW W. SUNSERI, Member

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANTS :

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL :

DEREK WIDMAYER

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CONTENTS

Opening Remarks 4

Staff Introduction 10

Xe-100 Principal Design Criteria Topical
Report 11

P R O C E E D I N G S

(8:30 a.m.)

CHAIR MARTIN: This is a meeting of the Advisory Committee on Reactor Safeguards X-Energy's Xe-100 Design-Centered Subcommittee. I am Robert Martin, Chair of today's subcommittee meeting. ACRS members in attendance include myself, Ron Ballinger, Craig Harrington, Tom Roberts, and Vicki Bier. All right, and members attending virtually via Teams, and I will definitely navigate the screen here, I see Greg Halnon, Matt Sunseri --

(Audio interference.)

CHAIR MARTIN: Is there a live mic? Please mute. If you have a live mic, please mute. And I see Scott Palmtag, and Walt Kirchner, and Vesna Dimitrijevic.

All right, and we have one consultant participating in person. To my right, we have Steve Schultz, and we have a couple of consultants, at least one, I saw Dennis Bley online, and I'm not seeing anyone else, but if I indeed missed somebody, either members or consultants, please speak up now. I'll give you a few seconds. Okay, thanks.

Derek Widmayer of the ACRS staff is the designated federal officer for the meeting today. No

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 member conflicts of interest were identified for
2 today's meeting.

3 During today's meeting, the subcommittee
4 will receive a briefing on the topical report and
5 staff's draft safety evaluation for X-Energy's
6 principal design criteria for the Xe-100 non-light
7 water small modular nuclear reactor.

8 Regarding principal design criteria, which
9 I expect we'll refer to by the acronym PDC many times,
10 we expect to focus today's meeting on X-Energy's
11 process to develop PDCs for the Xe-100
12 high-temperature gas-cooled reactor.

13 Consistent with the NRC's historic
14 reliance on general design criteria for light water
15 reactors, the PDCs proposed by the applicant and
16 accepted by the NRC are requirements that will
17 influence X-Energy's Xe-100 design and final safety
18 analysis report content.

19 The PDCs are therefore integral to the
20 review of the unique aspects of an advanced nuclear
21 power plant. We are reviewing this topical report
22 because it serves as the foundation for the safety
23 design approach of the Xe-100 advanced reactor.

24 For the record and to provide some context
25 for anyone less familiar with the PDC process, there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are a couple documents that we'll hear mentioned
2 during today's meeting that are publicly available on
3 NRC's website.

4 These are Regulatory Guide 1.232, Guidance
5 for Developing Principal Design Criteria for Non-Light
6 Water Reactors, and NEI 18-04, Risk-Informed
7 Performance-Based Guidance for Non-Light Water Reactor
8 Licensing Basis Development, and we'll add -- I'm sure
9 there's a couple other documents you'll bring up, but
10 those are the obvious two. The subcommittee will hear
11 presentations by and hold discussions with the NRC
12 staff and X-Energy regarding this matter.

13 A portion of the presentation by the
14 applicant and the NRC staff may be closed to discuss
15 information that is proprietary to the licensee and
16 its contractors pursuant to Title 5 U.S. Code, Section
17 552b(c)(4).

18 Attendance at the meeting that deals with
19 such information will be limited to the NRC staff and
20 its consultants, X-Energy, and those individuals and
21 organizations who have entered into an appropriate
22 confidentiality agreement with them. Consequently, we
23 will confirm that we have only eligible observers and
24 participants if there is indeed a closed portion of
25 the meeting. We've only allocated about 20 minutes if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that's necessary.

2 The ACRS was established by statute and is
3 governed by the Federal Advisory Committee Act, or
4 FACA. The NRC implements FACA in accordance with its
5 regulations found at Title 10 of the Code of Federal
6 Regulations, Part 7. Per these regulations and the
7 committee's bylaws, the ACRS speaks only through its
8 published letter reports.

9 We hold subcommittees like this one to
10 gather information and perform preparatory work that
11 will support our deliberations and final decisions of
12 whether to issue a letter report at the full committee
13 meeting, which I believe we'll be doing in two weeks.

14 All member comments should be regarded as
15 the individual opinion of the member only, not a
16 committee position. The rules for participation in
17 ACRS meetings, including today's, were announced in a
18 June 13, 2019 Federal Register Notice.

19 The ACRS section of the U.S. NRC public
20 website provides a charter, bylaws, member guidance,
21 subcommittee structure, agendas, letter reports, and
22 full transcripts of all full and subcommittee
23 meetings, including the slides presented there. The
24 meeting notice and agenda for this meeting were posted
25 there and can be easily found by typing About Us ACRS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 in the search field in the upper right corner of the
2 website. Now, the word easy may be subjective.

3 The ACRS, consistent with the Agency's
4 value of public transparency in regulation of nuclear
5 facilities, provides opportunity for public input and
6 comment during its proceedings. We have received no
7 written statements or requests to make an oral
8 statement from the public.

9 We have also set aside time in the agenda
10 at the end of this meeting for any comments from
11 members of the public listening to this meeting. The
12 subcommittee will consider all public comments as
13 appropriate.

14 The subcommittee will gather information,
15 analyze relevant issues and facts, and formulate
16 proposed positions and actions, as appropriate, for
17 deliberation by our full committee.

18 A transcript of today's meeting is being
19 kept and will be made available. For the convenience
20 of our members and staff, NRC staff, advocates, and
21 members of the public, our meeting today, of course,
22 is being held both in person and over Teams, Microsoft
23 Teams. The Teams link information with a telephone
24 bridge line was placed in the agenda on the ACRS
25 public website.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 When addressing the subcommittee, the
2 participants should first identify themselves and
3 speak with sufficient clarity and volume so that they
4 may be readily heard. When not speaking, we request
5 participants mute your computer microphone on Teams or
6 on the phone if you are on the bridge line. This
7 happens all the time. I'll just reiterate if you're
8 not speaking, please be on mute, as we, of course, had
9 a demonstration right at the beginning.

10 Please do not use any virtual meeting chat
11 feature, that is the chat feature that's in Teams, and
12 this happens a lot too, to conduct sidebar discussions
13 related to the presentations or just to say hi to the
14 friend you see online. Limit this to just reporting
15 on IT problems such as inability to hear speakers or
16 see presentations, or for our staff to communicate
17 generally to all participants that are on the line.

18 Also, for everyone in the room, please put
19 your electronic devices in silent mode, including
20 muting your speaker, microphone, or your laptops. In
21 addition, please keep sidebar conversations in the
22 room to a minimum since the microphones in the ceiling
23 are live.

24 Finally, for the presenters, your
25 microphones at the table are uni-directional, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you'll have to speak in front of the microphone in
2 order to be heard online.

3 Okay, after all of that formality, we will
4 now proceed with the meeting, and I will call on, so
5 I have Stephen Philpott, okay, you're over here to the
6 right, of course, of the NRC to begin today's
7 presentation.

8 MR. PHILPOTT: My name is Steve Philpott.
9 I'm the acting chief of one of the advanced reactor
10 licensing branches in the Office of Nuclear Reactor
11 Regulation. And as Dr. Martin mentioned, the purpose
12 of this subcommittee meeting is to discuss X-Energy's
13 principal design criteria or PDC topical report for
14 their Xe-100 design.

15 As you're aware, X-Energy is an awardee of
16 the Department of Energy's Advanced Reactor
17 Demonstration Program, and they are an early
18 implementer of the Licensing Modernization Project or
19 LMP technology in their licensing approach.

20 This PDC topical report describes
21 X-Energy's development of the principal design
22 criteria for the Xe-100 pebble bed high-temperature
23 gas-cooled reactor. X-Energy developed these PDCs
24 using guidance from, as Dr. Martin mentioned, from
25 Regulatory Guide 1.232, which we commonly refer to as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 advanced reactor design criteria guidance, as well as
2 the technology-inclusive content of application
3 guidance for non-light water reactors for applicants
4 using the LMP methodology as found in NEI guidance
5 20-07, as well as Xe-100's specific safety functions
6 and design elements. This topical report is intended
7 to support future licensing applications for
8 X-Energy's Xe-100 design.

9 I'd like to start by thanking, expressing
10 the staff's appreciation to the ACRS for your interest
11 and time to review this important topic. I also want
12 to thank the NRC staff and the X-Energy staff that are
13 here for their time and preparation for today's
14 meeting, and for the presentations that the ACRS is
15 going to hear today. So, I look forward to the
16 conversation today, and if there are no questions now,
17 I'm just going to quickly turn it over to X-Energy.

18 CHAIR MARTIN: Okay, the floor is yours.

19 MR. VAUGHN: Thanks, Steve. So, an
20 introduction, I'm Steve Vaughn. I'm the licensing
21 director at X-Energy. To my left, I have Kyle
22 Metzroth. He's the deputy director of Xe-100 systems
23 development. To my right, we have Drew Nigh. He's
24 our manager of risk-informed safety analysis, which
25 also includes PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We'll go ahead and get started. As Steve
2 mentioned though, X-Energy did get an award from DOE,
3 the Department of Energy, the advanced reactor
4 demonstration program.

5 PARTICIPANT: Yes, now X-Energy, Steven
6 Vaughn is speaking.

7 MR. VAUGHN: Yes, there are two Steves, my
8 apologies. So, again, X-Energy was awarded the
9 Department of Energy advanced reactor demonstration
10 program award, so here is just a disclaimer of that
11 acknowledgment.

12 So, agenda and objectives, we just did
13 introductions. First, we'll go over at a high level
14 the Xe-100 principal design criteria development
15 process, then we'll focus on general differences from
16 Reg Guide 1.232, which was just mentioned. That's
17 just a short slide.

18 The majority of the content are examples
19 of how we took the MHTGR, which I'll get into in a
20 little bit, and converge with the NEI 18-04, which
21 conformed to the Licensing Modernization Project
22 effort, and then questions throughout obviously, and
23 we can always end with questions and any closing
24 remarks.

25 As mentioned before, we started with Reg

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Guide 1.232, though again, just a quick history of
2 that, that effort was extremely important for
3 non-light water reactors since the general design
4 criteria is based on large light water reactors, and
5 created advanced reactor design criteria, and then
6 lucky for X-Energy, at the high-temperature gas
7 reactor Appendix C, that Reg Guide had design criteria
8 based on the MHTGR.

9 So, we were given a set of specific design
10 criteria based on our technology. So, we started with
11 that, and then 18-04 came along shortly after. We had
12 a risk-informed performance-based way to develop
13 design criteria based on functions we'll get into in
14 a bit, so those are the two key documents.

15 NEI 21-07, that wasn't mentioned before,
16 but effectively that document took, or provided the
17 industry with guidance from the NRC on how to actually
18 develop a safety analysis report based on 18-04
19 methodology. So, we looked at it as a practical guide
20 to develop, you know, the chapterization of a SAR.

21 And, of course, the NRC's ARCAP guidance,
22 Advanced Reactor Content of Application Project
23 guidance, was issued a couple of years ago, and we
24 also used that as well because it does describe how to
25 address principal design criteria in that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And the one down below, it's an Xe-100
2 X-Energy document and it's a first example of how we
3 implemented, I'd say, the NEI 18-04 methodology.
4 Drew, myself, and Kyle, and a couple of others were
5 the ones who actually developed this document and
6 styled required safety functions and PRA safety
7 functions, Revision 5. And obviously, there was
8 Revision 1 three or four years ago and we're up to
9 Revision 5, so we're iterating through the functional
10 hierarchy of the Xe-100 safety case.

11 And this is just a picture really that
12 kind of describes what we've already discussed. We
13 start with Reg Guide 1.232, which, you know, I will
14 say it might have some risk-informed elements to it,
15 but was historically maybe more deterministic when it
16 comes to design criteria, and then we bring along
17 18-04 and 21-07 methodology and framework. That tells
18 you kind of what you need to do, but not how to do it.

19 So, that document I just mentioned, that
20 Xe-100 document, that's how we did it is we developed
21 essentially the functional hierarchy from the top down
22 and then from the bottom up, so we decomposed the
23 functions at a high level down to a detailed level.

24 And then when you get here in the green
25 box, the yellow, and blue, and mixed green, our Xe-100

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 PDC, so the topical report you see, I look at it as
2 the convergence of those two paradigms, if you will.

3 CHAIR MARTIN: I'm going to interrupt you
4 just for a second. I noticed that you don't really
5 have like one slide that kind of presents Xe-100, and
6 for the record, you know, you haven't visited the ACRS
7 since before I was on. Just real quick at a high
8 level, kind of explain what the Xe-100 is for anyone
9 that may be less familiar?

10 MR. VAUGHN: Yeah, I'll take a shot at it
11 as the licensing director, although I'll refer to the
12 one in design and safety analysis. So, a
13 high-temperature gas reactor, our primary coolant is
14 helium. It's a pebble bed reactor using TRISO fuel,
15 and so it's online refueling.

16 So, we have a fuel handling system. As
17 pebbles go through the bottom of the core, they are
18 transferred back up to the top of the core. We have
19 a once-through steam generator, and that's, at a high
20 level, the main power system.

21 The helium is forced through the system
22 via two helium circulators. That's how we move the
23 helium through. And other key safety features are our
24 heat removal system reactor, RCCS, reactor --

25 CHAIR MARTIN: Reactor Cavity Cooling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 System.

2 MR. VAUGHN: Reactor Cavity Cooling
3 System, there you go. It has both an active and
4 passive capability. And I'm probably missing some
5 other key features, but those are the high level ones.

6 CHAIR MARTIN: Graphite-moderated, I don't
7 know if you said that one.

8 MR. VAUGHN: Oh, yeah, graphite-moderated,
9 yeah.

10 CHAIR MARTIN: So, I wanted to make sure
11 you said the three key things that were assumptions in
12 Reg Guide 1.232, which of course, was the
13 graphite-moderated, the helium, and of course, the
14 TRISO.

15 MR. VAUGHN: Yeah, so we do have, in
16 between the pebble bed and the core barrel and reactor
17 pressure vessel, there are graphite blocks that
18 provide moderation.

19 CHAIR MARTIN: All right, thank you. You
20 can go on.

21 MR. VAUGHN: I do want to point out that
22 we added some definitions to expand on the 18-04
23 methodology. The ones you see in blue are what we
24 added to the topical report. The ones in black are
25 already defined in 18-04 and 21-07.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so, you know, the first question, why
2 do you even feel the need to define a term? Well, the
3 SSC classifications of safety-related, non-safety
4 related special treatments, non-safety related window
5 special treatments are defined at an SSC
6 classification level, but they actually didn't define
7 how they tie to the functions.

8 The only one that 18-04 did was the
9 required safety function, which has a very clear
10 delineation to required functional design criteria and
11 safety-related design criteria, but the others didn't.

12 So, you see if you added an NSRST class,
13 SSC classified as NSRST, 21-07 shows there's a direct
14 correlation and it's complementary design criteria,
15 but that term right there, NSRST, wasn't a defined
16 term, and we used basically the language in 18-04,
17 used what was there to define that term.

18 CHAIR MARTIN: And I believe you made a
19 point early on that the reg guide came before the NEI
20 report, so clearly there's some language, you know,
21 that didn't get captured because, of course, the
22 chicken came before the egg in this case.

23 So, you have, you know, taken the work
24 that's been done and deliberations on NEI 18-04, you
25 know, with the benefit not only of just the year or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 two that passed between the reg guide, but also the
2 last five years, and have worked it into the language
3 of NEI, excuse me, the Reg Guide 1.232. That was my
4 interpretation as I was reading through your material,
5 correct?

6 MR. VAUGHN: Correct, yeah, and then even
7 within 18-04 itself, they didn't define these terms
8 when we felt the need to. So, for NSRST PSF, what
9 18-04 did do is they described there are two ways to
10 get a classification for NSRST, and that's for
11 specific function or necessary for defense-in-depth.

12 So, we defined this term, defined it
13 functionally essentially, and we did the same thing
14 with non-safety related with no special treatment PSF.
15 And one of the reasons we did that for the one below,
16 the NST PSF, is to draw a direct correlation to this
17 owner-controlled design criteria, which is a term
18 that, you know, we didn't make up, we added, but it's
19 based on 18-04 language.

20 That owner-controlled, owner design
21 requirements, owner-controlled design requirements is
22 a term used in 18-04. We just changed the
23 requirements to criteria just to show that there -- we
24 wanted to make sure it's very clear, the delineation
25 between functions and design criteria throughout,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 across the entire plant.

2 CHAIR MARTIN: They're not necessarily,
3 just as a clarification, not necessarily design
4 criteria that have a safety aspect to it, yes or no?

5 MR. VAUGHN: They're not safety
6 significant, which is a defined term in 18-04. Safety
7 significance includes safety-related in NSRST. Now,
8 those systems that are classified as NST PSFs, you
9 know, the PRA itself is going to model all functions,
10 including NST PSFs, but those functions aren't safety
11 significant, again which has a very clear definition
12 in 18-04.

13 CHAIR MARTIN: Meaning that there could
14 still be value from a defense-in-depth perspective?
15 Even though it can still be complementary, your
16 complementary design kind of covers some of that, but
17 maybe this is kind of clarifying the delineation, the
18 lines. You're crossing the line a little bit to
19 really kind of maybe later in safety analysis prove
20 they're not, you know, they're not really that
21 important to safety for instance.

22 MR. VAUGHN: I mean, there's --

23 CHAIR MARTIN: You're going a step beyond.

24 MR. VAUGHN: It plays a role in defense --
25 they play a role in defense-in-depth, or the need for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 sufficient defense-in-depth, no, right. That's the
2 assertion that we made is NSRST is sufficient for
3 defense-in-depth, but they do play a role. The NST
4 ones do play a role in defense-in-depth.

5 CHAIR MARTIN: Of course, but ultimately,
6 it's the required functional design criteria, the
7 complementary design criteria that really have the
8 safety role.

9 MR. VAUGHN: And just a terminology thing
10 too, I mean, one of the things we found challenging
11 communicating to our own team is technically
12 everything in the PRA is a PSF, and so like it's a
13 bunch of nested terms and they weren't mutually
14 exclusive, and so this was the attempt to create a set
15 of mutually exclusive terms so that we could clearly
16 communicate which ones we were talking about.

17 CHAIR MARTIN: All right, thank you.

18 DR. SCHULTZ: This is Stephen Schultz. I
19 have a question associated with these new definitions.
20 Is there any reason why this was done specific to your
21 design? The second question is have you been
22 communicating with NEI or others in the industry or in
23 the same position you are with regard to moving
24 forward with their designs to perhaps adopt this same
25 approach?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. VAUGHN: Great question. I wouldn't
2 say specific to our design. It was, I guess, specific
3 to, if you want to take the LMP construct and then
4 take the Reg Guide 1.232 construct and merge them.
5 Having these definitions just help keep the accounting
6 clear.

7 So, it wasn't specific to a technology.
8 I think anyone could use it. Have we discussed this
9 with NEI? No. That's a great suggestion and I'll
10 make sure they're aware that we did this and see if
11 other vendors, other folks in the industry want to use
12 it.

13 DR. SCHULTZ: Thank you.

14 MEMBER ROBERTS: Yeah, this is Tom
15 Roberts. What I thought I heard you say is that
16 everything modeled in the PRA is tracked in one of
17 these three categories. Is that right?

18 MR. VAUGHN: Correct, the --

19 MEMBER ROBERTS: That's a lot of
20 functions.

21 MR. VAUGHN: Yes, every function modeled
22 in the PRA is technically called a PRA safety
23 function, right, because it plays some role in
24 responding to events, and so we just made these
25 definitions to help delineate all of those things in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the PRA.

2 MEMBER ROBERTS: Did you use some sort of
3 metric like a risk achievement worth or something to
4 determine which ones are more important and show up in
5 a CDC?

6 MR. VAUGHN: Yeah, the metric piece risk
7 significance is the definition from NEI 18-04, so I
8 won't repeat it here, but it's consistent with
9 guidance in NEI 18-04.

10 MEMBER ROBERTS: Yeah, I think about
11 important to defense-in-depth. Some things that are
12 important to defense-in-depth might be complementary
13 design criteria. Everything in the PRA helped you
14 model. Therefore, it's important to defense-in-depth.
15 I'm just wondering how distinguished between the two
16 things.

17 MR. VAUGHN: Yeah, so there are two
18 criteria that get you to NSRST. One is risk
19 significance, which is a quantitative criteria, and
20 then the other one is defense-in-depth, which is a
21 blend of qualitative and quantitative criteria
22 outlined in Table 5-2 of NEI 18-04.

23 And when it comes to the qualitative
24 guidelines, you know, we have to interpret those in a
25 certain way to determine which functions are necessary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for adequate defense-in-depth versus providing
2 defense-in-depth.

3 MEMBER ROBERTS: Okay, thank you.

4 MR. VAUGHN: So, moving onto general
5 differences from Reg Guide 1.232, so the first three
6 are fairly straightforward, especially the first two.
7 So, we replaced important to safety with the NEI 18-04
8 definition of safety significant. So, again, safety
9 significant has a very clear definition, whereas
10 important to safety did not have such a clear
11 definition in regulatory space.

12 We did remove single failure criterion
13 from all PDC given that NEI 18-04 does leverage the
14 defense-in-depth evaluation approach, which I just
15 mentioned. That's when you go through the DID
16 evaluation for the entire plant, one of the last steps
17 in LMP before you enter it again, and during that
18 process, you kind of solidify the SSC classifications
19 and your defense-in-depth posture.

20 CHAIR MARTIN: Excuse me, question.
21 Regarding the single failure criterion, do you feel
22 like that the single failure criterion could play a
23 role in any LMP or NEI 18-04 approach to the safety
24 case or do you think that NEI -- I mean, I think my
25 read is that it obviously heavily weights, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reliability, which is -- but do you think it excludes
2 the use of single failure criteria?

3 MR. VAUGHN: I wouldn't say it excludes
4 it, and I'm sure Drew has some thoughts on this, but
5 I would say the defense-in-depth approach, because
6 you're looking at the entire plant and then LMP, you
7 do your required safety functions, PRA safety
8 functions, you do your SSC classification, you do
9 special treatments effort, and then you do your
10 defense-in-depth evaluation.

11 That, like, say, four-step process ending
12 with the DID evaluation, I feel like is a holistic,
13 integrated approach that I think gets you to a better
14 safety case than just applying single failure
15 criterion multiple times, right. I think you can miss
16 something if you just apply the single failure
17 criterion in isolation.

18 CHAIR MARTIN: Okay, I appreciate your
19 answer. Maybe it will come up again here.

20 MR. VAUGHN: And we did replace, again,
21 the terminology. We want to keep them as consistent
22 as we can. We replaced postulated accident and
23 accident conditions with the NEI 18-04 defined
24 licensing basis events or LBEs, so AOO, TBE, and DBA.

25 So, the fourth one was, you know, new. As

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we went through the process, we realized that the
2 MHTGR DC you see there, 18-32, 36, 37, 45, 46 to 72,
3 all talk about essentially monitoring inspection and
4 testing surveillance, and they're all system-specific
5 essentially.

6 And what we did is we took all of those
7 and really distilled it down to the essence of what
8 those criteria were really trying to get at. And it's
9 when you design a plant, you want to design for the
10 ability to monitor, inspect, test, and surveil through
11 the life of the plant, which is a great design
12 criteria to have.

13 What we did is we consolidated it down
14 into one and made sure we didn't leave anything out,
15 and then applied it to every system that is classified
16 as safety-related or NSRST. So, to me, it gave more
17 flexibility in language and we didn't miss anything
18 with it, so that's one thing we did to kind of
19 consolidate.

20 CHAIR MARTIN: Yeah, I thought it was one
21 of the bolder things you did in deviating from the reg
22 guide, but, you know, again, the committee expresses
23 their opinion, but I thought you caught something
24 there. You know, there's a lot of overlap, right, and
25 certainly by including statements related to testing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 surveillance, and the other ones, I mean, you're
2 covering everything, but I think what you did by
3 bringing in C-6 and really elevating it in the sense
4 that we have a design criteria that addresses all of
5 those things.

6 You know, I think it's unnecessary to
7 repeat and it allows you to focus maybe more
8 specifically on what all of the other DCs are really
9 saying. So, I don't know. It would not be unique to
10 X-Energy there, but I did think it was an interesting
11 observation you all must have had as you went through
12 that.

13 And I almost felt like it's elevating
14 monitoring, inspection, testing, surveillance by
15 having kind of the one central one as six as opposed
16 to kind of spreading it out and kind of reminding
17 everybody oh, yeah, you've got to do all of that.

18 MR. VAUGHN: Yeah.

19 CHAIR MARTIN: Right? So, I don't know.
20 That's something for the staff obviously to consider
21 in other reviews for sure, but actually my opinion, I
22 think it was a good move, that it does provide more
23 focus by having the one. All right, you cover it and
24 it covers for all of those things.

25 MR. VAUGHN: I appreciate that because it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 does force you to critically think for every
2 safety-significant system, what do I need to do in
3 this space? And it makes sense that the general
4 design criteria, the plants were already designed,
5 right, so they already kind of knew what the systems
6 were, so it's hard to not bring in system-specific
7 criteria because the designs were already there. So,
8 we wanted to, again, take a step back and get generic
9 to force you to think about it.

10 And now we're getting into the details.
11 So, again, you know, I selected these. I selected the
12 examples really based on -- because they're good
13 examples of how we took the 18-04 approach
14 essentially, but obviously in a PDC and a topical, we
15 can discuss. I kind of went in order starting at 11.
16 Well, I think PDC 10 describes SARRDL. The --

17 CHAIR MARTIN: Just for the record, define
18 SARRDL.

19 MR. VAUGHN: Yeah, SARRDL is specified
20 acceptable radionuclide release design limit. For
21 those familiar with SAFDL, it's the HTGR version or
22 TRISO-X version of a SAFDL. So, in essence, it's
23 described in PDC 10. So, I didn't bring that up
24 because it's not functional.

25 I guess one thing I should point out, when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 navigating through and converging the 232 design
2 criteria and 18-04, we were realizing all of the
3 design criteria are actually functional, and you
4 really had to think about them. Is there a function
5 here or just design criteria?

6 And the ones I'm showing here are the ones
7 that truly were functional, and that's why they
8 blended so well to the 18-04 method. So, PDC 10
9 describes SARRDL. We didn't change any words from
10 what was in Reg Guide 232, but really that's the first
11 place you see that limit, which is a really important
12 one for us, SARRDL.

13 So, I mention that because it is using the
14 CDC down below, but we did take PDC 11 and 12, so
15 reactor protection and suppression reactor power
16 oscillations, and again, combined them, made sure we
17 didn't leave anything out, and decomposed them into
18 two PDCs, so there's an RFDC 11 and a CDC 11.

19 And one thing to point out here, you know,
20 this RFDC 11 is also really important and it ties into
21 our RFDC 26, which we'll get into in a little bit.
22 So, it is one of the two means to supporting
23 controlled reactivity because our reactor inherent
24 protection is by core design, the strong negative
25 temperature coefficient reactivity, that's how you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 control reactivity during LBEs.

2 So, this, and coupled with what we'll see
3 in RFDC 26, collectively have those two means. So, it
4 is a little bit awkward that you need to take 11 and
5 26 to support a function called control reactivity,
6 but that's, at the end of the day, that's what we're
7 left with. There might be an opportunity in the
8 future to consolidate those.

9 And then the last line there is showing
10 that it does align with RSF, required safety function,
11 1.1.1, controlled reactivity within the inherent
12 reactivity feedback.

13 And I guess one thing to point out here,
14 between RFDC and CDC, you'll see something common
15 where RFDC align design basis events to design basis
16 accidents, and CDC align with anticipated operational
17 occurrences.

18 All right, PDC 13, instrumentation
19 control, this one was a tough one to break out on its
20 own into RFDC, CDC, and ODC, but it does contain all
21 -- the RFDC here aligns with control reactivity with
22 moveable poisons, so it obviously has a tie to control
23 reactivity, and the RSF isolate water steam ingress.

24 You know, maybe we should have spent some
25 time to go over not just the design, but some of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 required safety functions, but there's a functional
2 tree, that document shown down below, that energy
3 implementation of 18-04. There's a decomposed tree of
4 functions. So, you know, 1.3 is control water steam
5 ingress. Under 1.3, there's a 1.3.1, isolate water
6 steam ingress, right, so you can see the
7 decomposition. We don't show that in these slides.

8 I do believe that the previous, the only
9 other time we briefed the ACRS was Kyle Martin, right.
10 They described all of that. I think in those slides,
11 I think there's a picture of those functions.

12 CHAIR MARTIN: And you're referring to
13 your visit in May of 2023, correct?

14 MR. VAUGHN: Correct, yeah, I believe we
15 did break down at some level the functions there, but
16 without that kind of decoder ring, it's hard to kind
17 of see all of this, but I just wanted to point those
18 out. And then on a CDC level, it's really similar to
19 control reactivity, the moveable poisons.

20 There's an NSRST PSF associated with that,
21 and then controlling heat removal with active means,
22 and then maintaining helium pressure boundary,
23 pressure during transients. Those are some other PSFs
24 that align with the CDC.

25 And on the control design criteria, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is instrumentation control needed to keep the plant
2 just at a normal operating state, so the I&C obviously
3 supports that. The challenge with this one is to --
4 you'll see later in DC 34, it was more straightforward
5 to create an RFDC CDC and OCDC, but this one with the
6 wording, it was really hard to compartmentalize them
7 into three separate phrases, so, you know, they all
8 have their own elements to it. Any questions on this
9 one?

10 Moving on to PDC 15, again there's no RFDC
11 element to this, but I did want to clarify that the
12 helium pressure boundary design doesn't provide a
13 required safety function for the HTGR or Xe-100, so it
14 aligns with a CDC, not an RFDC, and specifically, the
15 function aligns to prevent loss of the helium pressure
16 boundary integrity, and down below, it aligns with
17 normal operations and anticipated operational
18 occurrences.

19 Moving on to PDC 16, it essentially
20 defines from a design criteria perspective our
21 functional containment. The RFDC portion of it is
22 retain radionuclides in our fuel particles and
23 pebbles, that RSF 1 is at the top of our hierarchy of
24 our required safety functions.

25 That is the start, and in the picture down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 below, that retain radionuclides in the fuel particles
2 and pebbles is to control reactivity, control heat
3 removal, and control water steam ingress.

4 Those are the three, and then
5 tangentially, you have, you know, maintain core
6 geometry, which kind of, you know, it's kind of, it's
7 crosscutting of all of them, but at a high level,
8 that's our functional hierarchy, and then down below,
9 those three, you know, you can decompose it further.

10 CHAIR MARTIN: Real quick, the language
11 you use there in your required functional design
12 criteria, to ensure that the functional containment
13 design limit. Now, could you have used SARRDL there
14 and said the same thing or is there expectations of
15 something more than SARRDL?

16 MR. VAUGHN: Great question. Currently,
17 the thought is that the functional containment design
18 limit at a high level is the frequency consequence
19 target in 18-04, that chart.

20 CHAIR MARTIN: That's SARRDL.

21 MR. VAUGHN: SARRDL is a little bit
22 different because SARRDL, you need to maintain SARRDL
23 during normal operations and anticipate operational
24 occurrences, yeah, but beyond that, SARRDL can be
25 exceeded.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR MARTIN: But the SARRDL would cover
2 the whole spectrum from 10 CFR 20 through evaluation
3 guidelines for DBAs and even beyond design basis, that
4 whole frequency consequence.

5 MR. VAUGHN: It's tough to describe.
6 Maybe we could talk about this during the closed
7 portion if we can, but at a high level, yes, SARRDL,
8 if you brought up PDC 10, the SARRDL limit does not
9 need to be met during design basis events or design
10 basis accidents, similar to SAFDL for DBA. You know,
11 you expect SAFDL to be exceeded during a design basis
12 accident. So, likewise for SARRDL, they kept the
13 same.

14 CHAIR MARTIN: Okay, we'll just table that
15 and keep on going.

16 MEMBER ROBERTS: Yes, Tom Roberts.
17 There's a requirement in 18-04 to look for cliff edge
18 effects. Does that factor at all into CDC and
19 functional containment? Because it seems like cliff
20 edge effects may require assessment of scenarios that
21 are beyond design basis or design basis accidents, and
22 yet you still want to have resilience in the
23 functional containment particularly. Is that a factor
24 here and how is that accounted for?

25 MR. VAUGHN: I mean, so the fact is when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we implement our 18-04 methodology, we will look for
2 cliff edge effects, and I would say that if we -- you
3 know, this whole process is iterative, right? So, if
4 we go through and we identify something that comes out
5 of that evaluation, there's the potential to add
6 something to this to be able to account for it, but,
7 you know, right now, we don't have anything that
8 covers it explicitly, but in going through our 18-04
9 methodology, we will evaluate cliff edge effects.

10 MR. METZROTH: And I'll add that the PDC
11 pertain to design basis events, and AOOs, and design
12 basis accidents, whereas cliff edge effects, in my
13 opinion, generally pertain to beyond design basis and
14 lower frequency events than that. So, yes, we will
15 still get requirements for our design from evaluating
16 cliff edge effects through the 18-04 approach, but not
17 necessarily through the PDC.

18 MEMBER ROBERTS: Okay, thank you.

19 MR. VAUGHN: The RFDC portion of this is
20 focused on the fuel particles and pebbles, whereas the
21 complementary design criteria focuses on maintaining
22 a pressure boundary. That's the third barrier where
23 the particles and pebbles are the first two, meaning
24 that aligns with the previous one where the helium
25 pressure boundary integrity isn't a required

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 functional design criteria that aligns with the CDC.

2 All right, so PDC 26 was a challenging one
3 to align all of the wording, but we did break it down
4 into not only an RFDC CDC and OCDC, but also a PDC,
5 and this, you'll recall that we didn't change the
6 wording much, but that's the fourth. If you look at
7 the GDC currently, the like four pieces to it, the
8 fourth one is that bottom one, and we just did
9 maintain that.

10 CHAIR MARTIN: Yeah, I mean 26 always
11 comes up with a new design. It seems like you're
12 focusing a lot of it on an active system requirements.
13 You're using the words moveable poison to attempt to,
14 say, credit passive response, or that comes in -- I
15 mean, it exists in your design because we're all
16 familiar with high-temperature gas reactors and their
17 performance with, you know, large negative feedback
18 with temperatures, but there's -- how does that play
19 into satisfying the design criteria? Because it seems
20 like you have like the implication that the statement
21 is that, you know, you have two active systems
22 basically.

23 MR. VAUGHN: Well, so RFDC 11, the reactor
24 inherent protection, is the passive means of
25 controlling reactivity, and then this RFDC up here is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the, you know, the moveable poison.

2 CHAIR MARTIN: So, it's completely
3 separate?

4 MR. VAUGHN: Yeah, and they're separate,
5 so that was that, two independents, but that was the
6 challenge of, unfortunately, you have to look at both
7 RFDC 11 and RFDC 26 collectively.

8 CHAIR MARTIN: Those were the two, yeah,
9 okay.

10 MR. VAUGHN: That's the challenge, and
11 again, for our design, it's a removal of power gravity
12 drop is the, sort of that active -- that would be the
13 poisons portion.

14 CHAIR MARTIN: Okay.

15 MR. VAUGHN: And if you look at the CDC
16 notes, they're not too off, but one focuses on --
17 again, CDC focuses on AOOs and the OCDC focuses on
18 normal operations.

19 PDC 30, at the top, it is integrity of the
20 reactor helium pressure boundary. So, the RFDC
21 focuses on, this is again controlling water steam
22 ingress, in this case, isolating the water steam
23 source, and that's the event sequence that our design
24 needs to protect against and it's a required safety
25 function, so that's what this RFDC focuses on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR MARTIN: Yeah, you're kind of
2 getting into the section where, again, I'm noticing
3 from the staff's review, and of course there's
4 limitation and condition related to events.

5 MR. VAUGHN: Right.

6 CHAIR MARTIN: I know you haven't
7 presented events yet. I mean, the PDC is the very
8 first topical reports, and nominally you would
9 consider -- nominally when we refer to light water
10 reactors and other designs, a loss of coolant
11 accident, or in this case, the depressurized loss of
12 coolant circulation event where you could have area
13 risks. And so, PDCs like this and maybe the next one
14 kind of touch into events, okay.

15 Now presented events, that's been
16 acknowledged by the staff in their review, so, you
17 know, it's kind of a TBD, but certainly that is
18 something that, you know, an external stakeholder
19 might look at kind of going, you know, okay, it's a
20 little different, but we know there's kind of an
21 eye-opening on that anyway.

22 MR. VAUGHN: And this was often formed by
23 our PRA and our initial set, and so that was to try to
24 bring the technology --

25 (Simultaneous speaking.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. VAUGHN: Yeah, exactly. And PDC 34 is
2 about residual heat removal. I think the MHTGR DC
3 just said passive heat removal, but like that
4 definitely applies to us. The reactor cavity cooling
5 system has a passive mode. That ties with the
6 required principal design criteria. So, we have two
7 active means of removing heat.

8 The CDC focuses on one system to address
9 AOs and the other system is internal operations, so
10 it aligns with owner-controlled design criteria. This
11 PDC was definitely more amenable to compartmentalizing
12 the three separate criteria as opposed to the I&C 11
13 and 13.

14 We have two more. So, at the end, we get
15 to the reactor vessel and reactor system structural
16 design basis. This is where we get into maintaining
17 core geometry. So, this is a required functional
18 design criteria to maintain core geometry, and some
19 things you'll see, we did that.

20 You know, core internal structure is here
21 too. That was one addition we made to add more
22 clarity from what we inherited from the MHTGR design
23 criteria. Other than that, we didn't change too much.

24 CHAIR MARTIN: 70 was something that GDCs
25 don't have, but obviously, there's a uniqueness to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 high-temperature gas reactors. You know, we're
2 relying on heat removal, passive heat removal, kind of
3 inside-out reactors if they've got a cavity cooling
4 system, and something like this, a design criteria
5 that focuses on everything else besides the fuel is
6 very, very important, so that's really more for maybe
7 people that are not as familiar, but that's really a
8 very key one there.

9 And we've come from other, you know,
10 safety analysis programs, and applications, and, you
11 know, other design centers. There's still the
12 expectation that you maintain thermal limits of, you
13 know, core internals and what have you, oftentimes in
14 particular, water.

15 You know, the margins are huge with gas
16 reactors and things are high temperature, so you don't
17 always know what component is being threatened. I
18 mean, in doing fuel, I've done a lot of research.
19 There's probably a lot of margin on that, so it might
20 be something else, so 70 is particular important.

21 MR. VAUGHN: Exactly, and then likewise,
22 this is focused on the reactor pressure vessel and the
23 core internals, and then you take a step back. We
24 also need to protect what's supporting the actual
25 reactor pressure vessel and the core, and again, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactor building.

2 So, obviously, you need to maintain the
3 structural integrity here to maintain the core
4 geometry. So, 70 and 71 kind of double to maintaining
5 core geometry. So, 1.42 is, I would say the structure
6 itself, and then 1.4.1 is the maintaining pressure
7 boundary and the actual core itself, so.

8 CHAIR MARTIN: But then I'm just going to
9 be nosy to Kyle, and this puts a bit more of a burden
10 of your safety analysis, but eventually you'll come to
11 us or come to the staff, and maybe you've already done
12 some of that. Are you going to have a true like
13 integrated safety analysis which kind of looks at
14 normal limits and all of these things all together and
15 your transient analyses?

16 MR. METZROTH: Yeah, sure, I mean, we have
17 to look at, you know, events that consider challenging
18 the structural capacity of the building. We have to
19 look at events which, you know, it brings all of those
20 things together. So, yes, it is -- we have a very
21 integral safety analysis that considers all of those
22 factors.

23 CHAIR MARTIN: Yeah, it's certainly a lot
24 more complicated --

25 MR. METZROTH: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR MARTIN: -- you know, maybe than a
2 light water reactor in some ways, meaning you're
3 tracking so many more things.

4 MR. METZROTH: Well, I'm not sure that it
5 ends of being -- I mean, you do have to do containment
6 analysis in a light water reactor. You know, we don't
7 have containment. We're not doing --

8 CHAIR MARTIN: Yeah, but are you
9 integrating that all together with your --

10 MR. METZROTH: It doesn't have to
11 necessarily all be integrated. I mean, it's integral
12 in the fact that we have a tool set which spans the
13 spectrum of all of the things that have to be covered,
14 and that could be done by analysis one, feed things
15 into analysis two, and get the right boundary
16 conditions, et cetera. I think at a high level, it's
17 consistent.

18 CHAIR MARTIN: They are still segregators.

19 MR. METZROTH: Yeah, correct.

20 CHAIR MARTIN: And there are objectives.

21 MR. METZROTH: Right, it's a different
22 interpretation of integrated, but yeah, it's still
23 integrated in the fact that we're considering it all,
24 but it's not one giant analysis that has to factor in
25 everything.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. VAUGHN: That's the end of the
2 presentation.

3 CHAIR MARTIN: All right, I'll turn to my
4 fellow members. Are there any further questions,
5 consultants? All right, I don't see any.

6 MEMBER ROBERTS: Yeah, one question.
7 Greg, 1.232 has a requirement to evaluate any unique
8 design features of your plant and determine if there's
9 any additional design criteria required for that.
10 Now, you've got a MHTGR, which you've got the benefit
11 of an appendix since it was basically written from
12 that.

13 So, it would seem reasonable that you
14 would have included it. You know, it covers you, but
15 the point is, is there anything unique about your
16 plant design or are you thinking about adding a design
17 criteria or do you consider you don't have to by the
18 reg guide?

19 MR. VAUGHN: The water steam was discussed
20 in the MHTGR DCE. I think I changed the wording a
21 little bit, but that was the only -- we didn't find
22 anything new, like a new licensing basis event we
23 needed to withstand to create a new design criteria.

24 MEMBER ROBERTS: Right.

25 MR. METZROTH: We utilized our early

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 version of our PRA to basically systematically
2 evaluate whether that was the case, and in going
3 through it, we found that, you know, all of the events
4 that considered the technology was pretty well
5 covered. We had to rearrange some things, but pretty
6 well covered by the PDC that were there.

7 MEMBER ROBERTS: Okay, thank you.

8 CHAIR MARTIN: Any further questions?

9 MEMBER KIRCHNER: Bob, this is Walt, yes.

10 CHAIR MARTIN: Hi, Walt.

11 MEMBER KIRCHNER: Could we go back to 16,
12 functional containment design?

13 MR. VAUGHN: What's your question, Walt?

14 MEMBER KIRCHNER: I'm just looking at that
15 and wondering versus what is in the reg guide, whether
16 this is meant to be as expansive as the reg guide.
17 The reg guide emphasizes multiple barriers.
18 Obviously, we have the different layers in the TRISO
19 particles and the fact that they're in pebbles. Is
20 that -- I'm just looking at the choice of words versus
21 what was used in the reg guide.

22 CHAIR MARTIN: Yeah, I think my comment at
23 the time was related to this, the language of
24 functional containment design limit. What all does
25 that mean? And I was looking for, you know, maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 something more narrow. It seems like for me, it
2 hasn't been completely defined, you know, but it could
3 mean a lot, right, and it seems to me that that was
4 your -- it's kind of your answer. It's not just --

5 MEMBER KIRCHNER: Yeah.

6 CHAIR MARTIN: It's something called
7 functional containment design limit, so it can kind of
8 create a much larger box.

9 MR. VAUGHN: Effectively, the dose limit
10 is what we are aiming for, but that may derive back to
11 other criteria on SSCs that we would then create
12 specific limits for after we do all of the iterations
13 of the analysis.

14 CHAIR MARTIN: Sure, we still have thermal
15 limits. You know, you still got to look at, say,
16 1600C and TRISO limits --

17 MR. VAUGHN: Exactly.

18 CHAIR MARTIN: -- and stuff like that.
19 There are still kind of SAFDLs. You know, they're
20 kind of buried under all of that.

21 MR. VAUGHN: But we have to make sure to
22 derive it because, you know, it's not as -- TRISO
23 isn't as discrete as other, you know, in how it
24 exhibits radionuclide release as other fuel forms, and
25 so it's a little continuous, and so that's why we sort

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of look at okay, we meet dose limits, and then we make
2 sure we want to derive back from that, you know,
3 because our safety analysts maybe want to have, well,
4 give me a number to shoot for and we want to derive
5 that back from the dose limit, and so there's just a
6 myriad of things that we could evaluate, but we
7 haven't got all of that in detail defined. We're
8 focused on the dose limit.

9 MEMBER KIRCHNER: What I'm tripping over
10 here is the second half of this where the pressure
11 boundary, the helium pressure boundary is not exceeded
12 during AOOs. Could you just elaborate on that? That
13 seems to me rather restrictive or less expansive than
14 the actual reg guide. And I understand why you're
15 partitioning, but I want to hear why you -- what's the
16 -- what AOOs? Why is it limited to AOOs?

17 MR. VAUGHN: So, I think what we're trying
18 to do here with PDC 16 is emphasize the different
19 between the SSCs performing the required functional
20 design criteria piece and the complementary design
21 criteria piece.

22 And the point of 16 is that the criteria
23 related to the RFDC or the requirement coming from the
24 RFDC is only applied to the fuel particles and
25 pebbles, whereas the requirement coming from the CDC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 links back to, I guess, creating defense-in-depth and
2 AOOs and the requirements from that CDC.

3 MEMBER KIRCHNER: Why just AOOs?

4 CHAIR MARTIN: Well, you have the required
5 functional design criteria that covers the design
6 basis events, right. You've segregated -- and
7 earlier, when you said, you know, AOOs and CDCs go
8 together, you were almost begging for a question it
9 seemed like.

10 (Laughter.)

11 CHAIR MARTIN: This is a little bit novel
12 there.

13 MEMBER KIRCHNER: Well, here is the
14 question.

15 MR. VAUGHN: So, it relates back to the
16 basis for the classification of the functions. So,
17 for -- within NEI 18-04, Table 5-2 provides
18 qualitative guidelines for evaluating if you have
19 sufficient plant capability for defense-in-depth, and
20 there's a guideline in there that pertains to AOOs and
21 it says that you should minimize challenges to
22 safety-related SSCs and AOOs.

23 So, as a result of that guideline, it
24 leads to a safety classification on the helium
25 pressure boundary. There are events, there are AOOs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 where we challenge safety-related SSCs, the fuel, such
2 that we need to have a requirement on the boundary to
3 create adequate defense-in-depth for those specific
4 events.

5 CHAIR MARTIN: Right, I mean, typically,
6 the limits associated with AOOs are more restrictive,
7 right, to the point you made. I guess my curiosity is
8 couldn't these CDCs just be part of the required
9 functional design? I mean, there's no less rigor, I
10 mean, for the work you do.

11 I mean, in some ways, the language maybe
12 deceives us, but terms like required functional design
13 criteria versus complementary design criteria, I think
14 it's trying to say there's some kind of secondary
15 importance associated with a word like complementary,
16 but it's not, right? I mean, when you go in practice,
17 you don't do anything different than --

18 MR. VAUGHN: This really derives from the
19 fact that these functions are performed by systems
20 based on a certain classification, right. This is
21 bringing in the 18-04 piece of it, right, and so in
22 the fact that we have identified there are things that
23 satisfy NSRST PRA safety functions. For the Xe-100
24 design, that's all based on defense-in-depth.

25 We don't actually have risk significant --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we haven't identified risk-significant SSCs that would
2 get you to NSRST that way. We get to NSRST purely
3 through defense-in-depth, and so a lot of the CDC
4 thinking that goes into here is because we've gone
5 through the PRA, we've done an initial classification.

6 All of the NSRST SSCs come out through
7 defense-in-depth, and as Drew mentioned on the Table
8 5 through guidelines and how it talks about AOOs,
9 that's how that language gets in there. So, it's a
10 reflection of the function we're asking it to perform
11 in a defense-in-depth capacity based on how NEI 18-04
12 points you in that direction. So, that's where some
13 of that language comes from.

14 MR. METZROTH: And I can just expand.
15 I'll give kind of like a counter-example here where
16 let's say like in design basis accidents, we were
17 relying on the helium pressure boundary to retain
18 radionuclides, to perform that required safety
19 function in those design basis accidents. If that
20 were the case, the second part of this PDC would
21 actually be an RFDC.

22 That required functional design criteria
23 would relate back to a required safety function. In
24 this case, since it's a defense-in-depth function,
25 NSRST PSF, it has a CDC. Bob, your point is well

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 taken. What's the difference between calling it RFDC
2 or CDC? The point is just to trace back to the origin
3 of the requirement.

4 MR. VAUGHN: And when you talk about
5 rigor, I mean, we still have to apply special
6 treatments. When we have an NSRST system, we'll apply
7 special treatments. That means design codes and
8 standards. We select those based on, you know, how
9 they play into the safety case, and so you can still
10 get to a certain level of rigor on that based on, you
11 know, the special treatments that you select. So,
12 you're right, it doesn't necessarily mean a difference
13 in level of rigor because we still have special
14 treatments to select for those systems.

15 CHAIR MARTIN: Walt, did you have anything
16 else to add on your question, original question?

17 MEMBER KIRCHNER: I'll wait for the staff.
18 Thank you.

19 CHAIR MARTIN: Okay, yeah, I think it does
20 kind of present some questions for the staff too.

21 MEMBER ROBERTS: Yeah, Walt, I think your
22 question is related to the one I asked about the cliff
23 edge effects assessments and how that might be part of
24 the outgrowth of the design requirements, because the
25 original PDC said that there will be, where are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 exact words at, multiple barriers internal and/or
2 external to the reactor. So, what they seem to have
3 done is define what those multiple barriers are for
4 all three classes, AOOs, design basis events, and
5 design basis accidents, and so what they've done is
6 made the requirement more specific, but it seems to
7 track to what it says.

8 But what neither one says is there should
9 be defense-in-depth for events that are beyond, you
10 know, what's modeled design basis events and design
11 basis accidents, and whether there's some element of
12 the multiple barriers that that will spawn. It sounds
13 like that's future work.

14 And, I mean, another idea to sit in is
15 when you look at the reasonable but beyond design
16 basis categorization and you come up with well, I've
17 just blown through all of my barriers that I had, so
18 I no longer have multiple barriers, maybe I need to
19 add one more for that. It sounds like that would be
20 a reasonable outcome, what you get there. Is that
21 right?

22 MR. VAUGHN: That's correct and there's
23 also a barrier beyond the helium pressure boundary,
24 but we don't have it listed here because it's not
25 necessary for defense-in-depth, and that would be the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 helium pressure boundary and the reactor coolant.
2 That is a barrier functional containment.

3 But based on our design and what we've
4 done in 18-04 space and the PRA, we'll have to
5 obviously support this with associated stage analysis
6 and does it rise to the level of a NSRST PSF and
7 staff-associated complementary design criteria? But
8 it is still part of the defense-in-depth picture.
9 It's just not necessarily sufficient for it.

10 MR. METZROTH: And I think when you think
11 about something like -- you know, we actually debated
12 this quite a bit. And when you look at something like
13 the reactor building, we sort of thought about some of
14 these functions and the criteria that were coming out
15 of it. It's like what design requirement am I giving
16 a designer, right, like that's really what this has to
17 flow down to.

18 You know, and so the building is kind of
19 there, correct. It's there. It's part of
20 defense-in-depth. It's not needed for adequate
21 defense-in-depth. We will still evaluate it as part
22 of the defense-in-depth philosophy, but I'm not going
23 to hand the designer a requirement that says, right,
24 you know, provide this much on defense-in-depth.

25 These were things were there were specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 requirements that we could hand down and actually
2 provide the designer versus it's there and we're going
3 to evaluate it as part of it. So, you're right, it
4 doesn't probably capture all of that picture, but
5 there are other SSCs that are contributing that are
6 modeled in the PRA.

7 MR. VAUGHN: Tom, I just want to make sure
8 we're answering your question though. Are you
9 wondering why beyond design basis events aren't like
10 mentioned in the topical report?

11 MEMBER ROBERTS: No, it was more follow-up
12 on Walt's point about the multiple barriers verbiage
13 was taken out and replaced with some specifics about
14 what your design does, and so that takes, you know, a
15 principle and replaces it with a specific design, and,
16 you know, whether that risks losing what the principle
17 actually is when you do these more detailed analyses
18 and find that maybe you're still achieving this
19 standard design criterion, but not the underlying
20 principle, and you need to go back and make sure
21 you're covering that, and so I think you've answered
22 that question.

23 MEMBER KIRCHNER: Could you go back then
24 to your last criterion, your last illustration? This
25 is Walt again. I think it's number 70 for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 building, excuse me, 71. That's it. Now, since
2 you've brought it up with regard to giving your
3 designers some criteria for the building design basis,
4 what about controlling unmitigated moisture and air
5 ingress?

6 Assuming you have a rupture in the primary
7 helium system boundary, are you going to provide a
8 functional requirement for the reactor building to
9 actually play a role in terms of a confinement
10 function?

11 MR. VAUGHN: So, well, hold on a second.
12 So, confinement and, and air ingress.

13 Let me address the air ingress piece of
14 that first.

15 When we look at our PRA and we look at the
16 events that are in the, you know, down at the DBE
17 region and the DBAs we derive from it, we don't have
18 credible scenario that leads to air ingress; right?
19 So, this is why we're not, we're not including that in
20 here because this isn't even informed by our initial
21 PRA.

22 That's why we don't have a specific
23 criteria on it.

24 MEMBER KIRCHNER: Wait a minute. Stop.

25 You classified your helium pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 boundary in a separate category only for AOOs. So,
2 that suggests that you could have a failure in your
3 pressure boundary, possibly a large failure.

4 MR. NIGH: This is Drew.

5 I think what Kyle's trying to say is
6 there's no scenario that could lead to a significant
7 amount of air ingress such that it affects the
8 radiological consequences. Like, yes, a breach in the
9 pressure boundary eventually leads to some amount of
10 air ingress.

11 CHAIR MARTIN: Thank you.

12 MR. NIGH: I believe analyzed all those
13 scenarios occur, and the impact of air ingress as a
14 result, and it basically showed that, the physics,
15 that there is no significant amount of air ingress
16 for, for those events that would alter the
17 radiological consequences of an impact.

18 MEMBER KIRCHNER: Okay. All right, thank
19 you.

20 CHAIR MARTIN: Yeah, I think that's one of
21 the challenges of us looking at the PDCs at this stage
22 because we've not seen your, like, you know, your
23 safety analyses and we haven't seen the PRA. And I
24 think it puts more burden on staff, you know, to kind
25 of recognize, you know, this is coming first, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there's only so much information. It really is
2 otherwise ready for primetime.

3 And I'll probably bring it up in a second
4 here when we talk to the staff.

5 At the end of the day there can be no
6 limitations in conditions more than likely; right? I
7 mean, all of this has to be resolved. I mean, there
8 is no limitation in conditions on the GDC; right?
9 They are what they are.

10 And so, this is still kind of a work in
11 progress. Anything could change. You could learn
12 something in the next few years that drives, you know,
13 a tweak to what you have today.

14 It really puts more responsibility on the
15 staff to stay on top of that and keeping -- you know,
16 you see a lot more than we do. You see a lot more
17 than the public sees. And you should be sensitive to
18 that because otherwise you're going to get questions
19 that maybe in your mind have already been answered but
20 that haven't been answered for the rest of us.

21 And so, you see some of that even from,
22 say, today's conversation. But, you know, I think
23 it's good to air out this, you know, for the record
24 that this is something that will continue.

25 I think, you know, my personal opinion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 since we provide this, you know, you've done a pretty
2 good job. I think you've taken the task of
3 integrating it before, and the Reg Guide 1.23 together
4 very seriously, and there might be value to from other
5 design centers.

6 So, this involves designs, the first one
7 through does a lot of work, you know, could very well
8 be to the benefit of other people who get it for free.
9 Thank you from 16th Street.

10 But I don't have any further questions.
11 I know we are, like, way early on the schedule. And
12 I'm going to need a little help on how do we manage
13 schedule and how we should.

14 MR. SNODDERLY: So, I think the first
15 question -- this is Mike Snodderly from the ACRS
16 staff.

17 Right now the agenda calls for breaking.
18 This is a logical time, but it is early. So, I think
19 the question is break or do you want the staff to come
20 up?

21 CHAIR MARTIN: I would say let's go ahead
22 and have a 15-minute break. Again, this keeps us
23 pretty, pretty early on all things considered. But
24 I'm up for tea, so.

25 So, how about, you know, I hate to have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 long break, but how about till 10:00 o'clock? Is that
2 okay? Anybody have any heartburn with that?

3 MR. SNODDERLY: You're the chairman.

4 CHAIR MARTIN: All right. There you go.

5 We'll recess until 10:00 a.m.

6 (Whereupon, at 9:40 a.m., the
7 above-entitled matter went off the record, and
8 reconvened at 10:00 a.m.)

9 CHAIR MARTIN: We're going to reconvene our
10 hearing here this morning.

11 We have heard from X-Energy. And we're
12 going to move into staff's presentation of their
13 evaluation. I believe Adrian Muniz will be leading
14 our discussion for the introduction part at least.

15 Go ahead.

16 MR. MUNIZ: Thank you.

17 Good morning. My name is Adrian Muniz
18 Perez. I am the lead product manager for the review
19 of the X-Energy Xe-100 design.

20 Sitting right next to me is Ian Jung, a
21 senior reliability and risk analyst, and lead tech,
22 technical leader for the X-Energy design.

23 And right next to him is Dan Beacon. He's
24 supporting their view on his integral part of the core
25 team design team, design review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We are all staff members of the Office of
2 Nuclear Reactor Regulation, NRR, Division of Advanced
3 Reactors and Non-power Production and Utilization
4 Facilities, also known as DANU.

5 We are here today to present on the NRC
6 staff review of X-Energy's principal design criteria
7 topical report.

8 Next slide. Thank you.

9 As presented during X-Energy's
10 presentation, the topical report describes their
11 process for developing the principal design criteria,
12 or PDC, for their design and the resultant PDCs coming
13 off this process.

14 The staff's evaluation documented review
15 and regulatory approval of their proposed PDCs, the
16 NRC staff found this is acceptable to support design
17 and licensing process associated with X-Energy's
18 design, subject to limitation applications stated in
19 the safety evaluation.

20 We'll provide additional details in some
21 of the slides.

22 In our review of our X-Energy's proposed
23 PDC started in July 2022 with the initial submittal of
24 their topical report, during the review of this
25 topical report the staff issued questions to X-Energy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and engaged in an RFI associated with this effort.

2 This resulted in greater understanding of
3 their proposed PDCs and X-Energy provider of the
4 topical report as a result of this engagement.

5 The NRC staff safety evaluation is based
6 on Revision 3 of X-Energy's topical report that was
7 submitted on June 17, 2024.

8 Now I'm going to turn it over to Ian Jung
9 who will cover the next slides.

10 MR. JUNG: My name is Ian Jung, Senior
11 Reliability and Risk Analyst. I have the honorable
12 position of technical lead, but I feel like it's more
13 of a punishment.

14 (Laughter.)

15 MR. JUNG: So, with that, I can begin and
16 I'll cover these slides.

17 In addition to us, we have engaged other
18 staff members as necessary to get insights and inputs
19 in our evaluation.

20 So, as you know, 10 C.F.R. Parts 50 and 52
21 contains requirements on PDCs. It doesn't say, the
22 requirements doesn't say a lot but it's simply
23 principal design criteria must be submitted for a
24 staff review and approval.

25 And just one note to 10 C.F.R. Part 50,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Appendix A on GDCs. It is not, it's a requirement for
2 light-water reactors but it contains some important
3 information about the scope and content of PDCs. The
4 language there it says that PDCs establish necessary
5 design fabrication, construction, testing, and
6 performance requirement for SSCs important to safety.

7 And that is SSCs provide reasonable
8 assurance that the facility can be operated without
9 undue risk to health, to the health and safety of the
10 public.

11 So, the reason I highlight this portion is
12 that when you apply licensing modernization project at
13 NEI 18-04, there's a set of information, critical
14 elements of LMP needs to be executed that provides a
15 reason for us to obtain a finding. I think there's
16 some difference between light water reactor side and
17 the risk-informed (audio interference) side.

18 It's going to come up later when we, when
19 I'm talking about the scope of the PDCs regarding
20 licensing basis events like, you know,
21 beyond-design-basis not being included in the PDCs for
22 X-Energy.

23 This conversation led to imposing
24 limitation on condition because under the LMP
25 beyond-design-basis is best if they show it to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 important which leads to classification, appropriate
2 requirements and so on, which could lead to safety
3 significant SSCs, which may require potential
4 principal design criteria.

5 Based on the current design that X-Energy
6 has, they have not identified any risks significant
7 beyond-design-basis events and so on. So, we are
8 going with that. I think that we are still imposing
9 a limitation to condition. The rest of the LMP
10 process has to be executed as well as their design,
11 currently being preliminary, has to be finalized.

12 Next slide.

13 As was mentioned earlier by X-Energy,
14 several regulatory guides are very relevant to our
15 review. Reg Guide 1.23 -- 232 provides items on PDCs
16 for non-light water reactors, non-LWRs.

17 Reg Guide 1.233 provides guidance for
18 risk-informed and performance-based methodology to
19 inform the licensing basis and content of
20 classifications. It endorses NEI 18-04 with certain
21 clarifications.

22 Regularly Guide 1.253, which has been --
23 which was issued a few, a couple months ago, it
24 provides additional guidance on PDCs as its related to
25 PDCs when you implement the LMP. So, required

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 functional design criteria and so on, CDCs and so on,
2 those start showing up in NEI 21-07 document.

3 So, staff approved the NEI 21-07 with
4 additions and clarifications.

5 Next slide.

6 CHAIR MARTIN: Just real quick.

7 MR. JUNG: Yes.

8 CHAIR MARTIN: It was first amended two
9 years ago. And it was noted on your slide one or two
10 back. And, of course, now you're mentioned regulatory
11 guidance.

12 Two years seems kind of a long time for a
13 topical report like this. Is it because of all the
14 newness, you know, their approach to, I mean, you
15 know, opinion, questions from staff that kind of led
16 to keep it from the more traditional assumptions that
17 appeared in the Reg Guide 22-52?

18 But, nonetheless, this integration of new
19 and possible suitable, was that really what most of
20 your questions through the different revisions and
21 maybe required an extra iteration about the design
22 evolving fast enough to support where it's influenced
23 the overall?

24 MR. JUNG: The answer is yes. Overall, we
25 found that the modular high-temperature test records

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and criteria are very similar. So, we knew going in
2 that it wasn't going to be a huge challenge. Yet,
3 implementation of LMP led to additional conversations.

4 And the reason it took a little bit longer
5 is that, actually, X-Energy suggested for the staff to
6 perform an audit so that we, the staff, can see some
7 of the implementation documents of the LMP relevant to
8 PDC developed, required function of design criteria,
9 classification, and so on.

10 So, we benefitted a lot from that which
11 led to another several months of delay. Overall, the
12 review of this topical report has gone very smoothly.
13 Our conversation with X-Energy was very cordial and
14 very professional.

15 CHAIR MARTIN: Okay, thank you.

16 Who asked for an audit?

17 MR. JUNG: X-Energy volunteered and we
18 accepted.

19 So, X-Energy design, key design features,
20 I'm not going to repeat it. Steve Vaughn at X-Energy
21 did it. And the report, MHTGR mostly, very similar
22 design. There are some differences, of course, but,
23 you know, the fuel design being, you know, prismatic,
24 fuel block versus pebble being one of those.

25 But, overall, there's no significant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 design differences.

2 DR. BLEY: Excuse me. This is Dennis Bley.

3 Can you say a little more about the audit,
4 what kind of things you learned and maybe what
5 difficulties you might have had if you hadn't had the
6 chance for that audit?

7 MR. JUNG: So, there's an audit report
8 that's a part of our safety evaluation. And so, I was
9 reading through it. X-Energy made available several
10 LMP implementation documents. So, development of the
11 required safety functions, PRA safety functions,
12 similar documents. I can refer to it.

13 CHAIR MARTIN: Safety classification
14 documents, like that?

15 MR. JUNG: Yes. I'm just going to go,
16 there's five documents: preliminary SSC classification
17 list; special treatment of reactor protection system;
18 integrate decision-making process into implementation
19 guide; and the PRA Phase 1 event sequence analysis
20 document.

21 So, these are the documents that X-Energy
22 provided staff. Also was engaged in find which
23 documents might be useful for us.

24 And it led to a conversation that if some
25 of them led to actually modification to the topical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 report and later revisions of the topical report.

2 DR. BLEY: Okay. Thank you.

3 I'm just wondering if some of these
4 documents they developed about how to implement NEI
5 18-04, if any of that suggested that there might be
6 more general guidance from the staff to other
7 applicants who might be following the general
8 approach?

9 MR. JUNG: I think my, my sort of
10 observation at the time on the subject has been into
11 X-Energy's implementation of these, these documents
12 are still preliminary in nature. I think it might be
13 more beneficial to go through the process and then
14 bring back the lessons learned into, into more broadly
15 to other stakeholders.

16 DR. BLEY: Okay, thanks. Because that,
17 yeah, I think some of the guidance in 18-04, predict's
18 not the right word, but might be difficult for some
19 applicants to implement. And this may have given some
20 clarity on how to go through that process.

21 MR. JUNG: I think, personally, I fully
22 understand that. And at the same time X-Energy
23 implementing, for even X-Energy it's very challenging
24 even now. We see that. And so I think all the
25 lessons learned we're going to get.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Of course, for the staff members we are
2 learning, using these Reg Guides we are learning a
3 lot of lessons. We are already applying lessons
4 learned on documentation of the NEI 18-04 into our
5 task.

6 So, those are being actually discussed
7 even among staff members on how to bring back the
8 lessons learned, and document that and bring back into
9 the potential revisions to future LMP guides and
10 guidance documents. That's already being useful.

11 DR. BLEY: Okay, thank you.

12 CHAIR MARTIN: And I'll add, you know, I
13 started to write my letter, my draft letter. And
14 focusing mostly on what we talked about Xe-100 PDCs.
15 But there is for me a temptation to talk about this
16 generically.

17 And, you know, given that we've, you know,
18 seen a couple of PDCs, you know, come through, and,
19 you know, maybe after the third one we have a better
20 idea maybe how, how to report with that, how to
21 consider these sort of things.

22 And so, I'm trying to decide in my head
23 whether I should add some content to my letter related
24 to the generic application of PDCs. Because I think,
25 you know, I'm learning a lot. Sounds like you all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have learned a lot over the last two years about
2 implementing.

3 You know, the Reg Guide itself has been,
4 you know, was focused on non-light water reactors.
5 That just feeds right into, you know, the
6 technology-inclusive philosophy of the subsequent Reg
7 Guides.

8 Maybe one day we see a little tighter
9 coupling between, you know, those subsequent Reg
10 Guides and kind of revisit Reg Guide 232 in light of
11 what we've learned from multiple design center
12 meetings like this one.

13 But this one I think is, particularly
14 mostly because I'm chair, the keeper, but I think
15 there's a lot to learn here, a lot of lessons learned,
16 I think. And certainly as you compile and we're
17 compiling some ourselves, that I think that it might
18 lead to further improvements, process improvements
19 that we can do here.

20 Anyway, proceed.

21 MR. JUNG: Understood.

22 DR. SCHULTZ: This is Steve Schultz.

23 Let me ask it a little differently.
24 You've spent a lot of time going through this portion
25 of the process. And Revision 3 as you've gone through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this evaluation and your review, are you for X-Energy,
2 has it prepared both you and X-Energy, put you in a
3 position to move forward more rapidly because of the
4 time you spent here?

5 Do you have a better understanding of what
6 needs to be done in the next steps of the licensing?

7 I would hope the answer would be yes, but
8 if you could answer from your point of view on that
9 I'd appreciate it. Thank you.

10 MR. JUNG: The answer is yes. Not just
11 because of this topical report. Because there are
12 several multiple topical reports that are currently
13 under review, and audits are ongoing on several of
14 those topical reports.

15 Overall, safety analysis there are four,
16 four topical reports that are currently under review
17 and audits ongoing. There's the training
18 qualification topical report, and graphite topical
19 reports are coming soon.

20 We are performing our audit, actually,
21 right now, pre-application readiness assessment on
22 that.

23 So, putting all these together it does
24 take a challenge. It's new and novel. But I think,
25 I think X-Energy's working hard and we can see that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 They have their own milestones. And staff's been
2 entertaining quite a bit of expense learning about the
3 design, learning about the LMP process.

4 So, ARCAP, advanced reactor content of
5 application and technology-inclusive content
6 application guidance finally issued a few months ago
7 with the endorsement from the committee. We are all
8 learning and implementing, I think it's to some degree
9 having a construction, Part 50 construction permit
10 application process allows gradual process to go
11 further into the final design. And the operating
12 license application will be coming out.

13 So, feel comfortable where we are. But I
14 think there's a lot more to be done.

15 DR. SCHULTZ: Thanks for your perspective.
16 Thank you.

17 MR. JUNG: So, next slide.

18 So, just a recap. Overall, PDC the
19 approach for us is that based on the fact that these
20 are, these PDCs are based on Appendix Charlie of the
21 Reg Guide 1.232, substantially similar in design,
22 allows us to be a little more efficient. And there's
23 some modifications made to the Appendix Charlie based
24 on the X-Energy-specific design.

25 Also, PDCs are, X-Energy PDCs are also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 based on LMP implementation, which was talked about.

2 Marriage of Reg Guide, deterministic Reg
3 Guide 1.232, a bit more risk-informed and performance
4 -based Reg Guide 1.233, is not yet, not a clear cut.
5 So, we struggled a little bit trying to marry those
6 things, two things together, and the terminologies and
7 so on.

8 And then new expressions of LMP require
9 safety functions, require safety function of the
10 criteria, PRA safety functions, and so on.

11 I think the staff wants me to hurry up.

12 MEMBER HALNON: This is Greg. Can I jump
13 in here real quick?

14 I just wanted to, on that previous slide
15 you mentioned it wasn't as clear as what you had
16 hoped. Are you guys keeping notes so that -- one of
17 my questions I was going to ask you all, if you were
18 happy with the guidance statutes through both
19 reviewing, and I should have asked the applicant about
20 developing the PDCs, are you all keeping notes and are
21 you planning on a future lessons learned type revision
22 of these, or maybe another Reg Guide that roadmaps you
23 for the right way to go, or the better way, more
24 efficient way of getting through this using LMP?

25 MR. JUNG: The answer is yes. It would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we have a contract with the Idaho National Lab who's
2 been supporting the development of many of this LMP
3 guidance.

4 So, one of the new task items is actually
5 collection of the lessons learned. And I think a
6 couple weeks ago there was a discussion of developing
7 a Excel spreadsheet where this information is
8 documented, lessons learned are documented and
9 questioned in the future.

10 Also, that lessons learned is somewhat
11 important from the perspective of Part 53 guidance
12 development because we, if possible, we want to
13 include those lessons learned into the Part 53
14 guidance documents that has to be developed based on
15 the past.

16 Some of those guidance under Part 53 is
17 going to be also based on the LMP guidance we do have
18 right now under Part 50 and 52.

19 MEMBER HALNON: Okay. That's excellent.
20 Thank you.

21 And perhaps when we get into the Part 53
22 interactions we can walk through some of the lessons
23 learned that you're capturing to see how it might make
24 things more efficient down the road.

25 But I'm glad you've got that task going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 on. Thank you.

2 CHAIR MARTIN: A follow-up to Greg's
3 question. You mentioned an Excel spreadsheet. Will
4 there be a document, public domain document kind of
5 capturing your work with the lab, work with DOE? I
6 would think that --

7 MR. JUNG: I know it's internal. At some
8 point those lessons learned will probably need to
9 circle back with industry.

10 CHAIR MARTIN: Sure. It will go public at
11 that point.

12 MR. JUNG: Exactly.

13 CHAIR MARTIN: Okay.

14 MR. JUNG: Yeah. Even during that meeting,
15 interactions with X-Energy, X-Energy already has
16 expressed some of the lessons learned and some of the,
17 actually, improvements that can be made to NEI 18-04
18 and so on. It's already showing up.

19 CHAIR MARTIN: Okay.

20 MR. JUNG: So, I'll be very quick. So, the
21 key differences are discussed here.

22 Overall, the significance of these items
23 are not super complex. And I would say I've seen
24 enough to emphasize some of these areas in our safety
25 evaluation. So, these are some of the areas that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 focused on.

2 So, I'm going to, just like X-Energy did,
3 I'm going to go through some of the examples of these
4 areas.

5 Next slide.

6 So, to my knowledge, X-Energy is proposing
7 to replace important safety with safety significant.
8 And the safety significant, the terminology is well
9 defined in NEI 18-04, a lot more clearly than
10 traditional important to safety definition.

11 So, the reason I think that terminology is
12 very important to be part of these PDCs is that under
13 the LMP your terminologies and definitions and so on
14 are quite different in some of the areas. So, even
15 Reg Guide 1.233 talks about if you are following an
16 LMP you are, you know, it is expected that terminology
17 under LMPs is supposed to be used.

18 So, I think X-Energy is being consistent
19 with that.

20 So, I think overall, overall, you know,
21 there are some areas that in LMP safety significance
22 you can access these being safety-related and NSRST
23 SSCs, and also LMPs, it's a score of these focuses on
24 normal operations, AOOs, and design basis events,
25 DBEs, and design basis accident, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 beyond-design-basis events.

2 But there was a notion that, that in NEI
3 21-07, as well as ARCAP roadmap I have a sheet on the
4 screen, talked about there may be cases where
5 important to safety SSCs may not be fully captured in
6 safety significant SSCs under the NEI 18-04.

7 So, finally, follow the Reg Guide 1.232
8 that brings some of these concerns to use, because
9 when you -- if you look at the Reg Guide 1.232,
10 Appendix Charlie, as well as X-Energy PDCs, it
11 addresses some of the PDC 60. I think, for example,
12 it talks about normal radiological releases, like gas
13 and that. Also, fuel handling and fuel storage
14 systems are discussed.

15 And, also, some of the normal operations
16 that was discussed by X-Energy, normal operation is
17 also included in the Reg Guide. So, I think that we
18 felt that there is no gap.

19 Next slide.

20 Yeah, I briefly touched on this on the
21 scope of the LBEs. And, so, X-Energy replaces the
22 terms in Reg Guide 1.232, such as postulate accident
23 and accident conditions with a terminology used in the
24 LMP. Postulated accidents and accident conditions,
25 those terminology has a certain meaning in the light

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 water reactor space.

2 Also, those are not used in LMP. So, I
3 think it's good to translate those terminologies into
4 LMP language.

5 One other area that we looked at was how
6 come there's no beyond-design-basis events discussed
7 here? Because under the LMP beyond-design-basis
8 events are one of the LBE categories which may
9 contribute to risk-significant or defense-in-depth
10 functions, as well as, as well as it can lead to a
11 safety-significant SSC, for example.

12 So, based on the current design, X-Energy
13 indicated that they have not seen any significant,
14 risk-significant SSC for the beyond-design-basis
15 events. And so, one, and also there it is one of
16 those marriages between Reg Guide 1.232 and 1.233.

17 They are generally equating these
18 postulated accidents and accident conditions to AOOs
19 and DBEs and DBAs. Yet, we, the staff did not really
20 have full confidence in that. All the current
21 preliminary design and current implementation of LMP
22 may lack the full benefit of LMP process: PRA,
23 defense-in-depth evaluation, and so on.

24 We felt that there is room that there
25 possibility of beyond-design-basis events showing up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to be potentially risk significant, for example.

2 And, also, if you look at the LMP process
3 and turn to some of the external hazards, or certain
4 sites may with the external hazard characteristics, if
5 these PDCs are applied you may also have some
6 challenges.

7 So, we felt that I think it's good to
8 impose the limitation of application based on
9 preliminary design and preliminary implementation of
10 the LMP. Future applicants may find these PDCs
11 applying to their design by verifying that their LMP
12 notification confirms this. That's the limitation
13 provision (audio interference.)

14 CHAIR MARTIN: I know from historical
15 context the GDCs design basis as, well, almost 60
16 years ago weren't as sensitive to beyond-design-basis
17 events as we are today.

18 But I do agree that the language in NEI
19 18-04, you know, when you acknowledge that certainties
20 associated with liability always in frequency of
21 events you are looking, you will look at events that
22 are considered beyond design basis.

23 I guess as I was reviewing the material,
24 reconciling the maybe lack of, you know, specific
25 mention of beyond-design-basis in the proposed PDCs,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the fact that they're going to do it anyway. I mean,
2 that's if you're, if you're following LMP in a
3 rigorous manner you will be, you know, considering
4 the, you know, safety significance of the SSCs in all
5 these contexts.

6 So, it is currently there. And indication
7 of LMP may be considered a little more restrictive
8 than the tradition of GDCs for light water reactors.
9 It comes down to whether the language appears there or
10 not.

11 Now, what we don't have is, like, the
12 flip-end events, and that's a little bit beyond, well,
13 you know, beyond 5 times 10 to the minus 7th, in that
14 space. So, that effect remains excluded even under,
15 you know, inevitable marriage of the Reg Guide with
16 NEI 18-04.

17 But I do think it's covered elsewhere in
18 the NRC safety framework documents.

19 MR. JUNG: Yeah. And I fully agree. And
20 it's sort of in the nature of where we are in the
21 whole process. And, also, if we did have the complete
22 design, final design, there might be a lot better
23 clarity on some of these things.

24 But, historically, equating postulated
25 accidents and so on are traditional DBAs. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 historical also it's these GDCs and so on came around
2 19 late 60s and early '70s. Maybe before my time, but
3 I was told.

4 But as we learned many lessons learned
5 since then, that two additional regulatory
6 requirements on what we call beyond-design-basis
7 accidents. It could be debated depending on the
8 frequency and consequence, sure this could have been,
9 you know, beyond-design-basis events or just been
10 DBEs. But at the time the decision was more a
11 traditional framework.

12 So, it could be a long story there. But
13 I think that we are covered clearly for ARDP as well
14 as commitment for X-Energy to follow the LMP, provide
15 the assurance to help continue to PRA, and they'll
16 still go through and make sure what can go wrong, you
17 know, comprehensive evaluation of what could go wrong
18 is evaluated for PRA standard requirements as well as
19 LMP implementation through integrated decision making
20 panel process that will be subject to future NRC
21 review.

22 CHAIR MARTIN: Till we get more
23 information, particularly on the LBES and first
24 response, do you have that LC, limitation condition,
25 associated with this TR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. JUNG: Yes.

2 Next slide.

3 MEMBER ROBERTS: The applicant talked about
4 how making qualitative and quantitative factors will
5 figure out the beyond-design-basis events, what parts
6 of the system need to be credited or what parts of the
7 system are, you know, dismantled for PRA modeling.

8 For the containment part specifically they
9 took out the words about multiple barriers. And so,
10 what they defined is a system that they think had
11 multiple barriers from a standpoint of specifically
12 what they put in as opposed to the generic, you know,
13 have multiple barriers.

14 The committee six years ago wrote a letter
15 on functional containment where one of the
16 recommendations was to always have multiple barriers
17 in functional containment systems. And I'm just
18 wondering if that gets lost taking the words out of
19 the PDC? Or is your expectation that the subsequent
20 evaluation will ensure there's multiple barriers
21 because that's just what the PRA and the judgement
22 will produce, something that's needed?

23 Just wondering what your thoughts are on
24 that? Because maybe not the words, multiple barriers
25 just means that, you know, the conclusion was what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 they specify doesn't contemplate multiple barriers
2 beside beyond-design-basis event, you know, what hope
3 do you have to get multiple barriers?

4 MR. JUNG: Member Roberts, can I, can I
5 speak, respond to that by the time we get to the
6 functional containment slides?

7 MEMBER ROBERTS: Sure.

8 MR. JUNG: So, staff also looked at the
9 area of normal operations and the use of
10 owner-controlled design criteria. X-Energy went
11 through owner-controlled design criteria pretty well.

12 The reason that we got established looked
13 at the normal operations is it's partly because LMP
14 scope does not include, NEI 18-04 scope does not
15 include the normal operations.

16 So, there was a notion, and NEI 21-07, as
17 well as NRC staff guidance that talks about there may
18 be cases where safety-significant SSCs may not equate
19 to important to safety, that I discussed earlier. So,
20 we looked at the area that was kind of, we thought
21 that was important to consider some normal operation
22 aspects of that.

23 So, X-Energy includes those normal
24 operations, normal operations were at normal
25 conditions these PDCs, some of them are related to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 OCDCs in particular SSCs is not performing -- is
2 performing non-safety related functions.

3 But, also, as I mentioned earlier,
4 X-Energy PDCs 60 through 64 discussed some of the
5 normal operational releases, gas, liquid, and solid
6 waste, and then also fuel storage and handling, design
7 criteria in 61 through 64 and so on. So, those are
8 captured.

9 So, overall, we felt that the overall
10 action of PDCs covered this area.

11 And then the use of OCDCs, although they
12 may not be the design basis of the plant, but it
13 clearly provides a clarity in terms of separation
14 between safety-significant SSC design criteria versus
15 those that are not. Or as we discussed earlier, the
16 PRA models, all these SSCs.

17 So, I think it's all being handled and
18 having this distinction is useful for this.

19 Next slide.

20 So, replacement of single failure
21 criterion with the reliability criterion was discussed
22 by X-Energy. We felt that this is consistent with the
23 staff guidance in Reg Guide 1.233.

24 The concept was approved by the Commission
25 earlier.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 In NEI 18-04 we also recognized that, that
2 safety-significant SSCs would be, would have a
3 reliability target and capability targets as well.
4 And then also defense-in-depth evaluation is needed
5 for us during the assessment of the event sequences.

6 So, we felt that this replacing --
7 replacement is not lost.

8 But we also recognized that single failure
9 criteria is in some cases good industry practice. So,
10 I took the 603 for I&C, for example, gets us the
11 criterion. Some of the active systems have to be able
12 to establish the redundancy and overall reliability
13 redundancy. And we found that diversity play a
14 critical role, in doing so apply a single basis
15 criterion is a good practice, theoretical practice.

16 CHAIR MARTIN: If they had kind of kept an
17 either/or kind of statement, single basis criteria for
18 reliability, would it materially change anything to
19 the PDC?

20 You know, my experience is doing safety
21 analysis for, you know, for other projects, I mean
22 having to address the reliability or, you know,
23 pinpoint design inputs in the decision-making process,
24 it counts; right? And we're dealing with new plants.

25 Now, when you get down to, you know, some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 very specific parts, well, then maybe there are, there
2 is data that supports, you know, the design inputs for
3 PRA. Maybe not. Maybe there's some novelty
4 associated with designs both TRL, technology readiness
5 level, to SSC, that really are hard to pinpoint in
6 reliability.

7 And as a practitioner in the single
8 failure criteria, while oftentimes terribly
9 conservative, versus why it was introduced 60, 70
10 years ago could be valuable and really help with the
11 regulatory engagement. It has had a long history and
12 a very successful history.

13 I perceive a possibility that, you know,
14 when you were starting to -- I know you've audited,
15 you know, the PRA, you know, this early PRA. But,
16 maybe not to the degree that you will down the road.
17 You know, might you find maybe a need to revisit this
18 one should you not be able to really make a conclusion
19 on some reliability numbers for maybe some, oh, TRL
20 aspect of the design.

21 So, that was kind of two questions. You
22 know, the first simple one, would it, you know, be
23 included just in your statement whether that would
24 have any problem with that? Or and then second, a
25 what if kind of question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. MUNIZ: Personally, I think, I think it
2 may not hurt to use the or. That gives them more
3 flexibility. So, I don't think there's an issue with
4 that.

5 But I think to me it's more at a function
6 level. I think if we look at the term reliability it
7 brings a lot. I think it captures the intent of why
8 certain design techniques would show up.

9 So, during the LMP implementation when you
10 set reliability terms, and capability terms, and
11 defense-in-depth, and all that, and as you classified
12 SSCs, at the time you start helping define what are
13 special treatments you want to identify about, it
14 leads to codes and standards, depending on the
15 significance of the functions these SSCs are
16 performing, I'm not surprised that you get to stand,
17 stand up to frame specific techniques. That helps use
18 of failure criterion or something.

19 So, personally, I'd rather leave that
20 choice to the designers rather than putting a single
21 failure criterion up front may actually be too narrow,
22 too specific, which may lead to potentially
23 unnecessary conservatism that we wanted to avoid. So,
24 that's my thought.

25 CHAIR MARTIN: I do think, along with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 opinions, the process, maybe it's August, applies more
2 on the PRAs. And it suggests that the quality of PRAs
3 are going to be higher than when it agrees with the
4 Part 52. Of course, that's pretty high standard
5 already.

6 But, you know, the operating plant, 40, 50
7 plus years of experience, you know, the qualities are
8 very, very high. The plants that are still on paper,
9 you know, there's a question mark there. And, of
10 course, LMP accommodates that. But I think from a
11 practitioner's standpoint it actually might be hard to
12 implement. You might want to have the "or" statement
13 in there to, you know, solve certain problems.

14 But I do think scrutiny on PRAs would be
15 a little bit higher. I'm sure the staff here is
16 sensitive to that.

17 But to the extent that criterion is a way
18 out, you know, and can be sticky areas, again, more to
19 the benefit of the applicant but certainly from the
20 engagement with the staff.

21 I saw Dennis. Dennis' hand. Go ahead,
22 Dennis.

23 DR. BLEY: I did put it up because this is
24 a thing I've worried about for a long time.

25 But the truth is, unless you've got a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 really lousy PRA, if a single failure is significant
2 in its impact it will surface very clearly in the PRA.

3 And, separately, speaking of it being
4 conservative, well, not quite. There are quite a
5 number of double or even higher order failures that
6 can be more likely than a particular single failure.
7 So, it's not always giving you what you're hoping for.

8 Back when it was formulated we didn't know
9 how to do the reliability approach thoroughly, so it
10 was kind of a cover to make sure we had enough
11 redundancy to at least have some protection. But I
12 don't see the value in it today.

13 CHAIR MARTIN: Okay. We all have opinions.

14 So, thanks, Dennis. Perfectly fine that
15 way. But I do appreciate, obviously, being given the
16 details of PRAs. You know, there's a lot of insights
17 that come from that.

18 My principal concern is the uncertainties
19 associated with those design inputs, particularly for
20 a plant that has never been built. Those
21 uncertainties are, you know, going to be and pretty,
22 pretty challenging I think for everyone.

23 But, Tom, you look like you have a
24 question.

25 MEMBER ROBERTS: Yeah. I just wanted to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 follow up on what Dennis just said.

2 I think you made an important point, which
3 is that for some designs, specifically I&C as an
4 example, there are decades, you know, of experience
5 with designing a single failure criterion as one of
6 the inputs. And throwing that out would have a whole
7 lot more baggage that you would have to figure out,
8 okay, how do I get the equivalent of that in terms of
9 my reliability assessment?

10 And so, at least for some areas, just
11 keeping a digital alternative single failure
12 criterion, at least the applicant level, not
13 necessarily at the safety analysis or the NRC staff
14 level, it might be important just to ensure that the
15 reliability analysis that's needed by the -- if, you
16 know, the approach is sufficient.

17 So, I don't know if you want to comment on
18 that. But that's what I understood you to say.

19 MR. MUNIZ: I think this is a conversation
20 we are having with an applicant and also internally.

21 I still believe that whether a single
22 failure criterion exists or not, the applicants are
23 right now accident significant and the PRAs speak
24 about it. They understand uncertainties. They have
25 a challenge of addressing potentially areas, so less

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 expense, less data, and so on.

2 But I think, personally, I do believe that
3 LMP is designed to deal with that. And that's why
4 there's a difference in that element.
5 Defense-in-depth, one of the main purposes is to deal
6 with uncertainties.

7 DR. BLEY: This is Dennis again.

8 I agree with Tom here, especially when you
9 start looking at digital I&C, which is an area where
10 we haven't got especially the reliability models these
11 days. So, you need some alternative to protect you
12 there.

13 I think in most of the places where we're,
14 you know, talking pumps, valves, that kind of stuff,
15 there's plenty of pages for the other opinion.

16 MR. MUNIZ: I think we all are recognizing
17 that same challenge. I think there are going to be
18 some areas with passive system failure modes or
19 digital system reliability for common failures and
20 things like that.

21 So, what I'm trying to get at is that
22 there are requirements and expectations that present
23 that, as well as uncertainty being considered as part
24 of the integrated system making process as well. And
25 then PRA, even TR review process we endorse will have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a tremendous requirement there and responsibility to
2 address how you are you addressing the uncertainties,
3 lack of operating experience. Which may lead to some
4 of this decision point.

5 This is important, if applicant or
6 designer choose to, I'm going to say, hey, we've done
7 this code always for the reactor protection system,
8 actually 603s, apply that. Give it to the vendor and
9 generate it.

10 That can be one of the options. But still
11 there's going to be some question. Do you want to
12 follow single failure criterion and then still have a
13 challenge here, like you have some of the sequences,
14 I&C system is involved, we'd like to understand always
15 the PRA model. What PRA model in terms of frequency
16 of consequences?

17 So, I just want to share that. The
18 provisions are there. But at this point I want to
19 give X-Energy to have an opportunity to decide on what
20 brings the reliability in sufficient quantity, in
21 their own choice.

22 CHAIR MARTIN: Certainly appreciate that.

23 I think one of my points is that we have
24 kind of two approaches for some decisions, you know,
25 even at a low level design process. And that's a good

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thing.

2 You know, we've been living off single
3 failure criteria for a very long time. And it's been
4 very successful. And now we have elevated the role of
5 risk in our decision making and development of safety
6 cases. Now we have kind of a different approach.
7 They can complement each other. They can use them to
8 verify each other, you know, should you need that, you
9 know, level of rigor.

10 My only, you know, concern might be that,
11 you know, we start moving past what has been
12 successful, you know, up to 2024, and not recognize
13 that benefit and try to go into the other, other
14 direction.

15 Right tool or the, the right problem, you
16 know. And that's what, you know, this language, you
17 know, maybe just take the PDCs offering. You cut one
18 out, well, maybe you're really, you know, cutting off
19 your arm, you know. Because there may be situations,
20 we've heard an example or two that, you know, you may
21 want to go the other direction.

22 I just want to comment real quick. Walt,
23 I did notice just briefly your hand went up and then
24 went down. Did you want to say something?

25 MEMBER KIRCHNER: Well, I would have just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 concurred with Dennis. One would hope that a good PRA
2 would flesh out very early on single points of failure
3 in terms of impacting the overall robustness of the
4 design.

5 I would observe, though, that applying
6 single failure criteria to the defense-in-depth audit
7 may be a useful way just to test the completeness.

8 I felt that early in the LMP process the
9 defense-in-depth exercise was the least well
10 fleshed-out aspect of the NEI 18-04 and LMP. And
11 certainly for a simple desktop audit of the
12 defense-in-depth exercise, looking at single failures
13 and, one would hope, as Dennis observed, those would
14 have been identified very early on, but it is a way,
15 Bob, to test out whether to have a robust design for
16 the particular system in question.

17 That's all I wanted to add.

18 CHAIR MARTIN: Well, thanks, Walt. That
19 kind of accentuates my point there that there's value
20 for verification testing.

21 All right, thanks. Go ahead.

22 MR. JUNG: Next slide.

23 PDC 16 uses, the language and Reg Guide
24 1.232 made certain changes. So, it came up at the
25 X-Energy presentation, they are dividing the PDC into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 two, on RFDC 16 and CBC 16, and consistent with the
2 NEI 18-04 and Reg Guide NEI 21-07.

3 So, for DBEs and DBAs, these are multiple,
4 right, the barriers and fuel particles.

5 That is, essentially, X-Energy is relying
6 on these fuel particles and pebbles, their main three
7 layers there as multiple barriers or as a function for
8 CDC in the area for helium bound before AOOs.

9 And then next bullet has they're placing
10 design conditions within importance to the design
11 limits. A little bit more clear, more clear that
12 design limit is established.

13 And so, overall they feel that the
14 function of containment is approved by the Commission
15 a few years ago. And the intent of the MHTGR 16 is
16 met.

17 So, with that, you know, remember Robert
18 asked me about the question of what do you think about
19 the, you know, multi-layer approach? I, to me I still
20 go back to the LMP process. So, there's a functional
21 requirements that are placed or functional
22 categorization, requires safety functions and PRA
23 safety functions, and so on.

24 So, for more significant elements are
25 related --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR MARTIN: Please mute.

2 MR. JUNG: So, from an overall LMP
3 perspective we feel that even the intent is, I think
4 the intent of the Reg Guide is met. There's no
5 question about the fuel failure, fuel particles.

6 For helium coolant boundary aspects of the
7 layer, if I remember correctly, even in Reg Guide
8 1.232 there's a, there's a table that showed what was
9 in the GDC and what was what the staff resolution is.
10 Even the staff at the time had some discussions on it.
11 And, actually, they had a discussion and it could be
12 a layer or more.

13 So, there is a little datapoint for that.

14 But I think, you know, also X-Energy has
15 indicated that there are other SSCs, right, you know,
16 in the actual building and so on. X-Energy has
17 determined that this is sufficient criteria to meet
18 the functional requirements that they identified.

19 If they needed additional layers for
20 defense-in-depth perspective, it would have shown up.
21 That's what we saw.

22 So, we felt this is reasonable approach.

23 Yet, the whole process to still go
24 through. That's why there's the imposition of the
25 limitation in condition, it has to be still

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 demonstrated.

2 CHAIR MARTIN: Okay. Walt, I see your
3 hand's up.

4 MEMBER KIRCHNER: Yes, thank you.

5 This is an area where it's more for the
6 staff, than the applicant. I see what the applicant
7 is doing here.

8 But my assessment is that this definition
9 actually dilutes what the Reg Guide provides for, and
10 let me explain.

11 The Reg Guide takes a much more expansive
12 view of what functional containment means by basically
13 stating multiple barriers, internal or external to the
14 reactor and its cooling system, shall be provided to
15 control the release of reactivity to the environment,
16 and ensure that functional containment design
17 conditions important to safety are not exceeded for as
18 long as the postulated accident conditions require.

19 Now, postulated accident conditions
20 earlier was redefined as licensing bases events.

21 This is not, this is a rather narrow, more
22 narrow interpretation in my opinion, of what is in the
23 Reg Guide under functional containment, PDC 16.

24 And, my concern is that it's the
25 Commission policy that multiple barriers to form a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 robust containment system, to prevent unmitigated
2 radionuclide release is the intent here of this.

3 And, that's why I asked the question about
4 the (audio interference), and whether that was going
5 to be credited or not, as one of those barriers
6 earlier.

7 I just think in this case, I know it's
8 been tailored by the applicant for their particular
9 analysis based on going through the entire NEI 18-04
10 cycle.

11 But it leaves the perception perhaps to
12 the public, that this isn't quite the robust multiple
13 barrier system that the Commission and Agency had in
14 mind, when they drafted the Reg Guide.

15 So, that's a personal opinion and
16 observation. It's a problem, we've seen this with
17 other applications as well, particularly on this
18 particular PDC.

19 And, my sense, how an applicant implements
20 it is a lower level thing. But retaining that basic
21 philosophy that the Commission laid out, is important.

22 And so sometimes just an observation, this
23 multiple, this dissecting of the PDC and the ascribing
24 in this case, the helium pressure boundary only for
25 AOOs, well, you need it during normal operation anyway

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 because you depend on the purity of the helium to
2 protect the pebbles, and the particle fuel.

3 So, it's a little bit, I know that's
4 addressed also in an earlier PDC in 15 about, I think
5 it's number 15, about unmitigated moisture control on
6 access in particular, is a concern for an MHTGR using
7 a steam Rankine cycle.

8 But when these PDCs get parsed like this,
9 I wonder whether they're losing the overall intent
10 that was initially determined in the Reg Guide.

11 So, any observation from the staff would
12 be welcome. But I've seen this in a number of the
13 PDCs.

14 They were getting into actual specific
15 design detail, rather than having an overlying, or
16 overarching is the better word, PDC for the particular
17 safety function that's in question.

18 MR. JUNG: Member Kirchner, I appreciate
19 your thought and it brings up your insights, something
20 to think further.

21 But I think at least my logic and the
22 review is that my trust in the (audio interference)
23 process, right?

24 You mentioned, there was mentioning about
25 Section 5 of the NEI in 04, which has a extensive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discussion of the defense-in-depth adequacy
2 evaluation.

3 And, there's a certain criteria that comes
4 along. For example, no single features, or no single
5 element is relied upon in demonstrating
6 defense-in-depth adequacy.

7 So I'm not sure exactly how this
8 particular AOO sequence may satisfy that element.

9 And also, if you look at the reason there
10 are steps in a kind of little bit challenging
11 situation, is the lack of the helium permutation
12 itself.

13 If you look at the construction permit
14 stage defense-in-depth evaluation, the NEI 21-07 talks
15 about because of the preliminary nature of the design,
16 and the lack of a programmatic elements, then that's
17 going to come down the road.

18 It focuses more on plant capability
19 defense-in-depth, not based on a programmatic element
20 that will come along, as well.

21 So, that limits also the scope of the
22 defense-in-depth to be plant capability, based on the
23 preliminary design.

24 So, NEI 04 allows the consideration of
25 both, at the end, both capability as well as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 programmatic elements in demonstrating overall
2 defense-in-depth.

3 I just want to mention that to kind of
4 express my trust in the process that's undergoing.
5 But I think it's more at the end is the language of
6 multi-layer.

7 I do worry about a little bit, having the
8 language imposed on the designers at this juncture,
9 may potentially impose a unnecessary conservatism that
10 may, that may actually negate the potential benefit of
11 a LMP permutation.

12 CHAIR MARTIN: We've spent a lot of time
13 talking about this.

14 MEMBER ROBERTS: Yes, I was going to make
15 the exact same comment as Walt. But one thing I might
16 add is if the ACRS reviewed the functional containment
17 approach back in 2018, the recommendation, I'll just
18 read it verbatim.

19 The functional containment should contain
20 multiple barriers as defense-in-depth features that
21 should be minimally dependent upon each other, and
22 adverse of nature.

23 And per the ideals in the letter, that was
24 because of a concern that containment is more
25 important, ultimately the safety, than probably any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 other feature.

2 And so, the idea of thinking you're smart
3 enough to rely on one barrier as sufficient, is cause
4 to concern to the committee 6 years ago.

5 I just wanted to make sure you're aware of
6 that, that precedent.

7 MR. JUNG: Yes, and another challenge is
8 the unique nature of these fuel pebbles, and fuel
9 particles.

10 Again, can we say on the language of are
11 they really independent, how that in a same, same,
12 under the same pebble things like that.

13 And, but there's an even interpretation of
14 a LBE sub right, if you want a really original intent
15 of the functional containment.

16 Is it really related to design basis
17 accident in a traditional sense. It's really the
18 original containment design is based on DVAs.

19 And so, we are in this somewhat unique
20 situation with the AOOs where we don't expect the fuel
21 to exceed the subtle temperature, things that we count
22 upon, there's going to limitation for that.

23 So, it appears that where DVEs and DVAs,
24 which is a significant, potentially more significant
25 consequential event, event sequences, if we equate to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 those events, I think the multiple barriers are really
2 articulated in here.

3 Even without multi, but barriers of
4 plural. So, I see that.

5 CHAIR MARTIN: Well, certainly we have
6 between the required functional design criteria and
7 the complementary design criteria, there are certain
8 barriers (audio interference) that are acknowledged
9 whereas the corpus of the Reg Guide just has the one
10 kind of statement.

11 Because obviously in this discussion kind
12 of falls back to kind of the historic discussion that
13 led up to the Reg Guide, about containment versus
14 confinement for high temperature gas reactors.

15 And, the Reg Guide is clear that TRISO is
16 kind of a key assumption in the preparation of these
17 PDCs.

18 But it's certainly something to keep on
19 considering, particularly and I'll bring up another
20 point.

21 They have a proprietary TRISO, the
22 TRISO-X. We're all familiar with EPRI's, I just call
23 it the TRISO topical, but obviously the staff reviewed
24 that in 2023 timeframe.

25 And, obviously came to a pretty strong

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 conclusion about the particular TRISO that was tested
2 out in Idaho.

3 But they had something a little different
4 and I know you have reviewed the fuel qualification
5 topical, and have some L&Cs associated with that.

6 But all that kind of plays into the
7 functional containment story. And, at least I had a
8 question and I got some help, when I was reviewing,
9 got some help from Derek Widmayer.

10 Because he's federal officer for this
11 organization, or staff was supporting and he pulled up
12 that topical and it answered a number of questions
13 kind of related to what commitments that you already
14 have with X-Energy supporting this obviously very key
15 barrier.

16 Or maybe another word, tri-structural that
17 implies multiple barriers, obviously at the kernel,
18 around the kernel.

19 So, I do think given that little bit of
20 history, it really supports my own personal comfort
21 level with the functional containment story that you
22 already have reviewed some of this.

23 Have L&Cs already kind of on record about
24 where they need to go ultimately with demonstrating
25 the fuel performance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, given how much time we've spent on
2 this, I didn't, I wanted to give you the same question
3 I had for X-Energy on this one related to SARRDLs
4 versus functional containment, but I'm going to let
5 that one go.

6 Believe it or not, I think we're getting
7 more and more on time. So, why don't we go ahead and
8 proceed to the next one.

9 DR. SCHULTZ: I've got one more comment.

10 CHAIR MARTIN: Okay.

11 DR. SCHULTZ: One more comment.

12 In the safety evaluation, you indicate
13 that the required functional design criteria and the
14 complimentary design criteria, they have been accepted
15 by the staff.

16 But then you also remark that with regard
17 to the specific functional containment design limits,
18 those have not yet been reviewed.

19 And, I think you had just indicated that
20 the limitation in condition 1 may cover that, but I
21 didn't really see that being applicable to your
22 statement in the SE, and thought that perhaps
23 expanding that limitation and condition would be
24 appropriate.

25 MR. JUNG: I think the way we added that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 just more of a expectation. So, just like any other
2 PDC, like even PDC 2, environmental qualification type
3 of things.

4 DR. SCHULTZ: Everything would --

5 (Simultaneous speaking.)

6 MR. JUNG: Everything --

7 DR. SCHULTZ: -- sort of get to that same
8 category in terms of what needs to be done, given the
9 more detailed design information?

10 MR. JUNG: Yes, it didn't have to get the
11 NRC, but I think it's just the emphasizing that that
12 work -- demonstration of conformance to the PDC design
13 our staff to carry through by having the design limits
14 established, which will be subject to NRC's review
15 perhaps during the construction permit application.

16 DR. SCHULTZ: As well as any other changes
17 that may affect the design criteria, as well?

18 MR. JUNG: Right.

19 DR. SCHULTZ: Thank you.

20 MR. JUNG: Next item is PDC 6, which was
21 discussed earlier by X-Energy, as well. It combines,
22 you're proposing a one single criterion for this area.
23 We felt that it's actually a better idea.

24 I think as you know, the LMP brand new
25 design, it's a clean sheet approach on things. So,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 identifying this one criteria that covers broadly to
2 all safety significant access, is a great idea.

3 Actually, it simplifies not limiting, but,
4 not limiting just particular systems but having a
5 design criterion that applies to all safety
6 significant assets. We felt it was a (audio
7 interference).

8 So, PDC 11, Dan, can you cover that? Dan
9 wasn't really feeling well earlier, so.

10 MR. BEACON: It's been a rough morning.

11 MR. MOORE: Could we take a short break?
12 This is Scott Moore, from ACS. Could we take a short
13 break for about 5 minutes?

14 CHAIR MARTIN: Oh, if we need a break,
15 let's go ahead and do it. I mean, 5 minutes, let's
16 get back at 11:20.

17 (Whereupon, the above-entitled matter went
18 off the record at 11:14 a.m. and resumed at 11:21
19 a.m.)

20 CHAIR MARTIN: Okay, so we were moving on
21 to PDC 11. You may proceed.

22 MR. MUÑIZ: Dan Beacon is not feeling 100
23 percent, so I'm going to take a shot. But Dan's still
24 here; he might try to answer some of the questions.

25 So, PDC 11 on reactor inherent protection,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 TRISO fuel plays a significant role there. X-Energy
2 exposed its plan this morning so I don't want to
3 belabor this.

4 And, PDC 11 both captures MHRDC 11 and 12,
5 and also inherent protection of the TRISO fuel is one
6 of the two means that's discussed in PDC 26.

7 It's a unique design in the sense that
8 instead of two active means, there's one inherent
9 protection along with the record, the trip system that
10 poison and to come along down the road.

11 There is a, we put a little one limitation
12 condition regarding the expression of the indoor power
13 range, power operating range, where the staff because
14 of the design stages we are in, as well as the LMP
15 permutation, there might be a possibility beyond the
16 power range there might be some potential oscillations
17 and other issues.

18 So, we are proposing a limitation on that.
19 That the designers and applicant's referencing that
20 would verify that there's no such issues in other
21 ranges.

22 CHAIR MARTIN: Okay, that power oscillation
23 was actually was it 12 or, right? Oh no, you didn't
24 have it because it probably that's kind of all goes
25 together with it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But I believe there is a separate PDC
2 specifically about power operation. But, or excuse
3 me, power oscillation. Obviously it plays into what
4 you're saying here about the totality of the power
5 operation range.

6 Okay, so just wanted, if anybody was
7 looking at the topical, you might want to look at
8 also, I think it's 12.

9 MR. MUÑIZ: Appreciate it.

10 So, limitation 2, yes, as Dr. Martin
11 mentioned, it has relationship to the MHTGR-DC 12.

12 Next.

13 CHAIR MARTIN: So, they say subsumed by PDC
14 11. Okay, so they integrate the two.

15 MR. MUÑIZ: Right.

16 CHAIR MARTIN: Okay, I guess my bad. I
17 mean, obviously the 12, 12 has always been there in
18 Reg Guide, but that's what they did kind of the same
19 way they used PDC 6 and just propagated its role.

20 MR. MUÑIZ: Yes, so PDC 11 captures both 11
21 and 12.

22 CHAIR MARTIN: I see.

23 MR. MUÑIZ: PDC 14 reactor helium pressure
24 boundary, and testing considerations are removed and
25 integrity part is captured by PDC 70.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 If you look at the PDC 70, it talks about
2 the integrity of the reactor helium pressure boundary.
3 PDC 6 as discussed earlier, it covers all testing
4 provisions for all the safety significant assets is
5 covered.

6 There is a, I'm trying to read through it.
7 Yes, what I was going to mention is that is ingress of
8 moisture, air, and secondary coolant to other fluid is
9 replaced with a moisture ingress, based on current
10 their design.

11 But I think staff is proposing the
12 limitation and condition that needs to be verified,
13 depending on the LMP implementation and the design.

14 We just couldn't see without the detailed
15 design, whether the moisture ingress simplification is
16 sufficient or not.

17 So, we are imposing a limitation of that.

18 MR. METZROTH: And, does this somewhat
19 imply that they don't believe, they don't, reliability
20 frequency of event data, that you can't have a double
21 guillotine break that when you consider the
22 characteristics of the most serious breach of the
23 pressure boundary, that it just falls outside of the
24 likelihood range.

25 And as a consequence, they're looking at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the next one up that is the moisture ingress. Is that
2 a basis for excluding mention of airing?

3 Because obviously you've captured it as
4 the limitation condition because there's more to be
5 said about it, I'm sure.

6 But is that the way you interpreted it?

7 MR. MUÑIZ: It doesn't ring me a bell the
8 specifics of this. Can I call up X-Energy to kind of
9 chime on that?

10 If you can speak up?

11 MR. METZROTH: Could you repeat the
12 specific question?

13 CHAIR MARTIN: Actually, Kyle, could you
14 just stand over here to make sure that everyone can
15 hear you.

16 MR. METZROTH: So, the gist of the question
17 was the statement that you provided here, which
18 effectively excludes the European press.

19 Because it's fine that you've kind of
20 excluded the largest breaks based on your PRA model.

21 (Simultaneous speaking.)

22 MR. NIGH: It's based on an evaluation of
23 the design, and looking at the frequency of various
24 break sizes.

25 Including that there are certain break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 sizes that fall in the design basis event region; and
2 certain fall outside of that.

3 So, the size that we have, we don't have
4 --

5 (Simultaneous speaking.)

6 MR. METZROTH: If you pressurize enough --

7 MR. NIGH: -- to have a significance. We
8 mentioned earlier we evaluate any possibility of that
9 occurring, but it's not enough, it's not break size
10 where we have a significant amount that gets in such
11 that it's a big concern.

12 MR. METZROTH: Yes, and you got to kind of
13 where you said there's no possibility for like a
14 double heat guillotine break, for example.

15 MR. NIGH: Right.

16 MR. METZROTH: Like, we did look what if
17 two holes open up in the helium pressure boundary.
18 And, that event is sufficiently unlikely that it
19 wouldn't be covered by this PDC.

20 PARTICIPANT: Can you identify yourselves
21 again for the court reporter, please?

22 MR. METZROTH: Oh, sorry, Kyle Metzroth.

23 MR. NIGH: Drew Nigh.

24 CHAIR MARTIN: It seemed obvious connecting
25 the dots, but I just wanted to hear it from you two.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. NIGH: Thank you.

2 MR. MUÑIZ: That's how I was going to
3 answer, but.

4 (Laughter.)

5 MR. MUÑIZ: I'm saved. PDC 26 next slide.

6 It was discussed earlier a little bit, PDC
7 26. There are several requirements the provisions, we
8 evaluated each one of them.

9 The key one being in the event and diverse
10 means to achieve, they shut down and a puncture rod is
11 one of the method. And the other one is inherent
12 reactivity feedback I discussed.

13 And, I'm not going to go through it.
14 There's RFTC and CTC related to DVEs. And DVEs and
15 DVAs, and AOs.

16 And, yes, so we felt that the underlying
17 intent of the Reg Guide 1.232 is achieved by this PDC
18 26 proposed.

19 MEMBER KIRCHNER: This is Walt Kirchner.
20 Could you elaborate? I'm not following the logic
21 here. This is a moderated, a gas-cooled graphite
22 moderated TRISO fueled reactor.

23 As you cool down the plant, it adds
24 reactivity. So I'm not getting the logic that
25 certainly that characteristic is desirable to prevent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactivity insertion accidents, or overheating. And
2 suppression of reactor power oscillations.

3 But as you cool down this system, you will
4 be adding reactivity. So, I don't understand the
5 logic of saying the inherent feedback effect is part
6 of the means, diverse means of achieving shutdown.

7 You're going to need control rods and
8 shutdown, and an independent shutdown mechanism to
9 achieve a cold shutdown condition.

10 MR. MUÑIZ: I'm going to call upon Dan or
11 X-Energy. I'm not a reactor engineer, but my
12 understanding is, is that the inherent reactivity
13 feedback mechanism demonstrated by the sum of the task
14 team, and to be further demonstrated a by fuel
15 qualification.

16 It demonstrated that the negative reactive
17 feedback is sufficient enough to reach a shutdown
18 condition.

19 That's an interesting --

20 (Simultaneous speaking.)

21 MEMBER KIRCHNER: No, no, the negative
22 feedback protects you against overheating reactivity
23 transients. It doesn't shut you down.

24 It adds reactivity as you cool down the
25 system. So therefore, you need sufficient reactivity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in the control systems, likely control rods, some
2 designs, smaller designs may use drones.

3 But, and then you'll need two independent
4 mechanisms to satisfy the overall intent of PDC 26.
5 But the inherent reactivity feedback, which is
6 desirable for overheating and reactivity insertion
7 transients, doesn't work to your advantage when you're
8 cooling down a reactor like this.

9 You're adding reactivity as you cool down
10 the system.

11 CHAIR MARTIN: I will add, I noticed, I
12 have to check but cold shutdown is not used here,
13 right?

14 MEMBER KIRCHNER: No, it isn't. The
15 condition already issued back, it was cited by the
16 applicant in one of the -- no, sorry.

17 It was cited in the Reg Guide 1.232 of the
18 conditions position on achieving shutdown. And not
19 requiring a cold shutdown, realizing that the mass,
20 the inventory, the thermal inertia for lack of a
21 better description of such a system, doesn't allow you
22 to achieve a cold shutdown condition like is possible
23 in a LWR system, in a reasonable period of time.

24 So, the condition recognized that and the
25 Agency made provisions for that. But what I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 objecting to is that the inherent feedback that you
2 get out of this kind of reactor design, protects you
3 against overheating transients, protects you against
4 reactivity insertion accidents.

5 But it doesn't help you shut down. You
6 have to compensate for the fact that as you shut down
7 this system and it cools down, that that adds
8 reactivity and hence, the reactor control systems,
9 reactivity control systems need to be designed
10 accordingly.

11 Then, to have a diverse means, you have
12 usually control rods and then shutdown rods. And for
13 most MHTGR designs that I'm familiar with, so that you
14 can actually have a means to ensure that you don't
15 return to criticality as the system cools down.

16 CHAIR MARTIN: So, the PDC, I wasn't and
17 maybe I'm being too generous, but the PDC as they have
18 written, has mentioned movable poisons.

19 I guess they don't, doesn't necessarily
20 apply what you say here, just control rods. I guess
21 I felt like the PDC was a still, maybe still open to
22 some interpretation about the means.

23 They had pointed specifically to PDC 11
24 related to the inherent reactivity feedback. I guess
25 my impression coming out of the earlier meeting, was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that there was at least an opportunity for X-Energy to
2 address that in a more specific manner.

3 PARTICIPANT: Well, don't you want to say
4 something?

5 MR. VAUGHN: Yes, definitely.

6 PARTICIPANT: Please introduce yourself.

7 MR. VAUGHN: Yes, yes, Steve Vaughn,
8 Licensee X-Energy. Yes, great question, Member
9 Kirchner.

10 And we can discuss more details in the
11 closed portion if you want, but you're right, the
12 inherent reactivity will take heat down to a certain
13 temperature, right, then it will start to add positive
14 reactivity.

15 And so PDC RTC 26 this let's say shutdown
16 rods, will cover all modes, all temperatures. If you
17 want to get into the details in the closed, we can
18 talk to you in a little more detail about that. But
19 we're getting into specific design criteria right now.

20 CHAIR MARTIN: Does the way you've written
21 that the PDC 26, Bill, support what Walt's saying here
22 about a diverse and even cold shutdown? Something a
23 specific concern.

24 MR. VAUGHN: The comment that safety
25 analysis will show that combination of inherent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactivity feedback in RFDC 11, plus PDC RFC 26, the
2 safe shutdown rods, will get you to safe shutdown
3 margin for all modes.

4 CHAIR MARTIN: Yes, I guess I agree. I
5 feel like we're getting close to proprietary content.
6 So I don't know if we can pursue this.

7 What do you feel, Walt? I mean.

8 MEMBER KIRCHNER: No, I'm just making the
9 observation that you don't get to the shutdown based
10 on the inherent feedback conditions.

11 That they will provide a means for holding
12 the reactor shutdown so that they can go to refueling,
13 et cetera, et cetera.

14 So, I'm just making a point that we
15 shouldn't mix up, yes, this is true. You've got a
16 desirable design characteristic for this system to
17 prevent reactivity insertion accidents, and
18 overheating. And that's inherent.

19 You still need two control rod control
20 systems to achieve and meet the goal of PDC 26.

21 CHAIR MARTIN: All right, so like I said,
22 I still don't think we can go much further into this
23 without getting into some very specific stuff.

24 MEMBER KIRCHNER: Okay.

25 CHAIR MARTIN: But it's a good point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: No, I just, the first
2 bullet there just is a little misleading.

3 CHAIR MARTIN: I would agree.

4 MEMBER KIRCHNER: To meet the intent of PDC
5 26, you're going to need in the case of an MHTGR
6 design, two active control rod, control-like
7 reactivity control systems. That's my point.

8 With the inherent reactivity feedback is
9 a desirable characteristic that will prevent the power
10 oscillations, and other aspects that are mentioned in
11 PDC 11 and 12.

12 PARTICIPANT: Yes, we can take it up on the
13 closed session, thank you.

14 MR. JUNG: Yes, we'll wait until that
15 closed session.

16 CHAIR MARTIN: All right, well we're like,
17 I'm not sure our schedule supports a closed session.
18 Is that fair to say?

19 DR. BLEY: This is Dennis. I wanted to
20 sneak a question in kind of for Walt. When I read
21 that first bullet, it doesn't say that means 1 and
22 means 2 either one works. It says and.

23 So, I'm wondering if we're, the arguments
24 about interpreting at that bullet saying that you can
25 wait till the later session for that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: Yes, it can, Dennis.
2 You're correct. I was just reacting to that, the way
3 it is presented in the view graph, which is different
4 than the actual PDC.

5 CHAIR MARTIN: It is different than what it
6 appears in any.

7 MR. SNODDERLY: So Bob, this is Mike
8 Snodderly with the ACRS staff. We have the ability to
9 go to a closed session. There is a MS Teams meeting
10 available.

11 I suggest we finish the open session, get
12 public comment, and then we can, and then see what
13 time, what the time is like and figure out next steps.

14 MR. MOORE: This is Scott Martin. We do
15 need to start the afternoon session at 1:00 o'clock.

16 CHAIR MARTIN: Exactly, so we do have a
17 constraint. I'd like to provide a little time for
18 lunch but we're used to pinching that a little bit.

19 Anyway, let's proceed and we'll see if we
20 can't provide a little more clarity in a closed
21 session on this question.

22 MR. MUÑIZ: Yes, I'm a substitute player so
23 expectations should be a little bit lower.

24 So, this is time for procedural heat
25 removal passage system for, within that particular

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 function is done through the fuel, and that
2 radionuclide limits are met for the DVEs and DVAs and
3 a 50-34 limit.

4 There's a active system that provides the
5 decay heat removal function, such that the SARRDLs
6 have not exited for AOOs.

7 But it's a CDC, normal operation size for
8 CDC, the helium, the circulating system plays a role
9 there.

10 The HP, helium pressure boundary
11 maintaining core geometries as discussed earlier in
12 PDC 7, related to integrity of the helium pressure
13 boundary system.

14 We felt that overall, the intent of direct
15 access on that.

16 Okay, next one.

17 I think this was the last item before the
18 limitation condition. PDC 70, reactor vessel and
19 reactor systems short design basis, and there's some
20 changes are made to be a little bit more specific
21 regarding the helium pressure boundary, and core
22 internal support reactor integrity.

23 And also, achieving low and also achieving
24 low probability of radically profligating failure
25 during DVEs and DVAs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And also, that also supports PDC 14 that
2 was discussed by the X-Energy earlier this morning,
3 ensuring core geometry for passive heat removal of
4 residual heat.

5 Also, it's part of this PDC, it supports
6 PDC 34, permitting, permits insertion of the neutron
7 observers and maintain core reactor inherent
8 protection.

9 As we discussed earlier, it is tied to PDC
10 11 and 26. So, we feel that intent of the MHTGR DC 70
11 is met.

12 CHAIR MARTIN: One just comment/question
13 possibly.

14 The language of course, focuses on the
15 core internals. You mentioned ensure geometry for
16 passive heat removal.

17 There's also a permit insertions of
18 neutrons. But in addition, guarding reactivity
19 control, the integrity of those neutron absorbers has
20 to be assured like a light water reactor, because we
21 worry about control rod elements. Same sort of thing
22 here.

23 And, those familiar with high temperature
24 gas reactors might be aware that Japan's HGTR
25 facility, they were very sensitive about that. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 they have a very interesting reactivity control
2 system.

3 These delay neutron, or excuse me, control
4 rod insertions, in the hottest part of the core to
5 make sure that they don't have this concern.

6 And, I can read the PDC and come to an
7 interpretation that obviously addresses some thermal
8 safety limit on control rod temperatures.

9 Do you feel like the language is strong
10 enough? Did you think through that particular aspect
11 of PDC 70 when you were going through this?

12 MR. MUÑIZ: I think about I can help.
13 Dan's chiming in but I think overall, that the
14 language there in terms of the scope of reactor vessel
15 and the internals inside of it, talk about how do you
16 captures overall, all the elements of safety, safety
17 significant assets.

18 Dan, can you chime in?

19 CHAIR MARTIN: It's certainly a temptation
20 to look at any one of these. I mean, for instance we
21 were looking at 26 and that's very much a reactivity
22 control safety function.

23 But I think here with 70, it actually
24 crosses the safety functions. It's not just a heat
25 removal, but there's also, and it touches reactivity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 control and its integrity.

2 MR. MUÑIZ: Yes, eventually it gets to the
3 issue of performing requires safety functions, and the
4 structural integrity as well as the reactivity
5 insertion.

6 All those things play together.

7 CHAIR MARTIN: Thank you.

8 MR. MUÑIZ: Next slide.

9 So keeping an eye on that, I'm not going
10 to labor too much. The first one is the really the
11 kind of more overarching limitation condition given
12 the preliminary nature of the design, as well as
13 implementation of LMP.

14 We are imposing a, this overarching
15 limitation of condition that says basically the
16 applicants for licenses referencing this topic report,
17 would confirm these PDCs are sufficient.

18 Because the further implementation of the
19 design and LMP, may identify changes were dealt up
20 from the what we proposed.

21 DR. BLEY: Excuse me, this is Dennis Bley.

22 I want to make a comment on these, and I
23 wanted to do it before you go through them all so you
24 could maybe address my comment and question as you go
25 through.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Number 1 and 3 here really bothered me.
2 Number 2 bothered me a little bit. And, my concern is
3 my understanding of topical reports once they're
4 approved, is that when you actually use them in the
5 license application, you have to essentially do the
6 things that are listed here.

7 And if we're taking out a few things, it
8 might give people the impression unless limitations
9 and conditions are proposed, they don't need to go
10 back over everything in the topical report and make
11 sure it's applicable to their design.

12 Now, number 2 is, fits that as well, but
13 number 2 has at least the sense of something that
14 might be forgotten.

15 But it seems to me these are basically
16 unnecessary, and could give a wrong impression that
17 you need something like this to relook at any issues
18 in the topical report, when the license comes up.

19 So, if you can talk about that as you go
20 through these, I'd appreciate it.

21 MR. MUÑIZ: Yes, our intention is not to
22 give that impression that the rest of the topical
23 report that we approve are not evaluated for
24 applicability.

25 We felt that number 1 and 3 are in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 same realm in terms of kind of more of a, I think it
2 was a sufficient number 1.

3 We felt it was sufficient to --

4 (Simultaneous speaking.)

5 DR. BLEY: I feel like a checklist for you
6 guys on what to look for when the actual application
7 comes in. But I stand with what I said before about
8 why it bothers me.

9 MR. MUÑIZ: Purely speaking, number 1 and
10 3 may not have been imposed, but we felt that still is
11 a unique approach.

12 And LMP implementation being that's fully
13 exercised, we wanted to emphasize this area very
14 strongly so that we actually give the clear indication
15 that what we are proving is based on somewhat limited
16 implementation of the design, as well as the LMP.

17 DR. BLEY: Yes, that's --

18 (Simultaneous speaking.)

19 DR. BLEY: -- that's true, but it always
20 is required for using a topical report that you make
21 sure all the assumptions in that report apply to your
22 design.

23 So, my worry is what I said, that somebody
24 might be reading this and thinking, unless things are
25 spelled out in limitations and conditions, they don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 need to do much more when they use it in the license
2 application.

3 I'm sure that doesn't apply to this
4 applicant, but it might to others.

5 MR. MUÑIZ: Understood. I think it's
6 something that X-Energy is, for at least for X-Energy,
7 are intending to be part of the future licensing
8 applications and so on, I think it's there.

9 But we understand your point, and but
10 fundamentally though, all the fundamentals of use of
11 topical reports as approved by the NRC staff, tends to
12 be consistently emphasized to the other applicants.

13 CHAIR MARTIN: We might have to look at
14 these as IOUs, right? Because we're on conformation,
15 future license application reference.

16 PDCs, and I'm voicing an opinion, should
17 ultimately be without L&Cs. At some point when you
18 have all the information, there are no L&Cs associated
19 with the GDC, right? Those are design criteria for
20 light water reactors.

21 Unlike other topic reports, I can see this
22 being revised much later in the license application
23 process where it's clear, meaning you cleared the L&Cs
24 because you have all the necessary information.

25 I know the PDC process is relatively new.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Surprisingly, it's only the third one we've seen. But
2 how do you feel about the idea that to a point, you
3 need to clear the L&Cs?

4 That's for really both the applicant that
5 you come to an agreement that these are the ones that
6 apply to Xe-100, and we are satisfied with this set
7 that it covers kind of after you've gone through these
8 L&Cs, and that I've confirmed and I've seen the PRAs,
9 I've seen the accident analyses.

10 There's convincing evidence that they have
11 really done everything they said in this PDC document.

12 Now, I will note that of course, I think
13 both in your SE and in their topical, it kind of says
14 yes, we may revisiting this.

15 But the ultimate goal I think, should be
16 to get rid of these L&Cs. Is that how everyone feels?

17 MR. MUÑIZ: From a staff's perspective,
18 that's a ideal case where there's no limitation
19 addition. Plus as these GDCs are applied, there might
20 be some lessons learned on how exactly this criteria
21 led.

22 So there could be a future improvements.

23 CHAIR MARTIN: Yes, Steven?

24 MR. VAUGHN: Before X-Energy had agreed
25 during the upgrading license application, you expect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this top report to be a rev 4 and or 5, and we
2 wouldn't expect any license conditions on it.

3 CHAIR MARTIN: You can't have an IOU and
4 approve a plant, right?

5 MR. MUÑIZ: Next slide.

6 Just quick conclusion. So, based on our
7 review, we found that X-Energy has provided a
8 reasonable set of PDCs that are appropriate for
9 establishing the requirements of the Xe-100 design,
10 consistent with the intent of the Reg Guide and LMP
11 guidance that I discussed.

12 These are subject to the limitation
13 condition we discussed. We found that this PDC
14 established the necessary design fabrication,
15 construction, testing and improvements design criteria
16 for safety significant SSEs to provide reasonable
17 assurance that the design could be operated with undue
18 risk to health and safety of the public.

19 Therefore, revision 3 of the topical
20 report is suitable for referencing and future
21 licensing applications under 10 CFR Part 50, Parts 50
22 and 52, for the Xe-100 design.

23 That's all we have.

24 CHAIR MARTIN: Great, open up for any
25 member or consultant questions? Anybody online?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Once, going twice?

2 I think at this point, I could open up for
3 public comment. So anyone, any member of the public
4 like to?

5 Ed Lyman, I see your hand raised.

6 DR. LYMAN: Yes, hi, it's Edwin Lyman, from
7 Union of Concerned Scientists. Can you hear me?

8 CHAIR MARTIN: Yes.

9 DR. LYMAN: Yes.

10 Yes, I'd just like to say I'm disappointed
11 that there was not further attempt to resolve Member
12 Kirchner's comments about the diverse reactivity
13 control system, GDC.

14 Just from what was presented here, it does
15 not look like what has been proposed as consistent, or
16 the same level of safety as a light water reactor,
17 because light water reactors also under most
18 conditions, have inherent negative reactivity
19 feedback. Yet, they have two diverse shutdown systems
20 in addition to that.

21 So, at least from what's presented here,
22 it looks like this would not have the same or
23 equivalent level of safety to light water reactors.

24 So, I'm hoping that more information about
25 that can be provided publicly, because I don't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 confidence in what I've seen.

2 The second point with regard to functional
3 containment. Again, I would, I think Member
4 Kirchner's observations are very relevant.

5 This is something that of course, is
6 cross-cutting. It's also applied to the Sodium
7 design. Every other plant with a functional
8 containment. I'm deeply concerned.

9 And I have very little confidence in the
10 process, especially in a Part 50 context where these
11 are being used, this approach is being used for
12 fundamental, making fundamental design choices based
13 on an inadequate dataset.

14 And, as is the case with the Sodium,
15 there are key issues related to fuel performance that
16 have not, that there is not the experimental data
17 available to validate those. Yet this key decision
18 about whether to have a containment or not depends
19 critically on the fuel performance, and questions that
20 may not be resolved until the plant is actually
21 operating. And, fuel performance data has been
22 accumulated.

23 So, I'm deeply concerned that for these
24 paper designs to rely too heavily on expectations
25 about fuel performance to make these critical design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 choices like functional containment or not, put great
2 risk on the applicant.

3 Okay, so that's the applicant's problem.
4 But I'm worried that the NRC ultimately is not going
5 to make a decision to deny an operating license, even
6 if there is a significant design choice that turns out
7 to be wrong, based on the accumulation of operating
8 data. So, I think a holistic, you have to take a step
9 back and look at what is being proposed here, and
10 whether there should be more conservative design
11 criteria, especially for a first of a kind plant.

12 Thank you.

13 CHAIR MARTIN: Thank you.

14 Are there any other further questions from
15 members of the public?

16 (No audible response.)

17 CHAIR MARTIN: All right, I need help
18 transitioning to a closed session so we can kind of
19 answer the, that one question that came up.

20 MR. SNODDERLY: Yes, Dr. Martin. So, I ask
21 that you close this open session and then we would be
22 the closed session invite. If there's anyone that
23 does not have the invitation to the closed session,
24 could you please raise your hand and we'll make sure
25 we forward it to you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR MARTIN: Okay, I don't think I got
2 it.

3 MR. SNODDERLY: Okay, so Derek, if you
4 could please forward the invitation to Bob. Everybody
5 else has it? Okay.

6 And then, so once Chairman Martin closes
7 this session.

8 CHAIR MARTIN: Yes, so all of a sudden we
9 have thee hands raised. Are these members of the
10 public?

11 MR. SNODDERLY: James is our court
12 reporter. So Derek, please send the invite to James
13 Cordes.

14 MR. WIDMAYER: Okay.

15 MR. SNODDERLY: Or to Shannon, then Shan,
16 we need to get it to James. And I'm sorry, Mr.
17 Stuhdreher.

18 MR. STUHDREHER: Stuhdreher, yes.

19 MR. SNODDERLY: Stuhdreher, can you please
20 identify yourself or your question?

21 MR. STUHDREHER: Yes, I was asking for the
22 meeting for the closed portion of this. I'm with the
23 Department of Energy.

24 MR. SNODDERLY: That's up to, can someone
25 from X-Energy please send an invite, or?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. MADDOCKS: Hey, this is Jessica with
2 X-Energy, Project Manager. Check your email. I sent
3 it out to you, but it's in an email. It's not a
4 meeting notice.

5 MR. STUHDREHER: Oh, okay, all right, thank
6 you.

7 MR. SNODDERLY: Thank you, Jessica.

8 Is there anyone on the line, anyone else
9 on the line that feels that they have a need to know?
10 Please identify yourself and make a request so that we
11 can determine whether.

12 (Pause.)

13 CHAIR MARTIN: Okay, if we can, I don't
14 want to leave this right, until James, until we,
15 James, can you please, let's stay on the line until
16 James confirms that he has the invite.

17 PARTICIPANT: No dogs allowed at the
18 meeting.

19 CHAIR MARTIN: Yes, no dogs.

20 Okay, James, let's --

21 MEMBER DIMITRIJEVIC: I don't also see
22 invite in my email. So this is Vesna, hi. So Derek,
23 can you also make sure that you send it to my Gmail?
24 Since I'm not in Boston.

25 MR. SNODDERLY: Okay, I will do that right

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 now.

2 MEMBER DIMITRIJEVIC: Okay, thanks.

3 MR. SNODDERLY: And I'm going to do it to
4 James, too.

5 CHAIR MARTIN: Yes, thanks, Mike. I
6 couldn't get a, I've been forwarding it but I've lost
7 the ability to do such all of a sudden.

8 MR. SNODDERLY: Okay.

9 MR. WIDMAYER: So, I think it was just
10 James and --

11 MR. SNODDERLY: Right, and James.

12 MEMBER DIMITRIJEVIC: And, Vesna.

13 MR. WIDMAYER: And, Vesna, yes.

14 MR. SNODDERLY: Yes, I've got Vesna.

15 Shan, are you on the line?

16 (No audible response.)

17 MR. SNODDERLY: I don't, all right, James,
18 please put your email address in the chat. For this
19 meeting.

20 MR. WIDMAYER: Yes, he just did.

21 MR. SNODDERLY: Okay.

22 MR. WIDMAYER: Walt, you've got your hand
23 up again?

24 MEMBER KIRCHNER: Yes, could you forward
25 that closed invitation?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. WIDMAYER: Oh, yes, I missed, you, yes.

2 Hey, Mike, can you forward it to Walt?

3 MR. SNODDERLY: Yes.

4 (Pause.)

5 MR. SNODDERLY: Walt, I just sent it to
6 your NRC email address. Is that acceptable?

7 (No audible response.)

8 DR. BLEY: Hey Mike, Dennis Bley.

9 MR. SNODDERLY: Yes, Dennis?

10 DR. BLEY: I was sure I had it but I've got
11 the one for tomorrow. I don't have this one.

12 MR. SNODDERLY: No worries, no worries, no
13 worries. I think the main, we just need to get, I'm
14 doing that now.

15 MR. WIDMAYER: Yes, you should have it
16 Dennis.

17 (Pause.)

18 MR. SNODDERLY: All right, I've asked
19 Chairman Martin to please close this meeting and
20 everyone please go to the closed session.

21 CHAIR MARTIN: Great, I'm going to use the
22 gavel here. We're closing this open session on the
23 Xe-100 principal design criteria.

24 (Whereupon, the above-entitled matter went
25 off the record at 12:04 p.m.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

NRC Staff Review of the X-energy Principal Design Criteria Topical Report for the Xe-100 Reactor Design

Adrian Muñiz, Senior Project Manager

Ian Jung, Senior Reliability and Risk Analyst

Dan Beacon, Nuclear Engineer

Office of Nuclear Reactor Regulation

Division of Advanced Reactors and
Non-Power Production and Utilization Facilities

Topical Report Purpose

- Purpose of the topical report:
 - Describes X-energy's process for developing principal design criteria (PDC)
 - Requests the U.S. Nuclear Regulatory Commission (NRC) staff review and approval of proposed PDCs
 - To comply with applicable regulatory requirements under Title 10 of the *Code of Federal Regulations* (10 CFR) Parts 50 and 52
 - To support the design and licensing process

Review Chronology

- Revision 1 of the topical report (ADAMS Access No. ML22195A260) on July 13, 2022
- Staff's preliminary questions and X-energy responses in a letter dated December 30, 2022 (ML22364A293)
- Regulatory audit to support its review based on an audit plan (ML23009B755) and documented its observations in an audit report dated January 19, 2023 (ML23093A215).
- Revision 2 (ML23181A172) on June 30, 2023
- Staff's additional questions (ML23277A274) on Revision 2 and discussion with X-energy in a public meeting (ML23346A120)
- Revision 3 (ML24047A308) addressing staff questions during the review and X-energy's self-identified items
- Draft safety evaluation issued (ML24190A060) on July 17, 2024 (based on Revision 3)

Regulations

- In accordance with the provisions of 10 CFR Parts 50 and 52, licensing applicants must submit PDCs for the proposed facility.
 - For example, 10 CFR 50.34(a)(3)(i), which requires, in part, that applications for a construction permit (CP) include PDCs for the facility.
- 10 CFR Part 50, Appendix A discusses the scope and content of PDCs:



“[PDCs] establish the necessary design, fabrication, construction, testing, and performance requirements for structures, systems, and components important to safety; that is, structures, systems, and components [SSCs] that provide reasonable assurance that the facility can be operated without undue risk to the health and safety of the public.”

Guidance

- Regulatory Guide (RG) 1.232, “Guidance for Developing Principal Design Criteria for Non-Light Water Reactors” (ML17325A611)
 - Appendix C provides Modular High-Temperature Gas Reactor Design Criteria (MHTGR-DCs)
- RG 1.233, “Guidance for a Technology-Inclusive, Risk-Informed, and Performance-Based Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light Water Reactors” (ML20091L698)
 - Endorses Nuclear Energy Institute (NEI) 18-04, “Risk-Informed Performance-Based Technology Inclusive Guidance for Non-Light Water Reactor Licensing Basis Development,” Revision 1 (ML19241A472)
- RG 1.253, “Guidance for a Technology-Inclusive Content of Application Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light-Water Reactors,” (ML23269A222)
 - Endorses NEI 21-07, “Technology Inclusive Guidance for Non-Light Water Reactors – Safety Analysis Report: For Applications Utilizing the NEI 18-04 Methodology,” Revision 1 (ML22060A190).

Xe-100 Design

- Key features
 - Pebble bed, high-temperature gas-cooled reactor (HTGR)
 - Tri-structural isotropic (TRISO) fuel
 - Graphite moderator
 - Helium-cooled
 - Passive heat removal
 - No active electrical power to perform required safety functions



Xe-100 PDC Approach and Overview

- Xe-100 PDCs are based on MHTGR-DCs (Appendix C of RG 1.232)
 - Xe-100 and MHTGR substantially similar
 - Some PDCs modify MHTGR-DCs to reflect Xe-100
- Xe-100 PDCs are also based on the LMP implementation
 - Risk-informed and performance-based approach
 - Required safety functions (RSFs), required functional design criteria (RFDC), probabilistic risk assessment (PRA) safety functions (PSFs), and complementary design criteria (CDC)
 - Terminologies based on the LMP
- The NRC staff's review used applicable regulatory guidance, mainly RGs 1.232 and 1.233 as applied to PDCs.
 - Evaluate deviations from RG 1.232 in consideration of the key Xe-100 design features and the LMP implementation

General Changes to PDCs

- Staff review focus: Key differences between the Xe-100 PDCs and the MHTGR-DCs including:
 - Use of the term “safety-significant”
 - Scope of licensing basis events (LBEs) in PDCs
 - Single PDC for monitoring, testing, inspection, and surveillance of safety-significant SSCs
 - PDC 26, “Reactivity control systems”
 - PDC 34, “Residual heat removal”

Use of the term “safety-significant”

- Replace “important to safety” from RG 1.232 with “safety-significant” to align with language from NEI 18-04
- RG 1.233: “Applicants referencing this RG are expected to use the terminology in NEI 18-04”
- Advanced Reactor Content of Application Project (ARCAP) DANU-ISG-2022-01, “Review of Risk-Informed, Technology-Inclusive Advanced Reactor Applications—Roadmap” (ML23277A139) identified that some SSCs may be “important to safety” but not “safety-significant” per NEI 18-04 process
 - No gap because of use of RG 1.232

Scope of LBEs for the Proposed PDCs

- X-energy replaces the terms such as ‘postulated accident’ or ‘accident conditions’ used in MHTGR-DCs in RG 1.232 with those describing LBEs* used in NEI 18-04.
- BDBEs are not included in the scope of the Xe-100 PDCs based on the current design and analysis.
- RG 1.253 provides guidance on scope of PDCs for LMP-based applications. Proposed PDCs need to address the functions provided by both safety-related (SR) and NSRST SSCs.
- Xe-100 design is preliminary and implementation of the LMP process is in progress. Proposed PDCs may not represent a full set of PDCs for all SSCs that are safety-significant. The NRC staff proposes a Limitation/Condition (item (1)).

*Anticipated Operational Occurrences(AOOs), Design Basis events (DBEs), Beyond Design Basis Events (BDBEs), and Design Basis Accidents (DBAs)

PDCs for normal operations and use of Owner Controlled Design Criteria (OCDCs)

- X-energy's proposed PDCs (i.e., 2, 4, 10, 13, 15, 19, 22, 26, 34, 44, 60, 61, and 64) include criteria associated with normal operations or conditions.
- X-energy uses OCDCs to designate design criteria for NST SSCs that are not required to be met during AOOs, DBEs, or DBAs.
 - NST SSCs are not classified as safety-significant SSCs according to the LMP process.
 - OCDCs are not part of the Xe-100 design bases scope
- Use of OCDCs for design criteria that correspond to NST SSCs distinguishes OCDCs from PDCs (RFDCs and CDCs) that correspond to SR and NSRST SSCs.

Replacement of single-failure criterion with reliability criterion

- PDCs 17, 34, and 44 do not use the single-failure criterion language in RG 1.232.
- X-energy is using the approach described in NEI 18-04 as endorsed by RG 1.233.
 - Commission approval in SRM-SECY-03-0047
- The NEI 18-04 methodology subjects the design to a reliability criterion (e.g., a reliability target) and to an evaluation of defense-in-depth (DID) adequacy based on assessments of event sequences.

PDC 16: Use of functional containment concept

- PDC 16 uses the language of MHTGR-DC 16 with changes.
 - PDC-RFDC 16 for barriers in fuel particles and pebbles for DBEs and DBAs.
 - PDC-CDC 16 for a barrier of the helium pressure boundary for AOOs.
- Additionally, replaces “design conditions important to safety” with “design limit” to clearly articulate that a design limit related to the functional containment exists and cannot be exceeded.
- Meets the intent of MHTGR-DC 16 in RG 1.232.
 - The Commission approved the use of functional containment concept in Staff Requirements Memorandum (SRM) to SECY-18-0096.

PDC 6, “Monitoring, Inspection, Testing, Surveillance”

- X-energy proposes PDC 6 as a single criterion for monitoring, testing, inspection, and surveillance of safety-significant SSCs.
 - Subsumes MHTGR-DCs 18, 31, 36, 37, 45, and 46
- Meets the underlying intent of the related MHTGR-DCs in RG 1.232.
 - Scope of activities consistent with those that would be required by the subsumed MHTGR-DCs
 - Broadly applicable to all safety-significant SSCs (i.e., SR and NSRST SSCs)

PDC 11, “Reactor inherent protection”

- Meets the intent of MHTGR-DCs 11 and 12
- Also provides for one of the two means to meet the intent of MHTGR-DC 26 (“adequately control heat generation”)
- Sufficient negative reactivity feedback ensures fuel performance and radionuclide release limits are not exceeded for DBEs and DBAs, and that specified acceptable system radionuclide release design limits (SARRDLs) are not exceeded for AOOs
- Condition/Limitation 2: The “in the power operating range” phrase is expanded to ensure that safety analyses include the full scope of the power operating range, DBE, and DBA conditions

PDC 14, “Reactor helium pressure boundary”

- Integrity and testing considerations are removed from corresponding MHTGR-DC 14.
 - Covered by PDC 70 and PDC 6, respectively.
- “Ingress of moisture, air, secondary coolant, or other fluids” is replaced with “moisture ingress.”
 - No risk-significant AOOs, DBEs, or DBAs with unacceptable ingress of air or other fluids. (Limitation/Condition item 3 applies)
 - “Moisture” encompasses the secondary coolant (water).

PDC 26, “Reactivity control systems”

- The independent and diverse means are control rods (means 1) and inherent reactivity feedback (means 2)
- Control rods insert and maintain safe shutdown for DBEs and DBAs (RFDC)
- Independent and diverse means ensure SARRDLs and HPB limits are not exceeded, and safe shutdown is achieved and maintained for AOOs (CDC) and normal operations (OCDC)
- Means to support shutdown interventions: Included verbatim from MHTGR-DC 26 paragraph 4 (PDC)
- Further supported by PDC-RFDC 11 (core cooling/heat generation)
- All underlying intents of MHTGR-DC 26 are covered
- Specific design features are not being approved in this SE.

PDC 34, “Residual heat removal”

- Passive system for decay heat removal (DHR) to ensure fuel and radionuclide release limits are met for DBEs and DBAs (RFDC)
- Active means to ensure DHR and residual heat are removed such that SARRDLs are not exceeded for AOOs (CDC) and normal operations (OCDC)
 - The function of the HPB to maintain core geometry is covered in PDC 70
- All aspects of MHTGR-DC 34 are covered

PDC 70, “Reactor vessel and reactor system structural design basis”

- HPB and core internals support reactor integrity and low probability of rapidly propagating failure during DBEs and DBAs.
 - Supports PDC 14.
- Ensure geometry for passive heat removal of residual heat.
 - Supports PDC 34.
- Permit insertion of neutron absorbers and maintain reactor inherent protection.
 - Further bolsters PDCs 11 and 26.
- All aspects of MHTGR-DC 70 covered.

Proposed Limitations and Conditions

(1) X-energy is requesting approval for the proposed PDCs based on a preliminary design and the LMP implementation at the time of the topical report submittal. Xe-100 design changes and associated LMP implementation could necessitate a revision to the proposed PDCs described in the TR.

Therefore, future licensing applicants referencing the topical report must confirm that the PDCs in this topical report remain appropriate for its design. In addition, if additional or revised PDCs are identified that are not within the scope of what is approved in this topical report, those PDCs will be subject to further NRC staff review.

(2) For PDC-RFDC 11, X-energy used the words “in the power operating range”. This phrase has the potential to complicate the applicability of PDC-RFDC 11 to the scope of MHTGR-DC 12. Power oscillations or reactivity upsets that may occur outside the power operating range should be assessed. Accordingly, the NRC staff conditions the acceptance of PDC-RFDC 11 on confirmation by future licensing applicants referencing this topical report that applicable safety analyses cover the full scope of the operating range, DBE, and DBA conditions for the final design.

(3) For PDC 14, X-energy is proposing to delete the words “ingress of air, secondary coolant, or other fluids” from MHTGR-DC 14 and replace it with the words “moisture ingress”. For justification, X-energy states that “no risk significant AOOs, DBEs, or DBAs were identified with unacceptable ingress of air or other fluids”. This cannot be verified at the present state of the Xe-100 design. Accordingly, the NRC staff conditions the acceptance of this PDC on the NRC staff’s review of AOOs, DBEs, and DBAs as part of a future license application referencing this topical report.

Conclusion

- X-energy has provided a reasonable set of PDCs that are appropriate for establishing requirements for the Xe-100 design consistent with the intent of RG 1.232 and the LMP guidance.
- Subject to these limitations and conditions, these PDCs establish the necessary design, fabrication, construction, testing, and performance design criteria for safety-significant SSCs to provide reasonable assurance that the Xe-100 design could be operated without undue risk to the health and safety of the public.
- Revision 3 is therefore suitable for referencing in future licensing applications under 10 CFR Parts 50 and 52 for the Xe-100 design.

Abbreviations

ARDC – advanced reactor design criteria

BDBE – beyond design basis event

CFR – *Code of Federal Regulations*

CP – construction permit

DANU - Division of Advanced Reactors and Non-Power Production and Utilization Facilities

DC – design criterion

DBA – design basis accident

DBE – design basis event

GDC – general design criterion

HPB – helium pressure boundary

L&C – limitation and/or condition

LWR – light-water reactor

MHTGR – modular high temperature gas reactor

NEI – Nuclear Energy Institute

NRR - Office of Nuclear Reactor Regulation

NSRST – non-safety related with special treatment

NST – non-safety related with no special treatment

OCDC – Owner Controlled Design Criterion

PDC – principal design criterion

PSAR – preliminary safety analysis report

QA – quality assurance

RG – Regulatory Guide

SAFDL – Specified acceptable fuel design limit

SARRDL – Specified acceptable system radionuclide release design limit

SSC – structure, system, or component

SE – safety evaluation

SR – safety-related

References


- RG 1.232, “Guidance for Developing Principal Design Criteria for Non-Light Water Reactors” (ML17325A611)
- RG 1.233, “Guidance for a Technology-Inclusive, Risk-Informed, and Performance-Based Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light Water Reactors” (ML20091L698)
- RG 1.253, “Guidance for a Technology-Inclusive Content of Application Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light-Water Reactors,” (ML23269A222)
- NEI 21-07, “Technology Inclusive Guidance for Non-Light Water Reactors – Safety Analysis Report: For Applications Utilizing the NEI 18-04 Methodology,” Revision 1 (ML22060A190).
- NEI 18-04, Revision 1, “Risk-Informed Performance-Based Technology Inclusive Guidance for Non-Light Water Reactor Licensing Basis Development” (ML22060A190)
- SECY-18-0096, “Functional Containment Performance Criteria For Non-Light-Water-Reactors” (ML18115A157)
- SECY-03-0047, “Policy Issues Related to Licensing Non-Light-Water Reactor Designs” (ML030160002)
- DANU-ISG-2022-01, “Review of Risk-Informed, Technology-Inclusive Advanced Reactor Applications—Roadmap” (ML23277A139)

MHTGR

- The standard MHTGR consists of **four identical reactor modules**, each with a thermal output of 350 MWt, coupled with **two steam turbine-generator sets to produce a total plant electrical output of 540 MWe**. The reactors are **helium cooled and graphite moderated** and **utilize ceramically coated particle type nuclear fuel**. The design includes passive reactor-shutdown and decay-heat removal features.
- The MHTGR reference configuration was established by DOE after tradeoff evaluations that indicated the selection of (1) **"prismatic" fuel blocks over "pebble-bed" spheres**; (2) steel primary-system vessels over PCRVs; (3) modular-sized reactors over a larger, single reactor; and (4) separation of the reactor from the remainder of the primary-system components in a side-by-side design rather than the containment of all components "in-line" within a single vessel.

Xe-100 Functional Containment

- (SECY-18-0096) Functional containment: “a barrier, or a set of barriers taken together, that effectively limits the physical transport of radioactive material to the environment.”
- Relevant phenomena are modeled mechanistically
- Multiple barriers between the UCO kernel and receptors of Interest
- X-energy’s XSTERM code is a suite of modules that model these phenomena in an integration manner
- Informed by RG 1.233 / NEI 18-04 implementation





Xe-100 Principal Design Criteria (PDC) Licensing Topical Report (LTR)

Steve Vaughn, Director, Licensing

Kyle Metzroth, Deputy Director, Xe-100 Systems Development

X Energy, LLC

August 21, 2024

Department of Energy Acknowledgement and Disclaimer

This material is based upon work supported by the Department of Energy under Award Number DE-NE0009040. This presentation was prepared as an account of work sponsored by an agency of the United States Government.

Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Agenda:

- Introductions/Opening Remarks
- Xe-100 PDC Development Process
- Xe-100 PDC:
 - General differences from RG 1.232
 - Example PDC Implementing the NEI 18-04 Methodology
- Questions/Closing Remarks


Objectives:

- Accurately communicate:
 - The Xe-100 PDC development process
 - General differences from RG 1.232 guidance
 - Example Xe-100 PDC that implement the NEI 18-04 methodology
- Respond to questions and comments from the ACRS Sub-committee

Xe-100 PDC Development Process

- The Xe-100 PDC LTR is developed based on the following:
 - RG 1.232 “Guidance for Developing Principal Design Criteria for Non-LWRs”
 - NEI 21-07 and RG 1.253 “Guidance for a Technology-Inclusive Content of Application Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light-Water Reactors”
 - DANU-ISG-2022-01 “Review of Risk-Informed, Technology-Inclusive Advanced Reactor Applications—Roadmap”
 - Xe-100 implementation of the NEI 18-04 Methodology
 - *Xe-100 Required Safety Functions and PRA Safety Functions, Revision 5 (001279)*

Xe-100 PDC Development Process



- Added some **definitions** to expand on the NEI 18-04 terminology:

Function	Design Criteria
Required Safety Function (RSF)	Required Functional Design Criteria (RFDC) Safety-Related Design Criteria (SRDC)
Non-Safety-Related with Special Treatment (NSRST) PRA Safety Function (PSF)	Complementary Design Criteria (CDC)
Non-Safety-Related with No Special Treatment (NST) PSF	Owner-Controlled Design Criteria (OCDC)

Xe-100 PDC: General Differences from RG 1.232

- Replaced “important to safety” with the NEI 18-04 definition of “safety-significant”
- Removed “single failure criterion” given NEI 18-04 leverages the defense-in-depth (DID) evaluation approach
- Replaced “postulated accident” and “accident conditions” with NEI 18-04 defined licensing basis event (LBE) terms (e.g., AOO, DBE, and DBA)
- Combined the language from MHTGR-DC 18, 32, 36, 37, 45, 46, and 72 into a single Xe-100 PDC 6 “*Monitoring, inspection, testing, surveillance*”

Xe-100 PDC: Example PDC Implementing the NEI 18-04 Methodology

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- Combined PDC 11 “*Reactor inherent protection*” and PDC 12 “*Suppression of reactor power oscillations*” and decomposed a PDC-RFDC 11 and PDC-CDC 11
- PDC-RFDC 11 is one of the two means for supporting PDC-RFDC 26 “*Reactivity control systems*”
- Aligns with RSF 1.1.1 “Control Reactivity with Inherent Reactivity Feedback”

Title:	<i>11. Reactor inherent protection</i>
Xe-100 PDC RFDC	The reactor core and associated systems shall be designed with sufficient negative reactivity feedback characteristics such that, in the power operating range, the net effect compensates for a rapid increase in reactivity, adequately controls heat generation, and ensures fuel performance and radionuclide release limits are not exceeded during design basis events or design basis accidents.
Xe-100 PDC CDC	The reactor core and associated systems shall be designed with sufficient negative reactivity feedback characteristics such that, in the power operating range, the net effect compensates for a rapid increase in reactivity, adequately controls heat generation, and ensures that specified acceptable radionuclide release design limits are not exceeded during anticipated operational occurrences.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC 13 “*Instrumentation and control*” contains RFDC, CDC, and OCDC
- PDC-RFDC 13 aligns with RSF 1.1.2 “Control Reactivity with Moveable Poisons” and RSF 1.3.1 “Isolate Water/Steam Ingress”
- PDC-CDC 13 aligns with NSRST PSF 1.1.2 “Control Reactivity with Moveable Poisons”, NSRST PSF 1.2.2 “Control Heat Removal with Active Means”, and NSRST PSF 2.5 “Maintain HPB Pressure Integrity During Transients”

Title:	<i>13. Instrumentation and control</i>
Xe-100 PDC RFDC CDC OCDC	Instrumentation shall be designed to monitor variables and systems over their anticipated ranges for normal operation and during anticipated operational occurrences, design basis events, and design basis accidents, as appropriate, to support and provide indication of the functions performed by safety-significant structures, systems, and components, including those variables and systems that can affect the fission process and the integrity of the reactor core, reactor helium pressure boundary, and functional containment. Appropriate controls shall be designed to maintain these variables and systems within prescribed operating ranges.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC-CDC 15 clarifies that the HPB design does not provide an RSF and therefore aligns with CDC not RFDC
- Aligns with NSRST PSF 2.7 “Prevent Loss of HPB Integrity”

Title:	<i>15. Reactor helium pressure boundary design</i>
Xe-100 PDC CDC	Safety-significant structures, systems, and components that are part of the reactor helium pressure boundary shall be designed with sufficient margin to ensure that the design conditions of the reactor helium pressure boundary are not exceeded during normal operations and anticipated operational occurrences.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC-RFDC 16 describes the functional containment provided by the fuel particles and pebbles and PDC-CDC 16 describes the functional containment provided by the HPB
- Aligns with RSF 1 “Retain Radionuclides in Fuel Particles and Pebbles” and NSRST PSF 2 “Retain Radionuclides in the HPB”

Title:	<i>16. Functional containment design</i>
Xe-100 PDC RFDC	The design of the reactor fuel particles and pebbles shall provide barriers as part of the reactor functional containment to control the release of radioactivity to the environment to ensure that the functional containment design limit is not exceeded during design basis events and design basis accidents.
Xe-100 PDC CDC	The design of the helium pressure boundary shall provide a barrier as part of the reactor functional containment to control the release of radioactivity to the environment to ensure that the functional containment design limit is not exceeded during anticipated operational occurrences.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC 26 “*Reactivity control systems*” contains RFDC, CDC, OCDC, and PDC
- PDC-RFDC and PDC-CDC aligns with the “Control Reactivity with Moveable Poisons” RSF and NSRST PSF respectively

Title:	26. <i>Reactivity control systems</i>
Xe-100 PDC RFDC	The reactor shall be designed to provide movable poisons that can insert and maintain safe shutdown during design basis events and design basis accidents.
Xe-100 PDC CDC	The reactor shall be designed with a means, which is independent and diverse from the reactivity control systems required functional design criteria, to insert negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the specified acceptable system radionuclide release design limits and the helium pressure boundary design limits are not exceeded, and safe shutdown is achieved and maintained during anticipated operational occurrences.
Xe-100 PDC OCDC	The reactor shall be designed with a means, which is independent and diverse from the reactivity control systems required functional design criteria, to insert negative reactivity at a sufficient rate and amount to assure, with appropriate margin for malfunctions, that the specified acceptable system radionuclide release design limits and the helium pressure boundary design limits are not exceeded during normal operations.
Xe-100 PDC	A means for holding the reactor shutdown under conditions that allow for interventions such as fuel loading, inspection, and repair shall be provided.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC-RFDC 30 is focused on mitigating a steam generator tube rupture DBE and DBA and PDC-CDC 30 is focused on preventing helium leakage during AOOs
- PDC-RFDC 30 aligns with RSF1.3.1, “Isolate Water/Steam Source” and PDC-CDC 30 aligns with NSRST PSF 2.5, “Maintain HPB Pressure Integrity During Transients”

Title:	<i>30. Integrity of reactor helium pressure boundary</i>
Xe-100 PDC RFDC	The reactor shall be designed to detect moisture ingress within the helium pressure boundary and automatically isolate the source of moisture ingress during design basis events and design basis accidents.
Xe-100 PDC CDC	The reactor shall be designed to detect and, to the extent practical, identify and isolate the source of reactor helium leakage during anticipated operational occurrences.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC-RFDC 34 “*Residual heat removal*” provides a passive heat removal function while the PDC-CDC and PDC-OCDC provide an active heat removal function
- PDC-RFDC 34 aligns with RSF 1.2.1, “Control Heat Removal Through Passive Means” and PDC-CDC 34 aligns with NSRST PSF 1.2.2, “Control Heat Removal with Active Means”

Title:	34. <i>Residual heat removal</i>
Xe-100 PDC RFDC	A passive means to remove residual heat shall be designed to provide effective heat removal to ensure that fuel and radionuclide release limits are not exceeded during design basis events and design basis accidents.
Xe-100 PDC CDC	An active means shall be designed to transfer fission product decay heat and other residual heat from the reactor core to an ultimate heat sink at a rate such that specified acceptable system radionuclide release design limits are not exceeded during anticipated operational occurrences.
Xe-100 PDC OCDC	An active means shall be designed to transfer fission product decay heat and other residual heat from the reactor core such that specified acceptable system radionuclide release design limits are not exceeded during normal operations.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC-RFDC 70 “*Reactor vessel and reactor system structural design basis*” supports maintaining core geometry for passive heat removal and controlling reactivity
- PDC-RFDC 70 aligns with RSF 1.4.1, “Maintain HPB and Core Geometry”

Title:	<i>70. Reactor vessel and reactor system structural design basis</i>
Xe-100 PDC RFDC	The helium pressure boundary and core internal structures shall be designed such that the reactor vessel and reactor system integrity is maintained and that there is a low probability of rapidly propagating failure during design basis events and design basis accidents to (1) ensure the geometry for passive removal of residual heat from the reactor core to the ultimate heat sink and (2) permit sufficient insertion of the neutron absorbers and maintain reactor inherent protection to provide for reactor shutdown.

Example Xe-100 PDC Implementing the NEI 18-04 Methodology

- PDC-RFDC 71 “*Reactor building design basis*” structurally protects the reactor vessel and reactor system in support of maintaining core geometry for passive heat removal and controlling reactivity
- PDC-RFDC 71 aligns with RSF 1.4.2, “Maintain Reactor Building Geometry”

Title:	<i>71. Reactor building design basis</i>
Xe-100 PDC RFDC	The reactor building shall be designed such that it structurally protects the reactor vessel and reactor system geometry during design basis events and design basis accidents to ensure passive removal of residual heat from the reactor core to the ultimate heat sink and permit sufficient insertion of the neutron absorbers and maintain reactor inherent protection to provide for reactor shutdown.

Questions and Closing Remarks