

Long term performance of Alloy 690 and associated weldments in a PWR environment

Objectives:


- 1. Develop an understanding of the microstructural changes in base Alloy 690, associated weldments, weld HAZ, and weld interfaces occurring during long term operation
- 2. Quantify the effects of aging on performance

Approach:

Use pedigreed materials aged long term in sufficient quantities to <u>quantify</u> long-term performance

- 1. A prototypical Alloy 152 weldment joining Alloy 690 and low alloy steel - identical to that used in the US NRC research program – that has been aged for over the last decade to 30, 60 and 80year service equivalents. Continuing to 100-year, some 100-year available
- 2. Others (80, 100-years)

Argonne



For more information: B. Alexandreanu (abogdan@anl.gov) and Y. Chen (yiren_chen@anl.gov)



Examination of field materials by Synchrotron XRD




- Was "ordering" a culprit in the SCC observed in the field? SRO was proposed as a mechanism for SCC in Alloy 600
- Encapsulation method with Kapton tubes was devised to allow potentially-radioactive specimens to be analyzed by Synchrotron XRD
- Specimens of Interest: V.C. Summer Alloys 82 (1WTL) and 182 (4BTL) and Davis-Besse Alloy 182 weldment from nozzle #11 (J11CC) and Alloys 600 CRDM nozzle #3 (N3CL) from the original head of Davis-Besse (15.78 EFPY, 24 chronological years)



For more information: B. Alexandreanu (abogdan@anl.gov) and Y. Chen (yiren_chen@anl.gov)

Examination of field materials by Synchrotron XRD




- Alloys of interest: V.C. Summer Alloys 82 (1WTL) and 182 (4BTL) and Davis-Besse Alloy 182 weldment from nozzle #11 (J11CC) and Alloys 600 CRDM nozzle #3 (N3CL) from the original head of Davis-Besse. For specimen 4BTL blue arrows are pointing to Nb(N,C) phase.
- Alloys 600 CRDM nozzle #3 (N3CL) from the original head of Davis-Besse. Location where SRO phase with a d-spacing of 2.1 Å would occur is indicated in the figure.
- No ordering SRO of LRO was found



For more information: B. Alexandreanu (abogdan@anl.gov) and Y. Chen (yiren_chen@anl.gov)



SCC Testing 100-year equivalent service: 370-Y60 + 40-year additional aging



CT Specimens tested in the program in the 60-year aged condition received additional aging to 100 years

- Alloy 152 Weld heat (1) WC04F6, (2) 720129 and 146444 successively, and (3) 720129 as 1st layer butter
- Alloy 690 370-Y60