

A pathway for achieving a performance target in a base-isolated nuclear power plant

Faizan Ul Haq Mir¹, Ching-Ching Yu², Benjamin M. Carmichael³, Brandon M. Chisholm⁴, Jason Redd⁵, Mohamed M. Talaat⁶, Chandrakanth Bolisetti⁷, and Andrew S. Whittaker⁸

¹Assistant Professor, Department of Civil Engineering, Indian Institute of Technology Jammu, Jammu, JK, India
(mir.faizan@iitjammu.ac.in)

²Structural Analysis Engineer - Senior Vibration Engineer, TerraPower, Bellevue, WA, USA

³Business Development Manager, Southern Company, Birmingham, AL, USA

⁴Advanced Nuclear R&D Engineer, Southern Company, Birmingham, AL, USA

⁵Project Engineer for Advanced Nuclear Power, Southern Nuclear, Birmingham, AL, USA

⁶Senior Project Manager, Simpson Gumpertz & Heger, Newport Beach, CA, USA

⁷Facility Risk Group Lead, Idaho National Laboratory, Idaho Falls, ID, USA

⁸SUNY Distinguished Professor, Department of Civil, Structural and Environmental Engineering, University at Buffalo, The State University of New York

The US Department of Energy funded the writing of a topical report on seismic isolation of advanced nuclear power plants. The report, publically available as an MCEER report at the time of this writing (Mir *et al.* 2024), was submitted to the US Nuclear Regulatory Commission for formal review and issuance of a safety evaluation report (SER) so that it can be used as a technical basis for future licensing actions. The presentation at the 2024 DOE-NRC NPH Workshop will introduce the report and focus on the methodology to achieve a user-specified performance target for a seismic base-isolation system for a nuclear power plant, which is a major focus of the report. The isolation system, composed of both isolators and damping devices, is treated as a structure, system, and component (SSC) per US nuclear practice and its required performance is defined as unrestricted isolator and damper horizontal displacement capacity to achieve the target performance goal. The methodology involves the generation of a seismic displacement demand curve for the isolation system, expressed as the mean annual frequency of exceedance of a horizontal displacement, and the generation of an appropriate fragility function for the isolation system. Recommendations for generating the displacement demand curves and fragility functions will be presented. The median displacement capacity of the fragility function must be confirmed by prototype testing of the isolators and dampers in the isolation system. The methodology will be described via an example application to isolation systems installed beneath an advanced NPP, founded on two different soil domains, and located at Clinch River in East Tennessee, USA.

Reference

Mir, F. U. H., Yu, C.-C., Carmichael, B. M., Chisholm, B. M., Redd, J. P., Talaat, M. M., Bolisetti, C., and Whittaker, A. S. (2024). "Guidelines for implementing seismic base isolation in advanced nuclear reactors." *MCEER-24-0001*, University at Buffalo, Buffalo, NY.