

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Thermal-Hydraulic Accident Analysis
 Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, October 1, 2024

Work Order No.: NRC-0057

Pages 1-141

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

THERMAL-HYDRAULIC ACCIDENT ANALYSIS SUBCOMMITTEE

+ + + + +

TUESDAY

OCTOBER 1, 2024

+ + + + +

The Subcommittee met via Teleconference,
at 8:30 a.m. EDT, Robert P. Martin, Chair, presiding.

COMMITTEE MEMBERS:

ROBERT P. MARTIN, Chair

RONALD G. BALLINGER, Member

VICKI M. BIER, Member

VESNA B. DIMITRIJEVIC, Member

CRAIG A. HARRINGTON, Member

GREGORY H. HALNON, Member

WALTER L. KIRCHNER, Member

SCOTT P. PALMTAG, Member

DAVID A. PETTI, Member

THOMAS E. ROBERTS, Member

MATTHEW W. SUNSERI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANTS :

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL :

MICHAEL SNODDERLY

CONTENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PAGE

I. Opening Remarks 4

II. Evolution of accident analysis and
 consideration of offsite consequences in
 support of siting and emergency preparedness . . . 8

III. Guidance on selection of accident
 scenarios for demonstrating general site
 suitability under 10 CFR Part 100 84

IV. Guidance to assess cliff-edge effects and
 defense-in-depth 97

V. Opportunity for public comment 137

VII. Adjourned

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR MARTIN: This meeting will now come to order. This is a meeting of the Accident Analysis Subcommittee of the Advisory Committee on Reactor Safeguards. I am Robert Martin, chair of today's subcommittee meeting.

ACRS members in attendance in person, Ron Ballinger, Craig Harrington, Roberts, Petti, Halnon, Kirchner, Vicki Bier, Scott Palmtag. Anybody else? And then online, we should have Matt Sunseri and Vesna Dimitrijevic. Do we have anybody else? I guess our consultants, we have Dennis. Yeah, there's Dennis on there and Steve Schultz, correct? Is Charlie on? Did Charlie join us?

Okay, all right, Mike Snodderly of the ACRS staff is the designated federal officer for this meeting. No member conflicts of interest were identified for today's meeting and we have a quorum for today's meeting.

The subject of today's meeting is Accident Selection in Support of Emergency Planning and Siting Analysis. Accident selection is determined by considering design features that influence event progression and their ability to prevent or mitigate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 hazards impacting facility safety and the public.

2 Safety-in-design through defense-in-depth
3 has been a hallmark of the NRC's reactor safety
4 framework, integrating both accident prevention and
5 mitigation. Assessment of accident mitigation assumes
6 prevention has failed, leaving the remaining layers of
7 defense to minimize harm to the public.

8 The methodology for the selection of
9 accident scenarios for these assessments has evolved
10 over time, influenced by regulatory updates such as 10
11 CFR 50.160, most recently, which specifically
12 addresses emergency preparedness for small modular
13 reactors and non-light-water reactors.

14 Balancing its safety mission with the
15 demand for the efficient reviews of advanced reactor
16 designs, the NRC has shifted toward a technology-
17 inclusive regulatory framework. This framework
18 emphasizes risk insights, revealing safety margins
19 across the domain of anticipated, design-basis, and
20 beyond-design-basis events. This change provides
21 flexibility in evaluating containment design, siting,
22 and emergency planning criteria.

23 The ACRS has been very much involved with
24 this evolving regulatory framework as it applies to
25 these topics. A few specific examples of such

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 engagements include our review of Reg Guide 1.233,
2 Guidance for a Technology-Inclusive, Risk-Informed,
3 and Performance-Based Methodology to Inform the
4 Licensing Basis and Content of Applications for
5 Licenses, Certifications, and Approvals for Non-Light-
6 Water Reactors, and that was in 2020, then the NuScale
7 SMR's EPZ in 2022, and Rev. 1, most recently, Rev. 1
8 of Reg Guide 1.183, Alternative Radiological Source
9 Terms for Evaluating Design Basis Accidents at Nuclear
10 Power Plants.

11 We have acknowledged the benefits of the
12 regulatory shift, but we have also noted the need for
13 clearer guidance on accident selection, or accident
14 scenario selection, defense-in-depth, and cliff-edge
15 effects. Today, we will hear from the staff on these
16 topics and their expectations for advanced reactor
17 designs.

18 The ACRS was established by statute. It
19 is governed by the Federal Advisory Committee Act, or
20 FACA. The NRC implements FACA in accordance with its
21 regulations. Per these regulations and the
22 committee's bylaws, the ACRC speaks only through its
23 published letter reports.

24 All member comments should be regarded as
25 only the individual opinion of that member and not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 committee position. All relevant information related
2 to ACRS activities, such as letters, rules for meeting
3 participation, and transcripts are located on the NRC
4 public website and can be easily found by typing About
5 Us ACRS in the search field on the NRC home page.

6 The ACRS, consistent with the Agency's
7 value of public transparency in regulation of nuclear
8 facilities, provides opportunity for public input and
9 comment during these proceedings. We have received no
10 written statements or requests to make an oral
11 statement from the public. We have also set aside
12 time at the end of this meeting for public comments.

13 The ACRS will gather information, analyze
14 relevant issues and facts, and formulate proposed
15 conclusions and recommendations, as appropriate, for
16 deliberation by the full committee.

17 A transcript of the meeting is being kept
18 and will be posted on our website. When addressing
19 the subcommittee, the participants should first
20 identify themselves and speak with sufficient clarity
21 and volume so that they may be readily heard, and if
22 you are not speaking, please mute your computer on
23 Teams or by pressing star-6 if you're on your phone.

24 Please do not use the Teams chat feature
25 to conduct sidebar discussions related to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 presentations. Rather, limit use of the meeting chat
2 function to report IT problems. For everyone in the
3 room, please put all your electronic devices in silent
4 mode and mute your laptop microphone and speakers. In
5 addition, please keep sidebar discussions in the room
6 to a minimum since the ceiling microphones are live.

7 For the presenters, your table microphones
8 are unidirectional and you'll need to speak into the
9 front of the microphone to be heard. Finally, if you
10 have any feedback for the ACRS about today's meeting,
11 we encourage you to fill out the public meeting
12 feedback form on the NRC's website. We will now
13 proceed with our meeting. So, we have the staff
14 before us here. I don't know who -- who are we
15 beginning with? Is it --

16 MR. RECKLEY: This is Bill Reckley. I'll
17 start. Steve, did you want to say anything, Steve
18 Lynch?

19 MR. LYNCH: Good morning, everyone. I am
20 Steve Lynch, Chief of the Advanced Reactor Policy
21 Branch at the NRC. I'm glad to be supporting the
22 staff today, and all I want to do is thank the members
23 for their time, and sharing their insights, and
24 considering this important topic, as we continue to
25 enhance the NRC's regulatory framework to accommodate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 new designs and an advanced reactor that is already in
2 front of us, so thank you so much for your time today.

3 MR. RECKLEY: Others? I'm joined at the
4 front by Todd Smith, Senior Level Advisor for
5 Emergency Preparedness out of NSIR, Michelle Hart,
6 Senior Reactor Engineer, who will be talking about the
7 Reg Guide 1.183 source term calculations, offsite
8 dose, and Anders Gilbertson with our probabilistic
9 risk assessment.

10 So, at today's meeting, we're going to go
11 over some of the evolution of accident analysis and
12 how we've considered actual offsite consequence
13 assessments in terms of both siting and emergency
14 preparedness.

15 We'll get into, in the second segment,
16 guidance on accident selection for demonstrating site
17 suitability under Part 100. That will largely be a
18 summary of our most recent revision to Reg Guide 4.7,
19 site suitability, and then we'll end with a discussion
20 on defense-in-depth and the related topic of how we
21 address cliff-edge effects.

22 So, you know, the protection of the public
23 from radiological hazards is our primary mission, so
24 it's not surprising that it shows up in a variety of
25 places, although to me, it's somewhat surprising how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 often or how little we actually talk about offsite
2 consequences when we're talking about reactor safety.
3 It's usually the discussions of barrier protection and
4 things like that, but we do actually consider analysis
5 of potential offsite consequences in a number of
6 areas.

7 The first, although we're not going to
8 talk about it in-depth today, is routine operations.
9 This is normal effluents, routine operations. That's
10 governed by Part 20 of our regulations, also
11 regulations within Part 50, Appendix I, related to
12 keeping doses to members of the public as low as
13 reasonably achievable as it relates to routine
14 effluents, and then other regulations in Parts 50 and
15 52.

16 The focus of today's discussion will be
17 more the unplanned releases, those that are coming
18 from transients and accidents, and the topics related
19 to that are the traditional Chapter 15 accident
20 analysis.

21 Again, most of those don't actually go as
22 far as computing offsite consequences in the
23 traditional light water reactor analysis. They're
24 focused on barriers like reactor coolant pressure
25 boundary, reactor fuel cladding, and the containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We do have a specific and rather central
2 assessment that we do, and that's the design basis
3 radiological consequence analysis. It's often
4 referred to as the siting analysis. That used to be
5 primarily in Part 100. It's now in both Part 100 and
6 in Parts 50 and 52 in terms of the regulatory controls
7 related to that particular assessment, and we'll be
8 getting into that in more detail.

9 As was mentioned, you see things like
10 revisions to Reg Guide 1.183, which is the central
11 guidance document for that assessment for traditional
12 light water reactors. Then we also looked at
13 population density considerations. I'll get into that
14 discussion. Obviously, emergency preparedness, we'll
15 talk about that later today.

16 Then over time, and we'll get into the
17 history on the next slide, but over time, we also
18 started to look at severe accident considerations,
19 what would be appropriate to address accidents that
20 progressed past core melt for light water reactors,
21 the assessment of the NRC safety bills, and we used
22 offsite radiological consequence assessments when we
23 do backfit analyses or cost benefit analyses.

24 CHAIR MARTIN: Before you leave that
25 slide, I wanted to ask you about -- well, I tried to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 do a little historical context before the meeting, and
2 so I was pulling the thread on accident selection, and
3 really, I wanted to know where Class 9 came from.

4 MR. RECKLEY: All right.

5 CHAIR MARTIN: So, it comes from a
6 proposed Appendix D to 10 CFR 50, which was back in
7 1971, which generated a lot of public comment and
8 subsequently was withdrawn.

9 Now, I have some personal experience, just
10 a little bit, with the environmental, you know,
11 report, and SAMDA, and what have you. That's very
12 much a technical analysis. Where does -- I think it's
13 because it's really now implemented in 10 CFR 51,
14 right? Where does all of that fit into this story?

15 MR. RECKLEY: Okay, and if you'll grant me
16 about three slides from now --

17 CHAIR MARTIN: Okay.

18 MR. RECKLEY: -- we'll start to get into
19 that --

20 CHAIR MARTIN: That's fine.

21 MR. RECKLEY: -- and then in the three or
22 four slides, we'll try to show that context.

23 CHAIR MARTIN: Okay, perfect. Thank you.

24 MR. RECKLEY: Thank you. So, in this
25 slide, I'll use -- it's not used very much within the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 nuclear industry, but I started to use it when we were
2 coming actually before the ACRS to talk about Part 53
3 as a way to show kind of an integrated approach, and
4 to some degree, we'll get -- for example, the
5 environmental effects is one of the places we
6 addressed consequences, so you'll see that in the
7 bottom right, environmental impact.

8 So, but just since I'm going to use it a
9 number of times today, the bow-tie diagram is simply
10 a representation of you start with the threat or an
11 event, you have certain prevention controls that is
12 intended to stop you from reaching a top level event,
13 and then should the top level event happen, you have
14 certain mitigating barriers or controls that would
15 address potential consequences.

16 So, a non-nuclear example, if a top level
17 event is losing control of a car in the rain and
18 hitting a tree, and that's the top level event, well,
19 the rain might be the initiator. Prevention would be
20 things like slowing down in the rain, an operator
21 control.

22 It might be anti-lock brakes and those
23 things that are built into the car to try to keep you
24 in control, but should you lose control and hit the
25 tree, then the mitigating measures are things like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 seatbelts, airbags to try to prevent the consequence
2 of serious injury or death.

3 So, that's the non-nuclear example. For
4 light water reactors, this has worked pretty well to
5 characterize what we do, and the top level event is
6 usually provided as core damage, and we'll get into a
7 little bit more detail as we go forward.

8 CHAIR MARTIN: Let me follow up on this
9 slide too. So, I've done this a number of times in
10 other meetings to bring up the topic of hazards
11 analysis, some feedback that I've provided in those
12 previous meetings is that while hazards analysis is
13 mentioned numerous places, there's a lack of formality
14 in the process with one exception, and that is the
15 integrated safety analysis that is associated with
16 fuel cycle activities, so that's not a 10 CFR 50
17 activity.

18 But in fact, with the fuel cycle stuff, we
19 do have the NUREG, I want to say 15, 17, or something
20 like that. The explanation of what is required for
21 hazard analysis is fairly well-articulated. I mean,
22 you could always get into more detail. And as someone
23 that has worked in that domain and has prepared hazard
24 -- there can be a lot of ambiguity and maybe
25 inefficiency with the exercise of doing the hazards

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 analysis, you know, to really ferret out really what's
2 important and what are the safety issues.

3 And even one of the objectives of this
4 meeting or motivations for this meeting was to bring
5 some clarity and motivate some more kind of coherent,
6 transparent type presentation of the content.

7 I'll acknowledge when it comes to, say,
8 beyond-design-basis accidents in particular, the
9 explanation of what might be required by an applicant
10 is really spread out over a lot of things, and the
11 regulatory guide, for instance, that starts to put
12 guardrails and encourage that efficiency is valued.

13 And I'm trying to, you know, bring this
14 around to more of a question than a comment, but, I
15 mean, what is the opportunity maybe as an action, not
16 necessarily as an information meeting, so we also have
17 actions at least in the formal sense, but to bring
18 about, you know, change to improve the coherency of,
19 you know, all of the information it is that relates to
20 this topic?

21 MR. RECKLEY: So, there's a couple items.
22 First, as we've -- the lower left here in this slide,
23 the revised approaches that we've tried to develop
24 because we're faced with new reactor technologies, or
25 at least new to our regulatory exercises, or ones we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 haven't visited in a long time. We needed to revisit
2 exactly the things you're talking about in terms of
3 how to evaluate hazards, because the hazards will
4 depend on the reactor technologies.

5 Whereas, the traditional approach for
6 light water reactors has been built over many decades
7 based on operating experience, risk assessments, and
8 so forth to address what events to assess, and then
9 again, add it to that. For instance, after Three Mile
10 Island, we started to look more at severe accidents.

11 As we got in and started to build Part 53,
12 for example, and one of the things, and Anders, you
13 can help me with the number because I forget, but one
14 of the things, and this was actually stressed by your
15 consultant, Dennis Bley, when he was at committee, and
16 other ACRS members, that we needed to address these
17 things with what some call a blank sheet, a blank
18 slate, so that we're assessing the actual hazards
19 related to technologies.

20 So, for Part 53, we do have a draft guide,
21 and it's unique among the guides we're issuing with
22 Part 53 because it's applicable to both 50, 52, and
23 the proposed 53, but it is our guidance on identifying
24 and assessing hazards. So, do you recall the number?

25 MR. GILBERTSON: Yeah, this is Anders

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Gilbertson of the staff at NRR. It's DG-1414.

2 CHAIR MARTIN: Yeah, I think we've had
3 some exposure to that previously.

4 MR. RECKLEY: At least when it came
5 through Part 53, the committee got an opportunity to
6 look at it, so, and we'll revisit this as we go
7 through the topics.

8 MEMBER KIRCHNER: So, Bill, since you
9 brought that up, what is the status of that guide?
10 Because that was one that the committee really felt
11 would be very valuable to have out there.

12 MR. RECKLEY: So, that guide will go out
13 with the proposed rulemaking for public comment, which
14 the package, I think, as you're all aware, is with the
15 Commission now. We expect to send it to the Federal
16 Register next week, and that guide would be one of the
17 things that would be open --

18 MEMBER KIRCHNER: It would be part of the
19 package.

20 MR. RECKLEY: Part of the package open for
21 public comment. And then from the ACRS standpoint,
22 we'll come back as we do that final rulemaking and the
23 final regulatory guide. That would be in 2025 and
24 we're already starting to talk about scheduling some
25 meetings. Anders, if we could go to the next slide?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, this does get into how we ended up
2 where we are, the evolution of approaches. And we
3 remain relatively well-rooted in what the Atomic
4 Energy Commission started in about 1960, and so that
5 initial proposal from the Atomic Energy Commission on
6 the licensing of commercial nuclear plants really
7 focused on what was different terminology, sometimes
8 maximum credible accident is one that's often used,
9 and for light water reactors, that was a large break
10 loss of coolant accident.

11 Chairman Martin, you mentioned Class 9.
12 In the assessment of events or accidents, there was a
13 categorization system that went from Class 1 and went
14 up through Class 9, with Class 8 being basically the
15 loss of coolant accident and Class 9 being core melt
16 and what we would in today's terms call severe
17 accidents.

18 Now, the initial proposals, and this went
19 all the way through the draft, the publication of
20 draft Appendix D and so forth that you were
21 mentioning, Class 9 accidents were excluded from
22 licensing based on low frequency, low anticipated
23 frequencies. So, the licensing and the environmental
24 reviews were Class 1 through 8 and Class 9 excluded.

25 Around late '70s, 1980, you had the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactor safety study published, and in 1979, as we all
2 know, we had the accident at Three Mile Island, and
3 that changed the thinking and the rationale for
4 excluding Class 9 accidents, and that led then to a
5 flurry of activity in the 1980s.

6 Jumping down one, there was a whole series
7 of Commission policy statements, like the severe
8 accident policy statement for example. It also led to
9 a series of studies like NUREG-0625, which was a
10 siting policy taskforce, NUREG-0396, which Todd will
11 probably mention, and it was an NRC EPA taskforce on
12 emergency planning, and environmental reviews we took
13 back after that that, hey, you don't need to consider
14 Class 9 accidents in environmental reviews.

15 That was ultimately, a few years after
16 that, challenged in a court case that brought about
17 our actual calculations of severe accident management
18 alternatives, SAMAs or SAMDAs at the design stage, as
19 a result of the court case, but there was already talk
20 in that direction after Three Mile Island that maybe
21 it was prudent to look at severe accidents as a
22 licensing matter, as an environmental matter.

23 MEMBER ROBERTS: Hey, Bill, this is Tom
24 Roberts. Could I ask you about some parts of history
25 that are missing and get your perspective on that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'll start with the 1960, '62 time frame. The AEC did
2 consider severe accidents in their accompanying
3 dialogue with the 10 CFR 100 rulemaking. They said
4 that the population center distance was the surrogate
5 for severe accidents for the scenarios studied up to
6 date, and then there was need for more study to see if
7 that remained the case.

8 And then several years later, there was
9 the 1968 report on emergency core cooling where the
10 Commission was concerned that there was a potential
11 common cause between the loss of coolant accident and
12 containment failure, and so there wasn't a diversity
13 of barriers that was previously thought.

14 There was a whole flurry of rules that
15 came out of that, including Appendix K and a focus on
16 emergency core cooling systems, as well as the general
17 design criteria tying containment function to
18 emergency core cooling, so it was clearly acknowledged
19 that they were not independent barriers.

20 And then going forward, some of the
21 studies you listed were, of course, written on, as a
22 matter of fact, most of them, because throughout the
23 '60s and '70s, the AEC and the NRC were uncomfortable
24 with the 10 CFR 100 criteria being sufficient, and
25 they found ways to reject various sites based on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 population density considerations, regardless of what
2 10 CFR 100 said.

3 So, it seems like there was kind of a
4 discomfort with the design basis manual maximum
5 credible accident approach dating back to almost the
6 onset of 10 CFR 100, and the concern about severe
7 accidents obviously became more, you know, more clear
8 after Three Mile Island.

9 I think that was part of the thought
10 process all along. Like Bob said, 1971 is when this
11 term first came out as a Class 9. So, anyway, I just
12 wanted to get your perspective on that. It seems like
13 there's a lot that --

14 MR. RECKLEY: There is definitely a lot of
15 history missing from this slide, so you're exactly
16 right. I mean, if you go back, and this is my own
17 personal view, and you could get the historian to come
18 if you wanted to and speak for days, but, you know,
19 the development of nuclear power, one of the first
20 things was to site them out, you know, the National
21 Labs in Idaho or various places, and isolation was a
22 key factor.

23 Then that can't hold, right? You can't
24 have all of your commercial nuclear plants located in
25 isolated areas, so containment was the next thing, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that really led to what we'll talk about, the TID, and
2 the siting study of what would be needed to get them
3 a little closer, but you're exactly right, then how
4 far do you take that?

5 With the containment, the proposal to put
6 a power plant in close proximity to Manhattan in
7 Ravenswood, it was like well, maybe two containments
8 will work, or maybe it's better not to put it in New
9 York City, so that was, you know, that was the
10 discussion that -- and you're right. This was being
11 done and evolving all the way from the beginning.
12 Then, yeah, as we learned more, we did experiments,
13 and Dave can lay in.

14 We did, you know, the experiments at LOFT
15 and other things that said hey, ECCS may not work as
16 well as we thought, so then we did the ECCS rulemaking
17 in the mid-1970s, but, you know, that was really kind
18 of well into, if you want to look at it, well into the
19 path of commercializing nuclear power to realize hey,
20 we need to do something like have an emergency core
21 cooling rule.

22 So, yes, there's a lot of history that's
23 not on this slide, and it's all interwoven because the
24 subjects that we're going to talk about, reactor
25 design, siting, the need for emergency planning,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 emergency preparedness, all of that is kind of
2 interrelated and it's evolved.

3 I just, I was trying to use here that the
4 accident at TMI was kind of a change in the regulatory
5 mindset, because up to that point, we found a reason
6 to exclude severe accidents, and after that, we
7 started to build it into processes and decision-
8 making. So, to me, that was a break point, but
9 there's plenty of other examples, plenty of other
10 lessons learned.

11 Then in the 1980s, again, the Commission
12 policy statements on severe accidents, the whole
13 containment program that was undertaken after Three
14 Mile Island, but then it also started to look at how
15 do we move past Three Mile Island? And you had
16 advanced reactor policy statements, PRA policy
17 statements, the NRC safety goals to try to say, you
18 know, we're not finished. What do we need to do to
19 make adjustments going forward?

20 With the reactor safety study, it
21 initiated a whole series of risk-informed performance-
22 based initiatives that have been ongoing really since
23 that time, and then more recently, the advanced
24 reactors and our move to try to find more technology-
25 inclusive ways of going forward, and we'll talk about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that.

2 So, again, going back to the bowtie
3 representation, and I'll call light water reactors or
4 large light water reactors Generation II if you're
5 familiar with the GIF terminology, and what we have
6 historically done, and that is we've looked at, on the
7 core, we've looked at core damage or severe core
8 damage as a top level event, and we've often
9 characterized what's done to prevent it as being the
10 prevention measures. That's things like reactivity
11 control, emergency core cooling.

12 And then we've looked at how to prevent
13 the release should that occur, and we've often
14 described that as a mitigation measure, and that would
15 include the ability of the containment to hold a
16 release or to limit a release, and then siting
17 provisions and emergency planning.

18 You'll see down in the various activities
19 that we do, a primary focus on the consequences is on
20 health effects. We'll talk mainly about that. That's
21 like Reg Guide 1.183. How do you limit the doses to
22 the public to below the reference values?

23 But then we also use it in regulatory
24 analysis where we look broader than just health
25 effects. This is where you start to bring in not just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 dose, maximum dose to an individual, but population
2 dose, so that you can start to do a conversion to
3 dollars and use it in a cost benefit assessment, and
4 then the severe accident management alternatives that
5 we look at under the environmental review that we do
6 for licensing. So, it's used in a number of areas.
7 It's kind of represented here. We'll talk a little
8 bit about each one of those as we go forward.

9 MEMBER ROBERTS: Bill, I like this
10 diagram, but like almost all of the defense-in-depth
11 diagrams, there are, you know, subtleties or, you
12 know, flaws, things that you may get the wrong view by
13 looking at this diagram.

14 And what occurs to me is emergency core
15 cooling on the left and containment on the right, like
16 I mentioned a few minutes ago, what the industry
17 discovered back in the '60s is that they're not
18 necessarily independent, that if your emergency core
19 cooling doesn't work, your containment may not work
20 either because you need to cool the core to prevent
21 some of the more exotic containment failure phenomena
22 that could occur.

23 You know, similarly, if your emergency
24 core cooling system worked, then you could still get
25 what you might call plant damage because you still get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 potentially, you know, bloating and bursts of the
2 clad, and app (phonetic) release out of the burst fuel
3 rods, and maybe FFRD depending on, you know, what the
4 burnup is in the rods.

5 So, you're still reliant on some
6 mitigation even for a case where the emergency core
7 cooling system did its job properly. I just wanted to
8 observe that again and see if you've got any comments
9 on that. At least I haven't seen a model yet that's
10 perfect.

11 MR. RECKLEY: No, yeah, and this is an
12 oversimplification, obviously. You have events that
13 bypass containment, and so in that particular case,
14 you need to come back and look and say you could get
15 a release and the containment's not going to stop it
16 because you have a bypass path or whatever.

17 So, yeah, this is a dramatic
18 oversimplification, but by and large, when you look,
19 it holds, you know, 80 percent of the time or
20 whatever, so it's good for the discussion, but, you
21 know, once you get into an actual event, you're going
22 to maybe identify a different prevention path,
23 barriers, or systems, and potentially even different
24 mitigation measures.

25 But when we're talking big picture, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we'll get into this a little later as well, it's often
2 just context and understanding where you are in the
3 conversation and what your reference point is, right?
4 But, so often when we talk about prevention and
5 mitigation, we talk in these terms on this slide, that
6 prevention is to prevent core damage and mitigation is
7 to mitigate core damage and limit the release.

8 But if you're talking about an individual
9 event, then what you do to prevent and what you do to
10 mitigate might be different than what's on this slide,
11 but, yes, it's a good observation. You know, things
12 are always more complicated than you're able to
13 describe on a small number of slides.

14 CHAIR MARTIN: I wanted to throw in a
15 question. One of the criticisms of Appendix D, at
16 least three years ago, was at least the perception
17 that given all of the different groups that are, of
18 course, vested in understanding accident selection,
19 there were different methods, different standards
20 being applied, and that inconsistency is its own kind
21 of inefficiency and potentially a safety concern.

22 Now, three years later, can we see that
23 there's more harmonization of methods and standards
24 across the different activities, environmental and,
25 you know, the economical, the safety, the health? You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know, I'm looking at the right-hand side there. I
2 think I have an answer for you, but I'm not going to
3 answer for you.

4 (Laughter.)

5 MR. RECKLEY: I would say there's still
6 some differences between vendors on particulars, but
7 in general, over time, we have standardized the
8 approach, for example, for SAMA, and using the PRA,
9 and how to use those dose assessments. We have
10 guidance. The industry has guidance. It has become
11 fairly standard reg analysis.

12 We have our, the NUREGs that tell us how
13 to do that, so that's become pretty standard. Even
14 for the top one, we have Reg Guide 1.183 for the light
15 water reactors, and Michelle can weigh in, but I think
16 it's pretty standard.

17 There's maybe more variation on the
18 prevention side between vendors, although for light
19 water reactors, there's many fewer vendors than there
20 used to be, so that probably has also consolidated,
21 but it's been a while since I've done that to be
22 honest.

23 CHAIR MARTIN: I certainly feel like that
24 the move towards risk insights and those current
25 methods is the way to harmonize, and that's definitely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 been trending for a long time.

2 MR. RECKLEY: Okay, Anders? So, this
3 slide is just meant, and we'll get into most of these
4 in a little more detail as we go through the
5 presentation, but it's just to try to show most of the
6 considerations of where we're actually doing an
7 assessment of offsite consequences, offsite dose, and
8 defining a zone around a nuclear power plant that's
9 related to that.

10 And so, most of us, I think, are aware, or
11 will be at the end of the presentation here, of some
12 of these. The exclusion area, the area in which the
13 licensee has to have control of the property, has to
14 be able to say, you know, give direction without
15 challenge is the exclusion area. That boundary line
16 for light water reactors is somewhere around half a
17 mile from the power plant.

18 The low population zone, and we'll get
19 into the connection of these to the consequence
20 assessment as we go forward, but the low population
21 zone, an area that should not include large towns goes
22 out to about four miles.

23 The population center distance, which is
24 the distance out to which you don't want a town of
25 over about 25,000 people, is defined as one and one-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 third times the low population zone, so that will put
2 it at about five miles.

3 Then historically, we've, through guidance
4 and the regulations in Part 100, said that the
5 population density should be assessed and be lower
6 than about 500 people per square mile out to 20 miles.
7 And then as was mentioned, we'll get into how that was
8 assessed, but it included looking at severe accidents
9 to find a value of 20 miles and a rationalization.

10 Todd will talk about emergency planning
11 zones for large light water reactors. That's been
12 around a ten-mile radius around the plant. Then in
13 terms of our calculations that are used to assess
14 designs, we do compare designs to the safety goals,
15 and we look at prob fatalities.

16 That calculation usually is done out to a
17 mile. And we look at latent cancers. Usually that
18 calculation goes out to ten miles. And then when we
19 do a cost benefit assessment, we're looking at
20 population dose out to 50 miles. And on the right is
21 things we'll talk about through here in terms of
22 ongoing things that you've seen lately and some things
23 you'll be seeing in the next revisions.

24 So, Anders, the next slide? So, using the
25 bowtie, and again, looking at the prevention side,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 most of Chapter 15 is looking at events like increases
2 in reactivity, decreases in cooling flow, loss of
3 inventory, those kind of internal events that are
4 assessed, and then systems are provided and tested
5 against those threats or events to protect the
6 cladding for an example.

7 Anticipated operational occurrences are
8 assessed to show that you don't get a loss of cooling
9 through exceeding departure from nuclear boiling
10 ratios or critical heat fluxes. The loss of coolant
11 accidents are looked at through peak clad temperature,
12 common parameters you're aware of.

13 The reactor coolant pressure boundary is
14 looked at to make sure if we have a loss of load, for
15 example, that the pressure doesn't exceed the primary
16 safety values. And then on the containment, Chapter
17 15 is looking at the challenges to the containment,
18 the design basis accident pressure, temperatures, for
19 example, to show that the containment can remain
20 intact.

21 But as I said earlier, most of those
22 aren't looking at offsite doses. They're looking at
23 the integrity of the barriers. That will be used in
24 Michelle's discussion to rationalize or justify using
25 the approach in Reg Guide 1.183 to actually calculate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 offsite doses.

2 Then external events are largely, it's an
3 oversimplification, but they're largely then looked --
4 when you look at those safety-related equipment needed
5 in the top row, and you protect them or show they can
6 withstand external hazards like design-basis
7 earthquakes, design-basis floods, tornado or hurricane
8 loads, and so forth.

9 The bottom we're not going to talk about
10 today too much, but it's important from an integration
11 standpoint and a big picture, that another set of
12 events is malicious acts. ACRS usually doesn't get
13 involved in security, but I put it up there in part
14 just because there's initiatives underway to better
15 integrate and take advantage of what's included in
16 internal events and external events, to take advantage
17 of that, and security by design is the term.

18 And so, although it's outside of the scope
19 of the ACRS, you will start to probably see
20 interrelationships between security and those things
21 under your purview a little more than maybe you did in
22 the past. So, again, this is primarily just as kind
23 of background, but it's important to see how we build
24 as we go to the next level, which is on the next
25 slide, Anders. How do we actually --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: To clarify what you just
2 said on that slide, what I heard is that you use the
3 traditional approach of picking a single event,
4 either, you know, a transient or accident, whatever,
5 but you've gone through the hazards assessment and
6 concluded these are the things that are of concern,
7 and then you credit all of the safety-related
8 equipment to act as designed because they're safety-
9 related and they're designed to act as designed.

10 And assuming that all happens, then you go
11 through and do the analysis, which in general is
12 intended to demonstrate that containment is not
13 affected adversely by the transient or accident as,
14 you know, supported by the safety-related equipment.
15 Is that a fair summary?

16 MR. RECKLEY: Yeah, that's true, and for
17 light water reactors, again, there are standards in
18 our review guidance that's identified what events to
19 look at, and they would not be surprising to you if
20 you used the process hazard assessment kind of
21 approach, again, increase in inventory, decrease in
22 inventory, increase in reactivity, decrease in
23 reactivity, increase in coolant flow, decreases in
24 coolant flow, which was the kind of question you would
25 go through to say what impact do those things have?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But by and large, that was identified in the '70s and
2 it's been basically used up until now.

3 For small modular reactors, you're
4 starting to see some of those historical things get
5 challenged a little bit. They don't quite work, so
6 there's been variations taken. You've seen it in
7 things like NuScale reviews where some of the
8 traditional approaches might not work or can't. If
9 you don't have large bore piping, it's hard to have a
10 break of a large bore pipe, right.

11 MEMBER ROBERTS: The reason I asked is
12 what gets confusing is like Reg Guide 1.183 uses a
13 severe accident release as the driving function or
14 source term, and I think it's probably important to
15 understand going in that's a conservatism in your
16 approach, that if you actually had the postulated
17 event from the hazards assessment, you know, mitigated
18 or whatever by the safety-related equipment that was
19 designed to mitigate or prevent core damage, you would
20 not have the severe accident release in the first
21 place.

22 And so, to talk about a severe accident
23 release being the purpose of Reg Guide 1.183 would be
24 a misnomer, and it's really a question of defining
25 enough conservatism to be satisfied that the analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is conservative once you get out the other side.

2 MR. RECKLEY: Right, and we'll talk, and
3 when we talk about the defense-in-depth, the
4 traditional approaches to containment is one of the
5 barriers or measures for defense-in-depth. We talked
6 about the history. Again, this has evolved over many
7 decades. You need to keep in mind, and I'll forget
8 the number, but --

9 PARTICIPANT: We know what you mean.

10 MR. RECKLEY: When that was written in
11 1960 to test the containment, almost go back in your
12 mind as to what the analytical capabilities were in
13 1960. You didn't have computer codes that could start
14 with an event and run it all the way through a
15 release. You had computer codes that could do a
16 subchannel analysis in the core, maybe a plant-level
17 response of the coolant system, and then the
18 containment.

19 And so, one of the reasons they were done
20 that way was because that was what was possible when
21 the methodologies were developed, but as time goes on,
22 we've modified them and we've brought in things as
23 they've evolved like PRA and so forth, and better
24 computer codes.

25 MEMBER ROBERTS: Right, I might also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 suggest that in the 1960s when the TID was written,
2 that was before there was this understanding that the
3 containment function was tied to emergency core
4 cooling. And so it was not that surprising to assume
5 you had a, you know, unterminated loss of coolant
6 accident with the containment terminating, you know,
7 blocking the release to the public, which became less
8 of a good assumption when the realization came that
9 they weren't necessarily independent events.

10 And that's part of my line of questioning
11 is starting in about 1968, it wasn't clear why you
12 would assume, you know, a severe accident kind of
13 release coupled with containment functioning, and so
14 the rationale if you're testing the ability of your
15 design basis systems, your safety-related systems,
16 you're going to terminate the event and prevent the
17 release, and that makes sense.

18 If it's like the TID and you had the
19 unterminated loss of coolant accident, but
20 containment, you know, stopped the release to the
21 public, that doesn't seem like as good an assumption,
22 and probably hasn't been for 50 years.

23 MR. RECKLEY: Exactly right. I mean, all
24 of this stuff has evolved over the decades, right? I
25 mean, this model for Generation II plants assumed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 diesel plants work, because all of the systems,
2 reactor coolants, emergency core cooling systems,
3 containment, protection systems, they all took AC
4 power.

5 Well, as we learned more, that started to
6 be questioned and we looked, but yeah, and again, it's
7 an interesting discussion because these topics, you
8 know, they've evolved over the many decades that we've
9 been involved in this, and we made adjustments in
10 certain places. Anders, next slide if you would? So,
11 getting off of Chapter 15 --

12 CHAIR MARTIN: Just a real quick time
13 check to get a better feel for how far behind we are.

14 MR. RECKLEY: Well, this part is going to
15 take longer, the first segment. The middle segment,
16 again, largely will take as long as you guys want. It
17 is really a summary of Revision 4 to Reg Guide 4.7,
18 which came through your committee. Many of you
19 weren't here then, but it came through the committee,
20 so that part will go faster.

21 CHAIR MARTIN: You feel like we're okay?

22 MR. RECKLEY: We're probably behind, but
23 that's -- Michelle doesn't talk as much as me, so
24 she'll go faster. So, that does get us then into Reg
25 Guide 1.183, the design basis radiological consequence

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 analysis, and what we've talked about a little bit up
2 to this point.

3 For that accident, you are assuming a
4 major accident, a core melt type of accident.
5 Michelle will talk about that a little bit more. That
6 puts a source term in terms of the timing and mix of
7 radionuclides into the containment.

8 The containment is modeled to leak at a
9 certain amount at the pressure that the accidents
10 impose, so it's, you know, what will the containment
11 leak when it's at 40 or 45 pounds of pressure from the
12 accident? And that number is usually on the order of
13 one quarter of one percent of the volume of the
14 containment per day, and then tests are done to make
15 sure that that is a conservative leak rate for the
16 containment.

17 So, it's tested, but then that leak rate
18 is used for the analysis that Michelle will talk
19 about, the dispersion and ultimately the comparison of
20 the doses at the exclusionary boundary and low
21 population zone, to show that the dose is over the
22 given period of time at those distances is less than
23 the references values.

24 MEMBER ROBERTS: Just to jump in again,
25 you used the term core melt accident, which is, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 think, right out of the regulation, but I think that's
2 confusing and it's probably good to again reiterate
3 that if you had a core melt accident, at least based
4 on our current understanding of severe accident
5 progression, you're going to challenge the containment
6 leak rate and that probably won't be the leak rate you
7 have.

8 So, what the regulation I think literally
9 says is the release assumed from fuel is based on a
10 core melt scenario, which means you've got kind of a
11 mix of scenarios. You've got a very conservative
12 release from fuel for a case where you're modeling
13 your engineering safety features are functioning
14 properly, but then you then assume that the
15 engineering safety features do function from that
16 point forward.

17 So, it's kind of a left hand, right hand.
18 You're making assumptions from both sides of the
19 table, that you're assuming that you were unsuccessful
20 in preventing core melt, but then when you look at the
21 containment function, you assume you were successful
22 at preventing core melt. Is that right?

23 MR. RECKLEY: Well, you're assuming that
24 containment will perform in terms of the leak rate at
25 the temperatures and pressures that's resulting from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the large break loss of coolant accident generally.

2 This is one set of analyses, and then
3 we'll talk later about another set of analyses where
4 we used different assumptions to make different
5 decisions, but for now, this is the approach for the
6 Reg Guide 1.183 analyses for the dose to individuals
7 at the exclusionary boundary and low population zone.

8 MEMBER ROBERTS: Right, I think you said
9 it's on a subsequent slide, so I guess I'll wait for
10 that.

11 MR. RECKLEY: Right.

12 MEMBER ROBERTS: But there's no physical
13 meaning you can attribute to these numbers? They're
14 simply figures of merit that come out of the analysis?

15 MR. RECKLEY: Like 25 rem and --

16 MEMBER ROBERTS: 25 rem around the EAB or
17 LPZ boundary.

18 MR. RECKLEY: Michelle's got a better
19 history, but they are reference values. We make very
20 clear in the regulations that they're not a radiation
21 protection standard, but they are numbers that have
22 been used historically to see if the design can limit
23 the releases to below those reference values when
24 combined with site features.

25 MEMBER ROBERTS: Okay, so maybe we'll come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 back to this, but this is also a comment we made last
2 year in a letter on the Reg Guide 1.183, that it would
3 be good to have something written down that explains
4 this apparent inconsistent assumption of the core melt
5 drives the release, but then containment is assumed to
6 be intact regardless of what physical phenomenon. If
7 you have core melt, it might affect containment. So,
8 if we need to come back here, but I think we'll
9 probably visit it next month when you talk about --

10 CHAIR MARTIN: Yeah, yeah, I wanted to
11 mention that just for the record, that -- is it both
12 November and December we get to talk about Reg Guide
13 1.183? I'm looking at Michelle because --

14 MEMBER KIRCHNER: I think the schedule is
15 coming up, yeah.

16 CHAIR MARTIN: Right, right, so I think
17 we'll certainly have plenty of time to dig into it,
18 but it's a good warning for Michelle.

19 (Simultaneous speaking.)

20 MEMBER KIRCHNER: Tom, I would go back and
21 just say that, you know, in 10 CFR 50 and then 52
22 picked up the same terminology of a maximum
23 hypothetical accident, that was used to set a bounding
24 source term without talking about how well the
25 preventive systems functioned, and then you entered

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the analysis on the previous view graph and you're
2 correct. In some of those cases, there may be an
3 actual challenge to the containment.

4 But I think my recollection of the history
5 is this would be a conservative bounding assumption,
6 and now let's see how a designed containment would
7 function as Bill said, with the leak rate that's about
8 a quarter of one percent per day, and then you go
9 ahead and do the siting analysis.

10 So, it was nothing that was acceptable
11 about this. That was not a goal to get 25 rem at the
12 EAB for two hours. In fact, there's language in the
13 -- there's a footnote to the language in 50 and 52
14 that suggests it should be well below that, but for
15 purposes of doing siting analysis, I think
16 historically that was a way to come to this next view
17 graph.

18 MEMBER ROBERTS: Right, I agree with that.
19 The way I look at this is a different defense-in-depth
20 model that's coming up later in the slides is the IAEA
21 Five Level model.

22 The assumption of a melt-type release
23 coupled with containment function is a very
24 conservative way to assess Level Four of defense-in-
25 depth, which is you're looking into building your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 engineering systems to prevent the casualty or prevent
2 it from getting worse, but when you get to Level Five
3 of defense-in-depth, that's failure. So, now what do
4 you have to go and assess that against? And we'll
5 talk and you'll hear about emergency planning and
6 other site population considerations.

7 We're not suggesting that the 10 CFR 100
8 criteria really don't fit in a Layer Five of defense-
9 in-depth thought process because the assumption has
10 already been made that the engineering safety systems
11 work, and so when you look at a Layer Five here,
12 that's where everything has failed.

13 So, it's just important to keep in mind
14 that this assumption that containment meets its
15 requirements regardless of design assumptions rather,
16 regardless of what the phenomenology might predict,
17 you know, I don't think that's what this analysis
18 actually does. I think it's actually a very
19 conservative source term for assessing design basis
20 systems. That's why I wanted to give this
21 clarification.

22 MEMBER BIER: Yeah, one other comment.
23 This is Vicki Bier. I think, you know, some of the
24 things we're discussing are kind of details of the
25 policy or the standards here, but I think at a high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 level, the general idea makes sense. I mean, one of
2 the things we've seen unfortunately in the last years
3 is that it's really hard to do evacuation of a huge
4 population, you know, if you're talking about Katrina
5 or that kind of level where you're evacuating hundreds
6 of thousands of people. It's difficult to do that
7 well, so things like the low population zone are kind
8 of just practical strategies to avoid that situation
9 is possible, so.

10 MEMBER ROBERTS: Right, and I would argue
11 the problem with that is the low population zone is
12 calculated with the assumption the containment works.

13 MEMBER BIER: Yes.

14 MEMBER ROBERTS: And so, what you get is
15 what would -- if you're really looking at the worst
16 case scenarios and you're ready to evacuate a
17 population, that's not the population you'd be worried
18 about. It would be a much larger population because
19 the real event, you know, presumably would have had a
20 containment, you know, failure in it, an event that
21 would actually trigger a mass evacuation.

22 And so, that's where the 20-mile radius in
23 Reg Guide 4.7, that's where it asks questions about
24 these LPZ and population center distances, their
25 adequacy and, you know, predicting the ability to deal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 with those kind of events. But yeah, I think that's
2 one of the key points here is what analysis supports
3 those types of events? Because it doesn't seem to be
4 the Reg Guide 1.183 analyses, which make that, you
5 know, assumption that the design basis systems work.

6 This is an important layer of defense-in-
7 depth. You want to know if your design basis systems
8 do their job, and you hope that -- not hope. You have
9 engineered the systems. You have a very, very low
10 residual probability of getting to where Layer Five of
11 defense-in-depth matters at all.

12 And so, you want to have that low
13 probability, and then you want to have an
14 understanding -- you do have capability for Layer Five
15 of defense-in-depth commensurate with the likelihood
16 of getting there, so that's kind of, you know, where
17 I look at this whole story of the siting analyses is
18 they don't seem to be really oriented towards
19 supporting that.

20 (Simultaneous speaking.)

21 MEMBER ROBERTS: -- history that Bill
22 didn't get to because we don't have three and a half
23 hours, but if you look at the NUREG-0625, the 1979
24 document, that's a good read because that was the
25 culmination of a team of NRC staff saying we have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 wrong criteria in Part 100, and they were for various
2 reasons unable to get them changed, but there were
3 other reasons that drove that, but it's important to
4 understand the limitations of those criteria if you're
5 really looking at mass evacuation kind of events that
6 are not impossible.

7 MR. RECKLEY: And what you'll see, and
8 we'll get to it in some of the later slides, is -- I
9 agree with the conversation. This is done for the
10 purpose it's done, and if we stopped here, then there
11 would be criticism that we stopped in an inappropriate
12 place, but we have the severe accident policy
13 statement that goes beyond this.

14 We have the population density controlled
15 out to some distance to help control this. We'll get
16 into emergency preparedness later. There are a number
17 of things, the safety goals, the inclusion of
18 probabilistic risk assessment that has been more
19 incorporated into our decision-making, so all of those
20 things are added to this assessment, right.

21 But with that, I'm going to skip slide ten
22 because it simply repeats the table from earlier in
23 terms of what the zones are. Then I'll just touch on
24 the population density. We're going to talk about
25 that more in the second session since it is the topic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But as Member Roberts said, this also has
2 a long history. Should it be ten miles, 20 miles, 30
3 miles, 40 miles? All of that was assessed in the
4 decision that was ultimately made in the Part 100
5 rulemaking that it would be 20 miles. The rulemaking
6 was in the '90s. It took a long time to do, but that
7 assessment went further than what we just talked about
8 in terms of Reg Guide 1.183. It did consider severe
9 accidents.

10 Now, at that time, that was a reactor
11 safety study. You know, if we were to do it now, we'd
12 have more data. We'd have SOARCA, and NUREG-1150, and
13 other sources of data, but when that they did this
14 assessment, it was largely a reactor safety study,
15 other assessments that they did.

16 Then in regulatory matters, it's not all
17 just the math, right? We went out and got public
18 comment on what the distances were, and some said it
19 should be larger, some said it should be smaller, but
20 that's part of the decision-making is not just doing
21 the calculations and saying oh, there's the number.

22 It's going out, soliciting public comment
23 and feedback, and considering any number of
24 qualitative factors, keeping in mind by this time,
25 there were a fair number of operating nuclear power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 plants, right, so that's playing into the decision-
2 making as well.

3 So, all of that went into play. We had a
4 generic analysis that basically said 20 miles is a
5 reasonable number. It's not something you can prove
6 or derive through a calculation. It's a reasonable
7 number and that's what we've lived with since the
8 rulemaking.

9 Again, there was a period where it was 30
10 miles, but for the last many decades, it's been 20
11 miles based on that generic analysis, and we'll get
12 into the second session where we're now saying we're
13 going to offer an alternative to that, but require
14 analysis to test it by. So, we'll go to the next
15 slide, and I'll shut up, and Michelle, you can make up
16 for all of the rambling.

17 MEMBER HALNON: So, Bill, before you go,
18 I mean, what you just said, this has no analysis to
19 it, that you're going to offer an alternative that
20 requires an analysis. How do you equate those two?
21 How do you do an analysis to prove that something you
22 never did an analysis for in the first place was --

23 MR. RECKLEY: And that was really a trick.
24 And that's why we had to send a paper to the
25 Commission. This is a policy issue. You have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 weigh in on --

2 MEMBER HALNON: It gets back to the
3 policy.

4 MR. RECKLEY: -- the criteria. And we did
5 look at some of, I won't say equivalency, but what did
6 generic analysis do? And we have to do something
7 similar. Plus, we're now better informed. And it's
8 30 years after that work was done.

9 MEMBER HALNON: Better informed in a
10 couple places. One is we were tainted by the assumed,
11 if not informed safety of the large light-water
12 reactors. That was all we had, except in the test
13 reactors. We even had different regulations.

14 Now we have advanced reactors, which are
15 much closer to the test reactor safety levels than the
16 large light-waters. And our mindset has to change.
17 So, I'm worried that we have to do an analysis to show
18 the thing we never did an analysis for is --

19 MR. RECKLEY: No. No, I understand. It's
20 not lost on us, right, that the generic analysis set
21 20 miles. But what we were hearing from stakeholders,
22 including the Department of Energy, who has been doing
23 plenty of studies about what was the impact of keeping
24 20 miles would be -- and Oak Ridge. A time I know
25 came when we were going Reg Guide 4.7, part of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thing to keep in mind -- again, you need to do public
2 safety, but the keeping of the 20 miles, they did
3 studies. And one that comes to my mind was around
4 Kansas City. You know, nuclear plants replacing
5 fossil stations. If you kept 20 miles you eliminated
6 all but maybe one or two of the retiring fossil
7 stations around Kansas City when they did that study.

8 So, the general thought was we need to
9 have an alternative to 20 miles. And now we can use
10 analysis, was the assumption. And that's, again, we
11 went to the Commission with a policy statement and
12 finished the guidance --

13 MEMBER HALNON: I'm waiting for the rest
14 of the story.

15 MR. RECKLEY: All right.

16 MS. HART: So, good morning. I'm Michelle
17 Hart. I'm a senior reactor engineer, and I'll be
18 talking about Reg Guide 1.183. I'm not in charge of
19 the review or the revision of it. I am part of the
20 working group as well.

21 We've talked a little bit about the
22 history. I won't rehash a lot of this. But, you
23 know, originally the large light-water reactors
24 currently operating were all licensed under a version
25 of Part 100 and the TID-14844 source term, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 assumes release of 100 percent of the noble gases,
2 about 50 percent of the halogens, and one percent of
3 others, is the way it's talked about in the Reg Guide.

4 TID-14844 was developed and is kind of the
5 technical basis for Part 100 as originally issued.
6 The figures of merit, the dose criteria for
7 determining the emergency planning -- I mean, not
8 emergency -- excuse me, the exclusion area boundary
9 and the low population zone was dosed to an individual
10 over certain time periods, and they were whole body
11 and thyroid doses. It was 25 rem whole body, 300 rem
12 thyroid.

13 These Reg Guides and the NUREG-0800, the
14 SRP, discussed the assumptions and analysis that you
15 would do with that is not an integrated analysis, as
16 we have been talking about. There's -- and I think I
17 agree with Member Roberts' characterization that it's
18 a large source term to look at the containment
19 capability if you assume that it operates at the
20 design basis capability of the containment.

21 Next slide, please. So, we have moved on
22 to Reg Guide 1.183. The original revision of Reg
23 Guide 1.183 was based on NUREG-1465, which is a severe
24 accident source term. It's more than one severe
25 accident. There's a set of different events that they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 used in all of these that's to meet the general idea
2 in the fission product footnote, which has words like
3 has generally been assumed, and is postulated for
4 purposes of siting, or not to be exceeded by any
5 accident considered credible, those type of words.

6 Generally has been assumed to be a core
7 melt. In NUREG 1465 it was still a core melting
8 event. It involved a whole core and was similar-ish
9 to TID-14844, but the timing did change. We had a
10 different timing of the release. And the noble gases
11 were still 100 percent. The halogens were about 30 to
12 40 percent. There were differences for BWRs vs. PWRs.
13 And the speciation of the iodine changed so that it
14 was mostly particulate instead of mostly gaseous, so
15 then there were more removal mechanisms available if
16 you wanted to model them specifically.

17 The dose criterion, the figure of merit,
18 did change from full body and thyroid to total
19 effective dose equivalent, or TEDE. It was then
20 determined to be 25 rem. There was a argument at the
21 time that was approximately risk equivalent to the
22 previous criteria. I think it's not exactly correct
23 to say that. But I think it's a reasonable, much less
24 than would cause any kind of health effect to persons
25 offsite, if they would exceed -- if they would receive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this dose. As well as the criterion is looking at an
2 individual in the center line of the plume for the
3 duration of its passage at the low population zone, so
4 it's not realistic assumption to assume a person would
5 actually see that type of dose.

6 At the EAB it's for the peak two-hour
7 period instead of the first two-hour period to
8 accommodate that difference in timing for the release.

9 And so this criterion is one that we would
10 use for any new reactor moving forward, would be the
11 25 rem TEDE. We would no longer use the whole body
12 and thyroid for a power reactor. Test reactors still
13 use that criteria.

14 Next slide, please. So, these are the
15 criteria that we currently use. I mean, I've just
16 described this. There's also a criterion, a design
17 criterion for the control room.

18 In Appendix H, Part 50, are the general
19 design criteria for generally applicable for light-
20 water reactors, may be used as guides for the
21 principal design criteria for other designs. And in
22 that case there is a control room radiological
23 practicability criterion that is 5 rem TEDE for the
24 duration.

25 Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HARRINGTON: Is that individual
2 cumulative dose?

3 MS. HART: So, it's the dose to the
4 individual operator. So, in Reg Guide 1.183 and also
5 in the standard review plan we do have different
6 criteria for the non-LOCA or non-maximum hypothetical
7 accidents. And they are generally graded based on a
8 qualitative likelihood. There are no specific
9 frequencies given, and they are the same for each
10 reactor.

11 We haven't had discussions with anybody
12 about changing the criteria. And there are three
13 different levels for the maximum hypothetical
14 accident, the accident that's described in the
15 footnote to the regulation. It's the full regulatory
16 dose value, 25 rem TEDE.

17 It's also applicable to some other or the
18 non-LOCA design basis accidents that have a lowest
19 likelihood of occurring among the ones that we need to
20 look at.

21 There's four I call it low relative
22 likelihood, kind of the middle range. There's the
23 criterion of well within our 25 percent of the dose
24 criterion of that 6.3 rem TEDE, is the way we noted it
25 in the Reg Guide 1.183.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And then for those with the highest
2 relative likelihood, it's a small fraction of or 10
3 percent of the dose criterion, that 2.5 rem TEDE.

4 And the general idea is, you know, the
5 more likely the event is to occur, the lower the dose
6 criterion that you would need.

7 MEMBER KIRCHNER: Michelle, just to probe
8 a little bit. When you actually evaluate an
9 application, how do you see yourself using this table?

10 MS. HART: So, in the case of light-water
11 reactors, which this was developed for, you already
12 have the accidents laid out in the SRP. So, everybody
13 generally follows that.

14 MEMBER KIRCHNER: Right.

15 MS. HART: Now you can have discussions
16 about this with a small modular reactor. You know,
17 one of the events that gets the well within criterion,
18 25 percent criterion, is the fuel handling accident.
19 And that's compared to the steam generator tube
20 rupture that, you know, they have the same dose
21 criterion.

22 Are they really the same likelihood? And
23 a steam generator tube rupture occurring when you're
24 at the 48 hour maximum tech spec coolant activity gets
25 the full dose criterion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, you can see that the fuel -- I mean
2 the steam generator tube rupture at the normal coolant
3 activity is much more likely to occur than one that's
4 at the 48 hour maximum coolant activity.

5 But can we compare the fuel handling
6 accident to the other, like, the steam generator tube
7 rupture or main steam line break and say that they're
8 equivalent or not?

9 I don't think that there's, there's a good
10 way to really move away from the criteria, as we have
11 set them up, in specific, you know, quantitative way.
12 There's more of a, you know, this was a decision made
13 back in the '80s or '70s kind of thing, and so how do
14 you move away from that?

15 And we haven't had discussions for those.
16 I know that seems rather unsatisfying. And it is kind
17 of unsatisfying. But I think if you compare this to,
18 like, the frequency consequence target that we're
19 using with LMP and with PRA, I think it's a lot more
20 structure and it's easier to see that the criteria and
21 the frequencies how they, they line up.

22 Next slide, please. So, as we note, in
23 Reg Guide 1.183 none of the DBAs, including the
24 maximum hypothetical accident are intended to be
25 actual event sequences were intended to be surrogates

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for those to enable deterministic evaluation of this
2 plant safety-related work.

3 And, specifically, the accident release
4 mitigation features, not prevention or core damage or
5 things like that, it's more focused toward those
6 things that would contain or retain fission products
7 or other radionuclides.

8 They're intentionally conservative in
9 order to address the uncertainties in accident
10 progression, transport, and atmospheric dispersion.
11 So, we do these, traditionally, these analyses have
12 taken deterministic not necessarily integrated, you
13 know, the same types of, you know, it's not an
14 integrated analysis.

15 You take just conservative assumptions in
16 these to try to maximize the potential consequences
17 offsite but, at the same time, also evaluate, you
18 know, giving them credit for the safety-related
19 systems.

20 And so, some of the conservative
21 assumptions are these 95th percentile meteorology, the
22 dispersion could only be worse 5 percent of the time
23 based on site-specific data.

24 There's no protection act -- no protection
25 actions that are credited in these analyses, no dry

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 deposition, or sheltering, or, you know, weathering or
2 any of those kind of things.

3 At the same time, you're only looking at
4 the consequences of the plume passage, so you're not
5 looking at ground shine or anything like that as well
6 for these types of analyses.

7 The source term is risk informed now. But
8 the Reg Guide 1.183 we have used more of today's
9 evaluations to determine the maximum hypothetical
10 accident. There are more recent studies have you seen
11 -- as you've seen in Revision 1 to Reg Guide 1.183.
12 And an even newer revision in the Revision 2 that
13 you'll be hearing about in conjunction with the
14 increased enrichment goal making activities.

15 And in those cases what we mean by risk
16 informed is you look at all of the spear accidents,
17 potential accidents that would result in core melting,
18 or core-wide damage, maybe not necessarily melting.
19 And you take, you know, you develop a source term that
20 would be representative of those type of events.

21 The modeling does generally not credit
22 facility features that are not safety-related, as
23 we've discussed.

24 If they're not covered by technical
25 specifications we generally don't model them. If they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 don't meet single failure criteria, or if they rely on
2 the availability of offsite power. Any delay should
3 be credited. So, you're looking at how do these
4 safety-related pieces of equipment really work to
5 negate potential releases.

6 CHAIR MARTIN: A clarification. When you
7 all visited last fall, mentioned you had been at
8 Sandia, right, in the presentation as well. Is a
9 newer document for Sandia 2023.1313, I thought it was
10 updating a 2011 document, or what is that? You didn't
11 put it on your slide, I wondered if --

12 MS. HART: No.

13 CHAIR MARTIN: -- that's intentional or?

14 MS. HART: No. I'm referring to the
15 documents that are currently guidance that is out
16 there now. So, the newer guidance or the newer Sandia
17 report is not being used for licensing yet. And
18 that's part of the process of going through the
19 process of going through the review.

20 CHAIR MARTIN: Thanks for that
21 clarification.

22 MS. HART: So, I know I went through that
23 kind of quickly. It's kind of high level.

24 Is there any additional questions?

25 MEMBER KIRCHNER: Just an observation,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Michelle.

2 But there still would be a second simple,
3 there are source term, you're still postulating a
4 failure significant event?

5 MS. HART: Correct.

6 MEMBER KIRCHNER: We're not seeing that on
7 LWR designs.

8 MS. HART: In the context of the
9 evaluation of the siting criterion, or the 15.34
10 safety analysis that you would do, the design basis
11 accident analysis, I think it's too early to really
12 say that nobody will do that. If they're using the
13 licensing modernization project process for the PRA,
14 they are not required to develop a, you know, a
15 bounding analysis or anything like that.

16 They may choose to.

17 I think there's some issue with how you
18 deal with the language in the regulation. The
19 regulation itself says you have a release of fuel into
20 the containment, you expected demonstrable containment
21 leakage rates, and then the meteorology. And then
22 there's the fission product footnote.

23 So, does what you're proposing for your
24 facility as a non-light water reactor meet all of the
25 or conform to that kind of language? That's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discussion we would have to have.

2 MEMBER ROBERTS: This is the slide I was
3 thinking of for broader response initiatives, the
4 slide that says you shouldn't really take any meaning
5 to the numbers. That's not quite what this says, but
6 again, that's essentially what this says.

7 But just wrapping back around to Vicki's
8 question from earlier, this is a very conservative
9 analysis for what it does. Is there any way to
10 correlate to severe accident scenarios? Or is that
11 just beyond what, what's been done?

12 You took an LPC of four miles, I think you
13 had. Could you draw any conclusions about that
14 evacuation zone or is that just a completely, you
15 know, different question?

16 MS. HART: I think because it's not really
17 an integrated assessment it's hard to make that
18 correlation.

19 MEMBER ROBERTS: Okay, thanks.

20 Then the other question is population --
21 this just wasn't on the previous slide -- but the 1962
22 rulemaking document said that the analyses to date
23 show that a population center distance was a
24 reasonable surrogate for severe accident performance.

25 Has there been any work in the last 60

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 years to, you know, confirm or refute that?

2 MS. HART: So, when we went through
3 developing the SECY paper for the discussion of
4 population-related considerations, I think we did look
5 at some of the historical information on that. And I
6 don't know that there were any quantitative
7 evaluations that we've done.

8 Bill, do you have any more information on
9 that?

10 MR. RECKLEY: No. We decided at that time
11 that we weren't going to pursue rulemaking to change
12 it. One-and-a-third is in the rule.

13 Now, you can look, Michelle, -- not
14 calibrated here -- but, you know, if you're at 25 rem,
15 you know, and just do the power entry you're going to
16 be -- you could get a rough estimate of what you're
17 going to be at one-and-a-third.

18 And but the primary, primary driver was we
19 decided not to pursue a rulemaking. So, one-and-a-
20 third remained.

21 Or, again, the 1979 NUREG, their
22 recommendation was to delete the population center
23 distance put it in Reg Guide 4.7 in the regulation.
24 So, that's where they were, essentially were 45 years
25 ago.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 It seems like I guess my observation is
2 there's no real correlation between these three
3 criteria out of, out of the Reg Guide 10 to 100 and
4 actual live emergency response or expectations for how
5 you would actually deal with an event.

6 MR. RECKLEY: So, Todd in the next few
7 slides will start to talk about the emergency of
8 various aspects.

9 But a lot of this ties to a general
10 Commission policy to locate reactors away from
11 populations; right?

12 And so, that's why it remains sort of
13 maybe less satisfying for people who want an equation
14 to show how we, how we got here.

15 MS. HART: And, of course, the regulation
16 does use words like generally low populations, and
17 generally away. And so, that's why I think a lot of
18 this guidance, you know, lies in the Reg Guides. You
19 know, like the population density is in the Reg Guide.
20 It's not in the regulation.

21 But, you know, as a very vague proxy for
22 societal risk, or a very vague proxy for capability of
23 taking action, I think that is maybe the intent. And
24 maybe I shouldn't have used the word vague, but it's
25 there's not a specific criterion or specific numerical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 value that's been put on these things that we just
2 discussed.

3 MEMBER PETTI: This is Dave. Michelle, I
4 wanted to follow up on Walt's question on the severity
5 of accident. It's called the maximum critical
6 accident. When you think about advanced systems, it
7 seems to me that LMP, they offer an avenue where the
8 severity of such an event is less based on frequency
9 arguments than, you know, the historical
10 deterministic, taking an event which is what our
11 light-water started.

12 I think that's what's somewhat unsettling
13 to think that there will be this dichotomy, if you
14 will. I mean, actually the question to ask yourself
15 is if you're in an LWR, LWR through LMP, what would
16 be, you know, those design basis events from which,
17 you know, you can go forward on the source term? I
18 mean, would it be what was postulated in the
19 regulations or not?

20 MR. RECKLEY: And the answer is probably
21 not.

22 MEMBER PETTI: Probably not. Right?
23 Yeah.

24 MS. HART: And, with that, my time with
25 you is done. And I will now pass over the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 presentation to Todd Smith.

2 MR. SMITH: Great. Thank you, Michelle.

3 Good morning. I'm Todd Smith, Senior
4 Level Advisor for Emergency Preparedness and Response.
5 And what I'm going to do now is give you a very high
6 level overview of emergency preparedness and some
7 insights on how do we use these risk insights to
8 inform the plan.

9 Emergency preparedness is an operational
10 program. It's all about taking action. For NRC to
11 issue a license we need to make a reasonable assurance
12 finding that protective actions can and will be taken.
13 EP is the final layer of defense-in-depth, and it's an
14 independent layer. So, EP and EPZ are not part of
15 siting or design. EP has its own criteria that have
16 to be met. And these criteria give you capabilities
17 to provide dose savings.

18 Now, here is where we're going to see some
19 difference in the character in the EP regulations from
20 siting and design. Michelle just talked about figures
21 of merit that we use. But in EP there is no -- an
22 active plan does not achieve some minimum dose savings
23 or some minimum evacuation time. The concept is
24 reasonable and feasible dose reduction under the
25 circumstances.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 For this, we are risk informed. We need
2 to understand what are those circumstances in which we
3 may need to act.

4 A lot has to do, though, when we start
5 talking risk informed performance-based EP. We can
6 confuse terminology of what we mean in design. For
7 example, usually when we talk risk in EP, we are not
8 talking risk triplet: what can go wrong, how likely is
9 it, what are the consequence? Usually when we say
10 risk, we mean radiological risk or dose.

11 Go to the next slide, please. The good
12 news for EP is that we've always been risk informed.
13 We're very adept at it. In the NRC we call this our
14 graded approach.

15 We license many different types of
16 facilities with hazards and risks. Some of them have
17 planning zones that support the finding, some do not.
18 They all have effective emergency plans.

19 But there's two key points I want to
20 emphasize then about planning. The first is it needs
21 to remain flexible. The idea behind planning is you
22 have some core planning that you can respond to any
23 event, including very low probability of accidents.

24 The second concept behind the planning is
25 it's not all based on quantitative analysis. There's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a lot of qualitative assessments that have helped
2 inform planning. And we use a lot of judgments.

3 Can we go to the next slide? So, taking
4 those two points, I've tried to illustrate that in
5 this slide here. In the quote that was up there in
6 the last slide it talked about margins of safety.
7 What does that mean really in an EP context? Do we
8 really talk about margins of safety as we would in
9 design?

10 When I'm in design space I can talk about
11 margins of safety between operating limits and failure
12 criteria. But that doesn't really translate into EP.

13 In EP we're not even there until we've
14 exceeded those safety margins. So, what I'm trying to
15 illustrate here in this figure is how is it that we
16 arrive at that core planning that meets the regulatory
17 requirements?

18 So, the core planning is represented by
19 that orange line. And what I'm showing you in blue
20 and red lines is how do factors like likelihood,
21 consequences inform planning?

22 Certainly we want to make sure we have
23 plans in place to deal with more likely events. And
24 as you start to develop your plans you find that
25 you've developed capabilities that are adequate to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 address even more very unlikely events.

2 Similarly for consequences, if there's
3 very low consequences you don't need bunches of
4 planning. If you're consequences increase, you need
5 to add for capabilities. But, ultimately, you get to
6 a point where those same capabilities can be applied
7 to even more severe accidents.

8 And so, the key point here is when we say
9 risk-informed performance-based EP, we're not
10 necessarily talking risk-informed performance-based
11 design.

12 Go to the next slide, please. Formerly we
13 accomplished this through the planning basis concept
14 that goes back to the 1970s and NUREG 0396. A key
15 point about this is though it's not unique to NRC
16 regulations, the idea of using a spectrum of accidents
17 shows up in other countries, in IAEA safety standards.
18 They call it the hazard assessment.

19 The concept is that you use a spectrum of
20 accidents to understand the distance time material to
21 scope the planning efforts. This concept, distance
22 time materials is very simple. It sounds a lot like
23 time distance shielding we use for radiological
24 protection. So, it's a very powerful, very simple
25 concept but it shows you what is it that we need to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know in EP to be able to scope the planning efforts.

2 Chairman Martin, your question came up
3 earlier about efficiencies. And part of our
4 transformation efforts in EP, like when we issued
5 5160, was to recognize that a lot of the information
6 that's needed to inform the planning is developed in
7 other parts of the licensing basis. And so, the rules
8 and guidance provide for that efficiency by making use
9 of licensing basis events, how you're treating
10 security, environmental reports, in scoping the
11 planning efforts.

12 MEMBER HALNON: So, Tom, this is Greg.

13 MR. SMITH: Yeah.

14 MEMBER HALNON: On events where it was the
15 fact that EP is not depended on. You said earlier
16 that if it's independent of all the other stuff that
17 goes on, how does that square up?

18 MR. SMITH: Because we use that
19 information to inform those capabilities. But the
20 capabilities themselves are independent of any
21 accident probability or likelihood.

22 I'll give you an example. Communications
23 capabilities, I may have a system in place, you know,
24 a phone line, dedicated phone line to call all sites.
25 But recognizing there are events, like station

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 blackouts, I will make sure I have some backup that's
2 independent Office of Administrative Law Judges the
3 main power supply to those communications.

4 MEMBER HALNON: So you're going a step
5 further then with that sort of what if?

6 MR. SMITH: Correct.

7 CHAIR MARTIN: So, to make judgments you
8 would have to be able to test the premises; right?
9 With regard to emergency preparedness or anything
10 related to safety, ideally you start with a benchmark,
11 and then you need to perform your tests.

12 So, you know, the easiest way to look at,
13 you know, any of these questions of radiological
14 safety is to consider something we might call
15 unmitigated outcome, unmitigated event. You know, you
16 want to pull back on the history lesson, right, you
17 have WASH-740 in the '50s, right? Basically you had
18 no containment and it postulated rather serious
19 consequences.

20 Subsequent to that, we layer on the
21 defense-in-depth philosophy, et cetera, et cetera, and
22 we can begin to quantify the benefits of all the
23 features, safety features, et cetera, et cetera.

24 I think what we do, we say Reg Guide 1.183
25 is -- doesn't necessary have a true unmitigated event

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 as you might have with a WASH-740, but you have a
2 serious event. And you can still test; right? You
3 can still quantify, you know, whether it's any kind of
4 mitigating procedure, you can indicate whether it's an
5 administrative procedure or performance of structure
6 system components.

7 Really, that is what is important here is
8 being able to demonstrate that you can improve the
9 situation. It's generally skiing along until things
10 break, of course. But isn't that the idea, really?
11 If you need a benchmark and so you can test and you
12 can -- you know, the devil's in the details. And
13 that's -- you've got to begin somewhere.

14 MR. SMITH: Absolutely. And that's the
15 heart of risk-informed EP, is that -- we could spend
16 all day -- you know, I could give you lots and lots of
17 presentations to show you this, we do test it and we
18 do challenge those assumptions and we do look to find
19 how can we use the risk insights to enhance the dose
20 savings that we get from EP.

21 A lot of this you won't find, though, in
22 PRAs. We do get insights from studies like SOARCA, we
23 will get insights from the Level 3 PRAs. But I just
24 brought one example -- a couple of examples of studies
25 that we do, right, where we look at, how do we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 quantify the benefit of emergency preparedness and
2 test those things against, you know, how would this
3 hold up under, like, severe seismic events --

4 CHAIR MARTIN: Real quick, for the record,
5 what did you just show us?

6 MR. SMITH: Yes. For the record, this is
7 the study of emergency preparedness significance
8 quantification process proof of concept, NUREG/CR-
9 7160. And, of course, NRC, we've studied evacuations
10 for decades. We know they're effective. We know they
11 save lives. We know the conditions, the planning that
12 are required to ensure you have effective evacuations.

13 We also recently looked at, how do we
14 better use shelters. So, again, I'm very much outside
15 of plant, right, and I'm looking offsite and I'm
16 looking at the actions that the public's taking. So
17 the risk-informed decision-makers of the public after
18 they go offsite. And we recently just published a new
19 study that looked at insights on how can you better
20 use heating and air conditioning systems in emergency
21 situations to control the indoor air contaminants to
22 reduce the exposure.

23 So, we do a lot of science behind that and
24 we've given a lot of talks at the Regulatory
25 Information Conference and at the conferences we go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to, how do we enhance emergency preparedness through
2 science.

3 MEMBER BIER: Another question. This is
4 Vicki Bier. Something that I probably should have
5 researched ahead of time, and didn't think to. Can
6 you talk about what provisions are made for emergency
7 response for people who don't drive or don't own a
8 car? Because that was a huge issue after Katrina.
9 We're obviously not talking about, you know, transit-
10 dependent urban areas here, but what has been done
11 about that?

12 MR. SMITH: Yeah. So, from a regulatory
13 requirement, licensees have to develop their
14 evacuation time estimates, and those ETEs consider
15 transit and transit-dependent populations, special
16 populations like hospitals and schools. And the
17 analyses then inform the offsite planning and the
18 capabilities and resources that they need for
19 protection for those demographics.

20 We also -- as I mentioned, we don't rely
21 just on evacuation. Another study I'd like to point
22 out, NUREG/CR-7285. We examined, what are the non-
23 radiological health impacts of evacuation relocation.
24 A lot of lessons learned from Fukushima, okay? So,
25 you don't necessarily want to rely on a precautionary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 approach. And this is why we're so interested in the
2 effectiveness of shelters because not everybody can
3 get in a car and evacuate, but that doesn't mean that
4 it can be any less safe by staying at home.

5 We're even looking at quantifying the
6 effectiveness of wearing a mask. So COVID
7 demonstrated people are acceptable -- comfortable
8 wearing a mask. We're quantifying and working with
9 our colleagues in research, you know, what benefit
10 does that give you in terms of inhalation dose
11 savings, what's the tradeoff for the skin dose, and
12 we're finding a lot of benefit which we're quantifying
13 and then we're going to use to update some guidance.

14 PARTICIPANT: Which is what, cleaning your
15 filter every six months, and --

16 (Laughter.)

17 MR. SMITH: Yes, and using standalone
18 filters.

19 PARTICIPANT: Right.

20 MR. SMITH: The key is, the EPA's
21 protective action guide manual, which provides the
22 guidance to state and locals, recommends doing this,
23 recommends putting a cloth over your face, recommends,
24 though, shutting off the HVAC. What we're trying to
25 do is get better nuanced guidance with real

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 quantitative data to back up those assumptions. When
2 we tell the public, this is safe to do this, it's
3 backed up by our science.

4 MEMBER BIER: Because I think, even in
5 rural areas where the vast majority of people drive,
6 there are always going to be, kind of, elderly folks
7 who aged out of driving who depend on their neighbors
8 to bring stuff in for them or whatever. So I'm glad
9 to hear that that's being reviewed.

10 (Simultaneous speaking.)

11 MR. SMITH: Yeah, we're trying to get the
12 more risk-informed decision-making.

13 MEMBER ROBERTS: Following up on Greg's
14 question. If you use a frequency-based criterion to
15 screen out accidents such that you conclude your EPZ
16 is the site boundary, what kind of infrastructure do
17 you not have in the community that you would have if
18 you did have an EPZ that went beyond the site
19 boundary?

20 MR. SMITH: Actually, very little. You
21 know, even going back to the 1970s when they were
22 asking the question for NUREG-0396, you know, what
23 distance should we plan, it wasn't a question of, we
24 don't have capabilities to evacuate, it was simply the
25 distance, right? So, there is a lot within all-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 hazards planning of capabilities to evacuate people.
2 We see this all the time. I mean, look at Hurricane
3 Helene right now. Okay, there was no emergency
4 planning zone but we had evacuations to save lives.
5 We saw this with the train derailment last year in
6 East Palestine. So, a lot of capabilities --

7 MEMBER ROBERTS: Okay you're not there yet
8 but a couple of a slides from here has a plot from
9 NUREG-0396, and I've interpreted it as an evaluation
10 of the effectiveness of the EPZ. I think you'd
11 probably disagree with that characterization, that
12 it's really just an analysis of what protective
13 measures would do regardless of whether or not there
14 was an EPZ. I was wondering if you could comment on
15 that. It's slide -- I think it's slide --

16 (Simultaneous speaking.)

17 MR. SMITH: Yeah, let me -- that's my next
18 slide, but let me make one more point, here. Because
19 there's another key difference between our current
20 regulations for large light-water reactors and the
21 risk-informed performance based regulations in 5160.
22 And that is, who does the hazard assessment. In the
23 past, the NRC, we did the hazard assessment through
24 the planning basis, and we scoped the planning effort.

25 So regulations are prescriptive but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 they're no less risk-informed. So, under the new
2 regulations, the applicant will do their hazard
3 assessment to scope the planning efforts. Can we go
4 next slide?

5 Yeah, so -- shut my mic off. And the key
6 thing about the regulation is that it's giving the
7 applicants the same flexibility to make risk-informed
8 decisions that the NRC has made in the past, and that
9 includes scoping the emergency planning zone. The
10 first thing to recognize about the emergency planning
11 zone is it's not a design feature, it's a planning
12 tool. It's meant to help implement pre-determined --
13 protective actions.

14 And NUREG-0396 didn't necessarily lay out,
15 you know, the definitive way to approach sizing an EPZ
16 or determine it, right? What it did illustrate is the
17 utility of the risk-informed approach and how you can
18 use multiple lines of reasoning to align at a
19 reasonable result, okay? So, at the time they used
20 the available information they had from design-based
21 accident criterias, the risk insights from the WASH-
22 1400 reactor safety study, their understanding of
23 environmental reports.

24 And then this, also -- this study that was
25 done at the time of, what would be the efficacy of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 different protective actions within, you know, certain
2 distances from the facility. And this brings up the
3 key thing to understand about the emergency planning
4 zone, then. If you look at that middle graph, the
5 green line, okay? What that's telling you is, the EPZ
6 is not a boundary beyond which I cannot exceed a dose.
7 It's a reasonable distance for the planning.

8 The assumption is, if there's an accident,
9 I may not have to take action within the entire
10 emergency planning zone but I also have capabilities
11 to take action beyond it as conditions warrant. And
12 that concept of the emergency planning zone is carried
13 forward today.

14 MEMBER ROBERTS: Right. Yeah, my question
15 had to do with the right-hand plot where, what that's
16 telling you is that if you do something from a
17 protective response standpoint and you reduce the
18 number of fatality, I think, is what this plot is, by
19 a lot. But, obviously, not down to zero, which is
20 your point, but down by a lot. And the question is,
21 does that correlate to an EPZ or it just correlates to
22 modeling protective measures irregardless of whether
23 or not there's an EPZ?

24 MR. SMITH: Yeah, it correlated to
25 modeling the protective measures. But, for the task

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 force in NUREG-0396, they used those insights as an
2 additional line of reasoning that ten miles was
3 adequate. They could achieve those dose savings, as
4 was the objective.

5 MEMBER ROBERTS: Right, because the bars
6 are all pretty low at 15 miles --

7 (Simultaneous speaking.)

8 MR. SMITH: Yes.

9 MEMBER ROBERTS: That's, kind of, the way
10 I read it too. So, it's really telling you that a
11 ten-mile, you know, kind of a mental thought process
12 is a way to think about it --

13 (Simultaneous speaking.)

14 MR. SMITH: Exactly.

15 MEMBER ROBERTS: But what you're telling
16 us is, from a capabilities standpoint, you expect the
17 community to have the capabilities regardless of what
18 you call the EPZ.

19 MR. SMITH: Yeah, and there's also
20 qualitative insights here, right? So the ten miles
21 was also based on an understanding that you would
22 include enough numbers of jurisdictions and, you know,
23 response agencies within that area so they could take
24 action within and outside that zone.

25 MEMBER BIER: One other question. In what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 fraction of cases, I mean, roughly, qualitatively, is
2 the EPZ just kind of proactive or precautionary?
3 Like, we're going to get you out of there just in case
4 there's a lot of contamination. And what fraction of
5 that is, nope, now you're never going to be able to
6 live there again. Do you have a sense of that?

7 MR. SMITH: Yeah, that is a great
8 question. And that is where you got to take a step
9 back and look at -- in EP, we're trying to do risk
10 management, okay? So, the accident has happened, now
11 we're trying to manage those risks. And so, we have
12 different strategies that we can employ,
13 precautionary, risk-informed, or dispersive.

14 Precautionary strategies are used when
15 there's a lot of uncertainty and consequences could be
16 high. And when you go back to the insights from the
17 Reactor Safety Study, remember the thinking was you
18 could have a release within 30 minutes, consequences
19 proving life threatening. So we took a precautionary
20 approach. But, when we look at the safety of advanced
21 reactors, small modular reactors, there's an
22 opportunity now to take advantage of risk-informed
23 strategies.

24 And so, we rely less on the emergency
25 planning zone in terms of implementing those actions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and more on the insights of what we understand what
2 could happen and we have to consider, you know, what
3 are the external factors. Maybe this is an event
4 that's happening in the midst of a severe seismic
5 event, what is the right action? It may not be the
6 appropriate action to say, everybody evacuate, when
7 you're putting them into more harm.

8 MEMBER BIER: One other comment. Even for
9 the large light-water reactors, long term relocation
10 is not without its own harms and burdens for the
11 population, even if not health related. And I have a
12 small study, I could share with people later, that
13 argues that possibly even the EPA protective act of --
14 action guidelines are too restrictive and that there
15 may be some people who would want to remain in an area
16 even that violates those guidelines.

17 And, you know, it's a tradeoff. You know,
18 you can cut radiation dose to the population lower by
19 relocating more people, but is it really net
20 beneficial? So I'm happy to share that or post it in
21 the record of today's meeting or whatever, it's a
22 published document, but.

23 MR. SMITH: Yeah, and this is an area
24 where we are very active within the federal family.
25 So there's a Federal Radiological Preparedness

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Coordinating Committee and that's where we all get
2 together to assist FEMA. We bring our risk insights so
3 that state and locals have the tools, the information,
4 the knowledge they need to make those risk-informed
5 decisions within the context of implementing the
6 protective action guides.

7 One example we saw during COVID is that a
8 few states raised their tags for evacuation because
9 they recognized that, if you evacuate and sheltered
10 people within community shelters, the risks were
11 higher, from COVID, than staying at home. Can we go
12 to the next slide?

13 Just a final point to emphasize design
14 information, risk insights -- which are very useful to
15 help us inform EP, to help us understand how we can
16 make risk-informed decisions, but, ultimately, the
17 effectiveness of the emergency plans independent of a
18 probability.

19 We have to deal with all the residual risk
20 of the facility, and this means recognizing that there
21 may be events, very low likelihood or consequence,
22 that we need to act on. But a key concept here is,
23 that doesn't mean you develop specific plans for those
24 worse case events. We have to understand the planning
25 concept here that even goes back to the 1970s and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 NUREG-0396 which is that, sometimes you may find
2 you're beyond your capabilities and you need to get
3 help from state and the federal government.

4 And that's part of our planning concept.
5 It's embedded in our national preparedness goal, it's
6 what we call the whole-community approach. And so, we
7 embrace this all-of-nation approach because it gets
8 very efficient, effective use of our resources. So,
9 the risk-informed performance based planning, we give
10 adequate protection of public health and safety even
11 for those very low likelihood events.

12 CHAIR MARTIN: I think this is a good
13 break point, right? We were like an hour behind,
14 maybe, or no? We're good?

15 (No audible response.)

16 CHAIR MARTIN: I just -- you know, looking
17 at the agenda and we're talking about accident
18 selection, and then --

19 MR. RECKLEY: I don't think it's quite
20 that bad.

21 CHAIR MARTIN: Okay. Good enough. So
22 let's break for 15 minutes, or 12 minutes? I know
23 that is short, but let's reconvene at 10:30.

24 (Whereupon, the above-entitled matter went
25 off the record at 10:18 a.m. and resumed at 10:30

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a.m.)

2 CHAIR MARTIN: Okay, it's 10:30, we're
3 back. And we're picking up with the slide that's
4 entitled Guidance on selection of accident scenarios
5 for demonstrating general site suitability under 10
6 CFR Part 100.

7 MR. RECKLEY: Okay, so this is Bill
8 Reckley again, I'll take this part. And again, this
9 is largely a summary of the vision for Reg Guide 4.7,
10 some of the thinking that went behind it. And that
11 leads to -- although we're pursuing technology-
12 inclusive approaches, we do still have a long history
13 of light-water reactors. So the question always comes
14 up, why are activities going forward continuing to
15 split. Light-water reactors, we'll do it this way.
16 Non-light-water reactors, maybe SMRs, we'll do a
17 different way.

18 We're not, in the guidance, saying that a
19 light-water reactor cannot pursue alternate
20 approaches. But, given the history, the
21 infrastructure, both on the regulatory side and then,
22 also, on the industry side in terms of codes and
23 standards, including the PRA standard that works a
24 little differently for light-water reactors, because
25 it was setup for different questions, if you will,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 than the non-light-water reactor PRA standard.

2 So, for all of that -- all those reasons,
3 we end up going forward, sometimes out of ease of use,
4 distinguishing between an approach for light-water
5 reactors and the approach for non-light-water
6 reactors. And that is true in Reg Guide 4.7 and the
7 consideration of population density.

8 So we'll go through, for light-water
9 reactors, both what we talked about largely already,
10 the determination or confirmation of the exclusionary
11 boundary and low population zone, and then the 20-mile
12 -- existing 20-mile distance out to which we consider
13 population density, an alternate mechanism to do that.
14 And then we'll just repeat for light-water reactors
15 using the licensing modernization project methodology,
16 or LMP methodology. And then a quick mention of non-
17 LWRs, should they not choose to use that approach.

18 So, I'll just go forward --

19 CHAIR MARTIN: Just real quick. The
20 premise that we've already kind of expressed earlier
21 in the meeting for all of this is the low likelihood
22 of failure by containment bypass. Now, you know, I'm
23 familiar, of course, with like, the SAMDA or SAMA, you
24 know, and those activities which can be used to show
25 that. And it occurs in the environmental report. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'm not familiar where it might show up more in a Part
2 50 context. I mean, certainly all the pieces are
3 there but, you know, when is that, kind of,
4 established by the application? It is only in the EI
5 -- ER, in the environmental report, or is it somewhere
6 else?

7 MR. RECKLEY: Under the existing structure
8 that we have, it would show up in a number of other
9 places. It would show up in the environmental
10 assessment and the SAMA analysis, it would also show
11 up in Chapter 19 which is where they summarize the
12 PRA. And that is going to, for light-water reactors,
13 the figures to merit are large release and core
14 damage, so you start to get into the surrogates,
15 traditionally, for light-water reactors, versus actual
16 dose calculations.

17 So that information would be there, it
18 would be considered. They'll have to show in Chapter
19 19, is the severe accident design features, that comes
20 out of the severe accident policy statement but it's
21 also the PRA, that would say what they do if there's
22 core damage in order to protect containment. It's a
23 soft regulatory area but, in addition to the physical
24 structure of a containment, a system, you're also
25 going to have severe accident management guidelines

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that are the operational side of what do operators do
2 to try to save containment, should you have a --

3 So, there are a number of areas where it
4 will show up on the plant design safety side, if you
5 will -- I don't like that term. But outside of the
6 environmental SAMA analysis, it'll all show up in
7 Chapter 19.

8 CHAIR MARTIN: Maybe you could state the
9 obvious. As we move to plants that credit functional
10 containment, it gets a little trickier about what all
11 this means, right? So, hopefully you touch on that.

12 MR. RECKLEY: We'll touch on functional
13 containment, because it and the licensing
14 modernization project go hand in hand. It really is
15 the LMP that kind of enables you to take better
16 advantage of the -- but we'll get into that, yes, we
17 will.

18 Okay, so this slide we've talked about a
19 number of times for traditional or light-water reactor
20 approach to confirming or determining the EAB, the
21 exclusionary boundary and low population zone, so I'm
22 not going to touch on it again. But, basically, it is
23 an assumed major accident radionuclides put into
24 containment. Containment will leak at a given amount,
25 that amount will be defined in tech specs, it'll be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 tested to show that that is, under those conditions,
2 the amount that it'll leak.

3 Now, with degradation and severe accident
4 studies, containments may fail later but, under this
5 assessment, that's the way it's done to calculate the
6 offsite dose. Next slide.

7 So, now we get into the population
8 density. This is the distance out to which the NRC
9 would look and do a confirmation that the population
10 density does not exceed 500 persons per square mile
11 out to a distance. As we talked about earlier,
12 currently, up till revision four of this reg guide,
13 that distance was established, by a generic
14 assessment, at 20 miles. But, based on feedback,
15 people wanted flexibility to maybe less than 20 miles.

16 And so, Reg Guide 4.7 defines this
17 methodology. It first says, you can assume the same
18 source term into containment as Reg Guide 1183 coming
19 out of risk-informed studies, NUREG-1465 and others.
20 That puts the radionuclide inventory into the
21 containment. But, as a distinction between this
22 assessment and the previous one on exclusionary
23 boundaries and low population zone, the applicant
24 needs to consider the containment performance in a
25 severe accident.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And that does not necessarily mean that
2 they have to assume containment fails, but they have
3 to do and show in the application how they considered
4 severe accidents. Under the severe accident policy
5 statement, they may have added specific design
6 features, they may have particular procedures to
7 address severe accident conditions that would, maybe,
8 justify not assuming a total failure of containment
9 but maybe a degraded containment compared to the tech
10 spec leakage values.

11 CHAIR MARTIN: We have a question by our
12 consultant, Dennis Bley. Go ahead, Dennis.

13 DR. BLEY: Hi, Bill. Isn't there also a
14 requirement that the applicant has to do a population
15 growth study for the life of the application?

16 MR. RECKLEY: They have to project it and,
17 this is from my recollection, we'll consider it out,
18 I think, five years. They -- the one thing that we
19 want to -- do make clear is that the 500 people per
20 square mile out to any distance that gets set, either
21 the 20 miles or this alternative, does not become a
22 requirement that they need to maintain, right? So,
23 ten, 15, 20 years from now, it might be higher in
24 certain segments. It's a siting evaluation, it does
25 not become a long-term requirement to maintain the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 population density --

2 (Simultaneous speaking.)

3 MEMBER HALNON: Bill, this is Greg. I was
4 going to butt in earlier, but I wanted to make that
5 clear that this is a one-time analysis for siting.
6 The evacuation time estimates, I think, requirement
7 for six years looks at population growth and whether
8 or not the EP, evacuation times and everything else
9 are still appropriate.

10 MR. RECKLEY: And those will be updated,
11 and Todd --

12 MEMBER HALNON: Right, those are
13 continuous, these are continuous issues. This is just
14 a one-time only.

15 MR. RECKLEY: That's right, this is an
16 initial licensing decision. So, sorry, Dennis, I
17 don't exactly remember. But I do remember we ask them
18 to show, I think it's five years that this would be in
19 place after the licensing decision. Something like
20 that.

21 DR. BLEY: Greg's comment did some further
22 clarification. Thanks.

23 MR. RECKLEY: Okay.

24 CHAIR MARTIN: Just a clarification. So,
25 after those five years, population increases, that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 okay. It's all underneath, kind of, the assumption
2 with the license that's --

3 MR. RECKLEY: Yes. Although, history
4 would show that, as it does that, questions arise.
5 And then you have to deal with it either in emergency
6 preparedness -- it may not require anything but it's
7 going to come up in conversation, right? It has --

8 (Simultaneous speaking.)

9 CHAIR MARTIN: It's all part of the
10 maintenance of the EP.

11 MEMBER HALNON: Those other processes in
12 a community that causes zoning board meetings, other
13 public and stuff that -- stuff comes into play in
14 additional to the all-hazards planning that the
15 containment does what the local --

16 MR. RECKLEY: And then you also have, in
17 addition -- we're not talking about them today, in
18 addition to the dose related criterias, like low
19 population zone or population density considerations,
20 you have security related ones, like owner-controlled
21 area that's going to define some area beyond. But,
22 Todd, did you want to --

23 MR. SMITH: One thing, and maybe somebody
24 can look this up, I do think, actually, the population
25 index was out of maybe 50 years?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: I think it's 20.

2 MR. SMITH: Twenty years? Yeah, I think
3 it's more than -- a little bit more than five. But,
4 yeah, you're exactly right. So then we account for
5 changes in the offsite conditions in the evacuation
6 time estimate --

7 (Simultaneous speaking.)

8 MEMBER HALNON: That's a 10 year -

9 (Simultaneous speaking.)

10 MR. SMITH: That's a ten year and then, in
11 between decennial censuses, every year the licensee
12 has to look at population increases and, if they
13 exceed certain criteria, then they update the ETE. It
14 also accounts that every ten years not just population
15 increases but changes in infrastructure.

16 MEMBER HALNON: And in my experience, it's
17 the licensee's responsibility to intervene in other
18 projects, such as a natural gas plant or a propane gas
19 plant or a proposed build of a nursing home right next
20 to their plant. The licensee has a responsibility to
21 maintain their EP program appropriate, which would
22 cause them to have to intervene in, potentially, a
23 public hearing on -- double zoning hearing or
24 something to that effect.

25 MR. RECKLEY: Yeah, there's two different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 things. One be, like, a pipeline which would be an
2 additional external hazard.

3 MEMBER HALNON: It would be an external
4 hazard, yeah.

5 MR. RECKLEY: And then the other one that
6 --

7 (Simultaneous speaking.)

8 MEMBER HALNON: I tried to give both
9 examples. We did intervene in a gas facility and we
10 also intervened in a nursing home that wanted to build
11 right next to us.

12 MR. RECKLEY: All right. So after
13 consideration of severe accident potential impact on
14 containment, again, it could be -- they could argue in
15 the application that that's addressed through measures
16 they have taken, both operational and design.

17 They will reach a leak rate from the
18 containment to continue the calculation, or the
19 assessment, and the dispersion to the atmosphere, into
20 the local populations. And then the alternative is
21 that the population density is less than 500 persons
22 per square mile out to two times the distance at which
23 the calculated dose to an individual is 1 rem over 30
24 days.

25 That was -- it may sound like an odd

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 number, we picked it for a number of reasons. One is,
2 the 30 days is the typical dose calculation under
3 licensing modernization, so we figured they were doing
4 it anyway.

5 Another one would go a little bit to the
6 societal measure. This is beyond, this is a lower
7 number than may be necessary for prompt protective
8 measures, but it starts to consider societal measures
9 such as relocation.

10 Not one-for-one, but in our thinking it
11 contributed. And as you look at the commission paper
12 we laid out that this number would contribute to
13 limiting the societal impact of relocations by having
14 the number of one rem over 30 days.

15 Next slide. So now we get into the non-
16 light water reactors and the concepts of functional
17 containment. And this is where we need to start the
18 sensitive to the terminology and the way we described
19 things changed.

20 On the top of this figure you'll see Reg
21 Guide 1.183 for light water reactors. There's assumed
22 to be core melt, losses of other, protections. Such
23 that you have a major accident and you put the
24 radionuclide mix into the containment. That's
25 typically called source term. Source term into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 containment. And then it's modeled, as it's shown
2 here, through the leak rate from containment and the
3 dispersion offsite.

4 When you go to a functional containment
5 concept you may have much less reliance on a last
6 physical structure. More reliance, for example, on
7 the codings within the individual TRISO particles for,
8 and surrounding graphite and the matrix.

9 So we change the way we address through a
10 functional containment to say, ultimately it is the
11 whole series of barriers that we're going to be
12 assessing. And the term functional containment starts
13 in the core, inside the kernel. And you take credit
14 for every barrier to its release.

15 And we call the source term what escapes
16 from the plant. And that may be, likely that's going
17 to be from a structure, like a reactor building. But
18 the reactor building may not be credited within the
19 assessment as a, nearly to the degree that can
20 essentially need tight containment.

21 So even when we are talking like the
22 source term it changes from the point of reference
23 being into the containment. And for functional
24 containment and LMP it changes to be a release from
25 the whole plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: So can you comment on
2 liquid fuels?

3 (Simultaneously speaking.)

4 MEMBER HALNON: Would that final barrier
5 just be re-labeled all the containment things going on
6 at the same time?

7 MR. RECKLEY: That would depend on how
8 that applicant wants to pursue their license. If they
9 want to approach it as a functional containment and
10 take full advantage of radionuclides being retained in
11 the salts, and the salt solidifying should you have a
12 break, and therefore we don't really need to put much
13 emphasis on the structure, they could pursue that
14 approach.

15 If they wanted to say, we are going to be
16 an essentially a leak rate (phonetic) containment,
17 they could take a more traditional approach, and we'll
18 talk about that going forward, they'll be challenged
19 because we don't have a Reg Guide 1.183 source term
20 from the salt reactor into a structure, they would
21 have to develop that.

22 But it's really up to the application to
23 a flexible approach. If they take a functional
24 containment, I think they would more likely do that
25 because they would be able then to take more credit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for the retention of the radionuclides in things like
2 the salts themselves.

3 MEMBER HALNON: So the first one in will
4 be an important --

5 MR. RECKLEY: Yes.

6 MEMBER HALNON: -- presence.

7 MR. RECKLEY: So if you go to the next
8 slide, Anders. This is just trying to slide --

9 MEMBER ROBERTS: Can you explain that
10 previous slide what a Reg Guide 1.183 release is?

11 Is there an intent to revise the reg guide
12 to cover all these different non-light water reactors?

13 MR. RECKLEY: No. Not at the current
14 time.

15 MEMBER ROBERTS: So what does that mean?
16 I thought the way this work is that there is an
17 assessment based on the PRA and the licensing basis
18 events and those would be risk sorted and there would
19 be some assessment and cliff-edge or defense-in-depth
20 to make sure it's a complete list, but is that what
21 you mean by Reg Guide 1.183 source term?

22 MR. RECKLEY: The Reg Guide 1.183 source
23 term is what we've talked about a number of times.
24 The major accident, a release from the fuel into the
25 containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The Reg Guide 1.233, which is the
2 licensing modernization, doesn't have the equivalent
3 of a source term, it includes the concept of a
4 functional containment and basically says, every event
5 that gets analyzed will be analyzed to see if it falls
6 into a category that has a release. Many will stop at
7 the, you know, the first barriers, the fuel doesn't
8 overheat. No release from the fuel into the coolant
9 or from the plant.

10 Some, the design basis events, beyond
11 design basis events, may include releases from a
12 system offsite. And there's would be evaluated by
13 each applicant, for each technology, for each event to
14 determine what the release is. We would not have an
15 equivalent of Reg Guide 1.183 that says, here's how
16 you do that.

17 MEMBER KIRCHNER: One problem that I see,
18 Bill, is that for the general public looking at this,
19 we have non-LWR designs using really conventional
20 metal clad fuel making a functional containment
21 argument, which is a lot different than the example
22 you gave of the TRISO.

23 How is the public going to be convinced
24 that they are provided equivalent level of protection,
25 starting with the siting, when probably their analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 will always show a source term much less than the
2 predicated worst case source term that goes into 1.183
3 for a large LWR?

4 MR. RECKLEY: I don't, I won't say it
5 won't be a challenge, but I think the argument in us
6 trying to explain it will be something like, here's
7 how this is done for the existing fleet. We took
8 information from Three Mile Island, how much
9 radionuclides actually made it into the containment?

10 We dove on that knowledge, we updated our
11 guidance. And that was a real event, real
12 assessments. And this is the result in dose.

13 Now as you go to, let's say molten metal,
14 liquid metal reactors, and you go to the public and
15 say, here's we're using a functional containment
16 analysis and we still have a structure, but our
17 analysis shows this is the hold up within the sodium.
18 It's within the liquid metal itself.

19 MEMBER KIRCHNER: Or the salt.

20 MR. RECKLEY: Less, less goes into the
21 containment than does for a light water reactor. But
22 we model what goes into the containment and then the
23 release. But it's less than a light water reactor
24 because it's retained by another system that's
25 included within the functional containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'm not saying it won't be a challenge to
2 try to explain that, but that will be what we have to
3 explain.

4 MEMBER PETTI: I think that personally I
5 think the challenge comes down to the database to
6 prove it where, you know, a lot of LWR have spent lots
7 of money on that. There's lots of data on the TRISO
8 and the data reprogramming.

9 But it will be useful to see in metal fuel,
10 there have not been tests specifically focused on what
11 the source term is. Can you put together what they
12 have, and I've seen some of the reports, is that
13 sufficient enough to make a licensing case. And
14 that's --

15 MR. RECKLEY: And we're not going to weigh
16 in here --

17 MEMBER PETTI: Right. Right. Right. Not
18 here.

19 MR. RECKLEY: Right.

20 MEMBER PETTI: But that's where it's going
21 to be I think.

22 CHAIR MARTIN: But, you know, as we have
23 talked to some of the design standards, you know, I
24 can't help but think that there should be a functional
25 containment topical report, but really it should be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 all encompassed into a mechanistic source term. And
2 of course I've seen, those have been submitted, but
3 doesn't it point to kind of new requirements, you
4 know, that go all the way back to the inventory. And
5 all the barriers in-between. Those things should be
6 pretty hefty documents.

7 MR. RECKLEY: And address the
8 uncertainties and the available data. But yes, what
9 you, what the agency will see will be a mechanistic
10 source term doc not a functional. It's the same
11 thing, but it's a functional containment talk.

12 CHAIR MARTIN: Right. Right. Which it
13 equates to.

14 MR. RECKLEY: Right. Okay, Anders. So
15 this slide is basically showing the same thing. Going
16 back to the bowtie, and just trying to deliver a
17 message that, again, we're changing the reference
18 point for the top level event, if you're describing it
19 using a bow tie, from core damage to release.

20 And it may not affect the design, but it
21 might affect how things are discussed. And if you use
22 the same high plant level assessment, then prevention
23 would go to what prevents the release.

24 And that would include functional
25 containment on the prevention side of the ledger, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 siting emergency preparedness. Other things might,
2 would still exist on the mitigation measure, but it
3 might just change the way the conversation is held.

4 The other focus on mechanistic source
5 term, and technology inclusive approaches, is we start
6 to talk about safety functions versus specific
7 cladding, pressure boundary containment. They don't,
8 all the technologies don't have those same things and
9 so you start to talk about safety functions or
10 reactivity control for cooling and for containing the
11 radionuclides. So just as we move forward, it's the
12 same concepts it just, it changes the conversation
13 somewhat.

14 Next slide, Anders. So that then goes to
15 what would be the approach under Reg Guide 4.7 for
16 addressing the exclusionary boundary and low
17 population zones for a non-light water reactor using
18 licensing modernization, or LMP. And what it says in
19 Revision 4 to Reg Guide 4.7 is, that assessment uses
20 the design basis accidents.

21 Which again, go back to the previous
22 discussion we had with the light water reactors. It
23 is a test of your safety related equipment to control
24 a release to the reference values at the exclusionary
25 boundary for low populations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so this is just reflecting what's in
2 the reg guide. That it's the design basis accidents
3 under LMP that you assess to show you're less than the
4 25 rem over two hours at the EAB or over the month or
5 the duration of the release for the low populations.

6 MEMBER KIRCHNER: That's the inconsistency
7 I was trying to highlight though, Bill, in my
8 estimation that for LWRs you don't limit yourself to
9 a design basis event, you assume you have a major loss
10 of, a major core melt. One would hope that all the
11 DBEs for any design would calculate through Chapter 15
12 and see no major release.

13 MR. RECKLEY: Right.

14 MEMBER KIRCHNER: So that's a perception
15 problem.

16 MR. RECKLEY: It is a delta. The logic is
17 that what you do under Reg Guide 1.183 and that
18 approach is to test your last safety related barrier.

19 MEMBER KIRCHNER: Right.

20 MR. RECKLEY: That does assume, the way
21 it's laid out, you had failures of other safety
22 related equipment in order to get there.

23 MEMBER KIRCHNER: Right.

24 MR. RECKLEY: But it is in the end a test
25 of your last safety related barrier. And that is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 difference from LMP because you're able then to look
2 at the performance of all your safety related SSCs
3 going into the assessment of the design basis accident
4 to show that the release is less than the reference
5 values.

6 It is a difference, and we get into this
7 constantly on LMP, that in one area there is a
8 perception, and it may be true, that you're somewhat
9 less conservative. But the reason for that, at the
10 DBA stage, is because you have a much more structured
11 assessment of the beyond design basis events than what
12 you do for the light water.

13 That the argument of the DBA, for existing
14 light water reactors, and it's moderated over the
15 years, as we've taught, because you had to do
16 responses to severe accidents and come up with SAMGs
17 and do various things to address issues as they've
18 arisen, but the concept still is there that the DBA is
19 a very conservative event meant to bound other more
20 significant events. That you don't, or at least in
21 the early part of the industry, you didn't assess.

22 And LMP, again, the argument is it's more
23 systematic approach over the whole range of accident
24 frequencies and therefore you might be more
25 conservative here, but you're less conservative at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 DBA, but more conservative in the BDBE, beyond design
2 basis event category, and you end up in a similar
3 place.

4 MEMBER HALNON: So, Bill --

5 MR. RECKLEY: It's just a redistribution
6 of assessments.

7 MEMBER HALNON: -- one of the issues that
8 we have for public perception, and the ability to
9 drawback on the conservative nature of today's
10 analysis that we use for large light water is sort of
11 the letter that you used, and I'm not saying it's
12 wrong I'm just telling you this is how it works. And
13 it worked the same way during our simulator
14 evaluations when we had tests.

15 You mentioned you had to have a lot of
16 safety related equipment fail to get there. And
17 that's not, that language makes you believe that
18 safety related equipment is going to fail within just
19 your single failure that you assume.

20 It's in likeness to the simulators where
21 an instructor wants to get to core melt so you have to
22 get to a general emergency so they started creating
23 all these crazy scenarios to get, finally gets them
24 there. Five things are tagged out on separate trains,
25 your already diesels, two diesels are pulled apart.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Something that will never happen based on the
2 administrative controls, tech specs and other things.

3 So it's sort of negative training. You
4 start believing that that happened to get you there.
5 It would be much better if you just said, we're going
6 to put half the cooler in the sump and measure that
7 source term and let it get out of the containment then
8 say that I'm going to have to have three trains of
9 this panel, one train of that panel.

10 And that has caused, at least in my mind,
11 and I know others, that these unreal sequences can
12 occur. And I think we said earlier on that these
13 access sequences meant to, they're all hypothetical
14 and we create them.

15 So I would just caution us to say, you
16 know, you have to have a lot of safety related for
17 them to fail because that provides a negative
18 connotation on the safety related equipment and our
19 ability to be on the left side of this scope. That
20 was just a comment.

21 MR. RECKLEY: And so, Slide 29, what we're
22 trying to show is under this assessment for non-light
23 water reactors how do you reach the alternative to the
24 20 miles per 500 persons per square mile population.
25 And so, Reg Guide 4.7, the revision that's been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 issued, calls out that those you look at under LMP,
2 the design basis events and beyond design basis
3 events, so that's taking you in frequency range from
4 10 to the minus 2 down to 5 times 10 to the minus 7 in
5 the categories with, again, the emphasis that 5 times
6 10 to the minus 7 is not a hard number.

7 So that is what we ran through in the
8 commission paper, and in ultimately, it is
9 incorporated into Reg Guide 4.7.

10 MEMBER ROBERTS: And one difference
11 between Reg Guide 4.7 and the EPZ Reg Guide 1.242 is
12 the statement in the reg guide about treating of
13 uncertainties. The EPZ reg guide says you need to
14 consider probabilities of events, you know, after
15 consideration of defense-in-depth considerations and
16 cliff-edge effects.

17 There is no similar wording in this reg
18 guide so I was wondering why. One theory would be
19 that beyond PRA requires it. And so, if beyond PRA
20 requires you to look for cliff-edge effects and
21 defense-in-depth assessments and maybe screen in
22 scenarios but otherwise be screened out of frequency.
23 And it's already done as an end poach, then as the
24 question why is it, and why not the other. I've
25 already gave a comment on what the intent was.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RECKLEY: I don't know that we had an
2 intent. I think it is, as you described it, that the
3 Reg Guide 4.7 was reflecting the use of LMP, which
4 includes those directions. So I believe, I don't
5 recall any conscious thought to leave those out from
6 here. It was just that they were already included.
7 The considerations of uncertainties and the
8 consideration of (audio interference).

9 MEMBER ROBERTS: Okay, thanks. And your
10 last few slides talk about defense-in-depth and cliff-
11 edge effects?

12 MR. RECKLEY: Right.

13 MEMBER ROBERTS: I'll reserve my questions
14 for then.

15 MR. RECKLEY: Okay. So then, Anders, go
16 to the next slide. So then the last thing addressed
17 in the regulatory guide 4.7 is for non-light water
18 reactors that may not use LMP or that kind of
19 approach, maybe use a more traditional approach.

20 This goes to the discussion we had
21 earlier. They are allowed, or not allowed. The
22 guidance includes higher level instructions on how
23 that might be done. Largely it goes that they could
24 go back to a more light-water reactor type approach,
25 include a source term (audio interference) containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 structure, and then model it.

2 As I mentioned earlier, the guidance says
3 that they could follow that approach. The challenge
4 in that approach is that we don't have the equipment
5 in NUREG-1465 or the TID or, for those other
6 technologies but they could pursue it.

7 Anders. That really is the summary of how
8 the events are looked at in terms of the Part 100
9 siting. There's no additional questions on that?

10 Again, you can look at Reg Guide 4.7
11 Revision 4 and the SECY paper. What year did we do
12 that? Anyway. The reference SECY paper. 1845 I
13 think.

14 MEMBER KIRCHNER: Is it your sense, I know
15 it's going to be application specific site, site
16 specific, but given the fact that people are talking
17 about re-purposing coal plants and they're existing
18 infrastructure, I'm not thinking right now of Wyoming,
19 but I'm thinking of other areas maybe more on the
20 eastern side of the country. Is it the population
21 density calculations or estimate that's going to
22 dominate, you think?

23 MR. RECKLEY: It can contribute. And if
24 you go back to the original paper, we looked at
25 population density from two perspectives.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 If you're using a micro-reactor to do an
2 industrial site, let's say a mining operation or a
3 small village, oddly enough the 500 people per square
4 mile might be the village.

5 MEMBER KIRCHNER: Right.

6 MR. RECKLEY: So you would have to put the
7 reactor outside the village. So we were looking at it
8 from that perspective. That's one way you can exceed
9 500 people per square mile. Is it a small spot?
10 Small but concentrated spot?

11 And then the other way would be, in the
12 more typical way, in the lower 48 if you will, which
13 is the use of them in something like to replace the
14 fossil station. Well a lot of older fossil stations
15 are going to be closer to population centers than are
16 large light-water reactors.

17 And so, if you can change that from 20
18 miles to some lower number you may be able to use that
19 fossil station, propose to use it, whereas, and again,
20 I go back to the Oak Ridge assessments that they did
21 back when we did the paper, and continue to do, to
22 show that taking the 20 miles out and using a
23 different number does allow at least other sites to be
24 considered that would be excluded.

25 So more questions? We can jump into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 defense-in-depth. This is another interesting and
2 kind of philosophical and long history kind of topic.

3 I put up two references that are useful,
4 I believe. The first is NUREG/KM-0009 which is kind
5 of a knowledge management collection of the NRC and
6 AUCs approach to considering defense-in-depth.

7 The other one listed here is the
8 International Atomic Energy Agency, IAEA, has
9 incorporated defense-in-depth concepts into a lot of
10 their design guidance and operational guides.

11 And the base documents, on which a lot of
12 that is based, is INSAG-10 and INSAG-12. So, just
13 again, useful references as we get into this a little
14 bit. We'll start to talk about what was brought up
15 earlier, the five levels of defense-in-depth in the
16 IAEA documents.

17 So next slide please. So I know this is
18 too much to read on the slide, but it is just meant,
19 actually, to reinforce that it's not an easy
20 assessment to consider in that the guidance in both
21 areas, the LMP guidance documented in NEI 18-04, and
22 the IAEA guidance, starts to bring in the fact that
23 you need to consider kind of a holistic view, plant
24 design, plant operation, plant programs when you're
25 doing this assessments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So NEI 18-04 does that specifically by
2 having plant capability defense-in-depth. This is
3 like redundancy, diversity and actual systems
4 performing safety functions.

5 And then also programmatic defense-in-
6 depth. I have a system, I like to bring up that as
7 we're looking at this it might be a matter of do I
8 need a guard pipe around my primary pipe. And the
9 decisions that people are going to make is, I can put
10 in a guard pipe or I can survey my single pipe without
11 the guard pipe more often perhaps. And that's, you
12 know, that's something for them to consider, along
13 with the uncertainty. Or I might do both, depending
14 on the uncertainty.

15 So those kind of things you have to look
16 at in total. How much safety margin do I build in?
17 Well again, how much uncertainty am I trying to
18 address by building in safety margin.

19 And then under LMP those things are traded
20 back and forth using the PRA and other parts of the
21 methodology, which also includes, and we'll talk about
22 it later, the integrated decision-making process or an
23 expert panel, engineering judgment, however you want
24 to characterize it to basically in the end say, yes,
25 this is reasonable, and then we can proceed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR MARTIN: Let me break in real quick,
2 we have a question from Dennis.

3 MR. RECKLEY: Yes, Dennis. You're muted,
4 I assume. We're not hearing you.

5 DR. BLEY: Sorry. I clicked on it, it
6 just didn't clear.

7 Yes, Bill, the NEI 18-04 sketch that's up
8 here I always did like, but had some questions came up
9 recently as we were talking, and a couple of issues
10 arise for me. And I wonder if you had thought about
11 them and how you think the staff will deal with these
12 when they start reviewing defense-in-depth arguments
13 and submissions.

14 This process, on one hand, is very
15 complete and looks at almost everything I can think
16 of. And urges you to be expansive in applying it. On
17 the other hand there is a sentence early on, in the
18 text I think, that says, eh, this is an iterative
19 process, and then it doesn't talk more about that.

20 Some years ago I was familiar with a book
21 on ship design that talked about a design spiral, but
22 you keep revisiting the issues of design as you go
23 around the spiral in that iterative way.

24 When one reads the text supporting this
25 diagram, it's possible to read it as saying all of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 these things apply after you've selected the LBEs.
2 And I hope that's not the intent.

3 I hope the intent is that we keep
4 revisiting this all along the design process until we
5 get to a final stage because that issue we talked
6 about earlier of, you know, starting with a clean
7 sheet of paper and thinking of all the things that
8 might be there that we haven't thought of ought to
9 arise again and again as your knowledge about aspects
10 of the design, the chemistry, the physicals evolve.
11 Can you speak to that at all?

12 MR. RECKLEY: Yes. And I think it's true
13 that it's considered to be iterative all the way
14 through the processes. Now the odd part is, me, as
15 the regulator, get involved in a certain place.
16 Right?

17 And so for a combined license application
18 that should be near the end of all the iterations.
19 Okay? That's not to say there won't be lessons
20 learned and changes that have traditionally been, but
21 it should be more or less the designer has gone
22 through all those iterations.

23 What we're actually seeing now, given that
24 the two leaders under the advance reactor
25 demonstration program are going construction permit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 operating license, is we're seeing a little more of
2 that iteration because of the construction permit
3 stage. It can be a little less defined, a little less
4 justified.

5 For example, even, gosh, there is a focus
6 initially on the internal hazards. And some of the
7 uncertainties and additional analyses for external
8 hazards will come later at the OL stage. And
9 introduces some risk for the applicant, but that's the
10 way the iteration is working between the CP and the
11 OL.

12 But the short answer is, Dennis, it should, from
13 the designer standpoint, be iterative all the way up
14 until they reach their conclusions that they're
15 putting in the applications. From the regulators
16 point of view we'll see that in different places
17 depending on what the application is.

18 DR. BLEY: Okay.

19 MR. RECKLEY: And we're seeing that in
20 real time right now.

21 DR. BLEY: You can audit some of the
22 supporting materials that were developed along the way
23 should we come convinced that this has been un-
24 thoroughly.

25 MR. RECKLEY: Right. And then from a real

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 practical matter, right, they don't want to be
2 iterating on things that are, I'll use an old term,
3 almost nonreversible, right?

4 You don't want to do something that has
5 you have to tear up the base matt if you were raw,
6 right?

7 (Laughter.)

8 MR. RECKLEY: So you want to do iterations
9 also dependent on the application you're making and
10 the flexibility you're going to have to adjust to
11 whatever the iteration might show. So you might feel
12 a little more comfortable if it's putting in a bigger
13 pump, but it's not going to be something you want to
14 pursue if it's redoing civil structural --

15 DR. BLEY: Okay. And I guess the issue
16 comes up when you read some of the language it says
17 here, we truncate all scenarios below a certain
18 threshold. But before one gets to that point I would
19 have hoped you were being very thorough in your
20 searches so that you have some comfort that you've
21 already looked at very unlikely but could be very bad
22 if they occur.

23 MR. RECKLEY: Right. And we'll address
24 that a little bit as we get into the topic of cliff-
25 edge. But also, and Anders, please weigh in. Under

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the PRA standard you need to have a rationale for
2 where you're making those decisions that I don't need
3 to consider that further. Anders?

4 MR. GILBERTSON: Yes, this is Anders
5 Gilbertson and staff. Yes. And that, you know, that
6 rationale, and when you're looking at the requirements
7 in the non-LWR PRA standard and how you apply those
8 judgements, you know, there are a set of what
9 essentially are the most qualitative screening
10 criteria that can be used as a matter of analyzing
11 your PRA. So not, it's a matter of constructing your
12 PRA if you will.

13 They're qualitative and there is some sort
14 of more semi-quantitative, qualitative and then
15 quantitative screening criteria that you can apply.

16 So if you imagine the range of potential
17 hazards that you can look at, you know, clearly some
18 of those are going to be, have a more qualitative
19 justification. Something that's more akin to a
20 plausibility argument, if you will. There's different
21 words that you could use to characterize that, but
22 that's generally how I kind of think of it. But yes,
23 that's, it will be a range of justifications.

24 DR. BLEY: Okay, thanks. And I guess one
25 of the recent applications we look at, the applicant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 at least convinced me that they were very, very
2 thorough in looking for things that might take away
3 from the assumptions of their design. And one
4 includes things that would show up here in your
5 defense-in-depth analysis.

6 MR. RECKLEY: All right. So I think that
7 that basically gets the message on this slide. You're
8 looking, the whole intent of defense-in-depth is
9 you're looking holistically. And it's including,
10 under both approaches, things like surveillances, the
11 role of operators, redundancy and diversity in the
12 planned systems, and so forth.

13 Next slide.

14 MEMBER ROBERTS: So, just an extension of
15 Dennis' question. Is there a frequency cut-off at
16 which you stop looking for defense-in-depth or cliff-
17 edge effects or is it all qualitative and more of a
18 deterministic thought process of when do we stop?

19 MR. RECKLEY: I would answer that, that
20 again, once --

21 DR. BLEY: This is Dennis Bley. If there
22 is still talking going on I've lost it out here.

23 MR. RECKLEY: Dennis, we can hear you.

24 MR. GILBERTSON: Yes.

25 MR. RECKLEY: Okay. All right, so the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 staff can try to contact Dennis I guess. Okay.

2 So, the answer to that, I think is that
3 defense-in-depth decisions ultimately need to factor
4 in all of those things. And as opposed to saying
5 there's a cutoff, at which I don't need to consider
6 defense-in-depth, the way it typically works is at
7 that area, this 10 to the minus 7 kind of range, that
8 you're really calling on the integrating decision-
9 making process where the expert's panel to make the
10 determinations, right? But the higher numbers, 10 to
11 the minus 5, 10 to the minus 6, the PRA is telling you
12 kind of what you needed in order to get that number.

13 But as you get near that 5 times 10 to the
14 minus 7 under LMP, the reason we emphasize time and
15 time again it's not a hard line, is because that's
16 where the engineering judgment really needs to come
17 into play. Is there events that are right below that,
18 what are the uncertainties, is there a cliff-edge such
19 that one of those events is lying beneath that value,
20 isn't like normal distribution but it's a sudden
21 change. And we'll get into that with the definition
22 of cliff-edge.

23 So the short answer is, there is not a
24 firm cutoff, but as you're looking in that range, 10
25 to the minus 7 area, it's historically been identified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 as diminishing returns if you will. And so I don't
2 need to take major measures to address the events that
3 come below. Anders, go ahead.

4 MR. GILBERTSON: Yes, this is Anders
5 Gilbertson with the staff. I was just going to add
6 that in terms of when you're developing the PRA if the
7 features that you have in the non-LWR PRA standard
8 would, generally are going to go much below the sort
9 of threshold or cutoff that Bill is kind of alluding
10 to here as a matter of defense, decisions about
11 defense-in-depth.

12 You have requirements that say you need to
13 look at the conversion of your PRA results as you go
14 down in lower and lower request numbers. If I go down
15 a decade in truncation of my cut sets and my event
16 sequences, do I all a sudden get a spike in my risk.
17 Okay. So it's not converging to something.

18 So, and then of course when you're looking
19 at it through LMP, when you're looking at event
20 sequences below that 5 to the minus 7, the notion is
21 still that you're retaining those in the PRA model.
22 So they're not disappearing, they're not going away,
23 they're still there for exactly that purpose of
24 looking at those cliff-edge effects.

25 MEMBER ROBERTS: Right. The LMP document

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 does not imply a lower threshold for cliff-edge as
2 depths assessments. But we got our topical report
3 with a proposed in the lower cu-toff and I was
4 wondering whether that's appropriate or whether that's
5 something that, you know, while you institute that you
6 might be cutting off something that would otherwise be
7 picked up.

8 MR. RECKLEY: And then this was raised
9 earlier. The other thing to keep in mind is, as
10 you're looking at the plant design you might actually
11 even use different levels than if you're looking at
12 operational society, even including emergency
13 preparedness because you might reach a point to say,
14 the external hazard, I don't need to, hypothetically
15 I don't need to consider a hazard above this because
16 in emergency planning space it's already a bad day,
17 I'm not going to get that much extra from adding
18 distance to the emergency planning.

19 That's not to say that same cutoff would,
20 by definition, by the same cutoff that you're using in
21 plant design. That might go to a higher acceleration
22 saying in the plant design I have to, either in
23 probability or in actual physical gram acceleration
24 use a bigger number.

25 You're looking at the barriers, again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 kind of holistically, but you're also looking -- and
2 the staff that are looking at each barrier is looking
3 at it from their own point of view -- at what's the
4 point of the barrier? And there might be differences
5 in how it's looked at. That might add complexity to
6 the situation, but it's the reality, I think.

7 MEMBER HALNON: Bill, one other question.
8 We're getting applications in with a statement that
9 there I no operator action required for responding to
10 licensing basis events. And they kind of waived that
11 flag saying, see how unimportant the operator is. But
12 they're clearly included in the defense-in-depth.

13 So can you comment on how that is viewed
14 relative to responding to the license basis events and
15 no operator action required?

16 And I'm assuming they're just thinking the
17 transient piece of it, but just --

18 MR. RECKLEY: Well, yes, I'm not involved
19 in the actual reviews of what we're, I haven't right
20 now. But I've been in the hypothetical discussions
21 for a long time. And it does range from a fairly
22 recognizable approach that we have now, licensed
23 operators doing actions in response to transients, to
24 operators not required to do anything but they may be
25 there for defense-in-depth. And you start to hear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 arguments that do the, we don't need operators even
2 for defense-in-depth.

3 So that will be up to the applicants to
4 try to justify the, and I'll agree, I think maybe it
5 was behind your question. The great thing about
6 operators is they offer flexibility. Right? A SSC is
7 going to do what the SSC is going to do. A person can
8 do what a person can do, and they also can think what,
9 that I might need to run out and get the battery out
10 of my car, right? There is not an SSC that's going to
11 do that.

12 MEMBER HALNON: Well, and the question
13 really comes down tom, can I credit, can I make that
14 statement that there is no operations required,
15 operator actions required, and then still take credit
16 for operator actions in the required defense-in-depths
17 portion of my discussion?

18 I mean do those two, can you make those
19 statements at the same time?

20 MR. RECKLEY: And again, we're getting
21 ahead because this is, you know, what we'll get into
22 perhaps down the road with antonymous operations and
23 things that we're not willing to --

24 MEMBER HALNON: Willing to go to that now,
25 yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RECKLEY: -- to predict how that goes.
2 But from my point of view, once you've built in an
3 assumption that the operator is there for defense-in-
4 depth, you are at least assuming that the person is
5 there. And it's reasonable to assume that the person
6 will do the action. Whether they're licensed or not.
7 That they have a ability to do the thing. And so you
8 would be held, is my own projection of how that would
9 --

10 MEMBER HALNON: I guess that's going to be
11 an ongoing discussion --

12 MR. RECKLEY: Yes.

13 MEMBER HALNON: -- and to what extent can
14 you say no actions are required by the operator. But
15 in Level 2 of defense-in-depth there are certainly, in
16 the EP portion they've got to be there because there
17 --

18 MR. RECKLEY: Right.

19 MEMBER HALNON: -- it's got to make a
20 decision. Okay, Bill, we can move on. Thank you.

21 MR. RECKLEY: Okay. So this goes back to
22 the same discussion we were having that defense-in-
23 depth, depends on your context, historically reviews
24 this language where prevention was what prevented core
25 damage. IAEA INSAG-12 kind of includes that kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discussion they talk about. Although they use the
2 levels, they talk about these levels being preventive
3 and these levels being mitigated.

4 Reg Guide 1.174, in terms of the guidance
5 used to assess changes, this is for operating plants,
6 changes the licensing basis information, also uses
7 this same general terminology. It's not critical to
8 the discussions but it's just, in the back of your
9 mind if someone is saying, you know, it's a prevention
10 or mitigated function, this is the context.

11 The other context that it comes up is in
12 particular areas. Because regulations related to fire
13 protection, regulations related to security have
14 specific requirements for defense-in-depth for those
15 particular areas. You know, whether it be detection
16 and delay or detection and extinguishing the fire, for
17 example.

18 So, whenever you're talking about defense-
19 in-depth you just have to understand the context that
20 the conversation is going. You can imagine after
21 however long we've been at this, 80 years, there is a
22 lot of different context in how it can come up.

23 Anders, go to the next slide. This is
24 basically the IAEA approach. This figure is out of
25 one of the reports that's there on the slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But this does, this is the generally
2 approach in NEI 18-04 licensing modernization. And it
3 does change the discussion a little bit from that
4 previous context. Which is, there's not as much
5 discussion of a top level event. And defense-in-depth
6 is basically assessed by the fact that things you do
7 for design in normal operations are meant to prevent
8 an AOO. Anticipated Operational Occurrence.

9 If you have an issue and that didn't work,
10 the mitigation of the anticipated operational
11 occurrence is meant to prevent the design basis. And
12 the design basis event is supposed to prevent the
13 beyond design event.

14 And as was said earlier, if you have
15 significant issues and a failure of all those systems
16 such that you projected you would have a significant
17 offsite release you can go to Level 5, which brings in
18 the emergency preparedness actions, the ability to
19 tell public, hey, shelter, evacuate, whatever, is the
20 protective action under Level 5.

21 And so you start to get a different
22 assessment. And if you look at NEI 18-04, Chapter 5,
23 that goes through defense-in-depth, it has this kind
24 of a logic and this kind of a discussion. And then
25 brings in other assessments, like part of the logic is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 also looking at the cumulative risk measure under LMP.
2 This is the NRC safety goals.

3 And the fact that you should not be
4 relying on a single feature for all your levels,
5 right? So if the, if you're taking credit for a
6 feature under anticipated operational occurrence, even
7 if it's very, very, reliable, you shouldn't be
8 carrying that one feature to protect you against
9 design basis event, beyond design events as well. You
10 have to have some kind of diversity across the five
11 levels.

12 CHAIR MARTIN: Is it spelled out in NEI
13 18-04?

14 MR. RECKLEY: Yes. These bullets are
15 basically taken right out of the guidance.

16 CHAIR MARTIN: I got.

17 MR. RECKLEY: We might have had one
18 application where they might have, probably the last
19 of it. But we'll look at that.

20 Well even historically, when you look at
21 defense-in-depth and you look at passive systems
22 there's been questions about how much you can rely on
23 them. So this is the guidance, there will always be
24 challenges and twists and turns to how it's
25 implemented.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Another question that has come up, and
2 it's been in the background, I don't think we've put
3 black and white to paper to actually definitively
4 answer is the concept of an inherent characteristic,
5 right?

6 So we played initially with trying even to
7 define that. There is some definitions floating
8 around. But it might be feasible to say, if it's an
9 inherent characteristic, meaning this is the physics,
10 there is no one, I'm going to exaggerate, there is no
11 uncertainty here, then maybe you don't need additional
12 measures beyond that. But that will, that will play
13 out when we see technology is probably than the ones
14 we're looking at in the current day.

15 So next slide, Anders. The next couple
16 slides are just basically some background on cliff-
17 edge, as has been mentioned a couple times. NEI 18-04
18 caused this out.

19 Now if you look at the literature there
20 was very little discussion of cliff-edge effects
21 before Fukushima. And then for obvious reasons after
22 Fukushima. And water topping the tsunami wall there
23 was a lot of discussion of cliff-edge effects.

24 So IAEA, after Fukushima added to the
25 safety standard 2/1, the design of nuclear power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 plants, this definition, which is a fairly standard
2 definition of cliff-edge effect, is basically it's a
3 major change to plant conditions as a result of
4 relatively small change in the parameter, like a flood
5 level. And then that's reinforced in the IAEA
6 guidance related to external hazards.

7 We start to bring in, and we'll get into
8 the discussion, the cliff-edge effect beyond looking
9 at probabilities and so forth, is the concept of
10 available physical margin. So how much margin do I
11 have before that flood actually causes that dramatic
12 change, for example.

13 Next slide. So these are all very similar
14 definitions, as has been mentioned. One action that
15 the NRC did take after Fukushima was the mitigation of
16 beyond design basis events. 50.155 of the flexible
17 mitigation strategies just basically says you'll have
18 to address a particular cliff-edge effect. And that
19 is a beyond design basis external hazard, flood or
20 seismic.

21 And ensuring that should that event cause
22 a loss of electrical power and loss of availability of
23 a heat sync, that you'll have some flexible
24 capabilities to address that for a given period of
25 time. So this is, in a way, a regulatory approach to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a particular cliff-edge effect.

2 Next slide. Then within the licensing
3 modernization, as has been pointed out, both NEI 18-04
4 and the non-PRA, non-light water reactor PRA standard
5 talk, and they're not in great detail but basically
6 bring up the topic that you need to look at potential
7 cliff-edge effects below the threshold. So again,
8 reinforcing 5 times 10 to the minus 7 per plant year
9 is not a hard and fast cutoff, look below that number.

10 As Anders said, not only for the conduct
11 of the PRA but to see if there are event sequences
12 that might identify as a cliff-edge effect. Then the
13 other place it shows it, and this goes to what I was
14 mentioning earlier, the place you really get into
15 these discussions is the expert panels, the integrated
16 decision-making process. What should we do about it.
17 And that's going to get into the discussion of how
18 much available physical margin do we have, what is the
19 actual frequency, and so forth.

20 CHAIR MARTIN: Me, I'm cutting in here.

21 MR. RECKLEY: Okay.

22 CHAIR MARTIN: At the time I read the
23 statement about, to confirm, there are no cliff-edge
24 effects. I'm bothered by that statement because it's
25 not a proactive statement about searching, it's more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of an induct, it sounds like more of an inductive
2 approach. I am proving something doesn't exist.

3 I mean, it kind of leads to kind of
4 another question. We don't have the guidance on how
5 to search. Now granted, when you're talking about
6 internal events, external events, you know, security
7 events, I mean, the diversity of possibilities is
8 extensive. But, you know, taking a step back it
9 should be a proactive activity. It should be an
10 afterthought where you are proving a negative because
11 it's just too easy to kind of go, well I looked at
12 that, looked at that, like they checked box, gone.
13 And I've written something up, and you know.

14 It's residual risk is that last layer. It
15 should get as much attention as any other layers as
16 far as, you know, the development of the safe case and
17 the review of the safe case. But, like I said, I'm
18 reacting to the negative the way it's written there.
19 But it appears there and maybe a couple other places.

20 MR. RECKLEY: Right. And I can, I was
21 there when we were writing this stuff, but we were, I
22 wouldn't over read it. I think what we were trying to
23 do was to develop the guidance to say when you needed
24 to take an action and therefore it might be worded the
25 way you're saying, which may not be optimum.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But I've looked at it. The hazard, from
2 our point of view, we don't need to take an action so
3 that's why it is worded that way. It takes something
4 like a volcanic hazard that you might look at and
5 basically say, yes, that's in our list of external
6 hazards we have to consider. But where my plant is
7 located I don't have to, I know there is not a cliff-
8 edge effect for a volcanic hazard for this location.

9 It might be different, I think an area
10 that you guys are likely to see, to be honest, is in
11 seismic, seismic historically is not really a cliff-
12 edge, but if you introduce something like a seismic
13 isolator that protects you up to a certain point, and
14 then a seismic event that exceeds that might actually
15 shake the plant more than the isolators can address,
16 than that might be a cliff-edge. Whereas normally the
17 seismic, and I'm not an expert so I'm going way off,
18 but it's not been traditionally considered a cliff-
19 edge, right?

20 CHAIR MARTIN: Obviously seismic has
21 gotten a line sheer of intention on --

22 (Simultaneously speaking.)

23 MR. RECKLEY: It is a major area that we
24 look at. I'm just --

25 CHAIR MARTIN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RECKLEY: -- in this particular
2 context it gets looked at a lot, but I don't think it
3 has historically been characterized as cliff-edge
4 because the fragility of equipment has been modeled
5 the way it, however it's been modeled. But the
6 introduction of a new design feature could change that
7 discussion is all I'm trying to say.

8 MEMBER BIER: I wanted to make a couple of
9 points here. One is that I think to an certain extent
10 I worry that that 5 times 10 to the minus 7, cutoff or
11 guidance, or whatever, encourages kind of a checkbox
12 mentality for cliff-edge effect. You get a list of
13 things that are at that level, you check them all and
14 say, none of them have a problem so I'm done.

15 And I really like your comment about, yes,
16 it really depend on physical margin and, you know,
17 maybe none of those 5 times 10 to the minus 7 events
18 have that problem but a much less likely event does.
19 And your example of the seismic isolators actually
20 gets to something that Vesna Dimitrijevic and I had
21 been contemplating earlier of, you can get a plant
22 where sort of the base level PRA results have such low
23 frequency of release that you look at it and say,
24 okay, maybe we can exempt this plant from certain
25 requirements regarding, whatever. Emergency planning

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 or staffing levels or something or other.

2 But if there is one component whose
3 failure could take you out of that regime, and the
4 seismic isolator is a great example of that, then
5 maybe you don't want to be granting those kind of
6 waivers because you could end up in a situation where
7 that would have been inappropriate. So I think that's
8 a great clarifying example for us to have in mind as
9 we go forward.

10 MR. RECKLEY: And I'm not presupposing
11 what their right answer is.

12 MEMBER BIER: Yes. Yes.

13 MR. RECKLEY: We're just trying to say,
14 you got to ask the question, you got to address the
15 issue.

16 MEMBER BIER: Yes.

17 MR. RECKLEY: It may be that there is a
18 cliff-edge, but you say it's so highly unlikely --

19 MEMBER BIER: Sure.

20 MR. RECKLEY: -- that you're not going to
21 take it.

22 MEMBER BIER: Yes. Yes.

23 MR. RECKLEY: Or you're not. But the
24 guidance is just trying to make sure that it gets
25 assessed. It's not, again, predisposing what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 right answer is in any particular case. David?

2 MEMBER PETTI: You know, just from the
3 designers perspective, the thing about LMP that's so
4 powerful is the balance. The list of balance across
5 the spectrum of events so that you don't over protect
6 something that's very low frequency and under protect
7 something that's higher frequency. Particularly when
8 you don't know what your events are in a molten salt
9 reactor because according to technology, it gives you
10 a way to think about how to logically order things
11 that can put together a story.

12 But in the end, I also think margin is
13 going to be critical when you get into these low
14 probability events because no one is going to believe
15 the numbers down to 10 to the minus 8. I mean, we
16 actually are going to, by an applicant, 10 to the
17 minus 12 --

18 MEMBER BIER: Yes.

19 MEMBER PETTI: -- for an event that has
20 been, let's just say considered historically as a key
21 event for that technology.

22 I mean, if they come in with a 10 to the
23 minus 12 number, I mean, that's going to get some
24 scrutiny, I would think by the staff, because it used
25 to be an event that you had to design and deal with,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 so.

2 MEMBER KIRCHNER: And that was an
3 internal, that would be an internal event --

4 MEMBER PETTI: That was an internal event.

5 MEMBER KIRCHNER: -- effect.

6 MEMBER PETTI: Yes, an internal, not
7 external. External I think it gets, it just gets much
8 more difficult, you know, because if you keep adding
9 requirements on the external events it's, they are
10 huge cost drivers to the plant. I mean, seismic
11 isolators are supposed to reduce cost because
12 hardening everything is so expensive. Because it's
13 done, it's usually done late in the design process and
14 so the iterative loop is huge and it just feeds back.

15 So it will be interesting to see how that,
16 how that goes. Because, well, we've got, what, Kairos
17 has come into the seismic isolator. But again,
18 they're coming in under a test reactor. So a lot of
19 this stuff doesn't (audio interference).

20 They're probably the first ones that
21 actually implement, again, the small reactor, not
22 (audio interference) bigger.

23 MR. RECKLEY: Okay. The last slide is
24 just -- we are building in kind of as we go and as we
25 update the concept of considering cliff-edge effects.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So I mention here one of our internal procedures for
2 integrated risk decision-making that it includes. But
3 there's not a lot.

4 So it's showing up currently mentioning in
5 the three to four places that I mentioned. But, you
6 know, as we update guidance you will probably see some
7 mention of it getting built in to other regulatory
8 guides and other guidance documents you might see.
9 That was the last slide.

10 CHAIR MARTIN: Okay, any last questions by
11 the members or consultants? Going around the room.
12 I don't see anything. Looking online. I see a hand
13 up.

14 So at this point I wanted to give an
15 opportunity for public comment. It looks like we have
16 a hand up right away. Okay. Oh, we have a couple.
17 So we'll start off with Monica Ray. Please go ahead.

18 MS. RAY: Good morning. Monica Ray,
19 energy compliance consultant.

20 My question kind of goes back to a
21 discussion throughout this meeting related to the
22 SOARCA. Now that report, NUREG-CR-70110 was issued in
23 2012. What are the NRC's plans for incorporating the
24 findings of that report related to the new release
25 time frames and new consequence levels that that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 report identified, and is there a schedule for
2 incorporation of that information to existing guidance
3 and what coordination is there with that between the
4 NRC and FEMA?

5 CHAIR MARTIN: So this is a comment
6 period, we don't necessary entertain questions. But
7 you have, yes, your comment, your question has been
8 recorded so we have captured that.

9 Next we have Ed Lyman.

10 MR. LYMAN: Yes, hi. It's Edwin Lyman
11 from Union of Concerned Scientists. Can you hear me?

12 CHAIR MARTIN: Yes, we can.

13 MR. LYMAN: Yes. I just wanted to point
14 out, Member Petti raised earlier the issue of applying
15 the LMP to an operating light water reactor. And my
16 impression is that the staff, the Office of Research
17 has actually done that.

18 And I haven't, you know, I can't follow
19 everything that the ACRS does but I think there were
20 plans to brief the Committee on the results of that
21 work. So it's just, from the discussion it sounds
22 like that hadn't happen so I just wanted to raise
23 that.

24 That there aren't many, or the results
25 are, or the details of the results haven't been made

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 public, as far as I can tell, but a sort of summary
2 paper from 2022 did show that if you include external
3 events that the NAI 18-04 threshold, frequency
4 consequence threshold is actually exceeded for some
5 event sequences.

6 So if you haven't been briefed on that
7 study I'm curious why not, but I think it could shed
8 some light on this discussion. Thank you.

9 CHAIR MARTIN: Okay, thank you very much
10 for your comment. Certainly on this subject we'll be
11 revisiting Reg Guide 1.183 both next month and in
12 December. It's going to be kind of a regular thing.
13 Obviously one of the important things we review.

14 MR. SNODDERLY: This is Mike Snodderly
15 from the ACRS Staff. You know, just looking at our
16 planning documents, the rainbow chart. So December
17 19th the Committee is scheduled to review Reg Guide
18 1.183 Rev 2. And then on January 14th, in the
19 morning, we're scheduled to meet with the folks from
20 Part 53 to hear an update on Part 53.

21 Which as Bill said, they expect the
22 package to be sent out for public comment relatively
23 soon. Hopefully on October 7th. But those will be,
24 I think, important meetings.

25 MEMBER PETTI: There's also a November

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 16th meeting, source term --

2 MR. SNODDERLY: Yes.

3 MEMBER PETTI: 1.183. November --

4 (Simultaneously speaking.)

5 MR. SNODDERLY: Yes. And as Anders said,
6 the DG-1414 I think there will be some discussion
7 hopefully on that on January. You know, the committee
8 will have an opportunity to ask questions --

9 CHAIR MARTIN: Absolutely.

10 MR. SNODDERLY: -- or to discuss it
11 further. So, and I bring all that up to assist you,
12 yes, as far as kind of next steps. And you're going
13 to get other opportunities to look at this.

14 CHAIR MARTIN: Sure. Well, let's make
15 sure, there is no last public comment, so we move into
16 member discussion of course.

17 MR. SNODDERLY: Sorry.

18 CHAIR MARTIN: I'm not seeing hand raise,
19 but, you know, five, four, three, two, one. Okay.
20 We'll move to any member discussion, which we've kind
21 of already started, but --

22 MEMBER PETTI: I defer because we only
23 have five minutes. Some of us have a meeting at noon.
24 I just wanted to thank the Staff, I thought this was
25 really well done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We've got so many new members on the
2 Committee now, I think it was timely. Particularly as
3 looking at the fact of the history, it just takes a
4 huge amount of energy to reconstitute that so it's
5 going to be a really useful presentation. We've got
6 a couple new members coming on, it will be a required
7 meeting I think.

8 (Laughter.)

9 CHAIR MARTIN: Yes. Again, thank you very
10 much. Obviously this was setup to be an information
11 meeting. A lot of information was conveyed. And I
12 think it preps us for the next several meetings that
13 we'll have on business and their subjects. Again,
14 thank you very much.

15 Any further discussion that we want to
16 jump into, other than the fact that there is a meeting
17 at noon? Hearing none, we will adjourn the meeting.
18 Thank you very much.

19 (Whereupon, the above-entitled matter went
20 off the record at 11:56 a.m.)

21
22
23
24
25

Advisory Committee on Reactor Safeguards

Thermal-Hydraulic Accident Analysis Subcommittee

Meeting on Accident Selection in Support of Emergency Planning and Siting Analyses

October 1, 2024

Outline

- Evolution of accident analyses and consideration of offsite consequences in support of:
 - Siting
 - Emergency preparedness
- Guidance on selection of accident scenarios for demonstrating general site suitability under 10 CFR Part 100
- Guidance to assess defense in depth and cliff-edge effects

Overview – Consideration of Radiological Consequences in NRC Activities

- Routine (Anticipated) Effluents
 - 10 CFR Part 20
 - 10 CFR Part 50, Appendix I and 10 CFR 50.34a
- **Unplanned Events**
 - Safety Analyses (Chapter 15, w/ primary focus on barriers)
 - Design Basis Radiological Consequence Analyses (“Siting Analysis”)
 - 10 CFR 100.21 (a) and (b); 10 CFR 50.34/52.79
 - Population Density Considerations (10 CFR 100.21(h))
 - Emergency Preparedness Considerations
 - Severe Accident Considerations
 - Safety Goals
 - Cost-Benefit Assessments


Overview – Consideration of: Threats/Events, Prevention, Mitigation and Consequences

“Traditional” Approach

- Safety Analysis
 - Challenges to barriers
- Siting/Containment
 - Major Accident
- Severe Accidents
- Generic Analyses
 - Population density
 - EPZs

Revised Approaches (e.g., LMP)

- Safety Analysis
 - LBEs (event sequences)
 - Frequency-Consequence
- Siting/Containment
 - LBEs (EAB/LPZ)
- Consequence assessment
 - Population density
 - EPZs




“Bowtie Diagram”


Evolution of “Traditional” Approaches

- Methodologies evolving since initial AEC/NRC approaches
 - Maximum Credible Accident/Design Basis Accident
 - “Class 9” Accidents
 - Reactor Safety Study
 - Three Mile Island
 - NUREG 0625, (Siting Policy Task Force)
 - Regulatory Guide 4.7, (General Site Suitability Criteria)
 - NUREG 0396, (NRC/ EPA Task Force on Emergency Planning)
 - Environmental Reviews
 - Commission Policy Statements
 - Risk-Informed, Performance-Based Initiatives
 - Advanced Reactors

Bowtie Representation (Traditional)



Overview – Consideration of Radiological Consequences in NRC Activities (Offsite Areas/Zones)

				 Distance (Miles) 	
Routine Effluents	Design and Programs	Part 20		Unrestricted Areas	
Unplanned Events	Siting and Design	100.21(a) 50.34/52.79	Exclusion Area Boundary	~0.5	
			Low Population Zone	~4	
		100.21(b)	Population Center Distance	~5	
		100.21(h)	Population Density	20	
	Emergency Planning	50.47	Emergency Planning Zone	10	
	Safety Goals	QHO	Prompt	1	
			Latent	10	
	Regulatory Analysis	NUREG/BR-0058	Cost-benefit (population)	50	

Recent & Ongoing Activities

ARCAP


RG 1.183

RG 4.7


10 CFR 50.160
RG 1.242

ARCAP – Advanced Reactor Content of Applications Program (DANU-ISG-2022-01; RG 1.253)
 RG 1.183, “Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors”
 RG 4.7, “General Site Suitability for Nuclear Power Stations”
 RG 1.242, “Performance-Based Emergency Preparedness for Small Modular Reactors, Non-Light-Water Reactors, and Non-Power Production or Utilization Facilities”


Traditional Safety Analyses (Chapter 15)



RG 1.183 - Design Basis Radiological Consequence Analyses (“Siting Analysis”)




Design Basis Radiological Consequence Analyses (“Siting Analysis”)



Population Density Considerations

Generic Analyses (Gen II) , Qualitative Factors, Public Comment



LWR Siting and Safety Analysis Radiological Consequence Analysis Guidance – Previous Methods

Whole body and thyroid dose figures of merit (FOM)

TID-14844 source term

Taken from 10 CFR 100.11 siting requirements

- Regulatory Guide (RG) 1.3, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss of Coolant Accident for Boiling Water Reactors," Rev. 2 (June 1974) - Withdrawn
- RG 1.4, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss of Coolant Accident for Pressurized Water Reactors," Rev. 2 (June 1974) - Withdrawn
- NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition," several Chapter 15 sections for accident-specific analyses
- RG 1.195, "Methods and Assumptions for Evaluating Radiological Consequences of Design Basis Accidents at Light-Water Nuclear Power Reactors," Rev. 0 (May 2003)

RG 1.183 Guidance

Total effective dose equivalent (TEDE) FOM NUREG-1465 and SAND 2011-0128 source terms

- RG 1.183, “Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors,” Rev. 0 (July 2000)
- RG 1.183, Rev. 1 (October 2023)
- NUREG-0800, Chapter 15.0.1, “Radiological Consequence Analyses Using Alternative Source Terms” (July 2000)
- NUREG-0800, Chapter 15.0.3, “Design Basis Accident Radiological Consequence Analyses for Advanced Light Water Reactors” (March 2007)
- Draft Guide 1524, RG 1.183 draft Rev. 2, being developed for Increased Enrichment Rulemaking efforts

Accident Consequence Figures of Merit Based in Regulation

Exclusion Area Boundary –

An individual located at any point on the boundary of the exclusion area for any 2-hour period following the onset of the postulated fission product release, would not receive a radiation dose in excess of 25 rem TEDE.

Low Population Zone –

An individual located at any point on the outer boundary of the low population zone, who is exposed to the radioactive cloud resulting from the postulated fission product release (during the entire period of its passage), would not receive a radiation dose in excess of 25 rem TEDE.

Control Room –

Adequate radiation protection is provided to permit access to and occupancy of the control room under accident conditions without personnel receiving radiation exposures in excess of 5 rem TEDE for the duration of the accident.

RG 1.183 Figures of Merit

Accident-specific offsite dose acceptance criteria

- Based on NUREG-0800
- Graded based on relative qualitative likelihood

Full regulatory dose value – 25 rem TEDE	Maximum hypothetical accident, lowest likelihood
Well within (25%) – 6.3 rem TEDE	Low relative likelihood
Small fraction of (10%) – 2.5 rem TEDE	Highest relative likelihood

RG 1.183 Analysis Approach

The DBAs were not intended to be actual event sequences but, rather, were intended to be surrogates to enable deterministic evaluation of the response of the plant engineered safety features. These accident analyses are intentionally conservative in order to address uncertainties in accident progression, fission product transport, and atmospheric dispersion.

Traditional deterministic radiological consequence analyses

- 95th percentile meteorology, no protective actions, no dry-deposition, etc.
- Source term is risk-informed
- Modeling generally does not credit facility features that:
 - are not safety-related;
 - are not covered by technical specifications;
 - do not meet single-failure criteria, or;
 - rely on the availability of offsite power. Design basis delays in actuation of these features should be considered, especially for those features that rely on manual operator intervention.

Radiological emergency preparedness (EP)—

- *ensures protective actions can and will be taken*
- *is an independent layer of defense in depth*
- *provides dose savings*
- *is risk-informed*

EP is a matter of judgment


“Regulation does not require dedication of resources to handle every possible accident that can be imagined. The concept of the regulation is that there should be core planning with sufficient planning flexibility to develop reasonable response to those very serious low probability accidents which could affect the public.”

[SONGS CLI-83-10, 17 NRC 528, (1983)]

“A reading of the Report [NUREG-0396] indicates clearly that the margins of safety provided by the recommended 10-mile radius were not calculated in any precise fashion but were qualitatively found adequate *as a matter of judgment.*”


[55 FR 5605, Feb 16, 1990]

EP has different use for risk information



RIPB Design

Risk-informed EP Requirements




RIPB EP


RIPB EP ≠ RIPB Design

RIPB: risk-informed, performance-based


The planning basis informs the planning




The EPZ is risk-informed



Design Basis Accidents



Beyond Design Basis



Effectiveness of Protective Measures

NUREG-0396, "Planning Basis for the Development of State and Local Government Radiological Emergency Response Plans in Support of Light Water Nuclear Power Plants," November 1978

EP is independent of probability

The NRC policy statement, “Safety Goals for the Operation of Nuclear Power Plants” (51 FR 30028; August 4, 1986), states that emergency preparedness is a “defense-in-depth measure.”


Emergency preparedness is carried out as a matter of prudence rather than in response to a quantitative analysis of accident probabilities. The effectiveness of an emergency plan is independent of probability.

[RG 1.219, Revision 1, dated July 2016]


Guidance on selection of accident scenarios for demonstrating general site suitability under 10 CFR Part 100 (RG 4.7, Rev 4)

- Light-Water Reactors
 - Determination/Confirmation of EAB/LPZ
 - Population density assessment
 - 20 miles
 - Alternative Determination
- Non-LWRs Licensing Modernization Project
 - Determination/Confirmation of EAB/LPZ
 - Population density assessment
 - 20 miles
 - Alternative Determination
- Non-LWRs not using LMP Approach

Traditional Determination/Confirmation of EAB/LPZ (LWRs) [Slide 9]



RG 4.7 Rev 4 “Traditional/LWR” Consideration of Population Density as Alternative to 20 miles



Regulatory Guide 4.7, Revision 4 Functional Containment (LMP)






Figure 1: Approaches for estimating radiological releases
(RG 4.7, Rev. 4, Appendix A)


Licensing Modernization Project Mechanistic Source Term



LMP Determination/Confirmation of EAB/LPZ




Licensing Modernization Project Assessment of Population Density




Non-Light-Water Reactor not using LMP

- Same approach as for LWRs (Slides 21/22)
- Challenge – no defined “source term” for radionuclides introduced into containment for a “major accident”





Confirmation of EAB/LPZ




Population Density Considerations

Defense in Depth and Cliff-Edge Effects

Defense in Depth - Background



INSAG-10
INSAG-12



Assessing Defense in depth





Figure 5-2. Framework for Establishing DID Adequacy

NEI 18-04


- Plant Capability Defense in Depth
- Programmatic Defense in Depth
- RIPB Assessments



INSAG-12

- Defence in Depth (5 Levels)
- Plant Operational State
- Prevention and Mitigation

Defense in depth – traditional discussions



- Different Contexts
 - Plant Level
 - Barriers
 - Controls
 - Fire Protection
 - Security
- Prevention & Mitigation often related to top level event (core damage)
 - IAEA INSAG-12
 - Reg Guide 1.174
 - Changes to licensing basis

Defense in depth - LMP

LMP Approach




FIG. 1. Flow chart for defence in depth.

IAEA Safety Report Series No. 46
Assessment of Defence in Depth
for Nuclear Power Plants
(Similar to NEI 18-04)

- Higher levels mitigate failure of prevention by lower levels
 - e.g., Mitigation of a DBE to address failure to mitigate an AOO
- LBE Evaluations
 - Frequency/Consequence
- Cumulative risk
 - Safety Goals
- No single design or operational feature, no matter how robust, is exclusively relied upon to satisfy the five layers of defense

Cliff Edge Effects Background

IAEA SSR 2/1

- A 'cliff edge effect', in a nuclear power plant, is an instance of severely abnormal plant behaviour caused by an abrupt transition from one plant status to another following a small deviation in a plant parameter, and thus a sudden large variation in plant conditions in response to a small variation in an input.
 - External Hazards
 - 5.21. The design of the plant shall provide for an adequate margin to protect items important to safety against levels of external hazards to be considered for design, derived from the hazard evaluation for the site, and to avoid cliff edge effects.

Cliff Edge Effects

Incorporation into Requirements & Guidance

10 CFR 50.155, “Mitigation of beyond-design-basis events.”

RG 1.226, “Flexible Mitigation Strategies for Beyond-Design-Basis Events”

Sections 50.155(b) and (b)(1) require that applicants or licensees develop and implement strategies and guidelines to mitigate beyond-design-basis external events from natural phenomena that result in a loss of all alternating current power concurrent with either a loss of normal access to the ultimate heat sink (LUHS) or, for nuclear power plants with passive reactor designs, a loss of normal access to the normal heat sink. This section of the RG addresses developing and implementing the strategies and guidelines, and section C.4 addresses maintenance of the strategies and guidelines.

Cliff Edge Effects

Incorporation into Requirements and Guidance

NEI 18-04

- Event sequences with frequencies less than 5×10^{-7} /plant-year are retained in the PRA results and used to confirm there are no cliff edge effects. They may also be taken into account in the RIPB evaluation of defense-in-depth.
- The evaluation of LBEs during the IDP [integrated decision-making process] will focus on the following questions:

* * *

Has the PRA evaluation provided an adequate assessment of “cliff edge effects?”

ASME/ANS RA-S-1.4-2021

- Cliff edge effect: an instance of a sudden large variation in plant conditions in response to a small variation in an input (e.g., change in flood height, grid perturbation based on voltage or frequency exceeding a breaker trip set point).

Cliff Edge Effects Incorporation into Guidance

LIC-504, “Integrated Risk-Informed Decision-Making Process for Emergent Issues”

... Additionally, an assessment of potential cliff-edge effect resulting from the emergent condition may help focus decisions. In 2018, the International Atomic Energy Agency, in its “Terminology Used in Nuclear Safety and Radiation Protection,” defined a cliff-edge effect ... Extreme flooding scenarios and available physical margin used in the NRC’s post Fukushima work used in previous LIC-504 assessments serve as an illustrative example of a cliff edge assessment. Another example may involve post-accident combustible gas sources, if the identified degraded condition involves increased post-accident combustible gas that exceeds detonation limits that may fail the reactor containment barrier.

Discussion

Acronyms & Abbreviations

AEC	Atomic Energy Commission	LBE	Licensing Basis Event
ANS	American Nuclear Society	LMP	Licensing Modernization Project
AOO	Anticipated Operational Occurrence	LPZ	Low Population Zone
ARCAP	Advanced Reactor Content of Application Project	LWR	Light-Water Reactor
ASME	American Society of Mechanical Engineers	NEI	Nuclear Energy Institute
BDBE	Beyond-Design-Basis Event (LMP)	NRC	Nuclear Regulatory Commission
CFR	Code of Federal Regulations	PCD	Population Center Distance
DBA	Design Basis Accident	PCT	Peak Clad Temperature
DBE	Design-Basis Event (LMP)	PPSM	Persons Per Square Mile
DNB	Departure from Nucleate Boiling	PRA	Probabilistic Risk Assessment
EAB	Exclusion Area Boundary	RCS	Reactor Coolant System
EP	Emergency Preparedness	RG	Regulatory Guide
EPA	Environmental Protection Agency	RIPB	Risk Informed, Performance Based
EPZ	Emergency Planning Zone	S/R	Safety Related
FOM	Figure of Merit	SAMA	Severe Accident Mitigation Alternatives
FR	Federal Register	SSCs	Structure, Systems, and Components
IAEA	International Atomic Energy Agency	TEDE	Total Effective Dose Equivalent
IDP	Integrated Decisionmaking Process	TID	Technical Information Division (AEC)

Attendance for ACRS Thermal-Hydraulic Subcommittee Meeting on October 1, 2024

Michael Snodderly
Larry Burkhart
Thomas Dashiell
Jana Bergman
Tyesha Bush
James Cordes - Court Reporter
Shandeth Walton
Jan Mazza
Anders Gilbertson (He/Him/His)
Dennis Bley
Stephen Schultz
Vesna B Dimitrijevic
Tammy Skov
Tracy Radel (She/Her)
Zach Gran
Tim Polich (Unverified)
Kevin Hsueh
Derek Widmayer
Hanh Phan
Jeffrey Herrera
Chris Courtenay (TerraPower)
Jeremiah Doyle (NuScale)
Robert Martin (He/Him)
Ron Markovich
Hovhannes Hovhannisyan
Monica Ray
Kyle Clavier
Brian Johnson (TerraPower)
Chris Forrest (TP)
Tiffany Long (She/Her)
Gregory Halnon
David Garmon
Nazila Tehrani (She/Her)
Hossein Nourbakhsh
John Biersdorf