

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Nuscale Design-Centered Subcommittee

Docket Number: N/A

Location: teleconference

Date: 11-05-24

Work Order No.: NRC-0100

Pages 1-150

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

NUSCALE DESIGN-CENTERED SUBCOMMITTEE

+ + + + +

TUESDAY

NOVEMBER 5, 2024

+ + + + +

The Subcommittee met via Teleconference,
at 1:00 p.m. EDT, Walter L. Kirchner, Chairman,
presiding.

SUBCOMMITTEE MEMBERS:

WALTER L. KIRCHNER, Chair

RONALD G. BALLINGER, Member

VICKI M. BIER, Member

VESNA B. DIMITRIJEVIC, Member

GREGORY H. HALNON, Member

CRAIG D. HARRINGTON, Member

ROBERT P. MARTIN, Member

SCOTT P. PALMTAG, Member

DAVID A. PETTI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

THOMAS E. ROBERTS, Member

MATTHEW W. SUNSERI, Member

ACRS CONSULTANTS:

DENNIS BLEY

CHARLES BROWN

MYRON HECHT

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

MICHAEL SNODDERLY

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CONTENTS

Call to Order, Opening Remarks, and
 Introductions 4
 Staff's Opening Remarks 8
 Discussion of NuScale Safety Analysis
 Report (SAR) Chapter 3, "Design of
 Structures, Systems, Components, and
 Equipment" (Except for 3.7, 3.8 and
 3.9.2) 10
 Staff's Evaluation of NuScale SAR Chapter 3 . . . 55
 Discussion of NuScale Safety Analysis
 Report (SAR) Chapter 8, "Electrical Power" . . 105
 Staff's Evaluation of NuScale SAR Chapter 8 . . 131
 Discussion of NuScale Safety Analysis
 Report (SAR) Chapter 14, "Initial Test Program
 and Inspections, Tests, Analyses, and
 Acceptance Criteria" 133
 Staff's Evaluation of NuScale SAR Chapter 14 . 141
 Opportunity for Public Comment 148
 Adjourn 150

P R O C E E D I N G S

1:00 p.m.

CHAIR KIRCHNER: The meeting will now come to order. This is a meeting of the NuScale Design-Centered Review Subcommittee of the Advisory Committee on Reactor Safeguards.

I'm Walt Kirchner, Chair of today's Subcommittee meeting. ACRS members in attendance in person are Ron Ballinger, Craig Harrington, Robert Martin, Scott Palmtag, Dave Petti, Thomas Roberts, and myself. ACRS members in attendance virtually via Teams are Vicki Bier, Vesna Dimitrijevic, and Matt Sunseri.

We have one of our consultants participating in person, Charlie Brown. I don't see him yet, but we expect him. And also, via Teams, we have Dennis Bley, Myron Hecht, and Stephen Schultz.

If I'm missing anyone, please speak up at this point. Oh, and I skipped over our esteemed Vice Chair, Greg Halnon. My apologies.

Michael Snodderly of the ACRS staff is the Designated Federal Officer for this meeting.

No member conflicts of interest were identified. And I note that we have a quorum.

During today's meeting, the Subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 will receive a briefing on the staff's evaluation of
2 the NuScale Power LLC's US460 Standard Design Approval
3 Application and will cover Chapter 3, Design of
4 Structures, Systems, Components, and Equipment;
5 Chapter 8, Electrical Power, and Chapter 14, Initial
6 Test Program and Inspections, Tests, Analyses, and
7 Acceptance Criteria, ITAAC.

8 We previously reviewed the Certified
9 NuScale US600 design, as documented in our July 29,
10 2020, Letter Report on the Safety Aspects of the
11 NuScale Small Modular Reactor.

12 Like the staff, we are performing a delta
13 review between the two designs, including the power
14 uprate from 50 to 77 megawatts electric per module.
15 We are reviewing these chapters as part of our
16 statutory obligation under Title 10 of the Code of
17 Federal Regulations, Part 52, Subpart E, Section 141,
18 referral to the Advisory Committee on Reactor
19 Safeguards to report on those portions of the
20 application which concern safety.

21 The ACRS was established by statute and is
22 governed by the Federal Advisory Committee Act, or
23 FACA. The NRC implements FACA in accordance with our
24 regulations. Per these regulations and the
25 Committee's Bylaws, the ACRS speaks only through its

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 published Letter Reports. Therefore, all member
2 comments should be regarded as only the individual
3 opinion of that member, not a Committee position.

4 All relevant information related to ACRS
5 activities, such as letters and rules for meeting
6 participation, and transcripts are located on the NRC
7 public website and can be easily found by typing
8 "About US ACRS" in the Search vehicle on the NRC's
9 home page.

10 The ACRS, consisting of the agency's value
11 of public transparency and regulation of nuclear
12 facilities, provides opportunity for public input and
13 comment during our proceedings. We have received no
14 written statements or requests to make a statement
15 from the public, but we have set aside time at the end
16 of this meeting for public comments.

17 Portions of this meeting may be closed to
18 protect sensitive information, as required by FACA and
19 the Government in Sunshine Act. Attendance during the
20 closed portion of the meeting will be limited to NRC
21 staff and its consultants, applicants, and those
22 individuals and organizations who have entered into an
23 appropriate confidentiality agreement. We will
24 confirm that only eligible individuals are in the
25 closed portion of the meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The ACRS will gather information, analyze
2 relevant issues and facts, and formulate proposed
3 conclusions and recommendations, as appropriate, for
4 deliberation by the full Committee. A transcript of
5 the meeting is being kept and will be posted on our
6 website.

7 When addressing the Subcommittee,
8 participants should first identify themselves and
9 speak with sufficient clarity and volume, so that they
10 may be readily heard. If you are not speaking, please
11 mute your computer or Teams or by pressing star-6 if
12 you're on the phone.

13 Please do not use the Teams chat feature
14 to conduct sidebar discussions related to the
15 presentations, but, rather, use the meeting chat
16 function to report IT problems and issues.

17 For everyone in the room, please put all
18 your electronic devices in silent mode and mute your
19 laptop microphone and speakers.

20 In addition, please keep sidebar
21 discussions in the room to a minimum, since the
22 ceiling microphones are live.

23 Presenters, your table microphone is
24 unidirectional and you'll need to speak into the front
25 of the microphone to be heard.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Finally, if you have any feedback for the
2 ACRS about today's meeting, we encourage you to fill
3 out the public meeting feedback form on the NRC's
4 website.

5 And unless there are comments from any
6 members -- seeing none, okay, we'll proceed with the
7 meeting. I'm going to turn to MJ from the NRC staff.

8 MR. JARDANEH: Hi. Good afternoon, Chair
9 Kirchner, and good afternoon, ACRS Subcommittee
10 Members, NuScale Participants, NRC staff, and members
11 of the public. My name is Mahmoud "MJ" Jardaneh and
12 I serve as the Branch Chief for the New Reactor
13 Licensing Branch, responsible for the licensing of the
14 NuScale US460 design, in the Division of New and
15 Renewed Licenses, the Office of Nuclear Reactor
16 Regulation.

17 Thank you for the opportunity today for
18 the staff to present on their review of select NuScale
19 US460 Standard Design Approval Application for SDAA
20 chapters.

21 As you are aware from previous meetings,
22 the staff is reviewing all chapters of the SDAA
23 concurrently with staggered completion dates based on
24 the complexity of the chapter and the extent of change
25 from the Certified NuScale US600 design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Today, the staff will be presenting on
2 their review of the third group of the SDAA chapters,
3 including Chapter 8, Chapter 14, and sections of
4 Chapter 3. Earlier this year, the staff presented to
5 this Subcommittee on Chapters 2, 7, 9, 10, 11, 12,
6 portions of Chapter 17 and Chapter 18.

7 The remaining SDAA chapters are still
8 being reviewed by the staff and we will inform the
9 ACRS when the Safety Evaluations of the remaining
10 chapters are available for their review.

11 In today's meeting, the staff will focus
12 on the deltas from the Certified Designs that the NRC
13 has approved and the Subcommittee and the Committee
14 reviewed in the past.

15 Once again, thank you for the opportunity
16 and we look forward to a good discussion.

17 CHAIR KIRCHNER: Thank you. And with
18 that, I'll turn to NuScale. Welcome. Nice to see you
19 here in person.

20 Peter, are you going to start for NuScale?
21 Go ahead.

22 MR. SHAW: We actually have Elisa who is
23 going to start.

24 MS. FAIRBANKS: Good afternoon, everyone.
25 My name is Elisa Fairbanks. I am the NuScale

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Licensing Supervisor for the Chapters 3, 8, and 14
2 that are being presented today, and we thank you for
3 the opportunity to give you a summary of the Standard
4 Design Approval Application and the review that has
5 been performed.

6 And with that, I'm going to turn it over
7 to Thomas Griffith who is online with us.

8 MR. GRIFFITH: Yes, thank you. Thank you,
9 Elisa. I appreciate the opportunity here as NuScale
10 to present Chapters 3, 8, and 14. I'd like to really
11 start out by commending the NRC staff, as well as
12 NuScale, for the amount of hours spent during the
13 review in preparing for these chapters to be presented
14 today, and I really look forward to the opportunity to
15 present the material today. Thank you.

16 MR. SHAW: Good afternoon. My name is
17 Peter Shaw. I'm a licensing engineer for NuScale
18 Power. I've been there for three years. Prior to
19 that, I've had 10 years of experience at the Vogtle 3
20 and 4 construction project. And we're here to present
21 the chapters as stated before, 3, 8, 14, and including
22 Part 8. Next slide, please.

23 Acknowledgment/disclaimer. This is based
24 on DOE award. We are very thankful for this
25 particular award and present here today the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 information on the NuScale Power Plant.

2 Next slide, please. We're, first, going
3 to go over Chapter 3. Chapter 3 as a whole is going
4 to have four presenters, and we're going to go over
5 design of structures, systems, components, and
6 equipment, and it excludes Sections 3.7, 3.8, and
7 3.9.2.

8 Next slide, please. A brief overview of
9 what we're going to be covering today. Chapter 3
10 describes the methodologies for design of structures,
11 systems, and components. The SDAA is a derivative of
12 DCA design. This presentation will focus on high-
13 level design methodology changes and also include the
14 important audit questions and RAIs.

15 The SDAA structures reflect a six-module
16 design. This has changed from the 12-module design of
17 the DCA. This necessitates an update of the civil
18 analysis, but the design basis is unchanged.

19 One of the other significant changes is
20 the SDAA design adopted the 2017 ASME BPV code and the
21 2017 ASME OM code requirements.

22 Next slide, please. This is just a quick
23 overview. This is a design of the SDA and the US460
24 reactor building and the modules within. There is a
25 common overhead load-handling system that transports

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the modules. The reactor building walls protect all
2 of the modules within. The bioshield is a radiation
3 protection barrier. The spent fuel pool and the
4 ultimate heat sink carry a common body of water that
5 is used in safe shutdown.

6 Next slide, please. And so, this is an
7 overview of all the sections that we're going to be
8 going over. There's quite a few sections here. Of
9 note again, 3.8 and 3.7 that pertain to seismic
10 analysis and design are excluded from this
11 presentation, as well as 3.9.2, which is mechanical
12 equipment analysis, and also, 3A and 3B appendices are
13 excluded.

14 Next slide, please. So, to start with,
15 with Section 3.1, "Conformance with U.S. Nuclear
16 Regulatory Commission General Design Criteria," the
17 differences from the DCA in this particular section
18 are generally unchanged. There are a couple of
19 exceptions of note.

20 The first is that the GDC 27 compliance
21 was simplified for the SDA with emergency core cooling
22 systems supplemental boron. This will be further
23 discussed in the presentations for Chapters 4, 6, and
24 15.

25 GDC 32 is a change to the lower RPV to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 stainless steel material. So, no material
2 surveillance is required. An exemption 6 requests
3 this. This will be further discussed in Chapter 5
4 when it's presented.

5 And then, for GDC 41 and PDC 41, these
6 have been updated with the passive autocatalytic
7 recombiners to maintain an inert atmosphere. This
8 will be further discussed in Chapter 6 and there are
9 similar follow-on updates for 42 and 43. There were
10 no audit questions and no RAI questions.

11 Next slide, please. Section 3.2 is the
12 Classification of Structures, Systems, and Components.
13 The differences from the DCA: DCA Table 3.2-1 was
14 split to align with the guidance for Regulatory Guides
15 1.26 and 2.19. SDAA Table 3.2-1 lists the seismic
16 classification of the buildings. Meanwhile, SDAA
17 Table 3.2-2 lists the seismic Category I pressure
18 retaining mechanical systems and components.

19 The specific component classifications for
20 components that are not in these tables were moved to
21 the system chapters.

22 COL Item 3.2-1 was removed, as no
23 applicants are expected to add components to these
24 tables in a COL application. There were no audit
25 questions and no RAI questions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I would, then, like to turn this over to
2 Andrea Mota.

3 MS. MOTA: Hi. I'm Andrea Mota, licensing
4 engineer with NuScale. I'll be presenting Sections
5 3.3 through 3.5. I've been with NuScale for three
6 years, and prior to NuScale, I was a civil and
7 mechanical engineer at the Hanford site.

8 3.1, "Wind and Tornado Loadings." The
9 major difference from the DCA is that the SDAA uses
10 more conservative wind loads than required by
11 regulatory guidance to consolidate our analysis.

12 There were eight audit questions resolved.

13 As a result of the audit, we added clarifications of
14 the FSAR to specify which codes conform wind speeds
15 and importance factors.

16 There were no RAI questions. Next slide.

17 CHAIR KIRCHNER: Andrea, before you go on,
18 it's unusual that an applicant comes and presents
19 something that's much more conservative than the
20 regulatory guidance. So, could you just for the
21 public record explain why you did that? Is it to
22 allow for more site options? Or not to beat the
23 witness, but could you explain the purpose, Andrea?

24 MS. MOTA: The most conservative loads
25 from both ASCE 7-05 and ASCE 7-16 consolidate our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 analysis.

2 CHAIR KIRCHNER: Thank you.

3 DR. BLEY: This is Dennis Bley. To
4 consolidate your analysis, to make it consistent
5 everywhere, is that what you're saying? I mean, what
6 do you mean by consolidating the analysis?

7 MS. MOTA: So, we can perform one analysis
8 rather than multiple.

9 DR. BLEY: Okay. And then it didn't have
10 to do with what Walt suggested, to be able to use this
11 at more sites?

12 MS. MOTA: That is a positive result of
13 using more conservative factors.

14 DR. BLEY: Okay.

15 MS. MOTA: Next slide. 3.4, "Water Level
16 (Flood) Design." The major differences from the DCA
17 are that the SDAA evaluates flooding zones instead of
18 rooms.

19 And COL items were removed for
20 clarification and to reflect the removal of the
21 personnel access tunnel from the reactor building to
22 the control building. There were 17 audit questions
23 that were resolved.

24 There was one RAI question that was
25 resolved. And as a result of the RAI, we updated the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 considerations and assumptions used in the flooding
2 analyses. We added tables for flooding sources and
3 flooding zones, and COL Item 3.4-2 was updated to
4 clarify that the onsite flooding program will be
5 consistent with Section 3.4.1 methodology and flood
6 levels.

7 Next slide.

8 MEMBER HALNON: Before you go on, this is
9 Greg. You said you know that mitigation of flooding
10 is going to be from a combination of watertight doors,
11 water-resistant doors, elevating equipment. Can you
12 give me a feel for the magnitude of how many
13 watertight doors versus water-resistance, which I'm
14 not sure we'll hear about, too?

15 But, you know, I've got a lot of
16 experience with watertight doors and it requires a lot
17 of operator action in order to close these doors at
18 time or even some large equipment sometimes, depending
19 on the type of door. Could you give me just a feel
20 for the magnitude of what you're talking about here
21 with regard to those types of doors?

22 MS. MOTA: Well, we have COL items in this
23 section to prompt the COL applicant to determine the
24 final methodologies for mitigating flood levels and,
25 also, to create the onsite flooding program to define

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 those operator actions in regards to those doors.

2 MEMBER HALNON: Okay. When you go from
3 rooms to zones, typically, the doors get bigger
4 because you're not closing off a room; you're closing
5 off an area. Do you envision having large watertight
6 doors that have to be closed or is that all down the
7 road a ways, depending on the configuration of the
8 site, and whatnot?

9 MS. MOTA: I'm going to ask that our
10 engineer David Benson on the line answer that
11 question.

12 MR. BENSON: Good afternoon. This is
13 David Benson. I'm a structural engineer with NuScale
14 Power.

15 The intention is to define flood levels
16 based on these zones for an applicant, and based on
17 the SSC, if there is an SSC in that location, they
18 would determine how they would want to mitigate those
19 floods. If they chose to pursue doors, if they chose
20 to pursue some other form of flood mitigation, it's up
21 to the COLA applicant at that point.

22 MEMBER HALNON: Okay. Yes, I kind of get
23 that, except you can help me with the actual
24 configuration that you're thinking about.

25 If you have a safety-related pump and it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 needs to be elevated above, you're affecting a lot of
2 the flow characteristics of the pump and the system.
3 Is that beyond the level of detail of what we're
4 talking about right now? Because that certainly could
5 potentially change the design.

6 MR. BENSON: That's correct. And part of
7 the COLA application would be that, if they change any
8 of the assumptions or inputs, the analysis would be
9 reperformed for flood levels.

10 MEMBER HALNON: Okay. Thanks.

11 CHAIR KIRCHNER: If I could just follow
12 on, Andrea? Rooms versus zones, I kind of understand
13 that, but would there be instances where you would
14 really want the ability to isolate a room within a
15 zone? I'm thinking of your battery, your EDAS system,
16 in particular, and how you configure that. Is that
17 enacted or are you treating that separately? It seems
18 to me, if it's a safety-related system, as the example
19 that Greg raised, that would be something you wouldn't
20 want to leave to the COLA applicant. You would want
21 to find that functionally and protect it accordingly.

22 Do you see where I'm going? We're just
23 trying to understand the zones versus rooms when you
24 have safety-related, or even if it's not classified as
25 safety-related, but something, you know, where high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reliability is important. It may need special
2 treatment --

3 MR. BROWN: Walt, can I amplify your
4 comment?

5 CHAIR KIRCHNER: Go ahead.

6 MR. BROWN: I'm sorry, I thought you were
7 finished. I'm sorry.

8 CHAIR KIRCHNER: I am, Charlie. Go ahead.

9 MR. BROWN: Okay. This is Charlie. Yes,
10 I was going to ask the question, when you talk about
11 zones, it seems to me rooms, like the main control
12 room, instrumentation room, a few places that you want
13 to keep as isolated as you can, you don't want to be
14 encompassed in some larger engulfment of water. Zones
15 sounds all-encompassing and could result in some more
16 critical rooms. And I'm just trying to amplify Walt's
17 comment a little bit on the rooms versus zones.

18 MS. MOTA: I'm going to ask that David
19 Benson answer this question.

20 MR. BENSON: Good afternoon again. The
21 definition of zones is trying to, I guess, consolidate
22 the analysis into specific regions. There are no
23 rooms in specific in those areas that we would want to
24 keep, that we would want to define the protection. It
25 would be up to the COLA applicant to define that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: This is Greg. It just
2 seems contrary to the standard design to leave some of
3 these critical configurations up to the COLA
4 applicant. It seems like, when they're redesigning
5 the plant, potentially, based on flood zone, we would
6 assume that these things are supposed to be
7 standardized. So, your room looks like another room
8 at a different site. Am I off-base there or is there
9 just a difference that you're going to accept? If so,
10 an nth-of-a-kind won't really be what we would
11 classically think as an nth-of-a-kind off the shelf.

12 MR. FISCHER: Hello. This is Kevin
13 Fischer. I am a test engineer and work on the
14 technical aspects of the equipment qualification
15 program here with NuScale. I'm the technical SME for
16 Chapter 3.11. And so, I'll take an attempt to answer
17 that.

18 We don't go down to the room level on that
19 sense. We designate those zones as mild by design.
20 So, we place all of our safety-related equipment and
21 anything that's important to safety in those general
22 areas to protect them from any post-accident
23 conditions.

24 So, going between rooms and zones is a
25 little bit nebulous. In the area, in general, in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 zone, we define it as mild and protect that as mild,
2 so that it's protected inherently from any post-
3 accident conditions, as well as any anticipated
4 operational offsets.

5 And so, there are a handful of rooms in
6 those zones, but, by design, we protect those zones to
7 remain mild post-accident, so that any of that
8 equipment, if that's important to safety, remains
9 protected. And how the applicant chooses to do that
10 will be, ultimately, up to them, but that's why we
11 design and place our equipment in those areas.

12 DR. BLEY: This is Dennis Bley. I'm kind
13 of with the other people. I'm trying to see the
14 benefit you're looking for here and why you decided to
15 do this, and why you thought it a wise idea to put
16 more of the onus on detection on the COL applicant.
17 I mean, that's how that feels. Or don't you think it
18 really needs protection? Perhaps that's going on.

19 CHAIR KIRCHNER: I think what we're -- if
20 I can amplify on Dennis' point and Charlie's as well,
21 I'll just give you a hypothetical example. So, you've
22 got a PRA for your design. Why would you leave things
23 up to the COLA applicant to change something in the
24 way you treat flooding or fires, or any of these
25 zones, such that it may alter performance of your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 plant with regard to safety? I think that's what
2 we're struggling with here.

3 MR. FISCHER: So, another item of thought
4 here is that we're not just protecting against
5 flooding for all that equipment, either. There are
6 other mitigation factors for other items that drive
7 those rooms to harsh which would put the equipment at
8 jeopardy post-accident, which we're protecting against
9 as well for those areas. So, it isn't only flooding
10 that's being mitigated in those areas, but also all
11 the other parameters as well post-accident.

12 CHAIR KIRCHNER: But that's precisely my
13 point or our points -- that why would you leave it to
14 the COLA applicant to do something that might change
15 the performance or characteristics of your plant with
16 regard to safety? I can see accommodating other
17 things that are site-specific, but it is your design;
18 it's your plant. I'm just struggling with the comment
19 that you're leaving this to the COLA applicant.

20 Okay. I know we need to go on.

21 DR. BLEY: This is Dennis again, just on
22 this one. We've seen, you know, if you were around
23 back in the '60s and early '70s, every plant by each
24 of the vendors ended up being very different,
25 sometimes even two units at the same plant but from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the same vendor. We had a bunch of pretty smart guys
2 who decided how they wanted their plants to be. So,
3 we had nothing really approaching standardization.
4 But when Part 52 came out, the hope was we would get
5 there and we haven't.

6 My memory is, when we first talked with
7 you guys quite a few years ago, you were going to make
8 one design. Everybody would buy it as-is and that was
9 the only way to go forward.

10 Then, you made a power uprate. Now you're
11 making this change. All of a sudden, we're looking
12 like things did in the past. And Greg mentioned the
13 nth-of-a-kind. It seems like that's going to become
14 ephemeral once again. At least that's what I'm
15 worried about a little bit.

16 MEMBER DIMITRIJEVIC: Walt?

17 CHAIR KIRCHNER: Go ahead, Vesna.

18 MEMBER DIMITRIJEVIC: So, just because you
19 mentioned PRA, I just want to add that the PRA,
20 generally, it doesn't expect the internal flood or
21 internal fires to be completed in this stage because
22 the equipment, piping, the cables, all of these things
23 will be laid out later, and then, you know, the
24 position of the important equipment and also sources
25 of, like, an internal flood will be better known. So,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 it is not unusual to see that these things are left to
2 be done when the plant is actually built and there is
3 a layout, including piping and, in the prior cases,
4 cables.

5 CHAIR KIRCHNER: But to Dennis' point and
6 mine, if it's important to safety, why allow a COLA
7 applicant to change the design? That would require,
8 then, redoing the PRA analyses for flooding, fire, and
9 other threats.

10 MEMBER DIMITRIJEVIC: But the flooding
11 theory would not be completed yet in that case because
12 you don't have, like, the sources of the flooding,
13 like pipes which can break. They're not laid out yet.

14 And also, equipment here, this is a very
15 specific case because all their major equipment is,
16 you know, passive and in the containment.

17 The thing is, if that's another case, that
18 the equipment is important for safety may not have an
19 exact position and a vault to protect them, and up to
20 which level do you have to protect them? So, that's
21 what I just want to say.

22 So, when they do the fire and the flood,
23 at this stage it is very general, that these zones are
24 designated and things like that, but they cannot be
25 specific yet. So, that's just my input, you know, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 help you in your thinking, that a lot of things happen
2 when the equipment is actually laid out.

3 CHAIR KIRCHNER: Agreed, Vesna.

4 Okay, I think we should go on. I think
5 we've made our point.

6 MR. BROWN: Walt, can I make one other
7 observation?

8 CHAIR KIRCHNER: Go ahead, Charlie.

9 MR. BROWN: Somebody mentioned -- I think
10 it was Dennis -- the purpose of an SDAA is a cookie-
11 cutter design. And at least my experience in the
12 Naval Nuclear Program, if it wasn't for total cookie
13 cutters, we wouldn't have a fleet of submarines and
14 aircraft carriers the way we have. We just don't
15 change it from plant to plant, based on little nuances
16 like that, based on the reactor plant, its controls,
17 its arrangements.

18 And the idea here is to make sure we can
19 have plants that are easily agreed-upon and built and
20 put in service. The more COL stuff that affects it,
21 the harder that gets, because, then, NRC has to get
22 involved somewhere along the line to assure that
23 that's okay, whatever the COL has decided doesn't do
24 something that's out of the range of our
25 considerations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'm just throwing that out. I just think
2 that's an interesting thing that we need to think
3 about or you all need to think about -- excuse me --
4 as a Committee.

5 I'll shut up now.

6 MR. SHAW: Before we move on, I just want
7 to add one more thing.

8 CHAIR KIRCHNER: Okay, Peter, yes.

9 MR. SHAW: So, part of the consideration
10 here is that we also want to limit what the risk is
11 for a COL applicant to impact the safety basis. So,
12 one of the important things that we've done, and part
13 of the zone identification, as we've spoken to
14 earlier, is that the critical rooms and the critical
15 components are identified, per the SDAA design.
16 Right? What we leave up to the COL applicant will not
17 have a safety impact basis when that application goes
18 through. And that's one of the reasons why that
19 responsibility is deemed adequate for a COL applicant
20 to take on, because it will not change the safety
21 basis and the safety statements that are completed
22 with the SDAA.

23 MS. MOTA: Next slide, please. Section
24 3.5, "Missile Protection." The major difference from
25 the DCA is that there are no essential equipment and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 no turbine missile evaluation for the control
2 building.

3 There are 12 audit questions that are
4 resolved. As a result, we added FSAR clarification
5 regarding the control building and no essential
6 equipment. Therefore, no turbine missile evaluation
7 required for the control building.

8 There are added inputs used in the turbine
9 analysis and a table for turbine missile parameters.
10 We added a table identifying essential structures,
11 systems, and components and their locations. And we
12 added missile parameters for RWA-IIa structures.

13 There were no RAI questions in this
14 section.

15 Next slide, please. Now, I will turn the
16 presentation over to Daniel Diefendorf.

17 MR. DIEFENDORF: Hello. My name is Daniel
18 Diefendorf. I have 12 years of nuclear mechanical
19 engineering experience. I've been at NuScale for the
20 past 10 years and I'm the subject matter expert for
21 the piping design and analysis. Prior to that, I had
22 two years of experience performing pipe stress
23 analysis in the petrochemical industry, and prior to
24 that, two years of experience in the design,
25 engineering, organization at San Onfre Nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Generating Station.

2 I'll be presenting the next slide on
3 Section 3.6, "Protection Against Dynamic Effects
4 Associated with Postulated Rupture of Piping."

5 As far as differences from the DCA, our
6 entire pipe rupture hazards analysis has been updated
7 using the US460 design inputs.

8 Methodologies were largely the same, with
9 the primary difference being that leak-before-break
10 methodology was replaced with Branch Technical
11 Position 3-4 B.1(ii) methodology. That's for
12 containment penetration areas for the steam generator
13 system, main steam and feedwater lines, and site
14 containment.

15 There were three RAIs in this section,
16 none of which resulted in technical changes to the SDA
17 and two of which resulted in no changes at all.

18 The first RAI provided additional
19 information related to removing LBB from the design,
20 including providing stress analysis results for the
21 affected lines.

22 The second provided information related to
23 the leakage detection systems. The last provided
24 additional information related to the break exclusion
25 zone requirements, specifically, in the area between

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the containment isolation valves and the containment
2 vessel.

3 For the audit, there were five question
4 submitted, primarily dealing with clarifying the
5 differences between the two designs for the high
6 pressure hazards analysis, including providing sample
7 stress analysis for the US460 design.

8 Only editorial changes were made as a
9 result of the audits.

10 I will pass it back to Peter Shaw for the
11 next --

12 MEMBER HALNON: Daniel, before you get
13 finished, can you help me understand the decay heat
14 removal system? You made a statement in there that it
15 was manufactured from piping products, but it was not
16 considered -- the piping system was considered a major
17 component before it was excluded. Just help me
18 understand that rationale.

19 MR. DIEFENDORF: Right. So, you're
20 talking about the decay heat removal condenser --

21 MEMBER HALNON: Right.

22 MR. DIEFENDORF: -- and the application of
23 BTP 3-4 B.1(ii) containment penetration area. For
24 that, we apply that criteria to piping and we don't
25 apply it to, say, the vessels or in this case the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 condenser.

2 MEMBER HALNON: Yes, I got that.

3 MR. DIEFENDORF: Right.

4 MEMBER HALNON: That's what the statement
5 said. Why not? I didn't look at the 3-4. Is it
6 within the bounds of what that's allowable? Or is
7 that --

8 MR. DIEFENDORF: So, yes, that criteria is
9 for piping. It's for piping which is designed to ASME
10 piping rules. It uses conservative stress criteria
11 for when you use the piping design rules, for example,
12 and we apply that only to areas that are covered by
13 the piping design specification.

14 MEMBER HALNON: Okay. So, you didn't
15 postulate breaks in that because it fell in the
16 condenser, because it fell within that criterion that
17 you just talked about?

18 MR. DIEFENDORF: That's correct. So, the
19 pipe break criterion BTP 3-4, it's applied to piping
20 systems to prevent, to eliminate the postulation of
21 ruptures in areas that are more likely to break, is
22 the way it's put, which is the terminal end of piping
23 systems, so that the condenser doesn't behave like a
24 piping system traditionally. But the connection for
25 the piping to the inlet of the condenser, that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 within the scope.

2 MEMBER HALNON: Okay. Thanks.

3 DR. BLEY: Hey, it's Dennis again. Ron
4 Ballinger, can I ask you a question? Did we review
5 BTP 3-4? I don't remember.

6 The ideas they're talking about are very
7 familiar, but where I'm hanging up is we're also going
8 to see at some point a PRA that looks at events of
9 very rare, 3 times 10 to the minus 5, minus 6, minus
10 7 kind of events. I don't know if this condition,
11 B.1(ii), means they are that rare or not. And if
12 they're not that rare, then they need to be in the PRA
13 and not just dismissed out of hand, if you're going to
14 do a PRA.

15 Can we say anything about the extent of
16 conservatism in 3-4? I just don't know it.

17 MEMBER BALLINGER: I do remember the
18 review, but you've got me on the details. I would
19 have to go back and check. In fact, I have it. If we
20 have a break, I'll go find out.

21 DR. BLEY: Okay. Then, for NuScale, I
22 think some of us will probably want to look at that
23 when it comes to thinking about what's in the PRA at
24 some later point in time.

25 MEMBER MARTIN: I had a clarification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 question. So, with the move from leak-before-break to
2 BTP 3-4, leak-before-break requires the leak detection
3 system. Has there been any change to the leak
4 detection system in this move or is it still way it
5 was approved originally?

6 MR. DIEFENDORF: This is Daniel
7 Diefendorf. This was brought up in the RAI, as
8 indicated on the slide. Essentially, the leakage
9 detection system described in the DCA was relaxed
10 because we were no longer using the LBB. In that RAI,
11 we explain that the design of the leakage detection
12 system has not changed and we still comply with
13 Regulatory Guide 1.45 with regards to being able to
14 detect degradation of the reactor coolant pressure
15 boundary.

16 Just the sensitivity requirements have
17 been relaxed because we are no longer utilizing a core
18 break. But the design has not changed.

19 MEMBER MARTIN: Okay. Is it considered
20 safety-related?

21 MR. DIEFENDORF: The leakage detection
22 system? I would have to ask that question.

23 CHAIR KIRCHNER: I was going to ask it a
24 little differently. There still would be a Tech Spec
25 on leakage. So, could you just give us a feeling,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Daniel, what the change in the leakage detection rate
2 might be if it's, quote-unquote, "relaxed"? Is it
3 like a gallon an hour? I'm trying to remember off the
4 top of my head what it was for the DCA. I think it
5 was .5 gallons per hour.

6 MR. DIEFENDORF: Okay, I am going to pass
7 these questions related specifically to the leakage
8 detection system to --

9 CHAIR KIRCHNER: But it would still show
10 up in Tech Specs, and then, there it would be a
11 question of --

12 MR. DIEFENDORF: Correct.

13 CHAIR KIRCHNER: -- what that rate is.

14 MR. DIEFENDORF: Right.

15 CHAIR KIRCHNER: I just don't remember the
16 DCA rate.

17 MR. DIEFENDORF: So, I'll pass this to --

18 MR. GRIFFITH: This is Thomas Griffith,
19 Licensing Manager. Yes, RCS operational leakage is in
20 Tech Spec 345. And the limit for unidentified leakage
21 is .5 gallons per minute. Still looking back at the
22 DCA, I believe that remains unchanged, but it's .5
23 gallons per minute unidentified leakage. And
24 obviously, there's a requirement for no pressure
25 boundary leakage as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Okay. I cut myself off.
2 Excuse me, Tom. Just when we say something is
3 relaxed, it begs the question, relaxed to what? It
4 sounds like you're using the same tech spec for that
5 particular parameter. Thank you.

6 MR. DIEFENDORF: I will now pass it back
7 to Peter Shaw.

8 MR. SHAW: Once again, Peter Shaw. We're
9 going over Section 3.9 now, which is 3.9.1. It is the
10 "Special Topics for Mechanical Components."

11 For these, there were changes to the
12 transients for the --

13 MR. BURKHART: Can I interrupt you for
14 just one second? I'm sorry. This is Larry Burkhart
15 from the staff.

16 I believe the court reporter had her hand
17 up. I just want to make sure we're addressing
18 concerns. Allegra?

19 COURT REPORTER: May I please ask people
20 to identify themselves when speaking inasmuch as their
21 camera is off?

22 MR. BURKHART: Thank you.

23 MR. SHAW: This is Peter Shaw speaking
24 once again. So, for 3.9.1, for "Special Topics for
25 Mechanical Components," there were changes to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 transients from the DCA.

2 There were transients added, one for the
3 density wave oscillations, for loss of feedwater,
4 initial test program, secondary leakages tests, and
5 control rod drive system piping failure.

6 Transients were removed for hydrogen
7 detonation and hydrogen detonation with deflagration-
8 to-detonation transition.

9 And there were changes with the cycle
10 changes for the containment flooding and drain, power
11 ascent from hot shutdown, and turbine trip without
12 bypass.

13 There were three audit questions resolved.
14 There were no RAI questions.

15 Next slide, please. As stated before,
16 Section 3.9.2, "Dynamic Testing" --

17 MEMBER BALLINGER: This is Ron. Could you
18 back up one slide? I'm going through BTP 3-4 at the
19 same time. With regard to the deflagration-to-
20 detonation transition, did that require any change in
21 design and configuration?

22 MR. SHAW: That did. That is the
23 inclusion of the passive autocatalytic recombiners
24 that are now in the SDA, which is why that transient
25 was removed. And that will be discussed more in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Chapter 6.

2 MEMBER BALLINGER: I got it. Okay. Thank
3 you.

4 MR. SHAW: Yes. Next slide. Section
5 3.9.2, "Dynamic Testing Analysis." This is going to
6 be covered at a later meeting.

7 Next slide, please. Section 3.9.3, "ASME
8 Code Class 1, 2, 3 and Non-Code Components, Supports,
9 and Core Support Structures." The most significant
10 difference was the update to the 2017 edition of the
11 ASME BPVC.

12 Audit results. There were 12 audit
13 questions that were resolved. There was one RAI and
14 that response has been submitted and completed. This
15 provided additional information for the RPV flange
16 bolted connections. There were no design changes
17 associated with this RAI.

18 Next slide, please. 3.9.4, "Control Rod
19 Drive System." Differences from the DCA, the most
20 significant one identified was the change from a
21 welded connection to a bolted connection.

22 There were seven audit questions that were
23 resolved in this section. For the RAIs, there were
24 two RAI questions.

25 The first, 3.9.4-8, provided additional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 information for the steam generator set screws. As a
2 result of this RAI, there were additional augmented
3 inspections that were added that visually examined the
4 set screws to verify that they don't fall out during
5 operation.

6 The next RAI, 3.9.4-9, this provided
7 additional information for the control rod drive
8 mechanism housings and their associated connections.
9 No changes to the bolted connection. There were no
10 changes to the SDAA.

11 DR. BLEY: It's Dennis Bley again. Can
12 you just tell us a little about why you switched from
13 a welded to a bolted connection on the CRDMs?

14 MR. SHAW: It was a manufacturing change
15 specific to the modular construction, including a
16 bolted connection was seen as optimal for our vendors.

17 DR. BLEY: Okay. Thank you.

18 MR. SHAW: Next slide, please.

19 CHAIR KIRCHNER: While you're on that,
20 Peter -- this is Walt Kirchner -- when you go from
21 welded to bolted, does that incur additional
22 inspection requirements and such, because we're
23 dealing with a borated system?

24 MR. SHAW: So, that, actually, is covered
25 in a later section, 3.1.3, where we did address that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 type of concern from the NRC. It is related to this
2 and we can discuss that more in that particular
3 section.

4 CHAIR KIRCHNER: Good. Thank you. Just
5 hold it for then.

6 MR. SHAW: Yes. Next slide, please.
7 Section 3.9.5, for the "Reactor Vessel Internals."
8 Differences from the DCA. The upper steam generator
9 support. This was reclassified from an internal
10 structure to the Class 1 support.

11 There were no audit questions or RAI
12 questions for this section.

13 Next slide, please. And then, Section
14 3.9.6, for the "Functional Design Qualification and
15 Inservice Testing Programs for Pumps, Valves, and
16 Dynamic Restraints."

17 Once again, this was a Code update,
18 updated the ASME OM Code from 2012 to 2017. Updated
19 ASME QME-1-2017. And updated requirements from a
20 regulation change for 10 CFR 50.55a for new reactors.

21 There were 16 audit questions and no RAIs.

22 MEMBER HALNON: Peter, this is Greg
23 Halnon. Way back when -- and I'm talking a decade or
24 more -- when NuScale first started, they said that not
25 all 12 or all 6 modules would be built and operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 at the same time. Is that still the case?

2 MR. SHAW: Are you talking about during
3 construction? Or are you talking about during --

4 MEMBER HALNON: Yes, we were talking about
5 having one module built, getting that in operation to
6 help finance the other modules, and whatever the case
7 may be. But, nevertheless, is it possible there would
8 be less than six modules built?

9 MR. SHAW: I can't really speculate on
10 that, just because some of that information is not
11 available. It would be up to the customer. I can say
12 that, by and large, it would be that all -- because of
13 ITAAC and because of the necessity for how you onboard
14 a plant, it's going to be all operating at the same
15 time.

16 MEMBER HALNON: I'm setting you up. I
17 should have asked the question first. The
18 frequencies, IST frequencies, and whatnot, were set as
19 if all six modules were operating. What if they're
20 not? Will that analysis you do with the test
21 frequencies still be done?

22 MR. SHAW: But that's largely the
23 responsibility of the COL applicant and the customer
24 for whenever they get into the in-service tests. The
25 frequency and outages, and what have you, that's all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 going to be determined by the applicant. There's only
2 so much --

3 MEMBER HALNON: But throughout this thing,
4 all of the frequencies for the HOVs, ECCS valves were
5 all grouped plantwide to optimize the testing. If
6 someone only puts three in, then that whole analysis
7 has to be redone relative to the amount of data that
8 will be coming in for the frequencies to be there.
9 So, it seems like a pretty significant change. Is
10 that real clear to an applicant, that that's going to
11 be potentially a big change in the amount of testing
12 you're going to have to do in that analysis of the
13 frequencies?

14 MR. SHAW: I would like Eric Lantz to
15 answer on the line to provide some additional context.

16 MR. LANTZ: This is Eric Lantz, licensing
17 engineer at NuScale. Yes, with fewer modules, you are
18 going to experience higher inspections of the valves
19 per module. And in the SDA, we do specify, in fact,
20 the IC program. The valve grouping is as required by
21 mandatory Appendices 1, 2, and 4. So, yes, if an
22 applicant has fewer modules, then they're going to end
23 up with higher valve inspections per module, based on
24 those groupings.

25 MEMBER HALNON: Okay, and that's real

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 clear. I wasn't clear when I went through it, and I
2 can tell you I don't know it as well as you do. So,
3 that's real clear that those testing frequencies for
4 the Code are going to be potentially much higher,
5 especially if you've only got one module, which would
6 change a lot of the dynamics of personnel, maintenance
7 personnel, programs, engineering programs, and other
8 things. So, if that's clear, that's fine.

9 CHAIR KIRCHNER: Dennis, do you have your
10 hand still up?

11 DR. BLEY: I do. A related question: I'm
12 sure I know the answer, but just to confirm, if I come
13 in and say, "I want to buy one module and I'll be
14 going up to three, but I'm never going to go to 06,"
15 my shared systems will be the same as that that's been
16 analyzed and built for a plant that's going to have
17 six modules, correct? I won't be able to make changes
18 to the shared systems because right now I don't think
19 I'm going to use all six.

20 MR. SHAW: I think that would be up to a
21 COL applicant at the time to --

22 DR. BLEY: Well, I can buy anything I want
23 any way I want it? Okay. Thank you. That surprised
24 me. And it also makes me worry more about
25 standardization.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. SHAW: Well, that's not the statement.
2 The statement is that the standard design has certain
3 expectations for a six-module operation. If a COL
4 applicant went to operate either in a different
5 configuration or less than six modules, that would
6 need to be addressed in their application as a change
7 from the standard site.

8 DR. BLEY: Clearly, yes.

9 MEMBER BIER: Hi. This is Vicki Bier. I
10 wanted to follow up on Dennis' question and some of
11 the earlier discussion.

12 I think part of what ended up with such
13 lack of standardization in the current fleet was kind
14 of an incentive issue that, you know, as Dennis
15 mentioned, yes, each site or each utility could put in
16 their own request for changes that they wanted, but it
17 was also kind of in the interest, especially of the
18 AEs who were making money doing those design changes.

19 And I would have thought that part of the
20 rationale for going to greater standardization in nth-
21 of-a-kind was an entirely different business model.
22 And that if the business model is, you know, we make
23 our money by selling a larger number of units, and
24 those units have to be the same, and if somebody wants
25 something different, unless it's a really big order,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 or whatever, we're not going to change our
2 manufacturing processes and our design to meet that.

3 And, you know, this is really more of a
4 business question than a safety question. But do you
5 folks have kind of a business strategy about
6 standardization versus customization?

7 MR. SHAW: I would say that a business
8 strategy for the purposes of conversation about the
9 standard design application being pursued right now
10 isn't necessarily subject to this presentation.

11 The SDA is a six-module plant. It will be
12 approved as a six-module plant and there are business
13 plans for how you onboard it and how you test, and
14 eventually, reach commercial production of power.

15 Again, for purposes of standardization,
16 COL applicants can't seek departures from that if
17 there are business cases that are seen as more optimal
18 for them. But for the purposes of this presentation,
19 this is a six-pack design, and the six-module design
20 is approved.

21 MEMBER BIER: Thank you.

22 MEMBER BALLINGER: This is Ron Ballinger
23 again. There's a NUREG that's coming out, 1.220,
24 which endorses the OM2 Code, which allows that to be
25 used in lieu of 55a. Is that something that's on your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 radar? The QME-1 is still in there, but there's a
2 newer, 2024 version.

3 MR. SHAW: Not for this application. We
4 are just seeking 2017. I'm not familiar with what the
5 differences are. If you want additional
6 clarification --

7 MEMBER BALLINGER: The (audio
8 interference) code is explicitly designed to allow for
9 advanced reactors, non-light water reactors.

10 MR. SHAW: Right.

11 CHAIR KIRCHNER: I feel like I should make
12 a statement here. We are examining safety-related
13 issues. Where standardization comes in and can be a
14 factor in the safety and performance of the plants is
15 that customization in the balance of plant often is an
16 initiating event, and a subsequent transient, in fact,
17 may have safety implications.

18 And I just remember back to my time as a
19 consultant to the TMI Commission, that one of the
20 recommendations was to go in the direction of
21 standardization, such that incidents and initiating
22 events could be for a standardized design shared
23 amongst many utilities, or whoever the COL applicant
24 is. And that is beneficial fleetwide in terms of
25 reducing incidents and transients that challenge

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 safety systems.

2 So, the spirit of some of this
3 questioning, at least where I was starting earlier
4 with Andrea's presentation about floods versus rooms,
5 is not to have a COLA applicant go change, for
6 example, the waterproof integrity of your battery
7 systems. And so, that's the spirit of our questions.

8 We're not testing your business case, but
9 I think at some subsequent time there are questions
10 about the actual installation and deployment of the
11 modules. For example, if you bring on all six at once
12 or do you bring them on sequentially? And how you do
13 that does have some safety implications.

14 But, again, our focus here is on safety.
15 And one of the takeaways from TMI was that the
16 industry would benefit from standardization. That led
17 to the development of 10 CFR 52, and here you are,
18 under 52, making an SDA application. So, that's the
19 interest of this Committee.

20 I just thought I would make that statement
21 for the record.

22 MR. SHAW: Right. And that's one of the
23 focuses of the NuScale modular design is that your
24 safety-related components are as limited as possible
25 to the modules. And for the purposes of the rest of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the plant-shared systems, those are made as limited
2 as possible for it, but they can be isolated, models
3 can be isolated during operation. Certainly when
4 we're onboarding it will be a sequential process
5 where you will not have all six turning on at the
6 same time. You do one, two, three as they arrive on
7 site. So that's the intention behind a lot of this
8 is that the COL applicant can finish a lot of his
9 designs for some of these ancillary-type components
10 without impacting the safety basis for it, and that's
11 been the intention of the design.

12 CHAIR KIRCHNER: Okay, but just note that
13 they could impact the performance and safety of your
14 system if they deviate in substantial ways.

15 MR. SHAW: Yes. Yes. And there's
16 evaluation processes --

17 CHAIR KIRCHNER: So I think what you're
18 feeling from us is the push to have you define what's
19 important to safety and get that configuration
20 standardized. I can think right off the top of my
21 head several systems that are outside your module but
22 could have an impact, like CVCS and how that's
23 implemented. So the expectation, at least the first
24 order is, at part, would be part of the standard
25 design. So I think you -- I think you get our point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. SHAW: Understood. Yes.

2 CHAIR KIRCHNER: Okay. Thank you. Go
3 on.

4 MR. SHAW: That concludes 3.9.6. I want
5 to pass it over to Gene Eckholt.

6 MR. ECKHOLT: Good afternoon. My name is
7 Gene Eckholt, licensing engineer with NuScale Power.
8 I've been with them almost three years. I've got 45
9 years' experience in the industry. Started at
10 Consumers Power at Palisades, Midland and spent the
11 rest of my career at NSP, Xcel Energy, mainly
12 supporting Prairie Island but also Monticello to a
13 limited extent. Also obtained a senior reactor
14 operating license at Prairie Island as well.

15 I'll be presenting Sections 3.10, 3.11,
16 3.12, 3.13, and Appendix 3C. We'll start with
17 Section 3.10, seismic and dynamic qualifications of
18 mechanical and electrical equipment. There weren't
19 any real significant changes between DCA and SDA.
20 The adopted newer versions of regulatory guidance and
21 industry standards, there were 3 COL items related to
22 administration of the qualification program that were
23 removed. COL application will incorporate the
24 seismic and dynamic qualification program as
25 described in the SDA design by reference. There's no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 need for separate COL items. The information that
2 would be needed is contained in the SCA.

3 There were -- there was only one audit
4 question, it was resolved, and there were no RAI
5 questions.

6 Next slide.

7 Section 3.11 describes the environmental
8 qualification of mechanical and electrical equipment.
9 The most significant change between DCA and SDAA is
10 the NuScale environmental qualified equipment was
11 updated to reflect the U.S. post-60 design. That's
12 a significant portion of that section, and that was
13 most significantly impacted. There was 11 audit
14 questions resolved. Three items here, noted, that
15 resulted from those audits. We created new equipment
16 qualification zones for the control building and for
17 the harsh environments that only contain electronic
18 equipment. We clarified the application of some of
19 the industry standards, and we evaluated design-basis
20 accident dose contributions for the limiting
21 collapsed liquid level event. And there were no RAI
22 questions.

23 Next slide.

24 Appendix 3C is related to 3.11. It
25 describes a methodology for environmental

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 qualification of electrical and mechanical equipment.
2 The significant differences from the DCA were the
3 tables. The back of Appendix 3C were updated to
4 reflect environmental qualification zones, harsh/mild
5 environment zones, post-accident operating times,
6 normal operating conditions, design-basis event
7 environment conditions, and limiting design basis
8 accident environmental qualification radiation dose.

9 There was one audit question that was
10 resolved, and there were no RAI questions.

11 Next slide.

12 MEMBER ROBERTS: Hey, this is Tom
13 Roberts. If you go back to the previous slide,
14 what's the difference between those last two bullets?
15 It was limiting -- here, design-basis event of
16 environment conditions and then limiting design-basis
17 accident environmental qualification radiation dose.
18 How do those differ?

19 MR. ECKHOLT: I'm going to ask Kevin
20 Fischer from NuScale Engineering to respond to that.

21 MR. FISCHER: Hi. This is Kevin Fischer.
22 When I introduced myself earlier, I did fail to bring
23 up my background. I did four years here at NuScale
24 in DQ and testing and then before that I was at
25 Bechtel at the Hanford Site for six years in nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 safety and radiological engineering, as well as a
2 start-up for the last two years. And so on the note
3 with design basis event environmental conditions,
4 that has to do with just throughout the facility the
5 changes in the -- all the parameters that had to do
6 post-accident for the limiting design basis
7 environmental qualification dose rates. Those are
8 specifically for areas of concern in the highest
9 experienced dose rate in that area. And so, in
10 certain cases, we only had a single radiological dose
11 that was provided. And we expanded that out to
12 provide additional dose rates over time to reduce the
13 eventual dose rate as those conditions changed.

14 MEMBER ROBERTS: Okay, thank you. So
15 neither of those assumes a core damaging accident?
16 Is that correct? Because if you look at the history
17 of your -- DCA had kind of a novel approach where the
18 environmental conditions for design basis event
19 didn't include a core damage assumption and kind of
20 relegated that assessment to Chapter 19. But I was
21 just trying to understand that last bullet is not
22 intending to cover core damage scenarios. It's just
23 different aspects of the design basis, the
24 environment, in different places. And that's where
25 I'm finished with my question. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. FISCHER: That's correct.

2 MR. ECKHOLT: Next slide. Section 3.12
3 discusses the design of ASME Class 1, 2, and 3 piping
4 systems, piping components, and associated supports.
5 The most noteworthy difference of DCA and SDAA was we
6 removed the reference to NUREG 1367, functional
7 capability of piping systems. There were 12 audit
8 questions resolved, and one of those clarified how
9 the functional capability guidance of that NUREG is
10 addressed by NuScale. There were no RAI questions.

11 Next slide.

12 CHAIR KIRCHNER: This is Walt Kirchner.
13 Could you just elaborate what the impact, if any, of
14 removing the reference to 13.67 means? In terms of
15 approaches or any substantive change in -- to any of
16 the safety-related --

17 (Simultaneous speaking.)

18 MR. DIEFENDORF: This is Daniel
19 Diefendorf. It didn't have any impact on the design
20 of any piping system. The reason we removed the
21 reference and instead explained how we addressed the
22 NUREG 13.67 concerns, separately, in that audit
23 response. Specifically, it only provides guidance --
24 or the very first criteria in there that is that it's
25 only for reversing dynamic loads. So right off the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 bat, essentially you're excluded from having any
2 functional capability criteria for loading
3 combinations that include a non-reversing dynamic
4 load. We weren't the first applicant to run into
5 that issue.

6 So instead of referencing NUREG 13.67, we
7 went through the criteria and showed how they were
8 addressed in other ways already either by -- they had
9 been addressed by the ASME code and since the
10 original report in 1992 or they were addressed by
11 separate regulatory guides that we conform to or --
12 essentially that, yes. Or by our design inherently.

13 CHAIR KIRCHNER: Okay. That's what I
14 thought. I thought you had all backed down the ASME
15 codes as appropriate. Thank you.

16 MR. ECKHOLT: Okay, next slide. Section
17 3.13 discusses Class 1, 2 and 3, threaded fasteners.
18 The most noteworthy change is containment pressure
19 vessel retaining threaded fasteners are now examined
20 in accordance with the ASME Section 11, subsection
21 IWE. There were three audit questions resolved. And
22 there was one RAI that resulted in the addition of
23 augmented visual inspection or examination
24 requirements for ASME Class 1 threaded inserts and
25 seal welds.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Gene, would you
2 elaborate and just share with us what that impacts?
3 It's mainly containment vessel, right? What about
4 the RPV?

5 MR. ECKHOLT: I'll ask Pete Shaw to speak
6 to that. This is your question from earlier about
7 the --

8 CHAIR KIRCHNER: Yes.

9 MR. SHAW: This is Peter Shaw speaking.
10 So for the purposes of the threaded inserts on this
11 account, if the insert is inside of a carbon steel,
12 stainless steel laminate construction, the threaded
13 insert, itself, is stainless steel, and then there's
14 a seal weld applied around it to maintain continuity
15 of the corrosion barrier.

16 What was identified during the RAI and
17 the questions asked that, you know, what if there is
18 a corrosion of that seal weld, if for some reason
19 there was a degradation. There are certain access
20 ways and man-ways during operations that are
21 regularly opened for inspection and access. And those
22 are being used as representative of the condition of
23 those seal welds. if there is a degradation noted in
24 those particular welds, there is then an expansion
25 criteria that's applied to look at other threaded

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 inserts in other portions of the reactive vessel.
2 Does that answer your question?

3 CHAIR KIRCHNER: Yes. Thank you.

4 MR. ECKHOLT: That concludes NuScale's
5 presentation for Chapter 3.

6 CHAIR KIRCHNER: Greg, do you have any
7 further questions?

8 MEMBER HALNON: No. No further
9 questions.

10 CHAIR KIRCHNER: Members? Vesna, Vicki,
11 have you any further questions on Chapter 3?

12 MEMBER DIMITRIJEVIC: No.

13 MEMBER BIER: No, I don't.

14 CHAIR KIRCHNER: Okay, and also I extend
15 that to our consultants. Dennis?

16 DR. BLEY: No, thank you.

17 CHAIR KIRCHNER: All right. Well, thank
18 you very much. We'll turn to the staff now, right?
19 Yes, so, there will be, for those online, a pause
20 here, where you're going to change out our NuScale
21 presenters with our NRR staff. Thank you.

22 (Whereupon, the above-entitled matter
23 went off the record at 2:14 p.m. and resumed at 2:17
24 p.m.)

25 CHAIR KIRCHNER: Whenever you're ready,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 go ahead.

2 MR. CHOWDHURY: Good afternoon. My name
3 is Prosanta Chowdhury. I am the NRR --

4 CHAIR KIRCHNER: Hold that closer,
5 please.

6 MR. CHOWDHURY: NRR project manager. I
7 have been with NRC for 19 years and 7 months, and out
8 of those, I've been a project manager for 16 years.

9 This will be the NRC staff's presentation
10 on Chapter 3, Sections -- subsections 3.7, 3.8, and
11 3.9.2 of the NuScale SDAA, standard design approval
12 application, that the staff has reviewed.

13 So I'll go over the slides, and if there
14 are technical questions, then staff, some staff are
15 present in this room and some are online.

16 As for my educational background, I have
17 a master's degree in nuclear engineering and a
18 master's degree in electrical engineering. I also
19 worked for the State of Louisiana for 18 years in the
20 radiation protection area dealing with (audio
21 interference).

22 So with that, if we can go to the next
23 slide, please.

24 So this slide shows the staff who
25 actually performed the review, and I have here only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 four of them, but others have presented to the
2 audience and online. So for the record I'll read the
3 names, please. So Michael Breach, George Wang,
4 Gordon Curran, John Honcharik, Kaihwa (Robert) Hsu,
5 Chakrapani Basavaraju, Nicholas Hansing, Raul
6 Hernandez, Cory Parker, Thomas Scarbrough, Edward
7 Stutzcage, Jorge Cintron-Rivera, and Sheila Ray.

8 Next slide, please.

9 I'm the project manager, as I mentioned
10 already, and Getachew Tesfaye is also present. He's
11 the lead project manager for this project.

12 Next slide, please.

13 So this is an overview of the staff's
14 view of Chapter 3, NuScale SDAA Chapter 3, except
15 Sections 3.7, 3.8, and 3.92. From this point forward
16 I will not say except 3.7, 3.8, and 3.9.2 because
17 I've already established that. That part the staff
18 already reviewed.

19 So NuScale submitted revision 1 of the
20 FSAR Chapter 3 on October 31st, 2023. NuScale
21 performed a regulatory audit as part of the review of
22 Chapter 3 from March 2023 to December 2023 when you
23 closed the audit.

24 Questions raised during the audit were
25 resolved within the audit. Seven RAIs were issued.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Staff completed the review of Chapter 3 and issued an
2 advanced safety evaluation to support the ACRS
3 Subcommittee.

4 Next slide, please.

5 Staff evaluated the following sections.
6 I don't see 10, 11, 12, 13 -- okay, they're coming.
7 Yes.

8 So as part of 3.11, Appendix 3C was also
9 reviewed. So these are the sections NuScale already
10 went through. They're in exact same sequence, so I'm
11 not going to read those.

12 Next slide, please.

13 So Section --

14 Previous slide. Reverse one. Yes.

15 Section 3.1 is conformance with NRC GDC,
16 General Design Criteria, and these are discussed in
17 our sections of the safety evaluation.

18 Next slide, please.

19 3.2, the classification of structures,
20 systems, and components. There are no significant
21 differences between the NuScale DCA, FSAR, and SDAA
22 FSAR, and NuScale provided SSC seismic classification
23 of Category I, II, and III and there are some tables,
24 3.2-1 and 3.2-2, consistent with regulations and
25 guidance, and the SDAA's safety evaluation conclusion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is the same as the Design Certification Application
2 SE conclusion.

3 Next slide, please.

4 Section 3.3, wind and tornado loading.
5 Significant differences are highlighted here. High
6 wind speed, 190 miles per hour, and maximum tornado
7 wind speed, 270 miles per hour. Using our American
8 Society of Civil Engineering/Structural Engineering
9 Institute 7-16 to establish the wind load pressure
10 for RW-IIa structures. NuScale provided adequate
11 justification for applying the wind load pressure on
12 the RW-IIa structures by using ASCE/SEI 7-16. The
13 SDAA conclusion is the same as the DCA conclusion.

14 Next slide. Section 3.4.1, the technical
15 staff is online if there are any questions for this
16 specific section. Significant differences listed
17 here, flood analysis methodology defined bounding
18 flood levels for building zones. Individual rooms
19 not discussed, such as battery rooms or instrument
20 rooms. Maximum SDA of flood heights are
21 significantly greater than DCA, and location of SSC
22 subject to flood protection not identified.

23 However, NuScale provided flood analysis
24 results table of zone, limiting flood source, and
25 maximum flood height. There are three COL items,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 3.5-1, 3.5-2, 3.5-3, confirm the final location and
2 mitigation of SSC subject to flood. So that will be
3 the responsibility of the COL applicant.

4 The SDAA safety evaluation conclusion is
5 the same as the DCA with additional COL applicant to
6 further evaluate the SSC protection from flood
7 levels.

8 MEMBER HALNON: This is Greg. Can you
9 elaborate, what was the DCA conclusion? If you can't
10 -- if you don't see the data on the specific rooms
11 like battery rooms, for instance, and you don't know
12 the final location of the mitigation equipment. How
13 can we make the same conclusion that it's okay?

14 MR. CHOWDHURY: So thank you for the
15 question.

16 Gordon Curran, are you online?

17 MR. CURRAN: Yes, I am. This is Gordon
18 Curran from NRR. I'm from the Containment Plant
19 System Branch. I've been at the NRC for 16 years and
20 in the industry for 24 years.

21 The same conclusion in the DCA is with
22 the conditions of the COL applicant because as you
23 have heard from NuScale, the COL applicant will
24 define later where the components are listed. So
25 that's why I indicated here with the addition of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 COL applicant's scope.

2 MEMBER HALNON: Okay. I think it's easy
3 to say that it's going to be okay because they're
4 going to figure it out later. I guess it goes back
5 to our earlier discussion. The level of
6 standardization is in its (audio interference)
7 platform and safety case for the whole plant. It
8 sounds like this is a big different, I mean this
9 could be a potential effect, not just in flood
10 levels. I mean, you can make the flood levels okay,
11 the full protection okay, but you could be affecting
12 another piece of design. How are you connecting us
13 those dots to make sure that they're not protecting
14 the significant equipment at the expense of some
15 other conclusion that you're making somewhere else?

16 MR. CURRAN: Yes, this is Gordon Curran.
17 We tried numerous times to get the information from
18 NuScale, but NuScale decided that their design is to
19 push the details off to the COL applicant.

20 One thing that I had noted in this slide
21 that was of particular interest is the significant
22 difference of the flood heights in the DCA as opposed
23 to the SCA. The DCA itself showed the rooms, and it
24 had it listed out in a table, the rooms with
25 batteries and there was a flood height of -- I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 it was around 24 inches for most rooms. However, for
2 the NuScale, the SDA design, the flood heights in
3 many of -- well, a lot of the rooms are anywhere from
4 4 feet to 15 feet, not inches. They are feet. So
5 many of the rooms with lower elevations could be
6 essentially submerged.

7 Now there's no discussion as to what
8 components are in these rooms and that was a concern
9 that the staff had had.

10 MEMBER HALNON: I understand your --
11 saying the conclusion is the same based on the
12 promise that the COL applicant will make it all okay.
13 I guess from a reviewer perspective, how are you
14 ensuring that flood protection is maintained, but
15 it's not at the expense of some other critical
16 design, like I mentioned earlier, potentially the
17 (audio interference) and pump or the instrumentation,
18 the batteries, or something else that you could make
19 okay from a flood level, but you may be changing some
20 other critical design characteristics. How -- from
21 a reviewing perspective, how are you making sure all
22 those dots are connected?

23 MR. CURRAN: As a former reviewer
24 perspective, this can't be done at the SDA level
25 based on the extent of information that is provided.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: I understand that. You
2 can't do it now because you don't have the promise.
3 But how are you going to do that when an applicant
4 comes in for a COL? They're going to come in and say
5 this is -- the flood protection is fine because I
6 raised this above the 15-foot level. It used to be
7 at 2-foot plus 1 inch level. Now it's at 15 feet
8 plus 1 inch. How are you going to ensure that
9 Chapter 3.4.1 is satisfied, but some other chapter is
10 not, you know, because it's changed. You've changed
11 the standard -- something else in the standard
12 design.

13 MR. CURRAN: The NRC's review of the COL
14 design, we'll have to review it at that point, and
15 the COL will have to provide an additional flooding
16 analysis based on the --

17 MEMBER HALNON: Okay, I realize I'm
18 asking you a hypothetical, I just -- it's concerning
19 to me that so many things can be changed at the COL
20 level that will make this one parameter just fine,
21 but will change other things. So it comes back to
22 the, I guess, the customization aspect of it again.

23 MR. SHAW: This is Peter Shaw speaking.
24 I'd like to maybe provide a little bit more context
25 to this discussion. When we talk about the 3.4, it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the civil features associated with the design. When
2 you're asking about the equipment, you need to be
3 looking at 3 Charlie which is the environmental
4 qualification for it. So a change in flood height of
5 water level and that type of an impact would have to
6 impact Section 3 Charlie, and it would need to be
7 evaluated as such. So this equipment isn't just
8 going to be changed in absence of any sort of context
9 with the safety evaluation. It has to be changed
10 with considerations of the environmental
11 qualifications of the equipment. Does that provide
12 some assistance?

13 MEMBER HALNON: It provides a level of --
14 I understand that. Maybe it's just an overly
15 simplistic example of thermal hydraulics of raising
16 an instrumentation above a water level, maybe level
17 instrumentation or potentially a pump or some other
18 thermal hydraulic calculations and other seismic
19 designs two over one, all kinds of different things.
20 How is that all going to be connected up if you're
21 making just the change to make it a flood?

22 MR. SHAW: So there's a table in 3.4 that
23 describes the flood height as was described earlier.
24 Is my mic coming in okay?

25 CHAIR KIRCHNER: Actually, you stand a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 little --

2 MR. SHAW: Stand over here? Okay. So
3 when we're talking about Section 3.4 and if there's
4 change in the flood level heights based on a
5 requested sign change from COL applicant, that would
6 have impacts across the license. You're never going
7 to change just one section without also considering
8 other impacts to the license basis, as part of your
9 license basis consideration process and your
10 subsequent 50.59.

11 So for -- if you change a flood height,
12 in a particular room, based on a design change sought
13 by an applicant, you would also have to look at those
14 impacts in 3 Charlie and make sure that the equipment
15 that you have in those particular flood zones or
16 rooms is going to be still qualified for that
17 location. If it needs to be changed because the
18 flood height impacts that particular component, that
19 would then be assessed at a change in the table and
20 a change in the equipment.

21 MEMBER HALNON: Thanks, Peter. It just
22 feels like it's going to be a string that has to be
23 pulled through most of the chapters.

24 MR. SHAW: It does, yes.

25 MEMBER HALNON: And then that comes back

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to my concern about have you changed the overall
2 safety case based on the standardization of design?
3 I get it, that's going to be a lot of work, but you
4 have to.

5 MR. SHAW: Yes, and those are departures
6 that are reviewed as part of a COL application
7 process. There will be a review on that.

8 MEMBER HALNON: Potentially it seems like
9 you can almost -- you may not even recognize the
10 design at some point other than the big pieces of it.
11 Some of these things maybe even could flow into the
12 accident analysis as well. So I get it. It will be
13 a lot of work by the COL applicant. Thanks.

14 DR. SCHULTZ: Peter, this is Steve
15 Schultz. I thought in your earlier discussion you had
16 mentioned at the outset that moving from rooms to
17 zones was going to provide some simplification in the
18 design and regulatory review of the design at the COL
19 stage. Is that not right?

20 MR. SHAW: So is your question pertaining
21 to the -- so the change from the DCA to the SDA in the
22 flood zone analysis process --

23 DR. SCHULTZ: Yes. Yes.

24 (Simultaneous speaking.)

25 MR. SHAW: -- associated to the rooms.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 When it comes to discussing the process for the
2 standard design application, yes, that is seen as a
3 optimization for the analysis for the flood design.
4 When it comes to COL applicant changes, they will need
5 to evaluate those and its impacts to flood zones.

6 DR. SCHULTZ: In essentially the same way?

7 MR. SHAW: Yes.

8 DR. SCHULTZ: Thank you.

9 CHAIR KIRCHNER: It seems to me that we're
10 skirting an issue that's out there. I hope I have the
11 right acronym, the EDAS, whatever the battery system
12 is called, does have some functions important to
13 safety. Where those battery systems are located in
14 the reactor building is pretty important when you're
15 looking at things like flooding, fire, and other
16 hazards. So I find this, one member, a little
17 unsettling.

18 If I read these lines literally, SDAA
19 flood heights are significantly greater than DCA.
20 We're talking about internal flooding. We're talking
21 about a system that's important to safety. I have a
22 concern that this is kind of -- we're reviewing an
23 SDA, and we're leaving this to the COL even though
24 this has concerns that may impact safety. Seems to
25 me, going back to this issue of standardization, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this is going to have an impact. This would require,
2 depending on the layout, subsequent reanalysis by the
3 staff of whatever a COLA applicant submits. I think,
4 unless I'm missing something here, aren't we going
5 away from the whole objective of 10 CFR 52 and an SDA
6 application?

7 So, Getachew, maybe you can -- you've got
8 the perspective as the PM here.

9 MR. TESFAYE: Yes.

10 CHAIR KIRCHNER: Can you help us here?

11 MR. TESFAYE: Yes, thank you. This is
12 Getachew Tesfaye. So as opposed to the DCA, which is
13 required for the -- essentially complete design, SDA
14 Part 52 SDA regulation doesn't require that. So when
15 we defer something to the COL state that means we're
16 not making any regulatory finding on that item.

17 CHAIR KIRCHNER: Move your microphone
18 closer.

19 MR. TESFAYE: Oh, I'm sorry. Can you hear
20 me now?

21 CHAIR KIRCHNER: Yes, better.

22 MR. TESFAYE: So just to repeat what I
23 just said, as opposed to the DCA, which essentially
24 requires a complete design of this -- when you approve
25 this by design, SDA regulation doesn't require that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So the applicant chose to defer this to the COL
2 applicant, or any other applicant that references the
3 SDA design, could be a construction permit applicant.
4 They have to do that. So we're not making any safety
5 finding on this particular issue.

6 MEMBER HALNON: Yeah --

7 (Simultaneous speaking.)

8 MEMBER BIER: This is Vicki Bier.

9 MEMBER HALNON: Hold on, Vicki.

10 MEMBER BIER: Yes.

11 MEMBER HALNON: That last bullet says that
12 you made the same conclusion as the DCA, which is a
13 safety decision. I assume that you accepted the
14 design. So I'm just kind of reading the last bullet
15 there. The conclusion is the same. So and you're
16 telling me the conclusion was not the same.

17 MR. TESFAYE: With the addition of a COL
18 line. So that's the key piece.

19 MEMBER HALNON: It seems to be the entire
20 argument you're making is that it's not at all
21 standard. I got it. Okay. Never mind. Go back
22 again. COL applicant has a lot of work to do and the
23 staff will have a lot of work to do to receive it.

24 MEMBER BIER: Yeah, if I can follow up
25 now. This is Vicki. It sounds like one of the issues

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that's going to be affected is just regulatory
2 certainty, not that I think a lot of applicants are
3 going to submit inappropriate designs or whatever, but
4 just that the SDAA approval is more along the level of
5 it is possible to build this design safely rather than
6 this design is safe. And so then it's incumbent on
7 the COL applicant to say that their particular
8 implementation of the design is going to be safe. And
9 again, I would hope that it's straightforward, but it
10 does I think affect regulatory certainty.

11 DR. SCHULTZ: This is Steve Schultz again.
12 Vicki, just to follow up on your comment, anything
13 that is pushed out like this to the applicant later
14 on, where there will be, we hope, many applicants, is
15 going to increase the burden on both the design
16 process as well as the regulatory review. And any
17 time you take -- any time you assign regulatory
18 resources to this project versus another project,
19 you're reducing overall safety of the system. It
20 doesn't seem like the right thing to do. The more we
21 can identify and standardize the safety of a facility
22 and not have to do it time after time after time, the
23 better off we are. Just a general comment really.

24 MEMBER DIMITRIJEVIC: This is Vesna
25 Dimitrijevic. I just want to point something and then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'm -- because I'm now really, you know, a little --
2 start getting confused about the standardization. We
3 know that PRA in COLA for as-built, as-to-be-operated
4 plant is totally -- it could be totally different PRA
5 than what was submitted in DCA or SD. So there is
6 expectations that PRA will have to be redone when all
7 of those things are finished, the equipment is lay
8 out, the plant is built, and non-safety -- the
9 systems, the procedures, all of these things, and
10 written PRA will have to be redone. So the -- if the
11 PRA is a measure of the safety it should show this.
12 So I am not sure why are we now concern so much here
13 and we were not so concern in the -- when we were
14 doing DCA.

15 DR. BLEY: This is Dennis. I think the
16 issue people are tied up with here, Vesna, is not what
17 you say. What you say is true; it's going to have to
18 be redone in time to support this review, but what at
19 least I hoped was that it wouldn't have to be redone
20 as you went COL to COL, that there -- it would be a
21 standard plant and except for the site you wouldn't
22 have to do any update even -- and that's what seems
23 not to be true.

24 MEMBER DIMITRIJEVIC: But this is also
25 site issue, building, the layout, the flood risk for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 extent of floods.

2 DR. BLEY: But building layout should be
3 the same, but it is a site issue for sure.

4 MEMBER DIMITRIJEVIC: Well, that's the
5 standard design guarantees the plant will look exactly
6 the same when it's completed and everything be lay out
7 the same. I'm not sure about that. The whole
8 procedures will be the same and the -- so I'm just
9 trying to see what's a difference between DCA and
10 SDAA.

11 MEMBER HALNON: I get the external
12 flooding. This is internal flooding. And so to me it
13 should be the same.

14 MEMBER DIMITRIJEVIC: Well, internal flood
15 also depending on the pipe layout, doesn't that -- I
16 mean, you know?

17 MEMBER HALNON: Why would the pipe layout
18 be any different?

19 MEMBER PALMTAG: This is Scott Palmtag.
20 I'm a little confused too on -- it seems like you're
21 asking for things -- the final design isn't done yet,
22 but you're asking for things that aren't -- we don't
23 know yet. So these things aren't -- the pipe layout
24 is not known yet so we're not going to be able to ask
25 these questions until the final design is done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 That's the way NuScale approached this, is they just
2 said well, they'd just push this off to the COL. I
3 mean, I don't see any other way you could do it
4 because the final design isn't done yet. So I don't
5 even know the pipe layout should (audio interference).
6 I don't see an issue with what they've done.
7 Financially it may not be the best way, but --

8 (Simultaneous speaking.)

9 MEMBER HALNON: No, it's -- I agree,
10 Scott. This is Greg again. It goes beyond just the
11 pipe design. It is different instrumentation and
12 other things. And if it goes from 2 feet to 15 foot
13 in a room, and the room is 16 feet high, that's a
14 problem.

15 MEMBER PALMTAG: Well, yeah, but it goes
16 back to the design requirements, the equipment design
17 requirements. So they're going to have to show that
18 it's safe in the end. They just --

19 MEMBER HALNON: Yeah.

20 MEMBER PALMTAG: -- don't have enough
21 information.

22 MEMBER HALNON: Yeah. No, I agree. And
23 I don't want to push this to a more detailed standard
24 design, if you will, but what I was trying to get a
25 handle on is that the standardization of design in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 itself just to me is a safety platform for the plant
2 since the beginning of -- my plant is safe because
3 here's my standard design. And now what I'm seeing,
4 at least here -- I'm trying to get a clear definition
5 of what that is and what it isn't. And when you get
6 internal flooding -- I didn't see where things would
7 be changing from plant to plant. So my sense is that
8 when we walk into the NuScale 1, 2, 3, 4, 5, and 6,
9 they're going to be the same because they're all on
10 the same site. When it goes somewhere else, it's
11 going to be way different because of different --
12 something else.

13 So my point is does that affect the safety
14 case --

15 MEMBER PALMTAG: Yeah.

16 MEMBER HALNON: -- in some other system or
17 some other conclusion being made? I'm trying to get
18 a clear definition of what the standard is.

19 MEMBER PALMTAG: Maybe I see it a little
20 differently because I don't -- this is me; I'm
21 speculating, but I don't see this -- the different
22 designs are going to be different. I just see it as
23 the final design is not finished yet so they don't
24 know these things.

25 (Simultaneous speaking.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: -- first part is that you
2 don't -- we can't say that.

3 MEMBER PALMTAG: Yeah, that's true.

4 MEMBER HALNON: So I'm trying to find out
5 what they approved, what's been offered, and what is
6 the safety platform for the plant. And internal
7 flooding is just the one that to me seemed it
8 shouldn't be all that different. I will say, I mean,
9 I understand the work will get done. It will be a
10 safe design. It just may not be the same as X, Y, and
11 Z's plants.

12 MEMBER BIER: One other comment following
13 up on Walt's reflections back to Three Mile Island.
14 Again, this is Vicki Bier. I think one issue that we
15 have found in the U.S. compared to, say, France is
16 that in the long run the lack of standardization kind
17 of affects fleet safety because if there are
18 unexpected problems, you find it once and correct the
19 problem everywhere. And if you have insufficient
20 standardization, then every plant may have its own
21 unique problem, or many plants may have their own
22 unique problems, and they all have to be found and
23 fixed one at a time kind of.

24 And it's -- I think it can be an issue,
25 but it's not one that's easy to address in our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 regulatory system because the system is really looking
2 at the safety of the plant at the moment. But it's
3 licensed, and in the U.S. all of those plants were
4 judged to be safe enough. And the subsequent backfits
5 and reanalysis and whatever were a hardship to the
6 industry, but it didn't really disprove the original
7 licensing approval in any way.

8 So it's just kind of some perspective
9 that, yes, this could have fleet-level implications if
10 the differences between plants end up being
11 significant, but I think it's going to be difficult to
12 address that at the level of the SDAA or even the
13 individual COL applications.

14 MEMBER HALNON: Vicki, this is Greg.
15 Thank you. And, Scott, appreciate your perspective.
16 I think it's -- I'll make a promise. I won't bring it
17 up again. Because now I'm just really trying to get
18 an understanding where the standard is and where it
19 isn't and what we're approving for a standard design
20 for both the fleet and in preparation for a final
21 design, like Scott said. I have no problem. I think
22 the plant will be safe. I think it's just going to be
23 some extra work down the road that I didn't expect to
24 have to do, so I was -- so I'm done questioning it.
25 I think the point's been made. I think we can move

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 on.

2 CHAIR KIRCHNER: Prosanta, why don't you
3 carry on, if you would, please?

4 MR. CHOWDHURY: All right. Thank you.

5 CHAIR KIRCHNER: And then I'm looking at
6 the clock. If there's a juncture here where we should
7 take a break, we'll take a break.

8 MR. CHOWDHURY: Sure.

9 CHAIR KIRCHNER: But go ahead, please.

10 MR. CHOWDHURY: Thank you. Next slide,
11 please? So this is our prediction from external
12 sources.

13 CHAIR KIRCHNER: Pull that microphone
14 closer again, please?

15 MR. CHOWDHURY: Once again, Prosanta
16 Chowdhury, PM. This is Section 3.4.2, Flood
17 Protection from External Sources. So there are no
18 significant differences between the NuScale DCA FSAR
19 and SDA FSAR. Information NuScale provided is
20 bulleted here. The analysis procedures to transform
21 the static and dynamic effects of the highest flood
22 and groundwater levels into effective loads. There
23 are two COL items, 3.4-4 and 3.4-5. The conclusion
24 has not changed from the DCA. There are 11 audit
25 questions, and all were resolved during the audit.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Next slide? Section 3.5.1.1, Internally-
2 Generated Missiles Outside Containment. No
3 significant differences. NuScale provided evaluation
4 of internally-generated missile from plant equipment
5 and credibility of missiles. And conclusion in SDAA
6 did not change from DCA.

7 3.5.1.2, Internally-Generated Missiles
8 Inside Containment. No significant differences. No
9 credibility of missiles inside containment based on
10 plant design. And SDA conclusion didn't change from
11 DCA.

12 3.5.1.3, Turbine Missiles. There are
13 differences between NuScale DCA FSAR and SDAA FSAR
14 that include increased bounding turbine missile
15 parameters, mass and velocity. So the SDAA has for
16 Module 77 megawatt electric versus 50 megawatt
17 electric turbine in DCA.

18 Orientation of control building is more
19 favorable with regard to turbine missile trajectory,
20 however the CRB is not considered essential to be
21 protected from turbine missiles, high trajectory.

22 NuScale provided bounding missile
23 parameters and barriers analysis of reactor building.
24 This is discussed in Section 3.5.3 of the SER.

25 S -- should that be SSC? They are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 required to be protected. There are two COL items
2 that demonstrate site-specific turbine missile
3 parameters bounded by analysis and evaluate other
4 nearby facilities turbine parameters.

5 The conclusion is essentially the same
6 that the essential SSCs are protected from turbine
7 missiles using barriers.

8 There are two audit questions and all
9 resolved in audit. And for any technical questions I
10 have John Honcharik who will answer technical
11 questions.

12 CHAIR KIRCHNER: Does that conclude your
13 presentation for Chapter 3?

14 MR. CHOWDHURY: No, I have --

15 CHAIR KIRCHNER: You have more, right?

16 (Simultaneous speaking.)

17 CHAIR KIRCHNER: Okay. So let's go on.

18 MR. CHOWDHURY: Okay. 3.5.1.4, Missiles
19 Generated by Tornadoes and Extreme Winds. Basically
20 NuScale described the missile types and parameters for
21 extreme wind missiles evaluated in design. COL item
22 3.5-2 exists to confirm automobile missile velocity
23 and altitude of impact parameters will bound extreme
24 wind conditions at site. And the SDAA conclusion is
25 essentially the same as DCA conclusion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Next is 3.5.1.5, Site Proximity. And this
2 is COL item 3.5-3 to evaluate the site-specific
3 hazards from nearby or co-located facilities for more
4 energetic missiles than defined in SDAA. The
5 conclusion has not changed from DCA. Now this does
6 not include aircraft impact.

7 3.5.2, Structures, Systems, and Components
8 to be Protected from External Missiles. NuScale
9 provided safety-related and risk significant SSC that
10 must be protected from external missiles are located
11 inside Seismic Category I reactor building and Seismic
12 Category I portion of control room building. CRB as
13 mentioned in slide for 3.5.1.3 is not considered
14 essential to be protected from turbine missiles. The
15 conclusion in SDAA did not change from DCA.

16 Next, please? 3.5.3, Barrier Design
17 Procedures. There are some differences. For example,
18 steel-plate composite walls were not available for the
19 DCA; neither were steel barriers. NuScale provided
20 three-step design approach based on Bruhl equations to
21 prevent perforation of SC walls from missile impacts,
22 Ballistic Research Laboratory, BRL, formula to
23 determine the minimum steel missile barriers with 25
24 percent thickness increase. The conclusion did not
25 change from DCA except for steel-plate composite walls

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and steel barriers.

2 George Wang is here, who is the technical
3 reviewer for this section, if you have any questions
4 for him. All -- eight audit questions were issued,
5 and all were resolved during the audit.

6 Next? 3.6, Protection Against Dynamic
7 Effects Associated with the Postulated Rupture of
8 Piping. There are differences. As you have heard,
9 LBB methodology no longer -- leak-before-break
10 methodology no longer used for main steam system and
11 feedwater system inside containment vessel. Break
12 exclusion zone to use BTP 3-4. Leak detection
13 sensitivity changed from 0.005 gallons per minute to
14 0.01 gallons per minute. No LBB. Containment
15 isolation test fixture added between CNV nozzle safe
16 end and containment isolation valve for lines outside
17 CNV in the break exclusion zone under bioshield.

18 NuScale provided preliminary analysis
19 results for MSS and peak FWS show acceptability for
20 change to BTP 3-4. Leakage detection sensitivity
21 change, stated above, meets Reg. Guide 1.45 limit of
22 0.5 gpm. Preliminary analysis results for welds in
23 break exclusion zone outside CNV under bioshield
24 justifies break exclusion with CITF. Preliminary
25 stress analysis for ECCS RRV and RVV bolted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 connections with threaded inserts, unchanged from DCA,
2 and is representative for other bolted connections
3 with threaded inserts.

4 There were five audit questions and three
5 RAIs for this section. All were resolved. And the
6 conclusion in SDAA remained the same as DCA. I have
7 Chakrapani Basavaraju at the end, who is the technical
8 expert, if you have any questions.

9 CHAIR KIRCHNER: Would you -- his is Walt
10 Kirchner. Prosanta, would you elaborate on the third
11 sub-bullet about the safe ends and the CIV? So has
12 this resolved to the staff's satisfaction your
13 concerns about a potential large break in those areas
14 outside containment, particularly lines like the
15 chemical volume control system, the CVCS lines?

16 MR. BASAVARAJU: Yes, we had --

17 MR. CHOWDHURY: Introduce yourself,
18 please.

19 MR. BASAVARAJU: Yes, we had an RAI
20 request on this particular --

21 MR. CHOWDHURY: Introduce yourself,
22 please.

23 MR. BASAVARAJU: This is Pani Basavaraju,
24 mechanical engineer in the Testing Branch. I am the
25 technical reviewer with 18 years in RC. And prior to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that I was in Bechtel for around 18 years and for some
2 time in --

3 CHAIR KIRCHNER: You'll need to speak up.

4 MR. BASAVARAJU: For some time in (audio
5 interference). So for this particular one -- and this
6 is in the break exclusion zone in the containment
7 penetration area outside containment. And there are
8 essential lines, pressurizer spray, CVCS in that, and
9 discharge. And high-pressure and degasification line.
10 So and there are welded connections in that area. So
11 we asked if -- in what area they applied BTP 3-4
12 criteria, which is extremely limiting. The stress is
13 limited to 80 percent of the ASME Code. And then the
14 usage factor for fatigue is limited to 1.1, which is
15 very conservative. So all these values in these lines
16 are -- were shown to be meeting, based on the
17 preliminary design analysis, they meet these extremely
18 limiting stress criteria in those -- for all of those
19 --

20 (Simultaneous speaking.)

21 CHAIR KIRCHNER: So the cycling of the
22 CVCS system pressurizer spray, you're still confident
23 that there's significant margin there --

24 MR. BASAVARAJU: Yes.

25 CHAIR KIRCHNER: -- in that analysis of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the piping stresses?

2 MR. BASAVARAJU: Yes.

3 CHAIR KIRCHNER: Okay. Thank you.

4 MR. CHOWDHURY: 3.9.1, Special Topics for
5 Mechanical Components. Significant differences, the
6 heatup rate for reactor heatup to hot shutdown
7 transient changed. NuScale provided final component
8 stress analysis will use the latest transients' input
9 for ITAAC. The SDAA conclusion is the same as DCA.
10 This does not include density wave oscillation.

11 MEMBER MARTIN: I've got a question. Bob
12 Martin. In NuScale's presentation they made a note
13 about the removal of an event -- this is the
14 detonation. Now, I don't think it was so much
15 removal, because I think in the previous approval they
16 didn't have say a recombiner and they had made
17 arguments that it was from a source term in terms of
18 hydrogen and oxygen, that there were -- it was
19 insufficient to cause a detonation.

20 But now we have a recombiner that has
21 appeared in the design, and I'm kind of wondering how
22 that came about. And I can imagine through
23 deliberations with you guys that maybe to address
24 uncertainties associated with scenarios, just the
25 hydrogen and oxygen generation, that this design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 change came about.

2 Can you provide some insight on where that
3 recombiner came from? Because now all of a sudden it
4 seems to be more of a concern because it's there,
5 whereas before it wasn't there. And it's not
6 completely fair because I didn't ask the same question
7 to NuScale.

8 MR. CHOWDHURY: NuScale may be able to
9 answer that.

10 MEMBER MARTIN: That didn't necessarily
11 come out of questions that came from you all. Maybe
12 in Chapter 19 --

13 (Simultaneous speaking.)

14 CHAIR KIRCHNER: Well, I can provide some
15 insight. When we reviewed the DCA, one of the
16 concerns that the Committee identified was the post-
17 TMI requirement to do sampling of the containment
18 atmosphere. And what was considered or proposed was
19 to open the containment -- I'm not going to get the
20 acronym right -- the containment fill and drain system
21 line, which is a substantial line, four inches if I
22 remember correctly, and that line then would have a
23 loop attached to it for actually sampling.

24 And there is lots of questions about the
25 risk of opening up a line of that size to bypass

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 containment effectively just to do a sample of the
2 containment atmosphere. And also there was
3 considerations of how representative that sample would
4 be from a stagnant line. You would have to have a
5 recirculating smaller line that would make the sample
6 measurement.

7 But that was flagged as a concern. I
8 don't know cause and effect that -- based on the
9 recommendation of the ACRS that the applicant NuScale
10 put the recombiners in as a means to not only take
11 down the pressure loading if you were to have a
12 detonation event, but also as a substitute to doing
13 that sampling, which had the risk of breaching --
14 bypassing containment. And so by having the
15 recombiners there in the containment, then I think the
16 applicant can make a convincing argument to the staff
17 that they don't need to have the provision or the
18 post-TMI requirement of a sampling of the containment
19 atmosphere.

20 MEMBER MARTIN: There wasn't a
21 conversation about sources of oxygen. I mean, it
22 seems a little hard to believe there's no way that,
23 you know, from some event that ultimately leads to a
24 severe accident, you can't get oxygen if you had a
25 breach of interfacing systems, what have you, that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 sort of in an oxygen environment. But that didn't
2 come up. I mean, they've otherwise argued that oxygen
3 from all sources has -- is excluded.

4 CHAIR KIRCHNER: I can't speak for the
5 applicant. I would say that I think they did in the
6 DCA design an actual evaluation of the detonation
7 threshold.

8 MEMBER MARTIN: Right. I saw that.

9 CHAIR KIRCHNER: And they --

10 MEMBER MARTIN: So I'm -- and it's almost
11 like, well, they did the work.

12 (Simultaneous speaking.)

13 CHAIR KIRCHNER: -- it was designed to
14 withstand that.

15 MEMBER MARTIN: Right. So then why don't
16 just include it instead of making of point that they
17 don't need it, which was kind of in the presentation?
18 Either you did it or you didn't. If you did it, go
19 ahead and take credit for it and just let it go.

20 CHAIR KIRCHNER: At this point we should
21 let the applicant correct the record.

22 MEMBER MARTIN: I think that --

23 CHAIR KIRCHNER: Okay. Go ahead.

24 MR. BECK: This is Tyler Beck with
25 NuScale. So we added the PAR (phonetic) to remove

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that load and remove the previous carve-outs from the
2 DCA, which the detonation loads -- you have to include
3 those in the design specs for all the components. And
4 it certainly leads to more expensive things of that
5 sort. And we just took -- there's no load anymore.
6 With the FAR there's no possible combustion event,
7 taking that out of the design.

8 MEMBER MARTIN: But there was before? No,
9 right? In your earlier design, I mean you made the
10 same argument.

11 (Simultaneous speaking.)

12 MR. BECK: -- design there was the
13 evaluation of detonation loads.

14 MEMBER MARTIN: But you would have had,
15 what, a relatively small amount of oxygen? And that
16 was what you were claiming all along. So, but that
17 load was still something that we're concerned about in
18 the first go-around or --

19 MR. BECK: Well, that was a load in the
20 DCA, but now it is not with the FAR.

21 MEMBER MARTIN: Yeah. Okay. One thing
22 about, you know, PARs, of course they work on a -- at
23 a pretty slow rate, right? Then oftentimes you'll see
24 the severe accident management or the combustion gas
25 control system having both igniters. And PARs deal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 with the uncertainties of the rate of hydrogen
2 releases. You'll feel like there's -- again, getting
3 back to the question of where does the oxygen come
4 from, you exclude that, you don't really have a big --
5 I'll call it the big problem. But there was no issue
6 or question regarding the rates at which these
7 processes could happen and the uncertainties
8 associated with a severe accident, which we all know
9 are very large.

10 MR. BECK: When we present Chapter 6
11 you'll -- we'll certainly cover combustions --
12 combustible gas. I'll just say that our design is
13 very different with the blowdown to containment and
14 the percent oxygen compared to a traditional design.
15 It's different in that respect. But we'll get to that
16 in Chapter 6.

17 MEMBER MARTIN: Thank you.

18 CHAIR KIRCHNER: No, their starting point
19 is a vacuum, right, in the containment, which is
20 completely different than a large LWR, which is an
21 oxygen environment unless you inert, which we don't.

22 MEMBER MARTIN: Right.

23 DR. SCHULTZ: This is Steve Schultz.
24 While we're still on this slide, the last statement --
25 last two statements indicate the conclusions are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 same, but does not include the evaluation of the
2 density wave oscillation. Some of the evaluations in
3 the -- some of the discussions in the safety
4 evaluation do include open items associated with
5 Section 9.2 and just presuming that those are going to
6 be resolved by our review of 9.2 in the end of next
7 spring, or the beginning of next spring. Is that
8 true?

9 MR. CHOWDHURY: This is Prosanta
10 Chowdhury. Are you talking about Section 39 -- 3.9.2?

11 DR. SCHULTZ: Yes, 3.9.2.

12 MR. CHOWDHURY: Yes, so the safety
13 evaluation for this particular presentation really
14 states that the DWO will be addressed in Section 3.9.2
15 of the -- of FSAR 20. The evaluation is completed by
16 that. So the advanced safety evaluation that we have
17 issued for this particular one does not have any open
18 item, but it simply points to Section 3.9.2 for DWO
19 and related -- other related sources.

20 DR. SCHULTZ: Okay. I'll take another
21 look at that. Thank you.

22 MR. TESFAYE: Chair, may I suggest -- may
23 I say something? For the record --

24 CHAIR KIRCHNER: Go ahead, Getachew, and
25 identify yourself.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. TESFAYE: This is Getachew Tesfaye,
2 the project manager for SDA. Oh, this is Getachew
3 Tesfaye.

4 Just for the record, the subject matter
5 experts that you see in front of you do not include
6 all those things that worked on the combustible gas
7 and PAR. So when we present Chapter 6 and Chapter 19,
8 tentatively scheduled for March, I think all those
9 things will be discussed in detail. And again, on
10 3.9.2 it's not -- this presentation doesn't include
11 that. So just wanted go on the record saying that.
12 We don't have any experts on PAR in (audio
13 interference) in this presentation. Thank you.

14 MR. CHOWDHURY: 3.9.3, ASME Code Class 1,
15 2, and 3 Components, Component Supports, and Core
16 Support Structures. There are some differences. As
17 you see on the slide, upper and lower sections of the
18 reactor vessel are constructed from different
19 materials that have different coefficients of thermal
20 expansion which is considered in the stress
21 qualification of the closure bolts and flanges. So
22 there were lot of discussions on bolted connection and
23 its design with NuScale. NuScale provided preliminary
24 finite element analysis results. So the SDAA
25 conclusion did not change from DCA conclusion on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 different materials that are used.

2 Next? 3.9.4, Control Rod Drive Systems.
3 There are differences. Use of DCA drop and shaft
4 alignment testing for SDAA design. Use of threaded
5 connections instead of welded connections between CRDM
6 and reactor pressure vessel. This is further
7 discussed in 3.13. Rod holdout mechanism failure --
8 feature. Sorry. Steam generator tube support
9 assembly, consider impact to CRDS.

10 NuScale provided adequate justification to
11 apply DCA testing to SDAA design, reconciling the
12 differences; analysis of threaded connections, again
13 discussed in Section 3.13 slide that's coming up;
14 justification that rod holdout mechanism failure would
15 not adversely impact safety function of inserting
16 rods; details of assemblies, purposed inspections to
17 monitor for degradation.

18 There were seven audit questions and two
19 RAIs. All were resolved. From the staff have Nick
20 Hansing present here in the room if there are any
21 questions.

22 3.9.5, Reactor Pressure Vessel Internals.
23 Again, there are no significant differences, and the
24 conclusion did not change from the DCA.

25 3.9.6. There are some design differences,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and we have Tom Scarbrough here from the staff in the
2 room to answer any technical questions.

3 So redesign of ECCS valve system requiring
4 10 CFR 50.43(e) testing and lessons learned to plan
5 for ASME QME-1 qualification testing. Need to address
6 2017 edition of ASME OM Code with motor-operated valve
7 and air-operated valve diagnostic testing requirements
8 beyond 2012 edition in DCA.

9 NuScale provided audit access to ECCS
10 valve system proof-of-concept test specification and
11 reports to support compliance with 10 CFR 50.43(e);
12 updated relief and alternative requests to reflect
13 2017 edition of ASME OM Code; draft revision to FSAR
14 and ECCS test description in response to NRC review
15 and audit findings. And then the conclusion did not
16 change from DCA to SDAA.

17 CHAIR KIRCHNER: So this is an area that
18 was identified as -- probably don't have the right
19 terminology that the staff would use, but requiring
20 further work and testing. And then several changes
21 were made to the ECCS valves and such. So could you
22 or John --

23 MR. CHOWDHURY: Yeah.

24 CHAIR KIRCHNER: John, could you give the
25 Committee an update of where things stands with regard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to the ECCS testing and your expectations?

2 MR. SCARBROUGH: This is Thomas
3 Scarbrough. I'm (audio interference) branch 46 years.
4 Yes, originally what we did for the DCA was they had
5 some initial testing that was -- we did consider to
6 meet 50.43(e). And we worked with them. They
7 developed a new testing plan. We observed that
8 testing of the target rods during -- and the
9 conclusion was the testing they did of that 50.43(e),
10 but they still had to follow through with QME-1
11 standard qualifications after that.

12 Now jump ahead to SDA, they right off the
13 bat conducted the proof-of-concept testing -- proof
14 testing that's need for 50.43(e). So that was already
15 completed by the time they submitted their
16 application. So we asked for all of those test
17 results, the test specification, all of the tests for
18 the ECCS valves, RVV, RRV, the IAB. We asked for all
19 of that test information, and we reviewed it as part
20 of audit. They put it in electronic reading room for
21 -- and, as you saw, we had a large number of questions
22 on what was done.

23 They did find some interesting things when
24 they were doing the testing, just like they did with
25 DCA where they had to do some adjustments in terms of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 different things, but the bottom line was we felt that
2 they had met 50.43(e) to demonstrate the design
3 feature. However, they still will need to demonstrate
4 that the entire system will perform its safety
5 function through the QME-1 qualification method.

6 So they're going to have to match the
7 plant conditions, they're going to have to look at
8 boron. They didn't do boron in this version. We had
9 them do boron in the first version, the DCA. And they
10 showed that there was not really an effect. So for
11 the SDA we did not require them to do the boron
12 condition testing. But they will have to do it for
13 QME-1 qualification.

14 So there's a number of lessons learned
15 that they came out with that were in the reports and
16 we summarized them in the safety evaluation. They had
17 some findings of different aspects. They're going to
18 be looking at the fundamental frequency, more things
19 of that nature. They're going to follow up on a
20 number of different areas like that in terms of the --
21 the stroke-time of the valve. They're looking at
22 that. There are a number of different areas. There
23 was some leakage. They're going to look at all those
24 aspects during the qualification. So there were a
25 number of lessons learned from this particular

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 testing, the proof testing that they did for 50.43(e),
2 but they still have quite a bit of work to do for
3 qualification under QME-1, which they'll have to meet.
4 When the COL comes in, they'll have to be able to meet
5 those provisions in QME-1. So that's sort of where we
6 are right now.

7 CHAIR KIRCHNER: Okay. So how do you
8 capture that? Does that become an ITAAC?

9 MR. SCARBROUGH: Well, it's -- we
10 summarized it high-level in the safety evaluation. We
11 mentioned some of those things I just mentioned.

12 CHAIR KIRCHNER: Right.

13 MR. SCARBROUGH: They will have to follow
14 through. And those reports -- we summarized the
15 reports. And so when a COL comes in, they're going to
16 have to pick it up from there and make sure the QME-1
17 qualification testing is complete. And the lessons
18 learned from this testing will have to be applied
19 instructing the testing. So the staff, when we --
20 when a COL applicant comes in and says we're going to
21 do QME-1 testing, we'll pick up our safety evaluation
22 and look at where we summarized these were issues that
23 need to be continued on. And we'll use that as part
24 of reviewing the test procedures for the QME-1
25 qualification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So I think we have it documented to make
2 sure there's no loss of information there so that we
3 can make sure the QME-1 testing is adequate.

4 CHAIR KIRCHNER: Okay. Now a follow-on
5 question. I remember that you, the staff, had a
6 concern about boron in the static lines of the ECCS
7 valve design. So without going into anything
8 proprietary, is that part of the qualification
9 testing, time and temperature with boron?

10 MR. SCARBROUGH: Yes, it will. They did
11 address our concerns during the DCA for that.

12 CHAIR KIRCHNER: Yeah.

13 MR. SCARBROUGH: And that was part of one
14 of the questions we had about the precipitation
15 aspect. And so they were able to resolve that for
16 that. For QME-1 qualification testing for the SDA
17 they will have to address that as part of
18 qualification testing.

19 CHAIR KIRCHNER: Okay. Thank you.

20 MR. CHOWDHURY: 3.10, Seismic and Dynamic
21 -- sorry, my microphone was off. Section 3.10,
22 Seismic and Dynamic Qualification of Mechanical and
23 Electrical Equipment. Basically no change, and no
24 change in the conclusion.

25 Next. 3.11, Environmental Qualification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of Mechanical and Electrical Equipment. There have
2 been changes. Changes to FSAR Table 3.11-1 for
3 equipment and qualification. Potential use of IEEE
4 standards not endorsed by NRC Regulatory Guides.
5 Chapter 15 accident scenarios with lower coolant
6 levels for longer duration than DCA.

7 So NuScale provided adequate justification
8 for NRC staff to rely on past experience from DCA
9 review to inform SDAA review; proposed FSAR revisions
10 to support NRC safety findings.

11 The staff found that all applicable
12 regulatory requirements were adequately addressed.
13 Just to mention that there have been a significant
14 number of interactions between the staff and NuScale
15 on this topic, and all issues raised were resolved
16 within audit.

17 We have Jorge Cintron-Rivera here, the
18 expert, and Ed Stutzcage on the line, and they're the
19 technical experts for this area of review, if you have
20 any questions.

21 3.12, ASME BPV Code Class 1, 2, and 3
22 Piping Systems and Associated Support Design. No
23 significant changes between DCA and SDAA, and no
24 changes in the DCA conclusion -- in the SDAA
25 conclusion from DCA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 3.13, Threaded Fasteners, ASME BPV Code
2 Class 1, 2, and 3. The RVVs and RRVs were changed to
3 -- are not changed, right, to bolted, but there have
4 been some changes in the bolted connections related to
5 the vessel nozzle. These four bolted flange
6 connections were classified as break exclusion areas.
7 Added augmented examination requirements for ASME
8 Class 1 threaded inserts and seal welds.

9 NuScale providing engineering study of
10 stresses of the bolted flange connections that
11 adequately show that the probability of gross rupture
12 of the ECCS valves bolted connections is extremely
13 low.

14 Sampling plan and expansion criteria from
15 the -- for the steam and feedwater plenum that can be
16 credited for RVV and RRV break exclusion locations.
17 That was the part of DCA -- SDAA conclusion.

18 We have Dr. Cory Parker in the staff who
19 can respond to any technical questions in this area of
20 review.

21 So this is the concluding slide for
22 NuScale SDAA Chapter 3 review except for Sections 3.7,
23 3.8, and 3.9.2. Overall very high level conclusion is
24 that while there are some differences as we indicated
25 through some of the slides between the DCA and SDAA,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the staff found that the applicant provided sufficient
2 information to support the staff's safety finding.
3 The staff found that all applicable regulatory
4 requirements are adequately addressed. That's the end
5 of the staff presentation.

6 CHAIR KIRCHNER: Thank you. Members, any
7 specific questions to this Chapter 3?

8 MEMBER ROBERTS: Yes.

9 CHAIR KIRCHNER: Go ahead.

10 MEMBER ROBERTS: Tom Roberts. Can you
11 back to slide 12? Slide 12 has a conclusion that the
12 control building is not required for safety. And I
13 was looking through your safety evaluation report
14 while you were talking, and it looks like -- you say
15 in the report the staff has not verified whether the
16 control room and its operators are not needed or
17 credited to ensure that the criteria are met. If the
18 criteria are not met then an analysis of the barriers
19 of the CRB prior to trajectory missile would have to
20 be performed.

21 So it sounds like it's an open item in
22 your view that whether or not the control building
23 really should be exempted from the turbine missile or
24 high-trajectory criteria. I wondering if you could
25 comment how you reached the conclusion on the slide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that --

2 MR. CHOWDHURY: Yes.

3 MEMBER ROBERTS -- the CRB is not
4 considered essential.

5 MR. CHOWDHURY: Okay. John, just a second
6 please.

7 So I don't know if you are looking at the
8 initial draft safety evaluation we sent to you,
9 because between then and just a few days ago we had
10 some back and forth discussions with NuScale on this
11 matter, on this subject. And then we finalized the
12 safety evaluation. I don't think the safety
13 evaluation has an open item in this area, but John
14 Honcharik is the subject matter expert technical
15 reviewer for this area.

16 John, go ahead. Please introduce yourself
17 first.

18 MR. HONCHARIK: Hi, I'm John Honcharik,
19 senior materials engineer in NRR. I've been at the
20 NRC for 22 years and another 15 years at a shipyard
21 building nuclear-powered submarines and aircraft
22 carriers.

23 So, you're correct. I think, initially,
24 there was some discussion that -- there was still some
25 discussion of whether or not there were essential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 equipment in the control room that needed to be
2 protected. But there were -- like Prosanta said,
3 there were other interactions that finally came to the
4 conclusion that there are none, and they don't need
5 that, because there are some redundant systems in the
6 reactor building, so that even if they didn't have the
7 control room, they could safely shut down the reactor
8 in accordance with the guidance in Reg Guide 1.115, so
9 that they wouldn't have to protect that control room
10 building.

11 MEMBER ROBERTS: So you looked at the loss
12 of indications and manual controls and the other
13 things that are in the main control room to mitigate
14 scenarios that aren't ones specifically called out in
15 the safety analysis report? Just seems like wiping
16 the entire control building was something that would
17 have to require some thought in terms of looking,
18 okay, what are all the scenarios that could be
19 challenged by that and whether that would warrant some
20 additional protection from certain events. So I was
21 wondering how you got there.

22 Is this something in the PRA that looks
23 at, okay, if the entire control building were lost,
24 then here's how the plan would be to restore it? Or
25 how did you get there?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. HONCHARIK: Well, we didn't look
2 specifically at the PRA, but there was a lot of
3 discussion back and forth on this topic of whether or
4 not you really need the control room building. And I
5 think there was some major changes in the FSAR that
6 are proposed and will probably be in the next revision
7 where basically it stated what are the requirements
8 for the Reg Guide, where it says these are necessary
9 to be protected. And in order to meet the guidance
10 you have to be able to safely shut down the reactor
11 and keep it in a safe shutdown condition.

12 So they provided information that showed
13 that all the equipment that is there is either
14 redundant or can be observed or initiated somewhere
15 else. And also there's automatic -- it's mostly
16 automated. So, with that, there's the failsafe that,
17 if they can't, they can always use the main controls
18 in the reactor building.

19 So that was basically the conclusion for
20 that. Now, this is just for the high-trajectory
21 missile, for the -- it's still protected from all the
22 other missiles based on conservative design
23 philosophy.

24 MEMBER ROBERTS: Yeah, I would imagine the
25 likelihood of the scenario is pretty low because, like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you said, the low-trajectory, apparently, is protected
2 just by the location of the building.

3 MR. HONCHARIK: Right.

4 MEMBER ROBERTS: High-trajectory missile
5 presumably are less likely. I just am, again,
6 wondering how you support that conclusion. It seems
7 like, from a defense-in-depth perspective, loss of all
8 of the systems in the control building on one event
9 could significantly challenge some accident
10 progression, maybe not the design basis accidents.
11 And I was wondering if that's something that comes up
12 again in Chapter 19 or in the PRA and looking at, okay
13 -- looking at likelihood and consequences or some
14 scenario outside the design basis that would be
15 challenged by that. Do you expect that to be looked
16 at in Chapter 19, or is this all we're going to --

17 MR. HONCHARIK: Yeah, I think -- I don't
18 know, Prosanta, if there is anything in Chapter 19
19 that will be coming.

20 MR. CHOWDHURY: Could be when we present
21 Chapter 19.

22 MR. HONCHARIK: Yeah, not sure about that.
23 Might have to get back to you on that, but --

24 MEMBER ROBERTS: Yeah, I can raise the
25 question then. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Let's see. Vesna and
2 Vicki, any further questions on 3?

3 MEMBER DIMITRIJEVIC: No, we are good.

4 MEMBER BIER: Yeah, not right now.

5 (Simultaneous speaking.)

6 MEMBER DIMITRIJEVIC: As I remember, there
7 is no really control of -- loss of control building
8 was not part of the Chapter 19 analysis in the DCA,
9 so.

10 CHAIR KIRCHNER: Go ahead.

11 MR. TANEJA: This is Dinesh Taneja. I am
12 the RNC (phonetic) technical reviewer. In Chapter 7,
13 when we discussed that, there is a PDC 19, which is
14 the remote shutdown capability. In that review in PDC
15 19, the capabilities are in the reactor building. If
16 we lost the accessibility of the control room for any
17 reason, you can go to the reactor building and do the
18 necessary manual initiations if you need to, if the
19 automatic did not, for some reason, work.

20 So I just wanted to add that to the
21 discussion, that we did look at that as part of
22 Chapter 7 and Chapter 18 evaluation.

23 CHAIR KIRCHNER: Okay. Let's, at this
24 point, stop and take a break, a well-deserved break.
25 Thank you for the presentations, both applicant and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 staff.

2 It is 3:32. Let's reconvene at 3:50
3 Eastern Time. Take a little bit longer break. And
4 then we'll turn to Chapter 8 at that point. Thank
5 you.

6 (Whereupon, the above-entitled matter went
7 off the record at 3:32 p.m. and resumed at 3:50 p.m.)

8 CHAIR KIRCHNER: Okay, we're back in
9 session. We're turning to Chapter 8, Electrical
10 Systems, and we'll start with NuScale.

11 Who's the lead here for NuScale? David,
12 go ahead, take it away, please. And, again, just
13 remember pull those microphones close to you. They're
14 really quite sensitive and if they're far off, we're
15 not really getting a good transcription for the court
16 reporter. Thank you.

17 MR. RICKENBACH: Good afternoon. I'm Dave
18 Rickenbach. I'm the Electrical Engineering Manager
19 here at NuScale. I have 18 years' experience in
20 nuclear power, drawing from the naval nuclear power,
21 electrical system engineering and the BWR fleet. For
22 the past six years, I've been at NuScale focusing on
23 stationary DC power design and engineering management.
24 Today, I'm going to present Chapter 8, Electrical
25 Power. Next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Here's our overview for Chapter 8.
2 Chapter 8 is broken into four sections. We'll talk
3 about the overview, offsite tower systems, onsite
4 power systems, station blackout, SBO. We're going to
5 discuss at a high level the changes from SDAA to DCA,
6 including the conforming changes in the SDAA reflect
7 US 460 standard design, which is functionally,
8 equivalent to the DCA.

9 Our DCA included six COL items. There are
10 none in the SDAA. FSAR content was optimized from the
11 US 600 DCA and in the example that would remove
12 specific wattage of plant loads from the FSAR tables.
13 We resolved 14 audit questions. Next slide.

14 Here is a high level overview of our
15 design changes from DCA to SDAA. I have broken it
16 into two sections. We have AC power and DC power.
17 I'll start with AC power.

18 Our design now includes a common load AC
19 power. It's provided by redundant transformers. We
20 made changes to the high voltage AC electrical
21 distribution configuration. We made changes to the
22 backup power supply system configuration.

23 For DC power, we now have a single battery
24 string for each augmented DC power system, which I'll
25 refer to as EDAS from now on, EDAS power channel. Our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 EDAS divisions are physically separated in independent
2 rooms and our EDAS includes power channel cross-
3 connects. Next slide.

4 For our Section 8.1 overview, this section
5 provided a high level overview of onsite and offsite
6 power sources. The technical content reflected the US
7 460 plant systems instead of US 600 plant systems.
8 Our GGC conformance is unchanged from US 600 DCA.

9 Audit results. We changed our FSAR Table
10 81-1. We revised it to include more information from
11 the US 6-400 standard plant design. This really had
12 to do with including IEEE standards applicable to
13 EDAS. There were no RAI questions. Next slide.

14 From Section 8.2, Offsite Power Systems,
15 the technical content is generally unchanged. Our COL
16 items were removed in SDAA. Removed COL item 8.2-1,
17 which is a description of the site-specific plant
18 switchyard. We removed COL item 8.2-2, the
19 description of the site-specific offsite power, the
20 grid study. We removed COL item 8.2-3, the
21 description of the required testing. The plan
22 supports a GDC 17 and 18 exemption. The site does not
23 rely on offsite power, so the DCA suitable items were
24 unnecessary. There were no audit questions nor RAI
25 questions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 From Section 8.3, Onsite Power Systems.
2 Technical content is revised to reflect design on US
3 460 electrical power systems. COL items removed in
4 SDAA, we removed COL item 8.3-1, US 460 design does
5 not have an auxiliary AC power system. Removed COL
6 item 8.3-2, there is no electrical heat tracing. We
7 removed COL item 8.3-3. Our site-specific information
8 was not needed to demonstrate compliance with Reg
9 Guide 1.204 in the DCA. The US 460 standard design
10 maintains conformance with the Reg Guide 1.204.

11 Real audit results. We made an addition
12 of Table 8.3-3 to describe EDAS augmented system
13 design qualification and quality assurance provisions.
14 There were no RAI questions.

15 MEMBER ROBERTS: Dave, can you go back a
16 couple of slides? I think this slide might be
17 collaboration, but the slide you had the overview of
18 design changes, maybe three slides ago, it describes
19 three changes you made to the AC power system, but
20 doesn't really explain what they were. The amount of
21 detail that's in the chapter now is pretty light
22 compared to the previous chapter. In terms of
23 electrical schematics there were probably, I don't
24 know, 50 sheets before and now it's only six, but can
25 you just give a quick synopsis of what those changes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 were?

2 MR. RICKENBACH: Yes. Our common load, if
3 we remember in the DCA, the common loads were provided
4 off modular-specific power systems. We split those
5 out onto its own specific common system, provided by
6 two transformers that are 100 percent redone. Those
7 come off the point of the common coupling or a plant
8 switchyard.

9 For our high voltage AC electrical
10 distribution change, so our turbine generators now
11 connected distribution voltage to the point of common
12 coupling, which is our plant's switchyard. We also
13 include by module a generator set up of transformer
14 and unit auxiliary transformer, where before those
15 were shared in the DCA.

16 For our backup power supply system
17 configuration, we removed the AAPS and integrated
18 those functions into our backup diesel generators.

19 MEMBER ROBERTS: The schematic on the
20 connection between the generators and the unit
21 auxiliary transformers doesn't clearly show what sort
22 of protective measures there are between them. We had
23 a presentation back, I think it was in March, that did
24 talk about one of the most common risks for high
25 energy and lack of a protective device at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 generator output. Do you have generator output
2 breakers in there or is the first protection at the
3 transformer or downstream with the transformer?

4 MR. RICKENBACH: US 460 guideline includes
5 generator circuit breakers.

6 MEMBER ROBERTS: Okay, so you've got an
7 arcing fault and then a transformer or in the upstream
8 wiring, you would trip the inner circuit breaker?

9 MR. RICKENBACH: That's correct.

10 MEMBER ROBERTS: And I think the DC power,
11 as you described in later slides, great keep going.

12 MR. RICKENBACH: For Section 8.3, Onsite
13 Power Systems, our technical content is revised --
14 (Simultaneous speaking.)

15 MR. RICKENBACH: Let me get back to my
16 slide. Yeah, the addition of Table 8.3-3 describes
17 EDAS augmentations and that's our system design,
18 qualification, and quality assurance. There were no
19 RAI questions.

20 MEMBER ROBERTS: I don't think we've seen
21 that table and I have a general question maybe I'll
22 ask that now. The EDAS system is not safety-related,
23 but it's also not exactly non-safety either because
24 it's got some important functions. You've augmented
25 the quality to kind of split the difference. What's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 very hard to figure out is what you're doing that's
2 beyond non-safety, which this table probably answers
3 and then what you're not doing that would be part of
4 quality and safety-related.

5 Do you have a quick synopsis of the kinds
6 of things that you would have to add to make it
7 safety-related or Class 1E or is it basically, well,
8 I guess I'll end the question there.

9 MR. RICKENBACH: I have a slide on the
10 reliability in EDAS. So I can answer that question
11 then or right now.

12 CHAIR KIRCHNER: Okay.

13 MEMBER ROBERTS: Yeah, the question is the
14 reliability and availability and all is great, but in
15 the question, if you call it safety-related, what more
16 would there be? And then, what kind of compromises
17 you're making relative to -- calling it safety-related
18 is very questionable in that case, so if that comes as
19 a later slide, great.

20 MR. RICKENBACH: Yes. Section 8.4,
21 Station Blackout. US 460 station blackout is similar
22 to the DCA and the conclusion is the same. SBO does
23 not pose a significant challenge to the plant because
24 the plant does not rely on AC power for performing
25 safety functions. A safe and stable shutdown is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 automatically achieved and maintained for 72 hours
2 without operator actions. Next slide.

3 So, here's our slide on reliability and
4 availability of EDAS. Of those 14 audit questions,
5 the majority were spent on the EDAS system and I have
6 condensed it down to these four bulleted points here.

7 I'll start off to address your question
8 directly on a gap analysis. We didn't actually
9 perform a gap analysis between EDAS being a safety-
10 related system and a non-safety-related system. The
11 EDAS system, when we were designing it, it did not
12 meet the definition, R50.2 definition, for a safety-
13 related system and that is where we started the design
14 from. That being said, EDAS has augmented provisions
15 for design and quality that satisfy asset protection
16 and production quality.

17 (Audio interference.)

18 DR. BLEY: Did people stop talking or did
19 I just lose sound?

20 COURT REPORTER: This is the court
21 reporter, I believe the room has been muted.

22 MEMBER VLAHOVICH: Yeah, I lost sound,
23 too. I don't hear anything either.

24 CHAIR KIRCHNER: Court reporter, can you
25 hear us now?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 COURT REPORTER: Yes, we can.

2 CHAIR KIRCHNER: Okay. Sorry, okay.

3 Thank you. Let's proceed. You might need to back up
4 a little bit, David.

5 MR. RICKENBACH: Okay.

6 DR. BLEY: This is Dennis. Can I sneak a
7 question in for your or a comment? Sort of a memory
8 test for me. My memory was the big deal was the
9 batteries you were using weren't available in safety
10 grade at the time and you needed those to control the
11 size of the building, which made sense at the time and
12 the stuff we looked up on the batteries looked very
13 good, but they weren't available as qualified at the
14 time. Is my memory right or did I just miss the boat
15 there?

16 MR. RICKENBACH: That is correct and I can
17 address that. The EDAS system uses a valve regulated
18 lead acid cell, which contrary to a vented lead acid
19 cell is not available at a safety-related grade or
20 quality. That being said, we have applied
21 augmentations to our non-safety-related EDAS where we
22 think our reliability and availability suit the
23 functions that it performs for acid protection in
24 production criticality.

25 The EDAS batteries will be environmentally

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 qualified for IEEE 323. This really takes into
2 account that we could just seismically qualify them,
3 but we want to make sure that we take into account
4 aging mechanisms that are applied through an
5 environmental qualification program and we address
6 those. Very similar to what you do with a vented
7 cell.

8 Stepping forward, portions of the non-
9 safety-related EDAS supplying our DC power to ECCS
10 valves are augmented. Additionally, these
11 augmentations are sided one components. They're
12 protected from natural phenomenon per GDC 2. They're
13 protected from environmental conditions for GDC 4.
14 They're not shared between modules per GDC 5. There's
15 an individual, module-specific EDA subsystem for each
16 module. We protect from fire per Reg Guide 1.189,
17 which is GDC 3. They include physical independence
18 per Reg Guide 1.75. We separate into redundant load
19 groups and we designate to be single-failure proof per
20 Reg Guide 1.53.

21 So, those are the mainline augmentations
22 that we applied to the EDA system, not Sage related
23 but we applied it for our acid protection and
24 production criticality.

25 MEMBER ROBERTS: Tom Roberts here. I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 not sure, Dennis, if you heard my question before the
2 room got unmuted, but it sounds like you did. The
3 question I asked is, if this were called safety-
4 related, what more would they do? I think the answer
5 you brought up is that because there's no
6 qualification of a BRLA battery for a safety-related
7 application then that would require additional work to
8 figure out what that would involve.

9 When I look at this list, you have
10 separation, independence, redundancy, single-failure
11 proof, separate redundant load groups, all those
12 things sound like a Class 1E electrical power system.
13 I couldn't understand what's missing.

14 PARTICIPANT: And this is just the
15 battery or is there more?

16 MR. RICKENBACH: It starts more
17 fundamentally. It was designed as a non-safety
18 system, but viewed through the lens as it's not just
19 any regular plant system, it's important. We define
20 the importance of it. It has production criticality,
21 right. We talk about loads for a moment. It serves
22 the module protection system, so a loss of power here
23 results in a plant trip. There's a high impetus to
24 make it as reliable from a production standpoint.

25 Also, asset protection, so having an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 inadvertent ECCS actuation that is not something that
2 you ever want to have, so that requisite amount of
3 reliability was built in from the ground up, but as a
4 non-safety system. There was no gap analysis done.
5 We didn't say, well, if it was safety, it would be
6 this, but because we did the EDAS, we made it this way
7 and tried to trace requirements that way.

8 DR. BLEY: Hey, Tom, it's Dennis. I
9 didn't hear your question and really with that,
10 Charlie might have a better memory on this than I do.
11 We also really chased to make sure there wasn't
12 something hidden around the system that really needed
13 power such that you could have a problem when you lost
14 power and that looked pretty solid.

15 MEMBER ROBERTS: Yeah, the piece of the
16 chapter that I really liked was the table. What
17 Dennis said just carried the thought that a lot of
18 people look at loss of power as a concern, but when I
19 got out of your table is it looked at other failure
20 modes, like oscillating voltage and under voltage and
21 high voltage and things that happen in real life that
22 don't fail as cleanly in maybe as deterministic a way
23 as loss of power, so you did look at that. That's
24 another aspect of this that probably gets you more
25 confidence in terms of knowing what all your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 consequences of failure are.

2 I think this is your last slide and one
3 question that remains, we may have to follow up in a
4 closed session because some of this comes from
5 proprietary material you provided. There's a scenario
6 that you call smart failure and there's a question
7 about whether or not smart failures need to be covered
8 within the design basis and that aspect of it, we
9 probably need to cover in closed session.

10 The question I had on that, the small
11 failure as I understand it, is that the EDAS chooses
12 to fail at the exact same time as the modular
13 protection system says I need to make a trip, so that
14 does something to performance. I was trying to
15 understand what, because it seems like if you lose
16 power at the same time as you need a trip, then the
17 loss of power will cause the trip, right? By tripping
18 the RCBs, the under strip. So, can you just give a
19 description of what the scenario is that causes the
20 concern with the smart failure?

21 MR. RICKENBACH: I'll discuss it from an
22 electrical standpoint and then I'll turn it over to
23 Kris Cummings for any safety analysis look at it. One
24 of the things we EDAS, when it's powering the module
25 protection system, based on the process variables that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are being monitored, the module protection system goes
2 through a sequence of trips. It can do a SRAM, but
3 not an ECCS actuation.

4 The smart failure we're talking about
5 removes that decision that the MPS and the SRAM, so
6 that really is the difference there.

7 As far as the set up to that smart
8 failure, I'll turn it over to Kris to speak to that.

9 MR. CUMMINGS: Great, thank you, Kris
10 Cummings, NuScale. I've been with NuScale for a
11 little over four years and have 25 years' experience
12 in the industry working for various reactors and dry
13 cask storage, transportation task vendors.

14 In particular, you're right. There is a
15 smart failure event that was a topic, I'll call it a
16 stylized event, that was a topic of interest that
17 we've had significant discussions with the NRC in
18 Chapter 15. I'm going to address it very high level
19 because we haven't yet seen the NRC's evaluation of
20 Chapter 15 and how they disposition this in the end.
21 The particular event of interest here, involves a
22 reactivity addition event, i.e., a failure of the
23 control rod drive system and that that failure then
24 causes the rods to withdraw, increasing the reactor
25 power and temperature. Then the reactor power and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 temperature are high when the RVVs would open and then
2 during that very particularly, very limited time frame
3 that that occurs, there would be before the reactor
4 trip is actuated, there would be multiple failures of
5 each train, so both trains in EDAS would both have to
6 fail independently, randomly causing the reactor vent
7 valves to open.

8 So, we provided some additional analysis
9 to show that even in that event, you would maintain
10 core coolability and that coolable geometry, but that
11 would be in a very limited number of scenarios, but
12 even in that situation, we would be safe. That's the
13 proprietary information so we have to defer to the
14 closed session to talk about that. But again, that's
15 the information that we provided the NRC.

16 We're not confident where they're going to
17 end up and how they're going to evaluate that in
18 Chapter 15 because we haven't seen that Chapter 15
19 SER. But from a Chapter 8 perspective, which we're
20 talking about today, the augmented requirements that
21 we've put on EDAS including that it would fall under
22 the maintenance rule and that we would need to put
23 provisions into the owner controlled requirements
24 manual, ensure that EDAS has the level of availability
25 and reliability that we rely upon downstream in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 various analyses that are considered in Chapter 15.
2 That's, I think, where I can focus on today in this
3 particular open session and we can try to address
4 that.

5 MEMBER ROBERTS: Okay, that's helpful.
6 So, the concern is the simultaneous ECCS valve opening
7 and SREM causes a different --

8 (Simultaneous speaking.)

9 MR. CUMMINGS: And then a failure -- yeah,
10 and then a failure of EDAS to cause that, yeah.

11 MEMBER ROBERTS: I understand. So, one
12 question is whether that particular scenario is within
13 design basis or outside design basis and that, again,
14 gets into some discussion we had at that proprietary
15 level at the previous meeting, but I was reading out
16 of your Chapter 8, there's a conclusion drawn in
17 Chapter 8 that says, these EDAS and EDAS C functions
18 are not accredited to meet the accepted criteria for
19 design bases of vent analyses in Chapter 15. So, it
20 seems like we would have to have the Chapter 15
21 discussion --

22 MR. CUMMINGS: Right.

23 MEMBER ROBERTS: To really understand that
24 and whether or not we would agree with it.

25 MR. CUMMINGS: That's right and so just to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 get a little bit into Chapter 15, we do evaluate loss
2 of EDAS, but we do it at event initiation and not
3 being available. It's really at event initiation that
4 we consider it. We don't consider that smart failure
5 of EDAS in this very kind of limited scenario at the
6 most inopportune time. But that is a Chapter 15
7 discussion.

8 MEMBER ROBERTS: Right, so excluding that
9 for Chapter 15 requires using all these, well not
10 mitigations, but augmentations on this slide, are
11 essentially making the system as reliable basically as
12 the safety --

13 MR. CUMMINGS: Yes.

14 MEMBER ROBERTS: Related system would be.

15 MR. CUMMINGS: And that is one of the
16 requirements is to ensure that EDAS has a level of
17 reliability equivalent to a Class 1E system for
18 exactly this reason.

19 MEMBER ROBERTS: So a level of reliability
20 equivalent to a Class 1E system without calling it a
21 Class 1E, that's where my question kind of started, is
22 trying to understand the gap of what is it you're not
23 doing that it would go to you, who has to do it right.

24 (Simultaneous speaking.)

25 MEMBER ROBERTS: Yeah, looking at your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 list, it's pretty good here. Maybe we can leave that
2 as an open question to ask the staff what their view
3 as we get to them, but I think I understand now what
4 the story is, which is essentially as good as Class 1E
5 without calling it 1E because you want it to be that
6 reliable to include the scenario from the design basis
7 that has the failure at the exact wrong time.

8 MR. CUMMINGS: That's right and that
9 reliability is to ensure that we don't have an
10 inadvertent ECCS --

11 (Simultaneous speaking.)

12 MEMBER ROBERTS: There's lots of reasons
13 for the system to deal with.

14 MR. CUMMINGS: That's right. We don't
15 want those ECCS valves to open unless they get a
16 reactor trip signal, right? We don't want that to
17 occur and then have to go back to the gray dock to
18 evacuate and clean up the system, right, but it's not
19 from a safety perspective. If EDAS is either not
20 available or it fails as an event initiator, we've
21 shown in Chapter 15 that that is not a safety issue.

22 MEMBER ROBERTS: Okay, thanks.

23 CHAIR KIRCHNER: So, David or Kris, let me
24 just follow up on our earlier conversation about flood
25 zones and internal flooding. Now, you point out here

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that these, you know, you're obviously going to
2 protect these EDAS systems from natural phenomenon,
3 flooding and environmental conditions, so internal
4 flooding.

5 This suggests that they're not shared.
6 Are they in separate rooms or do they share the same
7 room? Could you have common mood, common cause
8 failure from internal flooding of the EDAS systems for
9 multiple functions or are you going to separate them?

10 MR. RICKENBACH: So, they're protected
11 from environmental conditions per GDC 4. Really they
12 sit in their own separate rooms on separate floors of
13 the reactor building and those rooms have to be
14 precluded to be a mild environment by design.

15 CHAIR KIRCHNER: Right. So, not to
16 belabor it, but I can't help but repeat the point I
17 was trying to make, this is important. You're going
18 through all of these things to ensure the reliability
19 and availability, why wouldn't you define the
20 configuration in layout for these and the reactor
21 building to make sure that, for example, the COL
22 applicant doesn't put them in the basement or
23 wherever? It seems to me that this rises to a level
24 that it should be specified in a standard design.

25 So, I'll ask the same question of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 staff. What's your position? Are you going to
2 provide some specs on the reactor building that
3 accommodates providing this protection from the
4 environmental conditions?

5 MR. RICKENBACH: When we specify standard
6 plant design, it's with the understanding that these
7 sets of equipment, EDAS, MPS, are in a defined portion
8 of the building. So, I wouldn't say that the COL
9 applicant has much option to relocate these. My
10 understanding of the flooding analysis, they may have
11 some leeway to address how they want to address
12 flooding, but that wouldn't be by moving EDA or MPS to
13 a different location in the building. It's defined.

14 MR. CUMMINGS: Yeah, Kris Cummings,
15 NuScale. I think the misnomer even in the earlier
16 discussion on flooding was like there was some
17 perception that it hasn't been specified. We've
18 specified the particular room and location where EDAS,
19 the different trains of EDAS and the MPS are going to
20 be, are intended to be placed.

21 CHAIR KIRCHNER: And the expectation then
22 is that the build out will follow that specification?

23 MR. CUMMINGS: That's intended, I mean,
24 again as with any standard design in a COLA, if
25 somebody wants to deviate from it they are, but that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a larger generic issue. We wouldn't anticipate
2 somebody wanting to make that change at this time.

3 MR. RICKENBACH: Yes, we agree. We want
4 it standardized. We want all of our plants to be the
5 same.

6 CHAIR KIRCHNER: I belabored that point
7 enough, but okay. Thank you. Is that it, David? Is
8 that the last slide?

9 MR. RICKENBACH: Yes, that's the last
10 slide.

11 CHAIR KIRCHNER: Okay.

12 MR. RICKENBACH: I'll turn it over to
13 Tyler Beck.

14 CHAIR KIRCHNER: Thank you.

15 (Simultaneous speaking.)

16 CHAIR KIRCHNER: Okay, yeah, we're going
17 to do a little mix and match here. For NRC, Sheila,
18 are you going --

19 MEMBER ROBERTS: Let me ask one more
20 question before we move along.

21 CHAIR KIRCHNER: Okay.

22 MEMBER ROBERTS: The FMEA for the EDAS
23 looked, like I said earlier, that they were both
24 adjusting voltage and all. For the non-safety AC
25 systems, did you do a similar FMEA?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RICKENBACH: We didn't.

2 MEMBER ROBERTS: Because what I'm
3 wondering is things like open phase conditions that
4 can cause some very strange transients into the plant.
5 Did you look at any of the important loads to see if
6 there could be some effect from something like an open
7 phase condition that might take you outside of the
8 bounds of analysis in Chapter 15? Again, not a simple
9 load, but some sort of strange transient on that load?

10 MR. RICKENBACH: So, a loss of voltage or
11 degraded voltage condition or other electrical
12 transient on our non-safety AC related power system,
13 it doesn't adversely affect the performance of plant
14 safety-related functions. So, we wouldn't include
15 that, so the example of open phase, you can look at it
16 from an aspect of execution functions. There's no
17 equipment to process coupling between our non-safety
18 AC systems and safety-related functions.

19 MEMBER ROBERTS: Right, but a safety-
20 related function is reliant on having to find the
21 design basis events that need to be protected and part
22 of looking at the bounds of what an electrical system
23 can do, is can it take you outside of the defined
24 transients are?

25 MR. RICKENBACH: This is a --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: Say an oscillating pump,
2 for example, vice a loss pump, you know that kind of
3 thing .

4 MR. RICKENBACH: I would say this is
5 bounded in Chapter 15 and when we look at items like
6 open phase and oscillating voltage, those types of
7 events don't have a couple into the plant, right?
8 There's no safety-related pumps for instance. The
9 only real coupling is through the MPS system itself.

10 MEMBER ROBERTS: Right, the transients are
11 defined and then the MPS is shown to protect for those
12 transients and so if you have a transient, it could be
13 worse, but it's currently defined because of something
14 like an open phase condition and presumably you would
15 need to define that as a new transient for analysis or
16 somehow bound it. That's really the question I'm
17 asking is, there's more to it than just the module
18 protective system. There's the transients you're
19 evaluating the MPS against bounded by what the
20 electrical system could do to those loads.

21 Your plant is not without reactor cooling
22 ponds, it's not clear there's much that could be in
23 that category, so it may be relatively trivial for
24 this design, I just wanted to make sure that you
25 looked at that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RICKENBACH: Yes.

2 MEMBER ROBERTS: It's not just about our
3 loss of voltage, there's all these other failure modes
4 and as long as the transients that are assumed in
5 Chapter 15 are bounded by whatever you could possibly
6 do to those loads, then that should be fine.

7 MR. RICKENBACH: That's correct. That's
8 my understanding of Chapter 15. It bounds from a loss
9 to full flow and then a spectrum in between.

10 MEMBER ROBERTS: Okay, thanks.

11 MR. VIVANCO: Good afternoon, everyone.
12 My name is Ricky Vivanco. I'm the Project Manager for
13 Chapter 8 Electric Power. I've been with the NRC for
14 almost three years and before this, I was Senior
15 Actor/Operator at Calvert Cliffs Power Plant.

16 The time line for Chapter 8 is the same as
17 the previous chapters. We received revision zero in
18 December 2022. We received revision one on October
19 31, 2023. Chapter 8 performed its audit from March
20 2023 to August 2023 and generated 24 issues. Fourteen
21 of those issues were resolved in the audit with 10 of
22 them being retracted due to the information presented
23 earlier for their audit issues. No RAIs were issued
24 as a result of the audit.

25 Joining me are Sheila Ray and Liliana

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Ramadan. They're the technical reviewers for this
2 chapter. Again, I'm the project manager and Gatachew
3 Tesfaye was the lead for this project.

4 This presentation focuses on the
5 acceptability of the design of the electrical power
6 system. Staff discussed their findings and they
7 quickly associated design in the following sections
8 the introduction, offsite power system, onsite power
9 system, station blackout.

10 The staff utilized a risk-informed, graded
11 approach consistent with the commission SECY-19-0036,
12 to evaluate the augmented quality aspects of EDAS.
13 Based on the information in FSAR Table 8.3-3, staff
14 considered the description of the augmented design
15 provisions adequate. These provisions in conjunction
16 with the availability controls discussed in Chapter 19
17 support the staff safety conclusions.

18 I'll open it up to questions there.

19 MEMBER ROBERTS: Yeah, Tom Roberts again.
20 I'm not quite seeing the connection with that SRM, I'm
21 wondering if you could talk more about that. That SRM
22 was looking at single-failure criteria of inadvertent
23 blackouts. I remember reading and the question was
24 whether or not you really had to have a rigorous
25 application of the single-failure criteria for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 scenario where the likelihood was very, very low and
2 then some information said, yeah, you ought to use a
3 little more judgment in scenarios like that.

4 In this case, there's an electrical
5 distribution system that is essentially the equivalent
6 of Class 1E, although it's got some deviations that we
7 haven't really fully fleshed out yet, but probably
8 related to the battery and the status of how you
9 qualify the side battery to the Class 1E
10 qualification, but everything else is there. So, what
11 you're showing here is that this single-failure
12 criteria for the valve thought process kind of applied
13 to that, where maybe the common feed is the likelihood
14 is pretty low to have the EDAS chose that time to go
15 away for the specific scenario that's going on. So,
16 there was a relatively low likelihood that you could
17 glean from that.

18 I'm just trying to get more perspective on
19 how that SRM applied.

20 MR. VIVANCO: I think like you just said
21 we formed the approach of taking into account the low
22 frequency of that smart failure along with considering
23 the availability controls and the augmented qualities
24 is what we used to support our conclusions.

25 MEMBER ROBERTS: Risk-informed is more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 judgment than using a PRA to go do some scenario of
2 comparison. Is that right?

3 MR. VIVANCO: Chapter 19 does discuss the
4 PRA considerations associated with the EDAS.

5 MR. MORTON: Ricky, can I step in for a
6 second?

7 MR. VIVANCO: Wendell Morton, he's the
8 Branch Chief for the Electrical Branch. He's going to
9 speak to it today.

10 MR. MORTON: Thank you for the intro, I
11 appreciate it. The SRM itself at a fundamental level
12 grants the staff the flexibility to take risk-informed
13 graded approach so that's not necessarily about the
14 valve that was the subject of the SRM, but the
15 flexibility the commission gave the staff to take a
16 risk-informed approach to evaluating these kinds of
17 systems and the classification may not necessarily be
18 on that level. That's the basis of SRM and the risk-
19 informed graded approach is consistent with the
20 commission's flexibility that they grant the staff to
21 make those kinds of approaches. Just to give you some
22 conditional perspective to what Ricky was saying.

23 MEMBER ROBERTS: From my interpretation,
24 the single-failure criterion is a deterministic
25 criterion that gave you the authority to use judgment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and when it's very low, in this case it's the Class 1E
2 definition of an electrical power system that's the
3 equivalent maybe of the single-failure criteria
4 whereas because of the issue with the battery and the
5 current status of qualification methodology for the
6 battery, you can't call it literally Class 1E, but as
7 Kris pointed out, it's the equivalent of Class 1E.
8 So, you're getting into the same place with a slightly
9 less literal interpretation of the regulation. Is
10 that a fair description?

11 MR. MORTON: I think that's fair, but like
12 Ricky said, combined with the augmentations in place,
13 the process controls they have in place, etc., allows
14 us to get to that place, yes.

15 MEMBER ROBERTS: Thanks, that makes sense
16 to me.

17 MR. RICKENBACH: I'll just add on that,
18 that it's not just the performance, it's also
19 consequences, right, and that's where that additional
20 analysis went, which is why we did it was to show that
21 even if this event occurred, this is a non-
22 consequential event. We can get into more of that in
23 Chapter 15 if need be, but that was where we are
24 applying the risk-informed performance based approach,
25 right. Performance based is here's the augmented

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 requirements. So, risk-informed is this does happen
2 much.

3 MR. VIVANCO: So, in conclusion, while
4 there are differences between the DCA and the SDA
5 design, the staff found that the applicant provided
6 sufficient information to support staff's safety
7 finding.

8 CHAIR KIRCHNER: Okay, members, any
9 questions on Chapter 8 of the staff or NuScale? Vesna
10 or Dennis, Steve and Charlie, any questions?

11 MR. BROWN: No.

12 MEMBER DIMITRIJEVIC: I'm good.

13 CHAIR KIRCHNER: Thank you. Well, thank
14 you all. You've beat Chapter 3 by about an hour and
15 a half. Thank you very much.

16 Let's move on, then, to our last chapter
17 for today, which is 14, Initial Test Program. For
18 those of you joining by Teams, we'll pause here for a
19 little bit to change out presenters.

20 (Whereupon, the above-entitled matter went
21 off the record at 4:29 p.m. and resumed at 4:31 p.m.)

22 CHAIR KIRCHNER: Okay, we're going to
23 reconvene and turn to Chapter 14 and Tyler Beck from
24 NuScale.

25 MR. BECK: Hello, my name is Tyler Beck

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and I will be presenting Chapter 14. I am the Chapter
2 14 licensing engineer with NuScale. I've been with
3 NuScale for over two years. Prior to my time at
4 NuScale, I worked for the NRC as a Reactor Systems
5 Engineer in the Generic Communications and Operating
6 Space Branch.

7 My educational background is a Bachelor's
8 of Science in Nuclear Engineering from the University
9 of Tennessee. Next slide.

10 This slide has an overview of Chapter 14
11 and the audit. For Section 14.0, that is just a high
12 level overview of verification programs and it's less
13 than one page. It is unchanged from the DCA. Section
14 14.1 essentially has the regulatory requirements
15 relevant to the initial test program and ITAAC. It is
16 also unchanged from the DCA.

17 Section 14.2 is the initial test program
18 and we'll have a slide on that in a couple of slides.
19 Section 14.3 presents the ITAAC selection methodology.
20 Part A includes the ITAAC for the US 460 Standard
21 Design Approval Application. In terms of changes, the
22 changes, these are verification programs and they
23 reflect the design, so the changes are a reflection of
24 the design changes from the DCA to the SDA.

25 During the audit, there were 22 audit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 items directly tied to Chapter 14 or Part A; however,
2 there were several additional audit items from other
3 chapters relating to ITAAC or ITP. Next slide.

4 The last slide we showed that Section 14.0
5 and 14.1 are unchanged from the DCA so we're just
6 starting with Section 14.2, which is the initial plant
7 test program. At a high level, the methodology and
8 general content of ITP are unchanged from the DCA. We
9 have revised some test abstracts due to design changes
10 or specific issues from the NRC staff and so an
11 example we have here is there was an audit item
12 resulting in clarification of some test objectives for
13 our ECCS blow down test. We wanted to really clarify
14 the ECCS blow down test sequence and objectives and
15 those were the changes there.

16 Another change is that we have removed the
17 overhead heavy load handling system interlock tables.
18 Those were in the DCA, Section 14.2, now they are not
19 because those interlocks are described in Chapter 9.
20 And then there have been some minor test updates. If
21 you were to go through and compare the test abstracts
22 from the DCA to SDA, you might find that the test
23 sequences are slightly revised, but functionally, we
24 are still testing the functions and the functions from
25 the DCA to the SDA are largely unchanged. So, those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 changes are just rearranged testing sequences and
2 approved numbering schemes for ease of operations.
3 Next slide.

4 Section 14.3 is titled ITAAC. However,
5 for us, it is just the ITAAC selection methodology
6 because Part 8 of the application presents the ITAAC
7 and ITAAC discussions. The selection methodology is
8 largely unchanged from the DCA; however, because of
9 the difference between a design certification and a
10 standard design approval, such as design
11 certifications including Tier 1 information, there is
12 some restructuring on how we refer to things that is
13 different, so you might in DCA have Tier 1 design info
14 now it's top level design features, things like that.
15 However, the selection methodology is largely
16 unchanged. As I said, Part 8 presents the SDA ITAAC
17 and ITAAC discussions. Next slide.

18 So, the next three slides will talk about
19 the changes of ITAAC between the DCA and SDA. We have
20 those listed out. This slide is for additions and
21 includes the ITAAC we've added. We've added an ITAAC
22 for the passive auto catalytic recombiner. It
23 includes fair final recombination rate, qualification,
24 functional arrangement. We've added ECCS supplemental
25 boron which is a new design feature to the SDA. We've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 added an ITAAC to verify containment vessel net pre-
2 volume and that was a result of the NRC staff's audit.

3 We've added ITAAC to verify -- there are
4 new automatic system responses for what's listed in
5 that sub-bullet there so main steam line, splash
6 boiler system, demineralized water system, reactive
7 waste drain system, site cooling wash system. There
8 were alarms in the DCA, however, we have added
9 automatic system response in the SDA and so that's
10 what the ITAAC is verifying.

11 We've added an ITAAC to verify travel
12 limits of the new fuel elevator and that is because in
13 the SDA, the new fuel elevator has the potential to
14 hold irradiated fuel for inspection, whereas in the
15 DCA, it did not. We've added an ITAAC to verify
16 integrated system validation for human factors
17 engineering, which is a result of the NRC staff's
18 Chapter 18 audit. Next slide.

19 MR. BROWN: Can I ask a question? On the
20 containment vessel free volume, why do you only do
21 that to the first nuclear power module?

22 MR. BECK: That came through our
23 negotiations and audit with the NRC staff and --

24 MR. BROWN: I mean, there's six of them
25 total.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BECK: Yes, so that will be performed
2 for the first MPM. The containment free volume is not
3 -- the modules are standard. The geometry is going to
4 be unchanged module to module and so this is really to
5 reconcile any construction deviances for the first
6 module that is not something that's going to be
7 subject to change between modules.

8 MR. BROWN: Okay, so you do know in
9 geometry basis then? Construction geometry?

10 MR. BECK: Yes, how exactly we're going to
11 perform it is not identified right now. That will be
12 performed by the co-applicant, but yes, that is the
13 requirement.

14 MR. BROWN: Thank you.

15 MR. BECK: This slide presents the ITAAC
16 we have removed in the SDA from the DCA and simple
17 one-line description as to why. Earlier, you heard
18 about a leak before break, there is no leak before
19 break analysis in the SDA, thus there is no ITAAC.

20 For Chapter 5, there is not an RVV
21 material surveillance program and so that will be
22 presented with Chapter 5, but as a result, there is no
23 ITAAC associated with that. In the DCA, we're ITAAC
24 verifying ASME Class III conformance for CVCS piping
25 and components. For the SDA, that has been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reclassified to ASME B31.1, and so there's no ITAAC
2 for that.

3 There are no important human actions in
4 the SDA. There was previously an ITAAC verifying new
5 fuel jib crane travel limits; however, in the SDA, it
6 is now a single-failure proof design and it has the
7 potential to travel over spent fuel and so this travel
8 limit still exists.

9 The DCA had an ITAAC verifying normal main
10 control room lighting and in the SDA that is not a top
11 level design feature. One reason is because there are
12 no important human actions. The DCA had eight-hour
13 battery pack emergency lighting fixtures, those are
14 not included in the SDA and that's in Section 5.3 of
15 the SR. There was an ITAAC verifying the automatic
16 system response to a high radiation signal in the pool
17 surge control system. In the SDA, the automatic
18 action is no longer there. There is an alarm function
19 still, but there's no automatic action.

20 I left one off of the slide accidentally,
21 but we also removed the ITAAC associated with
22 verifying the attenuating capability of the reactor
23 building's shielding doors. There are no accredited
24 shielding doors in the reactor building for the SDA,
25 thus no ITAAC for that. Next slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 This is the last slide and it presents the
2 ITAAC that we have changed from the DCA to the SDA.
3 The first one discusses the inability of the drain
4 down of the ultimate heat sink, so in the DCA it was
5 making sure that just truly based off of level. In
6 the SDA, we have piping penetrations that go below the
7 level that we need to maintain and thus, we have an
8 added anti-siphon devices. So, the ITAAC includes the
9 verification of those anti-siphon devices.

10 We have revised our ITAAC for the single-
11 failure proofness for our overhead heavy load handling
12 system components. There used to be separate ITAAC
13 for the various cranes and now they're just revised
14 into one ITAAC. In the DCA, there was what's called
15 a module lift adapter or module lifting fixture. In
16 the SDA, that is now the lower block assembly and top
17 support structure so the ITAAC reflects that design
18 change.

19 Then, the last one is the verification of
20 the Rad Waste Building, the RW-IIa, structure. In the
21 DCA, it was RW-IIa and in the SDA, only portions of
22 the building are classified as RW-IIa and so the ITAAC
23 reflects those portions. And that is it for Chapter
24 14 and Part 8.

25 CHAIR KIRCHNER: Thank you, Tyler. Before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we turn to the NRC, I wanted to point out that Matt
2 Sunseri is the Lead for Chapter 14 on the committee.
3 He joined us at 2:30 Eastern Time and so I'll turn to
4 you first, Matt, do you have any questions of NuScale?

5 MEMBER SUNSERI: Thanks, Walt. This is
6 Matt Sunseri. I don't have any questions in
7 particular. I thought the chapter looked pretty good
8 from my perspective, that the summaries were
9 representative of the kind of tests I'm accustomed to
10 seeing performed on initial startup plans. I did
11 sample a couple, there's a lot of information there,
12 but I did sample a few of them to make sure they
13 followed their methodology for the ITAAC construction
14 and it looks like they did, so I don't have any
15 concerns or questions about what they've done.

16 CHAIR KIRCHNER: Thank you. Other
17 members? With that, I'll turn to the NRC staff.
18 Who's going to be the lead? River, are you?

19 MS. ROHRMAN: Yeah, I'm the --

20 CHAIR KIRCHNER: Go ahead.

21 MS. ROHRMAN: Okay.

22 CHAIR KIRCHNER: Please.

23 MS. ROHRMAN: Once we get the slides up.
24 Hello, I'm River Rohrman, Project Manager, NRR. With
25 me, I have Angelo Stubbs and Nick Hansing. I will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 presenting the staff's review of the NuScale US 460
2 SDA Chapter 14, Initial Test Programs and Inspections,
3 Tests, Analyses and Acceptance Criteria. Next slide,
4 please.

5 For an overview of the review process,
6 NuScale submitted revision zero of Chapter 14 on
7 December 31, 2022, and revision one on October 31,
8 2023. The NRC conducted a regulatory audit of Chapter
9 14 starting in March 2023 and ending in December 2023.
10 Through the audit, 22 audit issues were identified and
11 resolved, four of which resulted in NuScale submitting
12 supplemental information to address questions and zero
13 RAIs were issued.

14 The staff completed Chapter 14 review and
15 issued an advanced safety evaluation to support
16 today's ACRS Sub-Committee meeting. Next slide,
17 please.

18 There are a lot of contributors to the
19 review of Chapter 14 due to the many different topics
20 covered. I'll not be going through each person here,
21 but thank you to everyone who worked on this chapter
22 for your contributions.

23 The sections of the SDA evaluated in this
24 chapter are Sections 14.2, Initial Test Program or
25 ITP, Section 14.3 and SDA Part 8, Inspections, Tests,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Analyses and Acceptance Criteria or ITAAC. As a note,
2 the ITP and ITAAC may change to address information
3 required to make a safety finding and upper chapters
4 as needed. The changes will be discussed in the high
5 upper chapters presentation as noted in the SE. Next
6 slide, please.

7 The ITP was reviewed and the reviewers
8 found that the design changes between the DCA and SDAA
9 were appropriately captured in the applicant's test
10 programs, middle end revisions. No significant
11 changes to the ITP itself were noted by the staff and
12 staff concluded that the SDAA ITP submittal, as
13 revised, conforms to the NUREG-0800 Standard Review
14 Plan for Additional Test Programs.

15 A comprehensive review of the following
16 sections was performed and compared to the DCA system,
17 ITAAC and no significant changes to the ITAAC program
18 itself were noted by the staff. The staff concluded
19 that the SDAA ITAAC submittal for these sections, as
20 revised, conforms to the NUREG-0800 Standard Review
21 Plan for Additional Test Programs.

22 The NCAA proposed piping systems and
23 components ITAAC were reviewed and compared to the
24 DCA. The design changes were appropriately captured
25 in the applicant's proposed ITAAC, such as the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 addition of the ECCS supplemental boron dissolvers and
2 the CNV lower mixing tubes. The staff concluded that
3 the SDAA proposed piping systems and components ITAAC,
4 as revised, meets the regulatory requirements for the
5 ITAAC as described in the SER.

6 The SDAA plant systems ITAAC were reviewed
7 and compared to the DCA changes to the plant systems
8 ITAAC used to perform fuel handling and for systems
9 used to conduct heavy load movements. The staff finds
10 that the SDAA plant systems ITAAC submittal, as
11 revised, provides reasonable assurance that the
12 facility built would be constructed and operated in
13 accordance with the license the AEA has amended and
14 the commission's rules and regulations.

15 The human factors engineering ITAAC were
16 reviewed and while some HFE review activities related
17 to the integrated systems validation were still
18 ongoing, the staff concluded that the SDAA HFE ITAAC
19 submittal, as revised, conforms with the NUREG-0800
20 Standard Review Plan for Human Factors Engineering.

21 The containment systems ITAAC were
22 reviewed and compared to the DCA. The significant
23 changes that resulted from Chapter 6 review are that
24 NuScale proposed a one-time ITAAC for the first module
25 built to verify the as built CNV free volume bounds

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the minimum value used in the containment design basis
2 analysis and NuScale is proposing ITAAC for the
3 passive autocatalytic recombiner as a result. The
4 staff finds that the SDAA containment systems ITAAC,
5 as revised, conforms to the NUREG-0800 Standard Review
6 Plan for Additional Test Programs.

7 In conclusion, while there are some
8 differences between the DCA and SCA, the staff found
9 that the applicant provided sufficient information to
10 support the staff's safety findings. The staff found
11 that all applicable regulatory requirements were
12 adequately addressed for the design. COL items are
13 provided for programs and site-specific aspects
14 similar to the DC application. Any questions?

15 CHAIR KIRCHNER: I'll start with Matt.
16 Matt, do you have any questions of the staff?

17 MEMBER SUNSERI: No, I think the staff did
18 a good job with their safety evaluation. I will just
19 note for the committee though I'm sure we're going to
20 have to questions about the removal of important human
21 actions, you know, based on some of the changes they
22 made. Of course, this is not the chapter to discuss
23 those. We'll discuss those in the individual
24 chapters, but they've added a number of systems that
25 we haven't really dug into how they operate boron

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 addition systems and such like that, so I can't make
2 -- I'm not in a position to make any judgment on
3 whether or not there are any important human actions
4 that need to be verified through ITAAC or not at this
5 stage. We will look at that in, as they are referred
6 to, the high importance chapters. That's all I have.

7 CHAIR KIRCHNER: Thank you. I have two
8 questions. River, we haven't reviewed yet the
9 addition of the boron dispenser, so perhaps the
10 question awaits when we have that material presented
11 to us, but the applicant, Tyler, talked about
12 functional testing, so I'm curious what you're looking
13 for in terms of the testing of that boron dispenser
14 that was added in the SDA design.

15 MS. ROHRMAN: Yes, I would defer that to
16 Hanry Wagage online.

17 MR. WAGAGE: This is Hanry Wagage. I
18 think the boron dispenser is not in the containment
19 round. It must be repositioned. It's not our area.
20 I think the passive recombiner system is in our, not
21 boron dispensing.

22 (Simultaneous speaking.)

23 MS. ROHRMAN: That would be Antonio, then?

24 MR. BARRETT: Yeah, this is Antonio
25 Barrett, Acting Branch Chief for Nuclear Methods --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Just speak up a little
2 more, please.

3 MR. BARRETT: Nuclear Methods and Systems,
4 New Reactors Branch. We currently have issued an RAI
5 that's outstanding for the testing of that system and
6 we're still looking through that, that particular
7 process. We're looking for basically an optimal test
8 of the dissolution mixing involved.

9 CHAIR KIRCHNER: Thank you. Then, my
10 other question, River, would be when you do the pre-
11 volume measurements to verify the geometry and so on
12 as it impacts containment analysis, are you also going
13 to do it in stages so you verify how much water it
14 takes to fill up until you get to the top of fuel
15 level versus the rest of the containment? See, where
16 I'm going with this is that's an important aspect of
17 the NuScale design when you look at the re-flood of
18 the core during ECCS performance. Will you stop
19 somewhere along the line and say okay, this is the
20 free volume up to the top, whatever reference point
21 the RVV, no I misspoke, the RRV or the top of the fuel
22 and then get the gross measurement, which would impact
23 the containment performance drawing blow down.

24 MR. WAGAGE: This is Harry Wagage again
25 from Containment and Plant Systems Branch. I put that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in the slide. This came from Chapter 6 review, which
2 is ongoing. I think it's not completed yet. We have
3 to wait on that.

4 CHAIR KIRCHNER: Okay. So, we may hear
5 more about that particular ITAAC after we have Chapter
6 6?

7 MS. ROHRMAN: Yeah, that will be discussed
8 in the Chapter 6 presentation.

9 CHAIR KIRCHNER: Okay. Thank you. Other
10 members and consultants? I overlooked Myron during
11 Chapter 8. Myron, if you're still out there and have
12 any questions, go ahead. Steve and Dennis and
13 Charlie?

14 DR. BLEY: I'm good.

15 DR. SCHULTZ: Nothing here.

16 CHAIR KIRCHNER: Not hearing any further
17 questions, thank you. Thank you for being with us.
18 Okay, members, last call. Okay, well let me summarize
19 and thank NuScale and the staff for your presentations
20 today. We will have summaries on each of these
21 chapters that we will take up at our next full
22 committee meeting in December. Thank you again. At
23 this point, I think I would be remiss if I didn't ask
24 for public comment.

25 MR. POLICH: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: So, go ahead, Mike.

2 MR. SNODDERLY: So, we could release some
3 staff members. Do you still want to have a closed
4 session?

5 CHAIR KIRCHNER: Unless members feel the
6 need for a closed session, other than Tom's -- and I
7 think Tom got the answer to the question that he
8 thought might require a closed session, so I don't
9 think we require that at this point.

10 MR. SNODDERLY: Thank you for making a
11 decision that way some staff should be excused.

12 CHAIR KIRCHNER: We will not have a closed
13 session.

14 (Simultaneous speaking.)

15 CHAIR KIRCHNER: And now I need to turn to
16 the public, so if there is anyone here in the room or
17 online who wishes to make a comment, please open up
18 your mic, state your name and affiliation as
19 appropriate and make your comment.

20 MR. POLICH: This is Tim Polich.

21 CHAIR KIRCHNER: Tim Polich, go ahead.

22 MR. POLICH: The discussion on Chapter 3,
23 it seems that the design still needs some work and
24 that there seems to be a lot of analysis that will be
25 performed by a COL applicant. I guess my comment is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that this looks like it will potentially result in
2 additional costs for COL applicant to make sure the
3 design is complete and to do additional analysis
4 rather than having it being done in the design
5 certification.

6 CHAIR KIRCHNER: Thank you, Tim, for your
7 comment. Other comments from the public?

8 Okay, hearing none, unless there is any
9 further business from members relevant to this topic?
10 Okay, then thank you. We will adjourn our
11 Subcommittee meeting.

12 (Whereupon, the above-entitled matter went
13 off the record at 4:56 p.m.)
14
15
16
17
18
19
20
21
22
23
24
25

C E R T I F I C A T E

This is to certify that the foregoing transcript

In the matter of: ACRS NuScale Design-Centered
Subcommittee

Before: NRC

Date: 11-05-24

Place: teleconference

was duly recorded and accurately transcribed under
my direction; further, that said transcript is a
true and accurate complete record of the
proceedings.



Court Reporter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1716 14TH ST., N.W., STE. 200

WASHINGTON, D.C. 20009-7831

October 30, 2024

Docket No. 052-050

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Material Entitled “ACRS Subcommittee Meeting (Open Session) Chapters 3, 8, and 14 (including Part 8),” PM-175101, Revision 0

The purpose of this submittal is to provide the presentation materials for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Subcommittee Meeting on November 5, 2024. The materials support NuScale’s presentation of the subject chapters of the US460 Standard Design Approval Application.

The enclosure to this letter is the nonproprietary presentation entitled “ACRS Subcommittee Meeting (Open Session) Chapters 3, 8, and 14 (including Part 8),” PM-175101, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Jim Osborn at 541-360-0693 or at josborn@nuscalepower.com.

Sincerely,



Mark W. Shaver
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Mahmoud Jardaneh, Chief New Reactor Licensing Branch, NRC
Getachew Tesfaye, Senior Project Engineer, NRC
Michael Snodderly, Senior Staff Engineer, Advisory Committee on
Reactor Safeguards, NRC

Enclosure 1: “ACRS Subcommittee Meeting (Open Session) Chapters 3, 8, and 14 (including Part 8),” PM-175101, Revision 0

Enclosure 1:

“ACRS Subcommittee Meeting (Open Session) Chapters 3, 8, and 14 (including Part 8),”
PM-175101, Revision 0



ACRS Subcommittee Meeting

(Open Session)

November 5, 2024

Chapters 3, 8, and 14 (including Part 8)

Acknowledgement and Disclaimer

This material is based upon work supported by the Department of Energy under Award Number DE-NE0008928.

This presentation was prepared as an account of work sponsored by an agency of the United States (U.S.) Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.



Chapter 3

Design of Structures, Systems, Components, and Equipment

(Excluding Sections 3.7, 3.8, and 3.9.2)

November 5, 2024


Presenters:

Peter Shaw, Andrea Mota, Daniel Diefendorf,
and Gene Eckholt

Chapter 3 Overview

- Chapter 3 describes the methodologies for design of structures, systems, and components
- SDAA is a derivative of the DCA design
- Presentation will focus on high level design and methodology changes and important audit questions and RAIs
- SDAA structures reflect 6 modules (from 12 modules in the DCA) and necessitates updated civil analysis with unchanged design basis
- SDAA design adopted the 2017 ASME BPV Code and 2017 ASME OM Code requirements

US460 Reactor Building Overview



- Overhead Heavy Load Handling System
- Reactor Building Walls
- Bioshield
- Spent Fuel Pool
- Ultimate Heat Sink

Chapter 3 - Design of Structures, Systems, Components and Equipment

- Section 3.1 – Conformance with U.S. Nuclear Regulatory Commission General Design Criteria
- Section 3.2 – Classification of Structures, Systems, and Components
- Section 3.3 – Wind and Tornado Loadings
- Section 3.4 – Water Level (Flood) Design
- Section 3.5 – Missile Protection
- Section 3.6 – Protection against Dynamic Effects Associated with Postulated Rupture of Piping
- Section 3.9 – Mechanical Systems and Components (excluding 3.9.2)
- Section 3.10 – Seismic and Dynamic Qualifications of Mechanical and Electrical Equipment
- Section 3.11 – Environmental Qualification of Mechanical and Electrical Equipment
- Section 3.12 – ASME Code Class 1, 2, and 3 Piping Systems, Piping Components and Associated Supports
- Section 3.13 – Threaded Fasteners (ASME Code Class 1, 2, and 3)
- Appendix 3C – Methodology for Environmental Qualification of Electrical and Mechanical Equipment

Section 3.1 – Conformance with U.S. Nuclear Regulatory Commission General Design Criteria

- Differences from DCA
 - General design criteria conformance is unchanged from DCA with the following exceptions:
 - GDC 27 conformance simplified for SDA with emergency core cooling system supplemental boron
 - Further discussion in Chapters 4, 6, and 15
 - GDC 32 lower RPV changed to stainless steel so no material surveillance required, Exemption 6 requested
 - Further discussion in Chapter 5
 - GDC 41, PDC 41 updated with passive autocatalytic recombiner maintaining inert atmosphere
 - Further discussion in Chapter 6
 - Similar update to GDC 42 and GDC 43
- Audit Results
 - No audit questions
- RAI Results
 - No RAI questions

Section 3.2 – Classification of Structures, Systems, and Components

- Differences from DCA
 - DCA Table 3.2-1 split to align with guidance for Regulatory Guide (RG) 1.26 and 1.29
 - SDAA Table 3.2-1 lists seismic classification of buildings
 - SDAA Table 3.2-2 lists Seismic Category I pressure retaining mechanical systems and components
 - Specific component classifications moved to system chapters
 - COL Item 3.2-1 removed, no applicants expected to add components to these tables in a COL application

- Audit Results
 - No audit questions

- RAI Results
 - No RAI questions

Section 3.3 – Wind and Tornado Loadings

- Differences from DCA
 - SDAA uses more conservative wind loads than required by regulatory guidance to consolidate analysis
- Audit Results
 - Eight audit questions resolved
 - Clarifications in the FSAR to specify which codes inform wind speeds and importance factors
- RAI Results
 - No RAI questions

Section 3.4 – Water Level (Flood) Design

- Differences from DCA
 - SDAA evaluates flood zones instead of rooms
 - COL Items removed for clarification, and to reflect removal of the personnel access tunnel from Reactor Building to Control Building (CRB)
- Audit Results
 - 17 audit questions resolved
- RAI Results
 - RAI 10167 (Question 3.4.1-3)
 - Updated considerations and assumptions used in the flooding analyses
 - Added tables for flooding sources and flooding zones
 - COL Item 3.4-2 updated to clarify the on-site program will be consistent with Section 3.4.1 methodology and flood levels

Section 3.5 – Missile Protection

- Differences from DCA
 - No essential equipment and no turbine missile evaluation for CRB
- Audit Results
 - 12 audit questions resolved
 - Added FSAR clarification regarding CRB and no essential equipment, therefore no turbine missile evaluation required
 - Added inputs used in the turbine analysis and a table for turbine missile parameters
 - Added a table identifying essential structures, systems, components and their locations
 - Added missile parameters for RW-IIa structures
- RAI Results
 - No RAI questions


Section 3.6 – Protection against Dynamic Effects Associated with Postulated Rupture of Piping

- Differences from DCA
 - Postulated pipe rupture hazards analysis updated for the SDA design
 - Leak-before-break methodology replaced with Branch Technical Position (BTP) 3-4 B.1(ii) methodology
- Five Audit questions resolved
- RAI results
 - RAI 10134 (Question 3.6.3-1)
 - Provided clarification on methodology change from leak-before-break to BTP 3-4 B.1 (ii)
 - Resulted in no changes to the SDA
 - RAI 10135 (Question 3.6.2.7-2)
 - Provided clarification on the leakage detection system in regards to RG 1.45
 - Resulted in no changes to the SDA
 - RAI 10177 (Question 3.6.2-2)
 - Demonstrated compliance with BTP 3-4 requirements
 - Emphasized margin to demonstrate robustness of the design
 - Weld examinations clarified in the FSAR

Section 3.9.1 – Special Topics for Mechanical Components

- Differences from DCA
 - Additional transients: density wave oscillations, loss of feedwater, initial test program, secondary leakage tests, control rod drive system piping failure
 - Removed transients: hydrogen detonation and hydrogen detonation with deflagration-to-detonation transition
 - Transients with cycle changes: containment flooding and drain, power ascent from hot shutdown, and turbine trip without bypass
- Audit Results
 - Three audit questions resolved
- RAI Results
 - No RAI questions

Detail from FSAR Figure 3.9-1



Section 3.9.2 – Dynamic Testing and Analysis of Systems, Components, and Equipment


- To be presented at a later ACRS meeting

Section 3.9.3 – ASME Code Class 1, 2, 3 and Non-Code Components, Component Supports, and Core Support Structures

- Differences from DCA
 - Updated to the 2017 Edition of ASME BPVC
- Audit Results
 - 12 audit questions resolved
- RAI Results
 - RAI 10150 (Question 3.9.3-11) response submitted
 - Provided additional information for the RPV flange bolted connections
 - Resulted in no changes to SDAA

Section 3.9.4 – Control Rod Drive System


- Differences from DCA
 - Change from welded connection to bolted connection
- Audit Results
 - Seven audit questions resolved
- RAI Results
 - RAI 10131 (Question 3.9.4-8)
 - Provided additional information for steam generator set screws
 - Added additional augmented visual examinations
 - RAI 10131 (Question 3.9.4-9)
 - Provided additional information for the control rod drive mechanism housings and associated connections
 - Resulted in no changes to the SDAA



Detail from FSAR Figure 3.9-3

Section 3.9.5 – Reactor Vessel Internals

- Differences from DCA
 - Upper Steam Generator Support – Reclassified from internal structure to a Class 1 Support
- Audit Results
 - No audit questions
- RAI Results
 - No RAI questions



Section 3.9.6 – Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints

- Differences from DCA
 - Updated requirements from ASME OM Code, 2012 Edition to ASME OM Code, 2017 Edition
 - Updated to ASME QME-1-2017
 - Updated requirements from 10 CFR 50.55a for New Reactors
- Audit Results
 - 16 audit questions resolved
- RAI Results
 - No RAI questions

Section 3.10 – Seismic and Dynamic Qualifications of Mechanical and Electrical Equipment

- Differences from DCA
 - Newer versions of regulatory guidance and industry standards adopted
 - Three COL Items related to administration of qualification program removed
 - A COL Application will incorporate the seismic and dynamic qualification program described in the SDA by reference
- Audit Results
 - One audit question resolved
- RAI Results
 - No RAI questions

Section 3.11 – Environmental Qualification of Mechanical and Electrical Equipment

- Differences from DCA
 - List of environmentally qualified equipment updated to reflect US460 design
- 11 audit questions resolved
 - Created new equipment qualification zones for control building and for harsh environments with electronic equipment
 - Clarified application of industry standards
 - Evaluated design-basis accident dose contributions for the limiting collapsed liquid level event
- RAI Results
 - No RAI questions

Appendix 3C – Methodology for Environmental Qualification of Electrical and Mechanical Equipment

- Differences from DCA
 - Updated to reflect US460 design
 - Environmental qualification zones
 - Harsh/Mild environment areas
 - Post-accident operating times
 - Normal operating conditions
 - Design-basis event environment conditions
 - Limiting design-basis accident environmental qualification radiation dose
- Audit Results
 - One audit question resolved
- RAI Results
 - No RAI questions

Section 3.12 – ASME Code Class 1, 2, and 3 Piping Systems, Piping Components and Associated Supports

- Differences from DCA
 - Removed reference to NUREG-1367, “Functional Capability of Piping Systems”
- Audit Results
 - 12 audit questions resolved
 - Clarified how the functional capability guidance of NUREG-1367 is addressed by NuScale
- RAI Results
 - No RAI questions

Section 3.13 – Threaded Fasteners (ASME Code Class 1, 2, and 3)

- Differences from DCA
 - Containment vessel pressure retaining threaded fasteners are examined in accordance with ASME BPVC, Section XI, Subsection IWE.
- Audit Results
 - Three audit questions resolved
- RAI Results
 - RAI 10133 (Question 3.13-1) response submitted
 - Added augmented visual examination requirements for ASME Class 1 threaded inserts and seal welds



Chapter 8 Electric Power

November 5, 2024

Presenter: David Rickenbach

Chapter 8 Overview

- Section 8.1 – Overview
- Section 8.2 – Offsite Power Systems
- Section 8.3 – Onsite Power Systems
- Section 8.4 – Station Blackout (SBO)

- SDAA changes from DCA :
 - Conforming changes in SDAA reflect US460 standard design, which is functionally equivalent to the DCA
 - DCA included six COL items, none in the SDAA
 - FSAR content optimized from the US600 DCA
 - Example: Removed specific wattage of plant loads from FSAR tables

- 14 audit questions resolved

Overview of Design Changes

- AC power
 - Common load AC power provided by redundant transformers
 - High voltage AC electrical distribution configuration
 - Backup power supply system configuration
- DC power
 - Single battery string for each augmented DC power system (EDAS) power channel
 - EDAS divisions are physically separated in independent rooms
 - EDAS includes power channel cross-connects

Section 8.1 – Overview

- High-level overview of onsite and offsite power sources
- Technical content reflects US460 plant systems instead of US600 plant systems
- GDC conformance is unchanged from US600 DCA

- Audit Results
 - FSAR Table 8.1-1 revised to include more information for the US460 standard plant design, such as the IEEE standards applicable to EDAS

- RAI Results
 - No RAI questions

Section 8.2 – Offsite Power Systems

- Technical content is generally unchanged
- COL items removed in SDAA:
 - Removed COL Item 8.2-1, description of the site-specific plant switchyard
 - Removed COL Item 8.2-2, description of the site-specific offsite power (grid study)
 - Removed COL Item 8.2-3, description of required testing
 - With GDC 17 and 18 exemption, site does not rely on offsite power
 - DCA COL items were unnecessary
- Audit Results
 - No audit questions
- RAI Results
 - No RAI questions

Section 8.3 – Onsite Power Systems

- Technical content is revised to reflect design on US460 electric power systems
- COL items removed in SDAA:
 - Removed COL Item 8.3-1, as the US460 design does not have AAPS
 - Removed COL Item 8.3-2, no electrical heat tracing system: not required for a safety finding in DCA
 - Removed COL Item 8.3-3, site-specific information was not needed to demonstrate compliance with RG 1.204 in DCA
 - US460 standard design maintains conformance with RG 1.204
- Audit Results
 - Addition of Table 8.3-3 to describe EDAS augmented system design, qualification, and quality assurance provisions
- RAI Results
 - No RAI questions

Section 8.4 – Station Blackout

- The US460 SBO is similar to the DCA.
- An SBO does not does not pose a significant challenge to the plant, because the plant does not rely on AC power for performing safety functions. A safe and stable shutdown is automatically achieved and maintained for 72 hours without operator actions.

Reliability and Availability of EDAS

- EDAS batteries are environmentally qualified per IEEE 323
- Portions of the nonsafety-related EDAS supplying DC power to ECCS valves are augmented:
 - SC-I components
 - Protected from natural phenomena (GDC 2)
 - Protected from environmental conditions (GDC 4)
 - Not shared between modules (GDC 5)
 - Protected from fire per RG 1.189 (GDC 3)
 - Include physical independence per RG 1.75
 - Separated into redundant load groups
 - Designed to be single-failure proof per RG 1.53
- Validated EDAS is within the scope of the Maintenance Rule Program
- Included EDAS in owner-controlled requirements manual



Chapter 14 (including Part 8) Initial Test Program and ITAAC

November 5, 2024

Presenter: Tyler Beck

Chapter 14 Overview

- Section 14.0 – Verification Program (overview)
 - Section 14.0 is unchanged from the DCA
- Section 14.1 – Specific Information to be Addressed for the Initial Plant Test Program (describes relevant regulations)
 - Section 14.1 is unchanged from the DCA
- Section 14.2 – Initial Plant Test Program (ITP)
- Section 14.3 – Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC), including the ITAAC selection methodology
- Part 8 includes the ITAAC for the US460 standard plant design
- Changes from the DCA generally reflect system design changes to the US460
- 22 audit items directly in Chapter 14 or Part 8
 - Several additional audit items tied to ITP or ITAAC originate through other chapters

Section 14.2 – Initial Plant Test Program

- The methodology and general content of ITP is unchanged from the DCA
- Revised test abstracts are due to design changes or specific issues from the NRC staff
 - Example: Audit item request resulting in clarification of test objectives for the emergency core cooling system (ECCS) blowdown test (e.g., “Verify ECCS RRVs remain closed above the IAB block threshold differential pressure setpoint”)
- Overhead heavy load handling system interlock tables removed from Section 14.2
 - Interlocks described in Chapter 9
- Test updates to reflect ease of testing and operations (e.g., rearranged testing sequences, improved numbering scheme for test method)

Section 14.3 – Inspections, Tests, Analyses, and Acceptance Criteria

- Section 14.3 presents the ITAAC selection methodology
 - ITAAC selection methodology is unchanged from DCA
 - DCA Section 14.3 reflected ITAAC being included in Tier 1 → there is no Tier 1 for SDAA
 - DCA Section 14.3 included ITAAC discussions and → SDAA includes these in Part 8
- Part 8 presents the SDAA ITAAC and associated ITAAC discussions
 - This information was included in Tier 1 and FSAR Section 14.3 in the DCA

Part 8 – ITAAC

- SDAA ITAAC additions:
 - Passive autocatalytic recombiner
 - ITAAC verifying recombination rate, qualification, functional arrangement
 - ITAAC verifying functional arrangement for ECCS supplemental boron
 - ITAAC verifying containment vessel net free volume (applicable to first NuScale Power Module only)
 - ITAAC verifying automatic system response to new high radiation signals:
 - New automatic high radiation actions in main steam lines, auxiliary boiler system, demineralized water system, radioactive drain waste system, and site cooling water system
 - ITAAC verifying travel limits of the new fuel elevator
 - ITAAC verifying integrated system validation for Human Factors Engineering

Part 8 – ITAAC (continued)

- SDAA ITAAC removal based on design changes:
 - ITAAC verifying leak-before-break (LBB) analysis → no LBB analysis (Section 3.6)
 - ITAAC related to RPV material surveillance specimens → no RPV material surveillance program (Section 5.3)
 - ITAAC verifying ASME design and data reports for Class III chemical and volume control system piping and components → reclassified to ASME B31.1 piping (Section 9.3.4)
 - ITAAC verifying controls for important human actions → no important human actions (Section 18.6)
 - ITAAC verifying the new fuel jib crane travel limits → no travel limits due to single-failure proof design (Section 9.1.4)
 - ITAAC verifying normal main control room lighting → not a top-level design feature (Section 14.3)
 - ITAAC verifying 8-hour battery-pack emergency lighting fixtures → not included in the design (Section 9.5.3)
 - ITAAC verifying automatic system response to high radiation signal in pool surge control system → this automatic system action is not included in the design (Sections 9.1.3 and 11.5)

Part 8 – ITAAC (continued)

- SDAA ITAAC updates:
 - ITAAC verifying inability for drain down of ultimate heat sink → revised to include anti-siphon devices on piping that extends below 49.5 ft pool level (Section 9.1.3)
 - ITAAC verifying single-failure proof overhead heavy load handling system components → revised to one ITAAC
 - ITAAC verifying features of the module lift adapter and module lifting fixture → incorporated into lower block assembly and top support structure (Section 9.1.5)
 - ITAAC verifying Radioactive Waste Building as an RW-IIa structure → revised to reflect only the RW-IIa portions of the building (Section 3.8.4)

Acronyms

ACRS	Advisory Committee on Reactor Safeguards	ITAAC	Inspections, Tests, Analyses, and Acceptance Criteria
ASME	American Society of Mechanical Engineers		
BDG	Backup Diesel Generator	ITP	Initial Test Program
BTP	Branch Technical Position	NPS	Nominal Pipe Size
BPVC	Boiler and Pressure Vessel Code	NRC	Nuclear Regulatory Commission
COL	Combined Operating License	OM	Operation and Maintenance
CRB	Control Building	PDC	Principal Design Criteria
DCA	Design Certification Application	RAI	Request for Additional Information
ECCS	Emergency Core Cooling System	RG	Regulatory Guidance
EDAS	Augmented DC Power System	RPV	Reactor Pressure Vessel
EQ	Environmental Qualification	RRV	Reactor Recirculation Valve
FSAR	Final Safety Analysis Report	RWB	Radioactive Waste Building
GDC	General Design Criterion	SDAA	Standard Design Approval Application
IAB	Inadvertent Actuation Block	SDA	Standard Design Approval
IEEE	Institute of Electrical and Electronics Engineers		

Presentation to the Advisory Committee on Reactor Safeguards Subcommittee Staff Review of NuScale's US460 Standard Design Approval Application Final Safety Analysis Report, Revision 1

Chapters 3 (Except Sections 3.7, 3.8, 3.9.2),
8, and 14

November 5, 2024
(Open Session)

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

Contributors

- **Technical Reviewers**

Michael Breach (NRR/DEX/EMIB)

Gordon Curran (NRR/DSS/SCPB)

Kaihua Hsu (NRR/DEX/EMIB)

Nicholas Hansing (NRR/DEX/EMIB)

Cory Parker (NRR/DNRL/NVIB)

Edward Stutzcage (NRR/DRA/ARCB)

Sheila Ray (NRR/DEX/EEEB)

George Wang (NRR/DEX/ESEB)

John Honcharik (NRR/DNRL/NPHP)

Chakrapani Basavaraju (NRR/DEX/EMIB)

Raul Hernandez (NRR/DSS/SCPB)

Thomas Scarbrough (NRR/DEX/EMIB)

Jorge Cintron-Rivera (NRR/DEX/ELTB)

- **Project Managers**

-Prosanta Chowdhury, PM, NRR/DNRL/NRLB

-Getachew Tesfaye, Lead PM, NRR/DNRL/NRLB

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

Overview

- NuScale submitted Chapter 3, “Design of Structures, Systems, Components and Equipment,” Revision 1, of the NuScale SDAA FSAR on October 31, 2023.
- NRC performed a regulatory audit as part of its review of Chapter 3, from March 2023 to December 2023.
- Questions raised during the audit were resolved within the audit. Seven RAIs were issued.
- The staff completed the review of Chapter 3 (Except for Sections 3.7, 3.8, 3.9.2) and issued an advanced safety evaluation to support the ACRS Subcommittee meeting.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

Sections Evaluated

- Section 3.1 – Conformance with the U.S. Nuclear Regulatory Commission General Design Criteria
- Section 3.2 – Classification of Structures, Systems, and Components
- Section 3.3 – Wind and Tornado Loading
- Section 3.4 – Water Level (Flood) Design
- Section 3.5 – Missile Protection
- Section 3.6 - Protection against Dynamic Effects Associated with the Postulated Rupture of Piping
- Section 3.9 (except 3.9.2) - Mechanical Systems and Components
- Section 3.10 - Seismic and Dynamic Qualification of Mechanical and Electrical Equipment
- Section 3.11 - Environmental Qualification of Mechanical and Electrical Equipment –
- Section 3.12 - ASME BPV Code Class 1, 2, and 3 Piping Systems and Associated Support Design
- Section 3.13 - Threaded Fasteners—ASME BPV Code Class 1, 2, and 3

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):

- Sections 3.1 Conformance with the U.S. Nuclear Regulatory Commission General Design Criteria
 - Discussed in applicable sections of the SE.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):

- Sections 3.2 Classification of Structures, Systems, and Components
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - NuScale provided SSC seismic classification of Category I, II and III in FSAR Tables 3.2-1 and 3.2-2, consistent with regulations and guidance.
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.3 Wind and Tornado Loading
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - High wind speed 190 mph and maximum tornado wind speed 270 mph.
 - Using ASCE/SEI 7-16 to establish the wind load pressure for RW-IIa structures.
 - NuScale provided adequate justification for applying the wind load pressure on the RW-IIa structures by using ASCE/SEI 7-16.
 - SDAA SE conclusion is the same as DCA SE conclusion.
- 7 Audit Questions
 - All were resolved during the audit.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- Sections 3.4.1 Internal Flood Protection for Onsite Equipment Failure
 - Significant differences between NuScale DCA FSAR and SDAA FSAR.
 - Flood analysis methodology defined bounding flood levels for building zones (individual rooms not discussed, such as battery rooms or instrument rooms).
 - Maximum SDAA flood heights are significantly greater than DCA.
 - Location of SSC subject to flood protection not identified.
 - NuScale provided
 - Flood analysis results table of zone, limiting flood source, and max flood height
 - COL Items 3.5-1, 3.5-2 and 3.5-3 confirm the final location and mitigation of SSC subject to flood
 - SDAA SE conclusion is the same as DCA SE conclusion, with addition of COL applicant to further evaluate SSC protection from flood levels.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.4.2 Flood Protection from External Sources
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - NuScale provided:
 - The analysis procedures to transform the static and dynamic effects of the highest flood and groundwater levels into effective loads.
 - COL Items 3.4-4 and 3.4-5.
 - SDAA SE conclusion is the same as DCA SE conclusion.
- 11 Audit Questions
 - All were resolved during the audit.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.5.1.1 Internally-Generated Missiles (Outside Containment)
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - NuScale provided:
 - The evaluation of internally-generated missile from plant equipment and credibility of missiles.
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.5.1.2 Internally-Generated Missiles (Inside Containment)
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - NuScale described:
 - no credibility of missiles inside containment based on plant design.
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- Section 3.5.1.3 Turbine Missile
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - Increased bounding turbine missile parameters - mass and velocity (77MWe vs 50 MWe turbine)
 - Orientation of Control Building (CRB) is more favorable with regard to turbine missile trajectory; however, the CRB is not considered essential to be protected from turbine missiles (high trajectory)
 - NuScale provided:
 - Bounding missile parameters and barriers analysis of Reactor Building (discussed in Section 3.5.3 of the SER)
 - SCC required to be protected
 - COL Items 3.5-1 and 3.5-3- demonstrate site specific turbine missile parameters are bounded by analysis, and evaluate other nearby facilities turbine parameters
 - SDAA SE conclusion is the same as DCA SE conclusion that essential SSCs are protected from turbine missiles using barriers.
- 2 Audit Questions
 - All were resolved in audit

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.5.1.4 Missiles Generated by Tornadoes and Extreme Winds
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - NuScale described:
 - Defined missile types and parameters from extreme wind missiles evaluated in design.
 - COL 3.5-2 to confirm automobile missile velocity and altitude of impact parameters will bound extreme wind conditions at site
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.5.1.5 Site Proximity Missiles (Except Aircraft)
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - NuScale provided:
 - COL Item 3.5-3 to evaluate site-specific hazards from nearby or co-located facilities for more energetic missiles than defined in SDAA
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.5.2 Structures, Systems, and Components to be Protected from External Missiles
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - NuScale provided:
 - Safety-related and risk significant SSC that must be protected are from external missiles are located inside Seismic Category I RXB and Seismic Category I portions of CRB.
 - CRB is not considered essential to be protected from turbine missiles (see slide for Section 3.5.1.3)
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- **Section 3.5.3 Barrier Design Procedures**
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - Steel-Plate Composite Walls (not available for DCA)
 - Steel Barriers (not available for DCA)
 - NuScale provided:
 - Three-step design approach based on Bruhl Equations to prevent perforation of SC walls from missile impacts.
 - Ballistic Research Laboratory (BRL) Formula to determine the minimum steel missile barriers with 25% thickness increase.
 - SDAA SE conclusion is the same as DCA SE conclusion except for Steel-Plate Composite Walls and Steel Barriers.
- **8 Audit Questions**
 - All were resolved during the audit.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- Sections 3.6 "Protection against Dynamic Effects Associated with the Postulated Rupture of Piping"
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - LBB methodology no longer used for MSS and FWS inside CNV – BEZ to use BTP 3-4
 - Leak Detection sensitivity changed from 0.005 gpm to 0.01 gpm - no LBB
 - Added CITF between CNV Nozzle safe end and CIV for lines outside CNV in the BEZ under Bioshield
 - NuScale provided:
 - Preliminary analysis results for MSS & FWS show acceptability for change to BTP 3-4
 - Leakage detection sensitivity change, stated above, meets RG 1.45 limit of 0.5 gpm
 - Preliminary analysis results for welds in BEZ outside CNV under bioshield justifies break exclusion (with CITF)
 - Preliminary stress analysis for ECCS RRV/RVV bolted connections with threaded inserts (unchanged from DCA) is representative for other bolted connections with threaded inserts
 - 5 Audit Questions and 3 RAIs - resolved
 - SDAA SE conclusion is the same as DCA SE conclusion

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Sections 3.9.1 "Special Topics for Mechanical Components"
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - Heatup rate for Reactor Heatup to Hot Shutdown transient changed
 - NuScale provided:
 - The final component stress analysis will use the latest transients' input for ITAAC.
 - SDAA SE conclusion is the same as DCA SE conclusion
 - This does not include evaluation of DWO

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- Sections 3.9.3 "ASME Code Class 1, 2, and 3 Components, Component Supports, and Core Support Structures"
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - Upper and lower sections of the Reactor Vessel are constructed from different materials that have different coefficients of thermal expansion, which is considered in the stress qualification of the closure bolts and flanges.
 - NuScale provided:
 - Discussion of bolted connection and its design
 - Preliminary FEA results
 - SDAA SE conclusion is the same as DCA SE conclusion

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- **Sections 3.9.4 "Control Rod Drive Systems"**
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - Use of DCA drop and shaft alignment testing for SDAA design
 - Use of threaded connections instead of welded connections between CRDM and RPV (further discussed in Section 3.13)
 - Rod holdout mechanism feature
 - Steam generator tube support assembly (consider impact to CRDS)
 - NuScale provided:
 - Adequate justification to apply DCA testing to SDAA design, reconciling differences.
 - Analysis of threaded connections (discussed in Section 3.13)
 - Justification that rod holdout mechanism feature would not adversely impact safety function of inserting rods
 - Details of assemblies, proposed inspections to monitor for degradation
 - SDAA SE conclusion is the same as DCA SE conclusion.
 - Audit Questions and RAIs:
 - 7 Audit Questions were resolved in audit
 - 2 RAIs resolved

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Section 3.9.5 "Reactor Pressure Vessel Internals"
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
 - Section 3.9.6, “Functional Design, Qualification, and Inservice Testing [IST] Programs for Pumps, Valves, and Dynamic Restraints”
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - Redesign of ECCS Valve System requiring 10 CFR 50.43(e) testing and lessons learned to plan for ASME QME-1 qualification testing
 - Need to address 2017 Edition of ASME OM Code with motor-operated valve and air-operated valve diagnostic testing requirements beyond 2012 Edition in DCA
 - NuScale provided:
 - Audit access to ECCS valve system proof-of-concept test specification and reports to support compliance with 10 CFR 50.43(e).
 - Updated relief and alternative requests to reflect 2017 Edition of ASME OM Code
 - Draft revision to FSAR and ECCS test description in response to NRC review and audit findings.
 - **SDAA SE conclusion is the same as DCA SE conclusion.**
-

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Sections 3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- Section 3.11, “Environmental Qualification of Mechanical and Electrical Equipment”
 - Significant differences between NuScale DCA FSAR and SDAA FSAR include:
 - Changes to FSAR Table 3.11-1 for equipment and qualification
 - Potential use of IEEE standards not endorsed by NRC regulatory guides
 - Chapter 15 accident scenarios with lower coolant levels for longer duration than DCA
 - NuScale provided:
 - Adequate justification for NRC staff to rely on past experience from DCA review to inform SDAA review.
 - Proposed FSAR revisions to support NRC safety findings.
 - Conclusion:
 - The staff found that all applicable regulatory requirements were adequately addressed.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):
- Sections 3.12 ASME BPV Code Class 1, 2, and 3 Piping Systems and Associated Support Design
 - There are no significant differences between NuScale DCA FSAR and SDAA FSAR.
 - SDAA SE conclusion is the same as DCA SE conclusion.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

- **NuScale DCA FSAR Chapter 3 (Rev. 5) vs SDAA FSAR Chapter 3 (Rev. 1):**
- Sections 3.13 Threaded Fasteners—ASME BPV Code Class 1, 2, and 3
 - Significant differences between NuScale DCA FSAR and SDAA FSAR:
 - The RVVs and RRVs were changed to be bolted directly to the reactor vessel nozzle
 - These four bolted flange connections were classified as break exclusion areas
 - Added augmented examination requirements for ASME Class 1 threaded inserts and seal welds
 - NuScale provided:
 - Engineering study of stresses of the bolted flange connections that adequately show that the probability of gross rupture of the ECCS valves bolted connections is extremely low
 - SDAA SE conclusion is the same as DCA SE conclusion.
 - Sampling plan and expansion criteria for the steam and feedwater plenum that can be credited for RVV and RRV break exclusion locations.

NuScale SDAA FSAR Chapter 3 Review

(Except for Sections 3.7, 3.8, 3.9.2)

Conclusion

- While there are some differences between the DCA and the SDAA, the staff found that the applicant provided sufficient information to support the staff's safety finding.
- The staff found that all applicable regulatory requirements were adequately addressed.

**Presentation to the ACRS Subcommittee
Staff Review of NuScale SDAA FSAR, Revision 1**

Chapter 8 "Electric Power"

**November 5, 2024
(Open Session)**

NuScale SDAA FSAR Chapter 8 Review

Overview

- NuScale submitted Chapter 8, Auxiliary Systems, Revision 0 of the NuScale SDAA FSAR on December 31, 2022, and Revision 1 on October 31, 2023
- NRC regulatory audit of Chapter 8 was performed from March 2023 to August 2023, generating 24 audit issues
- 14 audit issues were resolved in the audit
- 14 audit issues resulted in NuScale submitting supplemental information to address questions raised during the audit. 10 issues were retracted as a result of information presented.
- No RAIs were issued
- Staff completed Chapter 8 review and issued an advanced safety evaluation to support today's ACRS Subcommittee meeting

NuScale SDAA FSAR Chapter 8 Review

Contributors

- **Technical Reviewers**
 - Sheila Ray, NRR/DEX/EEEE
 - Liliana Ramadan, NRR/DEX/ELTB
- **Project Managers**
 - Ricky Vivanco, PM, NRR/DNRL/NRLB
 - Getachew Tesfaye, Lead PM, NRR/DNRL/NRLB

NuScale SDAA FSAR Chapter 8 Review

Sections

- 8.1 – Electric Power - Introduction
- 8.2 – Offsite Power System
- 8.3 – Onsite Power System
- 8.4 – Station Blackout

NuScale SDAA FSAR Chapter 8 Review

Augmented DC Power System (EDAS)

- EDAS is the Augmented DC power system of the NuScale US 460 design
- Consistent with the SRM-SECY-19-0036, a risk-informed, graded approach commensurate with the design type and features that acknowledges the mitigative measures available to ensure reasonable confidence of public health and safety is acceptable.
- This holistic approach considers realistic conditions, plant behaviors, and operator responses in conjunction with the agency's deterministic assumptions and analyses to provide context and perspective to making risk-informed decisions.
- The staff used a risk-informed, graded approach to evaluate the augmented quality aspects in FSAR Table 8.3-3 of the EDAS as supported by SRM-SECY-19-0036.
- The staff considers that the description for the augmented design, qualification, and quality assurance provisions in FSAR Table 8.3-3 is adequate.

NuScale SDAA FSAR Chapter 8 Review

Conclusion

- While there are some differences between the DCA and the SDAA, the staff found that the applicant provided sufficient information to support the staff's safety finding.

**Presentation to the ACRS Subcommittee
Staff Review of NuScale SDAA FSAR, Revision 1**

**Chapter 14, "Initial Test Program and Inspections, Tests, Analyses and
Acceptance Criteria"**

**November 5, 2024
(Open Session)**

NuScale SDAA FSAR Chapter 14 Review

Overview

- NuScale submitted Chapter 14, “Initial Test Program and Inspections, Tests, Analysis, and Acceptance Criteria,” Revision 0 of the SDAA FSAR on December 31, 2022, and Revision 1 on October 31, 2023
- NRC regulatory audit of Chapter 14 performed March 2023 to December 2023, generating 22 audit issues
- 22 audit issues were resolved in the audit
- 4 audit issues resulted in NuScale submitting supplemental information to address questions raised during the audit
- 0 RAIs were issued
- Staff completed Chapter 14 review and issued an advanced safety evaluation to support today's ACRS Subcommittee meeting

NuScale SDAA FSAR Chapter 14 Review

Contributors

- **Technical Reviewers**
 - Charley Peabody, NRR/DSS/SNRB
 - Nicholas Hansing, NRR/DEX/EMIB
 - Andrew Prinaris, NRR/DEX/ESEB
 - Joe Ashcraft, NRR/DEX/EICB
 - Dinesh Taneja, NRR/DEX/ELTB
 - Liliana Ramadan, NRR/DEX/ELTB
 - Angelo Stubbs, NRR/DSS/SCPB
 - David Nold, NRR/DSS/SCPB
 - Ed Stutzcage, NRR/DRA/ARCB
 - Maurin Scheetz, NRR/DRO/IOLB
 - Kamishan Martin, NRR/DRO/IOLB
 - Ken Mott, NSIR/DPR/RLB
 - Hanry Wagage, NRR/DSS/SCPB
 - Stacy Prasad, NSIR/DPCP/RPPB
 - George Wang, NRR/DEX/ESEB
 - Zuhan Xi, NRR/DEX/ESEB
- **Project Managers**
 - River Rohrman, PM, NRR/DNRL/NRLB
 - Getachew Tesfaye, Lead PM, NRR/DNRL/NRLB

NuScale SDAA FSAR Chapter 14 Review

Sections Evaluated

- Section 14.2 – Initial Test Program
- Section 14.3 (SDAA Part 8) – Inspections, Tests, Analyses, and Acceptance Criteria
- The ITP and ITAAC may change to address information needed to make a safety finding in high effort chapters, as needed. The changes will be discussed as part of the high effort chapters presentation.

NuScale SDAA Ch. 14.2 Initial Test Program

Significant Changes from DCA to SDAA

- A comprehensive review of the Initial Test Program (ITP) procedures was performed and compared to the DCA ITP.
 - Reviewers found that design changes between the DCA and the SDAA were appropriately captured in the applicants test program submittal and revisions.
- No significant programmatic changes to the Initial Test Program itself were noted by the staff.
- The staff concluded that the SDAA ITP submittal as revised conforms to the NUREG-0800 Standard Review Plan for Initial Test Programs.

NuScale SDAA FSAR Ch. 14.3 ITAAC Review

NO Significant Changes from DCA to SDA

- A comprehensive review of the ITAAC requirements for the following SER Sections were performed and compared to the corresponding DCA system ITAAC Requirements and no significant changes to the ITAAC program itself were noted by the staff.
 - Section 14.3.2, "Structural and Systems Engineering"
 - Section 14.3.4, "Reactor Systems"
 - Section 14.3.5, "Instrument and Controls Systems"
 - Section 14.3.6, "Electrical Systems"
 - Section 14.3.8, "Radiation Protection"
 - Section 14.3.10, "Emergency Planning"
 - Section 14.3.13, "External Flooding Protection"
- The staff concluded that the SDAA ITAAC submittal for these Sections as revised conforms to the NUREG-0800 Standard Review Plan for Initial Test Programs and ITAAC.

NuScale SDAA FSAR Ch. 14.3 ITAAC Review

Significant Changes from DCA to SDAA

SER Section 14.3.3 Piping Systems and Components ITAAC

- A comprehensive review of the SDAA proposed Piping Systems and Components ITAAC was performed and compared to the corresponding DCA Piping Systems and Components ITAAC.
 - Reviewers found that design changes between the DCA and the SDAA were appropriately captured in the applicant's proposed ITAAC, such as the addition of the ECCS supplemental boron dissolvers and CNV lower mixing tubes.
- The staff concluded that the SDAA proposed Piping Systems and Components ITAAC as revised meets the regulatory requirements for ITAAC, as described in the SER.

NuScale SDAA FSAR Ch. 14.3 ITAAC Review

Significant Changes from DCA to SDAA SER Section 14.3.7 Plant Systems ITAAC

- A comprehensive review of the Plant Systems ITAAC requirements were performed.
- In comparing the SDAA ITAAC with those proposed in the DCA the staff found changes/modifications were made to the ITAAC for the systems used to perform fuel handling and for systems used to conduct heavy load movements.
 - The ITAAC for the Fuel Handling equipment added ASME NUM 1 to the ITAAC acceptance criteria
 - The ITAAC for the Overhead heavy load handling system added ASME NUM-1 to the acceptance criteria for a TYPE 1A crane
- The staff finds that the SDAA Plant Systems ITAAC submittal, as revised, to be necessary and sufficient to provide reasonable assurance that the facility built has been constructed and will be operated in conformity with the license, the provisions of the Atomic Energy Act as amended, and the Commission's rules and regulations.

NuScale SDAA FSAR Ch. 14.3 ITAAC Review

Significant Changes from DCA to SDAA

SER Section 14.3.9 Human Factors Engineering ITAAC

- A comprehensive review of the HFE ITAAC requirements was performed
- Some Human Factors Engineering activities for the NuScale SDAA are still ongoing
 - For the DCA, the staff reviewed results from the applicant's Integrated Systems Validation (ISV) activities before finalizing their SER
 - For the SDAA, ISV results were not available for the staff during their safety review
 - The SDAA includes an ITAAC for completion of an ISV test in accordance with the human factors verification and validation implementation plan
- The staff concluded that the SDAA HFE ITAAC submittal as revised conforms with the NUREG-0800 Standard Review Plan for HFE

NuScale SDAA FSAR Ch. 14.3 ITAAC Review

Significant Changes from DCA to SDA

SER Section 14.3.11 Containment Systems ITAAC

- The staff reviewed the containment systems ITAAC requirements.
- Significant changes resulted from staff concerns raised during the review of Ch 6:
 - Section 6.2.1.1, NuScale proposed a one-time ITAAC for the first module built to verify the as-built CNV free volume bounds the minimum value used in the containment design-basis analyses.
 - Section 6.2.5, NuScale is proposing three ITAAC In response to staff RAIs for the passive autocatalytic recombiner (PAR):
 - An inspection to confirm the PAR is installed in accordance with the associated installation specification
 - A report to confirm the PAR has sufficient capacity for required oxygen recombination to maintain the CNV atmosphere inert during DBEs
 - Environmental qualification of PAR
- The staff finds that the SDAA Containment Systems ITAAC submittal as revised conforms with the NUREG-0800 Standard Review Plan for Initial Test Programs.

NuScale SDAA FSAR Chapter 14 Review

Conclusion

- While there are some differences between the DCA and SDAA, the staff found that the applicant provided sufficient information to support the staff's safety findings.
- The staff found that all applicable regulatory requirements were adequately addressed for the design.
- COL items are provided for programs and site-specific aspects, similar to the DC application.

Meeting title**Open Session NuScale Subcommittee Meeting on Staff's Evaluation of Chapters 3, 8 and 14****Participants**

Michael Snodderly	ACRS (DFO)
Thomas Dashiell	
Sandra Walker	
Omer Erbay	NuScale
Tammy Skov	
Larry Burkhart	
Allegra Chilstrom	Court Reporter
Dennis Bley	
Eric Lantz	NuScale
Charlie Brown	
Vesna B Dimitrijevic	
Chris Nighbert	NuScale
Stephen Schultz	
Augi Cardillo	NuScale
Bradley Drake	NuScale
Joe Remic	NuScale
Emily Larsen	NuScale
Meghan McCloskey	NuScale
Kevin Fischer	NuScale
Rob Morrow	NuScale
Wendy Reid	NuScale
Aaron Pierce	
David Benson	NuScale
Vicki Bier	
Hank Pratte	
Addison Hall	
Edward Stutzcage	NRC
Erwin Laureano	NuScale
Stacy Joseph	
Jeff Ehlers	NuScale
Matthew Martineau	NuScale
Renee Martin	
Derek Widmayer	
Dan Lassiter	NuScale
Michael Valleau	NuScale
Thomas Griffith	NuScale
Jim Osborn	NuScale
Robert Martin	
Paul Guinn	NuScale
Rim Nayal	NuScale
Kenneth Armstrong	
Ron Ballinger	
Carlen Donahue	NuScale
Charley Peabody	

Isaac Wang	
Gordon Curran	NRC
Jon Bristol	NuScale
Justin Mechling	
Mary H Miller	
Matt Kulp	NuScale
Ricky Vivanco	NRC
Andrew Prinaris	
Tania Martinez Navedo	NRC
Dave Yeager	
Matthew Mitchell	
Kevin Spencer	NuScale
Maurin Scheetz	
Myron Hecht	
Gregory Halnon	
Marie Pohida	
Shao Lai	
Fanta Sacko	
Joseph Colaccino	
David Nold	NRC
Harry Wagage	NRC
David Drucker	NRC
River Rohrman	
Chelsea Lockwood	NuScale
Joseph Ashcraft	
Caty Nolan	
Doug B	NuScale
Stacy Prasad	
Mahmoud Jardaneh	NRC
Angelo Stubbs	NRC
Jim Schneider	NuScale
Eric Benner	NRC
Rob Atienza	
Alysia Bone	
Boyce Travis	
Steven Pope	
Antonio Barrett	NRC
John Wise	
Prosanta Chowdhury	NRC
Jaison Monachan	
Rob Krsek	
Mary Frances Woods	
Tim Polich	
Hannah Rooks	NuScale
Augi Cardillo	NuScale
Gary Becker	NuScale
Christina Antonescu	
Jessie Quichocho	
Matt Sunseri	

Ryan Nolan	
Sam Gellen	
Jeff Rohrman	
Nancy Rohrman	
Danielle Rohrman	
Nicholas Hansing	NRC
Jorge A Clinton Rivera	NRC
Sheila Ray	NRC
Ata Istar	NRC
Kris Cummings	NuScale
Tyler Beck	NuScale
David Rickenbach	NuScale
Peter Shaw	NuScale
Stewart Bailey	NRC
Gene Eckholt	NuScale
Andrea Mota	NuScale
Daniel Diefendorf	NuScale
Getachew Tesfaye	NRC
John Honcharik	NRC
Chakrapani Basavaraju	NRC
Thomas Scarbrough	NRC
Liliana Ramadan	NRC
Dinesh Taneja	NRC
Frederick O'Brien	NRC
Ken Mott	NRC
Raul Hernandez	NRC
John Tsao	NRC
Yuken Wong	NRC
Alissa Neuhausen	NRC
Stephanie Roche Rivera	NRC
George Wang	NRC
Kamal Manoly	NRC
Cory Parker	NRC
Elisa Fairbanks	NuScale
John Budzynski	NRC
Alex Collier	NRC