

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Fuels, Materials, and Structure Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, December 17, 2024

Work Order No.: NRC-0148

Pages 1-300

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

REGULATORY RULEMAKING, POLICIES AND PRACTICES

SUBCOMMITTEE

+ + + + +

TUESDAY

DECEMBER 17, 2024

+ + + + +

The Subcommittee met via Videoconference,
at 8:30 a.m. EST, Ronald G. Ballinger, Chairman,
presiding.

SUBCOMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman

VICKI M. BIER, Member

VESNA B. DIMITRIJEVIC, Member

GREGORY H. HALNON, Member

CRAIG D. HARRINGTON, Member

WALTER L. KIRCHNER, Member

ROBERT P. MARTIN, Member

SCOTT P. PALMTAG, Member

DAVID A. PETTI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 THOMAS E. ROBERTS, Member
2 MATTHEW W. SUNSERI, Member

3
4 ACRS CONSULTANT:

5 DENNIS BLEY

6
7 DESIGNATED FEDERAL OFFICIAL:

8 ZENA ABDULLAHI

9 WEIDONG WANG

10
11 ALSO PRESENT:

12 PHILIP BENAVIDES, NMSS/REFS/RRPB

13 KRISTY BUCHOLTZ, NRR/DRA/APOB

14 LARRY BURKHART, ACRS/TSB

15 THERESA CLARK, NRR/DSS

16 JAMES CORSON, RES/DSA/FSCB

17 SE-KWON JUNG, NRR/DEX

18 JOHN LEHNING, NRR/DSS

19 JOSEPH MESSINA, NRR/DSS/SFNB

20 CHARLEY PEABODY, NRR/DSS/SNSB

21 JASON PIOTTER, NMSS/DFM/NF

22 DAVE RUDLAND, NRR/DNRL

23 ROBERT TREGONING, RES/DE

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CONTENTS

ACRS Chairman Introductory Remarks 4

NRR Staff Leadership Introductory Remarks 8

IE Overview, Status of Rulemaking

 Activities 12

Criticality Accident Requirements 17

Fissile Packaging Requirements 22

Fuel Fragmentation, Relocation, and

Dispersal (FFRD) 43

FFRD Work done as a part of IE Rulemaking

to confirm transition break size

technical basis 139

FFRD Draft proposed 10 CFR 50.46a rule

language and DG-1426 (RG 1.225) 259

Adjourn

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR BALLINGER: The meeting will now come to order. This is a meeting of the Fuels, Materials, and Structure Subcommittee of the Advisory Committee on Reactor Safeguards. I'm Ron Ballinger, chair of today's subcommittee meeting.

ACR members in attendance in person are myself, Craig Harrington, Tom Roberts, Dave Petti, Bob Martin, and Scott Palmtag. Members that are in attendance virtually or may be or should be virtually by Teams are Walt Kirchner, Greg Halnon, Matt Sunseri, Vicki Bier, and Vesna Dimitrijevic. We have one consulting participant virtually, and I believe that's Dennis Bley, but I can't see. He's there. So I probably missed somebody.

Zena Abdullahi and Weidong Wang of ACRS staff are the Designated Federal Officers for this meeting. No member conflicts of interest were identified for today's meeting. We have a quorum.

During today's meeting, the subcommittee will receive a presentation on technical topics regarding increased enrichment of conventional and accident tolerant fuel designs for light-water reactor rulemaking. The U.S. Nuclear Regulatory Commission is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 proposing to amend its regulation related to the use
2 of conventional and accident tolerant light-water
3 reactor fuel designs. The NRC's goal is to establish
4 effective and efficient licensing of the use of fuels
5 enriched to greater than 5 weight percent uranium-235
6 while continuing to provide reasonable assurance of
7 adequate protection of public health and safety. The
8 new requirements also would address fuel
9 fragmentation, relocation, and dispersal, FFRD, in
10 relation to the key accident tolerant fuel components
11 of increased enrichment and burnup limits.

12 The ACRS was established by statute and is
13 governed by the Federal Advisory Committee Act, or
14 FACA. The NRC implements FACA in accordance with our
15 regulations. Per these regulations and the
16 committee's bylaws, the ACRS speaks only through its
17 published letter reports. All member comments should
18 be regarded as only the individual opinion of that
19 member, not a committee position.

20 All relevant information related to ACRS
21 activities, such as letters, rules for meeting
22 participation, and transcripts are located on the NRC
23 public website and can be easily found by typing about
24 us ACRS in the search field on the NRC home page. The
25 ACRS, consistent with the agency's value of public

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 transparency in regulation of nuclear facilities
2 provides opportunity for public input and comment
3 during our proceedings. We have received no written
4 statements or requests to make an oral statement from
5 the public. We also set aside time at the end of this
6 meeting for public comments.

7 The ACRS will gather information, analyze
8 relevant issues and facts, and formulate proposed
9 conclusions and recommendations, as appropriate, for
10 deliberation by the full committee. A transcript of
11 the meeting is being kept and will be posted on our
12 website.

13 When addressing the subcommittee, the
14 participants should first identify themselves and
15 speak with sufficient clarity and volume so that they
16 may be readily heard. You also make the stenographer
17 if you do that. If you are not speaking, please mute
18 your computer on Teams or by pressing star six if
19 you're on a phone. Please do not use the Teams chat
20 feature to conduct sidebar discussions related to the
21 presentations. Rather, limit use of the meeting chat
22 function to report IT problems. For anyone in the
23 room, please put all your electronic devices in silent
24 mode. Hopefully, I did that. Yes. And mute your
25 laptop microphone and speakers. In addition, please

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 keep sidebar discussions in the room to a minimum
2 since the ceiling microphones are live and they're
3 pretty sensitive.

4 For presenters, your table microphones are
5 unidirectional. I think most of you know that. You
6 have to really get close to them. Finally, if you
7 have any feedback for the ACRS about today's meeting,
8 we encourage you to fill out the public meeting
9 feedback form on the NRC's website.

10 We'll now proceed with the meeting, and,
11 Philip, are you going to give some opening remarks?

12 MR. BENAVIDES: Thank you. I'm Phil
13 Beneavides, project manager in Office of Nuclear
14 Material Safety and Safeguards, and I'm the rulemaking
15 project manager in charge of the rulemaking on
16 increased enrichment in conventional and accident
17 tolerant fuel designs for light-water reactors.
18 Today, we're going to present the draft proposed rule
19 for the increased enrichment rule, proposed rule. We
20 will begin with opening remarks from Theresa Clark,
21 the director of the Division of Safety Systems,
22 followed by a brief overview and status of the
23 increased enrichment rulemaking which will lead into
24 presentations from subject matter experts for each
25 technical topic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Next slide. Theresa.

2 MS. CLARK: Thanks, Phil. And good
3 morning to all the members. I'm really pleased to see
4 all of you, as well as the significant audience here,
5 so this is obviously a topic of high interest. It's
6 of strong interest to us, as well. I'm Theresa Clark
7 again. I'm the director of the Division of Safety
8 Systems here in the Office of Nuclear Reactor
9 Regulation at the NRC. I'm also the chair of the
10 Management Steering Committee for this rulemaking, so
11 very heavily invested in this rule. And I just want
12 to say I really appreciate the committee devoting so
13 much of its time to this rulemaking, as well as to the
14 related discussions on Reg Guide 1.183. I know it's
15 a lot of work. It's been a lot of work for our
16 collective team, and I want to appreciate their
17 efforts, as well. And special shoutouts to Phil here,
18 as well as to Joseph Messina, who is the lead in my
19 division, and you'll be hearing a lot from him. He's
20 been coordinating with the rest of the team to keep
21 this rule moving.

22 One of the reasons I'm especially proud of
23 this rulemaking is because it's collaborative,
24 creative, and groundbreaking. We figured out new ways
25 to integrate feedback on the rule while still keeping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to our schedule, and the result is expected to be a
2 big enabler to advancements in both safety and
3 economics across the industry.

4 Over the next couple of days, you'll hear
5 a lot of about FFRD, which was already defined: fuel
6 fragmentation, relocation, and dispersal. We'll hear
7 even more about what that actually is. And we began
8 this rulemaking in 2022 with Commission direction to
9 address that phenomenon within the rule, and the
10 committee has been very interested, obviously, in our
11 approach. It adds technical complexity to the rule
12 for sure, but it's also an opportunity for us to unify
13 several previously worked on 5046 rulemakings in a
14 holistic and risk-informed way.

15 So by selecting, as you'll hear, FFRD
16 Alternative 2 from the regulatory basis, we could
17 leverage the extensive work that was done several
18 years ago on the 5046(a) rulemaking. That helped us
19 stay on schedule while repeating the benefits that
20 licensees may be able to see of risk-informing the
21 large-break LOCA analytical approach. Further, by
22 integrating performance-based requirements into the
23 rule, as you'll hear a lot about later, we could
24 preserve flexibility for other ways that industry may
25 want to address FFRD while resolving the safety issues

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 with hydrogen embrittlement that were worked on
2 previously in the 5046(c) rulemaking, and that was
3 worked on by the staff and reviewed by the committee
4 like 5046(a) was. So integrating these two efforts
5 helped us stay on schedule and it will likely help
6 your review, as well. At the same time, we were
7 mindful of previously proposed requirements that may
8 be overcome by events or more prescriptive than we
9 need today, and so we thought hard about what's truly
10 necessary as we shape this rule.

11 And you'll hear about lots of topics,
12 other than FFRD, that I won't get into because Phil
13 will do that overview, but I really just want to thank
14 the committee for their effort in reviewing the
15 documents and your flexibility in giving us multiple
16 presentation time slots. That helps us a lot because
17 the documents are still in their final review and
18 concurrence stage. Phasing this and letting us
19 present in January lets us make even more progress
20 that way. So, for example, you'll see in some of the
21 slides that some of the provisions have even been
22 changed or deleted since we first sent you the
23 package. That's a natural evolution of that
24 concurrence process. And between this meeting and the
25 January meeting, we'll be poised to give you the full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 picture of the rule.

2 CHAIR BALLINGER: So that means I have a
3 question. The documents that we now have, at what
4 point will we get the final documents?

5 MS. CLARK: Phil might answer that
6 question even better than I would, but before the
7 January meeting I think.

8 MR. BENAVIDES: Yes, it would have to be
9 before the January meeting. I know, typically, you
10 want 30 days before. We're still going through
11 concurrence, and, yes, we will provide anything that's
12 significant changes before the --

13 CHAIR BALLINGER: Any letter that we would
14 write or will write would have to be based on --

15 MR. BENAVIDES: We want to have the letter
16 reflect what's actually going up to the Commission.
17 Correct.

18 MS. CLARK: And just so that I don't scare
19 you too much, the sorts of things that you'll see are
20 so far relatively minor changes related to reporting
21 requirements or updates frequencies, those sorts of
22 things where we've been re-weighing the burden, so not
23 a major technical change so far, nor do I expect one.

24 CHAIR BALLINGER: Also, one last thing for
25 the record. I'm told by certain moles within your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 organization that this whole process took a year,
2 which is remarkable and, to my mind, sets a precedent
3 for something that's as complex as this in the future.
4 Thank you.

5 MS. CLARK: Thanks for that recognition.
6 Couldn't have done it without a great team and without
7 those prior efforts on our prior goals. So take it
8 away, Phil. Thanks.

9 CHAIR BALLINGER: Okay. We now have a
10 binary distribution here. I could understand her
11 very, very well, but you're -- can you get a little
12 closer to the --

13 MR. BENAVIDES: Oh, sure. Is that better?

14 CHAIR BALLINGER: Yes.

15 MR. BENAVIDES: All right. Thank you,
16 Ron. With that, I'm going to provide an overview of
17 the increased enrichment rulemaking. Next slide.

18 As a way to provide background on how we
19 got to this point, I'd like to go back to the
20 beginning when the issue was identified. Throughout
21 the last few years, staff has seen increased
22 enrichment interest from the industry for the use of
23 fuel enriched above 5 weight percent uranium-235 or U-
24 235. The NRC noted that although the current
25 regulatory framework allows a licensee fuels above 5

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 weight percent U-235, this use of this fuel may result
2 in new redemption requests for licensees. So as a
3 proposed solution, NRC staff began pursuing rulemaking
4 rather than licensing individual exemptions.

5 In December 2021, the staff provided the
6 Commission with SECY-21-0109 requesting approval to
7 begin the rulemaking process, which was approved, you
8 know, in March of 2022.

9 Next slide. And when the Commission
10 approval was granted in SRM SECY-21-0109 in March of
11 2022, the Commission specified several considerations
12 to evaluate in addition to what was specified in the
13 rulemaking plan. One was that the rule should only
14 apply to high-assay low-enriched uranium levels. This
15 was done for both nonproliferation and safeguards
16 reasons and for the staff to focus on the range of
17 enrichment most likely to be contemplated in future
18 applications. In addition, staff was directed to
19 address fuel fragmentation, relocation, and dispersal,
20 and to take risk-informed approaches.

21 Next slide, please. The NRC issued the
22 regulatory basis on September 8th, 2023. Stakeholder
23 involvement throughout the process included public
24 meetings which were held before the regulatory basis
25 was issued on June 22nd of 2022 and after the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 regulatory basis was issued October 25th of 2023. The
2 regulatory basis comment period was open from
3 September 8th, 2023 through January 22nd, 2024.

4 In addition to the typical rulemaking
5 engagement, staff shared fuel dispersal insights at
6 the NRC's annual higher burnup workshop on September
7 3rd, 2024. The proposed rule is currently due to the
8 Commission in March of 2025.

9 Next slide. This slide shows an overview
10 of the rulemaking activity. We're still in the
11 proposed rule package development stage, and we're
12 currently working out way towards submission to the
13 Commission in March of 2025. After the Commission
14 reviews and approves the proposed rule package, the
15 staff will finalize the proposed rule based on
16 Commission direction. A Federal Registry notice will
17 then be issued opening up the proposed rule for public
18 comment in the purple box which is estimated to begin
19 in July of next year, 2025.

20 After the public comment period closes,
21 the staff will develop the draft final rule package
22 which is expected to be sent to the Commission in
23 September of 2026. Note that the dates listed are
24 estimates and subject to change.

25 I do want to point out, in addition to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 these ACRS engagements between now and February 2025
2 that we have plans. The staff plans to present these
3 to ACRS towards the end of the final rule development,
4 as well, prior to the draft final rule being sent to
5 the Commission for consideration.

6 Next slide. The increased enrichment
7 rulemaking addresses the following topics. Note that
8 the topics highlighted in red will be presented over
9 the next two days. These include criticality accident
10 requirements and 10 CFR 50.68, packaging requirements
11 for fissile material transportation in 10 CFR 71.55,
12 control room design requirements in 10 CFR 50.67 and
13 GDC-19, and also fuel fragmentation, relocation, and
14 dispersal.

15 Next slide. This slides shows the
16 associated guidance developed for the increased
17 enrichment rulemaking with one draft guide associated
18 with control and design requirements and six draft
19 guides associated with fuel fragmentation, relocation,
20 and dispersal. Please note that DG-1428 titled Plant-
21 Specific Applicability of Transition Break Size will
22 be presented during the January 2025 ACRS subcommittee
23 meeting. The other draft guides will be discussed
24 over the next few days.

25 Next slide. This slide shows the order of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 presenters for today. After this presentation, we'll
2 transition to presentations on critical accident
3 requirements and fissile packaging requirements. And
4 then, after a short break, we'll transition to the
5 fuel fragmentation, relocation, and dispersal
6 presentations.

7 Next slide. And day two will include a
8 continuation of the fuel fragmentation, relocation,
9 and dispersal topic presentations in the morning, and
10 then we'll transition to control room design criteria
11 presentations in the afternoon.

12 Next slide. With that, any questions?

13 MEMBER PETTI: I just had a process
14 curiosity question. Why is NMSS the lead? I mean, I
15 understand enrichment, but if you look at all the
16 people, just looking at the list, you think NRR should
17 have something to do with it.

18 MR. BENAVIDES: Yes. Historically,
19 rulemaking used to be -- I was in different offices
20 when they created the Center of Expertise for
21 rulemaking. It happened to be housed under the office
22 of NMSS, you know. So if you look at our office,
23 there's a materials rulemaking branch and a reactor
24 rulemaking branch.

25 MEMBER PETTI: Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BENAVIDES: You're welcome. Okay.
2 Well, hearing no other questions, we can move on to
3 the technical topic presentations. Thank you for your
4 time. We're going to start with Charlie Peabody.

5 MR. PEABODY: Sorry. I'm attending
6 remotely today, but I do appreciate the time to
7 present to the committee on this topic. Aaron, can
8 you advance to the next slide?

9 All right. So 50.68 was implemented in
10 1998, and that was basically to codify past exemptions
11 to 70.24, which the issue with that was that active
12 criticality monitoring and emergency preparedness
13 requirements were required to ensure that you could
14 respond to a criticality event in a spent fuel pool at
15 a light-water reactor. So provide alternative
16 compliance to this, we implemented k-effective safety
17 limits in Parts (b)(2), (3), and (4) of this rule to
18 remove the active criticality monitoring and emergency
19 drill requirements if you could demonstrate that the
20 k-effective in the pool would not exceed 0.95 at 95-
21 percent probability and 95-percent confidence.

22 There is another provision in the rule,
23 Paragraph (b)(7), which limited application to
24 enrichments of less than or equal to 5 percent by
25 weight U-235. Recently, we were approached by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 industry with a desire to increase enrichments beyond
2 5 percent specifically for PWRs who wanted to have a
3 24-month cycle.

4 Next slide, please. So we've actually
5 kind of started this a little bit. There was a
6 license amendment from Vogtle to utilize lead test
7 assemblies above 5 percent enrichment that we've
8 approved that included an exemption to 50.68 Paragraph
9 (b)(7), and we're forecasting that batch cycles would
10 be implemented for that potentially as early as the
11 end of the 2020 decade.

12 We also, over the past year, we completed
13 a research study that we contracted through Oakridge
14 National Labs. I have the number of the study, as
15 well as the accession number. It is publicly
16 available if anybody wants to review it. Basically,
17 what the study showed is that it actually exceeded our
18 expectations in terms of utilizing existing integrated
19 fuel burner absorber and gadolinium absorber
20 technologies to, you know -- we think that if we can
21 use them that we can possibly get criticality down.
22 Even in some hypothetical cases where we went closer
23 to 15 or 20 percent, we were still able to get the
24 overall k-effective down. So we're actually less
25 apprehensive than we were a year ago at least about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the fuel storage portion of this.

2 Another thing I want to talk about is
3 you're going to hear about a lot of reg guides in the
4 next couple of days and probably over the next month
5 or so. We did get a lot of public feedback on Reg
6 Guide 1.240, which is fresh and spent fuel pool
7 criticality analysis. There were a lot of commenters
8 that felt that we should actually, you know, make a
9 revision to this reg guide under the rulemaking. We
10 would like to point that, if you look at that reg
11 guide, as well as any NEI 12-16, which is the document
12 that the reg guide endorses, there's really no
13 specific ties to enrichment levels. There is Section
14 C.1.0, which specifies that the document's
15 recommendations are based on existing fuel
16 applications that are in widespread use and that new
17 and novel configurations and concepts implemented in
18 the future might require additional justification for
19 continued use of the assumptions and recommendations
20 of the reg guide.

21 Despite the feedback that we got that we
22 should consider updating the reg guide, we did not get
23 any new or novel approaches to review. So we're still
24 going to plan on next updating that reg guide as part
25 of the normal reg guide update process sometime in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 future when we receive new and novel approaches from
2 the industry.

3 Next slide, Aaron. So what the changes to
4 50.68 are going to look at, there's really only one.
5 We're changing that paragraph (b)(7) and we're
6 changing it from just, you know, 5 percent by weight
7 to an option of either 5 percent by weight or to the
8 value specified in the operating license. We're not
9 making any changes to any other paragraphs, and the
10 reason, I think if you all would recall, last year, we
11 were just opting towards changing it to the value
12 specified in the operating license. We decided not to
13 do that because we determined that there are some BWRs
14 that use an alternative k-infinity criteria for
15 ensuring subcriticality in the spent fuel pool.
16 That's essentially like an alternative to the k-
17 effective and enrichment limit that most other
18 licensees use. So we didn't want to get into a
19 situation where we would, you know, basically take
20 someone out of compliance if they didn't have a value
21 specified, an enrichment value specified in their
22 operating license, which is really the tech spec
23 design features.

24 Next slide, Aaron. So the overall
25 benefits of this, we think, are that, you know, the k-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 effective safety limit specified in paragraphs (b)(2),
2 (b)(3), and (b)(4) are maintained at their current
3 levels of 0.95 at 95-percent confidence and
4 probability. Of course, there is the 0.98 for the
5 optimal moderation. But, like, basically, they're
6 kept at the level that they're currently at.

7 We're going to use the fuel transition LAR
8 process to review any increased enrichments safety
9 impacts that we see coming forward. So, you know, as
10 part of the reviews that we're already performing for
11 fuel transitions, we're going to be, you know,
12 basically making sure that they're adhering to this
13 process, that they have the appropriate limits in
14 their tech spec.

15 Another advantage of this is that it will
16 allow for any licensee or applicant to utilize
17 whatever enrichments in the HALEU range that they want
18 to utilize. They won't necessarily have to go to a
19 higher value beyond what they would like to analyze,
20 and they basically get what's easiest for them, which
21 is very amenable to the fuel transition LAR process as
22 it reviews new and spent fuel criticality effects.

23 As I kind of alluded to in the last slide,
24 this alternative, we think, is also very good because
25 it preserves existing 50.68 (b) compliance for all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 light-water reactors currently operating in the United
2 States. And any increase enrichments LARs would be
3 considered to a voluntary regulatory initiative and,
4 therefore, backfit and forward fit considerations
5 would not apply.

6 Next slide. Are there any questions or
7 comments for criticality safety? All right. Well,
8 I'm hearing none; so, if that's the case, then I'll
9 hand it off to Jason Piotter so we can keep moving
10 things along. Thank you for your time.

11 MR. PIOTTER: Thank you, Charlie. Good
12 morning, members, colleagues, and guests. My name is
13 Jason Piotter, and I am the team leader for the new
14 fuels team in the Division of Fuel Management in the
15 Office of Nuclear Material Safety and Safeguards.
16 Prior to that role, I had been a senior technical
17 reviewer in the division for approximately 21 years in
18 structural, thermal, and containment areas. Today,
19 I'd like to briefly discuss our consideration of
20 fissile material package requirements contained in 10
21 CFR 71.55.

22 Slide 2, please. So the bottom line up-
23 front is what I'm going to start with today.
24 Transportation packages for UF₆, have a certification
25 pathway for enrichments up to 20 weight percent U-235.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 While our current regulations, as written, are
2 sufficient to transport higher-enriched UF6, we are
3 proposing a non-mandatory modification of the current
4 enrichment limit that allows for more regulatory
5 certainty while maintaining safety.

6 If you'll note in this slide, the current
7 regulations reference 71.55(b) and 71.55(g), noting
8 here that the regulation of interest is actually
9 71.55(b) in the sense that it is the starting point
10 for evaluation of these fissile material packages.
11 And it basically is saying that, when these fissile
12 material packages are evaluated, they need to be
13 evaluated with moderator present. For UF6 packages in
14 particular, an exception was introduced in 2004 that
15 provided a pathway for certification of those packages
16 provided that the enrichment limit of the UF6 is below
17 5 weight percent or below.

18 Now, the rest of the regulation for 10 CFR
19 Part 71, in general, do not have an enrichment level
20 limitation for the fissile material. But, again, in
21 this instance, 71.55(g) does have a specification and
22 an exception for UF6 packages. I will note, and I'll
23 get to this a little bit later in the presentation,
24 there is another regulation in 71.55 that does not
25 have an enrichment limit associated with it that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 allows for not considering moderator inclusion into
2 the package. But, again, we'll get to that in the
3 future slides.

4 Next slide, please. So absent utilizing
5 the provisions in 71.55(g), applicants for a
6 certificate of compliance have the option of
7 evaluating fissile material transportation packages in
8 a variety of ways. I've already mentioned 71.55(b).
9 They could seek an exemption to 71.55(b) as part of
10 their licensing options, or they could seek an
11 exception, again, to the water and leakage
12 requirements of 71.55(b) using the provisions in
13 71.55(c). The difference there is that there has to
14 be a special design feature present such that no
15 single failure of packaging would result in an
16 inadvertent criticality in the package.

17 Next slide, please. So recall from last
18 year for the reg basis we identified three alternative
19 actions that the NRC could take: no rulemaking
20 utilizing the existing certificate of compliance
21 options that could be chosen by industry, rulemaking
22 to increase the enrichment limit to less than 20
23 weight percent U-235, or rulemaking to remove the
24 enrichment limit in its entirety. The staff initially
25 recommended Alternative 1 simply because the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 regulations, as written, were then and are still
2 sufficient to certify UF6 packages up to 20 weight
3 percent and the financial analysis itself demonstrated
4 that the options were cost-neutral at the time. In
5 addition, there was not an evident demand signal from
6 industry that there would be a significant number of
7 additional certificates of compliance required, and
8 the NRC had also just recently licensed the DN30-X
9 package which allows for transport of UF6 enriched up
10 to 20 weight percent.

11 While the staff specifically requested
12 additional information on the need for new COCs for
13 existing packages for new designs, comments from the
14 public did not answer that question directly. The
15 public comments did, however, specifically indicate
16 regulatory certainty as a factor that was important
17 for consideration. Public comments also specifically
18 indicated that an exception for UF6 transport for the
19 enrichment levels in the 5 to 10 weight percent range
20 would also benefit industry. Finally, the public
21 comments indicated the NRC neglected to consider
22 downstream non-rulemaking costs due to the increased
23 number of shipments that would be needed if moderator
24 must be considered as part of certification. The
25 staff looked at these comments and took them into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 account when evaluating whether or not to update the
2 rulemaking alternatives.

3 Next slide, please. As a result of
4 additional staff discussion, as well as the public
5 comment, the staff determined that updating rulemaking
6 alternatives was warranted. The updated alternatives
7 include no action; increase the enrichment limit in
8 71.55(g) to include enrichments up to 10 weight
9 percent; and, three, increase the enrichment limit in
10 71.55 to include enrichments up to 20 weight percent
11 U-235.

12 Next slide, please. The staff is now
13 recommending Alternative 2, increase the enrichment
14 limitation for the exception in 71.55(g) for the
15 following reasons: It allows for a modest reduction
16 in regulatory flexibility found in the current
17 regulations in exchange for a modest prescriptive
18 approach for an expanded, yet limited, range of
19 enrichments to maintain safety. A regulatory path
20 still exists for a moderator-inclusion exception for
21 enrichment ranges from 10 to 20 weight percent in the
22 current regulations.

23 This option balances operational needs of
24 industry, including regulatory certainty, with the
25 increasing safety consequences of an inadvertent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 criticality due to the presence of moderator. The
2 range of enrichment levels for LWR fuels is not
3 expected to exceed 10 weight percent, and the NRC
4 could not conclude that sufficient justification
5 exists for allowing an exception for UF6 enriched from
6 10 to 20 weight percent that balances both safety and
7 regulatory certainty.

8 Next slide, please. This slide
9 illustrates the updated or the proposed updated text
10 that will be added to 71.55(g). Note that, in part
11 four of 71.55(g), it would add the 10 weight percent
12 indicator that we would be going up to that enrichment
13 level. And then in five, which would be a new sub-
14 bullet, a design feature that would need to be
15 incorporated to protect the valve or other fill device
16 for impact for contents with uranium-enriched above 5
17 weight percent and up to 10 weight percent. And this
18 is consistent with what we've done previously for a
19 separate package that was certified under 71.55(c).

20 CHAIR BALLINGER: So this is Ron
21 Ballinger. To be clear, this does not require a
22 change in the design of the container itself.

23 MR. PIOTTER: Correct.

24 CHAIR BALLINGER: Just the valving and
25 stuff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. PIOTTER: Yes. You could consider it
2 as similar to an impact limiter, I suppose, depending
3 upon what the designs look like. That's correct. And
4 what it would allow for is it would allow for
5 continued use of existing cylinders.

6 CHAIR BALLINGER: Thank you.

7 MR. PIOTTER: Yes, sir. And next slide.
8 And, again --

9 MEMBER ROBERTS: Quick question. This is
10 Tom Roberts. The text of this rule implies that
11 impact is the only failure that could cause
12 inadvertent fill; is that right?

13 MR. PIOTTER: Yes. If you look at the
14 rest of the regulation, it actually looks at the
15 performance requirements under 71.73, which is the
16 hypothetical accident conditions. So provided that
17 the package and the packaging survive the hypothetical
18 accident conditions, which is really a structural and
19 containment question, then that's, in essence, the
20 issue with excluding moderator. So that's really the
21 focus here is making sure that no moderator gets
22 inside the packaging.

23 MEMBER ROBERTS: Okay. Thanks. So impact
24 is shorthand for hypothetical accident conditions?

25 MR. PIOTTER: Correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: Okay. Thanks.

2 MR. PIOTTER: Yes. And just to clarify,
3 it's one element of the hypothetical accident
4 conditions that starts the sequence.

5 MEMBER ROBERTS: It just seems like that's
6 very specific in terms of not really covering
7 performance requirement, which is to have defense-in-
8 depth for the hypothetical accident conditions. So
9 it's okay in terms of writing the rule, but I don't
10 understand what you mean by the shorthand accident
11 conditions so, as long as it's clear, you know --

12 MR. PIOTTER: I think, within the context
13 of the entire 71.55(g) as written, it's evident with
14 the entirety of what's in the rule currently. But
15 thank you.

16 MEMBER KIRCHNER: Ron, this is Walt
17 Kirchner. May I ask a question?

18 CHAIR BALLINGER: Oh, sure. Sorry about
19 not keeping track of who's got their hand raised.

20 MEMBER KIRCHNER: Well, again, 71.55 is
21 general requirements for fissile material packages.
22 It's not LWR-specific, although I guess most of the
23 activity does support the LWR fleet. We have multiple
24 applications looking at using up to 20 percent
25 enrichment in the case of advanced of reactors, so why

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 wouldn't you just go ahead and provide that certainty
2 up to 20 percent industry-wide? I know this is an LWR
3 rulemaking package, but this specific proposal is
4 rather generic and, as Tom was also indicating, I
5 mean, should be looked at in a performance-based
6 manner.

7 MR. PIOTTER: Yes. Thank you for your
8 question. It's a multitude of factors. I think, one,
9 in terms of the staff considering whether to make this
10 change in an incremental fashion versus considering
11 this thing all at once, we do have the existing
12 regulation 71.55(c) that would cover packages that are
13 enriched 10 weight percent up to 20 weight percent.
14 I think that was sort of the starting point from staff
15 in the decision-making.

16 I think the second part of the decision-
17 making is that if you look at the increase in
18 consequences as enrichment increases for the packages,
19 the staff did not feel like there was adequate
20 technical basis for inclusion of that enrichment level
21 from 10 to 20 weight percent for these particular
22 packages. And, again, this is an exception. It's an
23 exception to an existing rule, and it's specific to
24 UF6 packages. So the question is is it in the
25 interest of moving forward without that additional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 technical basis for 10 to 20 weight percent. Is an
2 incremental approach best, and that was the staff
3 determination was that we could make some incremental
4 progress on providing regulatory certainty within the
5 71.55(g) framework for UF6 packages, but, yet, unless
6 and until we have that additional certainty with
7 respect to 10 or 20 weight percent, from a technical
8 basis perspective, staff was not comfortable moving to
9 that level.

10 And, again, if we didn't have 71.55(c) in
11 place, I think there would be a stronger consideration
12 for making the exception in 71.55 (g). But because
13 there are multiple pathways and 71.55(c) also is not
14 a prescriptive requirement, it's technology-neutral,
15 if you look at the proposed language that we have for
16 this, it is prescriptive and it's not technology-
17 neutral. If you do have a different type of UF6
18 package that comes down the pipe that does not have a
19 fill valve similar to what you have for this design,
20 now you're creating a situation where you're assuming
21 what industry is going to do with these packages.

22 So, again, we're trying to balance that
23 flexibility within the regulation with regulatory
24 certainty with safety. And so that's the point where
25 we decided that this was sort of the, if you want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 call it the sweet spot for looking at an incremental
2 improvement, this is where we landed.

3 MEMBER KIRCHNER: So this is only for
4 existing cylinders, aka packages?

5 MR. PIOTTER: This particular update would
6 account for existing technologies that have a valve or
7 other fill device, but, essentially, yes. I mean, you
8 would look at it from existing packages. If you're
9 looking at a new design, we're not going to be able to
10 anticipate what those new designs look like, which,
11 again, that's where 71.55(c) would come into play
12 where that's still a reasonable pathway to reach a
13 certificate of compliance. It's just not one that has
14 as much regulatory certainty.

15 And, again, I think part of the issue here
16 is that we don't know what these future designs are
17 going to look at, so we can't necessarily anticipate
18 what to regulate against if we don't know what's going
19 to be out in the environment. So, again, regulatory
20 flexibility is important in this conversation, which
21 is why we believe that 71.55(c) is an adequate pathway
22 for some of these unknowns that we still have.

23 MEMBER KIRCHNER: But then if one goes
24 that way, I have it open in front of me, then you
25 apply for an exemption.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. PIOTTER: That's correct. I mean,
2 exemption certainly is an opportunity to move forward,
3 as well. The public comment that we received on that
4 front was that, you know, if we want to stay away from
5 regulating by exemption, we have to provide an
6 alternative. And so that was part of the
7 consideration process, as well. Thank you for
8 bringing up the fact that exemptions are still an
9 opportunity.

10 MEMBER HALNON: This is Greg Halnon.
11 That's not an exemption to implement 71.55(c), though.
12 It stands on its own, right?

13 MEMBER KIRCHNER: Yes.

14 CHAIR BALLINGER: And that was Greg
15 Halnon, by the way, for the court reporter.

16 MEMBER HALNON: Yes. So the question,
17 continuing on with Walt's, is if you implement 51(c)
18 or 55(c) -- I'm sorry -- is there guidance that
19 prevents the bring me a rock syndrome where it stays,
20 you know, you have special design features?

21 MR. PIOTTER: No. Currently, there's not.
22 And I think that's one of the issues that we would
23 have to address looking at this. But, again, the
24 purpose and the point of 71.55(c) is to provide
25 regulatory flexibility, and so you have an opportunity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to provide regulatory certainty either through the
2 regulation or promulgating guidance. You could
3 consider that even for 71.55(g) where we could change
4 the way that the text is written to promulgate
5 guidance; but, again, we were trying to balance all of
6 these different features within the existing rule to
7 allow for the broadest range of flexibility based on
8 what we anticipate will come in for certificates of
9 compliance.

10 MEMBER HALNON: Okay. Well, I think, as
11 Walt was saying, many of the advanced reactors that
12 we're going to be seeing coming through is going to be
13 implementing 55(c) and you're going to get a potpourri
14 of different ways of doing it. So I'm just thinking
15 that there might be, at least at some point down the
16 road, where some guidance might be warranted. But I
17 understand what you're saying. Thank you.

18 MR. PIOTTER: Well, let me sort of do an
19 Uno reverse card here. Is the question on fuels or on
20 UF6 specifically? Because increased enriched fuel,
21 clearly, we'll have to either look at 71.55(b) or (c)
22 as the regulatory pathway. I'm just clarifying to
23 make sure that I understand.

24 MEMBER HALNON: Yes. I'm talking the fuel
25 itself.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. PIOTTER: Okay.

2 MEMBER KIRCHNER: So the implication here
3 is that, from what I'm hearing, is that to go to 20
4 percent would require different cylinders.

5 MR. PIOTTER: It would require perhaps a
6 different design. I don't know that it would
7 necessarily require different cylinders. I mean, the
8 issue in particular with ANSI N14.1, that's sort of
9 changed directions now in the sense that it doesn't
10 have the hard limitation of 5 weight percent. The
11 regulatory authority can make some determinations with
12 respect to that, so going to 20 weight percent would
13 be possible. I think the issue that you run into is
14 the number of transportation evolutions that you need
15 to have because you have to consider moderator. And
16 so it's going to reduce the payload capacity on a per-
17 cylinder or per-conveyance basis. And by not having
18 to consider water and leakage, you don't have that
19 restriction on your payload capacity that's due to
20 moderator inclusion alone. You may still have it
21 based on the total enrichment limit; and, again, as
22 you start to get above, I think the number that I
23 received was about 12.5 weight percent, it starts to
24 get away from moderator and starts to really look at
25 just the mass of the material itself. But, again, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are going to take a reduction hit if you have to
2 consider moderator in whatever cylinder or packaging
3 used for UF6.

4 MEMBER KIRCHNER: But the implications
5 here are then that in 71.55(g) that there's a specific
6 design and it has this valve body, as you reference in
7 sub-section one. So is that a double valve? Is that
8 a double valve? I mean --

9 MR. PIOTTER: No. It is prescriptive, and
10 it's not technology inclusive to include this
11 particular --

12 MEMBER KIRCHNER: That's my point.

13 MR. PIOTTER: Yes. And we're aware of
14 that, and part of the reason was that we did get
15 feedback from the public for existing technologies
16 that there would be a benefit in being able to ship
17 material up to, I think the comment was at 8 weight
18 percent, but we included up to 10 weight percent
19 because that's the range of applicability that we
20 presume, at least for LWRs. That's why the range was
21 chosen, but that was the implication from the comment
22 that we have is that it's for existing technologies.
23 And we recognize that it's not technology inclusive
24 and that it is prescriptive.

25 But, again, that's that balancing piece

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 between regulatory certainty, which, again, this is a
2 pathway for that, versus flexibility within the
3 regulation. And I think, in taking in total, when you
4 look at the entirety of 71.55, you have a significant
5 amount of flexibility in that regulation to make some
6 choices as a vendor seeking a certificate of
7 compliance.

8 MEMBER MARTIN: This is Bob Martin. I
9 appreciate, of course, the legacy that you're working
10 with. I think it probably does support the near-term
11 LWR needs. I think about, you know, what Walt has
12 brought up with, you know, the question of technology
13 inclusivity, and, you know, if this was truly clean
14 from a technology inclusivity, you might have other
15 rules related to the criticality or what have you
16 instead of kind of a state of, like, well, we
17 recognize, you know, a particular package and
18 everything else is kind of the bring us a rock kind of
19 thing. With what could be a bow wave of new reactors
20 and, I mean, I'm not talking about, you know, very
21 soon, you know, a full supply chain we have to worry
22 about to get to the point where we're shipping things
23 over 10 percent or even over 5. But, at some point,
24 do you think you need to revisit the rule to, you
25 know, put other guardrails? Again, related to some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the things you're talking about, you know, and how you
2 consider the problem. Do we need to say, you know,
3 bring up hazards analysis and do a more methodical
4 approach to defining what the packages really need to
5 be to satisfy the rule. I mean, it's really a rule on
6 a package, right, so we might say the enrichment is
7 immaterial, kind of like we just heard on 10.68,
8 right, that there really are -- the problem is the
9 package. It's not necessarily enrichment. But the
10 focus of the rule has been on the package because
11 that's what the community is focused on, but, as we
12 evolve, and, hopefully, this renaissance is going to
13 happen the way we envision it, it seems like we'd be
14 behind the curve if we're not being proactive with a
15 rule that focuses on what the next package has to look
16 like for folks that want to go above 10 and up to 20.
17 I mean, is anyone prodding you on doing that?

18 I know, obviously, there's a schedule here
19 to get stuff done. Like Ron said, it's incredible
20 that it's only been a year. But we do hear a lot from
21 the advanced reactor community and their chomp at the
22 bit, but they probably haven't thought about this
23 challenge, you know, as much as they're still just
24 thinking about design and operations. I mean, in the
25 background, are you all working on the next iteration

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of this?

2 MR. PIOTTER: Yes. I mean, the short
3 answer is, yes, we are. I think there's a lot of
4 different factors here that we're taking into
5 consideration, but this is not sort of a one-and-done
6 activity for us. I think what we're looking at here
7 is there are so many unknowns looking forward into the
8 future that it's very, very difficult, I think, to
9 pick a path to choose and figure out which one is the
10 correct path when we don't know what we're going to
11 see.

12 I think what this is reminiscent of is
13 really a recognition of the LWR fleet in general
14 because, again, that's what this particular rulemaking
15 is for is for the LWR fleet. That's what we're
16 looking at is looking at the operational history that
17 exists for that and the needs that exist for that for
18 the LWR fleet.

19 As more of that information, I think,
20 becomes available for the advanced reactor fleet,
21 we're definitely going to have to make new
22 considerations. And I think the new fuels team, in
23 particular, not to make a shameless plug for the new
24 fuels team within DFM and NMSS, but that's one of our
25 goals within that team is to look at sort of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 forward-looking or future-looking approach to how we
2 look at the regulatory framework, how we look at our
3 SRPs, and any other associated guidance documents that
4 go along with that; and it's going to have to be a
5 holistic approach. It's not going to just be this one
6 area of consideration. We're going to have to look at
7 the entire range of our regulatory framework as we
8 move forward as we get more information.

9 The other part of this is, and I mentioned
10 this at the very beginning, is what does that demand
11 signal look like? We do need information. There is
12 a dearth of information both -- and we presented this
13 even at a workshop that we had two weeks ago --
14 related to TRISO and metal fuels. There's a dearth of
15 information particularly on the back-end of the fuel
16 cycle but even, in some cases, on the front-end of the
17 fuel cycle about what we expect to see.

18 So as we're able to get more information
19 and integrate that into our process, we'll simply
20 pivot and move toward looking at whether or not
21 additional rulemaking does need to happen. For us,
22 again, this was an incremental step forward in making
23 sure we provided additional flexibility, as well as
24 regulatory certainty, for the LWR fleet, but it's not
25 going to be off the table to make further

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 considerations.

2 MEMBER MARTIN: It's very important to be
3 proactive. But I will give you a kudo. Last year,
4 and maybe you said explicitly that you were looking at
5 just exemptions for above 5 and, obviously, this is
6 going to be popular with the immediate customers.

7 MR. PIOTTER: And just for clarification,
8 I mean, exemptions, obviously, would be one way to do
9 that, and 71.55(c), while not having as much
10 regulatory certainty, is another pathway, and that
11 certainly could be something that we consider, as well
12 as any guidance opportunities that we have there, as
13 well, for 71.55(c). I think, again, the challenge
14 there is is, unless we have a design in front of us,
15 developing guidance for that particular part of the
16 rule is very difficult to do. We'd be sort of
17 throwing darts in the air and not really hitting
18 anything. So if we had designs available or at least
19 proposed designs, we would be able to start looking at
20 that even for 71.55(c) to provide, again, more
21 regulatory certainty.

22 MEMBER MARTIN: Thank you.

23 MR. PIOTTER: The last slide was just a
24 summary slide. Were there any other questions from
25 the members?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Yes, for clarification
2 on my part. As a practical matter, any advanced
3 reactor that's also in the LWR, this covers it. It's
4 only nonwater-cooled systems.

5 MR. PIOTTER: I would say that any fuel
6 type that needs UF6 enriched to X level is going to
7 benefit from this up to 10 weight percent. So if UF6
8 has a feed material, whether it goes into an advanced
9 reactor LWRs is somewhat immaterial because it's a
10 feed material for either or could be a feed material
11 for either.

12 CHAIR BALLINGER: That's what I thought.
13 Thank you.

14 MR. PIOTTER: Thank you.

15 CHAIR BALLINGER: Okay. By our schedule,
16 we're supposed to drag this on until 10:15.

17 MR. PIOTTER: I was a little concerned
18 about the --

19 CHAIR BALLINGER: We could probably try to
20 do that, but I'm pretty sure that we don't want to.
21 So I'm wondering whether or not the staff is ready to
22 just keep going or whether we should take a break of
23 some kind?

24 MR. BENAVIDES: If we could take a minute
25 just to switch over the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Okay. So we'll just
2 take a few-minute break to switch out people. Thank
3 you.

4 MR. BENAVIDES: All right. Great. Thank
5 you.

6 (Whereupon, the above-entitled matter went
7 off the record at 9:21 a.m. and then went back on the
8 record at 9:23 a.m.)

9 CHAIR BALLINGER: Okay. Go ahead. Thank
10 you.

11 MR. MESSINA: Thank you. I am Joseph
12 Messina, a reactor systems engineer in the Nuclear
13 Methods and Fuel Analysis Branch in NRR, and I am
14 going to give you a brief overview on how we are
15 addressing fuel dispersal with 10 CFR 50.46(a)
16 rulemaking. And since it's a big effort consisting of
17 many parts throughout the agency of different
18 disciplines, PRA, materials, and reactor systems, I'll
19 provide an overview to kick start before going into
20 some of the technical basis of transition grade size.

21 Next slide, please. To provide a little
22 bit of background, this part of the rulemaking is
23 driven by fuel fragmentation, relocation, and
24 dispersal, or FFRD. And to provide a little
25 background, at high burnup, experiments have shown

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that fuel fragment during LOCA, as shown on the figure
2 on the left, and then if the gliding balloons
3 eventually burst due to pressure differential across
4 the cladding, that fragmented fuel can relocate
5 actually into the balloon region and possibly disperse
6 into the RCS. So you'll see the figure on the right
7 are from first LOCA burst tests at Studsvik, and the
8 openings can be large, rather large. And if the fuel
9 fragments finely enough, that fuel can disperse out of
10 that opening. These phenomena are exacerbated at high
11 burnup, and industry is driving towards increasing rod
12 average burnups well past the 62 gigabyte-day rod
13 average limit. That moves methods or license to
14 date, in order to reach a 24-month cycle, so this
15 becomes more of an issue for us at the present.

16 Next slide, please. From a regulatory
17 perspective, the 50.46 criteria date back to 1974 when
18 FFRD were not known phenomena. The Commission
19 understood that rods would ductility balloon and
20 burst, but they did not know that fuel could possibly
21 disperse due to the fact that burnup was low at the
22 time.

23 So acceptable approaches to demonstrate
24 compliance with 50.46 and the regulations have ensured
25 that catastrophic failure of the fuel rod structure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and most of the fuel bundle configuration are
2 precluded, so we feel that fuel dispersal would be a
3 departure from precedent. And since fuel dispersal is
4 not explicitly addressed within the current
5 regulations, we thought it was important that we
6 develop a regulatory framework to address fuel
7 dispersal. So the draft proposed ruling, which allows
8 for some flexibility regarding fuel dispersal and DG-
9 1434 directly provides guidance for addressing fuel
10 dispersal within the proposed rule.

11 Next slide, please. To provide a little
12 bit of background on why we are pursuing the path
13 forward that we are, we are planning to risk-inform
14 LOCA in a 50.46(a) style modification of emergency
15 core cooling system requirements as shown in
16 Alternative 2 here, and that would establish a
17 transition break size based on LOCA break frequency
18 and designate the LOCA's above the transition break
19 size as beyond design basis accidents and allow for
20 best-estimate modeling and more realistic assumptions.

21 Some of the other alternatives that I'll
22 briefly touch on in the next few slides include
23 Alternative 3, which would be to provide a safety
24 demonstration of post-FFRD consequences in the current
25 framework at 95/95 confidence, just as any other LOCA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 phenomenon is typically done today. And then
2 Alternative 4 would be to provide a generic bounding
3 assessment of dose and risk insights for post-FFRD
4 consequences. And then Alternative 5 would be to use
5 probabilistic fracture mechanics to show that leaks in
6 large pipes will be identified before failure,
7 precluding the need to analyze large-break LOCAs. And
8 this is based, in part, on EPRI's alternative
9 licensing strategy but takes it a step further and,
10 instead of just using this logic to disposition fuel
11 dispersal, it would be used to disposition large-break
12 LOCAs.

13 Next slide, please. So I'll provide you
14 part of the reason why we chose Alternative 2 was
15 based on public comments, so I'll provide a little
16 overview of that. There was no really unanimous
17 single alternative recommended by industry, though
18 I'll emphasize that any comment represents many of the
19 organizations in industry, so when I mention where
20 their support was, please note that.

21 And industry recommendations were strongly
22 based on the qualitative schedule impacts that we had
23 in the regulatory basis, but those were quick and
24 crude estimates. After we published the regulatory
25 basis, we further evaluated the schedule impacts for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 each of the alternatives, and our opinion on the
2 schedule impacts changed and we actually felt that
3 Alternative 2, or 50.46(a) would be the quickest
4 alternative to pursue that was an immediate
5 consideration.

6 And then going through some of the public
7 comments that the Union of Concerned Scientists and
8 two members of the public did not support any
9 alternative that allowed for fuel dispersal, and then
10 another member of the public recommended waiting until
11 more research and analysis is performed before we make
12 a decision on fuel dispersal.

13 Next slide, please. So this slide
14 highlights some of the support across industry on
15 alternatives, except for Alternative 2 which I'll
16 discuss in the next slide. So you'll see NEI
17 supported a concurrent pursuit of Alternative 4 and
18 Alternative 5 in the increased enrichment rulemaking
19 schedule. The BWR Owners Group also supported
20 Alternative 4. They stated that they did not see
21 Alternative 5 as a solution due to the fact that leak-
22 before-break has not been approved for any BWRs to
23 date. And then Alternative 5, Westinghouse supported
24 a modified Alternative 5. And I'll state that NEI and
25 Westinghouse, they support Alternative 5 not as it was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 written but in the way it's written in ALS so not
2 using in probabilistic fracture mechanics to
3 disposition the entire large-break LOCA but to only
4 disposition FFRD. And some alternative approaches
5 mentioned in some of the comments include comments
6 from Framatome and the PWR OG, which suggested using
7 some of the insights that we used in GSI-191.

8 Next slide, please. On Alternative 2,
9 NEI, BWR Owners Group, and Westinghouse expressed
10 support for Alternative 2 outside of increased
11 enrichment rulemaking combined with 50.46(c) as a
12 separate rulemaking due to the perceived schedule
13 impact or as a backup to what was done in increased
14 enrichment rulemaking. We'll note that aspects of
15 Framatome's response in a 2023 white paper seem to
16 align with parts of Alternative 2.

17 And then, in the regulatory basis, we
18 asked a question that was responded to by NEI,
19 Westinghouse, and Framatome, and we received a
20 response that stated that, even with a no-dispersal
21 criterion, Alternative 2 was expected to be reasonable
22 with true best-estimate calculations. Now, we're not
23 pursuing a no-dispersal criterion on this rulemaking
24 for LOCAs above the transition break size, but that's
25 how the question was asked and provides some insight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 into how this rule could be advantageous for the
2 industry.

3 So this here shows some of the support
4 graphically in one slide, so you'll see where the
5 support was. It just summarizes the previous slides.

6 Next slide, please.

7 MEMBER ROBERTS: Joseph, maybe I'll ask a
8 question now. I didn't see anything in the rest of
9 the package that defined what true best estimate
10 means. Is that a term that you expect to disposition
11 later after you have a better definition, or did I
12 miss something?

13 MR. MESSINA: We provided some words, and
14 I'll talk about that a little more when I go through
15 the rule language and talk about the specific wording
16 of the rule. I can talk about that a little more, but
17 we kept it -- we didn't go into too much detail due to
18 the fact that this is typically done in other beyond
19 design basis accidents, such as ATWS and station
20 blackout.

21 MEMBER ROBERTS: The complexity of a loss-
22 of-coolant accident analysis is, you know, pretty high
23 and, you know, without doing some sort of sensitivity
24 study or uncertainty study, it seems like you wouldn't
25 know our true best estimate, whatever that term means.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I know there is a discussion in the rulemaking
2 document on sensitivity analyses, so it does appear
3 that there's some, you know, thought that you would
4 need to do just more than question all the numbers and
5 put it into a single calculation and say that's my
6 true best estimate. But I was wondering if you
7 thought that through, or is this all future work to
8 try to work with the applicants to figure out what you
9 would accept to be a true best estimate.

10 MR. MESSINA: We've done some thought, but
11 we could end up working more on this in the review of
12 different methods and whatnot. And, yes, you know,
13 while we say nominal calculations for these best-
14 estimate calculations, we would need to look at that
15 there's no cliff-edge effects, you know, if something
16 changes drastically, that number is not going to
17 change by 500 degrees and bring you over the limit if
18 you change something very small.

19 MEMBER ROBERTS: If you took the mean of
20 a best-estimate distribution, you might get a much
21 different answer than just running a calculation with
22 nominal values. Anyway, just trying to understand --
23 do you get a sense that this is very important, in
24 terms of the industry feedback, to be able to show the
25 true best estimate or do you think that's just kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a hoke at this point?

2 MR. MESSINA: I'm not entirely sure. I
3 think that would just be the easiest alternative. And
4 if we consider the factor of time in getting something
5 to high burnups and 24-month cycles, that would
6 probably be the easiest and quickest way to do it. So
7 maybe they do that until they develop more detailed
8 models on dispersal.

9 MEMBER ROBERTS: The option of either
10 shutting off burst or go through all the analyses
11 you're about to describe on trying to figure out the
12 effects of the dispersal -- okay. I guess I'll wait
13 and see if it comes up again in that context. Thank
14 you.

15 MEMBER MARTIN: This is Bob Martin. I
16 will add that, you know, on design basis basis,
17 there's plenty of precedent for consideration of
18 uncertainty. Some of it might be explicit with best
19 estimates plus uncertainty. Some of it, even with
20 ATWS and station blackout, maybe it's fairly easy to
21 establish process parameters because they tend to have
22 low uncertainties.

23 But in consideration of phenomena, you
24 know, those have to be considered because there is no
25 certainty with their characterization, so applicants

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 -- of course, I'm considering my own experience
2 working in industry, you know, whether we put biases
3 and still kind of call it best estimate or realistic,
4 it's there. So you can't ignore uncertainties, and I
5 know you're going to talk about that a little bit
6 more, so we're jumping on you a little bit soon. But
7 you can't avoid that, and it will be there and maybe
8 you'll get methods because, ultimately, you'll expect
9 the applicant to justify, you know, their decisions.
10 And that will go back to a characterization of
11 uncertainty regardless of whether it's design basis or
12 beyond design basis.

13 The difference, of course, is what do
14 those analyses support with regard to the design at a
15 beyond design basis, you know, large-break LOCA, you
16 know, with rule change that you're proposing, well, it
17 will mean something a little bit different and it will
18 start looking at what is design basis for tech specs
19 and what have you and things will move around maybe
20 quite a bit. But, nonetheless, because there already
21 is design considerations for beyond design basis
22 accidents and methods have already been established,
23 and you'll just want something consistent. But the
24 terminology without the word uncertainty is probably
25 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. MESSINA: Yes. And we did struggle on
2 exactly how to characterize it in some of the wording
3 of it, but what we really did mean was to match the
4 work done in ATWS space and station blackout space.
5 And there are varying approaches done in those spaces,
6 so, you know --

7 CHAIR BALLINGER: Walt.

8 MEMBER KIRCHNER: Thank you, Ron. Yes.
9 Just maybe this is more observation at this point and
10 the questions will come later, but it strikes me that,
11 to first order, a no-burst criterion is, essentially,
12 in my mind, a breakpoint -- poor choice of words -- a
13 demarcation of importance considering methods.
14 Basically, what I'm trying to say is that, up until
15 burst, you have a design basis accident; and, once you
16 burst, especially if you burst a significant amount,
17 I'm not just talking about leakers but actually
18 significant amount of the core reaches a burst by
19 condition, then you're essentially in a severe
20 accident state because the uncertainties at that
21 juncture become very, very large compared to design
22 basis accident analyses using uncertainties, et
23 cetera. That's the method.

24 The whole burst phenomenon is likely to be
25 very stochastic and not reliably predicted. And then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 what happens, once you lose geometry and location of
2 the fuel, it propagates huge uncertainty.

3 So are you, in your thinking, using some
4 burst criterion as a demarcation in how you approach
5 this? Because without burst, you don't have
6 dispersal, so that's a significant juncture. You can
7 deal with fragmentation in intact fuel geometries,
8 but, once you get to burst, then, as I'm suggesting,
9 the uncertainties just are huge.

10 MR. MESSINA: Yes. And we're not pursuing
11 a no-burst criterion, but that definitely would be
12 considered when we look at a method, you know, the
13 uncertainty in the ability to predict a burst.

14 MEMBER KIRCHNER: I would suggest the
15 uncertainties are very large and that the process is
16 likely stochastic, not repeated in experiment other
17 than driving the fuel to failure, like in the Studsvik
18 case. So a rulemaking that goes beyond that point
19 raises significant challenges for the staff in
20 evaluating an application, so I'm just observing that
21 that's a demarcation of significance.

22 MR. MESSINA: James, did you want to weigh
23 in?

24 MR. CORSON: Yes. So this is James Corson
25 from the staff. So as you say, there is this big

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 demarcation between burst and no burst. While in the
2 rule itself there's no such demarcation, in the
3 guidance that I'll talk about tomorrow, we do have
4 this sort of demarcation. So on the one hand, you
5 know, the sort of easy way, I guess, to satisfy the
6 coolable geometry concerns is to show no burst, but
7 then the guide has considerations that, if you do
8 burst, these are the types of things that you would
9 need to satisfy. So, again, I'll talk a lot more
10 about that tomorrow morning.

11 MEMBER KIRCHNER: Okay. Thank you. As I
12 said, that was an observation. I'll save my
13 questions. Thank you.

14 MR. MESSINA: Thanks. So since we are
15 pursuing an updated 50.46(a), I just wanted to touch
16 on some of the history. The initial development
17 started in the early 2000s, and there were several
18 Commission SRMs, as shown on the screen, guiding the
19 staff work on the rule; and there were about a dozen
20 ACRS meetings and three ACRS letters on this rule, as
21 shown here. I included some of the ADAMS Accession
22 Numbers for the letters and the committee transcripts.

23 This is part of why we had confidence in
24 pursuing Alternative 2 is because it was vetted by the
25 ACRS, so we knew it was technically mature and ready.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Eventually, though, it was rescinded due to lack of
2 industry interest, but there seems to be a renewed
3 interest in this today.

4 MEMBER PETTI: So, Joe, just a question on
5 the history since almost all of us weren't in that
6 ACRS to make sure I understand it and maybe Dave
7 Rudland wants to answer. That whole discussion and
8 framework was largely based on this expert elicitation
9 of pipe break frequency, et cetera. But, today, we
10 now have xLPR estimates, so, say, maybe a firmer
11 engineering basis to re-look at all of this through
12 that lens. Is that the fair way to characterize --

13 MR. RUDLAND: Yes. This is Dave Rudland
14 from the staff. Yes, it is. And we'll be talking
15 about that, you know, in a little bit. Rob will give
16 a brief background of what was done back in that time,
17 and then I'll talk about how we use these new tools to
18 try to confirm that.

19 CHAIR BALLINGER: This is Ron Ballinger.
20 I think the white paper on 1829 has a discussion of
21 both the history and --

22 MR. MESSINA: Yes. Next slide, please.
23 So this slide summarizes some of the previous slides.
24 We decided to pursue a modernized 50.46(a) in the
25 increased enrichment draft proposed rule due to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 support in public comments and the fact that it had
2 the smallest impact on the rulemaking schedule and due
3 to the high level of technical maturity and the amount
4 we could leverage the technical basis and work
5 originally performed in the 2010 50.46(a) rulemaking.

6 And I'll note that this 50.46(a) was and
7 is planned to be a voluntary alternative to 50.46, so
8 we're maintaining much of the original philosophy with
9 some change to some specifics. And I'll note that
10 LOCAs below the transition break size would not be
11 affected by this rule while LOCA above the transition
12 break size would be re-categorized as beyond design
13 basis accidents.

14 Also in this rule, we are planning to
15 include high-level fuel technology-neutral
16 performance-based ECCS acceptance criteria that are
17 based, in part, on 50.46(c), that rulemaking, but made
18 a little more performance based. And you'll see how
19 we did that this afternoon.

20 Next slide, please. So how does this
21 address fuel dispersal. So it doesn't directly
22 address fuel dispersal, but it's expected to
23 facilitate safety demonstrations of fuel dispersal
24 because best-estimate modeling and realistic
25 assumptions are expected to significantly reduce or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 eliminate the potential for fuel dispersal. While
2 this approach does not explicitly address other non-
3 mechanistic approaches to evaluating FFRD as described
4 in other alternatives in the increased enrichment
5 regulatory basis, other licensing pathways exist, for
6 example through the topical report process, and we
7 believe that our performance-based criteria may allow
8 some flexibilities in that space.

9 Next slide, please. So I briefly
10 mentioned 50.46(c), so I'll give a little bit of a
11 background on that. That was a draft final rule to
12 revise the ECCS acceptance criteria to be performance
13 based and reflect relatively recent research findings
14 on embrittlement of zirconium alloy cladding under
15 LOCA. The NRC LOCA research program running from 1997
16 to 2016 identified new embrittlement mechanisms shown
17 on the bottom of the screen, hydrogen-enhanced beta
18 layer embrittlement, cladding ID oxidation, and
19 breakaway oxidation, that show that under the current
20 regulations, the 17 percent local oxidation and the
21 2200 PCT post-quench ductility is not necessarily
22 assured following a postulated LOCA. This was
23 submitted to the Commission in 2016 and underwent
24 several rounds of ACRS review. We are leveraging some
25 of the work done in that rulemaking and in this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rulemaking, as well.

2 And if you go to the next slide, we'll see
3 that the Commission, this year, responded to our
4 rulemaking package, the draft final rulemaking
5 package, returning it to the staff without action and
6 directed the staff to do a few things. First of all
7 was that the staff should apply an appropriate risk-
8 informed regulatory approach to address the research
9 findings of cladding embrittlement. Staff should
10 evaluate that with other associated technical issues
11 being addressed, such as FFRD and risk-informed
12 treatment of LOCAs, including the draft final
13 50.46(a). And the staff should evaluate whether
14 specific emergency core cooling system criteria, such
15 as cladding temperature, should be codified or instead
16 addressed in regulatory guidance.

17 So you'll see from the next slide, you'll
18 see that we are addressing a large part of that SRM
19 with this rulemaking by including performance-based
20 broad failure criteria that account for the 50.46(c)
21 research findings in the rule and associated guidance.
22 And so we would use public comments received on those
23 performance-based aspects of this rulemaking to inform
24 any potential future action on the 50.46(c)
25 rulemaking. Since 50.46(a) is a voluntary rule, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 will continue to perform the annual ECCS safety
2 assessments to evaluate the impact of the cladding
3 embrittlement research findings for the plants that do
4 not elect to adopt 50.46(a) and address the research
5 findings. We would also evaluate the research
6 findings within the framework of existing regulatory
7 requirements when reviewing submittals that could
8 result in cladding embrittlement impacts, such as
9 power uprates or burnup increases since, for example
10 these phenomena are exacerbated at higher burnup, the
11 cladding embrittlement research findings.

12 CHAIR BALLINGER: This is Ron Ballinger
13 again. Just to be clear, folks that do not want to do
14 the voluntary rule are still subject to the new
15 research results related to embrittlement for
16 cladding?

17 MR. MESSINA: Not necessarily. So we're
18 saying if they go to higher burnups, then, yes, we
19 would most likely ask about it and we have asked about
20 it in reviews. But at current burnup, we would
21 probably not.

22 CHAIR BALLINGER: Ah, okay. So even at
23 current burnup limits, there's the possibility of
24 getting dispersal if you get failure. And so why not
25 ask the applicants that elect to stay with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 original to still comply with the new knowledge
2 related to cladding embrittlement in their evaluation
3 of ECCS performance?

4 MR. MESSINA: So we do our safety
5 assessments, and that provides assurance that, even if
6 we implemented the 50.46(c) criteria, plants would
7 adhere to them. So they are safe to date.

8 CHAIR BALLINGER: Okay. That's what the
9 conclusion was for 50.46(c). Okay. All right. I'll
10 have to think about it. We have new information and
11 had it for some time, and so, in your evaluation of
12 ECCS performance for any plant, we would think that
13 you would apply that knowledge in your evaluation.
14 Where am I wrong here? Where am I wrong?

15 MR. MESSINA: Well, we would have it in
16 the back of our mind and decide whether we would need
17 to ask about it or not. But, John, did you want to --
18 John Lehning in the back.

19 MR. LEHNING: John Lehning from NRC staff.
20 So we would consider any of that information, and we
21 have considered that, but we would look at it under
22 the existing regulations, like, if it's under 10 CFR
23 50.46, it might be under the coolable core geometry
24 and could this new information cause us to have a
25 question about that, and we would pursue it as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 necessary under that regulation. So that's the thing,
2 we just have to work within the existing regulation
3 for the plants that are under that.

4 CHAIR BALLINGER: So you're not putting
5 blinders on?

6 MR. LEHNING: Exactly. I mean, we know
7 that information. We're taking that information into
8 account in the reviews that we're doing under the
9 existing regulations for that plant.

10 CHAIR BALLINGER: Okay. Thank you.

11 MR. MESSINA: Thanks, John. Next slide,
12 please. So as I said, this is a big rule and a big
13 rulemaking effort, so I'll highlight some of the scope
14 of work that is associated with this rule. You'll
15 hear from Dave Rudland on how we confirmed the
16 original transition break size later today and work we
17 did there. You'll hear from James Corson on the
18 update to the three 50.46(c) reg guides on the screen,
19 and then we also developed three new reg guides. The
20 first one is on the risk-informed evaluation process
21 to support changes made under 50.46(a) that will be
22 discussed later today, the plant-specific
23 applicability of transition break size will be
24 discussed in January, and then addressing the
25 consequences of fuel dispersal we'll be discussing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 tomorrow.

2 Next slide, please.

3 DR. BLEY: Excuse me before you leave that
4 one. Dennis Bley with a question. Up under your
5 first bullet, are you going to talk some about the
6 internal and external expert elicitation in one of
7 these sessions?

8 MR. RUDLAND: Yes. When I talk about the
9 confirmation of the transition break size, we'll go
10 over the efforts, the recent efforts on the internal
11 and external expert elicitation, yes.

12 DR. BLEY: Okay. I'd like to see that.
13 I don't think I ever went through that before. Thank
14 you.

15 MR. MESSINA: Next slide, please. So as
16 you'll see, this rule is a relaxation of the
17 regulatory treatment of LOCAs above the transition
18 break size, but we believe that it maintains adequate
19 protection due to these three bullets: the initiating
20 event frequency for such events are very low and the
21 NRC will ensure that it is low and remains low on a
22 plant-specific basis, the NRC will ensure that risk
23 increases through the rule are minimal and that there
24 are not large increases in overall plant risk, and
25 we'll maintain regulatory control over LOCAs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 continuing to review ECCS evaluation models and
2 topical reports and plant-specific implementation of
3 those models in those LOCA analyses, as done to date.

4 Next slide, please. So as I said, this
5 consisted of several different technical expertises:
6 materials, risk, seismic, and reactor systems. So I
7 highlighted some of the main contributors here, and
8 there are others not listed, but I just wanted to give
9 credit where credit is due.

10 And next slide. And this brings me to the
11 end of my presentation.

12 MEMBER KIRCHNER: This is Walt Kirchner.
13 Sorry, Ron. I didn't raise my hand. Could you go
14 back two slides, please? So under each of these sub-
15 bullets, could you just enumerate for the record what
16 you anticipate the agency would be doing to -- using
17 your words, the rule relaxes the regulatory treatment
18 above TBS. Could you just enumerate compensatory
19 measures that you would expect the applicant to take
20 or you would inspect such that you would retain this
21 confidence?

22 MR. MESSINA: Yes. So for the first
23 bullet, you'll hear a lot more in January. There's
24 going to be a draft guide on plant-specific
25 applicability of the transition break size; and,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 relatively similar, we plan to do inspections on welds
2 for piping greater than the transition break size, as
3 Dave Rudland will talk about later. And then for the
4 changes and the risk increases due to these changes,
5 you'll hear more about that because we specify what
6 we'd expect an applicant to do in the reg guide that
7 will be presented later on, the risk-informed
8 evaluation process. And then we will maintain topical
9 report review and LAR review of LOCA analyses for the
10 --

11 (Audio interference.)

12 MEMBER KIRCHNER: Okay. Thank you.

13 DR. BLEY: This is Dennis Bley again.
14 50.46(a) just kind of disappeared for a long time.
15 Have there been any additions or changes to the basis
16 since back when that was first issued?

17 MR. MESSINA: So, partly, yes. So we
18 realized that the basis was developed well over ten
19 years ago, so we didn't just pick up the basis and
20 say, oh, no, it's applicable. We did our work to
21 ensure that that basis remained applicable today,
22 looking at operating experience, delays in
23 probabilistic fracture mechanics and whatnot, and
24 you'll hear more about the work we did to ensure and
25 re-establish that technical basis from Dave Rudland

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 later.

2 DR. BLEY: Okay. I'm glad to hear that,
3 and I hope you have sizes, you know, what you've
4 picked up since that time.

5 MR. RUDLAND: And, Dennis, this is Dave
6 Rudland. One of the things we also try to do is we
7 try to take into account and incorporate the thoughts
8 of the industry back in that time frame and some of
9 the concerns they had with the rule and the way the
10 guidance was written at that time and tried to take
11 those and incorporate those also in the updated basis,
12 the updated rule and guidance.

13 DR. BLEY: Okay. Thanks. And if we get
14 some details on that, that will be helpful.

15 MEMBER HALNON: This is Greg Halnon. Just
16 a quick question, not a question but I guess what I'll
17 be looking for. I see the rational between the first
18 two bullets on this, but I don't understand how those
19 two comport with -- why does the third bullet have to
20 be there? We leave a lot of risk that's very low in
21 the hands of the licensee to handle. I wouldn't
22 maintain regulatory control over these if the event
23 frequency is very low and we're making sure that it
24 stays low. So just as we go through this process,
25 I'll be listening for that rational.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: I had a question on --
2 this is Bob Martin -- adequate protection. Another
3 feature of protection, you know, is the tech specs;
4 and, you know, under a maximum hypothetical accident,
5 totality, you know, look to LOCA as defining the
6 limits on tech specs as we sharpen the pencil, and we,
7 in some ways, have already seen it, just the, you
8 know, just the best estimate LOCA rule change created
9 situations where, you know, non-LOCAs were becoming
10 limiting. Have you all kind of assessed the guidance
11 on the preparation of tech specs to ensure a
12 comprehensive review of events that, you know, will
13 lead to appropriate definitions of tech specs? I
14 mean, we have to revisit that?

15 MR. MESSINA: A little bit of a hint into
16 some of what we'll discuss later is, you know, we do
17 ensure that anything that is credited for LOCA is
18 placed into tech spec, so we will maintain regulatory
19 control over that. We don't expect there to be major,
20 we didn't think there would be major changes needed to
21 overhaul the tech specs.

22 MEMBER MARTIN: So that third bullet kind
23 of relates to tech specs; is that what you mean or
24 part of what you mean?

25 MR. MESSINA: Yes.

1 CHAIR BALLINGER: With respect to item
2 one, we've had a few precipitating events in the past.
3 V.C. Summer and Davis-Besse and the like, which have
4 resulted in a lot of changes in how we do inspections,
5 where we do inspections, how often we do inspections.
6 And is that applicable to assuring adequate
7 protection? In other words, this is modified in
8 inspection regimes that we have. Does that constitute
9 assurance of adequate protection or could that?

10 MR. MESSINA: I'll hand it over to Dave
11 Rudland.

12 MR. RUDLAND: So everything we've learned
13 from the time that this rule was originally written to
14 now has been considered in the development of this
15 basis, and the thought process of the industry's
16 efforts to optimize inspections and how that relates
17 to the relaxation that's happening because this rule
18 was one of the major considerations that we took in
19 developing the rule and the basis.

20 So I think it's all being considered, and
21 we'll, again, go through that here in the upcoming
22 presentations.

23 CHAIR BALLINGER: Sprinkled in the various
24 documents which I've read, which I can't remember the
25 exact numbers all the time, that type of wording about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the value of inspections and the like is sprinkled, if
2 you want to put it that way, through these documents.

3 MR. MESSINA: Okay. If no more questions,
4 I'll hand it over to Robert Tregoning.

5 CHAIR BALLINGER: Okay. Wait a minute.
6 We have sufficiently dragged this on so that, if it's
7 convenient for you folks, this is a good time to take
8 a 15-minute break. Is that good enough? Okay. So
9 let's take a 15-minute recess and come back in a
10 little after 10:15.

11 (Whereupon, the above-entitled matter went
12 off the record at 10:03 a.m. and then went back on the
13 record at 10:17 a.m.)

14 CHAIR BALLINGER: Okay. We're back in
15 session, and I think, Joe, are you still on or it's --
16 no. Okay. Rob.

17 MR. TREGONING: Yes, Rob Tregoning, senior
18 technical advisor for Research, part of staff. I'm
19 going to come and give a little bit of history.
20 Member Petti said we developed the original technical
21 basis for 50.46(a) about 15 or 20 years ago.

22 Before I start, and I hate to do this, I
23 don't mean to be openly antagonistic at the beginning
24 of an ACRS meeting, but I feel like I need to correct
25 the record somewhat. Chairman Ballinger indicated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that it was a heroic staff effort to do this rule
2 within a year. I just want the record to reflect we
3 started work in March, so it's really been closer to
4 nine months. I think there were many times when the
5 staff would have killed to have gotten another three
6 months to put all this stuff together, so I just
7 wanted to make sure that the record --

8 CHAIR BALLINGER: And what's the
9 uncertainty been?

10 (Laughter.)

11 MR. TREGONING: It's at least 20 percent.
12 So what I'm going to do is just give you a background,
13 and I am going to basically tee Dave up because you'll
14 see that a lot of what we did 15 years ago, we
15 followed a very similar playbook to confirm the
16 continued adequacy of the technical basis over the
17 last nine months or so. So I'm going to give you
18 enough of a flavor to set so that, when Dave presents
19 what he's going to present, you'll have a background
20 and an understanding of the motivation and the
21 approach that we used to try to make sure that the
22 technical basis is still acceptable moving forward.

23 Next slide, please, Phil. So, again, what
24 I'm going to do, I'm just going to summarize the
25 historical and, when I say historical, it's the pre-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 2024 technical basis that we used to develop the TBS,
2 but you'll see a lot of those concepts, approaches,
3 and techniques are very similar. We've just got
4 updated tools compared to what we did in the early
5 2000s.

6 There's three components to what I'm going
7 to talk about, and these go chronologically, but also
8 they reflect how the staff's thinking and basis was
9 used to develop the TBS. We first started with
10 assessing LOCA frequencies. And Member Petti
11 indicated that it was by expert elicitation, but it
12 was a blended sort of elicitation. And I think it
13 will be helpful to refresh the members' minds in terms
14 of what was done, so we'll talk about that NUREG-1829
15 basis. We used that as a starting point. We used
16 that effort as a starting point to select the TBS, but
17 there were other considerations that went into
18 actually picking the TBS, and I'll spend a couple of
19 slides talking about the other considerations that we
20 had.

21 The one thing that we didn't do in 1829,
22 it was really geared toward looking at normal
23 operating events and anticipated transients, things
24 that a plant would see over their operating life, so
25 sort of expected events. We didn't look at seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 or, in particular, rare seismic events. And we
2 recognized that gap from the very beginning, and we
3 knew we would likely need to do some additional work.
4 So a couple of years in on working on 1829, we started
5 an effort to evaluate seismic integrity of large asset
6 structures and particularly piping and component
7 supports, and that effort was documented in NUREG-
8 1903.

9 We started that work, we started all this
10 work around 2002 and then both of those NUREGs were
11 published around 2008, so there was a lot of technical
12 basis work that went into underpinning the development
13 of the TBS back in, again, the early 2000s.

14 Next slide, please, Phil. So I'm going to
15 jump in and talk about 1829: what was the scope, what
16 were the objectives, what we were trying to achieve.
17 Again, the scope is pretty simply stated in that first
18 bullet. We wanted to look at piping and non-piping
19 passive system LOCA frequencies as a function of leak
20 rate. Leak rate is just another way of saying LOCA
21 size. And we also wanted to look at operating
22 effects.

23 At the time, subsequent license renewal
24 was not on the horizon. We were in the midst of
25 license renewal. I think, at that time, we had maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 half the plants that had been either approved or going
2 through it. So we made sure we did an assessment out
3 to 60 years, but we didn't go, at the time, out to 80
4 years, again, because it just was something that was
5 not on the horizon. And we used expert elicitation.

6 So, again, we're focusing on LOCAs that
7 initiate in unisolable portions of the reactor coolant
8 system, and we were specifically focused on LOCAs
9 related to passive component aging but then also
10 tempered by mitigation measures. So, Professor
11 Ballinger, you mentioned Davis-Besse, V.C. Summer.
12 Those things happened really just before we started
13 and embarked on the elicitation, so there was a lot of
14 discussion about not only those events but operating
15 experience in general. I'll give a flavor for how we
16 used operating experience within 1829, and then Dave
17 is going to talk more about in his presentation how we
18 used operating experience since that time to do the
19 updated technical basis work that we've done over the
20 last nine months.

21 Again, I mentioned this before, but the
22 objective was to determine frequency distributions for
23 typical plant operating cycles and histories. And
24 this third bullet is a key one that we were assuming
25 that there would be no significant changes that would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 occur in plants' future operating profiles. Why was
2 that? Well, we didn't really have a basis to
3 speculate, so we didn't consider, you know, power
4 uprates certainly had happened but, you know, we
5 didn't consider the effects potentially of whole-scale
6 power uprates and we certainly didn't consider load-
7 following and effects such as that because that's not
8 even something that was discussed back in those times.
9 So there was an expectation that, you know, sort of
10 past performance and how the plants had operated
11 providing steady-state base load would be, roughly,
12 how they would continue to operate into the future.

13 Next slide. I don't want to spend a whole
14 lot of time on this, but 1829 was groundbreaking in
15 many ways because the LOCA frequencies that we used in
16 PRAs up to that time, they were developed solely based
17 on operating experience and operating history. And
18 there was three seminal efforts that really developed
19 LOCA frequencies, and the first two, WASH-1400 and
20 1150, they didn't even account for nuclear operating
21 experience by and large. WASH-1400 used oil and gas
22 transmission pipeline failure data to come up with
23 LOCA frequency estimates because, again, in 1975, that
24 was really the best that we had. And then 1150
25 basically used those same distributions and did a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Bayesian update of the fact that we hadn't had really
2 any LOCAs in nuclear service since that time, so 1150
3 was really just, again, a Bayesian update of those
4 WASH-1400 estimates.

5 It wasn't until the mid to late 90s that
6 NUREG/CR-5750 developed specific estimates based on
7 nuclear experience. If you're familiar with 5750, the
8 way it developed its analyses, it looked at precursor
9 events, right, because we haven't had LOCAs but we've
10 had plenty of precursor events. We've had leaks,
11 we've had cracks, we've had degradation due to fact
12 and other things, and it tried to take those precursor
13 events and then extrapolate, given those precursor
14 events, what are my conditional probabilities of
15 ruptures associated with those and then, based on some
16 assumptions, came up with LOCA frequencies that,
17 again, were used for several years in PRA.

18 When we embarked on 1829, there was a
19 strong recognition within the material and the
20 structural integrity community that operating history
21 by itself may not accurately reflect future
22 performance, especially when you're dealing with very
23 rare unlikely events. And operating experience in and
24 of itself requires significant extrapolation when
25 you're dealing with these larger frequencies that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 again, have never happened in service: medium break,
2 large break, and then beyond.

3 Next slide, please. So very early on, we
4 though expert elicitation was the best way to tackle
5 this, and I'm still convinced that it's the best way,
6 even given the improvements and tools that we've had
7 in the ensuing 15 years. You know, the issue with the
8 operating experience is that LOCA events are rare, as
9 I just detailed on the prior slide. And even with
10 modeling -- and, look, we had PFM models 15 years ago.
11 xLPR is a better model now, but the models are only as
12 good as the mechanism that they can model. Most
13 models are limited in terms of the degradation
14 mechanism systems and loads that they really consider.
15 You can get LOCAs from a variety of sources, and you
16 may or may not have an appropriate model for a LOCA,
17 right. We didn't have a model for Davis-Besse, right,
18 but Davis-Besse was potentially a LOCA that could have
19 happened. In fact, I would argue it's probably the
20 closest we've gotten to a medium-break LOCA over our
21 operating history to date.

22 And then elicitation has a very strong
23 history and use at the NRC. It was used back in the,
24 you know, 90s in development of the SSHAC hazard
25 curves. In the seismic community, it's been sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 widely used. A lot of the Yucca Mountain stuff,
2 performance assessments for expert elicitation was
3 really prominent there. And then even in the
4 structural community, when we redefined the PTS rule,
5 50.61(a), that was based on reactor pressure vessel
6 flaw distributions that, at the time were developed
7 via expert elicitation. So we have experience of
8 using this process in rulemaking. I think we've got
9 a hand up, so I don't know if you want to -- Dennis.

10 DR. BLEY: It's Dennis Bley, Rob. I just
11 wanted to support a little of what you said. Some of
12 the folks I was aware of back then were using that
13 data from leaks, over a range of leaks, to kind of
14 expand it and say, well, you get a larger hole, they
15 just modeled that rowing and completely different
16 mechanisms involved, I think, in looking at the medium
17 and large LOCAs than the mechanisms in the leaks, and
18 I think you guys took account of that.

19 Are you going to talk particularly about
20 the two elicitation efforts, internal and external?

21 MR. TREGONING: Yes. I'm going to touch
22 on what we did for 1829, and then Dave is going to
23 elaborate further on what we did over the last nine
24 months.

25 DR. BLEY: Okay. I'll wait for that to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ask questions about it. Thanks.

2 MR. TREGONING: All right. Thanks,
3 Dennis. Next slide, please. So this is the approach.
4 I'm not going to go into this into great detail, but
5 I do want to touch on aspects of the approach that
6 Dave is going to follow-up on later, so I want to make
7 sure I tee Dave up.

8 So similar to what Dave is going to talk
9 about, this internal and external elicitation, we did
10 the same exact process in 1829. We conducted what we
11 called a pilot elicitation, but that was done with
12 internal staff. We used that to help prepare us for
13 doing the formal expert elicitation using a variety of
14 outside stakeholders. So that pilot elicitation was
15 very important, and I'll talk a little bit about that.

16 Then it was selecting the panel, and the
17 facilitation team was a really important aspect of the
18 elicitation. And then, once we had that team
19 assembled, we collectively worked on developing the
20 technical issues that we were going to assess, and
21 then we developed what are called base cases, and I
22 want to spend a little bit of time on that because
23 Dave is going to talk about how we confirmed or
24 reconfirmed some of those base cases using both
25 operating experience, as well as probabilistic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 fracture mechanics methods. So it was very similar to
2 what we did 20-some odd years ago. And what the base
3 cases are is we defined, and I'll go into more detail,
4 but we had well-defined scenarios, and then we asked
5 different experts to provide quantitative estimates
6 for the likelihood of such scenarios. And we did it
7 for both piping and non-piping sorts of failures.

8 So those base cases were very important,
9 and I'll go into those in a little bit more detail.
10 And once we developed those, we formulated the
11 elicitation questions. We conducted individual
12 elicitations, so these were all individual interviews.
13 But then, once we got the individual efforts, we
14 informed the rest of the group on some of the
15 opinions. So even though things were done
16 individually initially, we wanted to make sure that
17 the experts had an understanding of what the other
18 experts had said, and we gave them the opportunity to
19 modify any of their responses to us based on what they
20 had heard from the other experts. I'm not going to
21 talk much about that. In fact, I won't talk anything
22 else about that, but I just wanted to give you a
23 flavor for how it was done.

24 We spent a long time analyzing the
25 quantitative results and making sure those results

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 matched the qualitative rational that we were provided
2 by the experts because, again, we just didn't ask them
3 for numbers, we asked them to support their numbers
4 with a qualitative basis. In some cases, there was
5 incongruency and, if we found incongruencies, we went
6 back to the experts and said, all right, things aren't
7 quite matching up, which should I believe: your
8 qualitative rational or the numbers that you gave me
9 to support it? And then we were able to rectify
10 things based on that sort of ongoing discussion.

11 Then we summarized documented results, and
12 then we had internal and external peer review of the
13 process and results. We were done with most of the
14 work for the elicitation, I want to say, around 2004 -
15 2005. We didn't publish until 2008. That's because
16 a lot of that time was spent doing peer review,
17 uncertainty analysis, sensitivity analysis, a whole
18 range of things that were done, which are documented
19 in 1829.

20 MEMBER MARTIN: Was there an effort to do
21 a formal failure modes and effects? You talked about,
22 of course, different mechanisms that can contribute to
23 break. I'm kind of curious just how formal the
24 process was. You know, today, of course, methods of
25 hazards analysis incorporate failure modes effects and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 other techniques. Certainly, those methods have been
2 around for a while, although it might have been pretty
3 new as far as, you know, NRC back in 2004. How formal
4 were those methods to characterize? Obviously, you
5 went to a lot of effort to understand the frequencies.

6 MR. TREGONING: There was a lot of
7 discussion and effort into modeling and discussing the
8 mechanisms associated with pipe and passive system
9 failure. We didn't do any FMECA analysis on what
10 might happen post failure, right; we were just
11 focusing on --

12 MEMBER MARTIN: Exactly. On what led to
13 the initiating event --

14 MR. TREGONING: So the structural
15 community, we don't consider that a FMECA, but we talk
16 about the process or the evolution of damage, right,
17 and aging effects. So those were discussed
18 explicitly, and we actually broke scenarios down into
19 their fundamental attributes or causal factors, things
20 that can lead to potentially degradation and can
21 ultimately challenge structural integrity. I've got
22 a slide that touches on --

23 MEMBER MARTIN: So it might involve, you
24 know, involving the experts who might make estimates
25 for, you know, hierarchy of failure mechanisms, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 then the combination of those leads to a final --
2 okay.

3 MR. TREGONING: Look, we had a pretty
4 broad diversity of experts. We had PRA folks. We had
5 structural engineers. We had materials folks. We had
6 plant folks. So each of those people approached this
7 problem from a different way, so we had to have an
8 evaluation framework that would satisfy all those
9 different approaches, and I'll talk a little bit about
10 that.

11 MEMBER MARTIN: How many people did you
12 have?

13 MR. TREGONING: We had 12 people. We had
14 12 experts and then supported by a four-member
15 facilitation team, so the facilitation team were the
16 ones that, you know, worked in conjunction with the
17 experts. And not all of those experts gave us actual
18 quantitative estimates. We got ten PWR quantitative
19 estimates and nine BWR estimates, so some of them
20 actually recused themselves from actually providing
21 estimates and some only provided a subset of estimates
22 that they felt comfortable with.

23 So it was a pretty good group, though. I
24 mean, it was the most fun I've ever had at the NRC is
25 trying to manage and herd the cats associated with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that.

2 MEMBER MARTIN: Well, you know, one of the
3 criticisms of expert elicitation is that it usually
4 gets dominated by a personality, one or two
5 personalities. Did you find that to be an issue?

6 (Simultaneous speaking.)

7 MR. TREGONING: That was not an issue
8 whatsoever.

9 CHAIR BALLINGER: You're talking about
10 around this table, we're sometimes wrong but never in
11 doubt.

12 MR. TREGONING: I don't have the names,
13 but most people would recognize, including some that
14 were, you know, future ACRS members. So we had a lot
15 of very opinionated people, and we sought that out.
16 When we picked panelists, we just didn't pick them
17 based on their expertise. That was one consideration.
18 We wanted people that were going to be opinionated.
19 We wanted people that were going to be able to provide
20 a basis for what their opinions were, so that was
21 something that we consciously thought about at the
22 time.

23 All right. I'm dragging this down.
24 Sorry. Next slide, please. So, again, I'll talk a
25 little bit about the pilot. And, again, I wouldn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 talk about this so much, but I want to tee Dave up a
2 little bit.

3 So the pilot was all done internally. We
4 had 11 internal NRC experts. And, again, we tried to
5 sample a broad knowledge base there, so not only
6 materials folks, structural integrity folks, but,
7 again, PRA, thermal hydraulic folks. And you'll see
8 that we followed a similar template when we did the
9 internal elicitation in this most recent effort.

10 And we actually got interim results that
11 we used as part of the initial very early-on
12 rulemaking development. We said, okay, here's some
13 estimates that we're seeing, these are some potential
14 break sizes that we might be able to support. So we
15 actually had some results very early on that we could
16 use at least on the side as we were developing the
17 rule at the same time we were developing the technical
18 basis; but, more importantly, we were able to try out
19 and pilot the framework. And so we found things that
20 worked, things that didn't work, and we were able to
21 really tune what we did in the expert elicitation.

22 And then, as importantly, the internal
23 folks brought up technical issues. They said you
24 really need to make sure that you address this with
25 the outside experts. So we felt like we had a really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 strong footing to start the external expert
2 elicitation after conducting the pilot elicitation.

3 I think I've already talked through all
4 these. These were individual elicitations led and
5 monitored by this four-person facilitation team. I
6 mentioned that we had 12 experts, and the facilitation
7 team was largely NRC and NRC contractor subject matter
8 experts.

9 A little bit about LOCA size
10 classification just because we used some unique
11 definitions at the time, but these definitions sort of
12 served us well. So, historically, LOCA sizes that are
13 used in PRA are based on plant response
14 characteristics, right, if you're doing it under high-
15 pressure or low-pressure injection. So we tried to
16 maintain those consistent definitions, and LOCA
17 categories one, two, and three are really using
18 consistent flow rate definitions and LOCA size
19 classifications that have been historically used in
20 nuclear and certainly NRC regulations, so small break,
21 medium break, large break.

22 But we really wanted to make sure we went
23 up to flow rates that would be, you know, consistent
24 with the double-ended guillotine break at the largest
25 pipe at the plant. So we defined three more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 categories for these, I'll call them extra large-break
2 LOCAs that we spanned this large-break LOCA regime
3 from a classical LBLOCA up to even a double-ended
4 guillotine break.

5 And, again, at least initially, we based
6 on flow-rate thresholds. But then we also developed
7 correlations relating the flow rates to actual break
8 sizes because, again, most of the experts were not
9 thermal hydraulic experts and they felt more
10 comfortably in terms of a break size, so what's a size
11 break that I need to worry about in this particular
12 system. So those correlations were actually
13 incredibly important to make sure the experts could
14 provide opinions and responses based on their subject
15 matter expertise.

16 We looked at three time periods. The
17 current day, at the time, it was around 2004, and the
18 fleet at that time was about 25 years average
19 operation. But we also did estimates out to the end
20 of the design life, which would be, again, an average
21 48 years operation and then the end of the first life
22 extension out to 60 years of operation.

23 Next slide. And you brought up how did we
24 consider, you know, did we consider failure modes and
25 effects. This is how we tried to break things down,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 right. So you have a general box with your LOCA
2 contributions. You have LOCAs based on passive system
3 and then active system LOCAs. The elicitation did not
4 discuss active system LOCAs at all. Now, this would
5 be something like, you know, valve reliability, pump
6 reliability, pumps running, valves opening when
7 they're supposed to and closing when they're supposed
8 to. And the expectation was those are already
9 handled, we deal with those under the maintenance rule
10 already. We were focusing here on passive system
11 LOCAs.

12 And then we further broke down passive
13 system LOCAs into piping and non-piping contributions,
14 and then, you know, the piping into the piping systems
15 and then, most importantly, the attributes of those
16 systems. And it's those attributes that provide the
17 causal information that make one particular mechanism
18 more or less likely to be active in that particular
19 system. So the attributes that we covered in 1829 was
20 the geometries of the system, the materials of the
21 systems, the loading history, what types of loads,
22 what mitigation and maintenance is and has been
23 applied in those systems, and then what aging
24 mechanisms are potentially active given these other
25 variables. And those were the different causal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 factors or attributes that we considered within the
2 elicitation.

3 The non-piping, we broke them down exactly
4 the same way, but, you know, each component has a
5 different set of attributes or a different weighting
6 of the attributes compared to the pipes. So
7 components that could lead to failures include
8 unisolable LOCA failures, includes steam generator
9 manways, pumps, pressure vessel itself, pressurizer,
10 and valves. But, again, each of those components were
11 also broken down into their attributes. I just don't
12 show it on the flow chart.

13 MEMBER MARTIN: How does external events
14 and particularly seismic fit into this?

15 MR. TREGONING: Well, again, as I
16 mentioned at the very beginning, we did not consider
17 seismic. We were only considering normal operating
18 transients, so steady state and sort of anticipated
19 transients, so service at level A and B sorts of
20 loading that you would expect over the lifetime of the
21 plant. That's why we ultimately did 1903 so that we'd
22 get a separate evaluation of the impact of the seismic
23 event. We thought, if we tackled seismic here, we
24 were going to need a whole different level of
25 expertise. We thought it was just going to expand the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 scope too much.

2 So we had this structure, and, again, I
3 mentioned we had different experts. Some people gave
4 us very high-level analyses, and some people started
5 at each attribute and worked their way up and
6 developed LOCA contributions at a very fine, very
7 finely-graded area, and we supported both of those
8 approaches. And some experts, again, some experts
9 gave us very high-level information and some, again,
10 as I said, just broke it down in a very detailed
11 manner. And the structure allowed them to provide
12 estimates however they were most comfortable providing
13 estimates.

14 Next slide. A little bit on the base
15 cases. So we developed base cases, and base cases are
16 important and we use them for anchoring the responses
17 and the base casing conditions specify a unique piping
18 system, size, material, loading, degradation
19 mechanism, and mitigation. And we defined five base
20 cases, two BWR and three PWR base cases. Although BWR
21 Base Case 1 on the recirculation system, there was a
22 28-inch and a 12-inch, so we really had two separate,
23 we called them Base Case 1a and 1b within the
24 recirculation system. We wanted to get a variety of
25 piping materials systems and then sizes, so you see we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have base cases related to the largest size pipes,
2 like the hot leg, the recirculation system. We had
3 more intermediate sizes like feedwater and surge line,
4 and then the HPSI makeup line we wanted to have at
5 least one smaller diameter system. You know, those
6 are typically four to six-inch long lines, and we
7 wanted to make sure that we had a set of base cases
8 that would be more relevant to the smaller pipes
9 because smaller pipes have unique challenges compared
10 to larger pipes.

11 Now, what we used those base
12 cases for, we actually had a separate subgroup within
13 the expert panel, and they actually did quantitative
14 evaluations of the base case. They calculated each
15 base case as a function of flow rate and operating
16 time and provided LOCA frequencies. We had four
17 separate panel members that were part of this subgroup
18 that analyzed the piping base cases separately. Two
19 of them used primarily classical PRA operating
20 experience types of approaches, and then two of them
21 used probabilistic fracture mechanics using different
22 tools. One guy, Dave Harris, who you certainly well
23 know, used the pcPRAISE code, which, at the time, was
24 probably the state-of-the-art PFM code. And then we
25 had a guy from Rolls-Royce that used the PRODIGAL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 code, and the PRODIGAL code was the same code that we
2 used in 50.61(a) to come up with flaw distributions.
3 So both of those codes had quite a good lineage and
4 track record at the time, so we thought they were
5 sufficiently mature enough to use in this exercise.

6 Next slide, please. So I don't want to
7 spend a lot of time on this. This is like a shock-
8 and-wow factor chart because what this shows is the
9 results from the four different estimates that we got
10 from the base cases, so each of those dots represents
11 a different analysis that we got. And then you can
12 see the two BWR base cases to the left and then the
13 three PWR base cases to the right.

14 I just want to make three points because
15 you can see the scales that I've used. I'm plotting
16 failure frequency as a function of LOCA category, and
17 there's the six or five different LOCA categories that
18 can be represented by those particular base cases. As
19 I think you'll see, there's incredibly large
20 variability, but that was due to the fact that, even
21 though we had well-defined base cases, not every
22 expert could analyze the definition as it was given to
23 them because of limitations in their tools or
24 limitations in the data that they had pertaining to
25 operating experience. So even though we defined the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 conditions, it didn't mean that everyone could
2 definitively analyze those conditions in a meaningful
3 self-consistent way.

4 CHAIR BALLINGER: Pardon me. We have a
5 hand held up, but it's not a member, and so I think we
6 need to -- I don't know who this person is. It says
7 Constellation, I think.

8 MS. SHI: Thank you very much, this is
9 Grace. I don't know if I missed that, can you go back
10 to the previous slide?

11 CHAIR BALLINGER: Excuse me, and I may be
12 wrong, but are you speaking as a member of the public?

13 MS. SHI: Probably, yeah.

14 CHAIR BALLINGER: Okay, so in that case
15 our procedures are that at the end of the presentation
16 we'll have the time for public comment, which we'll
17 take then. If you want to make a comment that's
18 written, you can submit those to the DFO, in this case
19 will most likely be Weidong Wang in the future. So,
20 we apologize for imposing our rules, but those are our
21 rules.

22 MS. SHI: Is there going to be a section
23 for questions at the end of the presentation?

24 CHAIR BALLINGER: There will be a session
25 where we will accept public comments. Those comments

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are not in the form of questions, but if you want to
2 make a comment in the form of a question then you
3 should communicate with Mr. Weidong Wang, the DFO for
4 this meeting.

5 MS. SHI: Okay, I think mine is more like
6 a question, I don't know if I missed that. Just --

7 MR. BURKHART: This is Larry Burkhart from
8 the ACRS staff, just to reiterate, this is an ACRS
9 meeting in which the staff and others will provide
10 their input to the committee so they can eventually
11 deliberate on advice to the commission. This is not
12 a public meeting with the staff with a back and forth
13 on questions.

14 So, there will be an opportunity for a
15 comment later today before we adjourn, and you can
16 provide written comments as Member Ballinger said to
17 myself, lawrence.burkhart@nrc.gov, if you wish. Okay,
18 thank you.

19 MR. TREGONING: Follow policies and
20 procedures. So, yeah, so even though there's
21 recognized large variability, each base case member
22 went into the entire expert panel and presented what
23 they did, and they took questions, and so everyone
24 made sure that they really understood what the
25 limitations and constraints were associated with each

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of the different four analyses that were done.

2 So, and we ask each panel member to
3 critique the approaches and the results from the base
4 cases as part of the elicitation session. So, we got
5 feedback from each expert on how well, or how
6 appropriate they thought the base case analyses were
7 done.

8 (Simultaneous speaking.)

9 DR. BLEY: And Rob, just a quick question.
10 I remember what the LOCA categories are, one through
11 six. I see on the BWR case, the BWR-1 results are
12 much higher than BWR-2 across the board. Will you
13 remind me what BWR-1, BWR-2, and BWR-133 are?

14 MR. TREGONING: Yeah, so BWR-1 was --
15 thank you for going back, Phil. Sorry for using the
16 shorthand, but BWR-1 was an evaluation of cracking
17 within the main recirculation loop piping. BWR-2 was
18 thermal fatigue in the feed water system, as well as
19 potentially FAC. PWR was SCC in the hot leg, SCC as
20 well as fatigue. Surge line was SCC and fatigue in
21 the surge line.

22 And then PWR-3 was primarily a fatigue
23 consideration of the HPSI makeup line.

24 DR. BLEY: Okay, when I look at the curves
25 on the next slide, I probably want to look at all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 those cases differently because they're different
2 events, but they might combine into an overall
3 frequency within each LOCA category.

4 MR. TREGONING: Yeah, right, so the
5 different colors are each -- and again, this is a busy
6 slide, I apologize for that, there's a lot of
7 information there that I just haven't explained. But
8 each of the specific colors are representing unique
9 base case. Like I said, each dot represents a
10 different estimate of those base cases.

11 DR. BLEY: Thank you.

12 MR. TREGONING: Now, those base cases are
13 very specific events, they don't necessarily equate to
14 LOCA frequencies whatsoever. I'll talk a little bit
15 later about how we use the base cases.

16 DR. BLEY: Thanks.

17 CHAIR BALLINGER: If I recall back in
18 those days, and maybe a bit before that, on the BWR
19 side, we were wrestling with BWR pipe cracking, and
20 actually replacing recirculation piping, and all kinds
21 of things. So, that probably has a bearing on
22 estimates.

23 DR. BLEY: Big time, yeah.

24 CHAIR BALLINGER: In those, because that
25 was a unique series of events that was going on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 DR. BLEY: By the time we did the
2 elicitation we dealt with IGSCC issues in BWRs, but it
3 had been a long history starting back in the late 80s
4 through even the 90s. And believe me, yes, it was the
5 fact that -- not the repair replacement activities,
6 but the fact that in many cases we'd left cracks in
7 service that we'd mitigated. So, some of the high
8 estimates, in fact the highest estimates were
9 concerned about those sorts of scenarios.

10 Now, recognizing that when we were doing
11 the PWR results, we were just starting to live through
12 the whole PWSCC issues, because those started in the
13 U.S. in the early 2000s. So, even though PWR
14 mitigation strategies were still evolving, there was
15 certainly a lot of discussion about current operating
16 experience, and what mitigation was likely going to
17 happen.

18 The experts at the time were probably
19 prescient, because they said we've got this whole
20 basis for how we mitigated IGSCC, the expectation was
21 that they would use many of those same techniques to
22 mitigate PWSCC cracking in PWRs, and that's ultimately
23 what was done. So, again, that's why they were the
24 experts, but it was smart because they knew we had a
25 technical basis, why develop new things if you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rely on a technical basis that largely worked for
2 BWRs?

3 MEMBER MARTIN: So, a clarification, this
4 is Bob Martin again, you said each plot symbol
5 represents an individual's estimate?

6 MR. TREGONING: One individual, and we
7 asked them to do a best estimate. Whatever that
8 means, we said give us your best shot.

9 MEMBER MARTIN: So, basically said you've
10 got input for ten BWRs, and nine PWRs, was that -- I
11 mean, I look at that going --

12 MR. TREGONING: Well, no, the base cases,
13 there were just four members that did the separate
14 calculations, these were separate calculations. And
15 these were just used to anchor for other people's
16 results. So, these only have a relationship to the
17 LOCA frequencies that they ultimately developed
18 because they were used to anchor other people's
19 estimates.

20 MEMBER MARTIN: In statistics you kind of
21 consider that a validation set, is that the intent?

22 MR. TREGONING: Yeah, I didn't want to go
23 too much into this, so --

24 MEMBER MARTIN: Jump on it now.

25 MR. TREGONING: When you're trying to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 predict very rare events, things that just don't
2 happen. So, providing absolute estimates of rare
3 events is incredibly challenging to do. So, what we
4 did, it's easier to provide relative estimates, I
5 think this is more likely than that. So, we used the
6 base cases to provide a series of quantitative
7 estimates under well defined conditions.

8 And then the experts said if I'm thinking
9 about recirculation line cracking, and all the
10 different LOCAs that can occur, I'm going to use this
11 BWR-1 as a base case for saying okay, when I think
12 about LOCAs in the recirc system, I'm going to do
13 everything relative to this base case. So, they would
14 say I would think that you're really going to have SCC
15 maybe ten percent as likely as you quantified in the
16 base case.

17 So, then when you use these relative
18 estimates, and based on the anchoring in terms of
19 whatever base cases they chose to actually develop the
20 quantitative estimates. So, that was really the only
21 purpose of the base cases. Experts can choose to use
22 them or not, many of them did, but not all of them
23 did. So, some of them chose to develop from whole
24 cloth their own absolute estimates.

25 We had one Westinghouse person use the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 SRRA code, which was a relatively recent PFM code, and
2 all of their estimates were developed explicitly from
3 just exercising that code.

4 CHAIR BALLINGER: Excuse me, we have
5 somebody is making noise in the background, probably
6 need to mute something. But we have two people with
7 raised hands, and number one is Vicki.

8 MEMBER BIER: Hi, Vicki Bier. I
9 understand your argument about that it's easier to
10 provide relative judgments than absolute judgements,
11 especially for these very small numbers. But one
12 point I want to raise, and I don't think I looked at
13 what you did closely enough to know whether this is an
14 issue.

15 Anchoring can influence people's judgments
16 a lot even when it's inapplicable. So, for example if
17 you spin a wheel of fortune before you ask somebody
18 for their assessment of something, even though they
19 know it's a random number, and shouldn't bear on their
20 assessment, it still ends up influencing what number
21 they give afterwards, which is kind of not ideal.

22 So, I don't want to make that as a
23 critique necessarily, because I don't know how your
24 experts used the anchors, but just a concern to be
25 aware of.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. TREGONING: Yeah, no, it's a good
2 point, it's something certainly that we were well
3 aware of that at the time. You sort of pick your
4 poison, it's hard to provide absolute numbers, but you
5 do have to be careful when you're anchoring that,
6 because the anchoring in and of itself, like you
7 correctly stated, it can lead to biases.

8 So, we had elicitation training, where we
9 talked about anchoring, and effects like that to try
10 to make sure that the panelists were aware of it. Do
11 you ever make sure that there are no biases? Of
12 course not. But the one thing I do say, the fact that
13 we had so much variability in those base case
14 estimates, I think was actually a good thing.

15 Because it provided really a wide range of
16 estimates that people could ultimately use to anchor
17 on based on what they thought was more appropriate or
18 not. And you need to do something, and we thought
19 that again, having relative answers was much easier
20 than trying to just directly provide these very low
21 initiating event -- these very low estimates.

22 And you'll see that some of the estimates
23 got down to ten to the minus eight per year. So, it's
24 incredibly difficult to even wrap your mind around
25 events that rare.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER BIER: Okay, I appreciate the
2 comment, thank you.

3 CHAIR BALLINGER: Dennis?

4 DR. BLEY: Yeah, I would second what Vicki
5 says, it's bizarre how much that can influence people,
6 even when they know that anchor isn't applicable.
7 Looking at the BWR, I'm guessing that low estimate is
8 all from the same expert increasing mechanistic
9 calculations are coming up with numbers like 10 to the
10 minus 16 and 10 to the minus 12.

11 I'm not sure what that means to us, but if
12 I were one of the experts looking at this I would
13 probably avoid paying too much attention to that one.

14 MR. TREGONING: Yeah, and again, these are
15 all the discussions that we had. I will say that
16 you're correct, if you look at those BWR-2 results,
17 and those low ones were all for one particular expert,
18 that expert again, that base case included
19 consideration of FAC as well as fatigue, and his tools
20 were only able to model fatigue failures.

21 So, fatigue failures in that system
22 according to his estimates were highly unlikely. So,
23 I indicated the notion that we had well defined base
24 cases, but not everyone analyzed the same problem.
25 And understanding what problem they analyzed was part

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of the discussions that we had with the wider expert
2 panel.

3 DR. BLEY: Okay, so they understood this
4 sort of stuff going in?

5 MR. TREGONING: Yeah, again, each of the
6 base case members came in, and had multiple
7 presentations to the rest of the panel, and questions
8 were asked, they each had a write up. The write ups
9 were sort of reviewed, and questions asked, and
10 modifications made, so this was an iterative process
11 as well.

12 DR. BLEY: Okay, and that was true for
13 both the internal and the external?

14 MR. TREGONING: No, we didn't do this at
15 all of the internal. The internal is just a pure
16 elicitation. We didn't do any of this base case
17 anchoring, none of that was done internally.

18 MEMBER MARTIN: I can't help but make the
19 observation that if I was coming in cold, my
20 expectation is that it would follow a power law,
21 right? That's just kind of the rule of thumb for rare
22 events, and for most part you've got to see the power
23 law. And given though you're talking about different
24 kinds of breaks, and I will acknowledge that I'm
25 looking at the document now, and certainly LOCA five

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to LOCA six, you can kind of see a difference.

2 But of course it should depart from the
3 power law because you have different things that lead
4 to the break. So, I know you're only giving us a
5 little snapshot here, and I'm the first to throw out
6 the bottom one, because that seems a little off. But
7 everything else seems to follow a nice smooth line,
8 and that would be my expectation going in.

9 But you would hope that when you started
10 considering all the branches that you showed earlier,
11 that you would see some departure from that. And I
12 guess now that I slide through the document, I do see
13 some of that that's got --

14 MR. TREGONING: Yeah, you'll see a little
15 bit. Again, when I share the total results, you're
16 coming up, assuming that I get to them, you'll see
17 some of the --

18 MEMBER MARTIN: No, we're going to keep on
19 asking questions.

20 MR. TREGONING: That's what we're here
21 for, we were way ahead of schedule, I figured I would
22 torpedo the schedule at this point, but that's okay,
23 that's why we're here. I'm trying to make Dave's
24 presentation after mine much easier, so thank you.

25 CHAIR BALLINGER: You're trying to force

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 him to be after lunch.

2 MR. TREGONING: Well, that's where it is
3 on the agenda.

4 MEMBER MARTIN: I think Walt had a
5 question.

6 MEMBER KIRCHNER: Yes, thank you. I just
7 observed that if you were to draw lines through your
8 estimates by your individual experts, these lines are
9 relatively flat, and that's surprises me. What I mean
10 by that is that I would have expected when you got out
11 to LOCA categories four, five, and six, you might see
12 a more distinct drop off in failure frequency.

13 Could you elaborate? Because you're
14 working up to defining a transition break size, so one
15 thing that would, in a sense from the elicitation,
16 give one confidence to truncate the size LOCA that
17 you're looking at is to see that your estimates for
18 the larger break LOCAs fall off in frequency too, much
19 smaller numbers, but I'm not seeing that.

20 MR. TREGONING: So, an important
21 clarification, these aren't holistic plant LOCA
22 estimates. These are estimates for various well
23 defined failure scenarios. It makes up part of the
24 LOCA population, but not the entire estimates. So,
25 one of the things that you'll see, especially with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 mechanistic analyses, and Dave is going to show the
2 latest results.

3 Sometimes the mechanistic analysis you can
4 either get a leak, or you can get maybe a larger
5 rupture. So, there's not a lot of demarcation between
6 intermediate size LOCAs, and it's a function of the
7 system itself. And you're seeing some of that here,
8 in some of the results, why they look flatter than you
9 might expect.

10 Now, when you see the total LOCA estimate
11 curves, they're going to look more power lawish,
12 because again, you have different populations, and you
13 have this cumulative effect where you're summing all
14 these different mechanisms of all these different
15 systems together. So, you're going to get this more
16 average, or sort of aggregated approach, it's going to
17 look more continuously decreasing than you see here in
18 some of these individual scenario estimates, if that
19 makes sense.

20 MEMBER KIRCHNER: Okay, I'll wait to see
21 the more detailed analysis, thank you.

22 MR. TREGONING: Well, Dave is going to
23 share some more recent xLPR estimates, and those are
24 flatter than you might anticipate as well, but they
25 actually -- they sort of mimic at least behaviorally

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 sort of the mechanistic effect of frequency as a
2 function of LOCA size that you see in some of these
3 base case estimates. But that's just a teaser, Dave
4 is going to provide that information after lunch
5 probably.

6 I think we can safely move on. I wouldn't
7 have provided this slide if Dave wasn't going to have
8 a similar slide later, because I knew we would take
9 forever on that slide. We did something similar for
10 non-piping base cases, but it was harder to do.
11 Something I neglected to mention, we also have an
12 operating experience database at the time for piping
13 failures.

14 A lot of the piping failures, not only in
15 the U.S., but internationally, part of this
16 international database. At the time it was an OPDE
17 piping database, we didn't have anything like that for
18 non-piping. Of course non-piping can consist of
19 things like steam generator tube failures, CRDM tube
20 failures, things like that.

21 So, one of the things we actually did as
22 part of this, is we actually developed initially a
23 non-piping database that people could use, because
24 something like that wasn't in existence at the time.
25 Now, since then the piping and the non-piping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 databases have merged, and we've got broader passage
2 system failure databases that have been developed.

3 But at the time we didn't have anything
4 for non-piping, so we developed this non-piping
5 precursor database. And then we also had prior PFM
6 modeling done of specific issues that we also used for
7 non-piping base cases. And these were past problems
8 that people had worked on prior to the elicitation.
9 For CRDM ejection was something that was very much in
10 vogue.

11 Because it was something that in the early
12 2000s, and into 2002, was something that people had
13 developed models on for predicting like North Anna
14 and then what ultimately became the Davis-Besse event.
15 So we had models related to CRDM ejection. And of
16 course BWR and PWR vessel rupture is something that
17 had been studied at that time very extensively, and
18 then even much more so since then.

19 We were doing 50 61 alpha at the same
20 time, so we had updated PTS evaluation models for
21 PWRs, but we also had events that had been done over
22 the last 10 to 15 years looking at LTOP and normal
23 operating events for BWR vessel rupture, and work that
24 had been done by the industry, so we tried to take
25 advantage of that as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And in the analysis we talked a little bit
2 about anchoring, but depending on what scenario the
3 experts were looking at, they had the opportunity if
4 they wanted, to choose what they thought was an
5 appropriate base case. It could be either precursor
6 events, one of the calculated events that we used
7 either for piping or non-piping.

8 And then they had to provide us a relative
9 likelihood of that particular failure scenario
10 compared to a chosen anchoring, or base case of that.
11 Next slide please. This is just more mechanics, I
12 don't want to spend much time here. But just the big
13 bullets, we developed total BWR and PWR LOCA
14 estimates.

15 We didn't break things down on a system
16 level, we aggregated each expert opinion all the way
17 up to the highest level, and then we did the
18 aggregation. And that was because we didn't get the
19 same level of consistency, and gradation, and results
20 with individual experts, so we really couldn't combine
21 them until we got up to their total estimates.

22 Of course aggregation at the time, that
23 was a raging controversy in terms of how we should
24 best aggregate expert opinion. And we looked at a lot
25 of different aggregation schemes, but ultimately what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we thought was the best is we thought -- under the
2 premise and philosophy that the group results should
3 be more accurate than any single estimate, we wanted
4 to make sure that the outliers didn't dominate the
5 quantitative estimates.

6 We did want more of a sort of calculation
7 of the median than again, having outliers drive the
8 final results. We asked experts not to just -- we
9 didn't ask them for means, we asked them for basically
10 quantiles of distribution. So, we asked them your
11 best estimate would be like a median estimate, 50
12 percent, but it could be higher, or 50 percent lower
13 than that.

14 And then we asked also for their 5th and
15 95th percentiles, and we couched them in a way that
16 how much lower could that estimate be, or how much
17 higher could that estimate be. They approached it
18 more from a bounding perspective. Then we interpreted
19 those bounds as more like 5th and 95th percentiles of
20 the individual distributions.

21 And then we calculated confidence balance
22 associated with each of those parameter estimates, we
23 did a whole boat load of sensitivity analysis, and
24 then the final LOCA distributions that I'm going to
25 show here in a minute reflect both uncertainty, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the uncertainty is quantified in the differences in
2 the individual panel members responses, and in the
3 variability, that was the range of responses among the
4 individual responses.

5 MEMBER MARTIN: Real quick, how did you
6 avoid outliers not dominating the estimates? I mean
7 seeing something on the earlier slide, 10 to the minus
8 14, different ways that you can do this if you're
9 fitting a power law you're going to do it differently
10 if you're fitting a linear fit there. Some people, if
11 you had plenty of data you might just drop them. But
12 you don't have a ton of data, so you have to consider
13 --

14 MR. TREGONING: No, we didn't do -- there
15 was no Olympic scoring, right? We didn't knead out
16 the high and low results, we took all the results.

17 MEMBER MARTIN: Right, you didn't have
18 enough.

19 MR. TREGONING: No, but that's to be --
20 and look, there's a lot of discussion in NUREG about
21 this, but that's why I felt strongly that geometric
22 mean aggregation was the best way to do it, because it
23 weighted all the results, it didn't unfairly weight
24 the outliers. But at the time that was something,
25 because SSHAC, and other elicitations have always

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 arithmetic mean aggregation.

2 If you use that for very low estimates
3 you're going to be dominated by outliers. And we
4 didn't feel like that that was an accurate
5 representation of what the true panel opinion was.
6 But again, 20 years ago, that was a raging controversy
7 about how we should best do that. You see a lot of
8 discussion about that in NUREG 1829.

9 MEMBER MARTIN: Thanks.

10 MR. TREGONING: Next slide please. So,
11 there's the estimates. And I won't go over them in
12 too much detail, but you can see the sort of power law
13 behavior, although you will see some noted drop off.
14 Like from BWRs there's a big drop off with size, and
15 that really reflects when you get to the biggest size,
16 there's just very few components that can result in a
17 LOCA of that size.

18 So, that's why you get this natural
19 degradation. The PWRs, at least initially you'll see
20 a little flatter curve, and that was really reflective
21 of the time of the expectation that stress corrosion
22 cracking, and events like that, if there was going to
23 be a higher frequency, it would be evidenced in these
24 smaller breaks.

25 So, that's why it's maybe a little bit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 flatter for the Ps, and then it starts to dovetail
2 off. You can see again I've plotted the median, the
3 mean, and the 95th percentile results here. And then
4 the arrow bars reflect the confidence balance. So,
5 those arrow bars reflect the spread in the expert
6 opinions associated with each of those parameters.

7 And then I've just drawn the ten to the
8 minus five, and ten to the minus six lines just as
9 reference points. Dennis has a question.

10 CHAIR BALLINGER: Dennis?

11 DR. BLEY: Yeah, Rob, this isn't a
12 critique of what you guys did, but it's, I think a
13 correction of something you said, two things that you
14 said. Arithmetic mean overemphasizes the high
15 outliers, and geometric mean overemphasizes the lower
16 outliers, so they both have a problem. In the end
17 SSHAC didn't do straight arithmetic mean, they brought
18 the groups back together, and this is the way the
19 methodology tells you to do it.

20 To come to the group consensus on their
21 best expectation of the view of the technical
22 community. They had some high outliers on some
23 specific things that were really corrupting results.
24 And that really focusing on how to put this stuff
25 together, and what the results are supposed to mean,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 it gave them a way out of it, and it's a way that
2 makes sense to me a lot.

3 MR. TREGONING: Yeah, no, thank you for
4 that, Dennis. I was maybe a little bit too glib, and
5 I think your comments are really valid, because you're
6 right, geometric mean can overemphasize the low
7 frequencies as well. We followed, at least
8 conceptually, the SSHAC approach. But we opted not
9 for -- we didn't want to develop consensus estimates.

10 Now, what we did do, is once we got the
11 initial set of estimates, as well as the qualitative
12 rationale, all that information was provided back to
13 the main group, right? We gave -- so, all of those
14 individual elicitations, it was funneled back to the
15 main group, and then we gave people the opportunity to
16 change their testimony, or the result of the responses
17 that they gave us.

18 If there was something that they heard
19 that they thought was appropriate to modify their
20 results, I'll say even giving them that opportunity
21 almost no one chose to modify, there were no
22 significant modifications that arose from that, but
23 the discussions that were had were very helpful.
24 Because again, even though things were done
25 individually, we wanted to make sure that at least the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 group was informed by the rest of the opinions from
2 the other experts.

3 It wasn't a classic SSHAC approach in that
4 we didn't try to hammer through a consensus approach.

5 DR. BLEY: And that's generally pretty
6 good unless you have some really strong disagreements,
7 and then --

8 MR. TREGONING: And that's right, because
9 that's the potential challenge with that. We talked
10 about the fact that strong opinions can dominate. If
11 you try to get a consensus approach, you're more
12 likely to have that sort of outcome, a couple of very
13 passionate individuals will drive the ultimate result.
14 That's why we felt like -- and again, we did mixture
15 distribution, we did geometric mean, we did arithmetic
16 mean.

17 We just thought based on these particular
18 results that the geometric mean aggregation provided
19 the best estimate of the median opinion of the
20 experts. So that's, I don't mean to give a blanket
21 recommendation of in a vacuum for low frequency
22 estimates you should always use geometric mean, but we
23 thought for this particular exercise, we thought it
24 gave us, again, best expression of what we thought the
25 median results we're being told was from the experts.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But Dennis is giving a sense of the rate
2 of controversy in discussions that we had 20 years
3 ago. It was a lot of fun, and I don't know that we
4 reached any consensus, but here we are 20 years later.

5 CHAIR BALLINGER: Vicki?

6 MEMBER BIER: Thank you, this is Vicki
7 Bier again. I'm a little surprised at the low
8 diameters, the uncertainty seems to be quite small.
9 And I don't know if that's because it's being driven
10 by empirical experience in that range, or whether you
11 had assumptions that drove higher uncertainty for
12 larger diameters, or if you can comment on the reasons
13 for that.

14 MR. TREGONING: Yeah, you have to
15 distinguish between the Ps and the Bs. If you look at
16 the BWR, there's still a fair uncertainty associated
17 with the smallest breaks for BWRs. But for Ps the
18 smallest breaks are dominated by steam generator tube
19 rupture. We've actually good operating experience and
20 data. So, there was an expectation that yes, steam
21 generator tube ruptures for these very small breaks,
22 that's going to be your highest risk driver.

23 And that's not going away regardless of
24 what you do, because those components have far and
25 away the largest margin of any other passive -- sorry,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 smallest margin of any other passive component in the
2 plant. So, that's why those particular very small PWR
3 estimates, the uncertainty is much smaller there than
4 for other estimates.

5 And on the other end when you're trying to
6 estimate rare events, you would expect the uncertainty
7 is going to increase, because you're measuring
8 frequencies that are highly unlikely. So, you should
9 expect to have greater uncertainty associated with
10 those. And that's actually what the results reflect.
11 You did see the uncertainty increase with the
12 threshold break size.

13 MEMBER BIER: Thanks, that makes sense
14 about the steam generator tubes.

15 MR. TREGONING: Okay, I think we can move,
16 can we safely move forward? So, summary, and I want
17 to wrap this up because we've got to get through to
18 the other two components. The formal expert
19 elicitation, had these piping and non-piping base
20 cases, panelists provided quantitative estimates
21 supported by qualitative rationale.

22 And then group results were determined by
23 aggregating the individual panelist estimates, and
24 that's -- I think I will keep going, I want to get
25 into the other meaty parts if there's any more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 questions. So, I'm going to shift gears now, and talk
2 about how do we use 1829 then to develop the
3 transition break size.

4 So, the first bullet, we used -- the 1829
5 results were just used as a starting point. And
6 getting to Dennis' point, we looked at all the
7 uncertainties, we looked at the different ways that
8 you could aggregate the expert opinion. We looked at
9 both mean, and 95th percentile results, and we decided
10 at the end of the day that we're going to use the 95th
11 percentile results so that we make sure that we have
12 some level of conservatism.

13 And our initial acceptance criteria as
14 we're looking for frequencies less than ten to the
15 minus fifth per year. Depending on uncertainties,
16 given the 1829 results, that puts you in a BWR range
17 of a break of about 13 to 20 inches, and a PWR of
18 about 6 to 10 inches. So, that was our starting
19 point, we said okay, this is an initial range.

20 But we realized these other things were
21 just as important. So, whatever we pick from the GBS,
22 it should accommodate uncertainties, right? So, we
23 need to make sure we do that. We need to consider at
24 least other types of LOCAs that weren't covered in
25 1829. Active LOCAs is one, low generated LOCAs from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 heavy crane drops, severe water hammer, those were
2 things that we didn't explicitly consider, and then
3 seismically induced LOCAs.

4 Which again, we had a separate exercise
5 related to seismically induced LOCAs. But then this
6 last pool, it was really probably as much of -- was as
7 important a consideration as any of the previous ones.
8 As we looked at the actual populations of pipe sizes
9 that were out in the plants, and what systems they
10 corresponded to, and what operating experience we had
11 associated with those systems.

12 And that's ultimately, we weighed all of
13 that along with the 1829 results in the final
14 selection of the transition break size. But then the
15 next slide will give the TBS definitions. And there's
16 separate definitions for the PWRs, and BWRs. So, the
17 TBS is defined as a pipe break that's the size of the
18 cross sectional flow area of the largest pipe attached
19 to the main coolant loop.

20 And for PWRs, that's the size of the
21 largest pipe attached to the cold or hot leg main loop
22 piping, and that's on the order of again, these are
23 plant specific, there's not one number, but it's on
24 the order of 12 inches, maybe anywhere from 10 to 14,
25 maybe even a little bit smaller. And for Bs it's the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 size of the largest pipe in either the residual heat
2 remover, or feed water systems inside primary
3 containment.

4 Again, this can vary, but it's somewhere
5 on the order of 20ish inches. And the rationale, the
6 next larger pipe breaks, they're significantly less
7 likely, they're more leak before break resistant.
8 There's a smaller population of those pipe sizes. And
9 then pipe sizes less than the TBS were ones that we
10 typically see experience degradation in terms of
11 operating experience.

12 And the other reason for picking these
13 sizes as we did, we wanted to make sure we had as much
14 regulatory stability as possible. Because we
15 recognize that passive system failure frequencies can
16 certainly fluctuate over time depending on what's
17 happening. But as we defined the TBS, we wanted to
18 come up with a TBS that we thought would provide us
19 stability.

20 So that even if these things estimate --
21 sorry, fluctuate in the future, they're not likely
22 going to require a new TBS definition to maintain
23 acceptable risk. So, those were principal
24 considerations that went into defining the TBS. Next
25 slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: Just real quick, trying to
2 make a connection between 1829. In your categories in
3 1829, and again, these were two different efforts, I
4 appreciate that, you have the smallest large break at
5 flow rate of greater than 5000 GPM, using that
6 definition you're still in large break land. I mean,
7 LBA, LBB --

8 MR. TREGONING: Yeah, you're still in
9 large break land, you're beyond -- I mean a lot -- the
10 threshold for a large break LOCA size is plant
11 specific, but a lot of plants it's around six to ten
12 inches maybe, depending on the configuration, and what
13 their ECCS system is designed to handle. But six
14 inches is maybe a rough metric. So, yeah, we're in
15 large break land.

16 MEMBER MARTIN: When you talk about
17 defining large break, I mean you're still in large
18 break land, you're just kind of shaving off.

19 MR. TREGONING: We're not -- again, I
20 consider large break land anywhere from six inch up to
21 a double ended guillotine break in the largest pipe in
22 the plant, and that's a very wide range.

23 MEMBER MARTIN: Thanks.

24 MR. RUDLAND: I think also for your
25 categories, it's LOCA three category and above, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. TREGONING: Yeah, we defined LOCA
2 three as the minimum large break, yeah.

3 MR. RUDLAND: Half of the categories you
4 see are still --

5 MR. TREGONING: Yeah, because that was the
6 focus, because we knew we were going to be changing
7 sort of the design basis. So, we really wanted -- and
8 that was the hardest thing to predict. So, that's why
9 we had a graded approach to try to look at all these
10 different categories of effectively large break LOCAs.
11 Thanks for that, Dave.

12 All right, I spent a lot more time on 1829
13 than I'm going to on 1903, just from a time
14 consideration, as well as a consideration that 1829
15 was really fundamental to a lot of the other work that
16 you are going to see presented here today. We did
17 have a very extensive effort to look at seismic risk,
18 and I at least wanted to spend a couple of slides
19 talking about it.

20 So, the purpose of this was to fill in to
21 some of the gaps that we didn't address in 1829, and
22 make sure that seismic risk was going to be
23 acceptable. Now, when we started in 1903, we had a
24 pretty good understanding of what the TBS was going to
25 be. So, we were focusing 1903 on just evaluating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 breaks that would be bigger than the TBS.

2 So, we weren't concerned about smaller
3 breaks, or fragility of components that could lead to
4 smaller breaks. We were really just focusing on those
5 bigger breaks that we were looking to move outside of
6 the design basis. And 1903 documents six supporting
7 activities, these are a little bit backwards, but this
8 is how it's written in the reg guide, so you can take
9 issue with the reg guide.

10 But there was a lot of review of past
11 earthquake experience, especially earthquake
12 experience and how it affected passive systems. There
13 was a review of past seismic PRAs up to sort of the
14 early 2000 time period. And then there was -- and
15 this is dated, but it was actually really good work.
16 In the mid 80s there was a Lawrence Livermore study
17 that looked at both direct and indirect seismic piping
18 rupture.

19 And it was used to support at the time,
20 GDC4 revision. And we spent a lot of time really
21 combing back over that mid 1980s work, because a lot
22 of it was relevant, and trying to see if we could
23 refresh that in a way to come up with new insights
24 that we could apply at the time to this TBS rule. So,
25 we looked at a lot of past work, and then we did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 analyses on three particular things.

2 We looked at the likelihood of unflawed
3 piping failure, flawed piping failure, and then
4 indirect piping failure. Indirect failure is a
5 failure of another component that then leads to a
6 failure of a passive system pipe. So, it could be a
7 failure of component support. Component support
8 fails, and then you get higher loads in the piping
9 system, cause the piping system to fail, it could be
10 a failure of snubber. It could be a failure of a
11 secondary system that causes a missile.

12 All of these things are considered
13 indirect failures. I'm not going to talk about
14 unflawed piping failures, because 1903 said it's
15 almost impossible to fail unflawed piping systems even
16 under rare seismic events. And there's a lot of basis
17 for that, both in operating experience, as well as
18 experimental work, and analyses.

19 And Fukushima, which hadn't happened at
20 the time, was another good sort of operating data
21 point which showed that the passive system components,
22 due to both the tsunami, and the seismic event,
23 performed flawlessly. And that's been typically the
24 operating experience that we've seen. It's the pipes
25 themselves are usually quite robust if they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 unflawed.

2 So, we were focusing on things that hadn't
3 been looked at as much, and that's the likelihood of
4 failure if you've got flawed or degraded components,
5 and then indirect piping failure. And we use a mix of
6 --it was largely a deterministic analyses, but we had
7 some probabilistic insights that we applied as well,
8 as part of the analysis.

9 Next slide please. So, we looked at
10 direct piping failure, and we were focusing on these
11 rare seismic events. And again, I think I said this
12 already, but we were focusing on systems with
13 diameters that were greater than the TBS. So, this
14 would be like the hot leg, cold leg, cross over leg in
15 PWRs.

16 One point, 1903 really only looks at PWRs,
17 because that was the only set of plants that we really
18 had good design and operating information on. We based
19 a lot of the information in the design that we used on
20 leak before break submittals, and information that had
21 been provided there. So, as I think someone mentioned
22 earlier, there's been no BWR that's been approved for
23 leak before break.

24 So, we didn't have the same wealth of
25 information to really do a BWR study. However,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there's certainly a recognition, and an understanding
2 that even though 1903 was focused on PWRs, a lot of
3 the same insights and results should directly apply to
4 BWRs as well. At the time we used the most recent
5 seismic hazard curves for plants east of the rocky
6 mountains.

7 Now, since those curves have since been
8 modified significantly as a result of efforts that
9 were ongoing even at that time, but then certainly
10 spurred further by the Fukushima Event, and we looked
11 at developing -- again, we were considering very rare
12 events. So, we were looking at developing seismic
13 stresses for the ten to the minus fifth, and ten to
14 the minus sixth per year seismic event.

15 And we did that through a very, I'll say
16 robust, and detailed scaling method to take SSE
17 stresses and scale them up to these more rare event
18 earthquake stresses. And even though we used the
19 scaling approach, it was intended to be a best
20 estimate scaling approach, and not overly
21 conservative.

22 But again, we talked about this earlier,
23 with any sort of scaling approach you are going to
24 have some uncertainties and biases, so I would argue
25 the scaling approach probably skews a little bit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 conservatively, even though we tried to be best
2 estimate. And then the same thing with indirect
3 piping failures, we tried to analyze, or we did
4 analyze indirect piping failures under rare seismic
5 events.

6 But we really only looked at a couple of
7 different scenarios, and we were really focusing on
8 large component support failures that may lead to
9 piping failures, and there was a crude assumption that
10 if you had the support failure, then you would
11 ultimately have a conditional rupture frequency of the
12 pipe of one, so a very conservative, crude assumption
13 there.

14 And we really relied heavily on these
15 prior Lawrence Livermore study results, which we just
16 updated using, at the time was new hazard and ground
17 motion information that wasn't available in the mid
18 80s, and we developed a mean failure probability of
19 components. Next slide please. So, you can boil down
20 all of the direct piping analyses into this one slide,
21 and there were a number of similar slides.

22 But this shows we looked at 26 PWRs that
23 we analyzed, so each of these data points, and you
24 can't quite see all of them, but each of those data
25 points is a plant specific evaluation. We looked at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a couple of different materials. The yellow curve
2 considers an austenitic pipe and weld, and the purple
3 results are ferritic pipe and weld.

4 And these look at the likelihood of
5 failure or rupture due to a very long surface flaw.
6 And by very long, a flaw that would be about 80
7 percent of the entire circumference of the pipe. So,
8 very long surface flaw under a very long seismic
9 event. So, the loading here, these were scaled
10 loadings up to what was expected to be a seismic event
11 with a ten to the minus six per year return frequency.

12 So, you can see the spread there, the
13 spread there is related to largely the seismic
14 stresses that would be applicable for that particular
15 plant. The main thing that you see is even though
16 this wasn't intended to be a bounding analysis in any
17 way, but what you do see is that for the -- even
18 though we looked -- other than the fact that we used
19 very large flaws.

20 That even when you consider these very
21 large flaws, you still need a relatively deep critical
22 flaw depth before you get rupture, even under these
23 very seismic loads. So, I'm sorry I neglected -- the
24 scale on the right is the critical flaw size, flaw
25 depth, nominalized by the piping thickness. So, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is the flaw depth at which failure was predicted in
2 the modeling that we did.

3 So, as long as you are below, or to the
4 left of those curves, you would predict that you would
5 survive the event. If you were on or above the
6 curves, you would predict that you failed that
7 particular event. So, even in the limit, the highest
8 seismic stress is up to about 35 KSI for these very
9 long surface flaws using an austenitic stainless steel
10 weld, you would predict that you would need about a
11 flaw depth of 30 percent through the thickness before
12 you would get a rupture.

13 Next slide. Now, for indirect piping
14 failures, we only looked at a couple of case studies.
15 So, again, I mentioned we did 26 PWR case studies for
16 the direct piping failure analysis, we only did two
17 plants for the evaluation, it was very limited just
18 because we didn't have a lot of information. And we
19 also recognize that the indirect piping failures are
20 -- I mean all these things are plant specific, but
21 those are incredibly plant specific.

22 So, we just didn't have the bandwidth,
23 scope, or really direction to do something that was
24 more inclusive, and generic. So, we looked at Calvert
25 Cliffs, which is the CE plant, and then we looked at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a Westinghouse plant, those are the only two plants
2 that we did. And I indicated that all we did is we
3 used the conditional failure probabilities that were
4 developed in the Lawrence Livermore study.

5 And then we just updated those based on
6 the update of the seismic hazard curve analysis
7 associated with those plants. So, you can see I just
8 showed the Calvert Cliff results, and the Calvert
9 Cliff results are also presented in the table, which
10 were extracted from the Lawrence Livermore study. You
11 can see we got a small bump due to the fact that the
12 seismicity increased.

13 But still, the mean results from the two
14 plants that we looked at were still -- the likelihood
15 of indirect piping failure due to failure of component
16 supports during a seismic event was still a mean
17 result on the order of ten to the minus six. But
18 again, it was a recognition, and you could see there
19 at least in some of the results that you get a fairly
20 good spread for specific plants in terms of what their
21 mean failure frequencies would be expected to be.

22 Based on again, a plant specific analysis
23 for each of the plants that are listed. Next slide.

24 So, a brief summary of 1903. The thing
25 that they found, and I mentioned this for unflawed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 piping, the failure frequency is much, much lower than
2 ten to the minus fifth per year. So, well below the
3 initial acceptance criteria that was used to define
4 the TBS. For flawed pipings, critical flaws, or long,
5 circumferential flaws are generally large, as much as
6 30 to 40 percent of the wall thickness depending on
7 what type of event you're looking at.

8 And the expectation was conditional
9 probability of breaks larger than the TBS should also
10 be less than this acceptance criteria that we used as
11 the starting point for developing the TBS. Although
12 having said that, we did not do a generic analysis, or
13 we didn't do a bounding analysis to determine that
14 this was always the case for every plant.

15 Hence you're going to hear about in the
16 January meeting, some plant specific applicability
17 work that needs to be done to make sure that these
18 particular conclusions hold for each particular plant.
19 And I see Dennis has got his hand up.

20 DR. BLEY: Yeah, once again. Is the
21 likelihood of a long flaw 80 percent of the way around
22 a pipe factored into this? That seems an incredibly
23 large, long flaw.

24 MR. TREGONING: Yeah, you're right, that
25 was a predefined assumption as part of the analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We did not estimate and factor in the likelihood of
2 having such a flaw. So, they were purely
3 deterministic from that perspective.

4 DR. BLEY: Okay.

5 MEMBER KIRCHNER: I was going to ask the
6 same question as Dennis. What would be the
7 probability of such a flaw being undetected?

8 MR. TREGONING: Well, we have this
9 discussion internally all the time --

10 MEMBER KIRCHNER: Based on inspection
11 regimes --

12 MR. TREGONING: Yeah, we have this
13 discussion all the time. And so, you'll get my
14 opinion here, Dave will probably jump out of his seat
15 because he won't agree with it. But I would say it's
16 on the order of ten to the minus two to ten to the
17 minus three, probably something like that based on
18 operating experience.

19 But I don't really want to go much beyond
20 that. So, Dave, you want to correct me and say how
21 incredibly high I am?

22 MR. RUDLAND: This is Dave Rudland, yeah,
23 I think it's extremely low, lower than that. A lot of
24 our work that we've done over the last ten or 15 years
25 on PWSCC, it really kind of demonstrates that these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 flaws will grow through the thickness and leak well
2 before they get to be 80 percent around the
3 circumference, and 40 percent deep unless they're a
4 small diameter, heavy wall pipe.

5 In that particular case you may get cracks
6 that are very long around the circumference, and
7 relatively deep. But for the large diameter pipes
8 that we're talking about, I'd have to say -- I'd have
9 to guess one order or two orders of magnitude lower
10 than what Rob estimated.

11 DR. BLEY: If Rob were correct, we would
12 have seen some of these, right?

13 MR. TREGONING: We have seen large flaws
14 in large pipes, we have.

15 DR. BLEY: Approaching that size?

16 MR. RUDLAND: Maybe not as big as that,
17 but we have seen relatively long, and maybe not as
18 deep flaws. Recent operational experience in the
19 French safety injection system showed very long but
20 shallow flaws. So, the propensity for long flaws is
21 there, but we have not -- in the U.S. especially have
22 not seen very many.

23 MR. TREGONING: And Dave is right, it is
24 the bigger the pipe, the more unlikely you are to get
25 such flaws, because it's more likely that you'll get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a leak before break, but it's highly dependent on the
2 weld residual stress distribution. And we've looked
3 at a lot of residual stress distributions over the
4 years, so we have a pretty good handle.

5 But I'm not confident that we've looked at
6 the entire population of weld residual stress
7 distributions that re really out there in the fleet.
8 And then if you have repair welds on top of that, that
9 can really skew what your weld residual stress
10 distribution is. So, we've got a lot of work, and I
11 feel like Dave has a very good basis for his
12 statement.

13 I'm a little bit more of a cynic than Dave
14 when it comes to the particular likelihood of these
15 flaws, given that I recognize that there's a
16 population of weld residual stresses in repair welds
17 that we just have epistemic uncertainty as to what
18 that true distribution looks like.

19 DR. BLEY: Well, Dave suggested it would
20 be higher for thick walled, small diameter pipe, where
21 do we have pipe like that?

22 MR. RUDLAND: We've done numerical
23 analyses that suggest that depending again, like Rob
24 said, on the residual stress, that you can get growth
25 around the circumference relatively quickly, because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a lot of these residual stress behaviors are kind of
2 sinusoidal, where they go into compression on the back
3 half of the wall, right?

4 So, it slows it down as it's growing
5 through the wall, but continues to grow relatively
6 fast on the inside surface.

7 DR. BLEY: Okay, thanks.

8 CHAIR BALLINGER: This analysis, and when
9 we get to Dave's -- the white paper, all of these
10 large diameter pipes in the U.S., with the exception
11 of maybe two have been mitigated.

12 MR. RUDLAND: It's a similar amount of
13 welds.

14 CHAIR BALLINGER: Yeah, the similar amount
15 of welds have all been mitigated. So, the failure
16 probability of those by, I think your own words, is
17 zero.

18 MR. RUDLAND: Yeah, it goes down extremely
19 --

20 CHAIR BALLINGER: It goes down extremely
21 --

22 MR. RUDLAND: I would never use zero when
23 I talk about a failure probability.

24 CHAIR BALLINGER: Okay, but there are
25 several --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: There are several places in
2 the plants where they're not eradicated, they're
3 managing it by inspection.

4 CHAIR BALLINGER: So, I'll ask the same
5 question with the white paper, you said the
6 elicitation still holds in spite of the fact that
7 we've done a lot by way of mitigation, inspections,
8 and everything. So, I was a little surprised --

9 MR. RUDLAND: Just wait until my
10 presentation.

11 CHAIR BALLINGER: Yeah.

12 MR. TREGONING: But recognize again, all
13 these things were happening, Ron, during the
14 elicitation, and we did not only current day
15 estimates, but future estimates. So, the future
16 estimates, all the experts agreed that we would have
17 that issue mitigated by the time we got out to 40
18 years, if not before that. So, in some ways that was
19 built into the responses. There was an expectation
20 that those were going to be mitigated.

21 CHAIR BALLINGER: And yet they still found
22 the same numbers.

23 MR. TREGONING: There is a trend versus
24 operating experience, not as much as you might think.

25 CHAIR BALLINGER: Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. TREGONING: But again, you've got
2 competing trends here. So, the expectation was PWSCC
3 is going to decrease over the next 15 years, but
4 you've still got aging that's going on. So, there's
5 other mechanisms at play here other than just PWSCC
6 and the welds that you've mitigated. Like Dave said,
7 you've got other welds in other systems that you
8 haven't mitigated.

9 MR. RUDLAND: And degradation that we just
10 don't know of quite yet.

11 MR. TREGONING: Correct.

12 CHAIR BALLINGER: Life is 100 percent
13 fatal.

14 MR. TREGONING: Okay, I think I'm --

15 CHAIR BALLINGER: One more slide, maybe?

16 MR. TREGONING: Yes.

17 MEMBER BIER: I have one question before
18 we move on, Vicki Bier again. It's not really
19 pertaining to this particular slide, but just in
20 general. You mentioned you wanted to have results
21 that would be kind of relatively stable to maximize
22 regulatory certainty. And I understand not wanting to
23 have things that would change by plant status, or
24 minor fluctuations, or whatever.

25 But I assume that this would all be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 revisited if there was some new phenomenon we found
2 out about, or some averse experience somewhere in the
3 world that caused us to rethink this.

4 MR. TREGONING: Yeah, that's a great
5 question, Dave is going to talk about that a little
6 bit more, and then we'll -- we'll talk about it, yes.

7 MR. RUDLAND: So, there was some
8 commission direction at the time in 2008, that at the
9 time the commission had asked the staff to reevaluate
10 this on a ten year basis because of evolving
11 technologies, because of evolving mitigations, and
12 things like that, to continually look at that as the
13 plants age.

14 MR. TREGONING: So, yes. So, there is --
15 the staff is planning to do this exercise
16 periodically, and especially if it's triggered by some
17 sort of operating experience event.

18 MEMBER BIER: Okay, thank you.

19 MR. TREGONING: All right, I think I have
20 one more slide. So, just in summary, we developed
21 passive system LOCA frequencies for Bs and PWR plants
22 using 1829, using an expert elicitation process. And
23 then TBS was increased to address additional factors,
24 and to promote regulatory stability, and then we
25 performed this confirmatory study that determined if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the risks of LOCA greater than the TBS due to rare
2 seismic events were acceptable.

3 Which, 1903 certainly found out, certainly
4 confirmed those events. So, that was the basis again,
5 up to 20 some odd years ago that was again, reported
6 ultimately in 2008 with the release of 1809 and 1903
7 reports. Dave is going to talk about what we've --
8 and I'm keying Dave up for after lunch, I'm assuming
9 we're going to break and go with Dave after lunch.

10 But he is going to talk about what we did
11 to reaffirm the continued applicability and viability
12 of that technical basis work. Because a lot has
13 happened in the ensuing 15 years or so since that work
14 has been published. So, we recognized when we got
15 this challenge, we couldn't just take off, and blow
16 off the dust on this technical basis without
17 evaluating if things had changed either favorably or
18 negatively.

19 And how we needed to account for those
20 changes both within the rule itself, as well as in the
21 guidance associated with the rule. So, we're not
22 going to talk about the guidance so much today, we're
23 going to talk about that in January. But Dave will
24 talk about some aspects that we used to factor in to
25 changes in the 50 46A rule compared to what the rule

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 looked like in 2010 time frame.

2 Although recognize that 2010 rule is the
3 basis, so there's a lot of similarities between the
4 current rule and what was originally developed in
5 2010. And that was all I had, I don't know if there's
6 other questions.

7 CHAIR BALLINGER: Questions among the
8 members and consultants? Okay, well you've got points
9 for finishing this whole thing in seven months, but
10 you get negative points for finishing 15 minutes
11 early.

12 MR. TREGONING: That's negative points?

13 CHAIR BALLINGER: Yeah. We have to go
14 until lunch. So, we're at the right point to take a
15 break, and so I would propose that we recess for lunch
16 until 1:00 p.m.

17 (Whereupon, the above-entitled matter went
18 off the record at 11:46 a.m. and resumed at 1:00 p.m.)

19 CHAIR BALLINGER: Okay, it's 1:00 o'clock,
20 we're back in session, and I think Dave Rudland is on
21 for the afternoon, or for however long it takes.

22 MR. RUDLAND: Okay, thanks, Ron. Yeah, my
23 name is Dave Rudland, I am a senior technical advisor
24 for materials in the Division of New and Renewed
25 Licenses at NRR, and I'm going to talk about the work

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that was done recently to look at the continued
2 adequacy of transition break size. As Rob Tregoning
3 talked about before lunch, the original effort to
4 develop the basis for the transition break size was
5 very comprehensive, very complex, took three plus
6 years to do.

7 And when we decided to move forward with
8 an alternative to address FFRD, one of the reasons why
9 we chose this path was to try to leverage as much work
10 as we could that was done earlier. The hope was to be
11 able to take the basis, and just use that, and write
12 the rule that way. But we knew it had been almost 20
13 years since the release of that proposed rule back in
14 the 2008 time frame.

15 And that we needed to take a look at
16 whether or not the basis was still valid. We've
17 talked several times about the time frames that we
18 were under. So, we didn't have an exorbitant amount
19 of time to really go into the nitty gritty details,
20 and confirm every little thing about the basis that
21 rob talked about earlier.

22 But we wanted to take as comprehensive of
23 approach as we could. Next slide. And so, we looked
24 at both the 1829 LOCA frequencies, and the NUREG 1903
25 results, and we wanted to confirm both of those, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 then take a look at whether or not the thoughts that
2 we had, or the changes that we thought might be would
3 impact the transition break size.

4 So, we took both a qualitative and
5 quantitative look at the basis. Qualitatively we
6 conducted a very similar, but much smaller scoped
7 internal and external elicitation, and I'll go over
8 these details in a few slides. We then looked at the
9 impact of recent operational experience, and this is
10 experience not just from our fleet, but also from the
11 international fleet, and lessons learned from the
12 internal and external elicitation.

13 We then also looked at some quantitative
14 views. We did a probabilistic fracture mechanic
15 study, not again to develop LOCA frequencies, but to
16 try to confirm some of the frequency estimates that
17 were made in NUREG 1829. We then also did an
18 international operation database study where we took,
19 and made a Bayesian update to the LOCA frequencies
20 based on the operational experience that occurred
21 between the 2004 time frame and the 2024 time frame.

22 All of this information is documented in
23 a white paper, and the ADAMS session number is there
24 for that white paper. I should point out that in
25 addition to that white paper, there are two technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reports that accompany that. One on the details of
2 the probabilistic fracture mechanic study, and the
3 operational database study, and one on the internal
4 and external elicitation.

5 CHAIR BALLINGER: Do we have those?

6 MR. RUDLAND: They are referenced in the
7 white paper. They're publicly available, and in the
8 white paper. Next slide. All right, I'm going to
9 start with the internal and external elicitation. As
10 Rob pointed out, 1829 was based on a formal expert
11 elicitation. They had done a pilot elicitation with
12 the internal staff, and then they had an external
13 elicitation that was based on lessons learned from the
14 internal pilot, and consisted of a dozen or so
15 external experts with a wide variety of technical
16 expertise.

17 The process that we chose for this mimics
18 that process to really evaluate the completeness, and
19 continued viability of both the 1829 and the 1903
20 results. Our goal in the internal and external
21 elicitation was not to develop LOCA frequencies,
22 again, but to identify any scenarios that maybe were
23 not considered, that were new, novel, or that were
24 underestimated in NUREG 1829 and 1903 efforts in the
25 early 2000s.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And also it was to look at the likelihood
2 and or technical rule making gaps associated with each
3 of those scenarios. Okay, next slide, thanks. So,
4 this is the approach, and again, it follows the
5 approach that Rob talked about earlier. We had to
6 first select an appropriate panelist internally, and
7 again, our elicitation in this effort focused more on
8 staff, and less on the external.

9 Mainly because again, of the time frame
10 that we had, it would have been very difficult for us
11 to put contracts in place to get the expert people to
12 participate in the time frame that we had. So, we
13 focused a lot on the internal experts within the
14 agency. We had 13 senior staff, and again, we chose
15 those staff members with collective expertise across
16 all of the relevant areas.

17 Externally we actually had two of the
18 original panelists that we were able to question that
19 had complementary expertise pertaining to these types
20 of systems. So, that's how our breakdown was in this
21 particular case. Then we formulated an initial set of
22 questions and topics focusing mainly on information
23 and data, and experience since the early to mid 2000s.

24 Again, as with the original elicitation,
25 they wanted to consider direct, indirect, and common

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cause failure scenarios, and identify any important
2 quality factors. In both cases, the internal and
3 external, we had all the kick off meetings where we
4 talked about the objectives, backgrounds motivations,
5 discussed and clarified topics, questions, and
6 identifying any initial considerations.

7 We then allowed the panelists to go off on
8 their own and develop independent responses. Again,
9 we weren't looking for, in this particular case, any
10 kind of quantitative numbers, just more scenarios
11 where the assumptions that we made in 1829 or 1903 may
12 have been impacted, or anything that may impact the
13 failure frequencies for those pipes that are greater
14 than the TBS.

15 After they submitted their responses, we
16 had follow on meetings to talk about the individual
17 responses, and determine path forwards for each of the
18 open issues. I believe there's a hand up, I couldn't
19 tell who.

20 MEMBER KIRCHNER: Dave, this is Walt
21 Kirchner, good afternoon.

22 MR. RUDLAND: Hi.

23 MEMBER KIRCHNER: How many of your 13
24 senior staff were what I would call repeats from your
25 original panels?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: I don't even know, was there
2 one? Yeah, so Rob says there was one.

3 MEMBER KIRCHNER: Good, okay, thank you.

4 MR. RUDLAND: Maybe two, yeah. So, again,
5 there's not a lot of folks that were here at the
6 agency that were there in 2008, or even before that.
7 I think Rob was here. In fact I joined the agency in
8 2008, but I was working prior for a contractor who was
9 one of the original panelists. So, I was heavily
10 involved in his input, but not directly involved in
11 the development of 1829.

12 So, not much, but the two external
13 panelists were two of the original panelists from
14 1829. Okay, next slide. So, from the internal
15 elicitation response, there were actually 21 scenarios
16 identified, and those scenarios were a range of
17 different issues. We've binned these here in
18 different categories.

19 The first bin is those that were addressed
20 through the applicability studies, and that is how a
21 plant specific issue that may need to be addressed to
22 demonstrate that they're applicable to use this
23 transition break size. Some of those topics included
24 embrittlement, SCC, and as such. We had a group of
25 scenarios that we felt were addressed through the rule

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 making itself, the proposed rule that we wrote.

2 Motivation for future plant changes, PRA,
3 margins, uncertainties, things like that we were able
4 to address within the rule making itself. And then
5 those things that are addressed within the current
6 regulations, and some of that was through all that
7 frequency, water chemistry, and degraded grid
8 stability, and things like that that are already
9 handled.

10 I'm going to be talking a little bit more
11 about the first two topics later in the presentation.
12 To give an example -- next slide, I'm sorry. To give
13 some examples of some of the topics, I've shown two
14 here, the first is treatment of leak before break
15 piping. And the concern, and the issue was are you
16 giving consideration for plants that have LBB
17 approvals over those that don't have LBB approval.

18 And through our discussions, the
19 disposition for that was that really no explicit
20 special treatment was given to those plants in the
21 rule itself, but we felt that any individual licensee
22 may be able to leverage their LBB approval as part of
23 the plant specific applicability. And again, a lot of
24 that particular thing, and how they would do that will
25 be in the regulator guide for plant specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 applicability, which we'll discuss in January.

2 The other is the potential for degrading
3 grid stability, and this is would you have a higher
4 risk if the loss of off site power is now evaluated
5 with the LOCA analyses. And if you move the LOCA
6 analyses to be an on site basis that may be the case,
7 and the staff felt that the loop frequencies really
8 don't indicate an increasing trend in those events.

9 PRA still needs to consider the risk
10 associated with that, and many plants currently employ
11 load monitoring software to predict that type of
12 unavailability. All of these different scenarios, or
13 dispositions in a similar way, and that's all
14 documented in our elicitation report summarized in the
15 white paper I talked about.

16 Okay, let's go to the next slide. Okay,
17 so, just to provide a quick summary of what the
18 external elicitation was, we asked the two panel
19 members what their thoughts were on frequency of
20 breaks that were less than the TBS, and frequency of
21 breaks that were greater than the TBS. For those that
22 were less than the TBS, kind of had a split view.

23 One panelist thought that the frequency of
24 breaks are representative that are lower than the TBS,
25 and one panelist thought they were still conservative.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 For the breaks greater than the TBS, both panelists
2 agreed that the TBS is conservative, or the frequency
3 of breaks is conservative relative to the TBS. And
4 those opinions were based on mitigation practices, and
5 increased knowledge as we've changed the procedures
6 and the rules from the early 2000s to the 2024 time
7 frame.

8 So, they really felt that the historical
9 TBS remains viable, and this is the value that Rob
10 talked about earlier. We did ask them again, what
11 possible scenarios may lead to breaks greater than the
12 TBS, and one panelist felt there was really, at this
13 point, no credible scenario where that may happen.
14 The other panelist was concerned a bit about some
15 aging effects, especially those that affect the
16 fracture toughness, like thermal aging, or residual
17 stress effects that are difficult to quantify.

18 They were also concerned again, about
19 long, shallow surface flaws in these low toughness
20 materials, and a propensity for causing a rupture.
21 But the panelists agreed that the likelihood of those
22 is strongly plant specific. I think Dennis.

23 DR. BLEY: Yeah, David, it's Dennis Bley.
24 On that first one, the frequency breaks less than the
25 TBS are representative or conservative, were your two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 panelists really far apart on this, or they're about
2 right in maybe they're a little conservative?

3 MR. RUDLAND: I think they were relatively
4 close. I think where the biggest differences were was
5 on whether or not there would be anything that could
6 possibly -- any credible scenario that could possibly
7 cause a break I those bigger than the TBS, right? But
8 this is frequency of a break less than TBS, I think
9 they were pretty close on those results.

10 DR. BLEY: Okay, thanks. And just a quick
11 question --

12 MR. RUDLAND: I think Rob wants to make a
13 comment.

14 MR. TREGONING: Yeah, Dennis, just to be
15 clear, we asked them to compare their results from 20
16 years ago with if they had to give similar results,
17 would those results increase, decrease, or remain the
18 same. So, when Dave talks about them being
19 representative of conservative, they're pertaining to
20 their own individual results that they brought almost
21 20 years ago.

22 DR. BLEY: Okay, thanks. And did you use
23 the same process this time around of sharing
24 information and seeing if they wanted to change their
25 minds?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. TREGONING: Yeah, everything was
2 accelerated this time, so we did everything
3 collectively.

4 DR. BLEY: Okay.

5 MR. TREGONING: These are all collective
6 discussions.

7 MR. RUDLAND: Again, our time frames did
8 not allow a lot of the details that occurred in the
9 original elicitation. Okay, let's move to the next
10 slide. So, some of the dispositions that we talked
11 about, of course, was continued research and
12 monitoring. We've been spending a lot of time talking
13 about the thermal aging for austenitic welds, and cast
14 materials, and I'll talk about that again in a little
15 bit.

16 The group agreed that harvesting is
17 important to be able to continue to look at those
18 things, to extend aging studies, to look at particular
19 properties at the end of the license renewal period,
20 and to continue to monitor the U.S. international
21 operational experience, and not just for SCC cracking,
22 but for any type of active degradation that could lead
23 to these long surface cracks, especially for large
24 diameter piping.

25 We thought it was very important even that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the output of the external elicitation to make sure
2 that we have plant specific applicability
3 demonstration for the TBS. So, as Joey will talk
4 about later, you'll see in the rule it requires that
5 they have to demonstrate plant specific effects, do
6 not invalidate the TBS before implementing the rule.

7 And like I mentioned just a little bit
8 ago, there is additional guidance that we'll talk
9 about in January in DG-1428, it provides methods to
10 demonstrate plant specific applicability, and gives
11 options for the plants to be able to find different
12 ways to demonstrate plant specific applicability.
13 Okay, let's go to the next slide.

14 All right, so from the expert elicitation,
15 we wanted to take another qualitative look at some of
16 the more recent operational experience, and what we
17 did in terms of selecting what we were going to look
18 at was really based on our staff's experience with the
19 operating experience that happened in the U.S.

20 The input that we got from the
21 elicitation, both the internal elicitation and the
22 external elicitation about operational experience and
23 things to consider, as well as our knowledge of the
24 international events that had occurred, and the
25 disposition of those. And so, we chose these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 categories, and I'll go through each one of these in
2 detail about what we looked at, and how we
3 dispositioned that, and if there were any impacts that
4 we thought needed to be taken care of as part of this
5 rule.

6 Okay, let's go to the next slide. The
7 first few are focused on piping, and so the first one
8 is thermal embrittlement, I talked about it a little
9 bit already. The issue really is a decrease in
10 fracture toughness, not only for cast, but also for
11 austenitic stainless steel welds that could impact the
12 failure frequencies.

13 The staff looked at a variety of
14 experimental testing that was done, developing of
15 aging management programs, which was not, at the time
16 that the original 5046A rule was written, there were
17 not many plants that had applied for license renewal,
18 so the plants didn't have aging management programs.
19 So, we know of the aging management programs.

20 These particular materials have lack of
21 active degradation, and there's ongoing inspections
22 that occur. So, staff felt qualitatively there's
23 really no safety concern with thermal embrittlement.
24 Anything that would occur would be found through the
25 normal inspection programs. Stress corrosion cracking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of stainless steels in PWRs, I think we're all aware
2 that there had been cracks that were identified in
3 safety injection, and RHR lines, and the stainless
4 steel welds in the French fleet, the French PWRs.

5 That was kind of an unexpected stress
6 corrosion cracking, and it could occur in the U.S.,
7 and may impact the failure frequencies. I think we've
8 talked to the ACRS about this effort in the past, but
9 the staff conducted a risk informed analysis using the
10 LIC-504 process to go through those, and calculate
11 whether or not there was a safety impact.

12 The industry also did a very parallel
13 effort on that, and so the staff, between those two,
14 felt that there was a reasonable sureness of
15 integrity, that if those flaws did exist in the piping
16 in the U.S., there would be no safety impacts. A lot
17 of the stuff, especially these ones that I say have
18 LIC-504s attached with them are all in the public
19 domain also, and are referenced within this white
20 paper that I talked about earlier. Okay, let's go to
21 the next one.

22 MEMBER KIRCHNER: Dave?

23 MR. RUDLAND: I'm sorry, yes.

24 MEMBER KIRCHNER: This is Walt Kirchner
25 again, sorry to interrupt you. Could you go back to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the last slide? And give us -- it's nice to know that
2 you did a risk informed analysis, but could you give
3 us the physical reasons why what happened in the
4 French fleet is not expected to happen in the U.S.
5 fleet, based on physics?

6 MR. RUDLAND: Okay, so the cause of the
7 French cracking is still under question. They -- even
8 if it has not released their root cause analysis.
9 However, staff feel that it's probably two different
10 reasons why it occurred. The French plants were
11 modified Westinghouse designs. So, they took the
12 Westinghouse design, and Framatome modified for the
13 dose requirements and such in the French regulations.

14 And in that they changed these systems,
15 and made the pipe different such that they had much
16 higher thermal stratification loading at the locations
17 where the cracks occurred. Those particular loads
18 aren't typical, or at all in the U.S. plants at
19 similar locations. So, that's one of the ideas why
20 that cracking occurred, and it wouldn't have occurred
21 in the U.S.

22 The second is the residual stress, a lot
23 of the welds that we looked at that were sectioned had
24 very large root welds, and because of that you end up
25 with a very high tensile residual stress on the ID

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 surface, and most of the cracks that occurred were
2 very long, but very shallow. And that was mainly
3 driven by the fact that the residual stressors were
4 all in that main root B weld basically.

5 So, they didn't grow beyond the root B.
6 And it was a very unusual welding practice, typically
7 you don't have those kind of large weld beads, because
8 you need a lot of heat input to do that, and you kind
9 of -- there's too many weld qualification issues to
10 cause you to have those types of welds. So, it's
11 expected that many of those types of welds would not
12 occur in the U.S. fleet.

13 In addition, we have done -- we went back
14 and looked through all of the past inspection records
15 for these welds in the U.S., and the industry has
16 implemented a change to the inspection procedure for
17 these welds, in that they now require that they look
18 for SCC, because originally these welds were only
19 susceptible to thermal fatigue, so they were only
20 looking for fatigue cracks, and the MDE is different.

21 So, they changed the requirement that they
22 would have to use an SCC qualified process to look at
23 these, and for those that have so far, there has been
24 no indications found. Does that help?

25 MEMBER KIRCHNER: Yes, thank you very

1 much, that's much better than saying it was risk
2 informed.

3 MR. RUDLAND: Yeah, we went through all of
4 that in that risk informed analysis. I'll just point
5 out that gain, in that case we leveraged probabilistic
6 fracture mechanics also to try and make an estimate of
7 what the initiating event frequency would be for a
8 LOCA of that size that we then rolled into the PRA,
9 that's why we called it risk informed.

10 MEMBER KIRCHNER: Well, since you offered
11 that, then it begs the question, did you use the
12 probabilistic fracture mechanics, and estimate how the
13 French designs would perform?

14 MR. RUDLAND: We did not, no, we did not.

15 MEMBER KIRCHNER: Okay, so the
16 probabilistic fracture mechanics analysis was just to
17 give you some level of confidence in addition to the
18 other physical design considerations.

19 MR. RUDLAND: Yeah, we were concerned for
20 the U.S. fleet, so we only did the analyses relative
21 to the designs and the loads of the U.S. fleet.

22 CHAIR BALLINGER: This is Ron Ballinger,
23 am I to understand that the French site also did a PFM
24 analysis?

25 MR. RUDLAND: I'm not sure if the French

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 did. I don't think the French -- the French aren't
2 really -- they're not proponents of probabilistic
3 analysis, so I know they did a lot of deterministic
4 work. EPRI also did safety --

5 CHAIR BALLINGER: I thought they had been
6 encouraged by that committee.

7 MR. RUDLAND: Yeah, EPRI also did a safety
8 analysis for this also. While they didn't use
9 probabilistic fracture mechanics, I don't believe,
10 they did leverage risk insights in making their
11 determination of safety.

12 MEMBER KIRCHNER: Ron, this is Walt again.
13 I might suggest for the future that if you have good
14 data from the French experience, that this would be a
15 good benchmark to try our probabilistic fracture
16 mechanics against. It would be interesting to see
17 what the results show.

18 MR. RUDLAND: Yeah, the French did a
19 pretty good job of documenting these flaws. So, they
20 have a good little database of what flaws were in
21 these pipes, what the distribution of lengths and
22 depths were, which would be extremely valuable I think
23 for running probabilistic fracture mechanics.

24 CHAIR BALLINGER: I think we have some of
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: We have all of that, yes, we
2 have all of that information. Okay, if there's
3 nothing else, I'll move on to the next slide. Okay,
4 the next issue was inspection frequency changes.
5 We've talked about this a little bit, but there are
6 ongoing efforts within ASME to optimize inspection
7 frequencies in developing less inspections for piping
8 and components.

9 In most cases for piping itself, risk
10 informed ISI is in place at all of the plants. So,
11 they have a focused inspection program on those higher
12 risk locations, but categories may change, the
13 inspection frequencies as more information is given,
14 and as the ASME decides to move forward. And so the
15 staff really feel that continuing inspections on these
16 welds, especially those welds that are in piping
17 greater than the TBS is essential to supporting the
18 basis for the transition break size.

19 I'll talk a little bit more about what
20 that means here in just a second. So, for all the
21 piping issues that I've talked about that the staff
22 considered, many of the issues were analyzed through
23 our LIC-504 process. Some were analyzed through
24 research or licensing action, or through the industry
25 efforts, and so we really don't believe there is much

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 impact on the piping frequencies from this.

2 But the staff really does -- did really
3 recommend that for this piping, where diameter is
4 greater than the TBS, that a ten percent sample of the
5 welds greater than TBS is needed for each interval.

6 CHAIR BALLINGER: But again, all of these
7 pipes, with maybe according to Craig one or two
8 exceptions, have been mitigated.

9 MR. RUDLAND: No, we're talking about the
10 pipe, the ones that are not mitigated. Yeah, we're
11 talking about stainless steel piping welds that are
12 not mitigated. The welds that we're talking about
13 currently are in a category of risk informed
14 inspection where they don't get much scrutiny, much
15 inspections, because they have no degradation, and
16 they have -- even though they're high risk pipes, they
17 have no known degradation.

18 So, they leverage the amount of
19 inspections based on that sensitivity. So, the ASME
20 process for doing these inspections allows you to
21 choose the welds that are going to be in your sample.
22 You do an inspection, and then every interval you
23 inspect the same sample of welds. In the rule, which
24 you'll see Joey will talk about later, we are allowing
25 the licensees to leverage their existing ISI programs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 however they can to try to meet this ten percent
2 sample.

3 MEMBER PETTI: So, how many welds is ten
4 percent, rough number?

5 MR. RUDLAND: Well, if we talk about all
6 of the welds, for instance in a PWR you're talking
7 about the hot leg, cold leg, crossover leg, and the
8 welds in between, so it can't be more than I would say
9 30 welds, 40 welds probably. We're talking about a
10 similar amount of welds in there. There's also the --
11 and the dissimilar metal welds also.

12 I would assume it's about the same in a
13 BWR. But again, this category of weld is in their
14 risk informed program, so they can modify their risk
15 informed program to make sure that the ten percent
16 requirement here is reflected in their ISI programs.
17 Okay, let's go to the next slide. So, there was a
18 minority review on this decision.

19 And it was very important that we talk
20 about this during the development. We had some
21 discussions about this, this was not an issue that was
22 -- that rose to the level of a non-concurrence, or a
23 DPO, but it was something that we thought was
24 important to document, and let the committee know that
25 we had these discussions, and that there were some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 staff that felt more was needed than what we have in
2 the rule right now.

3 The staff member that had this view was
4 really concerned about these SCC mechanisms that have
5 long surface flaws that can grow in low toughness
6 material, and they were worried that it impact leak
7 before break, that you could actually get break before
8 leak, and that we need to look at more than just ten
9 percent basically of the welds in this category.

10 But it's very Oplant specific, depending
11 on the plant itself. And so, what the staff person
12 wanted, was wanted to be able to not only inspect ten
13 percent, but as I mentioned, ASME allows you to
14 inspect the same sample every interval. He would have
15 preferred that a different sample be chosen every
16 interval, so that by the end of a 40 year life you
17 would have inspected all of the welds at least once in
18 that category.

19 And so, that was what they recommended.
20 The discussion of this is in the white paper, but I
21 think the staff in general thought that might be too
22 burdensome for the return that you got on that for
23 that additional requirement. Because realizing that
24 they have to have different -- that the industry has
25 to have different structures in place, whether it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 scaffolding, or whatever to inspect these things.

2 They'd have to have new equipment possibly
3 for each different interval as they move these
4 inspections around to different pipe welds.

5 MEMBER HALNON: Hey, John, this is Greg
6 Halnon, can you help me with this highly unlikely but
7 possible term up here? I mean, you can make that
8 argument for just about everything, but could you help
9 me with what that means from a practical perspective?

10 MR. RUDLAND: You're talking about the
11 likeliness of the SCC flaw?

12 MEMBER HALNON: Your first bullet there,
13 a LOCA greater than TBS highly unlikely, but possible.

14 MR. RUDLAND: So, again, I think that the
15 thought was that we have some evidence that you could
16 end up with very long surface flaws. And so, the
17 chances that you could end up with very long surface
18 flaws is real, but the chances of those really long
19 surface flaws leading to a LOCA is highly unlikely.

20 MEMBER HALNON: So, why can't we just stop
21 there? Why do we have to go but possible? Because
22 that to me just looks like it's someone worried about
23 it without any real empirical and or analytical data
24 that says that.

25 MR. RUDLAND: I think that was just the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 view of this particular staff member. I mean again,
2 it's based on, I'm sure, experience that we've seen.
3 Especially since we know we have seen kind of long
4 cracks like I mentioned earlier, in smaller diameter
5 pipes. That does not make it impossible that it would
6 happen in larger diameter pipes greater than the TBS.

7 MEMBER HALNON: Yeah, I lived through the
8 V.C. Summer, I know that's dissimilar, but after
9 looking at how bad that weld was, and how much crack
10 actually went through wall, I just don't see leak
11 before break not being real.

12 MR. RUDLAND: Let's -- the thing about the
13 V.C. Summer flaw that you're talking about is a little
14 bit different, that's an axial flaw, it's limited in
15 growth, length by the weld itself. There was a
16 circumferential flaw that occurred at that location,
17 but it was over near the cladding, and so it was
18 actually stopped by the carbon steel material.

19 So, it could not have grown deep, because
20 it grew into non-susceptible material. So, that's a
21 little bit different to talk about. There were some
22 cases, Wolf Creek had some very large surface cracks
23 found on their pressurizer surge nozzle back in the
24 early 2000s also, where we saw I think it was three
25 relatively large surface flaws in that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, it is possible that they could be
2 there, but I think it's less possible that they could
3 cause alarm.

4 MEMBER HALNON: Okay, we can move on, I
5 just wanted to make sure I understood where you were.

6 MEMBER PALMTAG: This is Scott Palmtag,
7 one of the things you said is this depends on the
8 plant, can you elaborate on that?

9 MR. RUDLAND: Sure. So, a lot of times
10 the cracking is very not just even plant specific, but
11 also weld specific. So, how these welds are made, if
12 they're repaired, and such like that is very specific
13 to that particular situation.

14 MEMBER PALMTAG: So, it's like the
15 chemical part of the weld, or the material part of the
16 weld.

17 MR. RUDLAND: It's the stresses that are
18 imparted due to the weld. So, if you have a weld
19 repair at a location, especially if it's on the ID,
20 you can end up with very large tensile stresses that
21 could drive these cracks.

22 MEMBER PALMTAG: Wouldn't you be more
23 susceptible to cracking once you have more sections on
24 that, rather than just rely on a ten percent?

25 MR. RUDLAND: Yes. And so, usually the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ten percent, which you'll see when we talk about the
2 rule, is focused on those that are the highest
3 susceptible welds. So, you have to choose a sample
4 that is representative of the ones that you expect to
5 crack first. So, look at the ones with the highest
6 stresses, maybe they have the highest cumulative
7 fatigue factors, and things like that to help them
8 decide which welds to inspect.

9 CHAIR BALLINGER: Is there any possibility
10 of a kind of a human factors issue here where a plant
11 decides to inspect X welds based on some criteria, and
12 one of those criteria being how much it costs to do
13 it, and that's certainly a piece of the decision. But
14 is there a possibility that by only inspecting the
15 same ten percent all the time that you run into a
16 problem where there was a weld that was chosen, for
17 lack of a better word, for human factors issues, cost,
18 that might have been actually more susceptible?

19 MR. RUDLAND: Yeah, that's always
20 possible.

21 CHAIR BALLINGER: So, I'm trying to take
22 the devil's advocate position here.

23 MR. RUDLAND: That's always possible, and
24 I believe that that was one of the rationales that the
25 staff member used in his basis, was that you don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know where those weld repairs may be, right? Because
2 they're not necessarily well documented in the fleet.
3 But again, I think the purpose of doing this ten
4 percent inspection, especially in a location where we
5 know there is no active degradation, is to protect
6 against anything that may occur.

7 And statistically, ten percent is good
8 enough for this population of flaws to be able to find
9 something, but it has to be systemic in nature, it has
10 to be something that is not just one weld off, it's
11 something that has to occur maybe in a couple of
12 different welds. But typically, like in the V.C.
13 Summer case, when you do have a really bad weld, they
14 typically tend to leak, because the driving force for
15 an axial flaw is greater than the driving force for
16 the circumferential flaw.

17 CHAIR BALLINGER: So, you don't think we
18 have anymore V.C. Summers out there?

19 MR. RUDLAND: I think there may be V.C.
20 Summers out there, but again, I think they're going to
21 be axial cracks, and not circumferential cracks, which
22 are the ones that will lead to LOCA. I don't know if
23 anybody else has any thoughts or comments, but let's
24 move on. All right, so the next few are going to be
25 talking about vessels.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, the non-piping things. The first two
2 that are on this screen are interacts from experience
3 that we considered also. The first one on the left is
4 carbon macrosegregation, so this was an issue that was
5 founded again, in a French EPR, it was actually in the
6 head in the Flamanville 3 unit. In 2015 it was
7 discovered that the upper head had high levels of
8 carbon that was due to the way that they manufactured
9 that head, through the forging process.

10 It resulted in a higher strength location,
11 very specific to the location in which the segregation
12 occurred, lower toughness. And the data suggested
13 that something that is segregated like this may be
14 more susceptible to embrittlement. So, back in that
15 time frame, the staff had done again, I'm going to use
16 the term risk informed analysis, but it included a lot
17 more than what those words say.

18 We did some work from the probabilistic
19 fracture mechanics standpoint, we did a lot of review
20 on what the industry was doing, we did a lot of review
21 on what the French were doing in terms of analyzing
22 this away. We also looked at how the forge that was
23 creating these components supplied the U.S. with their
24 upper heads, and looked at those particular individual
25 plants that may have gotten those heads from that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 particular forge.

2 At the end it was concluded that the
3 safety significance of that was negligible. Same with
4 the quasi-laminar indications, this happened in a
5 plant in Belgium. Ultrasonic inspections found a
6 whole variety of hydrogen flaking mid wall thickness
7 in one of the ring forgings in their RPV vessel. And
8 they were, again, they were parallel to the wall, and
9 subsurface, and almost all were axial, or slightly off
10 axial locations.

11 And how do those flaws impact integrity,
12 do they impact embrittlement? Things like that. So,
13 in this particular case the staff didn't really do any
14 probabilistic fracture mechanics, but we did do an
15 evaluation, we looked at what Electrabel, which was
16 the Belgian owner, what their analysis said. And we
17 did some finite element analyses, and some risk things
18 also included in there.

19 And really determined that it's not a
20 potential safety case for any plants that may be
21 affected by these hydrogen flakes. And again, both of
22 those analyses are referenced in the white paper, and
23 they go into a lot of detail in how those were
24 dispositioned. You're more than welcome to take a
25 read through if you have the time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Okay, the next slide. As with the piping
2 -- before we go into that there was two other items.
3 The one on the left was not really an operational
4 experience per se, it was actually something that was
5 discovered during a set of analyses that were being
6 conducted looking at ASME Appendix G, risk informing
7 Appendix G, which is the rules for calculating
8 pressure temperature limits.

9 Oak Ridge National Labs at the time, which
10 was a contractor for the NRC, suggested that a small
11 surface breaking flaw can produce a greater through
12 wall crack frequency than the assumed quarter T flaw
13 that was part of the Appendix G analysis. And this
14 particular small surface breaking flaw was just large
15 enough to penetrate the cladding of the vessel, or the
16 tip, which is an inch of the carbon steel.

17 And in those particular cases the through
18 wall crack frequencies were several order of
19 magnitudes larger than assuming a quarter T flaw. So,
20 that kicked off a very large effort across industry
21 and at the agency to really take a look at what was
22 going on here. It also involved folks at the ASME
23 code, and everybody kind of got involved in trying to
24 analyze this.

25 We did publish the fracture mechanics

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 studies, the industry did publish their fracture
2 mechanics studies to really understand what was going
3 on here. And what we found out was that even though
4 there was an increase in the conditional probability
5 of failure, the impact on the through wall crack
6 frequency really was minimal due to the fact that the
7 cool downs that we assumed were not very realistic
8 compared to actual plant cool downs.

9 And so when you considered the actual
10 plant cool down failure frequencies, and or the
11 idealized cool down frequencies, through wall crack
12 frequency was again shown to be low.

13 CHAIR BALLINGER: Now, would the P-T limit
14 curves have influence on the rate of cool downs
15 allowed?

16 MR. RUDLAND: The ASME code talks about
17 what the allowables are for the cool downs.

18 CHAIR BALLINGER: So it is built in?

19 MR. RUDLAND: Yeah, it is built in. And
20 the second one on this page on the right is the
21 embrittlement for the vessel. I talked to the
22 committee about this in the past, that the Reg Guide
23 199 embrittlement trend curve in some cases may under
24 predict embrittlement for high fluence. That coupled
25 with right now the way that the current embrittlement

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rules are written, licenses are allowed to defer
2 surveillance capsule testing.

3 That's intended to confirm that
4 embrittlement prediction from the ETC model. Those
5 combined, the staff again did a risk informed analysis
6 where we did probabilistic fracture mechanics, and
7 other types of analyses that suggested that there may
8 be a risk issue with the staff's confidence in the
9 integrity of the RPV for a certain subset of plants
10 for long term operation.

11 And so, the staff proposed a change to
12 those rules in SECY 22-0019, and we're still waiting
13 on commission decision on that.

14 CHAIR BALLINGER: I have it marked in my
15 docket, four to five years.

16 MR. RUDLAND: '22, now we're going on '25.

17 CHAIR BALLINGER: Okay.

18 MR. RUDLAND: Yeah, the original plan that
19 we had to the commission had us doing the reg basis,
20 and developing the rule, and publishing the final rule
21 in '27.

22 CHAIR BALLINGER: So, what is T zero, when
23 did the four to five years start?

24 MR. RUDLAND: Yeah, and again, the study
25 that we did kind of demonstrate that, the first plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 really wouldn't be impacted, and it was basically a
2 PTS issue for about ten years from the time that we
3 did the analysis in '22. So, it really won't reach
4 the fluence limit where there's an issue until maybe
5 '32 time frame. But we still need to write the rule.

6 CHAIR BALLINGER: We're getting a couple
7 of plants, one of them I'm sure is very old, that
8 they're thinking about restarting.

9 MR. RUDLAND: I understand.

10 CHAIR BALLINGER: That doesn't have any
11 influence on this fortified --

12 MR. RUDLAND: Not at this point, again, we
13 looked at all the plants --

14 CHAIR BALLINGER: They did a 61A.

15 MR. RUDLAND: Yeah, they did a 61A, that's
16 right. And we thought about that plant as we were
17 writing this -- doing this analysis, so it wasn't --
18 it's not going to be a concern until about, like I
19 said, about ten years. But the staff needs five years
20 to write a rule, and get a final rule published.

21 CHAIR BALLINGER: Well, we know it only
22 takes one year. We can only be heroic once.

23 MR. RUDLAND: To the manager sitting there.
24 So again, we're waiting on the commission decision,
25 but the staff is still concerned about this kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thing. Let's go to the next slide. And as with the
2 piping, we also have inspection frequency changes.
3 So, along with the piping work, the industry is moving
4 towards optimizing the inspections for a lot of the
5 large vessels.

6 Many licensees have come in through our
7 50.55a(z), which is our alternative process for code
8 requirements, and they've been granted approval to
9 modify their inspection programs for the reactor
10 pressure vessels, steam generator, and pressurizer,
11 shell to shell welds, nozzle to shell welds, and inner
12 radius inspections.

13 And the cumulative effects of those
14 relaxations, in addition to the relaxation that we're
15 talking about as part of this rule may have some
16 impact on the TBS, and so we needed to make sure that
17 we're okay with that. And the staff thought about
18 that a lot, and qualitatively yeah, I think the staff
19 is okay right now, that the appropriate amount of
20 performance monitoring is occurring in these
21 components, so there's not really a safety issue.

22 In each of the cases we've always -- each
23 of the cases where we've approved these relaxations
24 we've always tried to make sure that there was
25 sufficient performance monitoring to be able to verify

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that the analyses that were done remains valid, and
2 that if any novel degradation is found, it can still
3 be found through those performance monitoring
4 inspections.

5 So, what's the impact on the TBS? Again,
6 just like with the piping, some of the issues have
7 been analyzed through our 504 process, and are well
8 documented, and we did consider these cumulative
9 effects. The only thing that seems to be open at this
10 point is this embrittlement issue, and the staff will
11 take a look at that once the commission has taken
12 action on the rule making final.

13 CHAIR BALLINGER: But it's pretty clear,
14 the outcome on that rule is pretty straight forward.

15 MR. RUDLAND: I don't know what you mean
16 by straight forward, the commission has not acted, so
17 I don't know what --

18 CHAIR BALLINGER: The new ETS, the new
19 correlation, and the --

20 MR. RUDLAND: Yes, we know what we
21 proposed, our proposed action is relatively straight
22 forward. Okay, let's move on to the next slide. And
23 the last thing the staff looked at was secondary side
24 piping failures, and again as Rob pointed out earlier,
25 this is failures that may happen at piping that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 smaller than the TBS impacting and causing LOCAs in
2 piping greater than the TBS.

3 And it's definitely felt that current
4 regulations did a pretty good job of making sure that
5 that doesn't happen. GDC-4, and SRP 3.6.2 really
6 provide assurance that that's maintained. They have
7 to do certain things to make sure that those pipes
8 don't pipe whip, cause any issues in that case. The
9 piping is also very flaw tolerant, a lot of it is
10 stainless steel, and the stainless steel is extremely
11 flaw tolerant.

12 So, the probability of enough damage from
13 the one pipe causing damage on the piping greater than
14 the TBS is small. But guidance is still going to be
15 needed to cover any particular plant specific issues
16 that may impact secondary site failures, and so we'll
17 be generating that guidance as part of the DG-1428,
18 which we'll talk about in January.

19 Go to the next slide. So, that's the end
20 of the qualitative work that the group did to look at
21 the impacts of the Tbs. I'm going to move to the
22 quantitative stuff. So, in thinking about how we were
23 going to try to handle this in a relatively short time
24 frame, one of the staff initially recognized that a
25 lot of work had been done, at least for the PWR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 pipings to understand the LOCA frequencies through our
2 leak before break efforts, and the PWSCC efforts.

3 Both the agency as well as EPRI have
4 developed independent studies where we've done
5 analyses to try to look at what the impacts of PWSCC
6 are on those particular pipes that have been approved
7 for LBB. There has been reports published on that,
8 but the bottom line is that the probabilities of these
9 large breaks, the probabilities of these large pipes
10 breaking is extremely low.

11 And even especially, since like Ron
12 pointed out, most of them have been mitigated. The
13 concern about these large break LOCAs being a high
14 probability event is gone. But we wanted to try to
15 confirm, so we wanted to leverage that knowledge that
16 we got, that was developed over the last ten years,
17 with making sure that we could confirm the LOCA
18 frequencies that Rob showed earlier for the individual
19 base cases.

20 Again, our idea was not to recalculate
21 LOCA frequencies, it was just to see, to run some
22 analyses to see if we thought that the LOCA
23 frequencies that were in 1928 were representative, or
24 conservative, or how were they related to the analyses
25 that we did. So, we looked at those four base cases

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that are shown here, we had a 30 inch RPV nozzle, a 10
2 inch surge nozzle, 28 inch recirc line, and a 12 inch
3 recirc line.

4 And we recalculated the LOCA frequencies
5 using the xLPR probabilistic fracture mechanics.
6 Let's go to the next slide. So, the approach shown
7 here, we ran all these cases out to 80 years of
8 operation time, realizing that the 1829 work was only
9 for 25, 40, and extrapolated to 60, we wanted to run
10 them out to 80 years.

11 We chose sample sizes, and sampling
12 sufficient to give us confidence in a ten to the minus
13 six probability event. Which again, didn't have an
14 extraordinary amount of time to put on a whole bunch
15 of cases, so we had to use some optimization to run
16 these in a reasonable amount of time. We also enabled
17 leak detection, took credit for that as part of these
18 analyses.

19 We looked at probability of leakage,
20 probability of rupture, and leak rate, and then we
21 took that and post processed it to calculate component
22 level LOCA frequencies, and made those into annual
23 frequencies by taking into account the years in which
24 they were calculated. For PWRs, we assumed that the
25 most relevant mechanism was PWSCC.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We looked at a couple of different
2 residual stresses, the inputs that we used for the PWR
3 were very similar to those cases that we used in the
4 effort that I talked about earlier, the effort that
5 was done to look at PWSCC right before break. We had
6 two residual stresses, one was the residual stress to
7 mimic the profile that was found in the V.C. Summer
8 case that we talked about earlier, we assumed that was
9 very conservative.

10 And then we used a generic representative
11 weld residual stress profile that was developed
12 through the xLPR program for these pipes, for both the
13 reactor coolant loop piping, and the pressurized surge
14 piping. For the BWR we had to use an IGSCC crack
15 growth rate, but xLPR currently doesn't have a built
16 in IGSCC crack growth rate.

17 So we had to use the generic crack growth
18 rate model, and put in the parameters that matched the
19 most recent ASME Section 11 IGSCC crack growth rate.
20 And for the residual stress, we didn't really have
21 residual stresses for the BWR welds, and so we
22 generated them from this program to be able to run
23 these analyses, we generated them as part of this
24 effort.

25 Let's go to the next slide. All right, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the next couple slides I'm going to show some of the
2 results. These are mainly just for comparison
3 purposes for you. There's a lot more detail again in
4 the reports I talked about earlier. But in each one
5 of these plots, the Y axis, vertical axis is the
6 annual LOCA frequency.

7 In this particular case it's a small break
8 LOCA frequency, and on the horizontal axis is the
9 time in years. For most -- for all of the cases that
10 we ran for this effort, we got no large break LOCA
11 frequencies, which means that it's well below the ten
12 to the minus six value. So, for the number of
13 realizations that we run, we got no results.

14 In some cases we only got small break LOCA
15 results, in some places we got small break and medium
16 break LOCA results. But for most cases we could not
17 get any results for the very large break LOCA. In
18 each one of these plots the green lines, the vertical
19 lines are the NUREG 1829 results, and the red or
20 orange lines are the PFM results from this effort.

21 And for both the PWR-1 and PWR-2, you can
22 see that the results are either representative, and
23 kind of go through the middle, or conservative
24 compared to the 1829 results in the LBB readings.

25 DR. BLEY: This is Dennis Bley.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: Yes.

2 DR. BLEY: Just looking at your red curve
3 from xLPR, it kind of flattens out, does that imply
4 some kind of repair mechanism, or arrest mechanism
5 going on?

6 MR. RUDLAND: No, we didn't assume any
7 repair mechanisms in these particular analysis. I
8 think the trend that's shown there is because of how
9 the annual frequency was calculated. So, xLPR runs in
10 a time base, and at each time step, if you divide the
11 number by the years that you're at that particular
12 time step, at the larger years you'll get slightly
13 lower numbers.

14 So, the trend that you're seeing is due to
15 the fact that we have normalized by year over the
16 course of the analysis.

17 DR. BLEY: Okay.

18 MEMBER HARRINGTON: Dave, this is Craig.
19 On the PWR-2s, are the step changes inspections, or?

20 MR. RUDLAND: No. So again, as I said
21 earlier, we chose a sample size that was expected to
22 give us a reasonable numbers at 1E to the minus six.
23 However, you can see in those cases we're down to 1E
24 to the minus eight, so it's due to the sample size.
25 It's just coarse because of the sample size. It would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 smooth out if we were able to run a number of samples
2 that were down to ten to the minus eight.

3 But again, at that particular point it
4 didn't seem to be necessary because it shows even at
5 that coarseness, that it was below the 1829 numbers.
6 Okay, let's go to the next slide. Similar results for
7 the BWRs. Everything is the same, except in this
8 particular case there's green lines and blue lines.
9 The green lines are the small break, the blue lines
10 are the medium break LOCAs.

11 And you can see the same kind of results,
12 you see that the lower end of the distribution for
13 cases that Rob showed earlier, and these were
14 indicative of the fact that the numbers that were
15 generated from 1829 for at least the xLPR ones are
16 demonstrated that they seem to be slightly
17 conservative for LOCA frequencies.

18 Okay, let's go to the next slide. All
19 right, so in addition to the xLPR study that we did,
20 we also did this international operational database
21 study, and the purpose of this was to try to do a
22 Bayesian update on the LOCA frequencies that we had
23 back in 2004ish time frame. The basis of those
24 numbers that were chosen by those particular panelists
25 that decided to use the operational database of course

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 was only for the data up to that time of 2004.

2 And there's been a lot of changes in the
3 20 years since then, we have more operational
4 experience, and we have new mitigation techniques, and
5 we have better inspection techniques, and so the idea
6 was to take the fact -- of the change -- are there any
7 changes in the operational database that would cause
8 us to want to change the LOCA frequencies.

9 The plot on the right just kind of
10 demonstrates how much time in EFPY has changed between
11 2004 and 2024, so there is 952 years difference in
12 there in terms of the amount of time that was in the
13 operational database. So, again, the objective of
14 this was just to reevaluate the LOCA frequencies,
15 let's go to the next slide. The procedure was like
16 this, where originally they calculated the piping
17 failure precursor frequencies from an operational
18 database for up to 2004, and then up to 2024.

19 The database that was used, Rob mentioned
20 it a little bit earlier, it is the CODAP database.
21 That is a database that is managed by NEA, and it
22 contains all of the events, and experience worldwide
23 on operation data, whether it's inspection defects --
24 leakage, defects, or failures, it's all in that
25 particular database.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And for your information, Ron, the
2 information that we used at the last briefing where we
3 showed the data, it came from this database. So, from
4 that precursor data, we were able to calculate the
5 conditional probability of failure from the NUREG 1829
6 LOCA frequency estimates using the 2004 precursors.
7 And then from that we updated the LOCA frequencies
8 using -- make an estimate of the CFP and updated LOCA
9 frequencies from the 2024 failure frequencies.

10 Okay, let's go to the next slide. This
11 shows those estimates. So, if you look for both the
12 PWRs and BWRs for those LOCA categories that were
13 considered, the LOCA frequencies, the mean values of
14 the plant level LOCA, annual LOCA frequencies went
15 down an order of magnitude, or two in some cases,
16 suggesting again that the full LOCA frequencies are
17 actually better than what was estimated in 1829.

18 For both BWRs and PWRs the trends are
19 about the same. And that was attributed to again,
20 like I mentioned, improved mitigation techniques,
21 better inspection procedures, and honestly the
22 proactiveness of the industry to handle operational
23 experience as it comes along. Any questions on this?

24 CHAIR BALLINGER: So, I look at those
25 numbers and, again, I don't -- probability is not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 one or a zero but it's pretty low.

2 MR. RUDLAND: One in a billion, four in a
3 billion, right? Yes, they're, relatively, relatively
4 absolutely low, yes.

5 But, okay, so, let's go to the next slide.

6 Before we move on to 1903 I just want to
7 make a comment that the staff have made the tentative
8 decision that if the LOCA frequencies were determined
9 to be less than what they were calculated in 1929,
10 that we would take no -- we'd make no path forward to
11 change the transition break size.

12 We felt that this confirmation effort was
13 just to make sure that the assumptions that were made
14 in the 1929 were reasonable.

15 We have not been able to do a full,
16 complete, comprehensive study of redeveloping the LOCA
17 frequencies. So, we didn't want to make any changes
18 unless they showed increase in the LOCA frequencies
19 which we see.

20 And so, what you'll see in the rule for
21 the transition break size is the same as what Rob
22 talked about earlier.

23 All right. So, in addition to the 1929
24 work, we wanted to do a reconfirmation of, of the 1903
25 results. And as Rob talked about, 1903 addressed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 seismic effects on TBS.

2 We looked at, we looked at three, three
3 cases: the unflawed piping, the flawed piping, and the
4 indirect piping failures. It used the Lawrence
5 Livermore National Lab Seismic Hazard Curves for that
6 particular assessment.

7 And as Rob pointed out, the decision from,
8 the conclusion from that effort basically with the
9 direct flaw -- unflawed piping had failure
10 probabilities extremely low. So, we really didn't
11 look any further at the direct unflawed piping, but
12 they were definitely less than 1E-05 per year, which
13 was the basis that was used as a basis to establish
14 the TBS.

15 All right. So, where this effort -- let's
16 go to the next slide.

17 Again, for this effort we, we didn't have
18 an exorbitant amount of time to go through it and make
19 analyses the way that was done in 1903. So, what we
20 decided to do was take a look at the updated hazard
21 curves, both the, you know, the central and eastern
22 U.S., reevaluate their seismic hazard curves after the
23 Fukushima accident. And that NUREG contained
24 information on what those were.

25 And so, we wanted to be able to take those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 new hazard curves and see if there was any impact if
2 we took those hazard curves, calculated the 1E-5, 1E-6
3 probability to see if there was any impact on this.

4 So, for the direct flawed piping, the
5 associated stresses relating to those 1E-5, 1E-6
6 probability of exceedance events for seismics were
7 very large. And as Rob showed, the probability for
8 pipe breaks larger than that were shown to be lower
9 than the TBS frequency criterion.

10 For the indirect piping failure, the mean
11 probability of failure at the lowest capacity
12 component was less than 1E-05.

13 I'll show some results of that in a few,
14 in a few minutes.

15 And so, for both direct and -- direct
16 flawed piping and indirect, the numbers were much less
17 than 1E-05. And all of those results are detailed in
18 the White Paper for Continued Applicability of 1903,
19 which is at the ML number as shown.

20 I'll go into a little bit of detail next.

21 The next slide.

22 For the direct unflawed piping failure we
23 used the same steam that was used in 1903. Basically
24 you take the design stresses, which is the normal
25 stresses and the SSE stresses.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 You take the -- you determine the PGA for
2 both 10 to the minus 5 and 10 to the minus 6
3 earthquakes. In this case we didn't take them from
4 the LANL -- from the Lawrence Livermore results, we
5 took them from the updated seismic hazard curves.

6 Basically, calculate and determine the
7 scale factor that Rob talked about earlier which
8 allows you to go from design stresses to realistic
9 stresses.

10 And then we scaled those stresses to the
11 higher earthquake levels.

12 We then normalize those results by the
13 design stress intensity and obtain the probability of
14 exceedance from the seismic hazards.

15 Go to the next slide.

16 This shows an example of the direct
17 unflawed piping failure results as a function of
18 stress at the bottom. Basically the 1, 2, 3, 4 are
19 one times the design stress intensity, two times,
20 three times the design stress intensity. And last is
21 the probability of exceedance.

22 And the blue line is the 1 percent
23 probability of failure numbers. And you can see at
24 that page they're all below the 1E-5.

25 Taking that, taking those values, we go to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the next slide.

2 Here is the scatter plot that shows all of
3 the cases analyzed in this effort. And that threat
4 probabil -- threat piping failure probability per year
5 as a function of the number of plants, basically.

6 And you can see they're all below the 1E-5
7 per year.

8 They also did -- if you go to the next
9 slide -- indirect. We wanted to recreate the indirect
10 also. And these, again, are pipe ruptures caused by
11 failures of major components, or component supports as
12 a result of an earthquake.

13 We used the fragility curves that were in
14 1903 and did the same kind of analyses. And the
15 results show that the main probabilities are less than
16 1E-5.

17 You can see the actual results on the
18 next, the next plot.

19 Let's go to the next, the next slide,
20 please.

21 And, again, this is the indi --

22 Is there a question?

23 CHAIR BALLINGER: I don't know. That's
24 just some somebody that hasn't muted themselves.

25 MR. RUDLAND: So, the vertical access again

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is indirect piping failure probability as a function
2 of site. A number -- and you can see all the numbers,
3 again, are below 1E-05.

4 So, the staff felt pretty confident that
5 the results in 1903, which were basically that the
6 seismic effect wouldn't impact TBS, was still, was
7 still valid now.

8 All right. So, one more slide.

9 So, we did all this work, again, within,
10 within since about March. And staff felt pretty
11 comfortable after going through all this that the LOCA
12 frequencies are applicable only if, again, plant
13 specific applicability is demonstrated. In both the
14 1903 results, as well as in our results, our finding
15 elements, our PFM analyses. Again, affirmed generic
16 loads. We didn't do any class specific loads.

17 On the seismic efforts are now bounding.
18 We do believe that plant specific applicability needs
19 to be done.

20 Okay, like I was saying, the LOCA
21 frequencies and the TBS are applicable only if plant
22 specific applicability is demonstrated. We felt that
23 both the results from the original efforts as well as
24 now were not really that bounding, they were more
25 representative. And so, plant-specific applicability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is key to do the operation plan in 1903.

2 More importantly, we felt that if they
3 were not able to demonstrate that they were
4 applicable, that, for instance, if it was a redesign,
5 that they could develop their own transition break
6 size using the methodologies that we did, that we've
7 done in this set.

8 The change in requirements was that the
9 staff really felt that the inspection of these piping
10 welds with diameters greater than the TBS was needed
11 to ensure the LOCA frequencies remain applicable. We
12 wanted to be as flexible as possible on that, while
13 still retaining those inspections. So, allowed the
14 individual licensees to leverage their ISI programs to
15 account for those inspections as, as they need to.

16 CHAIR BALLINGER: Can we go back to 67?

17 MR. RUDLAND: I think so.

18 CHAIR BALLINGER: I was wondering why that
19 scale factor was pretty large, 1.4, 1.5 and
20 thereabouts?

21 MR. RUDLAND: Well, we're scaling from,
22 we're scaling from design conditions to more accurate
23 conditions. That's not unreasonable. I'd expect --

24 CHAIR BALLINGER: It's not unreasonable.
25 It just seemed large.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: And the design loads aren't,
2 the design stresses aren't large compared to --

3 CHAIR BALLINGER: So, do those
4 probabilities that you show scale linearly with that
5 scale factor?

6 MR. RUDLAND: That's a good question. Let
7 me, let me call a friend on that.

8 Se-Kwon, come up to the -- see where the
9 green light is there.

10 MR. JUNG: Yeah. I do the analysis that,
11 as Dave mentioned, that I take the stresses more
12 actually linearly scaled up.

13 CHAIR BALLINGER: Okay.

14 MR. JUNG: Yes.

15 CHAIR BALLINGER: All right. Thanks.

16 MR. RUDLAND: And that was Se-Kwon Jung
17 from DEX, engineering conditions. He helped with all
18 the seismic analysis.

19 CHAIR BALLINGER: Thank you.

20 MR. RUDLAND: Okay. If we can go back to
21 the last slide, last slide?

22 Yes. I think that was it for me.

23 Again, if there's any questions, happy to
24 answer them. If not, I think I turn it over to Joe.

25 So, we would request a 5-minute break, bio

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 break.

2 MEMBER KIRCHNER: Ron, would you entertain
3 another question?

4 CHAIR BALLINGER: How imminent is this
5 break required?

6 MR. RUDLAND: We can handle the question
7 until we do what he needs to do.

8 MEMBER KIRCHNER: Okay. This is Walt
9 Kirchner again.

10 So, just to reflecting upon the one
11 opinion of your staff about inspections, do you feel
12 that industry-wide, Ron had a line of questioning
13 earlier, you know, cost considerations come into play
14 in inspection choices? Also, dose and exposure
15 considerations play. And then degree of difficulty in
16 terms of access and such.

17 So, based on your experience looking at
18 the plant, do you, do you see any areas -- and I'm
19 thinking mainly PWRs now -- where there are welds that
20 are not being inspected that should be?

21 You mentioned there's on the order of 30
22 major welds --

23 MR. RUDLAND: Yes, yes.

24 MEMBER KIRCHNER: -- in a PWR plant. Are
25 all 30 of those being covered either --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: Yeah. Now, some of them have
2 never, some of them have never been inspected. You
3 know, they were inspected at -- during construction
4 and during the pre-service inspection. But they're
5 probably not part of sampling.

6 All of them cannot be part of the sampling
7 program because it is a sampling program. So, you
8 know, the typical, I mean sampling program for piping
9 is, for Class 1 piping is 25 percent, just across the
10 board 25 percent.

11 But these risk informed programs which
12 allow the plants to inspect only those welds that have
13 high risk is really only a 10 percent sample.

14 So, there are going to be welds out there
15 that have probably never been inspected. It's going
16 to be very plant specific how many welds. These welds
17 that we're talking about, it's going to be very plant
18 specific on whether or not those welds are currently
19 their risk informed program or are being sampled from
20 -- they're being inspected within the risk informed
21 program or not.

22 MEMBER KIRCHNER: Okay.

23 MR. RUDLAND: They're all part of the
24 program, but whether or not they're sampled or not is,
25 is very plant specific.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: Yeah. I understand all
2 that. But what I'm asking, I guess, more specifically
3 is there, in the current fleet is there a weld
4 location that isn't being sampled in any of the PWRs?

5 MR. RUDLAND: Not in, not in the reactor
6 part of the boundary, no, the reactor coolant
7 building, no. They're all --

8 CHAIR BALLINGER: Okay. That --

9 MR. RUDLAND: They're all part of some
10 inspection program, whether it's the new inspection
11 program, or it's the former inspection program, or an
12 augmented inspection program.

13 MEMBER KIRCHNER: Okay. No, you gave me
14 the answer I was looking for.

15 All right, thank you.

16 MR. RUDLAND: But that doesn't mean every
17 single weld is inspected.

18 MEMBER KIRCHNER: No, no. No, I didn't
19 mean to imply that. I just wanted to hear you say
20 that all welds -- no, let me try to pick my words very
21 carefully here -- that if there are on the order of 30
22 or 50 major different weld locations, that these have
23 all been surveyed and inspected at some point?

24 MR. RUDLAND: They're all part of the
25 sampling program. Whether any one particular weld has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 been inspected over the 40 years is unknown.

2 So, there is a possibility that there are
3 welds out there that have never been inspected.

4 MEMBER KIRCHNER: No, I understand that
5 part.

6 MR. RUDLAND: Okay.

7 MEMBER KIRCHNER: I'm just thinking
8 generically for a PWR there aren't -- that they've
9 covered all the weld locations in the generic sense.

10 MR. RUDLAND: All the welds are basically
11 part of their -- in their program.

12 MEMBER KIRCHNER: Yeah.

13 MR. RUDLAND: We don't know. I think
14 Walt's getting at generally, you know, do we think if
15 there is a weld in, for instance, in a hot leg that's
16 a common location --

17 MEMBER KIRCHNER: Yeah. That's
18 inaccessible or something.

19 MR. TREGONING: Let me use Westinghouse
20 plants. If, if some plant, some Westinghouse 3-loop
21 plant is inspecting that weld, we don't know that
22 because, --

23 MEMBER KIRCHNER: We don't know that.

24 MR. TREGONING: -- you know, the ISI
25 programs were developed on a plant-specific basis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Right? And, you know, based on their, again, there's
2 generic categories of welds that break down that
3 become part of their inspection program.

4 But then they're supposed to tailor what
5 loads they look at based on unique operating
6 experience and conditions within those, within the
7 particular plant. So, they don't coordinate in some
8 way to make sure that, okay, somebody's inspecting
9 this weld in this plant.

10 That level of coordination is not only not
11 required, it's, it's not done to my, you know, to my
12 knowledge.

13 But realizing you've got, like you said,
14 Walt, there are a variety of --

15 MEMBER KIRCHNER: Yeah.

16 MR. TREGONING: -- incidences that cause
17 them to choose which welds they're going to inspect.
18 Every licensee has their own set of rules to inspect.

19 So, it's a good possibility that a good
20 number of them are being inspected, but I can't
21 guarantee that all of them have been inspected.

22 CHAIR BALLINGER: But the point is, is that
23 you may not know, but the data's there.

24 MR. RUDLAND: The data's there.

25 CHAIR BALLINGER: You think the data's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there.

2 MR. RUDLAND: There probably is an old
3 employer probably has a lot of the data.

4 CHAIR BALLINGER: But the critical question
5 might be these welds are all ranked in some way to
6 susceptibility.

7 MR. RUDLAND: Yes.

8 CHAIR BALLINGER: Is there the possibility
9 that a highly-ranked, that is to say a bad one, has
10 not been inspected, is one of that population that has
11 never been inspected?

12 MR. RUDLAND: So, again, how they're
13 ranked, at least in a risk informed program, is once
14 the, once the risk significant, if that thing fails,
15 that's the first ranking.

16 The second is what's the degradation on
17 that?

18 So, if you have a high risk, low/no
19 degradation, it's a low category weld, right, even
20 though it maybe has a high risk of failure.

21 Which is why we are concerned about those
22 ones that are greater than the TBS. If those are in
23 that situation they are high risk welds, low because
24 of the no degradation. And so, they get less
25 inspections.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. TREGONING: But just to be clear,
2 you've got risk informed program, it tends, if we're
3 talking about Class 1, from a consequence perspective
4 they all have basically similar consequences in that
5 run of pipe.

6 MR. RUDLAND: In that run of pipe for Class
7 1. So, they're really based on material pipe
8 susceptibility.

9 So, if you're talking about a stainless
10 steel weld, it doesn't matter what weld that, you
11 know, if it's in a heat remover, safety injection, or
12 the main coolant loop piping, if it's a stainless
13 steel weld it's Class 1. It's likely all part of that
14 same inspection population.

15 And then they will choose their 10 percent
16 sample size based from that population. And if
17 they're all equally susceptible then, yes, cost,
18 acceptability, ALARA, all of those things factor in
19 because, obviously, if you make the presumption that
20 they're all equally susceptible, you're going to want
21 to try to minimize those other costs and risk factors
22 associated with the inspection.

23 CHAIR BALLINGER: So, but somebody that
24 would want to use this option, at that point the data
25 would -- you would find out.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: Yeah.

2 MR. TREGONING: Yes.

3 And to Walt, I want to comment to Walt.

4 So, for instance, in some of these
5 augmented programs like the certain amount of weld
6 programs, so there's a very comprehensive program for
7 inspection and mitigation of a certain amount of
8 welds. Because of that operational experience and the
9 fleet-wide behavior those welds are all inspected.
10 Okay?

11 So, 100 percent of those welds are
12 inspected or have been inspected. And even if
13 they're, or even if they're mitigated they're in,
14 within some kind of inspection program. So, because
15 we know the susceptibility of those materials, the
16 augmented programs are focused on those and they get,
17 they get the inspection.

18 So, if we did find out some new mechanism
19 popped up, augmented inspection programs would, would
20 probably find those.

21 CHAIR BALLINGER: But in effect you have,
22 basically, a canary in the coal mine because there are
23 some plants that are not mitigating these.

24 MR. TREGONING: Yes.

25 CHAIR BALLINGER: But they have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 augmented inspection?

2 MR. TREGONING: They have. They are
3 inspecting it more than those that aren't.

4 CHAIR BALLINGER: They're inspecting it
5 more. So, they are in one sense leading.

6 MR. TREGONING: Yes.

7 MEMBER KIRCHNER: Thank you, Dave. That's
8 enough.

9 I just wanted to get that on the record.

10 MR. RUDLAND: You asked the question, Walt.

11 MEMBER KIRCHNER: Thank you.

12 MEMBER PALMTAG: I have a very simple
13 question.

14 Could you go back to the graph with the
15 LOCA versus the time, maybe it was 65.

16 MR. RUDLAND: So, back in the PFM section,
17 I think.

18 MEMBER PALMTAG: Yeah. So, I'm not a
19 fractions mechanics person but.

20 MR. RUDLAND: No, yeah, keep going. Keep
21 going.

22 MEMBER PALMTAG: That's good enough.

23 Can you tell me why the LOCA frequency
24 goes down with time?

25 MR. RUDLAND: I talked about that a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 bit, a little bit earlier.

2 So, again, these LOCA frequencies are
3 annual frequencies. The way that problems with
4 fraction mechanics runs is that it runs on a time
5 basis; right? So, the way that we calculate the
6 annual frequencies, we take the time step that we're
7 at and we divide that by the year that we're at a
8 particular point.

9 So, if the LOCA frequencies aren't
10 changing much then they're going to look like they're
11 going down because dividing by 80 is a lot, is a lot
12 smaller than dividing by 20.

13 MEMBER PALMTAG: It's just more of a
14 normalization?

15 MR. RUDLAND: More of a normalization.
16 When you mate LOOP to annual basis.

17 MEMBER PALMTAG: Right. Okay.

18 MR. RUDLAND: Yeah. The problem is with
19 fraction mechanics kind of do a cumulative fre --
20 cumulative probability is not what they calculate.

21 MEMBER PALMTAG: It would be kind of like
22 a bathtub shape formation if you --

23 MR. RUDLAND: It won't go back, it won't go
24 back up, right, because as that number gets bigger
25 it's going to keep, keep looking like it's going down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 unless the absolute value of the frequency increases.

2 MR. TREGONING: So, just to be clear,
3 they're going down because you're getting no new
4 realization checks.

5 MR. RUDLAND: Yes. That's right.

6 MR. TREGONING: You're getting no ruptures
7 in the scenario.

8 So, when you saw those vertical lines,
9 that means you've got a least one realization that had
10 a rupture. So that's why the frequency jumped up in
11 that particular time period.

12 These that are showing this gradual
13 decrease you're getting no new realizations, and then
14 the frequency is just decreasing because you're
15 accumulating more years without getting a rupture, if
16 that makes sense.

17 MEMBER PALMTAG: Yes. Thanks.

18 CHAIR BALLINGER: Okay, we are, just to
19 renormalize us, we're scheduled for a break at 2:30.
20 It is now 2:24. In an effort to get us behind is it
21 appropriate to just keep going or should we take the
22 break.

23 MR. RUDLAND: Joey doesn't need a break.

24 CHAIR BALLINGER: And I don't know how much
25 time, how much time we need for Joe's presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. MESSINA: I think it's supposed to be
2 scheduled an hour-and-a-half; right? I don't know if
3 you'll take that long.

4 CHAIR BALLINGER: Okay. I'm fine with
5 keeping going. But there are other members that might
6 disagree with me on that.

7 Do we have a disagreement? We'll observe
8 the 5-second rule.

9 Let's go.

10 DRAFT PROPOSED RULE LANGUAGE FOR 10 CFR 50.46A

11 MR. MESSINA: Okay. So, again, I'm Joe
12 Messina, reactor systems engineer in NRR. And I'll be
13 walking through the draft proposed rule language for
14 50.46a, and a reminder that this is a voluntary
15 alternative to 50.46.

16 Next slide, please.

17 So, to provide outline of the rule,
18 several sections I'll go through. And I'll talk about
19 each of these as we go through. But sometimes it's
20 nice to have this outline to more easily parse the
21 rule.

22 Next slide, please.

23 So, in the definition section there's a
24 bunch of definitions. I've highlighted some of them
25 here that might be interesting or used throughout.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so I'll start with changes enabled by
2 this section means changes that would meet 50.46a but
3 would not meet the current 50.46.

4 Entity would mean, you know, the
5 application, holder of a construction permit,
6 operating license, COL, SDA, manufacturing license, or
7 applicant for a standard design cert rule.

8 LOCA means the coolant system LOCA here
9 with some slight modifications from the current
10 version in 50.46. First we, at the end we included
11 the LOCAs at or below the transition break size or
12 just design basis accidents. We clarify that.

13 And that LOCAs larger than the transition
14 break size are beyond design basis accidents.

15 We also, current 50.46 definition of LOCA
16 has, it says in the first bold, bolded section there
17 it says breaks in pipes in the reactor coolant
18 pressure boundary. We made it breaks in the reactor
19 coolant pressure boundary, partly to align with the,
20 align with the definition of LOCA in the GDCs.

21 The transition break size, as we talked
22 about, is the same as Rob talked about. So, I don't
23 believe I need to go through that.

24 But it's listed here. And the date that
25 we listed here, I'll explain why that's important in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the coming slides.

2 MEMBER PALMTAG: Sorry. Can you go back to
3 -- Thank you.

4 (Pause.)

5 MR. MESSINA: Okay, next slide, please.

6 The paragraph (b) of 50.46a, is a lot of
7 words in paragraph (b) if you look at it. But I tried
8 to summarize it here that it's mainly operating
9 licenses issued prior to this date, December 31st,
10 2015, and entities whose design is demonstrated under
11 paragraph (c)(2) to be similar to the design reactor
12 -- the designs of reactors licensed under part 50
13 before that date.

14 And the reason for us having this date is
15 that the NUREG-1829 frequencies in the transition
16 break size were based on plants licensed before that
17 date. LWRs licensed after may have different piping
18 materials, configurations, operational and service
19 conditions among, among other factors that may impact
20 the piping break frequencies and, thus, the transition
21 break size.

22 I'll talk about paragraph (c)(2) here
23 since it's mentioned. I'm talking about it here
24 instead of later.

25 And paragraph (c)(2) states that for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 plants after the date, an analysis should be
2 submitted that demonstrates why the proposed design is
3 similar to reactors licensed before that date, such
4 that provisions of 50.46a may properly apply.

5 And it must include a recommendation for
6 an appropriate transition break size and a
7 justification that the recommended TBS is consistent
8 with the technical basis of this section.

9 MEMBER PALMTAG: So, practically, the
10 plants after would be in P1000 NUSCALE?

11 MR. MESSINA: Yes. And any other LWRs.

12 So only, yeah, only those plants in 1020
13 NUSCALE.

14 MEMBER PALMTAG: Okay.

15 MR. MESSINA: Next slide, please.

16 So, a lot of discussion was had previously
17 on inspections. On inspections. And this is the
18 wording in the rule.

19 So, a licensee must inspect 10 percent of
20 the welds, circumferential welds in a PWR that have
21 the highest failure potential.

22 And this requirement is new for the 2010
23 draft rule, added in part in response to the public
24 comments to original 2010 rule to reduce the burden of
25 demonstrating plant-specific applicability, as well as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to verify that analyses that predict component failure
2 remain accurate through the time the component is
3 analyzed, so that it captures any new degradation
4 phenomena that may potentially occur and have an
5 effect on LOCA break frequencies and the transition
6 break size.

7 MEMBER HARRINGTON: This is Craig.

8 So, the focus concern is more on the
9 larger side. Are you assuming that other mechanisms
10 will manage to keep inspections in place at or below
11 TBS?

12 MR. MESSINA: Since we're not, since we're
13 not redesignating the -- we're not touching the LOCAs
14 below the transition break size, we're not really --

15 MEMBER HARRINGTON: Just letting it be?

16 MR. MESSINA: Yeah, we're letting, leaving
17 them alone.

18 MR. RUDLAND: These inspections that he's
19 talking about here are really just focused and need to
20 assure that we catch something that's not all
21 different; right? And that the analyses that we had
22 to say, continue to say that.

23 In the statement about "reduces the burden
24 of demonstrating," so one of the comments we had --
25 and, I'm sorry, Joe, if I'm stepping on your toes a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 little bit -- one of the comments we got back
2 originally was that the plant-specific applicability
3 guidance that we drafted at that time was way too
4 burdensome. And the industry was, like, that's just
5 too burdensome.

6 So, what we did here now is allowed them
7 to program inspections and then reduce the burden in
8 the plant-specific applicability, which we'll hear
9 about in January.

10 MR. MESSINA: Okay. Next slide.

11 50.46a is on application, so information
12 that the licensee or entity that is wanting to adopt
13 50.46a, we need to provide:

14 An evaluation of applicability of the
15 transition break size;

16 Weld inspection report;

17 Description of the risk informed
18 evaluation process to analyzes -- analyze change made,
19 changes made under this rule;

20 Description of how they are evaluating the
21 continued applicability of the transition break size;

22 Description of any non-safety systems that
23 are credited for LOCAs greater than the transition
24 break size. And they would need to be placed in the
25 Tech Specs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And now this, I'll talk about this a
2 little later, but above the transition break size we
3 would allow crediting of non-safety systems just as
4 long as they're placed in the Tech Specs.

5 You'd do an evaluation of the leak
6 detection program.

7 And same as I said before, for reactors
8 licensed after the 2015 date, an analysis
9 demonstrating that the reactor design is similar to
10 those before the 2015 date and the appropriate
11 transition break size.

12 I appear to have also, I forgot one
13 bullet. Paragraph (c)(3) is a statement that says
14 that the ECCS performance must meet the criteria in
15 paragraph (e). So, that should be obvious, but.

16 Next slide.

17 Paragraph (d) is the programmatic
18 requirements, so, the requirements that licensees
19 would need to maintain throughout use of this rule.
20 So, similarly, this is similar just as we progress.
21 So, that's it.

22 ECCS models and methods are maintained and
23 meet the requirements in paragraph (e);

24 Lead detection equipment are available;

25 Changes are evaluated in a risk-informed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 evaluation;

2 And then this fourth item was in the rule
3 language that the ACRS was sent a month ago, but has
4 since been removed during concurrence. And this had
5 previously stated that risk assessments must be
6 maintained and upgraded at least once every 5 years.

7 So, that was removed during concurrence.
8 And you'll see later on there was also a reporting
9 requirement associated with this later in the rule
10 that was removed as well.

11 The fifth item here is that it must be
12 demonstrated that any changes made do not invalidate
13 the transition break size.

14 And No. 6, during operation, licensees
15 must perform the weld inspections every subsequent in
16 service interval, so to identify any additional
17 degradation, as we had been discussing. So, that
18 would be, you know, about every 10 to 12 years.

19 Next slide.

20 Paragraph (e) is on ECCS performance.

21 (e)(1) establishes two principle ECCS
22 acceptance criteria that the fuel remains in a
23 coolable geometry and that there's -- that decay heat
24 will be removed in the long term.

25 So, this maintains coolability and removal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 date decay heat as fundamental objectives that really
2 have been there since the origin of 50.46.

3 And this, the structure of (e) and some of
4 the other paragraphs such as (f), similar to those in
5 50.46c, the draft final rule. 50.46c had two
6 principal ECCS acceptance criteria, but the first was
7 core temperature rather than coolability. We changed
8 it to coolability in light of how that, how
9 coolability remains fundamental to LOCA analysis since
10 19 -- the 1970s.

11 CHAIR BALLINGER: This is Ron now.

12 This is an interesting change. Because if
13 you look at the earlier ECCS, coolability was assumed
14 to be satisfied if you maintain the 2270 percent.

15 MR. MESSINA: Yes.

16 CHAIR BALLINGER: But now it's, so,
17 coolability was kind of an afterthought, kind of an
18 automatic. Now it's not an automatic.

19 MR. MESSINA: Yes.

20 Next slide, please.

21 So, paragraph (e)(2) is ECCS performance
22 at or below the transition break size. And most of
23 this wording is the same, is very similar to that in
24 the current 50.46.

25 We're not touching the LOCAs below the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 transition break size. We still expect them to be
2 analyzed with high probability modeling. And to date
3 we have interpreted that to be 95-95, so.

4 Next slide, please.

5 MEMBER ROBERTS: Excuse me. Before you do
6 that slide, what does the third bullet mean: "Changes
7 in fuel geometry must be addressed"?

8 MR. MESSINA: The changes in -- So, first
9 we have to consider, you know, the effect of
10 ballooning. And now that -- and, you know, the fuel
11 fragmentation and relocation into a newer region.
12 Such as that.

13 MEMBER ROBERTS: So, you're not precluding
14 burst for the breaks below the TBS? So, if there was
15 burst and FFRD and they're dispersing the fuel into
16 various cases, that's intended to be covered with the
17 high probability, if you hear?

18 MR. MESSINA: To follow the interruption,
19 for breaks below the transition break size we would
20 expect that licensees show that fuel did not disperse.

21 We discuss that a little bit in the
22 statements of consideration. But above the transition
23 break size we are -- we relaxed that.

24 MEMBER ROBERTS: Right. So, your
25 expectation is that there wouldn't be burst. But the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rule doesn't preclude burst?

2 So, if you had burst in a break below the
3 TBS, is that what that bullet point's intended to
4 cover, essentially including burst by the way this is
5 written?

6 MR. MESSINA: So, for like low burn-up fuel
7 you can get burst and not have fuel dispersement. So
8 that's, that's always been, we've always understood
9 that burst would occur during a LOCA. Now we know
10 that fuel will disperse potentially for those high
11 burn-up runs, but not for all the runs necessarily.

12 MEMBER ROBERTS: All right. But the other
13 document, at least for ALS, was that for all breaks
14 below the transition break size there will not be
15 burst. And that would be preventing FFRD, that would
16 be the end of it.

17 I'm still wondering the way this is
18 written, is that the intent, or would there be a
19 pathway to actually have dispersal in a break below
20 the TBS and use design basis methods to evaluate that
21 potential? That was from option 3, I remember, from
22 your initial list where you said nobody was in favor
23 of. But that would seem to be where you would end up
24 if you had burst.

25 Just an observation, if the expectation is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 how this is written, the implementation would be no
2 burst for breaks below TBS. I guess it doesn't
3 matter; right?

4 It seems kind of odd to leave that gap.
5 It looks like the way, at least the way the bullet
6 point's written there that there would a pathway to
7 have burst and still come through the analysis.

8 I guess I'll leave it at that.

9 MR. MESSINA: Next slide, please.

10 So, paragraph (e)(3) starts out very
11 similar to the paragraph (e)(2), but this is for LOCAs
12 above the transition break size.

13 And like the current regulation, it says
14 that must be analyzed up to the most severe -- most
15 severe LOCAs must be analyzed up to the double-ended
16 guillotine rupture of the large pipe in the RCS.

17 And in this is says there must be
18 assurance to at least a best estimate that the ECCS
19 and fuel system acceptance criteria are met.

20 I'll go into a little bit more about best
21 estimate in the slides.

22 Changes in fuel geometry must be
23 addressed.

24 Calculations may take credit for
25 availability of offsite power.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 You do not require assumption of a single
2 failure.

3 And non-safety-related equipment may be
4 credited.

5 So, these LOCAs above the transition break
6 size would be beyond-design-basis accidents and they
7 would be able to be analyzed with nominal and unbiased
8 analyses. You know, that means no intentional
9 conservatisms, realistic representation of plant
10 configuration, so no non-physical operating conditions
11 with inputs as may be done today.

12 And this was done in other beyond-design-
13 basis accidents such as ATWS and station blackout.

14 Questions, Walt?

15 MEMBER KIRCHNER: Yes, thank you.

16 Well, I'm looking at the overall
17 implications of this. And the first thing that occurs
18 to me is that the double-ended guillotine break is
19 actually the design basis for the containment.

20 So, are you going to talk about -- see,
21 when you, when you make a break like this, I'm
22 concerned about the implications elsewhere.
23 Containment design basis usually is driven by this
24 double-ended guillotine break. So, you're saying that
25 up to TBS is a design basis accident, beyond TBS is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 -- I misspoke.

2 Up to TBS, less than TBS is a DBA. Beyond
3 TBS is a beyond-design-basis accident. How does that
4 impact things like containment assessment and
5 analysis?

6 Because containment's usually designed for
7 the design basis accident. I mean, that's the basis
8 for the siting.

9 MEMBER PETTI: But, Walt, let me make sure
10 I understand.

11 The containment response is a function of
12 the internal energy in the primary system.

13 MEMBER KIRCHNER: Right.

14 MEMBER PETTI: The best estimate nature
15 there is more than response of the core. You're still
16 going to blow down all that steam, --

17 MEMBER KIRCHNER: Exactly.

18 MEMBER PETTI: -- and the temperature. And
19 so, the containment should see this at about the same
20 pressure; right?

21 MEMBER KIRCHNER: Yeah. It may change the
22 time it sees the peak pressure and temperature, but --

23 MEMBER PETTI: Might change the time
24 however?

25 MEMBER KIRCHNER: But I'm just concerned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that if you make a -- if you say TBS is the design
2 basis accident threshold, what are the implications?

3 So, you're saying -- I'm thinking of
4 Chapter 15, which is usually comprehensive design
5 basis accident analyses. So, --

6 MEMBER PETTI: Yeah. So, --

7 MEMBER KIRCHNER: So, you would analyze in
8 Chapter 15 up to the double-ended guillotine break no
9 matter where the TBS is?

10 MR. MESSINA: For containment sometimes is
11 used, I believe, a little different assumption. So,
12 for LOCA it's most conservative that, you know, the
13 energy of the core stays within --

14 MEMBER KIRCHNER: Exactly, yeah.

15 MR. MESSINA: And while for containment you
16 want the most conservative would be that the energy is
17 released as quick as possible.

18 So, there are some differing, differing
19 assumptions in the methods.

20 And, John, did you want to say anything
21 more on that?

22 MR. LEHNING: Sure. This is John Lehning
23 from NRC staff.

24 And so, the changes that we're making,
25 part of what Joe is talking about, they are for 50.46.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And those are for the core coolability requirements.
2 And, so, there aren't any changes being proposed here
3 relative to other requirements for containments.

4 And I think Member Petti's comments were
5 quite correct that we wouldn't expect there to be a
6 whole lot of differences relative to doing a very
7 precise best estimate or, you know, intentionally
8 adding conservatisms or uncertainties, because I think
9 that really isn't a part of what exactly is being done
10 there with those methods.

11 And, so, hopefully that clarifies.

12 Historically, payment analysis is
13 deterministic because it's supposed to be the final
14 barrier, final physical barrier. And if we had this
15 discussion when I was doing this for money, you know,
16 20, 30 years ago and, you know, I had licensee people
17 explain to me you'll never see that loot. You know,
18 best estimate containment is sacred. So, we keep the
19 methods.

20 MEMBER PETTI: I think I had a question on
21 the fuel geometry for breaks less than TBS.

22 You still proceed if, you know, you could
23 have analyses that push through ballooning without
24 rupture; right? Because you could say ballooning, of
25 course, you could very well get relocation. And, of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 course, that exacerbates the situation.

2 It's some kind of cliff edge even if it
3 doesn't result in ballooning.

4 The models that have been, NUREG-630 has
5 been the model that one's used for years, I was
6 wondering we ought to revisit this in light of, you
7 know, this change.

8 You know, I've always kind of felt like
9 these two things kind of went together. And that the
10 uncertainties associated with rupture and ballooning
11 together I just really, I had never ever really
12 thought of them separate in this way.

13 I don't know, I'm going to have to study
14 this, though.

15 MEMBER PETTI: I think this a generic issue
16 about, you know, we're here in 50.46 space, but this
17 could have tentacles other places. And I know you
18 guys have tried to think through all of those as best
19 you can.

20 But there's a lot of regulation here. And
21 operators, licensees and the like, how do you know
22 that you haven't tumbled into something, you know,
23 unexpected?

24 MR. LEHNING: And those are good comments.

25 And I just wanted to correct one comment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that I made.

2 So, there is, there was a change to some
3 of the wording on GDC 50 and which was pointed out to
4 me. The change was to look at the containment
5 analysis realistically rather than in some
6 conservative way.

7 And I think just over time the containment
8 analysis methods have been becoming increasingly more
9 and more realistic. And there aren't necessarily a
10 lot of regulatory requirements built in for
11 conservatism. But I think was, as part of the idea
12 that behind beyond design basis, this was made
13 explicit in that GDC there's some language there in
14 the Federal Register notice to that effect.

15 And, again, this is John Lehning from the
16 staff speaking.

17 MEMBER PETTI: So, just to be clear, what
18 analysis is looked at for the containment? Will it be
19 the break at the TBS, or will it be the beyond design
20 basis old double-ended guillotine break?

21 Which one gets used in the evaluation?

22 MR. LEHNING: This is John Lehning again.

23 I think that that could be either one. I
24 think the most limiting one, and my expectation, is
25 that that would be the large break in a realistic way.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Because as we were discussing before,
2 there are not some requirements to handle. And we
3 know pretty much this internal energy of the system
4 pretty well. So, I would highly doubt that the
5 smaller break, whatever conservatisms, may be the
6 limiting one.

7 MEMBER PETTI: Okay now, thanks. That
8 clarifies it.

9 MEMBER KIRCHNER: I'm not so certain.
10 Yeah, for a large dry containment, probably the time
11 it takes to blow down the entire primary system and
12 start refilling it probably doesn't have a large
13 impact.

14 But for an advanced design with a smaller
15 containment, this is a big difference.

16 So, if you say -- just I'm just trying
17 this out. Unfortunately, I'm doing it in realtime, so
18 bear with me.

19 If you say, if you define design basis
20 accidents, which is usually where we, we make the
21 normal assumptions, single failure, et cetera, et
22 cetera, we go through, say, fibrillated systems and so
23 on, if you limit it to TBS, then would it be possible
24 to design the containment for a lower pressure
25 temperature rating than if you assumed the largest

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 break discharging instantly into the containment?

2 MEMBER PETTI: Yeah, Walt, you're talking
3 about designing a legacy plant today from scratch.
4 The rule only applies to the reactors that have
5 already been licensed by December something, 2015.

6 MEMBER KIRCHNER: Right.

7 MEMBER PETTI: So, I mean, unless you, are
8 you thinking the ice condenser containments?

9 MEMBER KIRCHNER: No, no, no. I'm just
10 thinking of the implication of saying up to TBS is
11 design basis, beyond TBS is -- sorry, I misspoke
12 again.

13 Up to TBS is the design basis accident,
14 and beyond is, greater than TBS is beyond design basis
15 accident.

16 And I'm just going through the, I'm going
17 through 10 CFR 50 very quickly in my head and trying
18 to think through all the implications of that.

19 MR. LEHNING: This is John Lehning again.

20 And I think maybe there's just some
21 terminology issues that I wanted to point out that
22 beyond design basis in this instance doesn't mean that
23 it wouldn't need to be considered in the plant design.
24 It just means that it would be consid -- it could be
25 considered, potentially, according to less restrictive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 conservativisms and so forth.

2 But there's really three categories of
3 things. And some other countries may do it different
4 with design Category 1, 2, and 3 or what have you.
5 But, in essence, this beyond transition break size,
6 per the requirements here it would need to be
7 considered in the design but just in a more realistic
8 way potentially than that transition and below those
9 ranks, if that's clear.

10 So, I would agree, I think, with the
11 premise that you made that you might expect that that
12 beyond transition break would be more, more limiting.

13 MEMBER KIRCHNER: Okay, thank you.

14 MR. MESSINA: All right. Next slide.

15 So --

16 MEMBER ROBERTS: Sorry, John. The question
17 is kind of plant lower their design containment
18 pressure based on this rule change?

19 Sorry, you said that way in the back.

20 MR. LEHNING: And, again, this is John
21 Lehning.

22 And I think that's a possibility. But
23 there are other breaks that -- a steam line break in
24 containment that may limit some plants, depending on
25 their design. And there may already be somewhat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 realistic methods being used in their analysis.

2 But I would say, in theory, it is a
3 possibility that this could be, if that plant has a
4 limiting break for the double-end guillotine and they
5 have some conservatisms built in, it's possible that
6 they could look at this change and then potentially go
7 to a different method that is more realistic and maybe
8 lower, at least lower the -- gain more margin that
9 way, I guess I would say.

10 MEMBER ROBERTS: Okay, thanks.

11 MR. MESSINA: Paragraph (f) of 50.46c has
12 fuel performance criteria. And there are four
13 criteria here:

14 Address cladding degradation phenomena;

15 Maintain fuel coolability;

16 Avoid explosive concentration of
17 combustible gas;

18 And demonstrate long-term cooling.

19 Now, these criteria, one is based from the
20 previous 40.56c rule. So, under Item 1 we would
21 expect, you know, a PCT limit, a local oxidation limit
22 that are, you know, for example, currently in the rule
23 and may have been in 50.46c final rule language.

24 And those guidance for addressing these
25 criteria are in DG-1263 for Zr-UO2 fuel. And, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know, licensees would address those 50.46c
2 embrittlement research findings.

3 And this, these, this paragraph is fuel-
4 technology neutral, so there wouldn't be, need to be
5 an exemption if, for example, more advanced fuels are
6 used such as maybe, maybe non-UO2 or silicon carbide
7 fuel if they need an exemption to this paragraph.

8 MEMBER HARRINGTON: Joe, this is Craig
9 Harrington. This is not a change that you made, but
10 can somebody comment on the sort of convoluted wording
11 after any calculated successful initial operation of
12 the ECCS? What's hiding behind that statement?

13 MR. MESSINA: We were intending for it to
14 mean long-term cooling. Decay heat's removed for the
15 core.

16 MEMBER HARRINGTON: Just, I don't know,
17 the -- it says calculated successful initial
18 operation. It just -- and I mean, I know you haven't
19 changed anything there. It's a legacy set of words,
20 but just seems odd.

21 CHAIR BALLINGER: Yes, is there something
22 that's not successful?

23 MR. MESSINA: If it's not successful you
24 don't get to the next phase of the analysis, right,
25 which is removing --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 (Simultaneous speaking.)

2 CHAIR BALLINGER: Yes, you really don't
3 pass go.

4 MR. MESSINA: Right.

5 CHAIR BALLINGER: Yes.

6 MR. MESSINA: So you fail the first
7 criteria.

8 MEMBER HALNON: Yes, this is Greg Halnon.
9 Isn't this -- have to do when you have an actual
10 operation, you go back, analyze and make sure that
11 there was enough flow going through it based on back
12 pressure and everything else?

13 MEMBER HARRINGTON: So a retrospective
14 look kind of thing, Greg?

15 MEMBER HALNON: Yes, I believe that's what
16 this means is that if you do have a successful --
17 because you have inadvertent operations. I'm not
18 going to say all the time, but occasionally. You can
19 go back through the event reports and see that. And
20 we always did an analysis of the flow rates to make
21 sure that it was operating correctly. So I don't know
22 if that's the same thing, but that kind of rings a
23 bell for me.

24 MEMBER HARRINGTON: Okay. Maybe so. It
25 just seemed odd wording.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: Yes, when I read it I
2 thought that first set off my commas is make sure you
3 quench the core. And then the second is make sure you
4 can still do long-term cooling, right?

5 PARTICIPANT: That's how I read it, yes.
6 That's --

7 MEMBER PETTI: But I agree the words don't
8 -- doesn't say that. You need an interpreter of it,
9 yes.

10 MR. LEHNING: Joey, I could just add to
11 that a little bit. I think it's just commenting on
12 the fact -- and John Lehning again speaking from the
13 staff -- that there was more of an understood or
14 engineering nature to this long-term core cooling, at
15 least initially. And so the thought was that these
16 criteria in paragraph B, 2200 and so forth, that those
17 were for the initial operation, but then by just
18 demonstrating at least at that time that you continue
19 to provide the flow, you continue to keep it covered.
20 Then it's pretty much understood that you'll be able
21 to continue to do those things now.

22 I mean, as time went on we've realized
23 things like foreign precipitation and other things so
24 it's not always that simple especially for some of the
25 newer reactor designs. But I believe that that is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thought behind this wording that was again from the
2 original rulemaking back in 1973 time frame.

3 DR. BLEY: Dennis Bley. Listening to
4 this, I guess where the discussion started everything
5 else I've been hearing says that demonstrate that
6 after any successful initial operation of ECCS
7 everything works right. But the calculated successful
8 initial operation is the thing I think that makes
9 everybody hang up here. Yes. But, no, at least I
10 find confusing.

11 CHAIR BALLINGER: I'm just wondering why
12 you need the words between the two commas.

13 MEMBER PETTI: We can --

14 (Simultaneous speaking.)

15 MEMBER PETTI: -- because there's two
16 functions. You have to quench the core.

17 CHAIR BALLINGER: Okay. I got that.

18 MEMBER PETTI: And then you have to have
19 long-term cooling.

20 CHAIR BALLINGER: Right. But --

21 (Simultaneous speaking.)

22 CHAIR BALLINGER: -- successful.

23 MEMBER PETTI: But there was all sorts of
24 discussions about could you quench in the very early
25 days and re-flood and all the hydrodynamics there and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 all of that contentious in the earliest days because
2 the codes weren't anywhere near as good as they are
3 today.

4 CHAIR BALLINGER: But would you calculate
5 an unsuccessful operation?

6 MEMBER HARRINGTON: I think the intent is
7 clear, but -- broadly, but that sort of suggests that
8 if you calculated that it's not successful, then you
9 just go on about life. That makes no sense. It's
10 just curious.

11 MEMBER KIRCHNER: Could you enumerate --
12 could you explain further No. 3? This is a surrogate
13 for in effect -- well, 1 percent of the zircoloid
14 cladding inventory being oxidized.

15 MR. MESSINA: Correct. Yes. So the
16 current rule has the 1 percent hydrogen generation in
17 the rule so we're making this more performance-based
18 and moving that to the guidance document.

19 MEMBER KIRCHNER: Okay.

20 MR. MESSINA: Because other claddings may
21 produce possibly different combustible gases, silicon
22 carbide, maybe it's carbon dioxide that is produced
23 from (audio interference).

24 MEMBER KIRCHNER: But often assuming that
25 you have this break in the primary system, then the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 implication is that your concern is either a
2 combustible mixture in the primary system and/or the
3 containment. I mean, will the guidance address where
4 -- what's -- how do you determine that? It's design-
5 specific.

6 MR. MESSINA: I think the guidance goes
7 back to what's basically in the current rule. If
8 James wants to talk more about what's --

9 MR. CORSON: Yes.

10 MR. MESSINA: James, go ahead.

11 MR. CORSON: Yes, this is James Corson
12 from the staff. So I'll say a little bit about this
13 tomorrow, but basically in the guidance for zirc-based
14 cladding we have just the exact same limit that's in
15 the current rule.

16 MEMBER KIRCHNER: Okay.

17 MR. CORSON: So there's no guidance for
18 how to come up with a different criterion. If
19 industry wanted to come up with something different,
20 they could propose it. We could review it as we do
21 anything else. But for now we just moved the
22 prescriptive requirement from the rule to guidance.

23 MEMBER KIRCHNER: Okay. Thank you.

24 MEMBER PETTI: Joe, just in terms of the
25 actual words does it say avoid an explosive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 concentration or does it say avoid explosive
2 concentrations? Because there could be hydrogen
3 gradients in the containment and there could be
4 pockets and the like because it's lighter than -- the
5 steam is going to condense and there's also some
6 mixing dynamics that the codes calculate.

7 MR. MESSINA: I think it might be as
8 written here.

9 MEMBER MARTIN: (Audio interference) on
10 all these, the last one with -- I'm familiar with
11 oxide from my background. When you say look at
12 effects of crud and oxide, is kind of a deterministic
13 sense or are you still allowing for realistic models
14 that can treat these with uncertainty? And the crud
15 part, I didn't think we had the science. I mean, I
16 know we had Bearer and Castle (phonetic) and all that
17 and I -- whether we're even there to really fully
18 appreciate the effects of crud, maybe that's not
19 captured in the guidance. But that's kind of new,
20 too, isn't it? So I had kind of two questions, but --

21 MR. MESSINA: So this part was exactly
22 what was basically in the 50.46c draft final rule. So
23 generally I believe people assume a certain amount of
24 crud is on the rod in their analyses.

25 CHAIR BALLINGER: Yes, I think 80 or 100

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 microns is usually the limit, right?

2 MR. MESSINA: I don't recall --

3 CHAIR BALLINGER: Yes, I think the heat
4 transfer gets a little bit impacted if it's above some
5 number, but I thought it was either 80 or 100 microns.

6 MEMBER MARTIN: So going back to the first
7 question about do you treat that deterministically or
8 is this -- it's captured as an uncertainty parameter?

9 MR. MESSINA: That would depend on where
10 you are in the break spectrum, so above the transition
11 break size you might not need to consider all of the
12 uncertainties that you typically do today.

13

14 CHAIR BALLINGER: I mean during refuelings
15 they do measure -- they do look at this.

16 MEMBER MARTIN: Okay. So they have that
17 information. They could use realistic --

18 CHAIR BALLINGER: Yes.

19 MEMBER MARTIN: And then below -- I mean,
20 again think about how these methods are done, the best
21 estimate plus uncertainty methods. Pretty much
22 everyone does non-parametric methods, create
23 distributions, they sample from them, and you get what
24 you get. Can we create a new -- I mean, is this a new
25 figure of merit? Anyway, it seems a secondary to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ultimately what you're looking for is just the
2 integrity of the fuel. If you have explicitly
3 incorporated uncertainties associated with crud and
4 oxide into your inputs, which is -- again, it's input-
5 driven. You get an output on the temperature of the
6 fuel. Have you satisfied the criteria? Are you
7 looking for something -- by explicitly saying it, are
8 you looking for another add-on to the analysis?

9 MR. MESSINA: No, it's just making sure
10 that it's considered. And this dates back I believe
11 to a PRM that was submitted.

12 James, do you mind jumping in?

13 MR. CORSON: Yes, I was just going to --
14 like you said, Joey, this comes from the 50.46c days.
15 There was a petition for rulemaking that was lumped in
16 with 50.46c that asked us to explicitly consider the
17 thermal effects of crud and oxide layers. So this is
18 just something that -- when we combined basically what
19 was in 50.46a with 50.46c for this current rule, this
20 is something that was just carried over and not
21 changed.

22 So it's just to make clear in the analysis
23 that needs -- this needs to be accounted for somehow.
24 So how you actually would account for it -- whether
25 you do a deterministic thing or a statistical thing I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 think comes down to the licensee and whatever methods
2 that they choose to use both above and below the
3 transition break size.

4 MEMBER MARTIN: Well, and there was always
5 this challenge because if you do an analysis to
6 determine the maximum oxidation, right, you would
7 start off with (audio interference), right? You'd
8 start off with a clean rod. But if you put the oxide
9 on there, you've already reacted, right? So either
10 you deterministically treat it like we used to do back
11 -- way back when and do multiple analyses -- although
12 when you bring in the uncertainty analysis methods,
13 you just say that, well, as long as you considered it
14 as an uncertainty parameter, it's there as an input,
15 it satisfies the intent of the regulation. So it's a
16 different way of looking at the problem, but it's --
17 I think, Joey, you said it, that it's kind of as long
18 as you incorporate into the input and --

19 MR. MESSINA: Yes, I mean, it's not --

20 MEMBER MARTIN: I mean, the devil's in the
21 detail when you look at the methodologies, but you
22 elevate it when you put of course a line item like
23 that. (Audio interference) the crud's kind of (audio
24 interference). Just treat the same way as he oxide?

25 MR. LEHNING: Sorry, Joey. Just a quick

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 comment on the combustible gas on that question.
2 There are requirements for a mixed atmosphere in 10
3 CFR 50.44 and the guidance there. So we do -- in this
4 regulation I think we are focused a lot on the total
5 amount. And then there are other regulations and
6 requirements that speak to that, just to answer that
7 previous question.

8 MR. MESSINA: Next slide, please? So on
9 fuel coolability -- so you'll notice that it doesn't
10 -- coolability doesn't -- the phrasing doesn't change
11 drastically from the current rule, but we had a
12 discussion in the FRN or -- the Statements of
13 Consideration or if you want to call it the preamble
14 as it's now called -- its clarification on the
15 interpretation of coolability. So we say above the
16 transition break size. We can envision that some
17 amount of dispersed fuel would be expected to remain
18 coolable and safe during a LOCA so that it -- if it is
19 shown to be safe, then it may be acceptable for LOCAs
20 greater than the transition break size.

21 And but we did outline two scenarios that
22 would remain undesirable, which is widespread brittle
23 failure -- you don't want to fracture a significant
24 portion of your core and lead to complete destruction
25 of the core, core geometry, the fuel bundle geometry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And we still want to make sure that
2 there's no fuel or cladding melt during a LOCA. We
3 are not saying that this is a severe accident. We're
4 saying it's a beyond-design-basis accident. Severe
5 accidents usually would allow for fuel cladding melt.

6 And DG-1434 explicitly provides guidance
7 for analyzing the consequences of fuel dispersal.

8 Next slide, please? This slide just
9 basically says that NRC-approved fuel designs that
10 have specific ECCS performance requirements that have
11 been established should be used in the reactor and
12 mentions the importance of LTAs at the end of the
13 first paragraph. And this comes directly from 50.46c,
14 that direct final rule language.

15 Next slide? So I'll go into paragraph H.
16 And this I'll note at -- this will be talked about
17 more in the guidance that Kristy Bucholtz will be
18 presenting after me. And this is for guidance on --
19 this is rule language on changes enabled by 50.46, the
20 changes made under this rule.

21 An overview of this -- and I'll provide
22 some words on each of these paragraphs. (h)(1) is
23 about changes enabled under this section that are
24 allowed without prior NRC approval. (h)(2) are
25 changes enabled by this section not permitted under

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 (h)(1), so not allowed without prior NRC approval.
2 (h)(3) are criteria that all changes enabled
3 implemented under this section must meet paragraph
4 (h)(4), PRA requirements; and (h)(5), non-PRA
5 requirements.

6 Next slide, please? So changes enabled
7 under 50.46a are allowed without prior NRC approval if
8 it's allowed under 50.59 and the appropriate -- the
9 NRC-approved risk-informed evaluation process that
10 demonstrates that any increases in estimated risk are
11 minimal, and the requirements in (h)(3) are the
12 requirements that all must changes must be -- are met,
13 and that's no significant increase in LOCA
14 frequencies.

15 Next slide? Paragraph (h)(2) is the
16 things not permitted under (h)(1), not permitted with
17 prior NRC approval and they must provide this list of
18 information. And the second bullet I'll highlight.
19 Demonstration from the risk-informed evaluation
20 process that the total increases in CDF and LERF are
21 very small and the overall risk remains small. And
22 now these metrics come from the Commission SRM in
23 2007, SRM-SECY-07-0082 as denoted at the bottom of the
24 slide where the Commission directed the staff that we
25 should restrict changes to the plant to very small

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 risk increases. And I have what is enriched numbers
2 there.

3 MEMBER PETTI: So, Joe, just a question.
4 I mean, I understand the words, but large-break LOCAs
5 have never really dominated the CDF or the LERF in a
6 PRA. So it would seem like there's a lot there that
7 will not translate through in the end. Is that a
8 fair --

9 MR. MESSINA: Yes, and this is to ensure
10 that -- right now they don't dominate the CDF, but
11 changes made under this rule -- maybe they become more
12 significant. And then --

13 MEMBER ROBERTS: But, Dave, not to go
14 back, but the whole discussion about containment
15 pressure, the change allows the containment pressure
16 be reduced in maybe more severe accident scenarios
17 that are of interest and they (audio interference)
18 because of the transition break size, because of the
19 reduced containment pressure that goes with that. And
20 the containment pressure for severe accidents won't go
21 down like the loss of coolant accident pressure does.
22 Again, just a thought of maybe that the side effects
23 of this change might be a bigger deal from a risk
24 perspective than the actual main change being pursued.

25 MEMBER PETTI: Yes, that's what I thought,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 but there seems to be -- I guess I'm just not
2 convinced that all the Is are dotted and Ts are
3 crossed in terms of -- someone ought to be running a
4 calculation given the new rules of the road on what it
5 really means in some of these areas. There may be
6 secondary effects that we haven't thought of.

7 MR. MESSINA: Yes, and we would review
8 these changes and -- if the ECCS evaluation determined
9 they meet the LOCA criteria on a plant-specific basis
10 and in the LARs and whatnot.

11 And then these others are that overall plant
12 risk should not change drastically and that the --
13 again, no significant increase in LOCA frequencies.

14 Next slide, please? So this is all
15 changes made under this section must meet the
16 following criteria. So if it's a risk-informed rule,
17 a risk-informed -- so we looked at some the -- these
18 are fundamental to risk-informed regulation and that
19 adequate defense-in-depth is maintained, safety
20 margins are retained, and adequate performance
21 measurement programs are implemented.

22 Next slide, please? So here are the PRA
23 requirements. So they must address initiating events
24 from sources both internal and external to the plant
25 and that -- and for this -- I wanted to mention on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 first one we would expect that low-power and shutdown
2 conditions would be addressed with non-PRA methods.
3 The original 50.46a rule had explicitly stated that
4 low-power and shutdown PRAs need to be there and --
5 but we have relaxed that to allow for it to be
6 addressed with non-PRA methods.

7 And No. 2, it must reasonably represent
8 the current configuration of the plant. It must have
9 sufficient technical acceptability at the level of
10 detail to provide confidence that the total risk
11 estimates and changes in total risk estimates
12 adequately reflect the plant and the effect of the
13 proposed changes on risk, and the PRAs must be -- is
14 done under peer review.

15 Next slide, please? Non-PRA requirements.
16 This is basically just saying we must reasonably
17 reflect the current plant configuration and operating
18 practices.

19 Yes?

20 MEMBER PETTI: Just a question. I kind of
21 have lost a thread. I thought only Part 52 required
22 PRAs. And Part 50 out of the alignment we were going
23 to require 50 to have PRAs. But that's not final yet,
24 is it?

25 MR. MESSINA: I'm not sure about that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rulemaking, but on this rule as a risk-informed rule
2 we -- it's a major --

3 (Simultaneous speaking.)

4 MEMBER PETTI: So you're imposing a PRA
5 requirement if you take this path?

6 MR. MESSINA: Yes.

7 MEMBER PETTI: Okay.

8 MS. CLARK: This is Theresa Clark. Just
9 to add on. So this is one of the things that we're
10 looking at as it goes through concurrence. The Part
11 50/52 rulemaking, which was considered separately, was
12 about new reactor design applications and sort of
13 harmonizing the requirements, whether you come in
14 under a Part 50 construction permits space or a Part
15 50 combined license space.

16 This is sort of a different context. For
17 this rulemaking the idea is that if licensees
18 voluntarily want to use this alternative approach,
19 they would largely (audio interference) PRA option.
20 They'd largely be using PRAs for it just like they use
21 to adopt other voluntary things like risk-informed
22 tech specs. So we have some sort of high-level
23 requirements for the quality of the PRA that they
24 would need to use, but most of it's in guidance rather
25 than in the rule itself.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: Okay. No, thanks. That
2 helps.

3 MR. MESSINA: And Kristy had her hand up.

4 MS. BUCHOLTZ: Yes, this is Kristy
5 Bucholtz. So I am representing a PRA oversight branch
6 in Division of Risk Assessment working this
7 rulemaking. So I will talk about this more in the
8 next presentation that I'm going to give, but the way
9 the rule is written is it's written to work with both
10 a PRA and non-PRA requirements, right? So there is --
11 the way it's written doesn't technically require you
12 to have a PRA, but what it does do is requires you to
13 be able to quantify both your core damage frequency
14 and your large early release frequency in order to
15 pass the acceptance criteria, right? So --

16 MEMBER PETTI: Okay. I'm not a risk
17 expert, but --

18 MS. BUCHOLTZ: Right. So --

19 MEMBER PETTI: -- it's not (audio
20 interference) PRA.

21 (Simultaneous speaking.)

22 MS. BUCHOLTZ: Right. So I'll talk about
23 it more, but if you can quantify it without using a
24 PRA, right, you can use it. In other words, if you're
25 making a change that can be qualitatively assessed and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you have your baseline numbers already established --
2 because most of our operating fleet right now has
3 already adopted the Surveillance Frequency Control
4 Program.

5 So we all -- they all -- all the current
6 operating light water reactors have a -- at least a
7 base-level PRA available. So they could use that
8 model that they already have and their numbers in --
9 they can use that model along with new qualitative
10 non-PRA assessment methods to use this rule, if they
11 choose to. And I'll talk about it more in the next --
12 in the risk-informed discussion that I'll be giving
13 next, so --

14 MEMBER PETTI: Okay. No, thanks. That
15 helps.

16 MR. MESSINA: Thanks, Kristy.

17 Next slide, please? So this paragraph
18 states that the director of NRR can impose
19 restrictions on operation if ECCS cooling performance
20 is not consistent with the requirements. And this is
21 maintained from the current rule. And every proposed
22 iteration of the rule has had this as well, so this
23 isn't anything new.

24 Next slide, please? On reporting, (j)(1)
25 and (j)(2) talk about ECCS reporting and corrective

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 actions. It's largely the same as in the current rule
2 just with some clarifications on reporting
3 requirements and it matches largely what was in 50.46c
4 except for this first sub-bullet where we eliminated
5 reporting requirements for changes or errors that do
6 not result in an inability to assure compliance with
7 50.46a until an SDA or a DC is referenced in an
8 application for a CP, OL, COL, or manufacturing
9 license. So there's no impact on safety if no one's
10 currently planning to build a plant with this SDA or
11 DC. So we didn't think that it would -- they would
12 need to report these actions as the operating fleet
13 would. And this parallels what was proposed in the
14 Part 50/52 Alignment rulemaking.

15 (j)(3) is on risk assessment reporting.
16 And I mentioned earlier that the five-year PRA updates
17 were removed from the rule during concurrence and
18 concurrently this risk assessment reporting was
19 removed from the draft proposed rule during
20 concurrence.

21 Next slide, please? So under (h)(1) it
22 allows minimal changes without prior NRC approval.
23 Any minimal changes made under that paragraph would
24 need to be submitted every 24 months and there would
25 need to be a basis for the changes not invalidating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the transition break size.

2 Lastly, the welding inspection report must
3 be submitted within 120 days after completing an
4 outage where the inspections were performed. And this
5 can be combined with the summary report required under
6 50.55a.

7 Next slide, please? On paragraph K, first
8 we have what's considered as significant change to an
9 ECCS evaluation model for LOCAs at or below the
10 transition break size, and we describe it for
11 traditional UO2 zirc fuel. And that would be as is
12 today PCT greater than 50 degrees as well as we added
13 oxidation greater than 1 percent. And this matches
14 what was in the draft final 50.46c rule.

15 Next slide, please? For LOCAs above the
16 transition break size a significant change or error
17 could be proposed different from the previous
18 paragraph, but if alternate criteria are not defined,
19 then the same reporting criteria would be expected to
20 be applied to 50 degrees PCT and 1 percent ECR. And
21 then paragraph 3 allows for non-UO2 zirc fuel to --
22 they would have to define their own -- what is
23 significant change.

24 Next slide, please? Go back. Okay. So
25 lastly, I wanted to discuss the changes to the base

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 50.46. So there were some corresponding changes we
2 made to 50.46, mainly in applicability. 50.46 or
3 50.46a could be used if XYZ, which kind of parallels
4 the applicability section in 50.46a. We did not want
5 to touch much of the other criteria in 50.46 such as
6 the 50.46b criteria, such as 2200 PCT and 17 percent
7 ECR because we wanted to as much as possible limit the
8 scope of the rule and possible delays that would be
9 entailed by changing these requirements.

10 Our rule is voluntary, so there are other
11 considerations that we would need to go through if we
12 decided to change those 50.46b limits. But we did add
13 a statement that if you do not meet the cladding and
14 fuel specified at the beginning of current 50.46,
15 which says UO2 pellets within zircaloy or ZIRLO
16 cladding, that you can meet -- instead you could
17 choose to meet 50.46b, so the current rule, 2200 or 17
18 percent, or if you meet 50.46a(f)(1), which is the
19 address cladding degradation and those four criteria
20 that I went through previously. So this allows for
21 new fuel types to be implemented without an exemption
22 if people wanted to pursue it that way or they could
23 elect to still request an exemption to 50.46b
24 criteria.

25 Walt?

1 MEMBER KIRCHNER: Yes, thank you.
2 Cladding degradation is rather an amorphous phrase.
3 I want to point back to this 17 percent. The 17
4 percent; and perhaps I could be corrected if I'm
5 wrong, is different than the 1 percent of the zirc
6 being oxidized. That was more with regard to hydrogen
7 generation and concerns about combustion either in the
8 reactor system, primary system and/or containment.
9 But the 17 percent, if I remember correctly, really
10 had its origin in the idea that that was a limit that
11 would to first order provide structural integrity for
12 the zircaloy claddings.

13 MR. MESSINA: Yes, the 17 percent was --

14 MEMBER KIRCHNER: So that core coolability
15 would be maintained to first order and configuration
16 of the core would basically remain intact. So you're
17 opening the door to essentially large-scale core
18 relocation if there's not further specificity on what
19 you mean by cladding degradation.

20 Now the end state, as has been pointed out
21 by one of my colleagues in a previous subcommittee
22 meeting -- I mean, the TMI core melted down
23 substantially but was coolable. That's probably not
24 what we're looking for in a design-basis accident
25 situation in an LWR. So where are the boundaries on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this and how much relocation and reconfiguration of
2 the core do you see being acceptable?

3 MR. MESSINA: So yes, the 17 percent is
4 meant to preclude embrittlement of the cladding for
5 structural purposes and maintaining -- keeping the
6 fuel pellets in the cladding. To address cladding
7 degradation phenomena, that -- they would be expected
8 to address that oxidation, so the oxygen ingress into
9 the cladding that effects -- the embrittlement effects
10 of that. That is just in guidance.

11 So there's a 50.46c graph that says
12 percent ECR is a function of hydrogen. So that is in
13 DG-1263 that James will present tomorrow. So we would
14 still expect licensees to address this cladding
15 embrittlement that is addressed by the 17 percent.
16 The 50.46c research findings stated -- basically found
17 that 17 percent was not necessarily conservative with
18 the 2000 PCT limit due to the fact -- due to the
19 impact of -- the impact that hydrogen has on
20 embrittlement of the cladding. So that curve of ECR
21 versus hydrogen is in that draft guide and we would
22 expect them to address that embrittlement mechanism.

23 MEMBER KIRCHNER: But just for rhetorical
24 purposes to explore the implications, what's your
25 sense of what would be acceptable in terms of a large

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 relocation of the core?

2 MR. MESSINA: We don't necessarily know.
3 If there is a large relocation of the core, I would
4 expect that licensees would be -- would provide that
5 basis. James has a Reg Guide addressing the
6 consequences of fuel dispersal, so that's kind of how
7 they would demonstrate safety

8 James, go ahead.

9 MR. CORSON: Yes, this is James Corson
10 from the staff. So yes, as Joey said, I'll be talking
11 about this more tomorrow when I go into Draft Guide
12 1434. So that's just like one -- that Guide basically
13 represents like one idea of what we would find
14 acceptable. So at a high level what we're trying to
15 do is prevent melting of the fuel or some wide-scale
16 brittle failure of the cladding. And so like the
17 existing 50.46 criteria were really meant to prevent
18 that latter scenario where you have wide-scale brittle
19 failure.

20 MEMBER KIRCHNER: Exactly.

21 MR. CORSON: And we still have
22 requirements for that. On top of that, this new
23 requirement where you have fuel dispersal, we also
24 want to prevent that from escalating into a situation
25 where you either melt fuel or that bumps up your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cladding temperature enough to lead to widespread
2 brittle failure.

3 So that's what -- the Guides are trying to
4 prevent those sorts of situations from happening and
5 they do lay out ways that we find acceptable to meet
6 these requirements.

7 MEMBER KIRCHNER: Yes, the guidance is not
8 regulation.

9 MR. CORSON: It is not. But yes, I mean,
10 I think in a lot of ways we're moving in a way to make
11 our regulations a little more flexible and to have the
12 details in guidance.

13 MEMBER KIRCHNER: So you want to allow the
14 flexibility to have a widespread disruption of the
15 core as a design-basis accident?

16 MR. CORSON: So I think the guidance is
17 meant to prevent a wide-scale disruption. What we're
18 talking about is a much -- so if you're talking about
19 fuel dispersal due to ballooning and burst of the
20 cladding -- I'll get into this a little bit more
21 tomorrow -- but so far analyses suggest it's a pretty
22 limited amount of fuel. So certainly less than 1
23 percent of the fuel. Perhaps much less than 1 percent
24 of the fuel. So it's relatively limited. And what
25 we're trying to do is prevent that from turning into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 widespread disruption of the core. So yes, we don't
2 want widespread disruption and that's what our
3 requirements are trying to prevent.

4 MEMBER KIRCHNER: I'm not seeing it. And
5 remember, this is just one member's opinion. Now I'll
6 wait to see -- I will be interested to see the
7 guidance, but the implications here are significant.

8 Now it turns out if we're being candid
9 with each other, we know with the existing fleet and
10 estimates of higher burnup with some of the advanced
11 zircaloy claddings that at breaks below 10 or 12
12 inches, whatever, in a PWR the differential pressure
13 is probably not going to lead in a -- in one of these
14 LOCAs to ballooning and discharge or dispersal of
15 fuel. So I'm trying to explore why we're not asking
16 the licensee to preclude this situation.

17 In other words, one criterion that we've
18 seen some applicants use is no rupture. That takes
19 the dispersal off the table.

20 MR. MESSINA: Yes, we think that it's
21 possible for industry to demonstrate that some amount
22 of fuel dispersal into the coolant would be safe, and
23 we'll see -- we provide guidance on that.

24 And on the other topic of moving some of
25 this into guidance, we do have that 50.46c SRM from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 earlier this year that explicitly asked us to consider
2 whether certain prescriptive criteria such as core
3 temperature like the PCT should be placed in -- should
4 be codified or placed into the guidance. So part of
5 this is based on the Commission SRM that we basically
6 need to have -- be more performance-based in our
7 regulations and maybe have more specifics in guidance.

8 MEMBER KIRCHNER: No, I accept that. I
9 mean, there's nothing magic about 2200 degrees
10 Fahrenheit. It's highly likely that there would be
11 wide-scale ballooning if a large part of the core
12 reached that temperature, and probably well before
13 2200. So that's a historical number. It was, at the
14 time in the '70s, thought to be a rather conservative
15 estimate of structural integrity for zircaloy clad.

16 We've seen quite a bit of progress both in
17 -- on behalf of the fuel vendors, they've improved the
18 cladding materials significantly in terms of hydrogen
19 uptake and other issues that make for a more resilient
20 clad. But the direction is to preclude rupture is a
21 much more reasonable criterion than 2200 or some magic
22 17 percent oxidized.

23 That's an observation, not a question, but
24 I'm concerned that the -- what you're proposing for
25 the rulemaking doesn't necessarily -- where you take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 out the peak clad temperature and you take out the 17
2 percent oxidation that you're getting a comparable set
3 of requirements in terms of core performance under a
4 design-basis accident.

5 CHAIR BALLINGER: This is Ron Ballinger.
6 As a practical matter that's why I was asking the
7 question this morning. The data that we now have
8 related to embrittlement and the like, whether that
9 would get translated into it and be laid on people
10 that did not want to use the rule. Because 17 percent
11 with the new data that they have doesn't really exist
12 as an allowable because as soon as you get any burnup
13 with any hydrogen, with any cladding, the allowable is
14 less than 17 percent, for sure.

15 And so I'm still confused on how that data
16 would not -- you say backfit would be -- somebody
17 comes in and says I want to use 17 percent and you
18 come back and say, well, wait a minute, this data that
19 we have here says you can't. Well, you say, well, the
20 rule says I can. Now what do you do? Because if
21 you're lower than 17 percent, that in effect lowers
22 the 2200. It doesn't lower the limit, but it --
23 during an accident if you're allowed only 14 percent,
24 whatever the number is, to get to that you have to --
25 to get to that number you'd have to be at a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 temperature much longer and at a lower temperature
2 than 2200. Am I reading this wrong?

3 MEMBER KIRCHNER: No, I'm not trying to
4 defend or question the 17 percent. The functional
5 intent of the 17 percent was to maintain cladding
6 integrity so that the core didn't turn into a rubble
7 bed. So I don't see substituting cladding degradation
8 as achieving the same intent. How much degradation?

9 MR. MESSINA: That's in guidance. So
10 basically the 17 percent. Not exactly 17 percent, as
11 Ron talked about. The oxidation as a function of
12 hydrogen has been placed in the guidance to achieve
13 that objective.

14 CHAIR BALLINGER: But isn't the oxidation
15 limit, regardless of what it is, designed to prevent
16 brittle failure of the fuel?

17 MR. MESSINA: Yes.

18 CHAIR BALLINGER: Yes.

19 MEMBER KIRCHNER: Yes, that's what it was
20 there for.

21 CHAIR BALLINGER: Yes.

22 MEMBER KIRCHNER: Especially when you
23 quench the core during re-flood.

24 MR. MESSINA: Yes, maintain post-quench
25 ductility, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Yes. Tomorrow will be
2 interesting.

3 (Laughter.)

4 MR. MESSINA: Yes, we believe that --

5 MEMBER PETTI: But philosophically this is
6 -- performance-based regulations allows flexibility.
7 And this is the trade-off that when you try to pull
8 back and do something that's a little bit higher
9 level, you don't get that specificity, which I guess
10 gives you a warm fuzzy. This gives you the
11 flexibility. That's the trade-off, right, to the --
12 we've discussed this in Part 53 ad nauseam, as I
13 remember.

14 CHAIR BALLINGER: But I don't see that the
15 guidance gives you a loophole. There's no loophole
16 here where all of a sudden you can go some other
17 direction.

18 MEMBER PETTI: No, that's --

19 MEMBER KIRCHNER: My point, Dave, isn't --
20 I'm not defending 17 percent or 2200. I think I
21 already made a case for no burst criterion, but the --
22 what I'm not seeing yet, and maybe it will be in the
23 guidance, is a little more clarity of intent for the
24 regulation itself. Degradation is rather a vague
25 phrase. Seventeen percent is rather an arbitrary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 limit. So I'm not going either way. The intent
2 though, that's what I'm not seeing. The intent was to
3 maintain the core integrity. And can you state that
4 in a performance manner rather than a prescriptive
5 temperature or oxidation limit?

6 DR. BLEY: Walt, this is Dennis Bley.
7 This is pretty naive, but it would seem that the rule
8 could state some high-level -- as you were saying,
9 some high-level statement of what --

10 MEMBER KIRCHNER: Intent or objective.
11 Objective is a better word.

12 DR. BLEY: Yes, I mean you're trying to
13 avoid wide-scale, kind of a definition of wide-scale
14 and we don't want this to happen. Then the guidance
15 tells you a way to meet that intent. But with the
16 intent not being in the rule it leaves it pretty much
17 up to who's ever around at the time deciding what it
18 means.

19 MEMBER KIRCHNER: Yes.

20 MR. MESSINA: Yes, and I think some of
21 this will probably be answered tomorrow in the Reg
22 Guide. And on the rule we do have that -- one of
23 those high-level criteria is maintain fuel
24 coolability. And as Ron has said, the PCT and 17
25 percent has traditionally been used to ensure core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 coolability in the past. So that overall objective is
2 still in the rule, maybe just not as explicit as --

3 MEMBER KIRCHNER: But again, you can cool
4 a debris bed, but I hardly consider a debris bed in
5 the bottom of the reactor vessel as a design-basis
6 accident, acceptable design-basis accident.

7 MR. MESSINA: Well, we are saying that
8 LOCAs above transition break size where we would allow
9 for this fuel dispersal is a beyond-design-basis
10 accident.

11 MEMBER MARTIN: This line of questioning
12 seems to be what exactly are the analyses above the
13 TBS intended to protect? Severe accidents tend to
14 focus on anything but the fuel, right? You're --
15 looked at the defense-in-depth analysis. You are --
16 it could be Chapter 19. The loads in severe accidents
17 are used in Chapter 3 for structure, containment
18 structure, non-safety equipment used to mitigate those
19 events. Maybe I&C could be most safety and non-
20 safety.

21 The ways things are looking here is that
22 you would expect a limited scope of equipment to
23 depend on analyses, the break size of EDS, and
24 probably not the fuel. If you eliminate -- you make
25 things best estimate, you eliminate single failure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Those analyses will probably be -- show lower loads
2 than your limiting rate below TBS. I don't think we
3 got clarity on what exactly this -- these analyses
4 above that size really cover.

5 Now, we can think about it and maybe come
6 up with our own list, and maybe in some of the
7 guidance you -- it's being clarified. But I think
8 that's kind of questioning we're getting into. And it
9 kind of goes back to the containment discussion. But
10 I would not think you would redo analyses of break
11 sizes above TBS for every reload because it would not
12 expect that a beyond-design-basis accidents analysis
13 would be looked at every single time. It should be
14 very easy to disposition just like the severe
15 accidents in Chapter 19 are easy to disposition.

16 But anyway, I think we're all going to go
17 back and look through and try to get some clarity on
18 the -- how do you delineate what is used where when it
19 comes to using analysis to determine adequate
20 protection. But I expect anything beyond-design-basis
21 is really kind of a defense-in-depth kind of analysis.

22 More a comment, but the question is out
23 there is that 100 percent sure whether those analyses
24 being used for to demonstrate a protection. And why
25 would you do -- necessarily do a beyond-design-basis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 accident analysis for every reload? It's only if
2 you're looking at it to assess the fuel, the integrity
3 of fuel, but then that becomes design-basis for the
4 fuel. Make it circular.

5 CHAIR BALLINGER: Any other questions?

6 (No audible response.)

7 CHAIR BALLINGER: I think tomorrow will be
8 an interesting -- like I said, an interesting
9 discussion tomorrow. And I'll have to go re-read the
10 preamble because I think there's something in there in
11 this -- what you call -- we used to call the Statement
12 of Conditions.

13 All right. So it's 3:49. I propose that
14 we take a break until 5 after 4:00. That' would be 15
15 minutes. So until that, we're in recess until 5 after
16 4:00.

17 (Whereupon, the above-entitled matter went
18 off the record at 3:49 p.m. and resumed at 4:05 p.m.)

19 CHAIR BALLINGER: Okay, we're back in
20 session and Kristy is remote, and so the floor is
21 yours.

22 MS. BUCHOLTZ: Thank you, and good
23 afternoon to everyone there. Like you said, my name
24 is Kristy Bucholtz and I am representing the PRA
25 Oversight Branch, which is in NRR's Division of Risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Assessment.

2 My presentation today is on Draft Guide
3 1426, and I managed to make it the longest title
4 possible and maybe next time I will consider cutting
5 it down a little, but, so it is an approach for the
6 risk-informed evaluation process and it's to support
7 the alternative acceptance criteria for the emergency
8 core cooling systems for light water reactors.

9 As part of the development of this
10 proposed rule, the NRC staff included the risk-
11 informed evaluation and the risk-informed evaluation
12 process that were included in the previously proposed
13 by discontinued rulemaking on the risk-informed
14 changes to the LOCA technical requirements. This
15 draft guide provides implementing guidance for that
16 process and addresses previous Commission direction.

17 As part of the development of the
18 previously proposed rule, the staff had received
19 comments. These comments were reviewed and changes
20 were made to the previous rule as a base point and
21 this draft guide.

22 So, going forward, the staff will consider
23 any additional considerations or feedback that is
24 provided on the risk-informed evaluation and the risk-
25 informed evaluation process that we receive during

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this rule-making process. Next slide, please?

2 So, I want to start off by talking about
3 the approach in the rule. So, paragraph (c)(iii)
4 requires a risk-informed evaluation to make any
5 proposed change. The way the rule is established, it
6 has basically two risk pathways. The first pathway is
7 on this slide and the second pathway is on the next
8 slide.

9 The first pathway is you can individual,
10 or individual submittals can be made for this
11 application. It would require a risk-informed
12 evaluation which would include a risk assessment of
13 the proposed changes.

14 It would allow multiple submittals. It
15 would be set up so that you have an initial adoption
16 of the rule, and then every future change enabled by
17 this rule would be also then submitted, right.

18 So, the initial and each enabled change
19 would be submitted for NRC's review, and then the
20 requirements that would need to be met are those
21 requirements that are in paragraph (h)(2). And it is
22 the equivalent of the acceptance guidelines in the
23 Draft Guide 1426, and I'll talk about those risk
24 requirements as we get further into the presentation.

25 So, the first pathway that an entity can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 do would be to do, well, like I said, I consider to be
2 the individual, somewhat independent changes, right.
3 Each one of them would be submitted and the risk
4 requirements in (h)(2) are the only requirements that
5 will apply. Next slide, please?

6 So, the other pathway that's in the rule
7 is that you can -- it's a voluntary process that they
8 can -- the whole rule is voluntary, but then there's
9 a voluntary process inside the rule where an entity
10 can decide to submit information for a risk-informed
11 evaluation process.

12 So, it is, that is still done through a
13 submittal to the NRC, all right. It still contains a
14 risk-informed evaluation with the risk assessment of
15 the proposed changes. What differs here is that the
16 risk-informed evaluation process is also submitted to
17 the NRC for approval.

18 So, they would provide a risk evaluation
19 that goes through this rule and shows that it's
20 appropriate to adopt the rule, and then as part of
21 that submittal, it would lay out a process that would
22 then be used to review any future enabled changes, and
23 then it gets screened slightly differently.

24 So, this process also is done through
25 multiple submittals, or can be done through multiple

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 submittals, and it also requires an initial adoption
2 of the rule, right, but that initial adoption, that
3 license amendment that comes in is going to have the
4 risk-informed process laid out in it in addition to
5 the risk-informed evaluation, right, like I said, and
6 that process is then used for future changes that are
7 enabled by this rule.

8 So, as an entity would review the future
9 changes, they would use their process, and it's
10 envisioned that they would use the process and come up
11 with a calculated risk criteria, right. We've
12 included this in the rule as (h)(1) and (h)(2).

13 If they calculate the risk of the changes
14 that they want to make and they are low enough that
15 they meet those provided in paragraph (h)(1), then
16 they can make the, a change without NRC approval. So,
17 it will use 50.59, and we'll talk about that in later
18 slides, but they will be able to make the change using
19 50.59 without NRC's approval.

20 However, if when they calculate the risk,
21 if the risk is higher than the threshold that's in
22 paragraph (h)(1), but it's lower than that in
23 paragraph (h)(2), they can still make the change. The
24 difference is it would then be submitted to the NRC
25 for our review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, they can still -- so they have two
2 different pathways in this pathway itself, right. So,
3 if they choose to do the risk-informed evaluation
4 process, they can use the two different metrics. If
5 they meet the one, they can make the change on their
6 own. If they don't meet the other one, they can still
7 submit it for NRC review and approval.

8 If it's above paragraph (h)(2), then it
9 would not be allowed, right. And like I said, I'll
10 talk about the risk metrics once we get through. So,
11 I just wanted to lay out that framework first. So,
12 there's two pathways.

13 You don't have to, an entity does not have
14 to adopt this risk-informed evaluation process that's
15 laid out in this rule. It's just a benefit to them if
16 they want to go ahead and choose to use it, so I
17 wanted to make that clear first. Okay, so please go
18 to the next slide?

19 So, now let's talk about the Draft Guide
20 1426. So, this is the structure of the draft guide.
21 It follows the same structure as Reg Guide 1.174. It
22 lays out the four elements that are in 1.174, right.

23 The first one to define the proposed
24 change, the second one is to perform your engineering
25 analysis, the third one is to define and implement the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 monitoring programs, the fourth is to submit the
2 license amendment, and then five and six follow on
3 with quality assurance and documentation. So, Draft
4 Guide 1426 is structured in the exact same way as Reg
5 Guide 1.174. So, next slide, please?

6 So, the first element was defining the
7 proposed change. This element follows the same
8 structure as Reg Guide 1.174. However, Reg Guide
9 1.174 is written for licensees that want to do a
10 change to their licensing basis. So, we did take the
11 wording that is in 1.174 and we did have to modify it
12 a little bit.

13 So, we did modify it from licensee to
14 entity so it makes it clear that it follows the rule,
15 and then we modified it from a licensing basis change
16 to a proposed change because some of the changes that
17 are allowed in here could be procedural changes that
18 are outside the licensing basis, but impact your risk
19 assessment, right.

20 So, we did change it to say it's any
21 proposed change that is being enabled by this rule,
22 right, and then we added sentences for an entity to
23 identify the aspects that may be affected.

24 So, whereas Reg Guide 1.174 just assumes
25 that you're changing the licensing basis and it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 assumes you need to use 10 CFR 50.90 for a license
2 amendment request, this program is structured where
3 you may be able to do changes under 50.59 once you
4 adopt the rule.

5 So, it does have written into this
6 guidance that an entity would look at the change, see
7 what it's affecting, whether it's the licensing basis,
8 whether it's an entity-controlled documentation or
9 anything else, and then choose the proper
10 implementation pathway that they want to pursue,
11 whether it's going to be under 50.90 or whether or not
12 it might be through 50.59. All right, next slide,
13 please?

14 So, for Element 2, Element 2 is performing
15 the engineering analysis. This is the main portion of
16 the document, and so this is kind of how it's
17 structured. So, Section 2.1 is the risk-informed
18 evaluation process, with Section 2.2 being all of the
19 risk assessment requirements, or I should say
20 guidelines, not requirements, guidelines in there.

21 So, Element 2 starts with an overarching
22 guidance that the scope, the level of detail, the
23 technical acceptability of the engineering analysis
24 should be appropriate for the nature and the scope of
25 the proposed change, and that uncertainties should be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 considered.

2 And regardless of the analysis method
3 chosen, right, you still have to show that you meet
4 the key principles. In this case, the initial
5 adoption of this rule would be to show that your
6 regulation is being met.

7 So, the four principles laid out in the
8 reg guide are the increase in risk, your increases in
9 your risk criteria, right, your defense in depth, your
10 safety margins, and your performance measurement
11 programs.

12 So, when it comes to Section 2.1, this
13 section discusses that risk-informed evaluation
14 process, and it's at a high level to start with, and
15 that it should be used to assess each enabled change.

16 This section also discusses that the risk-
17 informed evaluation process should be able to evaluate
18 the risk assessments that are going to follow under
19 Section 2.2, right. It also includes your performance
20 measures, some discussion of the performance measures,
21 which are further discussed under Element 3.

22 And then the risk-informed evaluation
23 process should be able to evaluate both risk pathways,
24 whether an entity choose to pursue 10 CFR 50.59 and if
25 the minimal risk criteria is met or if they choose to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 go 10 CFR 50.90 and put in a license amendment if the
2 very small criteria is met.

3 So, Section 2.2, like I said, discussed
4 the risk assessment. The goal of this section is to
5 estimate the total increase in risk from any facility
6 technical specifications and procedural changes that
7 are enabled by this rule, and it addresses the
8 principle that the proposed increase in the core
9 damage frequency and the large early release frequency
10 are less than that small and are consistent with the
11 intent of the Commission's safety policy statement.

12 This section discusses establishing a
13 baseline risk, excuse me, establishing a baseline risk
14 estimate to which comparison can be made. It allows
15 for both quantitative and qualitative assessments, and
16 it encourages a full-scope PRA, but doesn't require
17 it. It allows for the exclusion of out-of-scope
18 modes.

19 So, under Section 2.2.1, it discusses that
20 the probabilistic risk assessment, this section, it
21 immediately calls attention to Reg Guide 1.200 as one
22 approach acceptable to the staff for the acceptability
23 of PRA results for risk-informed activities, right.

24 It states that when Reg Guide 1.200 is
25 used in support of this application, it will obviate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the need for an in-depth review of the base PRA,
2 allowing staff to focus on the key assumptions and
3 areas identified by the peer reviews as being of
4 concern and relevant to the application.

5 This is the way we do most of our license
6 amendments that come in right now for the risk-
7 informed completion times, right. When Reg Guide
8 1.200 is used for those, we focus on those peer
9 reviews and the findings and observations that were
10 put in by the peer areas to ensure acceptability of
11 that, and so it is envisioned that this rule would be
12 structured in the same way for this risk approach for
13 the probabilistic risk assessment, right.

14 This section then goes on to address the
15 PRA's scope, the level of detail, and the technical
16 elements, and the plant representation, and the PRA
17 configuration control.

18 And throughout the whole section, it
19 continues to point to Reg Guide 1.200. It isn't
20 trying to replace it, but it's trying to work together
21 with Reg Guide 1.200 so we're not duplicating any more
22 than we need to for this draft guide with our current
23 position in Reg Guide 1.200.

24 So, Section 2.2.2, it discusses the non-
25 PRA risk assessment methods. It states that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 impact of the proposed change on operating modes and
2 initiators that are out of the scope of the PRA should
3 be evaluated and estimated, right.

4 So, non-PRA methods should use and produce
5 realistic results, and should either quantify an
6 estimate of the change in risk or it should
7 demonstrate that the change will not significantly
8 affect the out-of-scope modes and initiators.

9 So, this is where you can use a
10 qualitative assessment to show that you don't have to
11 do your shutdown in low power modes if they are not a
12 mode that would be significantly affected by the
13 change that's being proposed, right. The result --

14 MEMBER MARTIN: Kristy? This is Bob
15 Martin.

16 MS. BUCHOLTZ: Yes?

17 MEMBER MARTIN: Could you elaborate a
18 little bit more on maybe the scope of what non-PRA
19 risk assessments? You mentioned qualitative as kind
20 of the lead-in. I just am not sufficiently familiar
21 with alternative methods like, you know, considered in
22 this domain of non-PRA.

23 MS. BUCHOLTZ: Yeah, so because this
24 evaluates, it evaluates all internal events as well as
25 all external events, so like a good example here of,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we'll call it a non-PRA method, would be like a
2 seismic margin analysis.

3 You're not using a seismic margin, or
4 you're not using a seismic PRA to do your
5 calculations, right. You're using the seismic margin
6 analysis that's a well-established method that is
7 known throughout the industry.

8 So, this is written on a generic level to
9 use non-PRA risk assessment methods. There are other
10 methods out there. Like I said, all of them for the
11 most part should be NRC-reviewed and approved methods,
12 and we did put that in the guidance, but it would be
13 a method like that that would be used.

14 MEMBER MARTIN: What size of margin is
15 that? That sounds quantitative.

16 MS. BUCHOLTZ: Yeah, it can be.

17 MEMBER MARTIN: So, it's a mix?

18 MS. BUCHOLTZ: Yeah, it's a mix. So, it
19 can be qualitative. It can be quantitative. It
20 depends on what type of method is chosen whether it
21 will quantify or not. It could also be, for a non-PRA
22 risk assessment method, it could be a bounding
23 assessment as well, right.

24 So, they could do a bounding assessment
25 that would take like a seismic penalty or put a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 penalty in place for the risk that is a conservative
2 penalty that could be done depending on, like I said,
3 what it is that they're trying to estimate the risk
4 on.

5 MEMBER MARTIN: Yeah, one thought in
6 looking at the draft guide would be a footnote to
7 expand on maybe a definition of non-PRA risk
8 assessments just to clarify them.

9 MS. BUCHOLTZ: Okay, thank you. I will
10 take note of that.

11 DR. BLEY: Kristy?

12 MS. BUCHOLTZ: Yes?

13 DR. BLEY: Dennis Bley. Since you talked
14 about NRC-approved non-PRA methods, I'm very familiar
15 with the seismic one you talked about. Do you have a
16 catalog of those or examples of them that you can
17 point us toward?

18 MS. BUCHOLTZ: I would honestly have to
19 check and see if we have them written down. I mean,
20 we have different ones that are known that are used
21 all the time during, you know, fire assessments and
22 for seismic, but I'm not sure if they're listed
23 anywhere. I will actually have to check on that.

24 DR. BLEY: Yeah, it seems there has to be
25 at least some stemming quantitative aspect to it if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you're going to really make claims about risk from it.

2 MS. BUCHOLTZ: Right.

3 DR. BLEY: And the margins' analysis is
4 partially, at least the ones I'm familiar with, are at
5 least partially quantitative. They just don't carry
6 out the full risk assessment. Okay, it would be good
7 to see that.

8 MS. BUCHOLTZ: Okay. Okay, for Section
9 2.2.2, the non-PRA risk assessments, the resultant,
10 your resultant total change in risk should be tracked
11 and then combined with any PRA assessments.

12 So, if you do, if an entity does a mixed
13 blend of a risk assessment where they're using both a
14 PRA model to do the in-scope changes and they use a
15 non-PRA method for out-of-scope changes, that any risk
16 that's calculated from the non-PRA should be added to
17 the PRA assessment together for the total risk.

18 And it allows, and the non-PRA risk
19 assessment also allows use of maintenance rule to
20 determine risk significance if your equipment is
21 scoped into the maintenance rule, so that can be --
22 you can use that as a -- assuming that, like I said,
23 assuming you can show why it's technically adequate,
24 and that's the last part, right.

25 So, any basis for why the method employed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is technically adequate for the application should be
2 documented. So, if you use maintenance rule, the
3 seismic margin, or any other non-PRA risk method, it's
4 expected that the entity would just document why it's
5 adequate for this application to be used.

6 CHAIR BALLINGER: Vicki?

7 MEMBER BIER: Quick question. You said
8 any non-PRA assessments would be added to the PRA
9 results, and I assume that does not mean like
10 quantitatively added, like summed, but combined with
11 or presented together with, is that correct?

12 MS. BUCHOLTZ: Well, it's both. So, if it
13 was a qualitative assessment, it would be used to show
14 that it doesn't need to be -- so they would use it to
15 show that whatever they're analyzing is not a
16 significant contributor to the risk.

17 MEMBER BIER: Yeah.

18 MS. BUCHOLTZ: So, in that case, it would
19 be used in one package together to show that you've
20 covered all of your bullets. However, if they were
21 using a non-PRA risk method that did quantify a
22 number, that number would then be added to the PRA
23 assessment, and that's assuming that you're not
24 double-counting, right. So, we wouldn't --

25 MEMBER BIER: Yeah.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. BUCHOLTZ: -- assume that they're
2 using their PRA to do, you know --

3 MEMBER BIER: Sure.

4 MS. BUCHOLTZ: -- let's say they have a
5 seismic PRA, then they decided to do seismic margin
6 separately, and then, you know. So, we wouldn't want
7 double-counting, so the thought is that --

8 (Simultaneous speaking.)

9 MEMBER BIER: I guess it's --

10 MS. BUCHOLTZ: Sorry.

11 MEMBER BIER: It's difficult for me to
12 visualize how a non-PRA method would give a
13 probability as an outcome that could be added to the
14 PRA probability, but maybe I'm just not aware of what
15 people are doing.

16 MS. BUCHOLTZ: Yeah, this comes in a lot
17 of times when they'll put like a penalty in place,
18 like sometimes they'll put a penalty in place saying
19 hey, we're not going to analyze this because they
20 don't want to go in-depth and they can live with the
21 penalty that they establish, right.

22 So, if it's for, let's say, an external
23 hazard, and they have a penalty that they want to put
24 in place, when they do that, usually a lot of times
25 it's a quantitative number that they are saying hey,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for, you know, like high winds, we're just going to
2 assume this number, right.

3 MEMBER BIER: Okay.

4 MS. BUCHOLTZ: So, it gets --

5 MEMBER BIER: So, I guess --

6 MS. BUCHOLTZ: -- done like that.

7 MEMBER BIER: -- I would describe that as
8 a bounding analysis or something, is that fair?

9 MS. BUCHOLTZ: Yeah, bounding analysis --

10 MEMBER BIER: Okay.

11 MS. BUCHOLTZ: -- would also fall to be a
12 non-PRA risk method --

13 MEMBER BIER: Okay, got it.

14 MS. BUCHOLTZ: -- because you're not
15 analyzing it.

16 MEMBER BIER: Now I understand what --

17 (Simultaneous speaking.)

18 MEMBER BIER: Thank you.

19 MS. BUCHOLTZ: Yeah, yeah. Okay, so
20 Section 2.2.3.3. discusses the risk metrics contained
21 in the rule and states the increase in core damage
22 frequency and the large early release frequencies
23 should be evaluated and compared to the acceptance
24 guidelines.

25 And Sections 2.2.3.1 and 3.2 will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 talked about in a moment. So, I have those on the
2 next slide because they say a picture is worth a
3 thousand words, so I put it in a picture, all right.

4 So, Section 2.2.4 discusses defense in
5 depth, right. This section summarizes Reg Guide 1.174
6 and it points to Reg Guide 1.174 for the full
7 discussion. It's consistent with Reg Guide 1.174's
8 intent and it states that entities should retain a
9 level of mitigation to ensure that mitigation
10 capabilities are maintained for accident sequences
11 that lead to relatively late containment failure and
12 result in late radiological releases to the public.

13 So, because of the transition break size
14 here and the fact that we're moving everything into
15 beyond design basis for everything above that
16 transition break size, right, we want to evaluate to
17 make sure we're not changing anything. So, I mean,
18 we're concerned about large early release frequencies,
19 but we also want to make sure that we're not going to
20 cause anything on the late end.

21 So, we do have it as a reminder to
22 entities that, depending on what proposed change
23 you're making, that they should verify or look at
24 containment failures on the late side and make sure
25 that they are not going to result in a late

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 radiological release to the public, so we're still
2 concerned with those.

3 And then Section 2.2.5 discusses safety
4 margins, and that section is the exact same as Reg
5 Guide 1.174. Like I said, we look at the
6 modifications to discuss proposed change in entities,
7 so it is the same. All right, so next slide, please?

8 All right, so Element 2, Section 2.2.3.1,
9 which is your acceptance guidelines for the risk-
10 informed evaluations that require prior NRC approval,
11 so I want to, before I go any further on this slide,
12 I just want to say that this is a picture that is not
13 being used anywhere other than in this presentation.

14 We are not rolling this into any guidance,
15 right. This is just to help visualize where we are
16 for the acceptance criteria, so I just want to clarify
17 that first.

18 So, for the risk metrics that require NRC
19 approval, paragraph (h)(2)(ii) in the regulation
20 requires that your total increases in core damage
21 frequency and large early release frequency to be very
22 small and that the overall risk remains small.

23 So, it uses and points to the figures in
24 Reg Guide 1.174, Figures 4 and 5, which are shown on
25 the screen minus the red edits, right, so this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 pictures of those figures marked up for where we're
2 at.

3 So, in the application here, the result in
4 increases above your core damage frequency, above ten
5 to the minus sixth per reactor year, or the large
6 early release frequency above ten to the minus
7 seventh, will not be considered, right.

8 So, on the left side there, you have your
9 change in core damage frequency and your change on
10 large early release frequencies. So, we're talking
11 for the change going up the side, right, which is why
12 we show the X-ed off region.

13 So, normally in Reg Guide 1.174, you would
14 be able to make changes if you fell into region two,
15 which is considered the small region, and in this
16 case, we're saying that for the very small changes,
17 you can't be in that region at all. You need to be in
18 the region three, which is underneath it, right, so
19 below less than the ten to the minus six, right, and
20 then you also need to meet the small criteria for your
21 baseline.

22 So, we're pointing down that the small
23 criteria is ten to the minus four for your core damage
24 frequency, and large early release frequency is ten to
25 the minus five. And I will stop there and take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 questions.

2 DR. BLEY: Dennis Bley again. What's the
3 rationale for having a different guideline here than
4 we have in 1.174?

5 MS. BUCHOLTZ: So --

6 DR. BLEY: This is for a change, right,
7 yeah.

8 MS. BUCHOLTZ: Right, so there's two
9 rationales. So, and I do want to say I was not around
10 in 2010 when we did this, or at least I was not
11 working in this area for that, so I was not involved,
12 so I don't know the full discussions of what happened.

13 But what I can find is that in that
14 little, the box underneath, which I know is hard to
15 read, I've got it on there just to kind of show what
16 it is, but out of the Commission's direction and the
17 staff requirements in the SRM SECY 782, right, the
18 Commission basically said in order to more closely
19 follow the approach presented in Reg Guide 1.174, that
20 the staff should modify the proposed rule to ensure
21 that any changes under this rule be further restricted
22 to very small increases, notwithstanding the fact that
23 they would otherwise be permitted under 50.59, right.

24 So, we do have Commission direction right
25 now that has not changed since that time frame when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this rule was previously looked at in, like I said,
2 the 2008-2007 time frame, so that's one reason that we
3 went with -- so that's one reason that it is very
4 small, to stay consistent with that, but then the
5 other --

6 DR. BLEY: That reason kind of locks you
7 in.

8 MS. BUCHOLTZ: It does lock us in, it
9 definitely does, but the other reason too, and so,
10 because we were, or I was not around then and I don't
11 know exactly what changes the industry had proposed at
12 the time, and so when I look at this rule, if you're
13 not making --

14 So, if an entity came in and they just
15 wanted to adopt the transition break size right now,
16 let's say they weren't making any changes other than
17 they want to move it out and it's to use new fuel,
18 right, and they want the enrichment, so they move the
19 transition break out of the design basis accident into
20 that beyond design basis space. If they make no other
21 changes than that, most of your PRA, right, will not
22 be affected. There will be no change in your risk
23 there.

24 So, the transition break size frequency
25 falls at that 1e to the minus five range, and so if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you were less, if we allowed the small changes area,
2 it basically wouldn't be risk informed. It would only
3 look risk informed because your TBS frequency is 1e to
4 the minus five, and any change would be so small,
5 right, that it would basically allow everything to go
6 through.

7 So, it's not until a licensee starts to
8 make other, or an entity starts to make a lot of other
9 changes in, you know, systems, structures, components,
10 other things, that it would actually start to screen.
11 So, part of the thought was it's on the lower end. If
12 an entity comes in and doesn't make a lot of changes
13 right off the bat, it would allow everything and it
14 wouldn't really screen much.

15 DR. BLEY: Yeah, well, maybe that's okay,
16 but I -- you can't do anything given the Commission's
17 guidance, but I don't understand the basis for it.

18 MS. BUCHOLTZ: Yeah, yeah, I agree, and
19 that's why I'm pointing it out. So, the Commission
20 did give us that direction so far, so we did keep it
21 consistent with that, so, and until we have further
22 information that might give us better ways of it being
23 used to show that it's overly restrictive, right now
24 I don't see that as the case until I get some more
25 information that would let me know that that is too

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 restrictive, so.

2 CHAIR BALLINGER: Walt?

3 MEMBER KIRCHNER: Yeah, in context of the
4 earlier presentations, how are you defining core
5 damage?

6 MS. BUCHOLTZ: We have not changed it.
7 So, for this, we have not changed the definition of
8 core damage, right, so it is still severe core-wide
9 damage that occurs.

10 So, FFRD in this case is not playing the
11 part here because this is severe accident, so we
12 haven't changed that part, at least currently not.
13 We've given some consideration to could we do
14 something along that area, but we have not decided to
15 push through that at this exact moment.

16 MEMBER KIRCHNER: So, I'm just trying to
17 play this out mentally then. How much dispersal and
18 relocation of fuel would be allowed and still not have
19 core damage?

20 MS. BUCHOLTZ: Yeah, that one I can't
21 answer. I would need James and them to help me with
22 --

23 MEMBER KIRCHNER: Then how do I use this?

24 MS. BUCHOLTZ: Well, this is --

25 MEMBER KIRCHNER: I'm confused. I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 really confused. And what does delta CDF mean?

2 MS. BUCHOLTZ: Okay, I got you for sure.

3 MEMBER KIRCHNER: Because you have a
4 sliding scale.

5 MS. BUCHOLTZ: Right, yeah, you're still,
6 so you're still -- this -- so there's two different
7 things going on in this rule. So, they're talking
8 FFRD, but when we are talking about using this for
9 that, you're still analyzing the, you're still
10 analyzing all of the breaks greater than your
11 transition break size. You're still doing that to the
12 PRA and to a full melt, right.

13 So, you're still looking at a full core-
14 wide damage. That's not changing. So, the PRA
15 analysis isn't evaluating the TBS from the FFRD
16 standpoint. That part is being done under the ECCS
17 and the TBS evaluations. So, this is still analyzing
18 -- this part of the rule is still analyzing the breaks
19 that are being made from any changes from the
20 structure, systems, components failure-wise.

21 So, if you decide to, upon doing a
22 realistic estimate of TBS, you decide to remove, you
23 know, what you're crediting for ECCS systems, you
24 could restructure your, a licensee, if they wanted to
25 go further in-depth, could restructure some of their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 event trees and stuff based on that, although we don't
2 expect them to remove, you know, ECCS components and
3 systems because of this rule.

4 But if they were to go along those lines
5 or to change, you know, like change diesel
6 requirements or change other things that can be
7 evaluated, we would still do that using the failure
8 criteria, and the standard core damage frequencies,
9 and the risks calculated from the core-wide damage.
10 We wouldn't be analyzing the FFRD directly. That
11 would be done under the other portion for the ECCS
12 requirement.

13 Make sense, or at least do you guys
14 understand or do you have further questions on that?
15 So, this is evaluating the risks to the plant and to
16 the structure changes you're going to make to tech
17 specs and stuff like that still using normal core
18 damage as your input for your probabilistic risk
19 assessment. It's not -- this portion of it isn't
20 actually trying to evaluate the FFRD.

21 So, okay, so I think I've covered
22 everything on this slide, so like I said, so we are in
23 region three for both your change in core damage
24 frequency and the change in large early release
25 frequencies for this, for the very small changes. All

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 right, so next slide, please?

2 So, for Section 2.2.3.2, the acceptance
3 guidelines for the self-approved risk-informed
4 evaluations, this discusses the risk metric that could
5 be made by an entity without NRC review and approval.
6 So, whereas paragraph (h)(2)(ii) required you to be in
7 the very small region, this is now, for self-approved,
8 is now what we call minimal changes.

9 So, paragraph (h)(1)(ii) requires that the
10 NRC-approved risk-informed evaluation process to
11 demonstrate that any increase in the estimate risk is
12 considered to be minimal. It's still building on
13 using those Figures 4 and 5 in Reg Guide 1.174, and it
14 does, this section does have a, sorry, does inform
15 entities that minimal impacts on risks should not be
16 risk-significant. That's just a basic assumption that
17 we're starting with, and that any minimal criteria are
18 less than two orders of magnitude below the maximum
19 allowed increase in Reg Guide 1.174, right.

20 So, we're talking one times ten to the
21 negative seventh for a change in core damage frequency
22 as opposed to the one times ten to the negative fifth
23 that's currently allowed for a change in region two,
24 and it's one order of magnitude less than the very
25 small criteria, right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Therefore, the calculated increases must
2 be less than your ten to the minus seventh per reactor
3 year for core damage frequency. So, we're showing on
4 this picture, for minimal changes, you're no longer in
5 region two or region three. You're now below and less
6 than this mark on the figure, so you're less than
7 that. So, I'll stop here before I give the last part,
8 so go ahead, please.

9 DR. BLEY: This is Dennis Bley. Have you
10 had any comments from stakeholders about this?

11 MS. BUCHOLTZ: The comments that were back
12 on the -- so this has not been presented to the public
13 as of yet, other than this is the first meeting that
14 is even open to see, so we haven't had any feedback
15 yet from industry on this.

16 However, the feedback that we did get in
17 2007 and '08 time frame, the feedback we got was the
18 very small was a tight band for the other band, but
19 minimal wasn't defined at that time, so we didn't
20 receive any comments on minimal then, so we're looking
21 forward to seeing them, you know, in the future when
22 this goes out.

23 DR. BLEY: Okay.

24 MS. BUCHOLTZ: Yeah.

25 MEMBER BIER: Hi, this Vicki Bier again.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'm curious about what auditing or accountability is
2 available for so-called self-approved changes. Again,
3 I understand the reasons for wanting to have self-
4 approved. It makes a lot of sense. If the change is
5 small, you don't want to go through a huge amount of,
6 you know, NRC paperwork, and review, and whatever.

7 But I know in the aviation industry, there
8 have been some problems of like airlines being
9 approved to do their own checkrides for pilots, and
10 then found out that some places were just pencil
11 whipping the checkrides, and so, you know, what are
12 the consequences or accountability measures on those?

13 MS. BUCHOLTZ: Right, so right now, any
14 minimal changes that are done by an entity, all of
15 those have to be reported to the NRC every two years.
16 So, they would, every two years, they would have to
17 look at them together to make sure that they don't add
18 up to a, you know, that all the minimal changes did
19 not add up to a very small change, and then they would
20 have to be submitted to us every two years. So, we
21 would get that information every two years of all of
22 the changes that they've made, and then we would look
23 at that to see if they are using this program
24 correctly.

25 MEMBER BIER: Okay, so if anything looks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 really suspicious or questionable, you would be able
2 to dig in and figure out why they had made that
3 change?

4 MS. BUCHOLTZ: Yes, exactly, and it will
5 be upon the NRC staff when we would approve the risk-
6 informed evaluation process to ensure that the process
7 that they've laid out, you know, it is appropriate to
8 screen the risk assessments that they're doing for
9 these metrics too.

10 So, we would ensure when we do that, just
11 like we do for the risk-informed completion time
12 programs, that the program is set up to, you know, to
13 take appropriate actions based on the thresholds that
14 they calculate, yeah, all right.

15 MEMBER PETTI: Kristy? This is Dave.
16 Just to understand, you'll need to approve their risk
17 evaluation process --

18 MS. BUCHOLTZ: Correct.

19 MEMBER PETTI: -- but they wouldn't have
20 to, with every license amendment, with every fuel
21 reload, have to regurgitate all of that information
22 over and over. It's kind of just the opening volley,
23 if you will.

24 MS. BUCHOLTZ: Correct, yes. Yeah, once
25 the risk-informed, once they've submitted the process

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to the NRC and we've reviewed it, looked at it, and
2 made sure that -- you know, just like we would with
3 like the other risk-informed rules that we do where we
4 allow them to have a process, like with 50.69 or the
5 risk-informed completion time.

6 We're envisioning that they would take
7 those programs that they've already had and build on
8 them to use this. So, we hope that this wouldn't be,
9 you know -- we know it will take some effort, but
10 we're hoping it's less than, you know, starting from
11 scratch, so if they have those programs, it would be
12 able to build on those.

13 And no, and so we don't expect them to do
14 this -- once that process is laid out, we expect them
15 to be able to use it as they do now for the other
16 ones, yeah, all right?

17 MEMBER PETTI: All right, thank you.

18 MS. BUCHOLTZ: Yeah, no problem. So, for
19 the version of Draft Guide 1426 that we did submit to
20 the ACRS, we had in there that there was a one-percent
21 -- we had an increase in CDF and LERF of less than one
22 percent for the overall plant risk we had in there as
23 a limitation, and then we did decide, looking back,
24 that we did remove that.

25 That was my mistake. I missed the fact

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that the Commission had told us that we're not -- I
2 was thinking of new reactors that are on the lower
3 line, and so I put that percentage in there thinking
4 that we would want to make sure that we're not, you
5 know, allowing for a reactor that has such a low PRA
6 that you could double it or triple it and still be,
7 you know, and it not be considered significant.

8 But I was reminded that the Commission had
9 weighed in on that, and that is a benefit of having a
10 lower-risk plant in that the bar is set where it is
11 and that would still be safe, and so I did remove
12 that. I missed that, so you'll see that that has come
13 out of the draft guide. Okay, so next slide, please?

14 So, for Element 3, Element 3 is defining
15 the implementation and monitoring program. So, this,
16 again, this is another section that points to Reg
17 Guide 1.174 for the implementation and monitoring.
18 The original rule, like Joey was talking about
19 earlier, it did have a period updating of two things.

20 It had a period updating of the risk
21 assessments themselves, where the entity would have
22 had every five years, look at all of the changes that
23 were made under the program and then redo the risk
24 assessment to verify it didn't go above the very small
25 changes when they're all put in place. We removed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that from this because that's not typically done for
2 other license amendments that we currently do.

3 So, every change they do, they would
4 evaluate the risk in place at the time and the current
5 changes that have been put into place, but we would
6 not make them redo every five years to do that, so it
7 would be done every time they make a change instead,
8 right.

9 And then the -- so we did remove that from
10 the rule itself and then we removed it from the draft
11 guide, so it no longer includes that reevaluation of
12 risk assessments.

13 And then we did also remove the
14 requirement to update the PRA every five years from
15 the draft rule. We decided that that, you know,
16 that's an ASME standard, and that we rethought that
17 and thought that that didn't need to be in the actual
18 rule as a requirement, that it is in the ASME standard
19 that they're following.

20 So, we did leave it -- so we took it out
21 of the rule, so it doesn't say that you have to do it
22 every five years, which had the intent of every two
23 refueling cycles, but we did leave it in the draft
24 guide.

25 So, in the draft guide, it's still in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there that an entity should update, you know, do any
2 updates and upgrades to their PRA at a maximum or at
3 the long time of every five years, but it was changed
4 from a must to a should, right, because we expect them
5 to still follow the PRA standard for that.

6 And then, of course, like the note on the
7 bottom of the slide, it's just reminding everybody
8 that the version of Draft Guide 1426 was still under
9 concurrence when we submitted it, so we have made
10 these four -- so these four changes were listed in
11 that draft guide, but they have now been changed or
12 removed. So, next slide, please?

13 MEMBER ROBERTS: Yeah, Kristy, it's not on
14 this slide, but this section of the draft guide talks
15 about if you have a design that doesn't meet single
16 failure criteria, because you're allowed to above the
17 transition break size, what the allowable outage time
18 would be, and one of the paragraphs says it should be
19 a pretty short time, without defining short, and the
20 paragraph after that seems to say you can't do it at
21 all, and so I was wondering what the thought process
22 was in terms of allowable outage where there's
23 basically no redundancy as permitted by the rule.

24 MS. BUCHOLTZ: Yeah, so the way the -- so
25 that is -- thank you. I thought I added that here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, that was one of the things that we did remove from
2 the rule.

3 The rule had in there, before we decided
4 to make sure that all of the systems, structures, and
5 components for this were placed into tech specs, we
6 did have in there a short time, so that if an entity
7 was operating and then recognized that they were in a
8 condition that wasn't analyzed by the rule, it gave
9 them a time period to basically come back into
10 compliance, because you would be out of compliance
11 with the rule.

12 So, since then, we have decided to remove
13 the short time from the rule and we put in the
14 requirement instead to make sure that the systems,
15 structures, and components that are important are in
16 the tech specs, so this way if you had a problem with
17 a piece of equipment, it would give you the time in
18 the tech specs to restore or to do maintenance, right.

19 We also recognized that maintenance, if
20 you had to do maintenance on any of the equipment and
21 you took it out, right, you could possibly not meet --
22 you know, especially if you have a realistic analysis
23 that's assuming you have everything or it's assuming
24 those changes, right, you might not meet that. So, we
25 did take short time out of the rule, and so that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 been deleted also from the draft guide.

2 MEMBER ROBERTS: Okay, so both of those
3 paragraphs I mentioned are being deleted from the
4 draft guide?

5 MS. BUCHOLTZ: They are.

6 MEMBER ROBERTS: Okay, thank you.

7 MS. BUCHOLTZ: Yeah, my apologies. I
8 thought I added that to this and didn't save it.
9 Okay, so Element 4. So, Element 4 is submitting the
10 license amendment request.

11 So, for all of the requests under this,
12 excuse me, for all of the requests under this rule,
13 it's expected and we lay out in the draft guide that
14 a summary of the PRA model and methods used to
15 evaluate the proposed change should be in the
16 submittal, right, and with the basics of it, you know,
17 which risk methods are being used, why are they
18 acceptable, right, your key modeling assumptions, your
19 considerations of uncertainty, the key operator
20 actions, your changes required for your event, your
21 fault trees. That's normal and typical of any license
22 amendment that's done under Reg Guide 1.174, so that
23 stays there.

24 And then we added in there for those that
25 choose to do the risk-informed evaluation process,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that any submittal or your initial submittal for this,
2 right, then you should have submittal details to
3 support the changes without the approval, right.

4 So, that should have a description of the
5 entity's PRA models, any non-PRA risk assessment
6 methods to be used, right, description of the entity's
7 approach, methods, your decision making to evaluate,
8 right, your risk criteria, your defense in depth, your
9 safety margins, your performance measures.

10 So, we do have -- so, Element 4 is divided
11 into two sections, which it kind of has the section,
12 or the discussion that's normally in Reg Guide 1.174,
13 and then we added a couple extra stuff for the risk-
14 informed evaluation process. All right, next slide,
15 please?

16 MEMBER PETTI: Kristy, before you go
17 there, this may be broader than you, the discussion
18 about safety margins and defense in depth, going to
19 best estimate for a large break LOCA and making it
20 beyond design basis will open up some margin, and an
21 entity may decide they want to use that margin in a
22 power uprate, for instance. So, and similarly, how
23 defense in depth looks after you execute that change
24 is going to be different than what it was in the plant
25 before.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, does this all recognize that defense
2 in depth could still be adequate? It's just going to
3 be different than what it was before, and that yes,
4 you're going to be giving up some safety margin, but
5 the plant will still be safe? I just worry that
6 people could get misled, particularly, you know, the
7 public as they would be looking at these.

8 So, these are some fairly esoteric topics
9 we've been discussing, but at the higher level, the
10 answer is yes. It's just different in form is how I
11 would describe it to the non-technical person. Is
12 that a fair kind of way to think about it?

13 MS. BUCHOLTZ: It is a fair way to think
14 about it, and I did bring in for this reg guide or the
15 draft guide, I did include to say in there, there is
16 a couple of paragraphs in there, well, I should say a
17 little bit of discussion in there that points out that
18 yes, that it is not the intent that you can't make any
19 changes to defense in depth or safety margins, right.
20 That is not the intent here.

21 The intent here is to look at them and to
22 make sure that you still have appropriate measures in
23 place for both of those, but we do recognize that yes,
24 there might be, depending on what proposed change
25 you're making, that the defense will, you know, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 defense in depth will look different, and the same
2 thing with the safety margins.

3 So, we do have that. I hope that's clear
4 in there, and I figure public comment will let us know
5 for sure, but we did -- we do have -- that is the
6 intent of those sections, to say that it's not going
7 to look the same, but it just needs to make sure you
8 still have, you know, you're still in line with the
9 defense in depth, you know, the philosophy of the
10 Commission all together.

11 So, it might shift, you know, barriers, or
12 it might shift systems as your defense, or you might
13 be relying on more non-safety stuff now, right, as
14 another layer in there, so, yeah, the defense can
15 change, yeah. All right, so next slide, please?

16 So, the last part of the draft guide is
17 the quality assurance and the documentation piece, and
18 these two were pretty much the same. So, the quality
19 assurance is the same as Reg Guide 1.174 with no
20 substantial changes, again, just the changes that we
21 talked before, changing it from licensing basis to
22 proposed change and changing it to recognize an entity
23 versus a licensee.

24 And then for the documentation piece, we
25 did bring in -- so it does differ a little from Reg

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Guide 1.174 in that we're pointing more to the
2 documentation that's used for Section C.4 of Reg Guide
3 1.200, which is evaluating your changes from a base
4 PRA perspective.

5 So, you would document the -- it still
6 involves the same, much of the same documentation as
7 Reg Guide 1.174 contains, but it goes a little further
8 in-depth on documenting changes to your base PRA in
9 your models that you're doing for this program, so, to
10 ensure that everything is documented and nothing is
11 missed, but it is consistent, like I said, with Reg
12 Guide 1.200 and Reg Guide 1.174. There was no real
13 intent to do anything different than what's already
14 been established under those reg guides.

15 So, all right, so the next slide, please?
16 So, that is the end of the draft reg guide. I'd be
17 happy to answer any other questions that I didn't
18 discuss or didn't answer on the risk portions. Okay,
19 hearing none, that's all I have.

20 CHAIR BALLINGER: Okay, we are at the end
21 of the presentations. I think we need to now go out
22 for public comment. So, if there are any members of
23 the public listening in or out there that would like
24 to make a comment, please state your name and
25 organization and make your comment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BURKHART: Yeah, this is Larry
2 Burkhart from the ACRS staff. If you are on the MS
3 Teams link, we kindly ask you to raise your hand and
4 we can get to each comment in sequence.

5 CHAIR BALLINGER: Well, I'm not hearing
6 anything. From the audience members or participants
7 in the audience, would anybody like to make a comment?
8 We probably beat everybody to death.

9 (Laughter.)

10 CHAIR BALLINGER: Hearing none, other
11 comments from the members before we adjourn for the
12 day? None? Well, I'm sure I speak for the rest of
13 the members that you guys have really done a yeoman's
14 job of putting this presentation together and it's
15 very much appreciated, and we'll continue to inflict
16 you tomorrow on this. And so, if there aren't any
17 other last-minute comments, we are adjourned until
18 tomorrow morning at 8:30.

19 (Whereupon, the above-entitled matter went
20 off the record at 4:59 p.m.)

21

22

23

24

25

C E R T I F I C A T E

This is to certify that the foregoing transcript

In the matter of: ACRS Fuels, Materials and Structures
Subcommittee

Before: NRC

Date: 12-17-24

Place: teleconference

was duly recorded and accurately transcribed under
my direction; further, that said transcript is a
true and accurate complete record of the
proceedings.



Court Reporter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1716 14TH ST., N.W., STE. 200

WASHINGTON, D.C. 20009-7831

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Fuels, Materials, and Structure Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Wednesday, December 18, 2024

Work Order No.: NRC-0148

Pages 1-217

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

REGULATORY RULEMAKING, POLICIES AND PRACTICES

SUBCOMMITTEE

+ + + + +

WEDNESDAY

DECEMBER 18, 2024

+ + + + +

The Subcommittee met via Videoconference,
at 8:30 a.m. EST, Ronald G. Ballinger, Chairman,
presiding.

SUBCOMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman

VICKI M. BIER, Member

VESNA B. DIMITRIJEVIC, Member

GREGORY H. HALNON, Member

CRAIG D. HARRINGTON, Member

WALTER L. KIRCHNER, Member

ROBERT P. MARTIN, Member

SCOTT P. PALMTAG, Member

DAVID A. PETTI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

THOMAS E. ROBERTS, Member

MATTHEW W. SUNSERI, Member

ACRS CONSULTANT:

DENNIS BLEY

DESIGNATED FEDERAL OFFICIALS:

ZENA ABDULLAHI

WEIDONG WANG

ALSO PRESENT:

LARRY BURKHART, ACRS/TSB

THERESA CLARK, NRR/DSS

JAMES CORSON, RES/DSA/FSCB

ELIJAH DICKSON, NRR/DRA/ARCB

DAVE GARMON, NRR/DRA/ARCB

JOHN LEHNING, NRR/DSS

JOSEPH MESSINA, NRR/DSS/SFNB

C-O-N-T-E-N-T-S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PAGE

ACRS Chairman Introductory Remarks
by Ronald Ballinger 4

NRR Staff Leadership Opening Remarks
by Theresa Clark 7

Fuel Fragmentation, Relocation, and
Dispersal by James Corson 8

Control Room Design (10 CFR 50.67
and General Design Criteria 19)
by Elijah Dickson 138

Public Comment 204

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR BALLINGER: The meeting will now come to order. This is a renewed meeting of the Fuels, Materials, and Structures Subcommittee of the Advisory Committee on Reactor Safeguards. We had a meeting yesterday. This is a continuation of that meeting.

I'm Ron Ballinger, the chair of today's subcommittee meeting. ACRS members in attendance in person are Craig Harrington, Tom Roberts, Dave Petti, myself, Bob Martin, Scott Palmtag. Members in attendance virtually I think mostly via Teams are Walt Kirchner, Greg Halnon, Matt Sunseri, Vicki Bier, Vesna Dimitrijevic.

We have consultant Dennis Bley who I think he's -- yes, he's there. Zena Abdullahi and Weidong Wang of the ACRS staff are the designated federal officers for this meeting. No member conflicts of interest were identified for today's meeting. We have a quorum.

During today's meeting, the subcommittee will receive continuing presentations on technical topics regarding increased enrichment conventional and accident tolerant fuel designs for light water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactors rulemaking. The Nuclear Regulatory
2 Commission is proposing to amend these regulations
3 related to the use of conventional and accident
4 tolerant light water reactor fuel designs. The NRC's
5 goal is to establish effective and efficient licensing
6 of the use of fuels enriched greater than 5 weight
7 percent uranium-235 while continuing to provide
8 reasonable assurance of adequate protection and public
9 health and safety.

10 The new requirements also would address
11 fuel fragmentation, relocation, and dispersal in
12 relation to the key accident tolerant fuel components
13 of increased enrichment and burnup limits. The ACRS
14 was established by statute and is governed by the
15 Federal Advisory Committee Act or FACA. The NRC
16 implements FACA in accordance with its regulations.

17 Per these regulations and the committee's
18 bylaws, the ACRS speaks only through its published
19 letter reports. All member comments should be
20 regarded as only the individual opinion of that
21 member, not a committee position. All relevant
22 information related to ACRS activity such as letters,
23 rules for meeting participation and transcripts are
24 located on the NRC public website and can be easily
25 found by typing About Us ACRS in the search field on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the NRC's home page.

2 The ACRS consistent with the Agency's rule
3 of public transparency and regulation of nuclear
4 facilities provides opportunity to public input and
5 comment during our proceedings and receive no written
6 statements or requests to make an oral statement from
7 the public. We have also set aside time at the end of
8 this meeting for public comments. The ACRS will
9 gather information, analyze relevant issues and facts,
10 and formulate proposed conclusions and recommendations
11 as appropriate for deliberation by the full committee.

12 A transcript of the meeting is being kept
13 and will be posted on our website. When addressing
14 the subcommittee, the participant should first
15 identify themselves and speak with sufficient clarity
16 and volume so that they may be readily heard. If you
17 are not speaking, please mute your computer on Teams
18 or by pressing *6 if you are on a phone.

19 Please do not use the Teams chat feature
20 to conduct sidebar discussions related to the
21 presentations. Rather limit use of the meeting chat
22 function to report IT problems. For everyone in the
23 room, please put all electronic devices on silent mode
24 and mute your laptop microphone and speakers.

25 In addition, please keep sidebar

1 discussions in the room to a minimum since the ceiling
2 microphones are live and they're very sensitive. For
3 presenters, your table microphones are unidirectional
4 -- very unidirectional. And you'll need to speak into
5 the front of the microphones to be heard.

6 Finally, if you have any feedback for the
7 ACRS about today's meeting, we encourage you to fill
8 out the public meeting feedback form for the NRC's
9 website. So we'll now proceed with the meeting. And
10 do we want to have any additional -- any intro from
11 Theresa? Okay.

12 MS. CLARK: So thank you very much and
13 good morning, everyone. I'll keep it brief. I don't
14 have a whole speech this morning. But we really
15 appreciated the compliments from the committee
16 yesterday and especially the interest and engagement
17 with lots of questions.

18 Though it may not always feel like the hot
19 seat, we really do appreciate that and it shows the
20 interest in our work. I think some of the questions
21 go to sort of the healthy tension of any optimization
22 project where we're going between whether it's
23 schedule and the ability to integrate feedback,
24 whether requirements should be more performance-based
25 or more prescriptive, how we relax certain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 requirements while keep guardrails on it to ensure
2 safety margins of defense in depth. We expected some
3 of this conversation, and we look forward to
4 continuing it.

5 We've heard a really robust technical
6 basis for the work the staff has done. We'll hear
7 even more of that today and the details. And we'll
8 still have January to further link everyone to their
9 details. So I look forward to that and appreciate the
10 time.

11 CHAIR BALLINGER: All set? Okay. Whoa,
12 we only have one person.

13 MR. CORSON: Yeah, you're going to be
14 hearing a lot from me this morning. So my name is
15 James Corson. I'm a senior reactor systems engineer
16 in the Fuel and Source Term Code Development Branch in
17 the Office of Research.

18 So I'm going to be talking about some
19 guidance related to fuel performance this morning.
20 The first presentation is related to some old work
21 that dates back to the 50.46c rulemaking. So there's
22 three draft guides on zirconium-alloy cladding
23 analytical limits that I'll talk about first.

24 Later on this morning, I have a separate
25 presentation that gets into fuel dispersal. So that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 will be a new draft guide. Next slide, please. So as
2 I said, as part of this 50.46c rulemaking dating back
3 about a decade now, we developed three draft
4 regulatory guides relative to zirconium-alloy cladding
5 analytical limits.

6 So the first two are essentially test
7 procedures. There's one related to measuring breakaway
8 oxidation. And I'll talk a little bit about what that
9 is later on.

10 A second one relating to how you measure
11 post-quench ductility related to oxidation and
12 embrittlement of zirconium-alloy cladding. And then
13 the third draft guide has to do with how you apply
14 those test procedures to create analytical limits for
15 zirconium-alloy cladding. So we updated these
16 documents to reflect the changes that we made to the
17 rule language in 50.46a.

18 The parts that we took from 50.46c, we
19 made some changes to the rule language. So the
20 guidance has been updated accordingly. Otherwise, the
21 guides are mostly unchanged for what was submitted in
22 the draft final rule package.

23 Of course, there was some minor editorial
24 changes here and there. But for the most part, it's
25 the same as what we submitted in 2016 with some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 changes to address differences in the rule language.
2 So next slide, please. So this slide is meant to show
3 how these guides relate to the rule language that we
4 have now.

5 So Joe Messina talked a lot about the rule
6 language itself yesterday. So we had these fuel
7 system requirements that we need. So the first one,
8 of course, is to address cladding degradation
9 phenomena.

10 That's essentially what these three guides
11 are getting at. There is this hydrogen limit in one
12 of the guides that we put there because we removed the
13 limit from the language itself. But otherwise, these
14 guides are mostly meant to address cladding
15 degradation phenomena.

16 However, the point of addressing these
17 cladding degradation phenomena is to prevent
18 widespread brittle failure of the fuel and cladding.
19 That could challenge fuel coolability. So ultimately,
20 these are meant to ensure fuel coolability.

21 Now as you'll hear later on this morning,
22 just addressing cladding embrittlement is not
23 sufficient to address fuel coolability because of fuel
24 dispersal. But these guides do try to address this
25 issue. So next slide, please. On this slide, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 wanted to highlight some of the zirconium-alloy
2 cladding degradation mechanisms that there are.

3 So I'll focus on the two lower things in
4 this figure. So loss of ductility, this is just due
5 to oxidation, oxygen uptake that leads to cladding
6 embrittlement. As you see on the top right, this is
7 a figure showing how this embrittlement changes with
8 the hydrogen content of the cladding.

9 So that's one mechanism. Another
10 mechanism that occurs more in small break type LOCA
11 accidents is breakaway oxidation where prolonged
12 exposure at lower temperatures can lead to this
13 behavior which I'll talk about a little bit more. But
14 one of the other things I want to highlight on this
15 slide is that there are other cladding degradation
16 mechanisms out there.

17 Our guidance does not address them because
18 these other degradation mechanisms, the loss of
19 ductility due to brittle failure and breakaway
20 oxidation happen at lower temperatures. So setting
21 certain limits to address these also addresses these
22 higher temperature phenomena. But this is just to
23 show that if you ever wanted to go to higher
24 temperatures, there are other things that would need
25 to be addressed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: This is Ron Ballinger.
2 I just feel compelled every time I see this, I make
3 the same comment. That figure on the lower right is
4 not from any U.S. cladding.

5 It's from E110. It's Russian cladding.
6 So it's almost deceptive to put that there as an
7 example of breakaway oxidation. You would think that
8 you'd be able to find a photo where they have real
9 breakaway oxidation on Zircaloy-4 or ZIRLO or
10 something like that. But I suspect it doesn't exist.

11 MR. CORSON: So there are photos not as
12 extreme as this but where you start to get
13 discoloration and you get significant hydrogen uptake
14 which is what the real concern with breakaway
15 oxidation cladding is you're right, yes. This is
16 E110. I think one of the important things that I'll
17 get at very shortly is that there are a lot of
18 manufacturing processes and minor changes to the alloy
19 that can have a significant impact on breakaway
20 oxidation.

21 So this is E110. E110 has pretty much the
22 same composition as M5 except it's made in a different
23 way. And the way it's made is what leads to this
24 behavior whereas M5 behaves very well when it comes to
25 breakaway oxidation. So yes, that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: And this is a public
2 meeting. And we really do want to be careful that we
3 don't send a message which we don't want to send.

4 MR. CORSON: Yeah. No, you're right.
5 U.S. alloys as far as we've seen so far behave very
6 well when it comes to breakaway oxidation. But the
7 trick is you can make minor changes to how you make
8 that cladding that can turn it into something that
9 looks more like this. That hasn't been done in the
10 U.S. But it could theoretically happen. Next slide,
11 please.

12 MEMBER PETTI: So just a question here.
13 As I first looked at this and particularly the plot on
14 the upper right, just you know how much Zircaloy has
15 been tested in the old days. And the old days aren't
16 that old for some of us.

17 And yet there's all these new mechanisms.
18 That's how it's described. I interpreted that to mean
19 they were new because we ended up going to higher
20 burnup, higher hydrogen content. But you seem to be
21 saying it's an issue because we didn't study oxidation
22 at the lower temperatures. Explain to me sort of how
23 we got here.

24 MR. CORSON: So the breakaway oxidation
25 thing is something separate. So again, this happens

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 at lower temperatures, prolonged exposure. It was
2 first discovered because someone was doing testing on
3 E110 cladding and saw this happen.

4 And so that caused the NRC and other
5 organizations to study this further. And as I had
6 said, we didn't see the same behavior, certainly not
7 at the short times that E110 experienced breakaway
8 oxidation. So the top right, that's more the
9 traditional higher temperature oxidizing at 1,200 C
10 per 2,200 degrees Fahrenheit and studying the
11 embrittlement. And so that -- yes, that is related to
12 higher burnup phenomena and hydrogen uptake in the
13 cladding.

14 CHAIR BALLINGER: Excuse me. Somebody has
15 got a mic open or something. Got it? Thank you.

16 MEMBER PETTI: Okay. So this is the other
17 problem I'm having. There are no Reg Guides telling
18 vendors how to manufacture their clad or tests they
19 need to do to prove that the clad is okay when we
20 don't have any indication that any U.S. clad
21 experiences this behavior. So that you would -- and
22 why wouldn't we just somehow deal with it as a
23 specification?

24 Again, this just jumps out at you. And
25 again, this was all done back, I guess, around 2000s.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 How did we get heat to that position?

2 MR. CORSON: So yeah. So basically, there
3 are manufacturing changes that can lead to this type
4 of behavior, that can turn a good performing alloy
5 into a bad performing alloy. And it's even some minor
6 things as potentially where you're getting your Zircon
7 from. Like, it could be down to the trace impurity
8 level.

9 And so at what point does the NRC or does
10 the vendor want to restrict their process to using a
11 certain time of material, source it from a certain
12 place, use a certain process to refine the Zirc, use
13 certain surface finishing techniques. So there's a
14 lot of steps in the process that could potentially be
15 controlled. Or you could come up with a relatively
16 simple test just to show that nothing bad has
17 happened, that you haven't made some minor change that
18 turns into a bad performing alloy.

19 MEMBER PETTI: Although it seems like a
20 relatively simple test, fuel vendors don't have
21 furnaces to do oxidation testing in their back rooms
22 usually.

23 MR. CORSON: Yes, so --

24 MEMBER PETTI: I mean, they're used to
25 saying, okay, we're going to inspect the impurities to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a certain limit. We're going to inspect processes or
2 put some process specs on it. I mean, that's -- my
3 sense of fuels, that's sort of where they're
4 comfortable. This just seemed a little bit out of the
5 ordinary. But if industry thinks this is okay, I
6 guess I'm okay with it. Just doesn't --

7 CHAIR BALLINGER: Following Member Petti's
8 comment, we wrote a letter on this on 50.46c which has
9 been -- the whole thing has been withdrawn. And we
10 made the same comments. And in the original
11 documents, there was literally a requirement for
12 vendors to actually do the testing on every batch, if
13 I recall. And looking at the new rule that's not
14 there which is a good thing, I think. So that's one,
15 in my opinion, one person's opinion, good changes to
16 the new rule.

17 MR. CORSON: So what I'll say -- I mean,
18 I'll get into this a little bit later. But I might as
19 well say it now is that part of the guide is saying
20 the vendor should come up with a plan for how often
21 they're going to test and how they're going to show
22 that they haven't made changes that adversely impact
23 breakaway oxidation behavior. And so that plan would
24 be reviewed and approved by the NRC.

25 And so they could very well propose

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 infrequent testing. Every once in a while, we're just
2 doing a sanity check, so to speak. So that could be
3 done. It would be reviewed and approved by the NRC.

4 There is a default time frame in the guide
5 which is once per ingot which is actually fairly
6 often. But again, that's just a default. The vendors
7 can come up with their own plans based on the types of
8 arguments that you're saying right now are based on,
9 okay, this is how we're controlling our process. So
10 we're fairly confident that we're not going to change
11 anything that messes it up. So that's part of the
12 back and forth with vendors.

13 CHAIR BALLINGER: Because we visited one
14 of the vendors. And we asked them about the cost, and
15 it was going to be passed on to the customer, each
16 load. And it was about half a million dollars. So
17 it's not chump change to do these kind of tests to
18 verify.

19 MR. CORSON: Yeah, I mean, it's tricky
20 because we don't understand all of the mechanisms and
21 all of the changes that can lead to this behavior. So
22 this is why we had this. There was a testing
23 requirement in the actual rule language for 50.46c.

24 That testing requirement is no longer in
25 the rule language itself. So that does provide some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 amount of flexibility right there. You can always
2 argue that it's not necessary for the reasons that
3 you're saying.

4 MEMBER PETTI: So let me ask a different
5 question. Has anyone tried to manufacture optimized
6 ZIRLO or M5 in a bad way to actually get the breakaway
7 oxidation?

8 MR. CORSON: Not to my knowledge. So I
9 know -- so at Argonne National Lab during this
10 process, they focused a lot on the different surface
11 finishing mechanisms. They looked at different types
12 of acid baths or polishing and so on and identified
13 some of the things that could lead to worse behavior.

14 Argonne did not do this. But I believe it
15 was TVEL, the Russian manufacturer or some other
16 organization looked at E110 and sourcing it from
17 western styles, Zirconium sponge. So using the Kroll
18 process and everything else. And that made it perform
19 much better.

20 So one of the things that was speculated
21 is that the impurities that were removed during their
22 electro-refining process that they had used to make
23 E110, some of those things that removed actually
24 helped breakaway oxidation, provide more favorable
25 breakaway oxidation behavior in western alloys. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 yeah, no one tried to make optimized ZIRLO to make it
2 bad, but someone did try to make E110 to make it good.
3 And that's essentially what they do now for E110.
4 They know enough to make it perform better.

5 CHAIR BALLINGER: Dave, I think what we're
6 getting at here is that this is a case where we're
7 running the risk of the tail wagging the dog. You
8 know what I mean. We see bad behavior, terrible
9 behavior actually, and then infer that terrible
10 behavior is somehow a done deal. It's going to happen
11 with our material.

12 And yet we haven't been able to make it do
13 that. And yet we've sent our material, our sponge,
14 over to Russia. And lo and behold, they can't make it
15 happen. So it's just a worry that there's a burden
16 here that is pretty costly.

17 MR. CORSON: Yeah, I mean, it's something,
18 I think, we'll have to think about moving forward when
19 we get into the draft final rule stage. I think to be
20 honest, part of the reason why we're here is that we
21 try to make as few changes as possible from 50.46c.
22 So we just -- we try to focus on the things that
23 really did change, the new stuff like fuel dispersal
24 and everything else.

25 It was sent to the Commission. We dusted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 it off, made some few changes, and sent it back out.
2 So yes, obviously, I think this is something that we
3 will need to think a little bit more about and perhaps
4 make it better.

5 MEMBER PETTI: Yeah, I mean, I would love
6 to it. The Reg Guide says in your process, you cannot
7 use fluoride-containing material, stuff that you know
8 causes the problem. You just say, you can't do that.

9 I think a manufacturer can deal with that
10 easier than this. If you can figure out what the real
11 issue was which means you got to dig a little deeper.
12 I mean, so I don't know. I conclude did you guys
13 decide that it wasn't worth doing more of the research
14 to figure this out or that there was some statistical
15 thing and you're chasing your tail? You could never
16 tie it down in terms of what's going on.

17 MR. CORSON: Yeah, I mean, I was getting
18 at this with different sponges. So there's zirconium
19 sponges. So there's different trace impurities. We
20 don't know exactly which of those trace impurities are
21 the ones that are problematic or good.

22 So trying to figure all that stuff out, we
23 didn't keep drilling down. And also then there's --
24 I guess the question is -- and this is maybe something
25 for industry later during the public comment period.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Is it better to tie down your process and to restrict
2 it in the ways that you're suggesting?

3 Only do these certain things. Or is it
4 better to do a test. And so that -- it might be
5 useful to have some feedback during the public comment
6 period on this issue. Do you want restrictions on
7 your process or do you want a test and not have to
8 worry about all the things that are happening?

9 MEMBER PETTI: This is the 21st century.
10 And I think manufacturers make stuff a heck of a lot
11 better than 20, 30 years ago, so --

12 CHAIR BALLINGER: I think that during the
13 discussion on 50.46c, that question actually came up.
14 And I think the consensus was on part of the industry
15 was that they would control the manufacturing process
16 which is what they already do. But the consensus on
17 the part of the staff, we want you to do a test.

18 And again, not to beat a dead horse, the
19 vendors don't want to see this. If this were to
20 happen once on one load of fuel, anytime they would be
21 in deep yogurt, so to speak. So there's a very strong
22 impetus to make sure that they control their process
23 so that something like this does not happen. Just one
24 person's opinion.

25 MR. CORSON: No, I mean, I went back and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 read the transcripts for the 50.46c ACRS meeting. So
2 I was aware of this back and forth. I think it is
3 difficult without knowing all the things that could
4 make this happened to restrict your process in such a
5 way that it wouldn't happen.

6 But I think it is a good point. Like, do
7 you need to do any testing at all, which I think that
8 it's a little risky without knowing all the things
9 that could happen. Do you do a test like very, very
10 infrequently just as a sanity check? Or do you do it
11 more often? I think the way the guide is written now
12 is probably leaning towards more often with some
13 flexibility to have more infrequent testing. But
14 yeah, that's something that we can think about and
15 revisit.

16 CHAIR BALLINGER: Now we're probably an
17 hour behind.

18 (Laughter.)

19 MR. CORSON: Well, the good thing is, I
20 mean, we felt good.

21 (Simultaneous speaking.)

22 CHAIR BALLINGER: We feel good about it.

23 MR. CORSON: Yeah, the good thing is I
24 think I can probably skip through some of the slides
25 on that guide, but we'll see. So next slide. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So this is an abbreviated history of just the whole
2 50.46c.

3 I think what I wanted to show here is that
4 there was a lot of back and forth. We're aware there
5 were a lot of industry comments on the original
6 versions of these guides, some of which we reflected
7 in what was submitted in the draft final rule package
8 for 50.46c. So we did get some industry feedback
9 along the way that led to changes from what was in the
10 original version of the draft guides that were sent
11 out in 2014. So next slide, please.

12 All right. So I got into some of this.
13 But basically, breakaway oxidation is you have
14 normally under LOCA conditions this protective oxide
15 that forms -- that protective oxide, the tetragonal
16 oxide is metastable. So there's things that can cause
17 it to switch to this nonprotective monoclinic oxide
18 which leads to higher oxidation, higher hydrogen
19 uptake.

20 And so that's the bad stuff that we're
21 talking about later. And as I said, we showed that
22 some minor changes in alloy composition or
23 manufacturing process can have a pretty significant
24 impact on the breakaway oxidation behavior. So the
25 E110 that we were talking about a little -- or a lot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 before, that showed that behavior in about 500
2 seconds.

3 So pretty quickly relatively speaking
4 whereas western alloys, we're talking more like 4,000
5 or 5,000 seconds. And then the behavior is not as
6 extreme as for E110. So that's just an order of
7 magnitude I'd say better in terms of timing to this.
8 So next slide.

9 So the guide defines an experimental
10 technique for doing the test. It has some flexibility
11 for doing it in different ways at different labs. And
12 then it discusses both the initial testing and then
13 the confirmatory testing.

14 So as I'll talk about later, the initial
15 testing that was done at Argonne is sufficient for the
16 existing alloys. The periodic testing I think is what
17 the controversy is about, how often you would have to
18 do the test and so on. So next slide.

19 MEMBER PETTI: So chrome-coated clad,
20 where does that fit?

21 MR. CORSON: So yeah, chrome-coated
22 cladding in general is not really covered by these
23 guides. So we do have interim staff guidance that's
24 related to chrome-coated cladding. And it has a few
25 things to say about how you might go about addressing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 some of these things, one of which is just to say,
2 hey, this behaves about the same as existing cladding.
3 Or it might behavior better but we're not going to
4 take credit for it.

5 And so there would probably need to be
6 either some testing or some engineering arguments, at
7 least to address the post-quench ductility stuff. For
8 the breakaway oxidation, it might be a little bit
9 simpler. But yeah, so the guides don't really cover
10 coated-cladding, but they may be informative.

11 CHAIR BALLINGER: This is Ron Ballinger
12 again. But I think the trend is to go for all the
13 BWRs, for PWRs, or all the vendors that use chrome-
14 coated cladding. Is that correct?

15 MR. CORSON: I can't comment on what the
16 industry wants to do. I mean, they haven't submitted
17 any license amendments. Certainly all the vendors are
18 still doing testing and development plans to develop
19 these claddings. Whether they get adopted or not, I
20 leave that up to --

21 CHAIR BALLINGER: Well, they have LTAs.

22 MR. CORSON: Yeah, they do. I mean, they
23 need that in order to study whether this is a viable
24 cladding or not. And they would need for NRC
25 approval. Whether it gets adopted or not, I mean,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that's going to come down to what the industry wants
2 to do. Whether it makes economic sense for them,
3 safety sense, whatever else, I can't really say how
4 that's going to go.

5 MEMBER KIRCHNER: Ron, this is Walt. Just
6 an observation, wasn't this rule to include accident
7 tolerant fuel?

8 CHAIR BALLINGER: That's what I was
9 getting at, yes.

10 MEMBER KIRCHNER: Yeah, I'm a little
11 concerned. Just an observation.

12 MR. CORSON: So the way the rule language
13 is written, it does allow for accident tolerant fuel.
14 They're generic criteria. The guidance does not
15 necessarily apply to the different accident tolerant
16 fuel concepts. And the reality is in order to do
17 that, there would need to be some sort of testing to
18 show that, hey, this guidance is applicable or it's
19 not. And so in order to do that, that would take a
20 significant level of effort which we just did not have
21 for this rule.

22 CHAIR BALLINGER: But I think you do.
23 Forget the DG numbers. But there's a progression of
24 what you need to do if you deviate from especially
25 radiation effects because the radiation data is for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Zircaloy-4, ZIRLO.

2 But if you deviate from that, the amount
3 of work you have to do depends on the amount of
4 deviation from that database. And chromium coated
5 fuel would definitely be deviating from that database.
6 So would that not -- as far as the radiation effects
7 and the like goes, wouldn't that be covered?

8 MR. CORSON: So the challenge is that
9 there may be -- and, in fact, there probably are
10 different cladding degradation mechanisms. So in
11 particular, you can get the fusion of the chromium
12 into the zirconium that forms a brittle inner
13 metallic. And so this diffusion, of course, it's
14 going to be a function of temperature.

15 At higher temperature, you'll get more
16 inner diffusion. How does that impact cladding
17 embrittlement? Certainly, I think you can do the test
18 procedure.

19 You can apply the test procedure that I'll
20 talk about to show whether you get the same calculated
21 Cathcart-Pawel equivalent cladding reacted and how the
22 embrittlement works as a function of this curve. But
23 again, you have a different mechanism. And so it's
24 hard to say whether the existing testing would
25 necessarily be sufficient to cover all these different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 degradation mechanisms.

2 CHAIR BALLINGER: Yeah, I think the
3 existing testing would not. But the guide would
4 require you to do the additional testings.

5 MR. CORSON: Yes, yeah. So I think that
6 the guidance, in terms of the test procedures, could
7 probably be used to provide some arguments for why
8 this is safer. It meets certain requirements. But
9 you would also have to address these different
10 degradation mechanisms.

11 And that's essentially what the interim
12 staff guidance on chrome-coated cladding says. It
13 basically says the existing stuff may be informative.
14 But there are other things to consider, another one,
15 of course, being the chrome zirconium eutectic which
16 takes place at a higher temperature than what we're
17 talking about here. But it's still not so much
18 higher. It is something to consider.

19 CHAIR BALLINGER: We never said it was
20 going to be easy.

21 MR. CORSON: Yeah, definitely. Definitely
22 not. Next slide, please. Okay. So I was talking
23 about this before. The vendors would come up with
24 their own plan for how often they would do the
25 testing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The guidance allows for relaxation of test
2 frequency with time. And then they wouldn't submit
3 the test results. But they would be available for
4 audit.

5 So we talked about all this before except
6 for that. That last point, I didn't mention. So next
7 slide. All right. So that's it on breakaway
8 oxidation until we get to 1263 about how you apply
9 that limit.

10 So 126w is determining post-quench
11 ductility. And so this is coming up with -- or this
12 defines an experimental method to measure the ductile-
13 to-brittle transition for the zirconium-alloy
14 cladding. So historically going back to the original
15 ECCS rulemaking, we try to define the success criteria
16 in terms of maintaining some cladding ductility.

17 So that's what this testing is for. So
18 the technique has some flexibility where possible to
19 allow for some different variations in equipment.
20 Both this procedure as well as the one in 1261, they
21 started out as Argonne National Lab test procedures
22 and then they were expanded a little bit based on
23 industry comments on the original 50.46c rule. So
24 there is a little bit of flexibility there.

25 CHAIR BALLINGER: So these ring tests have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 been done for many, many, many years.

2 MR. CORSON: Yes.

3 CHAIR BALLINGER: So this is not really
4 that controversial.

5 MR. CORSON: Yeah, yeah. It'd not that
6 controversial. So I'd say this part of the guide,
7 this part of the 50.46c rule, not very controversial.
8 So yeah, the whole point is saying, like, at a
9 particular hydrogen level, this is how much oxygen
10 uptake in your cladding leads to brittle behavior.

11 And so the important thing is that in
12 order to use these techniques and these guides is that
13 you use the calculated equivalent cladding reactant
14 using this Cathcart-Pawel correlation. So this is --
15 it's just a surrogate measure for the embrittlement
16 mechanisms that are going on in the cladding. But
17 it's a useful surrogate.

18 It compares really well to embrittlement.
19 So next slide. So this slide and the next one just
20 show how you would take your test results and come up
21 with what that ductile-to-brittle transition is for a
22 given hydrogen level. So one of the ambiguities in
23 the original guide that was sent out in 2014 before
24 the public comment period is that it's really hard to
25 charge zirconium-alloy cladding to a given hydrogen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 level.

2 There's always going to be some
3 variability. So there are different ways that we can
4 come up with -- in that data together to come up with
5 a limit. So the first approach was to take one
6 sample.

7 So the way the guide recommends is to take
8 a sample. Make it big enough that you can cut it into
9 three smaller samples for the ring compression tests,
10 and then measure what the offset strain or the
11 permanent strain is. So the first approach for coming
12 up with your limits is to just bin all three of the
13 rings from a given sample, average them together, and
14 that's what your average offset strain is for that
15 average hydrogen content.

16 And then you come up with a brittle set or
17 a brittle bin, a ductile bin. And then you can
18 interpolate between the two to get what your limit is
19 at the limiting CP-ECR. So that's one approach. Next
20 slide.

21 And the other approach is just instead of
22 binning, you just take each information ring
23 compression test separately and fit a line through it.
24 So those are the two approaches. And so this would be
25 done for each hydrogen level or a certain number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 hydrogen levels to come up with a curve. So next
2 slide, please.

3 So how do you apply these limits to your
4 zirconium-alloy cladding? That's what this guidance
5 addresses. So it describes an approach to establish
6 limits for both post-quench ductility and for
7 breakaway oxidation.

8 On top of that since we move the peak
9 cladding temperature limit from the rule language to
10 guidance, we made it clear in the guidance that all of
11 this is predicated on having a peak cladding
12 temperature of 2,200 degrees Fahrenheit. If you would
13 go beyond that, you would need to address different
14 mechanisms. There's no guidance available now for how
15 to do that. It's just kind of a warning. You go
16 outside of this, you would need to come up with some
17 other justifications and so on.

18 CHAIR BALLINGER: And there's also a lower
19 temperature limit, right?

20 MR. CORSON: Yeah, so --

21 CHAIR BALLINGER: Maybe ten -- I forget
22 the exact number. But there's a knee in the curve.

23 MR. CORSON: Yeah, you'll see that in a
24 little bit. So I'll talk about that when I get to it.
25 So the guidance also has some ways to consider the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 impact of oxygen diffusion from the inside surface of
2 the cladding.

3 This also dated back to the LOCA research
4 program and the 50.46c days when you have high burnup
5 fuel and binding between the UO2 and zirconium. Some
6 of that oxygen from the UO2 can diffuse into the
7 zirconium which also leads to embrittlement. So the
8 guide talks about how to handle that.

9 Of course, these limits for post-quench
10 ductility are based on hydrogen content in the
11 cladding. So you need to know what your hydrogen
12 content is for a given burnup level or a given oxide
13 thickness. And so the guide has some default cladding
14 hydrogen uptake models that industry could apply if
15 they don't feel like coming up with their own model.
16 And then lastly, it has the analytical for combustible
17 gas generation. That's just taken directly from the
18 old 50.46 rule language and placed into guidance with
19 no additional this is how to come up with a different
20 limit.

21 CHAIR BALLINGER: Okay. None of your
22 slides show the data on hydrogen uptake from which the
23 percent is achieved. The one on M5, you don't have a
24 backup slide with that.

25 MR. CORSON: No, I'm sorry.

1 CHAIR BALLINGER: That data looks like a
2 random walk. And somebody put a line through that
3 data. And it could just as well been vertical because
4 the data is clustered around a column.

5 And yet we designed a 15 percent hydrogen
6 update which I think the M5 people would disagree
7 strongly with because that puts it almost the same as
8 other zirconium alloys from which M5 was supposed to
9 be better. So I'm just -- I mean, I know there's
10 limited data. But you said that vendors could come up
11 with a different number. But I suspect that's one
12 where they'll come up with a different number.

13 MR. CORSON: Yeah, so I mean, they're free
14 to do that. One thing I will note, this is the amount
15 of hydrogen based on how much oxide you form during
16 normal operation. M5 performs much better in that
17 respect. So it has a much lower oxide thickness which
18 means even when you consider the hydrogen pickup
19 fraction, it still typically has a lower hydrogen
20 uptake.

21 CHAIR BALLINGER: I'm just saying the 15
22 percent takes away a lot of their margin.

23 MR. CORSON: Yeah, again, this is -- this
24 was added back, again, 50.46c days. It was added to
25 offer something for vendors and for licensees to come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 into compliance with 50.46c relatively quickly without
2 having to go for approval for some of these sorts of
3 things. So they certainly -- Framatome certainly has
4 flexibility and can propose their own uptake model if
5 they wish.

6 Because the reality is they have a lot
7 more data than what we do. And that was the problem
8 with coming up with the M5 hydrogen update model was
9 there's a lot less publicly available data for that
10 than there was for Zirc 4 or ZIRLO. So that was, I
11 think, part of the reason for the maybe conservative
12 line that was drawn.

13 CHAIR BALLINGER: When I looked at it, I
14 would say once we give people something or tell people
15 something, it's hard to get it back.

16 MR. CORSON: Yeah, fair enough. Okay.
17 Next slide, please.

18 MEMBER PETTI: So this just seems like
19 we're solving yesterday's problem. These things are
20 all developed back then. And because this schedule,
21 we're going to just cut, paste, put them in here now.
22 But it doesn't recognize -- I mean, those days, did M5
23 even exist in the early 2000s?

24 CHAIR BALLINGER: I think so.

25 (Simultaneous speaking.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Yeah, 2005.

2 MR. CORSON: Yeah, it was part of the NRC
3 LOCA program. We did have M5 as part -- we didn't
4 have Op ZIRLO. But we adopted it based on some
5 comments from Westinghouse.

6 MEMBER PETTI: I just -- I'm always
7 worried when you do something like that because the
8 whole context back then is given the context today,
9 you're probably going to get a lot of comments over
10 the comment period. But it's just not -- it's not a
11 good look for the regulator, I guess in my sense.

12 MR. CORSON: Yeah, so the challenge is
13 these are known degradation mechanisms. And it's
14 important to address them in some way. How you
15 address them, of course, is it takes time to come up
16 with the guidance.

17 And so the easiest thing to do given our
18 limited time was to use what we had done in the past.
19 I think it will be an interesting question whether
20 this stuff matters or whether it's more the fuel
21 dispersal stuff. That's really what limits your
22 design and your LOCA analysis in the end.

23 We'll get to that a little later. All
24 these things are happening at 1,200 C or so.
25 Ballooning and burst happens way before that. So what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ends up being limiting, it will be hard to say.

2 And maybe you're right. Maybe this is
3 going to be more yesterday's problem. And it will be
4 other things that are more limiting that we need to be
5 more concerned about.

6 So this is the acceptable limit for the
7 currently deployed alloys. As I had mentioned, we had
8 certain alloys that we tested in our LOCA program
9 which included Zirc 2, Zirc 4, ZIRLO, and M5. Op
10 ZIRLO wasn't included, but Westinghouse had submitted
11 a public comment showing that it should be included.

12 So all those currently approved alloys,
13 this limit could be used. As you had mentioned,
14 there's this knee in the curve above 400 weight ppm of
15 hydrogen. This has to do with the fact that you're at
16 a low enough embrittlement level that the way you do
17 the test, you have to ramp up to a certain
18 temperature.

19 The ramp rate was slow enough that you
20 embrittled before you hit that, that 2,200 degrees
21 Fahrenheit plateau. So that has to do with how the
22 testing was done at Argonne and the NRC program. And
23 that's why there's this knee in the curve there
24 because you hit these embrittlement CP-ECRs before
25 2,200 degrees Fahrenheit. So next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: But in reality, most of the
2 clads today to the left of that --

3 (Simultaneous speaking.)

4 MR. CORSON: Yeah, yeah. Certainly, in
5 the earlier figure where I show the degradation
6 mechanisms, it was kind of small. But it's in the
7 guide. It shows, like, burnup levels for some of the
8 cladding that was tested.

9 The M5 that -- I forget the burnup. I
10 think at least 63 gigawatt days per MTU, it was at 150
11 weight ppm. So yeah, you're right. And Op ZIRLO
12 performs better than ZIRLO as well when it comes to
13 the oxidation.

14 CHAIR BALLINGER: Right. But that's
15 measured hydrogen. If you do the analytics with that
16 rule that you have for M5, you find out that it's not
17 the same. In other words, the required reduction in
18 ECR for M5 gets much lower on that curve if you use
19 the 15 percent.

20 MR. CORSON: Again, it's based on what
21 your calculated oxide thickness is. And then you
22 multiply by the pickup fraction to get what the
23 hydrogen is. I can't say what all the calculated
24 thicknesses are for oxide at end of life for various
25 plants that use M5. So I can't say exactly where it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is on the curve. But I still suspect it's on the left
2 part of it still.

3 CHAIR BALLINGER: It's definitely on the
4 left. But it's not 17 percent. It's more like 12.

5 MR. CORSON: Yeah, certainly, yeah. But
6 I mean, that's the reality that with a relatively
7 small amount of hydrogen uptake, as you said, maybe
8 100, 150, 200 weight ppm. You still get significant
9 embrittlement behavior.

10 That's what all our testing has shown. So
11 it's a real mechanism. So next slide. Oh, there we
12 go. So this section of the guide deals with how you
13 would apply this figure or adopt it for new alloys.

14 So there would still need to be some
15 testing to show that this figure would apply to a new
16 alloy. But it's a relatively small amount of testing
17 compared to what was done to come up with a figure to
18 begin with. So you do some tests on as received
19 cladding to come up with what the fresh no hydrogen
20 content CP-ECR is.

21 You do it on unirradiated cladding.
22 That's within 100 ppm of whatever maximum calculated
23 hydrogen content. You would get an end of life.
24 You're do it halfway, what you get at about halfway
25 through or half of what the maximum hydrogen uptake

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is. And then potentially, you do testing on
2 irradiated material. And so the next slide will cover
3 when testing on irradiated material would be necessary
4 for the guide.

5 CHAIR BALLINGER: This is the progression
6 I alluded to when we were talking about --

7 MR. CORSON: Yeah.

8 CHAIR BALLINGER: -- chromium coated at
9 some point.

10 MR. CORSON: Okay. So the question of
11 what is similar to alloys tested in the LOCA program.
12 So one of the things that the NRC LOCA program at
13 Argonne did was show that pre-hydrided cladding is a
14 good surrogate for irradiate cladding at the same
15 hydrogen level. So what the guide says is that if you
16 have certain specifications, our testing at Argonne
17 gives us enough confidence that irradiated testing
18 would be necessary because it's similar enough to
19 assess at Argonne that unirradiated testing could be
20 used.

21 And so here are the requirements, that
22 it's manufactured essentially the same way using the
23 Kroll process. Operates at less than or equal to the
24 maximum fluence tested in the Argonne program which it
25 was cladding, I think, up to 73 gigawatt days per MTU.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So I'm not -- don't know quite what the conversion is
2 to fluence, but it's around there. That includes
3 similar elements to the materials that were tested and
4 that the alloying content is similar. And it says
5 what the deviation can be to be similar. So next
6 slide.

7 CHAIR BALLINGER: Well, excuse me. Let's
8 go back. The Russian alloy, E110, is basically
9 ozonide, basically zirc-niobium. M5 is basically
10 zirc-niobium. When we -- 25 percent deviation in the
11 alloying elements, that's a lot when it comes to
12 running back to this breakaway oxidation.

13 MR. CORSON: Yeah, so this is just for the
14 post-quench ductility part. So we're talking about
15 the post-quench ductility. So breakaway oxidation,
16 very sensitive to manufacturing, very sensitive to
17 alloy composition.

18 What we've seen for oxidation, post-quench
19 ductility not the same thing. The curves that we've
20 seen, pretty much all the alloys kind of line up on
21 the curve. There are some minor differences between
22 Zirc 4 versus M5 or whatever when it comes to post-
23 quench ductility.

24 But they're pretty similar for pretty
25 different alloy compositions. So next slide. There

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are situations where perhaps industry would want to
2 come up with their own curve for their own post-quench
3 ductility limits either because a new alloy behaves
4 better or because we've shown in our testing program
5 that embrittlement happens more slowly at lower
6 temperatures. So if you had an ECCS design, that
7 gives you lower peak cladding temperatures and you
8 wanted to take credit for that, you could do testing
9 at lower temperatures.

10 And so you would do similar sorts of
11 testing to what we did in the Argonne program where
12 you would look at different hydrogen levels and so on.
13 And it provides guidance for doing that. So next
14 slide. So we talked a little bit about the hydrogen
15 pickup models.

16 As I said, the guide has some acceptable
17 hydrogen pickup models. But of course, vendors and
18 licensees can propose their own. Next slide. So this
19 last part for demonstrating compliance for post-quench
20 ductility, the point is to identify the different
21 conditions and assumptions that maximize the predicted
22 PCT and local oxidation.

23 And so it's important to do this both for
24 stuff below the transition break size as well as above
25 the transition break size. Demonstrate that your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 calculated peak cladding temperature and maximum local
2 oxidation are below these limits. It does talk about
3 dividing up your core into looking at different burnup
4 levels since, of course, you have different
5 embrittlement levels for different cladding burnup
6 levels.

7 So you can take credit for that, if
8 desired. And it has some allowances to use this
9 figure for legacy fuel that might be in the spent fuel
10 pool because plants occasionally will look to the
11 spent fuel pool to put higher burnup assemblies on the
12 exterior of the core or to deal with things like
13 leakers and so on. And of course, if you had
14 something sitting in the spent fuel pool that was made
15 some time ago, it's kind of hard to do testing on that
16 material.

17 So yeah, it provides allowance to do that
18 kind of thing. So next slide. So this next section
19 deals with breakaway oxidation. As I had mentioned
20 for the existing alloys, you can adopt the Argonne
21 data and then just show that whatever the either --
22 the measured breakaway oxidation time or you can set
23 a more conservative limit.

24 So let's say if you had measured breakaway
25 oxidation of 4,000 seconds, you could say, well, we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 going to set the limit at 2,000 seconds just to give
2 us some buffer. In your analysis, you would just show
3 that the time spent above 800 degrees Celsius is less
4 than whatever that minimum breakaway oxidation time
5 is. So next slide.

6 CHAIR BALLINGER: Again, now I'm
7 remembering what the curve looks like for the
8 oxidation. And what you're calling breakaway
9 oxidation as opposed to the little curlicues on the
10 fuel cladding, it's really a change in the slope in
11 the oxidation rate.

12 MR. CORSON: Yeah, it's --

13 CHAIR BALLINGER: And it's not -- it
14 doesn't go vertical. It's just a change in the slope.
15 I'm guessing if I recall a factor of two or so in the
16 slope. So could somebody just include that in their
17 overall analysis?

18 MR. CORSON: So one of the challenges,
19 it's not just that the oxidation rate goes up which it
20 does.

21 CHAIR BALLINGER: The hydrogen.

22 MR. CORSON: It's the hydrogen uptake.

23 CHAIR BALLINGER: But still, you could
24 include that, right?

25 MR. CORSON: Yeah. I mean, I guess you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 could include that. It would certainly be a little
2 more complicated to do that sort of mechanistic
3 analysis. It's not in the guidance, but someone could
4 certainly propose that as being acceptable.

5 CHAIR BALLINGER: Because I think --
6 coming back to above the transmission break size where
7 you're allowed to use best estimate and all kinds of
8 other -- there's easier path. Let's put it that way.

9 MR. CORSON: Yeah, the thing I'll say,
10 though, about breakaway oxidation is it's more of a
11 small break phenomena. You don't really get these
12 long temperature plateaus in the larger breaks. It
13 really only happens in the smaller break where we have
14 the more traditional LOCA analysis. So that's, I
15 guess the caveat here.

16 CHAIR BALLINGER: Okay.

17 MEMBER ROBERTS: Yeah, I think you said
18 this. But if you're looking at a no burst criterion
19 that's around 800 C or maybe a little bit less. And
20 I'm just wondering if this would ever come into play.

21 MR. CORSON: Well, again, for a small
22 break LOCA, you may be at an elevated pressure. And
23 so then your burst temperature could be quite a bit
24 higher than 800 C. I mean, if your system pressure
25 stays comparable to whatever your rod internal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 pressure is, you're not going to balloon and burst.

2 So it could come into play for lower
3 burnup rods. For higher burnup rods, yeah, it's
4 probably not going to come into play because they have
5 higher rod internal pressures. But again, it just
6 depends on what the pressure response of the system is
7 as well.

8 MEMBER ROBERTS: Okay, thanks.

9 MR. CORSON: John Lehning from the staff.

10 MR. LEHNING: This is John Lehning from
11 staff. And I just wanted to add that that no burst
12 criterion that was being discussed was particularly
13 for the higher burnup fuel that might be susceptible
14 to fragmentation in that burnup range. And so it
15 wasn't that we were suggesting that that criterion
16 would apply for the small break, for all burnups,
17 including the fresh fuel and so forth.

18 MR. CORSON: Yeah, thanks for that
19 clarification. I'll get to that more when I go into
20 the fuel dispersal part. But yeah, that's another
21 important thing to note.

22 Okay. So this is something that we added
23 since we moved the hydrogen -- removed the hydrogen
24 generation limit from the rule language. We put it
25 into guidance. Again, we didn't make any changes to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 come up with a new criteria.

2 But this is -- as far as I know, this
3 isn't really a limiting thing. It's not
4 controversial. So we're not changing anything there.
5 So next slide.

6 I talked a little bit about this inner
7 diameter oxidation issue. So we already account for
8 inner diameter oxidation after balloon and burst. So
9 once you balloon and burst, oxygen can get in the
10 cladding.

11 This is already accounted for in models.
12 So the guide just makes clear that you should still
13 keep doing that. What's new is that for higher burnup
14 fuel where you have this fuel clad bonding layer, you
15 can also get some additional oxygen uptake.

16 What we say in the guide is that to be
17 conservative, you just do two-sided oxidation for any
18 higher burnup rods. So that way, you don't need to
19 know mechanistically what's the bonding between the
20 fuel. How much fusion do you get and so on? If you
21 just do two-sided oxidation to account for this,
22 that's sufficient.

23 CHAIR BALLINGER: Now, yeah, in Appendix
24 -- the old Appendix K, still Appendix K, you do two-
25 sided oxidation. But that's after you burst.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: Yes.

2 CHAIR BALLINGER: Okay. And that's
3 legitimately you got water and oxidation and
4 everything. But does allowing two-sided oxidation
5 using those rules, does it penalize people? I don't
6 know if the oxidation rate is for a bonded system.
7 But it seems to me like it would be lower.

8 MR. CORSON: Yeah, it's definitely --

9 CHAIR BALLINGER: A bit lower.

10 MR. CORSON: Yeah.

11 MEMBER PETTI: Solid diffusion problem,
12 that's always lower.

13 CHAIR BALLINGER: Yeah, it is. So is this
14 a significant penalty requiring that?

15 MR. CORSON: Yeah, I mean, it's certainly
16 very conservative, I think. Again, this was done
17 rather than come up with the mechanistically this is
18 what the diffusion between solid O₂ is and solid
19 zirconium for a given burnup level. So the real
20 diffusion is less than what we're proposing.

21 How much less, that's what we don't know
22 exactly. As you say, it's probably a lot less. But
23 this is just something to get started. And people
24 could come up with something better based on their own
25 data and arguments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: But if you require two-
2 sided oxidation, you can basically double the layer.

3 MR. CORSON: And to be clear -- so one
4 thing I should make clear. For the oxidation from the
5 ID, that's just for the embrittlement. It's not for,
6 like, added heat or other things like that.

7 It's just to account for extra
8 embrittlement due to oxygen uptake because that's
9 what's embrittling the cladding. Next slide. Okay.
10 So that's it on the --

11 CHAIR BALLINGER: You made it this far.

12 MR. CORSON: That's it on the 50.46c
13 stuff. So we had these three guides that we had
14 proposed back in the 50.46c days. We made some minor
15 updates, not many, but some minor updates to address
16 the new rule language.

17 And so yeah, there was a lot of back and
18 forth with industry stakeholders during 50.46c. I
19 think the post-quench ductility stuff was I'd say less
20 controversial or not really controversial. As you've
21 said, there is some continued industry interest in the
22 breakaway oxidation stuff that we'll have to address
23 moving forward. So that's it for this presentation.

24 CHAIR BALLINGER: Okay.

25 MEMBER PETTI: Just a final question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Have you guys taken any of your codes and actually try
2 to do some analysis here of following the recipe if
3 you will in the Reg Guides, particularly in light of
4 the transition break size? If you think it's a small
5 break, it could be doing some different stuff. Have
6 you guys actually tried to analytically look at that
7 or are you thinking about it?

8 MR. CORSON: So I -- so I'll start and
9 then I'll defer to my NRR colleagues. But we do
10 periodic analyses looking at the current fleet and
11 comparing them to these 50.46c criterial. So some of
12 those things kind of are in these analyses. John or
13 Joe Messina, I don't know if you want to say more
14 about this.

15 MR. MESSINA: Yeah, we do annual safety
16 assessments -- Joe Messina from the staff. We do
17 annual safety assessments comparing to the 50.46c
18 remnants based on the annual reports that people under
19 LOCA EMs for the changes and errors that they report
20 annually. We would look at the changes that would be
21 expected in the ECT, and the effect that it would have
22 on our ECR when we consider -- when we compare it to
23 --

24 MEMBER PETTI: That's under the component
25 rule set. But under this new transition break size

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rule set, have you re-looked at everything and said,
2 okay, what's our best estimate look like? And then
3 now the low transition breaks, have to look at those
4 LOCAs which maybe we haven't spent as much time
5 looking at them in the past and look at it relative to
6 the Reg Guides.

7 MR. MESSINA: We haven't done any specific
8 calculations regarding connecting it.

9 MR. CORSON: So what I will say, I'm
10 actually going to talk about this a little bit later
11 in the context of fuel dispersal. But about ten years
12 ago when we were considered whether to include fuel
13 dispersal as part of 50.46c, we did a number of
14 calculations looking at how much fuel you would expect
15 to disperse from different plants. And for those
16 analyses, we use our thermal hydraulics code.

17 The types -- more of the types of
18 assumptions that we would use for above the transition
19 break size, not all the same. We still, I think, did
20 loss of offsite power at the start of the accident.
21 But we had more nominal conditions.

22 We weren't necessarily biasing things to
23 be conservative or 95/95 or anything like that. And
24 for those calculations for some of the plants we
25 looked at, we had peak cladding temperatures that were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 pretty low, like, well below where you would even need
2 to worry about balloon and burst. So you certainly
3 didn't need to worry about these things.

4 For the Westinghouse four-loop plan that
5 we looked at, we did have higher peak cladding
6 temperatures where you had ballooning and burst. But
7 it was still a lot lower where you had to worry about
8 these sorts of things. So as I had mentioned, whether
9 these limits will ultimately be limiting, they very
10 well may not be depending on what's predicted for fuel
11 dispersal.

12 It's also hard to say because it depends
13 on what the burnup of your core is, where you put the
14 high burnup assemblies. If you only have lower burnup
15 assemblies in the interior, then you don't necessarily
16 have to worry about fuel dispersal and so on. And
17 then maybe you start to push some of these other
18 limits. But yeah, so we've done some calculations a
19 while ago that look a little bit more like what we'd
20 expect above the transition break size. And we
21 haven't seen anything close to the embrittlement type
22 limits.

23 CHAIR BALLINGER: There's a -- because of
24 the speed of this having to be done, there's a WCAP
25 which we're scheduled to see in a year. But we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and you folks have that takes the FSLOCA and expands
2 the usefulness to all of these break sizes. And they
3 don't get any -- they don't see anything.

4 MR. CORSON: Yeah, so I mean, to your
5 point, this might be yesterday's problem.

6 MEMBER PETTI: That's exactly -- I said to
7 you, I go, what the heck are we doing?

8 CHAIR BALLINGER: The train is moving.
9 Okay. Believe it or not, we are actually ahead of
10 schedule. We're scheduled for a break at 10:15. But
11 the next presentation is likely to be at least as
12 spirited as the one we're having now.

13 And so I would propose that we take our
14 break now because we're going to have a longer
15 presentation next. So it's now 9:38. Let's see if we
16 can get ourselves behind schedule and reconvene at
17 10:00.

18 (Whereupon, the above-entitled matter went
19 off the record at 9:38 a.m. and resumed at 10:00 a.m.)

20 CHAIR BALLINGER: Okay. We're back in
21 session. It's 10:00 o'clock. So again, the floor is
22 yours.

23 MR. CORSON: Okay. So what I talked about
24 earlier this morning was all old stuff. And I can
25 always blame other people for all the things that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 didn't like about that. This is new, and I only have
2 myself to blame for it. So here we go. So next
3 slide, please.

4 You saw this exact same slide yesterday
5 during Joe Messina's talk. I just want to remind
6 everyone what we're talking about. We're talking
7 about during high -- for high burnup fuel, experiments
8 have shown that during under conditions that you would
9 get in a loss of coolant accident, the fuel can
10 fragment, relocate axially, and disperse into the
11 coolant.

12 So the ballooning and burst stuff is
13 driven by difference between the internal pressure,
14 the cladding, and the reactor coolant system pressure.
15 And so if you get this behavior, relocation to the
16 balloon region can impact some things about peak
17 cladding temperature and so on. Bursts, of course,
18 can release fuel into the RCS which is not ideal,
19 let's say. So next slide, please.

20 This slide is meant to show some of the
21 history behind fuel fragmentation, relocation, and
22 dispersal. It's meant to highlight that some of these
23 things were understood quite some time ago,
24 particularly the fragmentation and relocation part.
25 And existing best estimate LOCA models often account

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for this axial relocation which can happen even for
2 lower burnup fuel.

3 What changed around 2006 or so is that
4 tests at Halden on very high burnup fuel around 90
5 gigawatt days per MTU. So far beyond what we have
6 right now showed significant dispersal and significant
7 fine fragmentation. And that's what really led us
8 down this path to studying this issue more.

9 And so there's a few other sort of
10 signposts along the way on this slide which I'll
11 mention a little bit more in the rest of the
12 presentation. So next slide, please. You also saw
13 this slide yesterday during Joe Messina's talk. But
14 basically, the whole point is that when the original
15 ECCS criteria were established, this dispersal issue
16 was not known.

17 The whole point of these rules or the
18 whole point of the rule back then was to prevent a
19 giant pile of rubble essentially forming because of
20 embrittled cladding shattering from this rubble pile.
21 When you start to talk about fuel dispersal, you're
22 starting to approach that thing or that scenario that
23 was the original rules were meant to avoid. So the
24 current rules don't explicitly address this phenomena.
25 Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So of course you heard yesterday we got
2 direction from the Commission to address fuel
3 dispersal as part of this rulemaking. So the rule
4 language is a little ambiguous about how fuel
5 dispersal will be treated. There's some statements of
6 consideration in the Federal Register notice.

7 But a lot of the stuff is being left to
8 guidance for how you address fuel dispersal. So I'll
9 walk through what's in the guide. But at a high
10 level, it includes a model to estimate how much fuel
11 could be dispersed.

12 It provides some high level acceptance
13 criteria for how much fuel you could disperse. And
14 then it has a number of analyses to perform if you
15 predict any fuel dispersal. So again, I'll walk
16 through this in a lot more detail later on.

17 I'd also like to emphasize that this guide
18 builds on a lot of recent research efforts, some at
19 NRC, some through our international partners, some at
20 the national labs. So I'd just like to highlight a
21 few recent publications. So we had the Research
22 Information Letter or RIL 2021-13. It was published
23 at the end of 2021.

24 We briefed ACRS on this. So we've had
25 some back and forth about this document. More

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 recently, we sponsored this Phenomena Identification
2 and Ranking Table or PIRT exercise related to fuel
3 dispersal. So we had our first meetings on that about
4 a year ago.

5 And then we published this report,
6 NUREG/CR-7307. That documents the panel's discussions
7 and conclusions. And so that was just published in
8 May.

9 Separately, EPRI has been working on this,
10 this white paper interpreting how fuel dispersal
11 should be, how the research results should be
12 interpreted. So we were aware of this. We've seen
13 it.

14 And then there's a lot of work going on at
15 the national labs doing additional testing as well as
16 in the international community on this topic. So a
17 lot of stuff going on. And we're using that to inform
18 the guidance.

19 MEMBER PETTI: So just another question.
20 This is harking back to yesterday. Philosophically,
21 what changed that made you guys go from we really
22 don't want any dismissal -- and that's sort of what
23 the old rules implied, whether it was intended or not
24 -- to, well, we're going to give you a little wiggle
25 room, which almost to me, it sounds like a trap.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Because showing something doesn't happen, there's a
2 good criteria, I think you can do it.

3 And it's a goal that has a lot of surety
4 behind it, right? I mean, you can live to that. Once
5 you open the door and allow fragmentation and you
6 start asking questions about uncertainties, you're
7 going to get into unknown unknowns. And you're going
8 to be in what I call analysis hell.

9 You can't get your way out of it. Yet
10 they provided in the guidance to acceptable -- equally
11 acceptable ways. And I don't see it that way. I see
12 them as really different. And to me, that's, again --
13 that's just not the way I think we should write
14 regulations myself going forward. So any thoughts you
15 guys have to help me kind of think through this.

16 MR. CORSON: Yeah, I mean, it's a really
17 good question. I think part of the issue is that it's
18 hard to say that you would get absolutely no dispersal
19 at all, that it's zero. Because if you have
20 ballooning and burst, even for lower burnup rods where
21 we have fragmentation, it's much more coarse
22 fragmentation.

23 But you have fragmentation. You've been
24 at lower burnups. You could lose a very small amount
25 of fuel from that. So certainly it's hard to show

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that it's absolutely zero unless you can complete
2 prevent ballooning and burst.

3 Of course, at these lower burnups, almost
4 nothing would come out. It's essentially zero, but
5 it's not exactly zero. So at what point -- so we can
6 also say, like, if a little bit comes out, if a few
7 pellets' worth were to come out, let's say, that
8 certainly seems like it should be pretty easy to cool.

9 And so philosophically, that should be
10 acceptable. It may be very restrictive to say that
11 you can't disperse any fuel whatsoever. But drawing
12 that line as you say is very difficult.

13 I think maybe the guidance isn't written
14 this way. But I think the staff would prefer to have
15 no dispersal. That would make everyone's life a lot
16 easier.

17 Philosophically, it makes a lot more
18 sense. But we did provide this other pathway in the
19 guidance. So I don't know. I guess it's a difficult
20 philosophical question.

21 You can say that some amount of fuel you
22 can probably show that it's coolable and doesn't have
23 any other bad consequences. But as you say doing that
24 is difficult and maybe a slippery slope and so on. So
25 we're aware of this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We've got direction from the Commission to
2 address it. They didn't say how to address it. But
3 we're trying to read the room, so to speak, on where
4 industry is coming from, where we're coming from, and
5 so on.

6 Come up with something that we find to be
7 acceptable and practical. So next slide. So before
8 I get into the guide, I think it helps to go through
9 the conclusions from the fuel dispersal part. So this
10 involved a number of experts from academia, from the
11 national labs, from the international community who
12 have studied either fuel dispersal itself who are
13 experts in things like core design or thermal
14 hydraulics.

15 So one of their big conclusions is that in
16 order to demonstrate that the fuel would remain
17 coolable, you need to know how much fuel comes out.
18 And so for some of the parameters that impact this
19 that they identify, you can calculate pretty well
20 things like your core loading pattern. Obviously,
21 that's going to affect how much high burnup fuel you
22 have to begin with.

23 If it's in the interior versus the
24 exterior is going to impact its temperature, whether
25 or not it's vulnerable to dispersal and so on. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 some of these things can be calculated pretty well.
2 Other things can't be calculated so well.

3 There's high uncertainty for things like
4 what the fragment size is, how much would come out of
5 a fuel rod if it balloons and bursts, and so on. So
6 they listed some of the things that are well known,
7 some of the things that aren't well known that all
8 impact how much fuel would be dispersed. One other
9 big conclusion is that once fuel leaves the rod, it's
10 pretty difficult to say where it will end up.

11 The thermohydraulics are very complex.
12 The models are probably not quite good enough to
13 predict with a lot of accuracy exactly where the fuel
14 would end up. But what they said is that it should be
15 possible to come up with some bounding scenarios, a
16 few different scenarios where fuel could end up and
17 demonstrate that the consequences would be acceptable.

18 So that was the PIRT panelist's opinion.
19 But that's sort of our jumping off point for this
20 guidance. So next slide. So this slide shows what
21 the structure of the guide is, and I'll talk about
22 each of these things in the following slides.

23 But it starts out with the limits on
24 applicability for the models and the discussions in
25 the guide. It talks about what the thresholds are for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 where you have to start worrying about fuel dispersal
2 has the analytical limits for fuel dispersal. And
3 here as I mentioned a little bit before, we have this
4 sort of two options, no dispersal versus some
5 dispersal.

6 If you have any dispersal, then you have
7 to start worrying about the rest of the guide, being
8 able to predict how much fuel disperses and then
9 evaluating the impacts of that dispersal. So I'll go
10 through all of this in the following slides. Next
11 slide, please. I'll start with the limits on
12 applicability.

13 So the test data that was reported in
14 Research Information Letter 2021-13, it was all UO2
15 fuel in zirc cladding. So that's where we restricted
16 the applicability on the method for estimating the
17 amount of fuel dispersal. What I will say is that
18 there have been other tests performed on fuel with
19 dopants that could be used to support whether this
20 would be applicable or not, whether these thresholds
21 would be applicable or not to these dopants.

22 So unfortunately, a lot of this comes from
23 protected data from, like, the SCIP-IV tests which
24 were just completed in I think June. And there will
25 be some additional upcoming tests. But the vendors

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have access to this data. We have our own access. So
2 there is a way to extend this to different fuel types.

3 MEMBER MARTIN: But -- it's Bob Martin.
4 Looking at your list here of examples, gadolinia seems
5 to stand out, right? Everyone uses gadolinia, right?
6 It would almost seem that the guide is too restrictive.
7 Without gadolinia, it just puts a financial burden on
8 applicants. Is there not enough data with gadolinia
9 to draw similar conclusions or at least joint
10 conclusions about undoped and at least O2 with gad?

11 MR. CORSON: There is, but it's not
12 publicly available. So SCIP-IV did include some tests
13 on gadolinia. As I said, the vendors have access to
14 this.

15 Since the tests were just recently
16 completed, we can petition Studsvik or the SCIP
17 management board to release some of this data.
18 Because of the timing of when this finished versus
19 when we're developing this, we didn't have time to do
20 that and get approval to consider whether we could
21 include that to support this guide itself. So this is
22 relying on what's publicly available right now. And
23 so there is this current restriction.

24 MEMBER MARTIN: Is there nothing at
25 Halden?

1 MR. CORSON: I don't -- they didn't do any
2 LOCA -- they didn't do any LOCA tests on the gad fuel.
3 So again, Studsvik, they did as part of SCIP-IV.

4 CHAIR BALLINGER: Do you have a feeling as
5 to whether those results may affect this guide and/or
6 will you likely have that information? This is a
7 draft guide. We're going through this progression.
8 By the time the draft final gets released for public
9 comment, will that data be available for you guys?

10 MR. CORSON: So this data is already
11 available to NRC. So I'll say I think we have enough
12 information to say whether or not it applies to some
13 of these different fuel dopants. But again, since
14 this is a publicly available guide relying on publicly
15 available information, to say, like, okay, this is
16 applicable to a certain dopant based on some data that
17 no one can see kind of says a little bit what that
18 data has to say, so to speak.

19 So we have the data. We may be able to
20 petition to release it more widely and update the
21 guide to make it applicable or not as appropriate in
22 the draft final rule stage. But right now, we didn't
23 have the time to do that.

24 MEMBER MARTIN: You know, if it was one of
25 those things you can look at the data and it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 indistinguishable from undoped, might that be a slam
2 dunk. I kind of say that there's enough differences
3 that you would -- if you revise this in a few years
4 because the data is available, you would probably have
5 something that's a little bit different. And you have
6 --

7 (Simultaneous speaking.)

8 MEMBER MARTIN: -- this little knowledge
9 you may have.

10 MR. CORSON: I guess what I would just say
11 is no comment at this point. We have enough
12 information to make decisions on these dopants. The
13 vendors do as well. Right now, we can't really talk
14 about it so much in an open forum because it's
15 protected as part of these projects that people pay
16 into. And so certain people have certain expectations
17 of what information can be shared. So --

18 CHAIR BALLINGER: But if there was a
19 cliff, we would know it.

20 MR. CORSON: Yeah, we would know it.

21 CHAIR BALLINGER: To use a term that's
22 been used around here, the cliff edge.

23 MR. CORSON: Yeah, we would know it. So
24 yes, we're aware of this. Unfortunately, again, it's
25 protected as part of the SCIP-IV project. We can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 release that information.

2 We petitioned the SCIP management board to
3 release the SCIP-III data, that Research Information
4 Letter. So there's a process to do it. We may be
5 able to do it for the draft final rule, but we haven't
6 gotten to that point yet.

7 MEMBER MARTIN: Appreciate that.

8 MR. CORSON: Okay. So yeah, that has to
9 deal with the estimating the amount of dispersed fuel.
10 The stuff later on about demonstrating coolability and
11 so on, it's generally applicable to other fuel types.
12 Of course if you had something pretty exotic like
13 uranium nitride, there might be different things that
14 you would have to consider.

15 But I think the principles are still
16 pretty similar. So next slide. So the first thing
17 that the guide talks about is the FFRD thresholds.
18 And really the main concern in all of this is fine
19 fragmentation.

20 It's not necessarily the fragmentation
21 that happens at lower burnups. It's the really fine
22 fragmentation. So you see on the left these figures
23 that were in the research information letter that
24 shows publicly available test data.

25 There's two figures, one just showing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 fragments smaller than one millimeter, another showing
2 smaller than two millimeters. So obviously there's
3 more that are smaller than two millimeters. But the
4 trends are pretty much the same.

5 And based on this data and some arguments
6 in the Research Information Letter, we've concluded
7 that fine fragmentation begins at a burnup of around
8 55 gigawatt days per MTU. We recognized that this is
9 a real oversimplification of what's actually happening
10 in the fuel. It's undergoing a lot of changes to its
11 microstructure.

12 There's other things that impact these
13 changes like temperature. All these things feed into
14 fragmentation behavior. But to simplify things, we
15 just set this burnup threshold in the guidance. So
16 next slide.

17 MEMBER MARTIN: Just looking at it, the
18 figure, you might say 60.

19 MR. CORSON: Yeah.

20 MEMBER MARTIN: Is there no data at 55?
21 I mean, given all the tests that were done or just all
22 hidden behind proprietary --

23 MR. CORSON: Yeah, so again, this is --
24 yeah, so one thing I'll say, this is what we released
25 as part of the Research Information Letter in 2021.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And at that time, there weren't these types of tests
2 in there. Obviously, anyone looks at this figure
3 realizes, oh, yeah, we should probably do some tests
4 in that range which we did as part of SCIP-IV which
5 again is not publicly available right now.

6 MEMBER MARTIN: Thanks for that.

7 MR. CORSON: Yeah. I will say in the
8 Research Information Letter, we did look at a test
9 that was performed at Argonne National Lab. We didn't
10 measure the size distribution. But qualitatively, it
11 started to show some fine fragmentation at 55. So
12 that was another argument in the Research Information
13 Letter, another reason why we said 55 instead of 60 as
14 you say where it jumps up.

15 MEMBER PALMTAG: This is Scott Palmtag.
16 I have a question.

17 So, this says fragmentation begins at 55,
18 current limits are 62 --

19 PARTICIPANT: Right, that's the question.

20 MEMBER PALMTAG: How does this work when
21 these are optional?

22 MR. CORSON: Yes, so, you know, this is a
23 really good question.

24 So, I'll talk about this in a little bit
25 in another slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But one thing I will say is that,
2 typically, the higher burnup fuel in current designs
3 is on the periphery where it's not very vulnerable to
4 ballooning and burst.

5 So, it's not as much of a concern.

6 So, I talked about a little earlier how we
7 did these calculations ten years ago to look at fuel
8 disbursal.

9 And for the Westinghouse plant, there was
10 one high burnup fuel assembly in the center of the
11 core, the very center of the core. Everything else
12 was on the periphery.

13 So, all the stuff on the periphery never
14 got hot enough to balloon and burst.

15 The one in the middle did and so, we had
16 some estimates of how much fuel could be dispersed as
17 a result of that.

18 So, this is, you know, obviously, an
19 ongoing issue that we're trying to resolve.

20 Right now, we're focusing on the voluntary
21 part of this rule.

22 But going forward, we'll have to see what
23 needs to be done for the existing, you know, fleet
24 under the existing requirements.

25 So, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, what I'll say also, you know, in 2015,
2 we were -- well, before this, we were tasked by the
3 Commission to consider fuel dispersal as part of
4 50.46c.

5 We did that. That was the reason we
6 performed some of these calculations in the past.

7 We wrote a SECY paper to the Commission
8 basically saying that, for various reasons, there is
9 no need for immediate action.

10 And part of it is that, based on the way
11 cores are designed, very little fuel that's acceptable
12 could confine fragmentation and dispersal would
13 balloon and burst during a LOCA.

14 It would only happen pretty late in cycle
15 because you would have to get, you know, late in cycle
16 to get to these burnup limits for some of these rods.

17 And so, based on some other, you know,
18 qualitative risk insight type things, we decided there
19 was no need for immediate action.

20 And so, we still believe that's true for
21 existing fleet, existing core loading patterns and so
22 on.

23 So, it's, you know, once you start getting
24 to higher burnups that these issues are exacerbated
25 and there's more of a concern.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so, that's why we're focusing on it
2 for this voluntary rule which is really meant for the
3 higher burnups and enrichments.

4 Next slide?

5 Not only do you need, you know, a certain
6 burnup or certain microstructural characteristics in
7 the fuel to get fragmentation, the research has also
8 shown that you need a certain amount of cladding
9 strain.

10 So, you know, the cladding provides some
11 restraint that prevents the sort of fragmentation
12 behavior.

13 If you get enough strain, this is when you
14 start to see this fragmentation and relocation.

15 So, based on a lot of data, we concluded
16 that below about 3 percent hoop strain, you don't get
17 this fragmentation and relocation.

18 And so, the figure on the left is just
19 meant to show, you know, after one of these tests
20 performed at Studsvik, this was a -- before the SCIP
21 3 program. This is an NRC sponsored test at Studsvik.

22 But after doing the test, they stuck a
23 wire probe in to see how much, you know, how much
24 empty space essentially there was. That's the kind of
25 neon green line.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 They broke the rod in half, shook out all
2 the loose fragments, did the probe again to see how
3 much loose fuel had come out basically, and then, did
4 a gamma scan.

5 So, the black line shows the strain.

6 The blue is the gamma scan were you have
7 a lot of strain. There's no fuel.

8 Where you have less strain, the fuel
9 stayed there intact, everything else.

10 So, you know, based on all these tests,
11 not just the NRC sponsored test at Studsvik, but the
12 SCIP test, we concluded 3 percent strain is a
13 reasonable threshold.

14 Next slide?

15 Okay, so, those are the -- that's meant to
16 identify what rods would be susceptible to
17 fragmentation and dispersal -- to find fragmentation
18 and dispersal.

19 So, this guide provides acceptance
20 criteria for dispersed fuel mass.

21 So, below the transition break size, we
22 continue to say, no fuel dispersal.

23 And so, you address this by showing no
24 ballooning and burst for rods with peak pellet burnup
25 of greater than 55 gigawatt days per MTU.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, that's, you know, below transition
2 break size, straightforward.

3 CHAIR BALLINGER: Excuse me, this is Ron
4 Ballinger.

5 We get confused with units. The 55 is
6 pellet average burnup.

7 And now, you just used the word peak.

8 Are they the same?

9 MR. CORSON: Yes, yes, pellet --

10 CHAIR BALLINGER: Okay.

11 MR. CORSON: average, I should have said,
12 yes. Sorry.

13 Yes, yes, there's a lot of burnup
14 measurements.

15 It's just meant to say like if you take a,
16 you know, pellet or an axial slice, that's what the
17 burnup of that actual slice is.

18 It's not meant to say, you know, the
19 radial local burnup distribution of anything like
20 that, it's, yes, this axial slice is what we're
21 talking about.

22 So, for breaks above the transition break
23 size, as I mentioned, you know, there are two options.

24 No dispersal, which is maybe, I don't
25 know, saying the easy way is really the right

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 terminology because you need to design your core in
2 order to show this, but it's certainly the more
3 straightforward way. You've just shown no dispersal
4 and you don't have to worry about all these other
5 things.

6 Or, you know, as I'll talk about on the
7 upcoming slides, if you predict some dispersal, there
8 are some additional considerations.

9 So, the dispersed fuel mass should be
10 calculated using an approved valuation model and the
11 field dispersal models.

12 So, the fuel dispersal models, that's
13 what's in this guide.

14 The approved evaluation model that's, you
15 know, based on existing guidance and whatever new
16 methods the vendors come up with and propose to us to
17 deal with above the transition break size or to do
18 these new sorts of analyses.

19 So, we did not go into all the details of
20 developing or updating the guidance to say how the
21 evaluation model, part of it would change to do these
22 sorts of analyses.

23 One other thing we did specify, sorry, is
24 to say that the evaluation model should consider the
25 impact of transient fission gas release.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Part of these tests at Halden and Studsvik
2 showed that you can get additional releases of fission
3 gas in part due to either microcracking or this
4 fragmentation of the fuel under loss of coolant
5 accident conditions.

6 Next slide?

7 MEMBER MARTIN: Going back there just a
8 little bit, isn't it on the previous slide were you
9 talk about the 3 percent strain limit and then, talk
10 about it in context of it's backed up by data.

11 Ultimately, the data has limitations,
12 right? And there's, you know, you've looked at burnup
13 only so far.

14 You looked at all these certain fuels, et
15 cetera, et cetera.

16 It seems like it's missing that
17 qualification, like, you know, we look at fuel burnup
18 up to 80 or whatever, whatever the data.

19 You don't just leave the door open, you
20 know, even though people probably aren't going to go,
21 yes, all the way.

22 But, you know, you defend it with data,
23 you've got to qualify limits with the limits of the
24 data set.

25 MR. CORSON: Yes, no, that's a good point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I will say, you know, for the Halden test,
2 the tests were done up to I think as high as like 92
3 or 93, I think it was perhaps used, so very, very high
4 burnup.

5 SCIP, I don't recall. When I have my
6 slides up, I'll be able to --

7 MEMBER MARTIN: Well, not every test may
8 be measured --

9 MR. CORSON: Yes.

10 MEMBER MARTIN: -- at this rate either.

11 MR. CORSON: Yes, so, the Halden test, I
12 think that that's an issue. They didn't necessary
13 measure all the strain.

14 For the SCIP test, they went up to closer
15 to like 80 gigawatt days per MTU.

16 So, that's maybe getting closer to where
17 we would expect.

18 MEMBER MARTIN: And they measured the
19 strain?

20 MR. CORSON: Yes.

21 Yes, so for all of the SCIP 3 tests, and
22 for the NRC sponsored test at Studsvik, they measured
23 the strain. They did a lot more detailed
24 measurements.

25 In the end, Halden did a lot of detailed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 measurements, but back in, you know, 2006 when they
2 first discovered this widespread dispersal, they
3 didn't do nearly as many as detailed measurement as we
4 did subsequently.

5 But yes, up to I'd say like 80 we've done
6 a lot of these more detailed measurements.

7 MEMBER PALMTAG: This is Scott Palmtag
8 again.

9 I'm going -- Ron, you brought up a good
10 point about units because we talk about 62, that's rod
11 average.

12 MR. CORSON: Yes.

13 MEMBER PALMTAG: But your local burnup
14 could be 70 on a rod average.

15 And then, you're -- but you're saying the
16 fuel fragmentation limit is a local burnup, not quite
17 the peak, but the local burnup or maybe a couple
18 pellets?

19 MR. CORSON: Yes, yes, that's the case.

20 So, one thing I'll say about this is, what
21 we've seen in a lot of our calculations, and I think
22 this is consistent with other calculations that we've
23 seen, the first location tends to be pretty high up in
24 the rod where you're maybe a little bit closer to what
25 the rod average is than you might be at another

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 location in the rod.

2 But yes, this is local phenomena.

3 And I'll say the calculations we did
4 earlier and the conclusions we made earlier based on
5 whether we needed to do anything for the current
6 burnup limits and so on, that was based on this
7 understanding of peak local behavior of what the
8 pellets would be at a certain location.

9 So, even with that in our calculations, we
10 still then see, you know, lots of fuel dispersal for
11 existing types of core loading patterns.

12 CHAIR BALLINGER: So, later on in the
13 guide, you probably have looked at the slides, that
14 when it comes to determining how -- dispersal from
15 where?

16 You're using between -- you're assuming
17 it's between spacer grids, right?

18 MR. CORSON: Yes.

19 CHAIR BALLINGER: So, high up in the rod
20 it's a big gradient between spacer grids.

21 And so, that's a little bit of a -- you're
22 having to assume that the releases for, I don't know,
23 ten inches or whatever the number is --

24 MR. CORSON: Yes, I mean --

25 CHAIR BALLINGER: -- between spacer grids.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: -- that would be one way of
2 doing it if you had a more detailed model that showed,
3 you know, strain is more limited within that spacer
4 grid span then you could account for that.

5 But yes, at a minimum or, I guess, at a
6 maximum, it would be limited to the distance between
7 spacers.

8 Just the reason we said this in the guide
9 is that, you know, most codes, you're not going to
10 account for exactly how the spacers impact the strain
11 and all of that.

12 So, it's just easier to say, okay, we're
13 going to cut it off.

14 Like when we do calculations with our FAST
15 code, we don't account for the spacer. So, we might
16 see like several feet above 3 percent strain.

17 But of course, the spacer grids are going
18 to more realistically restrict what that strain is.

19 CHAIR BALLINGER: Just because there's --
20 in general, I don't know if it's codified, there's a
21 1 percent strain limit for design on the cladding.

22 MR. CORSON: Yes, that -- I mean, that's
23 for, you know, like normal operations --

24 CHAIR BALLINGER: That's the starting
25 point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: Yes.

2 MEMBER PALMTAG: Just go back to limits,
3 but you're saying that the limits that you've seen
4 have always been on the outer edge of the core? Not
5 putting words in your mouth.

6 MR. CORSON: Sorry, say that again?

7 MEMBER PALMTAG: You've only seen where
8 the 55's exceeded, has it always been assemblies on
9 the outer edge?

10 MR. CORSON: Yes.

11 (Simultaneous Speaking.)

12 MR. CORSON: So, yes, that's what we see
13 from most just in core designs.

14 I don't know, John Lehning might be able
15 to say more about this because he deals more closely
16 with this stuff.

17 MR. LEHNING: This is John Lehning from
18 the staff.

19 I would just say that there's not any
20 restriction or requirement that, in general, that fuel
21 above that 55 gigawatt day peak or pellet threshold
22 has to be on the periphery.

23 And so, I think what James is talking
24 about is certain typical designs.

25 And so, sometimes, you will see that those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 higher burnup assemblies will be on the periphery, but
2 there's not some restriction.

3 And I guess the other thing I would add
4 that I think Member Palmtag was not present for our
5 review of a topical report that dealt with this issue
6 that was presented maybe before the ACRS, WCAP-18446.

7 And there was some consideration and some
8 discussion then where we went into some more detail
9 about the issue of current operating fleet and that
10 burnup range.

11 And the staff presented some additional
12 thoughts about how we're continuing to look at that.

13 It was also a non-concurrence there about
14 whether that was being dealt with in a sufficient way.

15 But there is more information there. I
16 won't go into a lot more detail on this comment, but
17 certainly, we could explain a little bit more about
18 that if needed.

19 MR. PALMTAG: I just - I mean, I agree
20 with you that if the burnup is limited to the outer
21 edge, we'd have much lower probability of ballooning
22 and bursting, the power is going to be very low.

23 If it starts getting further inborn, that
24 may not hold up.

25 CHAIR BALLINGER: Well, if they go to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 24-month cycle and increase enrichment to 7 or 8
2 percent, then they start pushing these bundles in --
3 further into the core in high burnup.

4 MEMBER PALMTAG: I don't think so.

5 CHAIR BALLINGER: You don't think so?

6 MEMBER PALMTAG: I think they'd still be
7 on the outer edge, but I mean --

8 CHAIR BALLINGER: I mean, outer edge.

9 MEMBER PALMTAG: Yes.

10 MR. CORSON: Yes, well, it'll depend on
11 the core design. This is something for vendors to
12 figure out.

13 What I will say is that the DOE NEAMS
14 program worked with one utility and Westinghouse to
15 come up with, you know, just a hypothetical core
16 design that is 24-month cycles, goes to high burnup,
17 higher enrichment.

18 And for that core design, they did have
19 high burnup fuel in the interior.

20 We did our own calculations using this
21 core design just to sort of demonstrate our methods
22 for doing calculations of fuel dispersal and, yes,
23 there were a lot of high burnup assemblies at end of
24 cycle that were above this burnup threshold, quite a
25 bit above.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But that was a hypothetical core design.
2 It was just, you know, an academic exercise.

3 What vendors would actually come up with
4 remains to be seen.

5 Okay, so, we've been talking about this a
6 little bit, but I guess I'll address it right now in
7 this slide.

8 The plausibility of this no dispersal
9 criterion.

10 I talked about these analyses that we did
11 about ten years ago on the different plant designs.

12 Based on current license burnup limits and
13 fuel management practices, so again, where we have
14 primarily the high burnup assemblies on the outer ring
15 of the core, using generally nominal initial
16 conditions, maybe not quite as far as what we're
17 anticipating for this rule above the transition break
18 size, but certainly closer to that than what you would
19 get in licensing methodologies.

20 And what we saw for those calculations for
21 both large break and some small breaks that we looked
22 at is that we didn't get any dispersal for the CE PWR
23 or the GE BWR for -- that we looked at.

24 The peak cladding temperatures were just
25 too low.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The CE plant was getting, you know, close
2 to where you might start getting some ballooning and
3 burst, but the BWRs was just far below areas where
4 that would be a concern.

5 So, these were just three specific
6 calculations, plant types. It doesn't necessarily
7 mean anything for the entire fleet, but it does show
8 that there are certainly certain plant designs where
9 this is plausible.

10 So, the other thing I'll say is that we
11 specifically asked this question during the public
12 comment period on the regulatory basis.

13 We asked industry, would it be -- do you
14 think it would be plausible to show no dispersal using
15 more realistic LOCA methods?

16 And generally, they said, yes, we do think
17 that this would be possible.

18 So, we, you know, took their word that
19 they think using their own methods, they can do this.
20 And we went with it.

21 So, certainly, you know, this would be the
22 more straightforward path showing no dispersal.

23 So, next slide?

24 But if you don't take that straightforward
25 path, things get a lot more complicated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, I'll start with a method that we had
2 for estimating the dispersed fuel mass.

3 So, I alluded to this a little bit when I
4 talked about the fuel dispersal part. But there are
5 a lot of things that go into how much fuel disperses,
6 not just the fragment size distribution, but things
7 like how big your burst opening size is or what your
8 rod internal pressure is.

9 And so, this on the left, this is another
10 figure from the research information letter
11 contrasting two tests that had, let's say, similar
12 fragmentation profiles, not exactly the same.

13 Obviously, the one on the bottom had more
14 of the big fragments.

15 But they also had very different burst
16 opening sizes.

17 And you can see the one with the very
18 large burst opening dispersed a lot more fuel during
19 the test, even for some of the larger sizes.

20 Whereas, you know, the smaller burst
21 opening, as you would expect, not as much comes out.

22 So, there's a lot of really complicated
23 stuff going on.

24 A lot of these processes are highly
25 stochastic, not really well understood.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, rather than coming up with some
2 mechanistic way of estimating fuel dispersal, we had
3 a much simpler surrogate model that was based on
4 something on the research information letter.

5 MEMBER ROBERTS: Real quick, if you would
6 explain the difference between dispersed and collected
7 mass?

8 MR. CORSON: Yes.

9 So, I talked -- I mentioned this very
10 briefly when I was talking about the relocation stuff.

11 But basically, the test procedure is you
12 run this simulated LOCA test.

13 It balloons and bursts, some fuel comes
14 out.

15 You collect that and measure it.

16 That's the dispersed mass. So, that's the
17 blue in these things.

18 What is then done is -- or what was then
19 done was the rod was broken in half and shaken to
20 shake out loose fragments.

21 So, obviously, this is not something that
22 happens in a LOCA.

23 But it was just meant to try to quantify
24 how much loose stuff there was in the rod.

25 And so, you can see, you know, on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 bottom, there's a relatively large amount of loose
2 stuff in the rod, but it all stayed in there until we
3 broke it apart and shook it out.

4 Whereas, on the top, a lot more came out
5 initially.

6 MEMBER HARRINGTON: This is Craig
7 Harrington.

8 So, the fragmentation or the fracturing of
9 the pellets happens, but without the strain the pellet
10 basically stays intact.

11 Is that --

12 MR. CORSON: So, the --

13 (Simultaneous Speaking.)

14 MEMBER HARRINGTON: -- understanding?

15 MR. CORSON: The pellet pretty much just
16 stays intact when you don't get a lot of strain. You
17 need a lot of strain for it to fragment, you know.

18 And there's a lot of complex processes
19 exactly what's leading to the fragmentation isn't
20 fully understood. It's still debated.

21 But yes, there's, you know, a number
22 things that are happening. And it does rely on a
23 certain amount of strain for this to happen.

24 MEMBER HARRINGTON: And is that a
25 distinction between fracturing and fragmentation?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: Yes, yes.

2 So, like normally, during normal
3 operations, the pellets do fracture. I mean, they
4 undergo a lot of thermal stresses. They fracture.
5 So, they're -- you can look at some pictures,
6 micrographs that you see all these big cracks in
7 pellets.

8 But they're big cracks. So, they're
9 essentially still intact pellets.

10 It's during the LOCA that you get these
11 basically rubble or sand at really high burnups.

12 So, yes, that's the distinction.

13 MEMBER MARTIN: One follow up on that
14 collected.

15 You're cutting a segment and then, shaking
16 it out or --

17 MR. CORSON: So, the whole -- so, these
18 tests are performed on segmented rods.

19 So, you take a full length rod and you cut
20 it into pieces.

21 MEMBER MARTIN: How long?

22 MR. CORSON: For the Studsvik test, they
23 were I think up to 30 centimeters, so a foot --

24 MEMBER MARTIN: Okay.

25 MR. CORSON: -- basically, so pretty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 small.

2 Halden, they went a little bit bigger, but
3 I think no more than 50 centimeters, so a foot and a
4 half roughly.

5 So, yes, they're pretty small samples.

6 You know, there's a lot of discussion
7 about how this relates to a real loss of coolant
8 accident.

9 You have higher gradients in this furnace
10 because you're talking about a pretty small sample.
11 How does that affect the ballooning and burst
12 behavior?

13 So, yes, there's a lot of really
14 complicated stuff. How well this represents real life
15 is still hotly being debated right now.

16 MEMBER MARTIN: Yes, we're seeing that the
17 -- these results with the collected mass would be
18 sensitive to that segmentation.

19 MR. CORSON: Yes.

20 So, I think that's why we tried to also
21 define things in terms of burnup and strain thresholds
22 that you calculate rather than just correlating how
23 much mass comes out because of this length effect.

24 So, I think our philosophy was, it's
25 easier to, you know, you don't know exactly the extent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of the balloon and so on, so it's easier to correlate
2 to something like the --

3 MEMBER MARTIN: Yes, sure, that makes more
4 sense, for sure.

5 MR. CORSON: You know, the collected mass
6 just seems like something you could take with a grain
7 of salt, and the pun was intended. Right?

8 Yes, I mean, some of these probably are
9 that size, so, yes, it's appropriate.

10 MEMBER HARRINGTON: Just to help explain
11 -- I'm Craig.

12 But my understanding is it's the pellet
13 can fragment at any time, but you still have the
14 cladding contact, so it's still holding the pellet
15 together.

16 MR. CORSON: Yes.

17 MEMBER HARRINGTON: It's not to the
18 balloon and burst that it gets released again.

19 MR. CORSON: Yes, so, yes, there's a lot
20 of processes that lead to this fragmentation or fine
21 fragmentation.

22 The fracturing, that's something that
23 happens at normal operations. And as you say, the
24 cladding holds that all intact.

25 Okay, next slide?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 All right, I apologize for how small the
2 font is on here, but this is, you know, figures from
3 the research information letter that you can go back
4 and look at.

5 But what it's showing, the left most
6 figure, this is our correlation showing the fragments
7 that are smaller than one millimeter.

8 And I'll just say, we just drew a line to
9 try to include most of the points. We didn't do any
10 sort of statistical analysis or anything like that.

11 This was just a pretty simple line meant
12 to bound most of the tests showing fine fragmentation
13 behavior.

14 MEMBER MARTIN: This is the same plot as
15 before with a line on it?

16 MR. CORSON: Yes.

17 MEMBER MARTIN: Okay.

18 CHAIR BALLINGER: There's a lot for doing
19 that rather than some sophisticated multi-parameters
20 to physical fit within R square or point one?

21 MR. CORSON: I mean, I'm not that smart.
22 So, I was like, you know, this line looks pretty good,
23 so, yes, that's what I did, you know, a few years ago
24 and it seemed to make some sense.

25 So, yes, on the other figure it shows the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 actual collected dispersed mass during the test.

2 And you see this similar sort of trend
3 where, you know, lower burnups, you have no dispersal
4 or very little.

5 Higher burnups, you get more.

6 So, we had this line showing small
7 fragments basically.

8 We have this other curve with a similar
9 shape showing how much gets dispersed.

10 So, we -- I'll let you ask your question.

11 CHAIR BALLINGER: Is there any correlation
12 with the rim?

13 MR. CORSON: Yes, so, as I said, the exact
14 mechanisms are not fully understood. But certainly
15 the high burnup rim contributes to this a little bit.

16 But it's probably not just the high burnup
17 rim, there's also some restructuring where you're
18 moving towards the rim a little bit more into the
19 pellet where fragments seem to be coming from that as
20 well.

21 Again, the exact mechanisms, what's
22 causing it, not fully understood, but certainly the
23 rim -- high burnup rim plays an effect right here.

24 And so, there is some discussion about
25 like, you know, at what burnup do you start to form a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rim?

2 Does it start to get thick? And those
3 other considerations.

4 It's -- you start for form it before 55,
5 but it's, you know, really, really thin then.

6 So, yes.

7 MEMBER HARRINGTON: This is Craig again.

8 Is there anything unique about the one
9 very low data point?

10 MR. CORSON: Sorry, which particular data
11 point?

12 MEMBER HARRINGTON: Forty-two, 43 gigawatt
13 days?

14 MR. CORSON: Yes, I mean, that was just,
15 you know, based on some -- the testing that we showed
16 in the research information letter that was like the
17 low burnup sample that we had.

18 Certainly, there have been a lot more
19 tests that have been conducted on fuel at much lower
20 burnups than that in various international programs.

21 In all of these programs in the past, we
22 never saw any sort of significant fuel dispersal.

23 So, this wasn't something that was
24 measured going back to those older LOCA tests and
25 Phebus, for example, in France or PBF.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But certainly, if you would keep extending
2 this, you would see, you know, no dispersal, basically
3 no fine fragmentation for those lower burnups.

4 So, this is just like the data set that we
5 chose to show in the realm. There is this one point
6 at this burnup that was in the SCIP 3 program.

7 MEMBER HARRINGTON: So, you just have a
8 range of things that some of which had very low, no
9 mass fraction release even at high burnups over and
10 across the spectrum?

11 MR. CORSON: Yes, you know, I said
12 earlier, burnup is just one thing. There's a lot of
13 other parameters that go into it.

14 And you can, like you say, there's a lot
15 of scatter in this data and there's certainly some,
16 like you said, there's some tests that show less fine
17 fragmentation.

18 I think you can look at this and you can
19 see a lot of those low points are from Halden which,
20 you know, Halden, the tests were performed in a
21 reactor with some internal heating.

22 They also supplemented it with furnaces to
23 get the cladding temperatures they wanted.

24 But those tests, in some ways, were
25 different than what's in the, you know, performed in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the hot cell.

2 So, what difference does that make? You
3 know, is that important? Is this just a coincidence?

4 I'll say we have -- I talked about Oak
5 Ridge is doing a lot of tests in their hot cell on
6 samples from Byron, for example, in the U.S.

7 There's also going to be tests at Oak
8 Ridge -- or sorry, at Idaho National Lab in TREAT.

9 So, then, we will have an in reactor
10 internal heating test to see, you know, does this
11 change the fragmentation behavior.

12 But yes, right now, this is the
13 information we have.

14 There's a lot of scatter.

15 You could argue that our -- you know, the
16 curve we have is conservative, which it probably is,
17 but we're talking about the situation where you
18 disperse fuel with a lot of unknowns and other
19 situations.

20 So, it's maybe appropriate to be -- to err
21 on the side of caution there.

22 MEMBER HARRINGTON: Has anyone just looked
23 at burned fuel and just open up and see if it's
24 fragmented or any correlation on that?

25 MR. CORSON: You mean, just normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 operation?

2 MEMBER HARRINGTON: Yes, normal operation?

3 MR. CORSON: Yes, I -- for all these
4 tests, what's simply done is they do like a before.
5 So, they take a sample that they're not going to test
6 and take a slide and do some optical microscopy or
7 some other SEM, whatever else.

8 And they look at the micro structure
9 before the test and a sample, maybe slightly above
10 where they're actually testing.

11 And then, they look at, you know, similar
12 microscopy, SEM after the test.

13 And yes, that -- you don't see any of this
14 fragmentation happening at high burnup fuel from in
15 reactor stuff.

16 Again, you get some fracturing, you don't
17 get fragmentation until you put it through loss of
18 coolant accident conditions, get significant strain,
19 and so on.

20 So, this is a -- really a LOCA phenomena
21 -- phenomenon and it could potentially happen in some
22 things that have similar heating transients to a LOCA,
23 but --

24 MEMBER PALMTAG: So, the LOCA's actually
25 what causes the fragmentation?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: Yes, yes.

2 MEMBER PALMTAG: Even if it's no burst?

3 MR. CORSON: Yes.

4 So, if you did have enough strain but
5 didn't burst, so there is also some question about
6 this exactly when you get fragmentation.

7 Typically, what we do, we have, you know,
8 we run the tests. We know what it looks like before.
9 We know what it looks like after.

10 We don't know exactly what's happening at
11 each point in time, when exactly it's fragmenting.

12 But certainly, we think that if it
13 balloons and doesn't burst, you get fragmentation.

14 And there was one Halden test that was
15 specifically designed to balloon and not burst. We
16 still saw fragmentation behavior.

17 But as you saw in the curve, those Halden
18 tests had less fine fragmentation. It's fragmented,
19 but they were bigger pieces basically.

20 MEMBER MARTIN: James, it's Bob, again.

21 When you mention LOCA, it's some other
22 events that look like, I assume, and includes
23 reactivity insertion, accidents of same likelihood in
24 that design basis realm?

25 Nodding you head.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: Yes, so, this is --

2 Okay, so, right now, we really focused on
3 LOCA to try to make our lives a little bit easier.

4 The PIRT did look at different scenarios
5 including reactivity initiated accident.

6 So, what I'll say bout reactivity
7 initiated accidents are you need a specific set of
8 circumstances to lead to this sort of behavior.

9 So, you would need something that would
10 not fail the cladding due to pellet cladding
11 mechanical interaction, but would fail it due to
12 ballooning and burst, essentially.

13 And so, you need the right pressure
14 differential across the cladding.

15 You need the right temperature transient
16 and so on.

17 Those conditions are pretty unlikely and
18 I think the -- like much less likely than getting this
19 sort of behavior in a loss of coolant accident.

20 So, the panel -- PIRT panel concluded it
21 wasn't really much of a concern.

22 I will say that we have guidance for
23 reactivity initiated accidents, separate guide already
24 in use that has limits to prevent violent expulsion of
25 fuel.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 There, we're talking about higher enthalpy
2 where you hit the rod with enough energy to basically
3 blow it up.

4 You know, going back to some of the SPERT
5 type --

6 MEMBER MARTIN: And that's been around a
7 while.

8 MR. CORSON: Yes, it's been around a
9 while.

10 So, that limit's been there.

11 Whether you know you would need a lower
12 enthalpy target for higher burnup fuel to prevent
13 ballooning and burst in these situations, I, you know,
14 it's still somewhat of an open question.

15 We're pretty comfortable that it's not a
16 big issue.

17 MEMBER MARTIN: Really did no new tests
18 looking at that in that context to identify an
19 enthalpy limit.

20 MR. CORSON: So, another program that we
21 participated in at NRC is the Cabri International
22 Project.

23 So, the Cabri reactor in France, it's
24 doing tests in a pressurized water reactor loop where
25 they might start to get conditions closer to this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 where you would have to worry about fuel dispersal.

2 So, we're part of that project. The tests
3 are still ongoing and so, it remains to be seen.

4 I'll also say, you know, TREAT is also
5 performing tests on high burnup fuel as part of the
6 FIDES project that we're a part of.

7 And so, again, that's another opportunity
8 to make sure that there's no issues that we discover
9 in these tests on reactivity insertion accidents.

10 MEMBER MARTIN: I think the technical
11 basis for that enthalpy limit also goes back to some
12 Japanese tests, too.

13 MR. CORSON: Yes, we --

14 MEMBER MARTIN: And I can't remember the
15 name of the --

16 MR. CORSON: NSRR.

17 MEMBER MARTIN: There you go, thank you.

18 MR. CORSON: Yes, actually, most of the --
19 I'd say most of our data for RIA probably comes from
20 NSRR. They've done a lot of really good, interesting
21 tests.

22 So, that forms a lot of the basis for our
23 guidance on RIA.

24 I see Dennis has his hand up?

25 DR. BLEY: Oh, yes, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Dennis Bley.

2 It's a very simple question, very simple
3 question for you.

4 As far as we know, this is strictly a
5 physical process it sounds like. And the bits coming
6 out are, I assume, chemically inert ceramic bits.

7 So, we don't have any kind of weird
8 chemistry we're worrying about peak and the rods
9 falling apart, right?

10 MR. CORSON: Yes, I'd say, you know, yes,
11 they're pretty stable.

12 I mean, I can't say for very long-term
13 whether there would be -- if you had dispersal like if
14 we're talking days, weeks, so on, if there would be
15 significant issues.

16 You know, there's already this -- these
17 sorts of considerations for leaking rods and reaction
18 rates with UO2.

19 But, yes, as far as like immediately what
20 happens, it's physical phenomenon.

21 There is some question about whether
22 moisture does impact the dispersal, whether or not the
23 particles are sticky, for lack of a better word, and
24 whether that would impact how much fuel comes out.

25 So, it's still, you know, somewhat of an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 open question. It's sort of physical, sort of
2 chemistry, surface effect type things, still unknown.

3 But yes, in terms of, you know, like long-
4 term stuff, UO2, water interactions, it's not as much
5 of a concern.

6 DR. BLEY: Okay.

7 And, yes, I know, we just don't want this
8 stuff out there, but no real concerns about where it
9 could accumulate, if it would accumulate. And it
10 doesn't sound like it's likely unless these surface
11 effects stuff.

12 MR. CORSON: Yes, I think, you know, this
13 is what Member Petti was getting at.

14 There's -- once you start allowing
15 dispersal, there's a whole lot of things you need to
16 start considering.

17 And some of them, we do specifically have
18 in the guide and have some methods to deal with, maybe
19 just high level conceptual methods, but nevertheless.

20 Then, there are other things, longer term
21 things, equipment qualification, or environmental
22 qualification of equipment, dose effects, all these
23 sorts of things which this guide doesn't deal with.

24 To some extent, like, you know, I
25 mentioned environmental qualification and dose, you'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 hear about Reg Guide 1.183 later and how it thinks
2 about some of these sorts of things.

3 But yes, you know, long-term, whether
4 there's chemical effects, it is a question that would
5 need to be considered if you go down this path.

6 Okay, so, just getting back to this slide,
7 what I'll just say is that, you know, we provided this
8 model for dispersal.

9 The model is based on the small fragments
10 but it doesn't mean that all small fragments disperse
11 or that all that disperses is just fragments.

12 As, you know, I showed on the previous
13 slide, you can get some larger fragments dispersing,
14 some smaller stuff can stay in the rod.

15 But this is just like a surrogate for all
16 the complex things that go into field dispersal.

17 So, next slide?

18 And this just compares this -- if you
19 would apply this surrogate model to these tests that
20 were performed at SCIP 3, what would you get?

21 And in most cases, you would over predict
22 how much fuel was actually dispersed during the test.

23 So, that's how much came out and was
24 collected before any short of shaking or anything like
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 In most cases, we're over predicting that.

2 In some cases, we are slightly under
3 predicting that.

4 So, it's not necessarily conservative in
5 all cases against this test set, but it is, you know,
6 meant to be, you know, somewhat realistic, perhaps
7 erring on the conservative side.

8 But yes, not intentionally conservative.

9 And we mentioned this earlier, it has this
10 on here, the guide also says you can credit spacer
11 grids to limit the axial length of fuel dispersal.

12 And there's a number of things that the
13 spacers do that all act to sort of limit how much
14 stain you get. And that's why we took this position.

15 So, if you predict high burnup rods that
16 are above the fragmentation threshold, if you predict
17 them to balloon and burst, you should perform this
18 sort of calculation to estimate how much fuel comes
19 out of those rods.

20 So, next slide?

21 MEMBER MARTIN: I'll pick on you again.

22 Going back to my comment earlier about,
23 you know, the limitations on limits that are
24 established from data, you know of mentioned the 80.

25 But here, you have last mass friction, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know, a burnup greater than 80.

2 Why don't you just say you stop at 80
3 because that's where the data stops?

4 MR. CORSON: Well, I --

5 MEMBER MARTIN: I mean, it seems to imply
6 that you can support beyond 80, but you don't have the
7 data to support beyond 80, well, everything.

8 MR. CORSON: Everything comes out after
9 80, so that's like the --

10 Again, we had -- we have the Halden tests
11 that were above this 80 gigawatt of days where they
12 didn't -- they didn't do this rigorous measurement of
13 exactly what came out.

14 But qualitatively, a lot came out.

15 So, to say --

16 MEMBER MARTIN: Well, I'm just saying
17 across the board going to like the 3 percent comment
18 I had before.

19 You kind of said, well, the data only goes
20 up to 80, you know, it just gives the impression that,
21 you know, that Reg Guide can apply above 80 when maybe
22 you don't have everything.

23 MR. CORSON: Yes, that's a good point and
24 that's maybe a limitation that we can add that, you
25 know, we think it's -- or we're confident it's only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 good up to about 80 gigawatt days. If you go beyond
2 that, you need to provide additional justification.

3 So, I think that's a good point.

4 Okay, next slide?

5 So, I mentioned this earlier, but, you
6 know, we showed in the RIL that transient fission gas
7 release is an important thing to consider.

8 And what we're concerned about is that
9 there's a situation where you might not predict
10 ballooning and burst without accounting for transient
11 fission gas release.

12 But if you account for it, it would lead
13 to the rod ballooning and burst.

14 So, what -- one very important caveat I
15 have to the figure on the left is that most of these
16 tests were conducted at peak temperatures that were a
17 1,000 degree Celsius or 1,200 degrees Celsius.

18 So, you would already be ballooning and
19 burst before that.

20 So, these tests, some of them did measure
21 the release with time.

22 Others, we just had, at the end of the
23 test, this is how much is released.

24 So, certainly, we would expect the extent
25 of transient fission gas released to be less than the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 highest points on this curve.

2 But there is enough and to show, it may
3 be, you know, 5 percent or so, and it is impacted by
4 burnup.

5 So, we didn't endorse the model in this
6 guide, but we did point to some papers in the
7 literature that discuss this, that discuss temperature
8 effects, and so on that could, you know, sort of get
9 people on the right track, so to speak.

10 Next slide, please?

11 So, now, we're getting into dealing with
12 the consequences of that dispersal.

13 So, the first part deals with transport of
14 the particles in the reactor coolant system.

15 The PIRT had noted that the transport of
16 these irregularly shaped particles that we expect from
17 fragmented uranium dioxide in multi-phase flow is
18 poorly understood.

19 So, to come up with a model for tracking
20 where all of this goes would be very difficult.

21 You could potentially perform some tests
22 to get some qualitative estimates and there is some
23 work, I think, going on right now in industry and at
24 EPRI related to this.

25 But yes, it's really difficult to track

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 where things go.

2 So, what they suggested doing, the panel
3 -- the PIRT panelists, is they suggested coming up
4 with some more simplified scenarios for where the fuel
5 ends up and analyzing those.

6 So, that was the approach that we took.

7 So, one of the most likely scenarios they
8 identified was that material would get trapped on
9 spacer grids. So, certainly, spacer grids can collect
10 some of this material, particularly the bigger
11 particles.

12 So, we recognize that not all material
13 would get trapped on spacer grids. But if you're
14 going to come up with a bounding problem, that seems
15 like a good place to start.

16 Certainly, as you'll see later, you know,
17 some particles could fall down to the lower head or
18 lower regions. And so, we have ways of addressing
19 that as well.

20 The next slide, please?

21 So, assuming, you know, certain
22 configurations, we have a few considerations for how
23 you address fuel coolability.

24 So, first of all, we -- the guide says
25 that you should address the impact and dispersal on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the peak cladding temperature and maximum local
2 oxidation.

3 I'll note that we don't have details in
4 this guide for how that would be done. So, I think
5 that's a shortcoming for how you would consider the
6 impact of dispersed fuel on PCT and maximum local
7 oxidation.

8 What I will say is that we're -- we have
9 plans internally to do some calculations to look at
10 this type of thing in the next couple months or next
11 few months.

12 So, hopefully, when it comes time to the
13 draft rule stage, you might have a few more thoughts
14 on this matter.

15 On top of that, one of the issues with the
16 particle bed is that, even once the particles might be
17 cool, if there's internal heating, if the bed porosity
18 and particle size is -- has certain characteristics,
19 you could reach a point where the water is essentially
20 pushed out of the bed and it can't remain cool
21 anymore.

22 And so, this -- there have been a lot of
23 tests looking at more severe accident scenarios to
24 look at this sort of thing.

25 There's this 0-D Lipinski model that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 developed based on these sorts of tests.

2 So, we say, you know, this is a model that
3 can be used to look at, you know, these debris beds.
4 And it has some ranges of conditions to consider.

5 And the particle size range is just based
6 on the available test data that we have looking at
7 different particle sizes from the tests.

8 And then, the bed porosity also based on
9 some measurements of the porosity within the fuel rod
10 so it's, you know, not quite what you would get
11 outside the fuel rod, but it's informative
12 nevertheless.

13 So, next slide?

14 So this just show, you know, the Lipinski
15 model. These plots come from OECD/NEA Working Group
16 on Fuel Safety report that looked at FFRD.

17 And so, I believe it was some German
18 colleagues did these calculations for different debris
19 bed heights.

20 They did show that under, you know,
21 certain conditions, if you had really small particle
22 sizes, high decay heat loads, you could reach these
23 dryout heat fluxes.

24 So, it is something that would need to be
25 verified if you did have fuel dispersal.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, next slide?

2 So, the guide also says a few things about
3 long-term cooling.

4 One of the issues with long-term cooling
5 is that you could get, you know, some deposition or
6 some chemical precipitates within the bed that could
7 change its porosity.

8 And so, you know, that could impact the
9 dryout heat flux.

10 Of course, in these longer time frames,
11 the decay heat goes down a lot, too.

12 But it's something that would need to be
13 considered.

14 Next slide?

15 MEMBER PALMTAG: I just had a quick --

16 MR. CORSON: Oh --

17 MEMBER PALMTAG: Sorry, this is Scott
18 Palmtag.

19 I just had a quick question.

20 You're talking about these beds that would
21 be hard to cool.

22 How much fuel would have to fail before
23 you'd get -- and I'm thinking a few rods would be
24 negligible.

25 MR. CORSON: Yes.

1 MEMBER PALMTAG: But it needs to be a lot
2 of fuel to fail to get a bed this big.

3 MR. CORSON: So, it would have to be --
4 so, within an assembly, if you fail, let's say, most
5 of the rods because you're at -- you have a high
6 burnup of assembly, you know, inter rod peaking
7 factors are, you know, there's some differences, but
8 you're going to get similar behavior within a given
9 bundle.

10 If all the rods were to fail within a
11 bundle, you could start to get these debris bed
12 heights of, let's say, ten centimeters, which was used
13 in some of the working group on fuel safety
14 calculations.

15 You can start to get those sorts of debris
16 bed heights.

17 So, it is possible where --

18 MEMBER PALMTAG: I'm trying to understand
19 that.

20 So, every fuel assembly would fail --

21 MR. CORSON: So --

22 MEMBER PALMTAG: -- but in the regions
23 between the fuel grids?

24 MR. CORSON: So, it would be just within
25 a certain assembly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Basically, if the fuel is going to collect
2 on a spacer, it's -- the fuel's not going to move
3 necessarily a lot laterally.

4 So, it's most likely going to stay within
5 the assembly that it came from or it's going to go up
6 and down or disperse outward.

7 But so, within one assembly, if the rods
8 fail within that assembly and fuel doesn't relocate,
9 you know, radially, you could start to get these
10 larger debris bed heights, just considering what's
11 between two spacer grids.

12 MEMBER PALMTAG: Okay.

13 MR. CORSON: So, next slide?

14 All right, so I think the last set of
15 analyses that I talked about or the last set of
16 consequence considerations I talk about is this
17 possibility for recriticality of dispersed fuel.

18 So, the PIRT panel did consider this a
19 little bit. Basically, they said it wasn't much of a
20 concern and that there are existing tools that could
21 be used to pretty much do away with this concern.

22 And so, we did some calculations to do
23 this.

24 What we did was we came up with a
25 simplified model of the lower plenum. We just did a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 wet Westinghouse four loop, but this should be
2 applicable in principle to other designs.

3 We assumed that all the fuel that
4 dispersed was at its most reactive configuration, so
5 that's the lowest burnup where you start to get
6 dispersal.

7 And that it had an initial U-235
8 enrichment of 8 weight percent.

9 So, you know, pretty high -- pretty
10 reactive conditions.

11 We didn't credit soluble boron, either.

12 So, next slide, please?

13 So, basically, this is a really extreme,
14 extremely conservative scenario.

15 And when we did these calculations and
16 calculated the effective multiplication factor, for
17 very large masses of dispersed fuel, we were still far
18 below any scenario where you would get at criticality.

19 So, yes, this just has some context for
20 how much fuel in a really extreme case could disperse
21 where if you had, you know, half of your rods were at
22 high burnup, they all failed. Ten percent came out of
23 each rod, extremely conservative, way beyond what's in
24 our models, that would still be less than five metric
25 tons of U-235 -- or sorry, U-02.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so, we still don't even get any sort
2 of criticality concerns far beyond that dispersed
3 mass.

4 So, next slide, please?

5 So, the analysis showed This is very
6 unlikely.

7 There were some earlier calculations that
8 were in this same working group of fuel safety report.
9 Those calculations used a lower enrichment which is
10 why we went back and looked at this again to make sure
11 that higher enrichments aren't a concern.

12 We did only look at this one
13 configuration, but based on some other engineering
14 judgments and how far we are from any criticality
15 concern, we concluded that it's really not an issue
16 that would need to be addressed.

17 So, next slide?

18 I think this brings me to the conclusions.

19 So, this guide provides guidance for
20 addressing the impact of fuel dispersal.

21 There's a lot more detailed stuff or a lot
22 more surety of what needs to be done to show no burst.
23 If you -- no burst for high burnup rods, that is.

24 If you start to disperse fuel, there's
25 less clear guidance, more high level considerations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 because that's, you know, not an ideal path to go.

2 And as I will stress with any guidance,
3 this is just one method of meeting the regulatory
4 requirement. Vendors can, you know, of course,
5 propose something else.

6 So, that's all that I have.

7 Any questions?

8 MEMBER PALMTAG: So, kind of a big picture
9 here, but you have failure, you have disbursement, you
10 get a lot of it, 20 centimeters on the bottom of the
11 beds.

12 So, what's the limit? I mean, what would
13 say is too much disbursement?

14 MR. CORSON: So, I think, you know, that
15 -- it's really hard to say. That 20 centimeter bed,
16 I think the calculated mass was like 2 metric tons.
17 That's a lot.

18 I would still say that's a lot and not
19 desirable.

20 For some of our calculations that we've
21 done and that industry have done for This sort of
22 hypothetical core loading pattern with lots of high
23 burnup fuel in the interior, a lot of other issues
24 with it that would cause it to not be a realistic
25 loading pattern.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But you've been with that kind of
2 unrealistic loading pattern, we're getting more like
3 400 kilograms of dispersal or less, depending on what
4 assumptions you go into it.

5 Whether that would be acceptable based on,
6 you know, the considerations in the guide, we,
7 unfortunately, didn't have a lot of time to do these
8 sorts of calculations.

9 A few hundred kilograms, I did some quick
10 calculations. I think 100 kilograms of fuel in like
11 80 percent packing fraction is something like 11 or 12
12 liters for 100 kilograms.

13 So, I mean, that's a decent amount of fuel
14 for just a 100 kilograms.

15 Is that acceptable or not? That's
16 something we're, I guess, struggling with really, to
17 be honest.

18 MEMBER PALMTAG: I guess that's my
19 question, what's the limit?

20 MR. CORSON: Yes, I mean, the simplest in
21 the guide is zero or come up with something better.

22 So, that's the limit right there.

23 MEMBER PALMTAG: You have to look for
24 coolability?

25 MR. CORSON: Yes, so the concern

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 coolability, that's a big thing that the guide talks
2 about.

3 It does mention there's other issues
4 potentially related to environmental qualification or
5 dose that are dealt with it to some extent in Reg
6 Guide 1.183.

7 But it's -- I'll be honest, it's less
8 clear what would need to be done to demonstrate, you
9 know, to come up with an acceptable limit.

10 That's, you know, we're far more
11 comfortable with zero. Beyond that, we're not as
12 comfortable.

13 And so, we didn't have as clear guidance
14 and we're, frankly, struggling with what would be
15 acceptable.

16 And so, that's where --

17 MEMBER MARTIN: He's making my point.

18 MR. CORSON: Yes, it's --

19 CHAIR BALLINGER: You're sending a very
20 clear message.

21 MEMBER PETTI: Yes, you opened the door
22 and that was a mistake.

23 MR. CORSON: Yes, it's --

24 MEMBER PALMTAG: I'm sorry, this is a big
25 picture, I realize this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So, what's the point of this? You
2 calculate the dispersal, you calculate how much --

3 MR. CORSON: Yes, ideally --

4 MEMBER PALMTAG: So, how is it not allowed
5 --

6 MR. CORSON: Again, ideally, you calculate
7 zero. If you don't calculate zero, then I guess, you
8 know, per the guidance, it is allowed.

9 But what is acceptable and how you
10 demonstrate what's acceptable, that's the part that's
11 not as clear in the guidance. It's not -- to be
12 honest, we haven't come to strong positions on this
13 which is why I think the guidance is a little unclear.

14 Some of this is going to have to be hashed
15 out in the final version of the rule, obviously.

16 Some of it is going to be hashed out
17 during our interactions with the vendors and with
18 industry as well.

19 MEMBER HARRINGTON: With very low
20 regulatory uncertainty -- or very high regulatory
21 uncertainty.

22 MR. CORSON: Yes, yes, that's true.

23 If you disperse anything, it's higher
24 regulatory uncertainty.

25 MEMBER PALMTAG: So, the guide is how to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 calculate it, but there's really -- the limits are
2 still unknown right now?

3 MR. CORSON: Yes, the limits are still
4 unknown.

5 Some of the considerations are known, the
6 coolability thing, certain methods that you could use
7 to come up with acceptable criteria.

8 But there are unknown unknowns, you know,
9 other things that we might not be considering that
10 it's hard to say that these are the only things you
11 need to consider. And this is the only limit.

12 So, it's a tough problem, obviously, to
13 come up with, all the more so in a few months.

14 I think John Lehning has some comments as
15 well from the more regulatory side of things.

16 MR. LEHNING: Yes, John Lehning from the
17 staff.

18 And I think James did a great job of
19 answering that.

20 But I would say, even after we know more,
21 because of the plant, each plant may have a different
22 configuration as well.

23 And so, we could never be in a position
24 where we would be able to say, it's always going to be
25 a 100 kilograms and that goes for every single plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 regardless of the size of the core and the design of
2 the vessel and how much of it may in a certain plant
3 get carried out into the containment or where it might
4 go in the containment.

5 Because I mean, again, it could be some
6 equipment that's being relied on that, if it spills
7 out and fuel may pile on top of a certain piece of
8 equipment.

9 And so, that's why I think that this
10 guidance -- we will know more and we are working to do
11 research.

12 And there are some things where, like the
13 recriticality, where we may be able to sort of
14 dispense with this for a large amount of fleet.

15 And we'll do that where we can. But it's
16 very likely, in my opinion, that on some of these
17 matters, we will still be in a case where, and I think
18 this is what the regulatory guide is trying to do,
19 where it spells out, here are the performance based
20 objectives that need to be satisfied.

21 And then, it's up to the licensees to
22 demonstrate what, in their plant or the vendors to
23 demonstrate for their type of fuel, whether they
24 satisfy those performance based objectives or not.

25 And so, I think that's where this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 likely on some of these to maintain, even in the area
2 after we get done working on it further.

3 MR. CORSON: And I'll also add, you know,
4 philosophically this is a concern for above the
5 transition break size where we're going to a little
6 more realism in the analysis because we think this is
7 a very low likelihood event, So that's another
8 consideration and another struggle.

9 How strict should we be for something that
10 we're expecting to be unlikely. Something that based
11 on our analysis, our inspections, everything else,
12 show is unlikely to occur.

13 I think that's where we're coming from
14 where we say, you know, some dispersal philosophically
15 is acceptable because this is such a low likelihood
16 event. And if it's a small enough amount that should
17 be fine. But then answering the question of how much
18 is enough, that's where we haven't really come up with
19 a good answer beyond just the philosophical, a few
20 grams or a few kilograms is okay.

21 MEMBER PETTI: Remember, this is a classic
22 case of flexibility versus regulatory certainty. And
23 there's a push in one direction, a push in another
24 direction. It's not always the same for every case.
25 But my personal opinion is, this is a slippery slope

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in a difficult area where regulatory certainty may be
2 more important than flexibility.

3 MR. CORSON: Yes, it's, you know, we've
4 struggled with this a lot. You know, not just, we've
5 been working on the rule for seven months, whatever it
6 is. It goes way beyond that.

7 I mean, we've been focusing on this since,
8 really 2006 since we saw those Halden test results.

9 MEMBER PETTI: Right.

10 MR. CORSON: We struggled --

11 MEMBER PETTI: And if you remember our
12 letter on the RIL --

13 MR. CORSON: Yes.

14 MEMBER PETTI: -- a lot of us had concerns
15 that there was enough atypicality in the existing
16 database that until you did something more typical it
17 could look very, very different. And you're trying to
18 make, you know, regulatory decisions on this, it's
19 just, it's fraught with --

20 MR. CORSON: Yes. I think, you know, to
21 that point the challenge is, how do you design a
22 prototypical test.

23 You're almost a hundred percent going to
24 be limited to small segment of the rod. We're not
25 going to build a facility just to create a LOCA and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 melt it down, so.

2 MEMBER PETTI: It would be years ago.

3 MR. CORSON: Well LOFT, yes. Yes.

4 MEMBER PETTI: No, no, no. I mean, also
5 there was tests at PNNL because of full length rods.

6 MR. CORSON: Yes.

7 MEMBER PETTI: It's the same exact issue,
8 but in the days there was a lot more money back then.

9 MR. CORSON: Yes. So I think, you know,
10 we're going to go back to those days where we're
11 building these gigantic multi-million dollar, probably
12 billion dollar to be honest these days, facilities
13 where we're going to do these tests. So there is
14 always going to be, you're always going to have
15 smaller segments.

16 How do you heat that internally, it's
17 really hard to do that. TREAT, you can sort of mimic
18 some of this stuff, but TREAT has its own limitations.

19 Jules Horowitz Reactor, they have some
20 ideas for how they would do tests in that reactor, if
21 they ever get it up and running.

22 MEMBER PETTI: Finish it.

23 MR. CORSON: If they ever finish it. You
24 know, the point is well taken from the ACRS. We've
25 heard similar thoughts from Industry that the tests

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 aren't necessarily prototypical.

2 But they're what we have in coming up with
3 a better test. A more prototypical test is not so
4 straight forward. So we're left with making
5 regulatory decisions on imperfect information.

6 MEMBER ROBERTS: Along with tests as far
7 as how you do analysis. When you mentioned 400
8 kilograms gets out, where is that written down, is
9 that --

10 MR. CORSON: Yes, so we --

11 MEMBER ROBERTS: Is that published?

12 MR. CORSON: Yes. We had, we did this
13 analysis, the Staff did this analysis. We presented
14 it at the NURETH-20 conference in Washington --

15 (Simultaneous Speaking.)

16 MR. CORSON: Yes. In Washington, D.C.
17 last year. We were then invited to submit it to
18 Nuclear Engineering and Design. So there is some
19 minor changes to the, what was published for Nuclear
20 Engineering and Design.

21 MEMBER ROBERTS: Does that appear in an
22 internal document?

23 I mean, the thing about journal and
24 conference papers, you know --

25 MR. CORSON: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: -- you can only fit so
2 much in the 15-page limit or whatever the conference
3 does.

4 MR. CORSON: So no, we don't have more
5 internal, we don't have a longer internal report. I
6 will say we had grand ambitions to write a NUREG or
7 something on that and then we got tasked with doing a
8 rulemaking and --

9 (Laughter.)

10 MR. CORSON: -- and coming up with a PIRT
11 to help support the rulemaking, so. Like a lot of
12 other things you do all this great work and it's
13 wonderful and then you don't have time to document it.
14 And so, we at least got the conference paper out of
15 it. And the NED article out of it.

16 I will say, Industry did very similar
17 calculations and published a report. I think it was
18 Oak Ridge and INL with the same core design, similar
19 sort of methodology.

20 They did publish a report which might have
21 some more details than what's in our paper. At least
22 on the core design, which is the same. The
23 methodologies are a little bit different but they are
24 similar.

25 MEMBER ROBERTS: Okay, great.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: And they came to similar
2 conclusions. I think they had a little bit less
3 disperse mass. Maybe like two or 300 kilograms. But
4 it comes down to what assumptions you make in the
5 analysis.

6 For our analysis I'll say we, at that time
7 we did credit the spacer grids with limiting
8 dispersal, so it certainly would be less than that
9 amount because if you would take the spacer grids into
10 consideration.

11 So yes, that, and that was just, like I
12 said, I can't say this enough, that core design is not
13 very realistic so take those, take that to mind when
14 you think of those numbers. But that's what we have.

15 CHAIR BALLINGER: I think that Craig was
16 actually being kind. If you don't get dispersal no
17 problem. If you do get dispersal you have no
18 regulatory certainty.

19 MR. CORSON: Yes.

20 CHAIR BALLINGER: And that's really a very
21 bad position to be in.

22 MR. CORSON: Yes. I mean, I guess the
23 alternative would have been to write the rule in a way
24 that would prevent any dispersal whatsoever. That was
25 not the decision that was made.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so, to come up with a guide that
2 provides regulatory certainty in seven months when we
3 haven't had time to think of all the various things
4 that go into it, to do all the calculations ourselves,
5 it's not easy, not ideal. So we're left with very
6 imperfect guidance for what happens if you use fresh
7 fuel, which we acknowledge.

8 CHAIR BALLINGER: So that begs the
9 question, given the fact that we've got this
10 potentially very serious issue that could be dealt
11 with, with a little bit more time, we have this
12 restriction on the rule having to be issued by X.

13 We're going to, we're going to issue a
14 rule which no matter what we do in that amount of time
15 will have something along the lines of what you're
16 saying in there. Is that the right thing to do?

17 MR. CORSON: Well --

18 CHAIR BALLINGER: I mean, it's not your
19 call, I'm sure.

20 MR. CORSON: Yes.

21 CHAIR BALLINGER: But is that the right
22 thing to do?

23 MR. CORSON: So it's really tricky. There
24 is different considerations here. I think ideally I
25 would say no that's not necessarily the thing to do.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But this rule is much bigger than just fuel dispersal
2 there is a lot of other stuff in this rule that if we
3 would delay the entire rule just to deal with fuel
4 dispersal it would have other impacts. And Industry
5 has told us a lot, that this rule, and having it done
6 on schedule, is very important to them. So we are
7 somewhat constrained in what we can do.

8 I will say we, you know, requested an
9 extension to our schedule. A lot of it was to deal
10 with more of the stuff that Dave and Rob talked about
11 yesterday, but was to help us as well. And, you know,
12 we got a little bit of a longer schedule but not
13 really.

14 It was a, an extra three months I think is
15 what it ended up being. So we asked. We were kind of
16 accepted, kind of denied. And so, yes.

17 DR. BLEY: Dennis Bley again. So the
18 conundrum that's been hanging us up here at the end,
19 have you heard anything from Industry about their
20 feelings?

21 I mean, it seems to me they're in the spot
22 that you got the rest of the rule and here you're
23 either going none or you really take a gamble. What
24 are the feelings that you've heard back from
25 stakeholders?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CORSON: So the unfortunate thing is
2 that we did not have a time to have public meetings to
3 discuss this specific issue. So I think we'll hear
4 more from them during the proposed rule public comment
5 period.

6 DR. BLEY: Okay. I'll bet.

7 (Laughter.)

8 DR. BLEY: Though I don't know what
9 they'll have to say.

10 MEMBER HALNON: This is Greg Halnon.

11 (Simultaneous Speaking.)

12 MEMBER HALNON: This is Greg. Just a
13 quick question. Do you guys, have you -- or would you
14 consider maybe a graded approach to the level of
15 analysis required or level of justification required?

16 I mean, I understand that you either have
17 dispersal or not, but if you have some, very little,
18 it may not require as much analysis and justification
19 as if you have a lot. And the reason I say this
20 because it just seems like there is a lot of margin
21 and a lot of places that were, say is there, but we're
22 not really crediting the rationale for why it's okay.

23 And maybe we need to go through the public
24 comment, think about, you know, whether it should be
25 a window of, in this window of kilograms, or whatever

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you want to call it, whatever parameter. You don't
2 have to go off and do tests or something like that,
3 but you have to justify it. But it just seems like
4 there could be an opportunity for a graded approach
5 here.

6 MR. CORSON: Yes. I think, you know, in
7 theory yes, I agree, it would be possible to do this.
8 As John Lehning had said earlier, it's hard to say
9 what those thresholds should be though to even do less
10 analysis or more analysis. And that, this is where
11 we're struggling. It's also probably plant specific,
12 as John had alluded it. It's, yes.

13 Again, in theory I agree with you. In
14 practice, coming up with those limits, not so
15 straightforward.

16 MEMBER HALNON: Well everybody is going to
17 be in a learning situation and there going, you know,
18 the applicants are going to find different methods,
19 different ways, different models to be able to justify
20 the amount. And it just seems there could be credit
21 provided for very small issues, but maybe a good
22 learning process.

23 I know you have to get engaged with the
24 vendors and the Industry, and I think that's going to
25 be pretty eye opening so we'll see where it goes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Thanks.

2 MR. CORSON: Yes, we're certainly looking
3 forward to the public comment period I would say.

4 MEMBER PALMTAG: This is Scott. I just
5 want to follow-up on that. I kind of agree with Greg.
6 And at first, I think you've well thought out your
7 processes.

8 And to me it looks like at least you have
9 enough data to get started. I mean, you always want
10 more data but it seems like you have a pretty good
11 limit on the data.

12 But once you start opening the door to
13 these big fluid beds it gets really complicate. If
14 you could maybe allow a one percent or five percent
15 failure maximum I think that's a lot easier to digest.

16 You can learn down the road if someone
17 wanted to go more they could do the analysis. But one
18 or five percent failure seems like a much better
19 target than these huge failures.

20 MR. CORSON: I just --

21 (Simultaneous Speaking.)

22 MR. CORSON: No, I agree. Again, I do
23 back to what is, coming up with those limits, what's
24 the basis for it, why is one percent okay and why
25 shouldn't it be less than that, why should it be more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 than that.

2 You know, these are the things we're
3 struggling with and it's hard to come up with these
4 parameters. And again, it might be somewhat plant
5 specific.

6 DR. BLEY: Well this is Dennis Bley again.
7 It seems to me you don't need to come up with why.
8 And three percent is not okay, you really just need,
9 with some level to say, you know, one percent or
10 whatever it is, some small amount is okay to, at least
11 by engineering judgment can create more judge. It
12 won't create and make a problem.

13 And the other side of that is to the
14 places you're never, well at least not for a long
15 time, is going to get an answer.

16 MR. RAYNAUD: This is Patrick Raynaud of
17 the Staff. I just want to point out that the existing
18 limits on PCT and ECR allow for fuel rod burst. And
19 so, you know, the discussion of allowing no dispersal,
20 even under current burn-ups, you can't say that it's
21 absolutely zero. Even though you have low burn-up
22 fuel you already have a greater than zero amount of
23 dispersal. And so I think that saying no dispersal at
24 all is not really realistic.

25 When it comes to fuel rod ruptures, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know, I think even existing LOCA now that's used
2 within the current criteria would probably result in
3 more than one, five, ten percent of the rods bursting,
4 depending on the transients and other things. And,
5 you know, we can't really limit that to less than one
6 percent or whatever unless we prevent all rod bursts.
7 And that is much more restrictive than the existing
8 PCT and ECR criteria that we have.

9 So I think some of these questions have to
10 be more narrowly qualified. Maybe, you know, what
11 dispersal did we not want to allow? Maybe it's just
12 high burn-up finely fragmented fuel that we don't want
13 to allow. I don't know.

14 If there is some bounds that probably need
15 to be better defined if we go down the avenue if
16 they're saying something like, no dispersal. Well,
17 what kind of dispersal are we talking about
18 specifically because I don't think even within our
19 current regulations we can guarantee no dispersal.

20 MEMBER PETTI: Yes, but I'm a little
21 confused. If when you're above the transition break
22 size you are now best-estimate. And so, I agree with
23 you if the statement was, I had to use all the
24 conservative stuff. But now I, there is a lot of
25 margin there that you could impose a more severe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 criteria than what was under the old rule set because
2 you're doing a best estimate, so, you know. You got
3 to look at it, the rule is set in the criteria
4 together, not just the criteria in and of itself.

5 MR. CORSON: Yes, I'm not sure exactly
6 what the final answer that a vendor would come up with
7 using best estimate would be. I don't know what their
8 final numbers on rod burst would be. I don't know if
9 they can get to zero.

10 MEMBER PETTI: Well we've seen stuff that
11 suggests that --

12 DR. BLEY: Yes.

13 MEMBER PETTI: -- A, they can, and B, the
14 margin, relative to the peak clad temperature is
15 large. Not 10 degrees, not 100 degrees, it is very
16 large. Which is why there's all this discussion about
17 power uprate because now I have margin and I can use
18 it. Why wouldn't you.

19 MR. CORSON: Yes, I mean I, you know, I
20 talked a little bit about our older analyses that use
21 more of the realistic assumptions. Maybe not quite
22 where Industry would go but, yes, we saw that for some
23 plants that we just didn't get any ballooning in
24 bursts let alone for low burn-up stuff. So it's
25 certainly possible.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The way we wrote the rule did leave the
2 door open for some dispersal. I think, you know,
3 whether that's appropriate or not I think we'll get
4 more feedback as we go along from the public comments
5 and so on.

6 Again, I'd say our preferred path is no
7 dispersal period. And, you know, the guide, maybe we
8 don't make that clear enough in the guide, but
9 certainly there is a lot more work to do and a lot
10 less certainty, or no certainty perhaps for if you did
11 disperse anything. But yes, that's where we're at.

12 We do, you know, we got feedback from
13 Industry that no dispersal should be feasible during
14 the regulatory basis public comment. And so as far as
15 we know this might not necessarily be a big issue.
16 But we wanted to have some flexibility because we
17 don't know what the future holds. Doing rulemaking
18 takes a long time, it's a big effort.

19 MR. LEHNING: And John Lehning from the
20 Staff. Just to add to that too. I think this
21 regulatory guide isn't necessarily the only item that
22 would sort of inform how licenses evaluation plant go
23 in the same manner that there are evaluation models
24 that vendors propose in topical reports for the loss
25 of coolant accident.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 As it stands right now we have envisioned
2 that there would be development of additional methods
3 that Industry might come up with, that Staff would
4 interact with them on. And then that might help
5 better define, in more detail, how each vendor or
6 licensee might do these calculations.

7 So I think we don't envision this as the
8 only source of guidance, but I think some of the
9 points, we understand like this idea of having some
10 kind of limit, for now. I think we didn't do that,
11 like James said, because it would just be perspective
12 in one certain value or another. But we do see the
13 data at this time that would support development of
14 methods being along those lines of what could be
15 justified as probably toward the lower end of the
16 spectrum.

17 But I think the overall rulemaking
18 approach here is predicated upon this takes a long
19 time and we wanted to establish this pathway. And for
20 right now the data limitations may require or may
21 cause the vendors and licensees to be somewhat
22 restricted or governed by some lower end.

23 But as they develop more and more data
24 we'll have setup this rule approach and then the
25 guidance modified. And then these methods can be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 developed by vendors that the staff can interact with
2 them on, and then we can work through exactly where do
3 we end up in terms of what's acceptable for these
4 different plant configurations. So that's sort of
5 just a little bit more philosophy of where this is
6 coming from.

7 CHAIR BALLINGER: Questions? More
8 questions? Okay, it is 11:40 and we're sort of on
9 schedule. We're early actually. But we have lunch
10 that's scheduled from 12:00 to 1:00. So let's recess
11 until 1:00 p.m.

12 (Whereupon, the above-entitled matter went
13 off the record at 11:40 a.m. and resumed at 1:00 p.m.)

14 CHAIR BALLINGER: Okay, we're back in
15 session. Elijah, who is going to do the --

16 MR. DICKSON: I'll do the presenting, the
17 talking.

18 CHAIR BALLINGER: Okay. Does Staff want
19 --

20 MR. DICKSON: Do we have a Staff Member
21 running through the slides?

22 PARTICIPANT: Elijah --

23 MR. DICKSON: Thanks. Yes. So want to go
24 ahead and get started?

25 CHAIR BALLINGER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. DICKSON: All right, great. My name
2 is Elijah Dickson. I'm a senior reliability and risk
3 analyst in the division of risk assessment. And this
4 is my co-worker Dave Garmon, health physicist. We'll
5 be presenting today on the increased enrichment
6 rulemaking with respect to the general design criteria
7 of GDC-19 in 10 CFR 50.67.

8 With that, we'll go ahead and go onto
9 Slide 2 please. So the topics today, we'll be
10 discussing the rulemaking driver and goal just very
11 briefly. We'll give a little bit of background in
12 history into the control room design criteria itself.
13 We'll discuss some of the regulatory issues with
14 respect to what we're seeing now with current
15 enrichment and burn-ups and what we expect with higher
16 burn-ups and increased enrichments. Then we'll
17 discuss the rulemaking proposal language itself.
18 We'll walk you through our proposed changes to the
19 rule and our rationales for the proposed changes. And
20 then lastly we'll discuss our rulemaking approach so
21 you can understand our decision making process.

22 So with that let's go ahead and go on to
23 Slide 3. The legislative driver for proposing an
24 amendment to the control room design criteria is the
25 Nuclear Energy Innovation and Modernization Act signed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 into law back in January 14th, 2019. Purpose of this
2 proposed rule in response to the nuclear power
3 industry's interest in accident tolerant fuel, or ATF,
4 in conditional fuel designs with higher enrichment as
5 well as interests in economically beneficial
6 operational targets to meet the standard cycle times
7 as well as perhaps power uprates as well.

8 So what the Staff has done is evaluated
9 several areas of the regulatory framework that would,
10 could be impacted with increased enrichments and
11 higher burn-ups and assess whether or not adjustments
12 can be made in order to support efficient reviews of
13 these licensing actions.

14 With that, let's go on to Slide 4 please.
15 A little bit of background in history of general
16 design criteria for the control room. Both GDC-19 and
17 10 CFR 50.67 provides specific dose base criteria in
18 a 5 rem total effective dosage equivalent, or TEDE,
19 for demonstrating compliance with control room
20 acceptability. These rules represent their own
21 distinct layer of defense-in-depth that assumes a
22 major accident results in a substantial meltdown of
23 the reactor core with a subsequent release of
24 appreciable quantities of fission products to the
25 containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 These are your classic performance-based
2 regulations which require the licensee or applicant to
3 provide a control room accountability design using
4 traditional deterministic radiological consequence
5 analysis methods to judge its acceptability. The
6 performance-based aspects of this rule are typically
7 covered in regulatory guides.

8 Specifically the topic tomorrow will be
9 Reg Guide 1.183. We have a draft guide on that. It's
10 referred to as BG-1425.

11 It's important to note that both the
12 general design criteria under GDC-19 and 10 CFR 50.67
13 are design criteria. And they should not be construed
14 as operational limits.

15 The design criteria itself do not
16 represent actual occupational exposures received
17 during normal operations or emergency conditions which
18 are primarily controlled, are at 10 CFR Part 20, the
19 standards for protection against radiation. Also, the
20 consequence analyses themselves are more than just an
21 initial design analysis or an academic exercise. They
22 do play an important role in the day-to-day operations
23 within the nuclear fleet. Such as verifying other
24 regulatory requirements, guiding maintenance
25 activities, which do incur actual occupational

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 exposures, as well as serve as a guideline in
2 performing a 50.59 analyses as well.

3 Let's go on to Slide 5.

4 MEMBER ROBERTS: Wait, Elijah. Tom
5 Roberts. When you looked at the history did you point
6 out why the word accident instead of design basis
7 accident is used in GDC-19?

8 MR. DICKSON: No, I couldn't find that.

9 MEMBER ROBERTS: And one of your public
10 comments questioned that in whether the, you know, the
11 guideline or at least part of, you know, related to
12 severe accident doses. I guess what your conclusion
13 is, is practice has been, it's a design basis accident
14 dose not a severe accident dose.

15 MR. DICKSON: Yes.

16 MEMBER ROBERTS: I was wondering if you
17 found anything that would, you know, prove that?

18 MR. DICKSON: Yes. These are design basis
19 accidents. We do use what's referred to as a severe
20 accident source term. That's something that we'll be
21 talking about tomorrow in some of the history behind
22 the in-containment source term.

23 There are a few discussions in regards to
24 the purpose of this criterion in the statements of
25 consideration for 50.67 that was published in 1999.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We'll discuss that.

2 MEMBER ROBERTS: Okay, thank you. It's a
3 severe accident released into containment but it
4 doesn't model the several accident phenomena could in
5 fact continue, right?

6 MR. DICKSON: That's correct. That's
7 right. Yes.

8 MEMBER ROBERTS: So it's arguably either
9 very conservative or somewhat not conservative
10 depending on what accident scenario you're looking to
11 assess against.

12 MR. DICKSON: Right. We call that a
13 representative source term for design basis purposes.

14 MEMBER ROBERTS: Right. Okay, thank you.

15 MR. DICKSON: Yes. Okay, so we're on
16 Slide 5. All right. So in moving forward with
17 increased enrichment we, typically what you do is you
18 assess the acceptability of our current regulations.
19 Right now the control room design criteria is one of
20 three cited, three dose base criteria that we use in
21 these analyses.

22 The first being the exclusionary boundary,
23 or EAB. We have the low population zone and the
24 control room. The control room right now is the most
25 limiting figure merit or fact, between the three.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So during the development of the original
2 GDC-19 in the late 1960s and early 1970s they didn't
3 foresee, or staff didn't foresee how licensees are
4 currently operating their facilities and managing
5 their fuel. The history of fuel utilization with the
6 fleet has seen a gradual progression towards higher
7 fuel discharge burn-ups and higher enrichments.

8 There has been enough margin in the
9 facility's design basis to effectively accommodate the
10 control design criteria up to 120 percent, for
11 instance, of their originally licensed steady state
12 thermal power. So during the power uprates about 15
13 years ago we were able to accommodate this, this
14 criterion.

15 The NRC recognizes that there are
16 challenges that the licensees face with obtaining
17 margin within their licensing basis for the purposes
18 of operational flexibility and the small amount of
19 margin to the control design criteria itself. In
20 general, not even specific just to the control room
21 design criteria, it's an unjustifiably low design
22 criteria used in regulations can unnecessarily burden
23 licensees seeking increased enrichments by at times
24 requiring extensive analyses to preserve margin.

25 Often, just from licensing experience,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 it's typical if licensees need additional margin in
2 their consequence analyses that will sharpen our
3 pencils before re-analyses. And sometimes they can be
4 extensive analyses. At times they can deviate from
5 regulatory guidance, the staff then needs to double
6 check the models, reach out to our staff members in
7 the Office of Research, make sure that they're all
8 right.

9 And so what we're looking to do here is
10 make sure everybody stays on the same page in regards
11 to looking at these increased enrichment technologies
12 and utilizing the regulatory guidance that we got.

13 MEMBER PETTI: Elijah?

14 MR. DICKSON: Yes.

15 MEMBER PETTI: Just a question. I
16 understand this idea that the margin to the design
17 limits are getting tighter.

18 MR. DICKSON: Right.

19 MEMBER PETTI: But we're doing two things
20 at the same time. One is, you're talking about losing
21 those, but the source term, that we'll worry about
22 tomorrow --

23 MR. DICKSON: Right.

24 MEMBER PETTI: -- is going tomorrow. Is
25 it about 50/50? Is the source term going down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 providing more greater margin? How is that in there?

2 MR. DICKSON: I think we'll answer that
3 question I think between today and tomorrow. At the
4 very end of this slide I'll sort of talk about our
5 three-prong approach to this rulemaking efforts.

6 I think we can go ahead and just cut to
7 the chase. That we did, we're looking at this in
8 three different ways.

9 One, making improvements to the source
10 term itself, that in containment source term,
11 expanding its applicability to reach licensees
12 operational targets to go to these longer cycle times.
13 So that means we work with the Office of Research in
14 developing this updated Sandia 2023 source term and
15 these pathway specific source term models, right.

16 So then the second prong of this approach
17 is to update the transport models themselves. Several
18 of these transport models can date back to the 1960s
19 in these modeling practices. And so we had
20 discussions last month in regards to developing these
21 pathway specific transport models that can credit
22 safety related features to mitigate the source term
23 that weren't technically credited.

24 And so, and that's one area in this, in
25 the area of consequence analysis that really hasn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 had a lot of attention just updating these transport
2 models. We spent a lot of time and attention on the
3 in-containment source term itself.

4 And then the last part of this three-prong
5 approach is to effectively update the control room
6 design criteria itself. And that's the discussion
7 today. Presenting to you are multiple lines of
8 reasoning as to why we believe it's okay to propose an
9 amendment to amend the control room design criteria by
10 essentially by a factor of two. Okay.

11 MEMBER PETTI: Thanks.

12 MEMBER ROBERTS: Elijah, I'll get to this
13 question eventually, but when I read this whole
14 section what concerned me was that the design criteria
15 is using a somewhat artificial source term. And in
16 reality you'd like to have this habitable condition
17 that's practical in the control room for virtually
18 any, you know, plausible scenario which would include
19 certain accident scenarios like they say in Fukushima.

20 And so, when you get through this, how
21 much of this is pencil sharpening and how much of this
22 is actually allowing a leakier control room or, you
23 know, a relatively higher dose in the control room for
24 accident scenarios that aren't part of the way that
25 you're treating the regulation?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. DICKSON: Sure thing. So it's
2 important to remember that this is a design criteria
3 itself. That it is one part of the overall regulatory
4 framework that demonstrates adequate protection.

5 We went through, we spent a lot of time
6 and attention in the federal register notice, as well
7 as some of these other white papers that we presented,
8 that discussed the radiation protection framework
9 itself, as well as the emergency response plannings.
10 All of that together provides adequate protection to
11 the control room operators and other folks that are,
12 you know, performing emission doses during actual
13 emergencies.

14 We have evidence that this does work quite
15 well. Fukushima being a good example of a very, very
16 beyond design basis accident occurring in which the
17 design basis of the facility was completely moot.
18 Especially the control room itself in an extended loss
19 of offsite power accident where they were able to
20 actively respond to the emergency at hand and ration
21 out the mission doses that were received. And they
22 did a very good job with that.

23 Both UNSCEAR and the IAEA have published
24 reports on that operational experience and how they
25 dealt with maintaining doses of ALARA, essentially.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And they did a very good job trying to work with
2 upwards to several thousand people onsite for that
3 accident.

4 MEMBER ROBERTS: They we were also very
5 hindered by leakage into the control room.

6 MR. DICKSON: What's that?

7 MEMBER ROBERTS: They're also very
8 hindered by leakage into the control room.

9 MR. DICKSON: Yes.

10 MEMBER ROBERTS: There were reports to
11 make masks, you know, 24/7. And had to take some
12 heroic actions for ALARA.

13 MR. DICKSON: Right.

14 MEMBER ROBERTS: I mean, they still got
15 some pretty high doses --

16 MR. DICKSON: This is important to
17 remember, that was design basis. I mean, that's far
18 beyond design basis, not design basis. At some point
19 you do need to say, what is like reasonable for design
20 basis purposes. And that is what has been presented
21 to, you know, with us over several, I think two years
22 now at this point, with that in-containment source
23 term. That the magnitude of that source term is good
24 enough for the purposes of designing the control room.

25 MEMBER ROBERTS: Right. And if you were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 dealing with things like power uprates and details in
2 the transport model and that kind of thing I get that,
3 but if the upshot of a change like this is to allow a
4 leakier control room because that's now permitted per
5 the requirements, you know, I would think you would
6 also need to look at what that might do in terms of
7 the challenge of managing the spurious unit. Because
8 as you point out, the emergency planning and the
9 framework does allow for lots of things you wouldn't
10 do normally. And it also, you know, support, have
11 people onsite to --

12 MR. DICKSON: Right.

13 MEMBER ROBERTS: -- event, and it will do
14 whatever you need to, to keep the people safe within
15 the confines of what the mission is.

16 Again, starting from a condition with a
17 less tight control room --

18 MR. DICKSON: Right.

19 MEMBER ROBERTS: -- just adds to that
20 challenge. And then that's the part I didn't really
21 see --

22 MR. DICKSON: Got it.

23 MEMBER ROBERTS: -- discussed in the white
24 paper. That the upshot is, again, to better model
25 transport, you're great, but the upshot is to have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 leakier control room which would have, in practice,
2 you know, a higher control --

3 MR. DICKSON: I'm not sure if that's the
4 --

5 (Simultaneous Speaking.)

6 MEMBER ROBERTS: -- that seems like, you
7 know, we would want to avoid.

8 MR. DICKSON: I don't think, I appreciate
9 that. And I think that's some things we avoid too.
10 Designing a leaky control I don't think is the intent
11 of these analyses. Is one part of them.

12 The input parameters of these types of
13 analyses or not just assessing the leak tightness of
14 the control room, they're also assessing the leak
15 tighteners of the valves within the facility, the leak
16 tightness of the containment itself. They do have
17 other uses as well, not just control room.

18 MEMBER ROBERTS: Yes, I agree with all
19 that.

20 MR. DICKSON: Yes.

21 MEMBER ROBERTS: I mean, that's all, you
22 know, necessary part of the regulatory instruction --

23 MR. DICKSON: Right.

24 MEMBER ROBERTS: -- to make sure that the
25 containment meets its design requirements because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there is also scenarios where we don't, won't --

2 MR. DICKSON: Right.

3 MEMBER ROBERTS: -- because of the nature
4 of the accident.

5 MR. DICKSON: That's right.

6 MEMBER ROBERTS: And what you have left is
7 the protection of the operators of the control room.

8 MR. DICKSON: Right.

9 MEMBER ROBERTS: And again, if the upshot
10 of the exchanges were to make that environment worse
11 because it's allowed by the regulation then that's
12 something I think we ought --

13 MR. DICKSON: Yes, I'll push back with
14 those types of words of saying that we're making the
15 environment worse. I do not believe we're making the
16 environment worse with providing some relaxation with
17 the control room design criteria.

18 It's important, it's really important to
19 remember that these are not occupational dose limits.
20 We have that controlled under Part 20. Absolutely.

21 MEMBER ROBERTS: Okay, thank you.

22 MR. DICKSON: Thank you. Okay. So part
23 of the discussion we'll be having tomorrow as well is
24 the regulatory guide itself and the in-containment
25 source term. And we'll be discussing what both the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 NRC and the Industry have been doing now for about 40
2 years at this point, and that is transitioning the
3 originally licensed TID-14844 source term that was
4 developed back in 1962 with an alternative source term
5 that was published in NUREG-1465 in 1995.

6 We have been transitioning the fleet. At
7 this point we've done a hundred percent of the fleet,
8 I think. There might be one or two reactors that have
9 not transitioned to the alternative source term.

10 This re-base laying action, these are very
11 large complex multidisciplinary type reviews. The
12 license amendments that come in can often be several
13 thousand pages long for licensees.

14 The engineering analyses and the
15 consequences analyses can take long lead times to
16 develop and prepare. And they can take contractor
17 support as well.

18 From the staff's perspective. From the
19 staff's perspective we have, I just lost my notes. We
20 spent several decades reviewing these licensing
21 amendments under 50.67 to adopt the alternative source
22 term. We have a tremendous amount of licensing
23 experience in this area.

24 And we would like to preserve all that
25 kind of great work. And we're actually proposing some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 great improvements we think, not only to the rule
2 itself but to the guide and to help us move forward in
3 this particular area of the regulatory framework. And
4 as I mentioned, at the very end of the slide I was
5 going to talk about our three-prong approach and the
6 control room design criteria itself was one of those
7 particular areas that we're going to look at.

8 So let's go ahead and go on to Slide 6.
9 So the regulatory issues. When considering rulemaking
10 we need to research the original bases for the rule to
11 understand the Commission's reasoning for developing
12 it in the first place. And once we understand the
13 bases for developing it we can then make informed
14 decisions as to whether or not the rule meets today's
15 needs, right? This particular environment.

16 From there we can assess if some
17 relaxation could be warranted and still provide a
18 reasonable assurance of adequate protection. With the
19 exception of, Member Roberts, with the exception of
20 the 1999 rule, the original bases for the control room
21 design criteria itself is not readily available.

22 We were able to find early drafts of the
23 design criterias published in the late '60s, as well
24 as some meeting minutes, some correspondence between
25 staff. But the numerical selection for that, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 basis for that numerical selection is, wasn't directly
2 addressed.

3 Effectively what they did is they
4 referenced at that point, or that point in time, the
5 part wouldn't, Part 20 radiation protection
6 occupational exposure limits at that point. So it's
7 an easy thing to reference. It's there, why not
8 reference it as a design criteria.

9 Now in the preamble to 10 CFR 50.67, which
10 was published back in 1999, there is a little bit of
11 information regarding the Commission's rationale for
12 the original establishment of the GDC-19. And the
13 first sentence says it all. But then it discusses
14 what the purpose is of these criteria, right?

15 And I'll go ahead and read it verbatim.
16 That the criteria of GDC-19 were based primarily on
17 the occupational exposure limit. That the use of the
18 5 rem TEDE as a control room design criteria did not
19 imply that is the value that would be acceptable
20 during exposures during emergency conditions or that
21 other radiation protection standards of Part 20,
22 including the individual organ dose limit might not
23 apply. The criterion was provided only to assess the
24 acceptability of the design provisions of protecting
25 control room operators under postulated DBA, or design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 basis accident conditions.

2 The DBA conditions assumed in these
3 analyses, although credible, generally did not
4 represent actual accident sequences but were specified
5 as conservative surrogates for creating boundary
6 conditions for assessing the acceptability of engineer
7 safety features.

8 So with that, let's go ahead and go onto
9 Slide 7. We've established now what the purpose of
10 the control room design criteria is. And we'll do a
11 little bit of a refresher in regards to the regulatory
12 basis document and the different alternatives that we
13 assessed in ultimately going down the path of what we
14 decide to do following the public comments that we
15 received.

16 So the first alternative was to maintain
17 the current regulatory framework. The NRC would
18 continue to revise the existing regulatory guidance on
19 an ad hoc basis as the research results and resources
20 become available.

21 Licensees would use regulatory guidance or
22 very likely develop their own regulatory guidance.
23 These are some of the things that we were hearing
24 about maybe four or five years ago that they were
25 having difficulties meeting the control room design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 criteria as specified in the consequences analysis and
2 the regulatory guide. It is likely that the Staff
3 would need to review these on a case-by-case basis as
4 they went through the licensing actions.

5 Alternative 2. The NRC would pursue
6 rulemaking to amend the control room design criteria
7 with stakeholder input and identify and assess a range
8 of acceptable values based on sound regulatory and
9 scientific insights. This would also leverage severe
10 accidents research to develop an updated AST to meet
11 the operational targets the fleet is looking at, as
12 well as develop updated transport models and read
13 baseline several other operational and human health
14 assumptions and guidance.

15 Alternative 3. That is our, effectively
16 our research heavy, research heavy approach where the
17 regulation would remain unchanged. This would
18 initiate new staff initiatives to develop other
19 mathematical methods, computational and statistical
20 analyses and perform consequence analyses.

21 This would have taken we believe several
22 years. And the results of that work would still need
23 to be disseminated out to stakeholders, develop the
24 guidance.

25 Come to ACRS to present on these new

1 methods. And ultimately we felt the presented, if
2 they were still acceptable at that point, in a
3 Revision 3 a regulatory guide 1.183.

4 Okay. So let's go ahead and go on to
5 Slide 8 please. Public comments. In the regulatory
6 basis document the NRC sought comment on each of the
7 proposals. We Recommended Alternative 2 in that
8 regulatory bases comment.

9 And we also asked two questions. The
10 first question sought input as to whether the
11 numerical selection of the control room design
12 criteria would be better aligned with regulations
13 designed to limit occupational exposures during
14 emergency conditions or regulations designed to limit
15 occupational exposures during normal operations.

16 The second question sought to input as to
17 whether a graded risk-informed method for
18 demonstrating compliance with a range of acceptable
19 control room design criteria values instead of the
20 single value would provide the necessary flexibilities
21 for current and future nuclear technologies.

22 Overall, public comments were supportive
23 of a Staff's recommendation to amend the control room
24 design criteria under Alternative 2. They generally
25 suggested a value of 25 be applied to the amended

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 regulation.

2 Nearly all commenters included suggestions
3 to develop a graded risk-informed approach to the
4 control room design criteria. Several commenters
5 commented, relied on PRA technology and methods and
6 contemporary understandings of facility risk profiles
7 to justify a higher numerical value for a low
8 probability high consequence event.

9 As Member Roberts brought up, there was
10 one submitter who was not supportive of Alternative 2
11 or Alternative 3 and preferred to go down the
12 Alternative 1 pathway. And based off of this
13 commenters comments, we felt that it was very
14 important to go very heavy in radiological risk
15 communication.

16 Explaining what the regulatory framework
17 is for radiation protection, as well as framework to
18 response planning and then discuss, at length, what
19 these numerical values actually mean in regards to
20 health effects.

21 So you will see that reflected in the
22 federal register notice, as well as in these other
23 white papers just to, trying to provide some context
24 as to what it is that we're trying to accomplish here
25 in this rulemaking effort. And we also wanted to make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 it very clear that we are not changing the operational
2 exposure limits of Part 20 or its underlying radiation
3 protection philosophies that we've adopted through the
4 ICRP.

5 So with that, we can go on to Slide 9.
6 All right. So we down the alternative to regulatory
7 basis item, I supposed. Within Alternative 2 we
8 identified three options. Options 2A, 2B and 2C.

9 Options 2A and 2C are similar. They would
10 simply amend the control room design criteria to
11 either 10 rem or 25 rem. Option 2A was 10 rem, Option
12 2C would be 25 rem.

13 A value of 10 rem we felt wouldn't provide
14 the additional flexibilities licensees may require and
15 could lead to some possible exemptions if you wanted
16 to go above 10 rem. But then the 25 rem would provide
17 the maximum amount of margin that the Staff was really
18 comfortable.

19 So we also had this option, 2B, which is
20 a combination of the two. Where you can codify the
21 numerical acceptance value by a factor of 2 from 5 rem
22 to 10 rem, but then allow for a graded approach to
23 reaching 25 rem based off of the facility specific
24 risk information. And that's how we've gone down this
25 path now at this point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So let's go ahead and talk about the
2 proposed rulemaking language in Slide 10. Oh, sorry.
3 Yes, Slide 10.

4 High-level changes. We're proposing a
5 modest increase of a factor of 2 from 5 rem to 10 rem.
6 All nuclear power plants in the United States would
7 benefit from a higher but still safe performance level
8 from 5 to 10 rem when implementing advance pool
9 technologies and maintaining their operational
10 flexibilities.

11 If additional margin is needed beyond 10
12 rem they can use facility specific risk profiles or
13 information that can be leverage to just by a higher
14 numerical value.

15 We're also clarifying the purpose of a
16 control room design criteria to distinguish it from
17 the radiation protection and emergency preparedness
18 framework with some proposed textual changes.

19 The proposed amended values will, ranging
20 up to, between 10 and 25 rem would be consistent with
21 aspects of 10 CFR Part 20 which allow for any frequent
22 occupational exposures of the 10 rem. And those that
23 are discussed in 10 CFR 50.47 emergency plans which
24 provide provisions to follow the EPA PAG guidelines
25 which go up to 25 rem depending on the severity of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 accident.

2 Also, the upper range of proposed
3 numerical value would be consistent with the use of 25
4 rem which is applied in other regulations such as the
5 exclusionary boundary and low population zone of power
6 reactor siting which is generally thought to be
7 assessing public protection during emergencies.

8 Then lastly, GDC-1425 would adopt a method
9 and develop a framework for a graded risk-informed and
10 performance-based control room design criteria.

11 Now I'm going to walk you through some of
12 the proposed language on Slide 11.

13 MEMBER MARTIN: Real quick.

14 MR. DICKSON: Yes.

15 MEMBER MARTIN: It's more of an academic
16 question. In considering revising design criteria --

17 MR. DICKSON: Yes.

18 MEMBER MARTIN: -- do you know the EAB has
19 a time as a clock?

20 MR. DICKSON: We're going to talk about
21 that too. Yes. The --

22 MEMBER MARTIN: Okay.

23 (Simultaneous Speaking.)

24 MEMBER MARTIN: -- consider a clock?

25 MR. DICKSON: Oh, you mean like consider

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a clock in changing the acceptance criteria itself for
2 the control room?

3 MEMBER MARTIN: Yes.

4 MR. DICKSON: No --

5 MEMBER MARTIN: I mean, like --

6 (Simultaneous Speaking.)

7 MEMBER MARTIN: -- expect maybe a shift 12
8 hours or something like that.

9 MR. DICKSON: All right. There in the
10 consequence analyses we do have what's known as
11 occupancy factors. And there are occupancy factor
12 assumptions that go into that.

13 And we're not talking about it directly
14 tomorrow in the updates to the reg guide, but what we
15 are doing is providing a provision in the guide that
16 allow licensees to make their own occupancy factors
17 based off of their actual, you know, emergency
18 planning --

19 MEMBER MARTIN: Right.

20 MR. DICKSON: -- plans, right? But yes,
21 we codified in these rules, the other acceptance
22 values that we look at, the exclusionary boundary is
23 25 rem over two hour periods.

24 MEMBER MARTIN: Okay.

25 MR. DICKSON: It's a pretty high dose rate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 as compared to, what we have right now is 5 rem over
2 a 30 day period. And low population zone 2 is a 30
3 day period as well. Yes, that's all I got on that.

4 MEMBER MARTIN: Okay. No, that --

5 MR. DICKSON: Yes.

6 (Simultaneous Speaking.)

7 MEMBER MARTIN: -- you've obviously
8 thought about --

9 MR. DICKSON: Yes.

10 (Simultaneous Speaking.)

11 MEMBER MARTIN: -- question.

12 MEMBER ROBERTS: Elijah, if I get a chance
13 to ask about the process for making these changes. We
14 spent the last day and a half closely looking at FFRD.
15 One of the things that was clear there is the approach
16 is, there is a pretty detailed process for making
17 changes enabled by the rule.

18 MR. DICKSON: Yes.

19 MEMBER ROBERTS: I didn't see any of that
20 here. And in fact, there was a sentence that used to
21 be in the Reg Guide 1.183 that seemed to be deleted
22 that wasn't prior specific approval to make any design
23 change that would be enabled by the AOC.

24 So is your thought that once you put this
25 out there you wouldn't need to get to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 justification to approve the design changes that were
2 enabled by the higher control room dose or the
3 different model?

4 MR. DICKSON: In rev, I'm not sure what
5 specific sentence was deleted in Rev 1. Though in Rev
6 1 we had discussions about how licensees can make
7 changes on their own through 50.59 as long as they
8 meet the acceptance criteria. It's in an NEI
9 document. It escapes me right now.

10 It's an NEI approved document, we're going
11 through 50.59 changes, where they can make a change if
12 their analysis of record is within ten percent of the
13 acceptance criteria in the regulation itself. And if
14 they're within that ten percent they can make the
15 change on their own.

16 But we did retain, I'm almost certain in
17 Rev 1, language that talks about making changes to the
18 technical specifics. That if there is going to be a
19 change made to the technical specification, even if
20 the change meets that 50.59 criteria they still need
21 to come in with the license amendment.

22 MEMBER ROBERTS: Yes, we can talk about it
23 tomorrow, but the sentence that I highlighted that was
24 in Rev 1, but is not in Rev 2, it says, licensees
25 should evaluate proposed modifications that seek to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 downgrade, remove, require engineering safeguards
2 equipment to confirm that the modification does not
3 invalidate its functional state at the facility, PRAS
4 does not adversely impact the facility severe accident
5 management program.

6 So I couldn't find that sentence in Rev 2.
7 It seems to be deleted. So we can talk about that
8 tomorrow when we get --

9 MR. DICKSON: Yes, sure --

10 (Simultaneous Speaking.)

11 MEMBER ROBERTS: -- reg guide.

12 MR. DICKSON: Yes. Thank you.

13 MEMBER ROBERTS: That kind of that gave
14 back my, you know, my question about the leak
15 tightness in the control room. Somebody were to use
16 this criterion to have a leakier control room, that
17 that would appear to give you a hook to at least, you
18 know, get another look at that.

19 MR. DICKSON: Yes.

20 MEMBER ROBERTS: But taking that hook out
21 of the reg guide would then, I think that's something
22 that would be within our scope to do.

23 MR. DICKSON: Okay.

24 MEMBER ROBERTS: So again, just to, you
25 know, to try to make sure that the severe accident and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 worthiness of the control room isn't degraded by these
2 rule changes.

3 MR. DICKSON: Understood. Yes. Thanks
4 for giving me some homework tonight.

5 (Laughter.)

6 MEMBER ROBERTS: Okay. Yes, thank you.

7 MR. DICKSON: Yes. So let me walk you
8 through, is there a question over there, Member
9 Martin?

10 MEMBER MARTIN: No.

11 MR. DICKSON: No? Okay. All right. Let
12 me walk you through the rule change. Or the proposed
13 rule change.

14 And I'm going to discuss more rational for
15 these proposed rule changes. So the original phrase
16 of adequate radiation protection would be replaced
17 with the necessary design fabrication construction
18 testing and performance criteria for structure systems
19 and components in order to safely keep, which is
20 consistent with the purpose of the discussions in the
21 opening paragraph of Appendix A, to 10 CFR Part 50 the
22 general design criteria.

23 As explained in the opening paragraph,
24 SSCs important to safety are those SSCs that provide
25 reasonable assurance that the facility can be operated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 without undue risk to the health and safety of the
2 public.

3 However, over time the appraised adequate
4 radiation protection has been completed with NRC's
5 statutory authority of adequate protection. Adequate
6 protection is achieved through the licensee's
7 compliance with the NRC's comprehensive radiation
8 framework of which the GDC is one part not just one
9 particular design criteria.

10 Also, we are proposing the phrase
11 personnel receiving to be replaced with the phrase
12 calculated and the phrase access and be deleted. The
13 performance of the control room design criteria does
14 not assess actual personnel receiving radiation
15 exposures nor does it assess personnel traveling to
16 and from the site boundary to the control room. We
17 believe that these will help address some of the
18 licensing issues that we received over the last, I'd
19 probably say 20-ish years in licensees adopting the
20 alternative source term.

21 And lastly we are proposing a new
22 paragraph, Paragraph 3, which would provide the
23 additional operational flexibilities if needed be on
24 10 rem up to 25 rem. And execution of this paragraph
25 would be provided in guidance. And we'll be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discussing that tomorrow.

2 Okay. So now that we discussed the bases
3 and the purpose of the rule --

4 MEMBER KIRCHNER: This is Walt Kirchner.

5 MR. DICKSON: Yes, Walt.

6 MEMBER KIRCHNER: Could I interrupt for a
7 moment while this is up?

8 MR. DICKSON: Absolutely.

9 MEMBER KIRCHNER: Could you go over what
10 was deleted and why? For example, access was deleted.

11 MR. DICKSON: Yes. So in, access can be
12 implied in a couple different ways. Access can be
13 just opening the control room door and getting into
14 the control room. The ability to do that.

15 It could also be interpreted as access
16 from the site boundary to the control room itself.
17 And so, when you do the consequence analyses, what you
18 can interpret the phrase access as having to have gone
19 for the dose received to the dose receptor during that
20 period of transit.

21 MEMBER KIRCHNER: Well as a former
22 operator that's the consideration.

23 MR. DICKSON: That's right. We do have
24 TMI action plan items in NUREG-0737 that talk about
25 the use of mission doses. I mean, these are assessed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in a EPR-20 type framework. Does that answer your
2 question potentially?

3 MEMBER KIRCHNER: Well I think the
4 original concept was that the actual operators would
5 not receive a dose in excess of 5 rem TEDE. Well the
6 TEDE wasn't there originally, but --

7 MR. DICKSON: Right.

8 MEMBER KIRCHNER: -- during, for the
9 duration of the accident, so it was designed
10 conservatively. You could say that the 5 rem was
11 arbitrary but it was a conservative estimate. So
12 we're relaxing this.

13 MR. DICKSON: I think another way you
14 could look at it took is that, what about having
15 design provisions for operators that go from the site
16 boundary to the control room. Could there be shielding
17 from the site boundary to the control room? I've been
18 told at times that that's been considered.

19 MEMBER KIRCHNER: Well if you are going to
20 consider, as you suggested, that there could be a
21 rotation in the manning to manage the total exposure
22 and so on, then that would be a valid consideration in
23 laying out such a strategy for relieving operators
24 during the course of the duration of the accident.

25 MR. DICKSON: Okay. And then these are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 just proposals for language. And I do hear what
2 you're saying. Did you want to talk about the phrase
3 calculated as well?

4 MEMBER KIRCHNER: Well what's the subtly
5 that you're trying to make here? It's actually, the
6 concern is an actual operator receiving the dose.
7 This is calculated so I don't have a major problem
8 with that.

9 Obviously the design of the control room
10 and the prediction of the operations is based on
11 shielding and over calculations. Obviously leakage
12 rates, et cetera.

13 MR. DICKSON: Right.

14 MEMBER KIRCHNER: So the whole exercise,
15 for purposes of the existing GDC, and I guess for the
16 new revised proposed language, would be a calculation.
17 I don't have a major problem with that part.

18 MR. DICKSON: Yes, I think, I'm trying to
19 think back to some of my research in the ASTs that
20 we've received. As I mentioned, we've moved the
21 entire fleet now at this point from the TID source
22 term to the AST.

23 And I think I can probably think of three
24 or maybe four facilities that account for this, it's
25 called a, in the consequence analysis world it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 called a travel dose. And these accounted for, like
2 groundshine for instance on, in the contribution to
3 the dose receptor within the control room.

4 Now often, if I recall, those values are
5 usually pretty low. Most of the fleet. Vast majority
6 of the fleet do not consider in this transit dose.

7 I can go ahead and move on to the next
8 slide or we can keep discussing this if you like?

9 MEMBER KIRCHNER: No, go ahead.

10 MR. DICKSON: Okay, thank you.

11 MEMBER KIRCHNER: Thank you.

12 MR. DICKSON: Yes. All right, so now that
13 we've gone over the bases for the rule and talked
14 about the proposal to amend the control room design
15 criteria and some of the proposed contextual language
16 changes as well, I want to walk you through the
17 Staff's decision making process and how we got here.

18 First what we did was we assessed the
19 foundation of the Commission's policies and
20 regulations concerning the radiation protection
21 framework with this common understanding with how and
22 if proposal to the control room design criteria is
23 possible. From there we looked and research evidence-
24 based justifications for proposed numerical values for
25 the control room design criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 With this common understanding of those
2 first two areas we can then proceed with developing
3 reasonable regulatory relief through rulemaking. And
4 so we'll go through each of these items for these next
5 few slides.

6 Slide 13. All right, so let's talk about
7 the foundational policies and regulations that Part 20
8 is based off of. And what we're trying to do here at
9 this point is look for flexibility within the
10 commission policies proposed to submit a control room
11 design criteria value.

12 So Part 20 puts into practice
13 recommendations from the International Commission on
14 Radiological Protection, or ICRP, and its U.S.
15 counterpart, the National Council on Radiation
16 Protection & Measurements, the NCRP. Both these
17 organizations are responsible for the advancements and
18 state of knowledge and practice on all aspects of
19 protection against ionizing radiation to provide
20 recommendations and guidance for public benefit.

21 From this we went to the statements of
22 consideration published in the federal registrar
23 underneath, under 56 FR 23360 published in 1999, which
24 discussed the purpose of 5 rem TEDE for the
25 occupational exposure limit, which is to limit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 stochastic effects, or effectively to limit stochastic
2 effects for cancer mortality for large populations and
3 to prevent deterministic effects.

4 Three is flexibilities provided under
5 planned special exposures as described by the ICRP,
6 recognizing that under certain conditions exceeding
7 the exposure limit may be needed either under normal
8 or emergency conditions. The ICRP does permit up to
9 10 rem in addition to the annual limit, which can
10 equal 15 rem in one year.

11 The NRC, when adopting the ICRP
12 recommendations, it did intentionally reduce this
13 value for planned special exposures from 10 rem to 5,
14 which would equal 10 rem as an upper limit. And
15 that's reflected in our current rules now.

16 The Commission deemed this to be a safe
17 practice specifically because it would be infrequent.
18 And for small groups, or particularly for individuals.

19 Part 20 also retained the lifetime total
20 dose limit for planned special exposure to 25 rem, the
21 same as ICRP recommendations, but it must be spread
22 out over a period of time. No faster than 5 rem in
23 any one year.

24 So our findings from looking at some
25 flexibility within the Commission's policy is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there is flexibility for proposing an amendment to the
2 control design criteria taking a risk-informed
3 approach to this.

4 So with that, let's go ahead and go on to
5 Slide 14. So this slide talks a little bit more, more
6 highlights the radiation protection and emergency
7 response frameworks highlighting that, it covers both
8 normal and emergency responses conditions, as well as
9 prepare licensees to respond to abnormal and emergency
10 conditions to protect the public health and safety.

11 Nuclear power plant facilities are
12 designed to ensure a readiness for a wide range of
13 beyond design basis accident conditions. These
14 regulations mandate comprehensive training, emergency
15 response drills, exercises to equip plant operators
16 and staff with the skills and knowledge necessary to
17 effectively manage an event.

18 Our findings from this review found that
19 there are a range of dose-based of occupational
20 exposure limits, as well as design assigning criteria
21 values that are also dose-based, up to about 25 rem
22 within the regulation. And understanding the basis
23 and purpose, and application of these rules, help
24 inform the Staff in proposing this numerical change
25 from 15 rem to 10 rem and ranging up to 25 rem for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 control design criteria.

2 So with that we'll go and briefly talk
3 about each of these rules over the next three slides.
4 We're on Slide 15.

5 So at the time the GDCs were established
6 in 1971 the Part 20 limit for the occupational
7 radiation exposure was 3 rem whole body for calendar
8 quarter provided that the lifetime dose was verified
9 not to exceed in any specific limit, thus workers
10 could receive up to 12 rem in any one year.

11 And you can see this when you look at the
12 NUREG-0731 radiation exposure information reporting
13 system report. You can look at exposures in the '70s
14 and '80s and see very well that folks, on occasion,
15 would receive actual application exposures above 5
16 rem, sometimes above 10 rem. It's just something that
17 was common back then. Now that's not the case.

18 The fleet have doses like well below 3
19 millirem I think at this point on average. So the
20 current annual limit for occupational exposures under
21 20.1201 is 5 rem per year, but technically a worker
22 could receive an occupational radiation exposure of 10
23 rem over a 12 month period startling two calendar
24 years.

25 And as I discussed with planned special

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 exposures, that individuals could receive an
2 additional 5 rem above their occupational dose limit
3 in one particular year for a maximum of 10 rem in one
4 year.

5 Now let's go ahead and go on to Slide 16
6 talking about the emergency plans. Those are
7 regulations in 50.47 do require licensees to establish
8 the means for controlling radiological exposures
9 during emergency.

10 The rules states that the means for
11 controlling radiological exposures must include
12 exposure guidelines consistent with the EPA's
13 emergency worker and lifesaving activity protective
14 action guides. The EPA exposure guidelines recommend
15 that doses received under emergency conditions should
16 be maintained ALARA and to the extent practical, below
17 5 rem.

18 The guidelines do provide flexibility
19 however. Either in the severity of the event for
20 protecting property values of 10 rem, and for
21 lifesaving and protecting large populations up to 25.

22 All right, so let's go ahead and go on to
23 Slide 17. The upper range to the proposed numerical
24 value would be consistent with the Commission's use of
25 the 25 rem, primarily regulations for power reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 citing. And you can find these under Part 100, as
2 well as in two places in Part 50, 50.34 and 50.67.
3 And I believe there is several areas in Part 52 as
4 well.

5 As discussed in the preamble to the 50.34
6 rule that was published in 1996 in the federal
7 register under 61 FR 65159, it provides a little bit
8 of context in regards to the Commission's use of the
9 25 rem value stating that the Commission's use of 25
10 rem does not imply that it's considered to be an
11 acceptable limit for emergency doses to the public
12 under accident and conditions, but only that it
13 represents a referenced value to the use for
14 evaluating planned features and site characteristics
15 intended to mitigate the radiological releases of
16 accidents in order to provide assurance of low risk to
17 the public under postulated accidents.

18 The Commission dates this, their rationale
19 for continue to use this value based off of the
20 extensive experience applying this criteria in
21 recognition of the conservatism under the assumptions
22 made in the consequence analyses. In particularly, a
23 large fission product released in containment
24 associated with a major core damage accident, maximum
25 leak rates on the containment and conservative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 atmospheric dispersion modeling practices.

2 So with that, I've gone through some, to
3 give context as to how the NRC utilizes the different
4 dose days exposure limits and dose days citing
5 criteria and design criteria. From there we can talk
6 briefly about the Staff's research in regards to what
7 are the evidence-based scientific recommendations out
8 there.

9 So on Slide 18 the Staff reviewed several
10 sources of the material to understand the current
11 recommendations for national and international
12 organizations responsible for making recommendations
13 for radiation protection standards. The purpose of
14 this review is to determine whether reexamining the
15 scientific and technical bases for the numerical value
16 itself would be warranted.

17 Findings, our findings from this review is
18 published in a paper, a white paper, from Dr. Brock in
19 the Office of Research. It's entitled, a Control Room
20 Design Criteria and Radiological Health Effects. And
21 you can find that at the ADAMS number at the bottom of
22 this page.

23 And then general our findings from this
24 review, as well as the continued work on the
25 publication of this white paper is that there are a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 range of international and national organizations that
2 are responsible for making radiation protection
3 recommendations for both normal and emergency
4 conditions up to 25 rem.

5 I'll be going to Slide 19 please. This
6 slide simply presents some of the referenced documents
7 that we reviewed. We looked at the EPA, PAG Manuals
8 CORs, ICRP, IAEA, the NCRP as well as the Health
9 Physicist Society. And I believe the white paper
10 looked at a couple other sources of information too as
11 well.

12 Okay. So let's go on to Slide 20. So as
13 part of our risk communications with this proposed
14 rule we included in the federal register notice pretty
15 much a very extensive discussions on the first
16 principle to radiation protection, health physics and
17 radiological epidemiology.

18 This is because there are a lot of
19 discussion, this is because the discussions that we're
20 having now are tossing around a lot of numbers. And
21 it may not be apparent to the casual reader what these
22 numbers actually mean in terms of actual radiation
23 health effects.

24 The range proposed control room design
25 values is significantly lower than the thresholds for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 observable deterministic health effects such as acute
2 radiation syndrome and hematopoietic syndrome which
3 range around 70 to 100 rad. Which is an acute dose.

4 Additionally, this range is far below the
5 mean lethal dose of ionizing radiation without medical
6 treatment, which is between 300 and 500 rad. And then
7 lastly, is far below the criteria range for estimating
8 individual estimates of cancer risk mortality given
9 the short time frame of these types of exposures.

10 We know from the radiation protection and
11 emergency response programs that we actively
12 monitoring actual occupation exposures before the Part
13 20 limits are met under an actual event. Also, the
14 traditional deterministic DBA consequence analyses
15 will continue to be conservative providing additional
16 defense-in-depth from the Part 20 exposure limit.

17 And the big takeaway is that all of this
18 really, looking at all of this as a whole and the
19 radiation protection framework, the emergency response
20 framework, looking at the recommendations from these
21 other organizations, and then the real actual health
22 physics underpinnings of these values do ensure a high
23 level protection and still be provided well minimizing
24 long-term health impacts.

25 We'll go on to Slide 21. Now that we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 established the Commission's radiation protection
2 framework and the evidence-based justifications for a
3 higher numerical value, we can talk about providing
4 some reasonable regulatory relief. Our findings from
5 our work is that adequate radiation protection for
6 public health and safety, and occupational
7 radiological safety can still be achieved at a higher
8 but still safe control room design criteria
9 performance levels while balancing both dose-savings
10 to workers and providing some regulatory relief to
11 maintain operational flexibilities.

12 We're going to talk about some of the
13 Staff's examinations in regards to just how much
14 margin the light, the fleet has. If we can move on to
15 Slide 22 please.

16 What we did was we went and looked at as
17 many as we could, the analysis of record, design basis
18 accident radiological consequence analyses, or the
19 entire fleet, that have adopted 50.67. The data set
20 that we have here represents about 84 of these
21 facilities. And what we're looking at here is a
22 histogram of the percent margin of these 84 facilities
23 to the 5 rem control and design criteria itself.

24 Of these facilities nearly 70 percent of
25 them are within 25 percent of the 5 rem value. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 they're about between three and three quarters and 5
2 rem. And then to a greater degree about 35 percent of
3 the facilities are within 10 rem, 45 to 5 rem of the
4 controlled design criteria value.

5 Overall the fleet, for the most part, have
6 a relatively small margin to the control design
7 criteria. And we did do a similar analysis on the
8 exclusionary boundary and low population zones. You
9 can see that on Slide 23.

10 We looked at those same 84 facilities for
11 the exclusionary boundary low population zone. This
12 figure represents their percentage margin to these
13 criteria as well. It is good to acknowledge, as you
14 have mentioned, Member Martin, that the calculations
15 themselves are a little bit different.

16 So for the control room and the exclusion,
17 the control room and the low population zone, those
18 calculations are done over a 30-day period. And the
19 low population, and the low EAB, or exclusionary
20 boundary, is done over a two-hour period. But what we
21 can generally see here is that there is plenty of
22 margin to these acceptance values for the fleet.

23 Now let's go on Slide 24. Now that we've
24 given you an idea where the fleet stands in regards to
25 their margin to the control design criteria, I'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 present to you our process in designing the proposed
2 rule in developing the regulatory guide.

3 So, first and foremost, our starting point
4 was considering some Commission directed PRA policies
5 which advocate for certain changes in the development
6 and implementation of its regulations using risk-
7 informed and ultimately performance-based approaches.
8 We have three policies. We have your classic 1985
9 severe reactor policy statement. We have the PRA
10 policy statement of 1995.

11 But then more specifically I'd like to
12 point folks attentions to SRM-SECY-98-114. This is a
13 white paper on risk-informed and performance-based
14 regulations. This SECY paper describes the terms and
15 expectations the Commission has for the Staff in
16 developing risk-informed and performance-based
17 regulations.

18 And we focused on Item 8 within this SRM-
19 SECY. And I'll go ahead and read it now. Stated
20 succinctly, a risk-informed, performance-based
21 regulation is an approach in which risk insights,
22 engineering analysis and judgment, including the
23 principles of defense-in-depth and the incorporation
24 of safety margin and the performance history are used
25 to, one, focus attention on the most important

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 activities, two, establish objective criteria for
2 reevaluating performance, three, develop measurable or
3 calculable parameters for monitoring system and
4 licensee performance, four, provide flexibility
5 determining how to meet the established performance
6 criteria in a way that will encourage and reward
7 improved outcomes, and five, focus on the results as
8 the primary basis for the regulatory decision making.

9 We took this policy and we divided it up
10 into two elements. The first element is in regards to
11 the rulemaking efforts. Elements, Element 1 took sub-
12 items 2 and 3 to develop the proposed rule, and the
13 Element 2 took Item 4 to develop the guided framework.

14 And so if we go on to Slide 25, this shows
15 you how we executed this proposed rule for breaking
16 down the SECY into two fundamental elements. Element
17 1 in a rulemaking we designed a rule which establishes
18 objective criteria for evaluating performance which
19 developed a measurable or calculable parameters from
20 under insistent and licensee performance.

21 Then Element 2 is the guidance to design
22 a regulatory framework which provides flexibility to
23 determine how to meet the established performance
24 criteria in a way that will encourage and reward
25 improved outcomes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So with that in mind, and understanding
2 how the Staff proposed this rulemaking between the two
3 elements we're going to talk about both elements here
4 on Page 26 and 27. Page 26 discussing, or Slide 26
5 discussing the Element 1.

6 We're proposing an increase with the
7 control design criteria by a factor of two from 5 rem
8 to 10 rem up to 25 rem with a consideration of plant-
9 specific profiles. These numerical values are risk-
10 informed based on Commission policy and regulation for
11 infrequent and emergency exposures as I have discussed
12 before.

13 These recommendations from national and
14 international organizations responsible for radiation
15 protection standards and guidance. And then as well
16 as a modern understanding of radiation protection,
17 foundational health physics principles and radiation
18 epidemiology.

19 We are retaining the performance-based
20 aspect of this rule, which has always been maintained
21 in guidance which requires the traditional design
22 basis accident, radiological consequence analyses to
23 be performed thereby retaining significant and
24 licensee experience in performing these analyses, at
25 least has to go back 70 years now at this point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But we're introducing the ability to have
2 some flexibility with the rule and scalability with
3 the rule. Incentivizing safety improvements, which
4 where additional margin may be needed above 10 rem, by
5 taking into consideration the way the facility has
6 been designed and operating. That could allow for a
7 higher, but still safe, performance criteria.

8 Let's go on to Slide 27, please. This is
9 Element 2 of our approach to proposing the submitted
10 rule.

11 So we're establishing in guidance a
12 framework for a graded risk-informed and performance-
13 based control room design criteria in part based off
14 of comments received from regulatory bases document.

15 The intent of this framework is to enable
16 a performance-based evaluation using traditional
17 deterministic radiological consequence analysis
18 methods within defined risk-informed boundaries.

19 These boundaries are defined by acceptable
20 radiation exposure guidelines of radiation workers
21 during accident and emergency conditions and
22 acceptable nuclear risk profiles using modern PRA
23 methods.

24 The intent of this framework is to provide
25 some flexibility when determining how to meet the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 established acceptance criteria in a way that
2 encourages and rewards the facility's safe profile.

3 In practice, the framework will leverage
4 its safe design and operation to justify a higher
5 numerical value for a lower plant-specific risk
6 metric.

7 Considerations in developing this
8 framework is that it follows condition policy. It's
9 simple to understand and use, it's leveraging already
10 well-understood nuclear safety analysis methods, such
11 as DBA consequence analyses and PRA methods.

12 The approach is similar to other graded
13 regulatory methods such as seen in Reg Guide 1.174.
14 The Standard Review plan also has a graded dose-based
15 acceptance of criteria approach for the exclusionary
16 boundary and low population zone that range from 2.5
17 rem up to 25 rem as well as some of the more modern
18 uses of frequency consequence curves that we're
19 starting to see now with the advanced LWRs and I
20 believe a couple of non-LWRs as well.

21 We did develop a White Paper trying to get
22 this thought out into, you know, the ether so people
23 can take a look at it, digest this method, understand
24 its bases, its rationale. You can find that White
25 Paper at the bottom of the slide here, the ML number

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 at the very bottom.

2 Okay, so we'll go on to Slide 28. On
3 Slide 28 we're just going to briefly discuss here how
4 we're implementing this framework into DG-1425. The
5 proposed rule, Rev 2 of Reg Guide 1.183.

6 We ultimately settle on, of course, this
7 graded approach. We base this off of the state of
8 PRA, a review of the state of PRA, the various risk
9 metrics, and a suitability assessment. All of this is
10 described in that White Paper.

11 We settled on the use of the CDF, or core
12 damage frequency, risk metric to be applied to this
13 framework. A risk metric range is based off of those
14 presented in 1.174 as they are well established and
15 understood with the fleet.

16 The range of acceptance values goes from
17 10 rem up to 25 rem. What we are looking at here on
18 the bottom left-hand side of this slide is a
19 screenshot of DG-1425, Table 8, that has this range of
20 acceptance criteria that correlate to a range of CDF
21 bins.

22 So the intent is that a licensee could
23 take their site-specific -- If they want to go above
24 10 rem take their site-specific CDF value based off of
25 the acceptable PRA, typically we would, we'll talk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 more about this tomorrow, accept a PRA value, CDF
2 values for licensing actions that have already been
3 approved.

4 So if you had done a TSTF-515 type
5 licensing action you could say, hey, look, you know,
6 we've done this PRA work, it's already been approved
7 for this TSTF-505 program, here's our CDF value, if
8 you want to get more information in regards to its
9 technical adequacy and other items, whether or not
10 they close out all the facts and observations from
11 peer review, utilize Regulatory Guide 1.200 for
12 technical adequacy, you can find that there in that
13 licensing action.

14 So we are trying to leverage that work to
15 inform going up to a higher control design criteria
16 here in this Regulatory Guide.

17 For those that appreciate, you know,
18 visual figures, you can see here on the right-hand
19 side of this slide where we just simply plopped Table
20 8 into a nice X/Y chart, or X/Y graph, where if you
21 had a CDF for instance that was higher than $1E$ to the
22 negative 4 it would be retained in the 10 rem bin, but
23 if you fell into any of those other bins then you
24 could have a higher control design criteria value.

25 The only way we are utilizing the CDF

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 value is really only as a sliding scale to identify a
2 higher control design criteria. We're not asking
3 licensees to update their PRAs or to even develop PRAs
4 to implement this.

5 MEMBER PALMTAG: This is Scott Palmtag.

6 MR. DICKSON: Yes.

7 MEMBER PALMTAG: Can you tell me how you
8 came up with these bins on that, was there some --

9 MR. DICKSON: Regulatory judgement.

10 MEMBER PALMTAG: It just seems like, and
11 this is my judgement --

12 MR. DICKSON: Yeah.

13 MEMBER PALMTAG: -- 1E to the minus 4
14 seems pretty low so it seems pretty easy to get higher
15 than ten.

16 MR. DICKSON: Yeah. That range is based
17 off of the criteria that is in Regulatory Guide 1.174.
18 So that guide has a range to make licensing-based
19 changes from 1E to the negative 4 to 1E to the
20 negative 5, other way around, 1E to the negative 5 to
21 1E to the negative 4, and you utilize that Reg Guide
22 for that framework when you are making or looking at
23 proposed changes at the facility. We just used that
24 same range in this.

25 MEMBER PALMTAG: Is that the same, all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 four ranges are in the Reg Guide?

2 MR. DICKSON: The max, the min and the
3 max, and then we divvied it up just a little bit
4 further to get a little more detail between 10 rem and
5 25 rem, and it made for nice bins, bins of 5 rem from
6 10 to 25 rem.

7 MEMBER PALMTAG: It doesn't seem that
8 difficult to get up to 25.

9 MR. DICKSON: So tomorrow we'll talk about
10 that.

11 MEMBER PALMTAG: Okay.

12 MR. DICKSON: We have some -- We've done
13 some analyses in regards to where we think the fleet
14 will fall out in this framework and what we did was is
15 we looked at all the different types, I wouldn't say
16 all of them, but quite a few different types of risk
17 metrics, CDF, LERF, full body that used to be used for
18 these dose calculations, even some risk metrics such
19 as population dose risks that are used in like the
20 environmental reports for license renewals, we looked
21 at all these different risk metrics.

22 We gathered from approved licensing
23 actions the numerical values from those approved
24 licensing actions.

25 So, for instance, in a TSTF-505

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 application they will have in their CDF value, they'll
2 have their LERF value, and we created datasets for
3 each of these risk metrics.

4 We then performed an analysis where we
5 filtered each of the licensees into these bins,
6 developed a histogram to see where they fall out, so
7 we were able to assess based on the quality of the PRA
8 or the intent of the PRA for whatever, you know,
9 regulatory action they were looking at, where they
10 would shake out in applying this.

11 I'll cut to the punchline, but --

12 MEMBER PALMTAG: Yeah.

13 MR. DICKSON: Okay. And we'll talk about
14 this tomorrow, what we ultimately settled on is that
15 we would like them to have PRAs that meet the
16 technical adequacy expectations of a TSTF-505.

17 That's a high level, that's a high bar in
18 regards to the development of that PRA and it goes
19 through peer review and we have good confidence in
20 that value and allow them to use a TSTF-505 program
21 for risk-informed completion times for their limiting
22 conditions of operations and tech specs.

23 If you use those PRA values none of them
24 received can be in the 25 rem bin.

25 MEMBER PALMTAG: You'd get -- What's the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 average?

2 MR. DICKSON: I have a histogram. Well --

3 (Simultaneous speaking.)

4 MEMBER PALMTAG: Well --

5 MR. DICKSON: -- I'm just wondering --

6 MEMBER PALMTAG: -- you'll have more
7 details tomorrow --

8 (Simultaneous speaking.)

9 MR. DICKSON: I will have more details
10 tomorrow.

11 MEMBER PALMTAG: Okay.

12 MR. DICKSON: The average for the most
13 part -- We can go -- We can add it to tomorrow's
14 presentation.

15 MEMBER PALMTAG: Yeah.

16 MR. DICKSON: Most of them stayed within
17 10 and 15 rem, probably a few of them would get 20
18 rem, but none of them would benefit from 25 rem within
19 this framework.

20 I don't quite have an average. I am
21 looking at the --

22 MEMBER PALMTAG: That's good enough.

23 MR. DICKSON: Yeah.

24 MEMBER PETTI: Elijah, even AP1000?

25 MR. DICKSON: Well, you popped my bubble.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 (Laughter.)

2 MR. DICKSON: So I didn't -- Member Petti,
3 thank you.

4 MEMBER PETTI: Sorry.

5 MR. DICKSON: I suspect that the AP1000
6 would probably fall into that 25 rem category.

7 MEMBER PETTI: Yeah.

8 MR. DICKSON: When we did this work they
9 weren't up and running yet and I didn't go and pull
10 that information. I was really focused on the
11 operating fleet that adopted 50.67. That's was the
12 focus at that time.

13 MEMBER ROBERTS: Elijah, I was wondering
14 why you didn't use LERF as another criterion. The
15 reason I ask is that it's theoretically possible that
16 the degradation control room happened, then it would
17 show up in LERF --

18 MR. DICKSON: Yeah.

19 MEMBER ROBERTS: -- if it impeded the
20 ability of the operators to take certain actions that
21 are credited, which is I'd say ideally because we
22 heard last year that Level 2 HRA is kind of in its
23 infancy and there's not a lot of fidelity and
24 actually, you know, modeling the likelihood of
25 operator take this kind of an action --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. DICKSON: Yeah.

2 MEMBER ROBERTS: -- is this all goes to
3 qualitative aspects of a LERF calculation and you're
4 going to see if there is a, you know, significant
5 credit given for operators in a control room who may
6 or may not be challenged to be there --

7 MR. DICKSON: Right.

8 MEMBER ROBERTS: -- at the time of this
9 change. So, anyway, I just wondered if you could
10 answer why you didn't LERF and then maybe the second
11 question is if you were to see something like, you
12 know, a qualitative credit for a control room
13 operator, you know, action in preventing a release?

14 MR. DICKSON: Yes. Thank you for that
15 comment. I thought and prepared for that comment. So
16 we did look at all these different risk metrics in
17 that White Paper.

18 We didn't go into like extensive analysis
19 as to why we proposed one over another other than CDF.
20 It was several lines of reasoning why we chose CDF,
21 ultimately in the Regulatory Guide.

22 One, primarily it is the main risk metric
23 that's used for the fleet right now. Then going back
24 to how we derived the in-containment source term,
25 those are based off of CDF analyses in deriving the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in-containment source term, so what they do is they
2 run the PRAs, they bin the accident sequences, and
3 develop the Level 2 and MELCOR models that are
4 representative of those accident sequences that make
5 the majority of the CDF calculation.

6 Some of those discussions are like in
7 NUREG-1465, so we felt that there were some like
8 commonality behind the degradation of that CDF source
9 term, or, sorry, the use of CDF with the in-
10 containment source term and then using it in this
11 area, and then also we went and we took a look at some
12 of our SPAR models, internal SPAR models that we have
13 for PRA, and you can see for some of the BWRs, for
14 instance, that they do need to take some actions in
15 regards to protecting against LERF and we did provide
16 some language in the guide that can qualitatively
17 leverage that type of information to just make sure
18 that people are thinking about fast accidents that
19 happen that can not only melt the fuel but could then
20 challenge containment integrity and see if they are
21 thinking about those things as well.

22 That language is in the guide. I can't
23 remember it off the top of my head though.

24 MEMBER ROBERTS: Yeah, thanks. We had a
25 discussion of the Subcommittee last year about the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Level 2 HRA and the ability potentially at some point
2 in the future to be able to model things like
3 operability influence on that preventing some of these
4 scenarios.

5 MR. DICKSON: Yeah, mm-hmm.

6 MEMBER ROBERTS: So I'm glad you've got
7 something in the Reg Guide that has at least that
8 thought process.

9 MR. DICKSON: That's right. Thank you.
10 Okay, so I think we're on Slide 29 now. So just to
11 recap our approach for this rulemaking presenting an
12 amended control room design criteria higher than five
13 is that we focused on three areas.

14 First we discussed the foundational
15 aspects of the conditions policy and regulation of the
16 radiation protection framework established in Part 20.
17 With an understanding of this framework we were able
18 to assess how a proposal to the control room design
19 criteria could be possible.

20 Second, after understanding if the
21 proposal fits within the Commission's framework we
22 reviewed evidence-based justifications by these
23 various national and international organizations
24 responsible for radiation protection recommendations
25 that have strong scientific and technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 underpinnings.

2 Third, lastly, we discussed about
3 providing some reasonable regulatory relief by
4 proposing an increase by a factor of two from 5 rem to
5 10 rem and provide some flexibility up to 25 rem based
6 off of policies provided by the Commission to the
7 Staff to implement those regulations in a performance-
8 based risk-informed manner.

9 In closing, on Slide 30, the NRC
10 recognizes the challenges licensees face in retaining
11 margin within their licensing basis for operational
12 flexibility purposes and the small amount of margin
13 that we have in the control room design criteria
14 itself.

15 Now with currently enriched and burned
16 fuels and then going into looking at higher
17 enrichments, ATF designs with higher enrichments,
18 higher burnups to achieve the LOCA cycle times and
19 even eventually some of these power references as
20 well.

21 One of the key drivers behind this
22 proposal to the amended control room design criteria
23 is to facilitate increased regulatory efficiency and
24 consistency while still continuing to provide adequate
25 protection of public health and safety.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 As I mentioned before, as we were starting
2 to look at this as NEIMA had come out back in 19--,
3 what was it 2019, we were starting to hear from
4 vendors and from some other licensees that they were
5 looking to deviate from regulatory guidance based off
6 and due in part from the conservatisms baked into that
7 guidance, but then as well as to the control room, the
8 margins for the control room design criteria itself.

9 This proposed rule and supporting guidance
10 does execute SRM-SECY-98-144 which defines the terms
11 and expectations the Commission have for developing
12 risk-informed and performance-based rules.

13 We do believe that this rulemaking effort
14 will also support increased consistency with the
15 Commission's comprehensive radiation protection and
16 emergency response frameworks by realigning the
17 numerical value of the control room design criteria to
18 a potential reactor accident with exceedingly low
19 probability, which is effectively what the in-
20 containment source term represents.

21 With that, I'll take questions.

22 CHAIR BALLINGER: Questions from Members?

23 (No audible response.)

24 CHAIR BALLINGER: I can tell you my
25 personal opinion is that you guys buried this. Very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 good.

2 MR. DICKSON: Thank you.

3 (Pause.)

4 CHAIR BALLINGER: Which is why there are
5 no questions, I guess.

6 MR. DICKSON: We looked at in as many ways
7 as we possibly could. We appreciate that.

8 CHAIR BALLINGER: Well if there aren't any
9 questions that concludes the presentations for the
10 day. We should probably thank you again because you
11 got us about two hours ahead of time.

12 Now we have a period of overall, I guess
13 overall discussion. You folks don't have to sit up
14 there and monitor us.

15 MR. DICKSON: Okay.

16 CHAIR BALLINGER: We have a kind of an
17 unusual situation with respect to the letters that we
18 would write in that the letter is due in February and
19 we have Subcommittee meetings now and we have a
20 Subcommittee meeting in January where we'll complete
21 the presentations related to the rule and it's not
22 until, in theory, after that that we would write a
23 letter.

24 That's a fairly long period of time, so I
25 am hopeful that reasonably quickly, we've had a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discussion, detailed and back and forth, that Members
2 would consider providing me with some thoughts of key
3 pieces that we should include in the letter.

4 There is a lot of -- We've had to have to
5 review an awful lot of material, not all of which is
6 in any controversial, and so we should probably try to
7 stick with stuff in any letter that we would write
8 that would be related to safety or policy, I guess.

9 We had a lot of discussion this morning
10 related to the FFRD issue, so I'm suspicious, I'm
11 suspecting that we'll get a lot of comments there, but
12 that's kind of the -- We'll have the transcript within
13 three days.

14 Weidong is all over this, and so
15 everybody, including the people that are virtual, will
16 be able to read the transcript. So hopefully we can
17 enshrine some of this a little bit earlier so we don't
18 forget. I don't forget, for sure. So what do folks
19 think?

20 MEMBER PETTI: So just in general,
21 Members, we have two days in January.

22 CHAIR BALLINGER: Yeah.

23 MEMBER PETTI: We only have one Reg Guide,
24 okay, but the reason we're retaining it is because it
25 seems like we need to spend some time deliberating as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a committee on this.

2 The graph and depth of this is difficult.
3 It's probably one of the most significant rulemakings
4 in terms of impact on the industry, and so I feel like
5 we need to show we've done our due diligence with it
6 in terms about the letter sense.

7 It would be nice if we could get sort of
8 a consensus before the January meeting and then just
9 hash out any small details, but I just don't know how
10 we'd do that.

11 CHAIR BALLINGER: I'm kind of hoping that
12 the input that I would get I would, without violating
13 our rules with respect to deliberation and FACA and
14 all that stuff, that something like an interim
15 something.

16 MEMBER PETTI: Interim points, yeah.

17 CHAIR BALLINGER: Interim points that
18 would be produced. So that's a starting point.

19 MEMBER PETTI: But we could look at that
20 in January and --

21 CHAIR BALLINGER: Yeah. Yeah. If we wait
22 too long we'll lose track.

23 MEMBER PETTI: Yeah, because then we only
24 have one week --

25 CHAIR BALLINGER: Yeah.

1 MEMBER PETTI: -- for Ron to finalize the
2 letter in front of Full Committee.

3 CHAIR BALLINGER: Yeah.

4 MEMBER HALNON: Hey, Ron?

5 CHAIR BALLINGER: Yes, sir?

6 MEMBER HALNON: This is Greg. Just two
7 quick comments.

8 CHAIR BALLINGER: Oh, wait a minute,
9 should we let the court reporter go --

10 MEMBER PETTI: Yes. Do the public
11 comments first.

12 MALE PARTICIPANT: Public first.

13 MEMBER HALNON: Okay, I'll hold off.

14 CHAIR BALLINGER: Oh, that's true, yes.
15 Before we continue let me get the public comments.

16 MEMBER HALNON: Okay.

17 CHAIR BALLINGER: If there are members of
18 the public that would like to make a statement could
19 you please state your name and organization, I
20 suppose, and then make your comment.

21 (Pause.)

22 CHAIR BALLINGER: Oh, I'll get to you.

23 MR. CSONTOS: Okay.

24 CHAIR BALLINGER: I'm waiting for the
25 radio to, for the radio to come back in here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BURKHART: Yeah, this is Larry
2 Burkhart from the ACRS Staff. If anybody online would
3 like to make a comment please raise your hand and
4 we'll take your comments sequentially and then we'll
5 take comments from the --

6 (Simultaneous speaking.)

7 CHAIR BALLINGER: That's what I was going
8 to do next.

9 MR. BURKHART: So if anybody online
10 interested in making a comment please raise your hand.

11 CHAIR BALLINGER: Well something happened.

12 MR. BURKHART: Paul Clifford.

13 CHAIR BALLINGER: Ah.

14 MR. BURKHART: Paul Clifford, give us your
15 comment, please.

16 MR. CLIFFORD: Yes. Hello. I appreciate
17 the opportunity to make a comment. This is Paul
18 Clifford, a consultant with Framatome.

19 I would like to make a comment on backfit
20 and how it fits into the draft rule package. So the
21 draft 50.46(a) rule is defined as a voluntary
22 alternative to the existing 50.46 ECCS performance
23 requirements and is being pursued to support future
24 licensing actions involving high enrichment and
25 burnup.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Section VIII(f) of the Statement of
2 Considerations provides a backfit assessment for the
3 draft 50.46(a) rule and in that backfit assessment the
4 Staff concludes that holders of existing operating or
5 combined licenses would not be required to comply with
6 the proposed amendment and would have the option to
7 continue their current treatment of LOCAs.

8 Therefore, the proposed revisions would
9 not meet the definition of backfitting in 10 CFR
10 51.09(a)(1) and would not constitute backfitting for
11 an operating license or affect the issue of finality
12 of a combined license.

13 For a majority of the currently operating
14 fleet their "current" treatment of LOCAs does not
15 consider fuel fragmentation and fuel dispersion, the
16 hydrogen-enhanced beta-layer embrittlement, breakaway
17 observation or clad ID oxygen diffusion.

18 Furthermore, their definition of LOCA is
19 limited to breaks in piping. The Staff's -- It's
20 important to note that the Staff's designation of this
21 rule as a voluntary alternative is a departure from
22 its classification of the 2016 50.45(c) draft rule
23 which was defined as adequate protection and as an
24 adequate protection rule that earlier draft included
25 a mandatory implementation of the research findings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Given the low safety significance
2 associated with large piping breaks that we've heard
3 over the last two days, the industry supports the
4 voluntary alternative designation of this rule and the
5 backfit assessment.

6 In accordance with the backfit assessment
7 though the industry expects that these new or modified
8 Staff positions will not be fully fit on licensing
9 actions not involving high burnup or high enrichment,
10 such as a potential wave of future power uprate LARs.
11 That's it. Thank you for the opportunity.

12 CHAIR BALLINGER: Thank you. Now comments
13 -- Well I haven't seen anybody else online. Members
14 of the public in the room?

15 MR. CSONTOS: Thanks, Ron. Thank you very
16 much. We do have, the industry has a few comments
17 that we would like to make, just some high-level
18 discussion points.

19 First of all, we want to thank the Staff
20 for all of the hard work. In fact, this Friday marks
21 three years when the SECY went up to the Commission
22 for the increase in reg rulemaking and then followed
23 by April of that year, of the next, the following
24 year, being the one where the SRM comes down, you
25 know, to move forward with the enrichment rulemaking.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Then this past April the other SRM that
2 came in to incorporate, which was this (a) and (c),
3 into the rulemaking. So there has been a lot of
4 activities and a lot of effort and we thank the Staff
5 for all of the things that they've done.

6 One thing that we would like to, just for
7 me to highlight is that one of the things that we have
8 been seeing as an overarching kind of a general
9 comment is we see individual groups, technical groups,
10 having different and varying levels of risk-informing
11 or various levels of prescriptive and deterministic
12 and sometimes risk-informed approaches to various
13 activities.

14 We're looking to see if there is an
15 overarching group that might, and maybe it's ACRS, but
16 there is an overarching group that looks at this
17 holistically and looks at how you implement which are
18 being put out there in the rule, because part of this
19 is that we in the industry really want this rulemaking
20 to be completed because we have strategic aspirations
21 for high burnup, high enrichment, high performance
22 cycles for PWRs as well as power uprates.

23 Applications are coming in as early as
24 this coming, early first quarter of next year, okay,
25 on some of this, and so having regulatory stability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and predictability is really important going forward.

2 On this case we see differences in
3 different technical disciplines where there are
4 different approaches being taken, and so maybe there
5 is a way to ameliorate some of those inconsistencies
6 maybe or an approach to looking at it in a more risk-
7 informed overarching manner that can help us with
8 moving forward more quickly.

9 I know it's a challenge. I know it's
10 hard. I know we don't have a lot of time between now
11 and March, so maybe that's something that we take on,
12 you know, further as we go with this process, but it's
13 just something that we just wanted to bring up, that's
14 all. I'll turn it over to Jim.

15 MR. STAVELY: Jim Stavely, PSEG Nuclear.
16 First of all, thank you. The comments and the
17 presentations over the last two days has been really
18 informative and I do appreciate a lot of the
19 insightful comments and questions asked by the ACRS
20 Subcommittee, so thank you.

21 I would like to reinforce the comment on
22 enabling the implementation of this planned guidance,
23 but we've heard some things over the last couple days
24 that may present perhaps a few challenges on how we
25 could implement this in the timeframe we are hoping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for for the strategic changes of whether it's SBU or
2 whether it's 24 month fuel cycles.

3 As Al explained, some of it appears to be
4 a little bit of coordination or integration and we can
5 do better perhaps and look forward to a containment
6 conversations and a few other things to make sure we
7 have a smooth implementation of this rule and without
8 minimizing any unexpected impacts that we didn't
9 foresee on implementation, so appreciate that and make
10 that comment.

11 Also in terms of 50.46(c), just a little
12 bit of a concern. Again, this is a first look and I
13 understand fully why the Staff and management took the
14 position of moving the proposed 50.46(c) from a few
15 years ago with minor changes into this new rulemaking
16 and new guidance documents.

17 But I think with that approach we perhaps
18 made a little bit of a differential between some of
19 where the current risk-informed performance-based
20 manner was not perhaps as prevalent when we saw
21 50.46(c) before.

22 So I would just recommend or consider if
23 there is things in there we need to take a little more
24 of a look at of how we move into to 50.46(c).

25 Last, ALS. We didn't hear that much about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ALS, the Alternate Licensing Strategy. The industry
2 and Salem puts a lot of emphasis behind the risk-
3 informed nature of that.

4 That really penalizes some of taking that
5 type of manner and applying it to our current
6 knowledge base and our current expertise and
7 leveraging that for strategically moving the industry
8 forward in a safe manner.

9 I would just appreciate the continued
10 emphasis on ALS. Thank you.

11 CHAIR BALLINGER: Other comments?

12 MS. GERKEN: I'll go real fast. I just
13 want to add on to what he's saying. So I just want to
14 -- Lisa Gerken, Framatome.

15 So just adding on to what Jim was talking
16 about about 50.46(c) and even the dispersal stuff as
17 well, I think when you are looking at it, you know,
18 straight and flat it can -- You know, we talked about
19 a little bit earlier about the picture, it makes it
20 seem really significant when operationally it's not
21 that significant.

22 So we have been operating with the 17
23 percent limit, for instance, with the 50.46 and then
24 you look at the hydrogen-based curve and the limit
25 comes down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 That can present a picture of, wow,
2 there's a big concern, but it's not that we're not
3 accounting for degradation in these phenomena, we're
4 just accounting for it in a different way.

5 So the risk may be perceived as higher
6 because of, you know, how it appears on a picture or
7 in discussions, but maybe it's less significant than
8 it actually is.

9 The same thing with dispersal, we do
10 operate today in ranges where dispersal could happen
11 and terminology like "no dispersal" is a little bit
12 misleading as well as in terms of the scariness of the
13 consequences, I think, that means, oh my God, it
14 explodes and stuff is going to go everywhere, you
15 know, coming back to where LOCAs, how they look,
16 actually happen and the physics of them.

17 The physics of fragmentation and dispersal
18 are important considerations when promulgating new
19 regulation, especially stuff that can be enclosed in
20 rather conservative ways.

21 We don't want to make it more difficult to
22 do stuff that we're already doing today, both with
23 respect to 50.46(c) and dispersal. Thank you.

24 MR. SMITH: Thank you. Fred Smith from
25 EPRI. The discussion and the large amount of angst

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 about dealing with dispersal consequences is very
2 reminiscent of discussions that EPRI had when we
3 sought to develop and ALS strategy.

4 We elected to not take a strategy that
5 would require evaluation of dispersal. What I didn't
6 hear in your discussion was I think a very important
7 element, that any realistic accident sequence for a
8 large break LOCA has to include leak rate protection.

9 Leak break detection at current expects
10 would require a plant to shut down. Some of you were
11 here in June when I presented the ALS framework and we
12 said and still say that our probabilistic fracture
13 mechanics analysis and large break piping demonstrate
14 that the time between the detectable leak and LOCA was
15 only, was 19 months on the 95/95 vessels.

16 And so the detectability has a large
17 margin in it and, of course, if you shut down you lose
18 stored energy, decay heat, and you lose the motive
19 force for a LOCA and if a LOCA were to occur it would
20 have no consequences on the cladding rupture or
21 dispersal. Thank you very much.

22 MR. KINDRED: Good afternoon. Tom
23 Kindred, Southern Nuclear. Can everyone hear me?

24 (No audible response.)

25 MR. KINDRED: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BURKHART: Can you just spell your
2 name so we get a true record?

3 MR. KINDRED: Yeah. Kindred, K-I-N-D-R-E-
4 D. My comments are in regard to NUREG-1829. The
5 industry, we agree, that NUREG-1829 seems to be
6 applicable.

7 But what we're seeing, at least from the
8 presentations yesterday, is that as our understanding
9 of, quite frankly, the mechanics pictures and
10 comparisons, you know, up to 2024 with xLPR, we're
11 seeing decreasing trends of high rupture frequencies.

12 So we are a little concerned within the
13 industry and we don't understand how with an increase
14 in trend of frequencies we're going to mandate more
15 frequent plant inspections and that's going to provide
16 real dose to our nuclear workers, like those
17 inspections will require nuclear workers to get real
18 dose, right, for a hypothetical event.

19 So that's one thing we don't understand
20 how a decrease in risk we're going to get a risk-
21 informed recommendation to increase the frequencies
22 for risk, yeah.

23 MR. BROADBENT: I think I'm the last. I
24 am Greg Broadbent, a consultant to NEI. I just wanted
25 to address something that was just mentioned about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 leakier control rooms.

2 If you look at the release fractions from
3 Rev 0, which most of the plants are on right now, to
4 Rev 2, a lot of them have doubled. Some of them have
5 gone up even more than that.

6 So, you know, by going to this higher
7 enrichment we would expect our doses to approximately
8 double and that's why, you know, we would need an
9 increase in the acceptance criteria.

10 It's not to make our control rooms
11 leakier, it's to be able to not make, have to make
12 wholesale changes to other things to the plant.

13 MR. BARBER: Kevin Barber, Westinghouse.
14 I want to talk about the true best estimate
15 definition, or maybe the lack thereof.

16 I mean the Member made a comment yesterday
17 about how you can get a very different result, whether
18 it's the 50th quantile of the LOCA population or
19 whether you apply a LOCA methodology using nominal
20 models as is.

21 You know, the Staff had talked about it
22 and certainly the Westinghouse letter in response to
23 the reg basis being noted that we think that there is
24 a good probability that we can demonstrate, you know,
25 rupture with the true best estimate methodology.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 That is with a caveat though. There are
2 a number of aspects or a number of models that we need
3 to ensure are being treated realistically, for example
4 like the break size.

5 That is something that is very important.
6 If we are looking at the break size and we decide that
7 even though it's a beyond design basis accident we're
8 going to just look at the double-ended guillotine
9 breaks instead of a realistic distribution of the
10 probability of breaks, that's a significant bound.

11 That is the type of requirement that, you
12 know, whether it gets codified or whether it gets in
13 the Reg Guide that we need to make sure as an industry
14 that we have clarity and efficiency in that to ensure
15 that we can deliver on what we're saying about a true
16 best estimate really not having, leading to feel this
17 way.

18 MR. PORTER: One comment. Ian Porter,
19 GNF. So just a quick comment on the 50.46(c) aside
20 the new Reg Guide. So when that was first created,
21 you know, ten years ago there were a number of
22 cladding alloys that were actually approved and in use
23 at the time.

24 Since that was written there have been
25 three new alloys that have been approved and they are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 actually in use or in the state of deployment and they
2 are not included in the Reg Guide updates as approved
3 alloys that can actually use the Reg Guide.

4 So it's not clear if those approvals are
5 going to actually require the vendors go do the
6 testing for the new alloys that have been approved the
7 last ten years or if there is applicability.

8 So just a comment that there is not
9 clarity with what's actually happened with new alloys
10 that are currently licensed after actually use of the
11 Reg Guide would have to go be tested.

12 CHAIR BALLINGER: There are probably 50
13 people in the room and we've already had 30.

14 (Laughter.)

15 CHAIR BALLINGER: Okay. If there aren't
16 any other public comments now I think we can release
17 the court reporter. Thank you. Thank you.

18 (Whereupon, the above-entitled matter went
19 off the record at 2:35 p.m.)

20

21

22

23

24

25

Proposed Rule: Increased Enrichment of Conventional and Accident Tolerant Fuel Designs for Light-Water Reactors

December 17-18, 2024

Opening Remarks

Theresa Clark
Director
Division of Safety Systems

Overview of Increased Enrichment Rulemaking

Philip Benavides
Project Manager

Reactor Rulemaking & Project Management Branch

Issue Identification

- **Regulatory Issue:**

- Current licensing framework allows for the use of ≤ 5 weight percent uranium-235; however, technology developments may require numerous exemptions to utilize fuel enriched above 5 weight percent.

- **Proposed Solution:**

- Rulemaking would provide for a generically applicable standard informed by public input, providing consistent and transparent communication, rather than individual licensing requests as discussed in SECY-21-0109, “Rulemaking Plan on Use of Increased Enrichment of Conventional and Accident Tolerant Fuel Designs for Light-Water Reactors.”

- **Commission Rulemaking Plan Approval:**

- Staff request to pursue rulemaking and develop a regulatory basis was approved by the Commission via SRM-SECY-21-0109.


SRM-SECY-21-0109 Overview

- SRM-SECY-21-0109 was issued on 3/16/22, in response to SECY-21-0109.
 - The Commission approved the staff's proposal to initiate a rulemaking to amend requirements for the use of light water reactor fuel containing uranium enriched to greater than 5.0 weight percent uranium-235.
 - Provisions to the rule should only apply to High-Assay Low Enriched Uranium (HALEU).
 - Fuel Fragmentation, Relocation, and Dispersal (FFRD) should be appropriately addressed.
 - Staff directed by the Commission to take a risk-informed approach.

Status of Rulemaking Activity

- **The NRC staff issued a regulatory basis on September 8, 2023 (ADAMS Accession No. ML23032A504)**
- **Stakeholder Involvement:**
 - Before Regulatory Basis Issued:
 - Public Meeting on June 22, 2022 (ML22208A001)
 - Post Regulatory Basis Issued:
 - Public Meeting on October 25, 2023 (ML23319A259)
 - Comment Period closed on January 22, 2024
 - Publicly shared Fuel Dispersal insights at the NRC's Annual Higher Burnup Workshop on September 3, 2024 (ML24277A161)
- **The Increased Enrichment proposed rule package is in concurrence.**
 - Proposed rule due to the Commission: March 2025

Status of Rulemaking Activity



Note: Dates listed are estimates only, and thus are subject to change.

Rulemaking Topics

- **The IE rulemaking addresses the following topics:**
 - **Criticality Accident Requirements (10 CFR 50.68)***
 - Uranium Fuel Cycle Environmental Data - Table S-3 (10 CFR 51.51)
 - Environmental Effects of Transportation of Fuel and Waste - Table S-4 (10 CFR 51.52)
 - **Packaging Requirements for Fissile Material Transportation (10 CFR 71.55)***
 - **Control Room Design Requirements (10 CFR 50.67 and GDC-19)***
 - **Fuel Fragmentation, Relocation, and Dispersal***

*ACRS Subcommittee Meeting Topics

Associated Guidance

- **Control Room Design Requirements (10 CFR 50.67 and GDC-19)**
 - DG-1425, “Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors”
- **Fuel Fragmentation, Relocation, and Dispersal**
 - DG-1261, Revision 1, “Measuring Breakaway Oxidation Behavior”
 - DG-1262, Revision 1, “Determining Post-Quench Ductility”
 - DG-1263, Revision 1, “Establishing Analytical Limits for Zirconium-Based Alloy Cladding”
 - DG-1426, “An Approach for Risk-Informed Evaluation Process Supporting Alternative Acceptance Criteria for Emergency Core Cooling Systems for Light-Water Reactors”
 - *DG-1428, “Plant-Specific Applicability of Transition Break Size”*
 - DG-1434, “Addressing the Consequences of Fuel Dispersal in Light-Water Reactor Loss-of-Coolant Accidents”

Note: DG-1428 to be presented in January 2025

Agenda (December 17)

Topic	Presenter	Organization
NRR Staff Leadership	Theresa Clark, Director	NRR/DSS
IE Overview, Status of Rulemaking	Philip Benavides, Rulemaking PM	NMSS/REFS/RRPB
Criticality Accident Requirements (10 CFR 50.68)	Charley Peabody	NRR/DSS/SNSB
Fissile Packaging Requirements (10 CFR 71.55)	Jason Piotter	NMSS/DFM/NF
Fuel Fragmentation, Relocation, and Dispersal	Joseph Messina Robert Tregoning David Rudland Kristy Bucholtz	NRR/DSS/SFNB RES/DE NRR/DNRL NRR/DRA/APOB

Agenda (December 18)

Topic	Presenter	Organization
NRR Staff Leadership	Theresa Clark, Director	NRR/DSS
Fuel Fragmentation, Relocation, and Dispersal (Continued)	James Corson	RES/DSA/FSCB
Control Room Design (10 CFR 50.67 and General Design Criteria 19)	Elijah Dickson	NRR/DRA/ARCB

Questions

Criticality Accident Requirements (10 CFR 50.68)

Charley Peabody
Nuclear Engineer
Nuclear Systems Performance Branch

10 CFR 50.68(b) Historical Overview

- Final Rule issued in 1998
- Provides alternative to 10 CFR 70.24
- Implements k-effective safety limits
- Limits enrichments of $\leq 5\%$ by weight U-235
- Industry desires to increase enrichment beyond 5% at operating LWRs

10 CFR 50.68(b) Recent Developments

- Single License Amendment for Lead Test Assemblies (LTA) utilizing enrichments beyond 5% has been approved to date
- NRC Contracted Research Study
 - ORNL/TM-2024/3350 “Scoping Studies on the Impacts of Increased Enrichment on Nuclear Criticality Safety,” May 2024 (ADAMS Accession Number ML24163A016)
- Reconfirmed Regulatory Basis Decision not to Update Regulatory Guide 1.240 “Fresh and Spent Fuel Pool Criticality Analysis” March 2021

10 CFR 50.68(b) Proposed Rule Unofficial Redline

- §50.68(b)(7) would be changed to state “The maximum nominal U-235 enrichment of the fresh fuel assemblies is limited to five (5.0) percent by weight **or to the value specified in the operating license.**”
- No changes to any other paragraphs.

10 CFR 50.68(b) Proposed Rule Benefits

- The k-effective safety limits specified in 10 CFR 50.68(b)(2), (3), and (4) are maintained
- Increased enrichment criticality safety impacts will be evaluated as part of the fuel transition LAR review process
- Allows for the entire range of high-assay low-enriched uranium (HALEU) to be utilized
- This alternative preserves 10 CFR 50.68(b) compliance for all LWRs currently operating in the United States

10 CFR 50.68(b) Proposed Rule

Member questions or comments for the staff?

Packaging Requirements for Fissile Material Transportation 10 CFR 71.55

Jason Piotter
Team Leader - New Fuels Team
Division of Fuel Management - NMSS

Packaging Requirements of 10 CFR 71.55: Summary of Regulatory Issue

Current Regulations

- § 71.55(b) applicants evaluate a single package, optimally moderated and reflected
- § 71.55(g) Provides an exception to § 71.55(b) for packages containing UF₆
- § 71.55(g)(4) Specifies that enrichment of UF₆ cannot exceed 5 weight percent U-235

Regulatory History

Proposed rule (§ 71.55(g)) issued 67 FR 21390, April 30, 2002, Final Rule issued 69 FR 3698, January 26, 2004

Codified NRC longstanding practice to provide an exception to § 71.55(b)

10 CFR 71.55: Certificate of Compliance (CoC) Options for Enrichments Greater than 5 weight percent U-235

1

Evaluate UF₆ packages with optimum moderation per §71.55(b), or

2

Request an exemption to §71.55(b), or

3

Request approval under §71.55(c) for an exception to the optimum moderation requirement in §71.55(b).

Regulatory Basis - Rulemaking Alternatives

Original Recommendation



Option 1:
No Action **71.55(b), 71.55(c),
exemptions** (Also applies to Options 2
and 3)

Option 2:
Increase
Enrichment
Limit **20 weight percent U-235**

Option 3:

Remove Enrichment Limit

Proposed Rule - Rulemaking alternatives

Option 1:
No Action **71.55(b), 71.55(c),
exemptions** (Also applies to Options 2
and 3)

Option 2:
Increase
Enrichment
Limit **10 weight percent U-235,
*defense in depth requirements***

Option 3:
Increase
Enrichment
Limit **20 weight percent U-235,
*defense in depth requirements***



Current Recommendation

10 CFR 71.55(g)(4): Updated Recommended Alternative

Alternative 2

Increase enrichment limit to 10.0% wt U-235, with prescriptive defense in depth requirement for additional protection of fill valve or other device

10 CFR 71.55(g): Updated Rule Text

(4) The uranium is enriched to not more than 10 weight percent uranium-235; and

(5) A design feature is incorporated to protect the valve or other fill device from impact for contents with uranium-235 enriched above 5 weight percent and up to 10 weight percent.

Fissile Material Transportation Packages - Summary


- Transportation packages for UF_6 have a certification pathway with enrichments up to 20 weight percent U235. While our current regulations as written are sufficient to transport higher enriched UF_6 , we are providing a non mandatory modification of the current enrichment limit that allows for more regulatory certainty while maintaining safety

Fuel Dispersal and 10 CFR 50.46a Overview




Joseph Messina
Reactor Systems Engineer
Nuclear Methods and Fuel Analysis

Fuel Fragmentation, Relocation, and Dispersal (FFRD)

- At HBU experiments have shown that the fuel can fragment during a LOCA
- Differences in pressure across the cladding can lead to cladding ballooning and burst
- The fragmented fuel can relocate axially into the balloon region of the fuel rod and if burst occurs, disperse into the RCS



Segment from NRC's ANL LOCA program at 55 GWd/MTU before and after testing



Burst openings from Studsvik LOCA tests (NUREG-2121)

Fuel Dispersal: Background and Regulatory Issue

- The 50.46 acceptance criteria date to 1974 when FFRD were not known phenomena
- Acceptable approaches to demonstrate compliance with the regulations have ensured that catastrophic failure of the fuel rod structure and loss of fuel bundle configuration are precluded
 - Fuel dispersal would be a departure of precedent
- Fuel dispersal is not explicitly addressed within the current regulations
 - Draft proposed rule language allows for some flexibility regarding fuel dispersal
 - DG-1434 provides guidance for addressing fuel dispersal within the proposed rule

IE Rulemaking Regulatory Basis FFRD Alternatives

The IE Rulemaking Regulatory Basis ([ML23032A504](#)) considered 5 licensing pathways for addressing fuel dispersal:

- **Alternative 1**: No action.
- **Alternative 2**: 50.46a-style modification of ECCS requirements.
- **Alternative 3**: Perform a safety demonstration for post-FFRD consequences.
- **Alternative 4**: Provide a generic bounding assessment of dose and use risk insights for post-FFRD consequences.
- **Alternative 5**: Use probabilistic fracture mechanics to show that leaks in large pipes will be identified before failure, precluding the need to analyze LBLOCAs.

Public Comments Overview, Part 1 of 4

- No unanimous alternative recommended by industry
- Industry recommendations were strongly based on the qualitative schedule impacts published in the Regulatory Basis.
 - These were quick and crude estimates.
 - Staff has learned more, and accuracy of these estimates has improved.
- UCS and two members of public:
 - Do not support any alternative that allows for fuel dispersal
- One member of public:
 - Recommends waiting until more research and analysis is performed for fuel dispersal

Public Comments Overview, Part 2 of 4

Alternatives 1 and 3:

- No support

Alternative 4:

- NEI and BWROG supported Alternative 4
- BWROG does not see Alternative 5 as a solution

Alternative 5:

- NEI and Westinghouse supported a modified Alternative 5 (ALS)

Alternate Approaches:


- Framatome and PWROG suggest using integrated decision making as done to disposition in-vessel downstream effects (IVDEs) associated with GSI-191

Public Comments Overview, Part 3 of 4

Alternative 2:

- NEI, BWROG, and Westinghouse support Alternative 2 combined with an updated 50.46c as a separate rulemaking due to perceived schedule or as a backup
- Aspects of Framatome's response and their 2023 white paper align with Alternative 2
- NEI, Westinghouse, and Framatome stated that even with a no-dispersal criterion, Alternative 2 would be reasonable with true best-estimate calculations

Public Comments Overview, Part 4 of 4



Previous 50.46a History

- **Commission SRMs on rule development:**
 - SRM-SECY-02-0057 (ML030910476)
 - SRM-SECY-04-0037 (ML041830412)
 - SRM-SECY-05-0052 (ML052100416)
 - SRM-SECY-07-0082 (ML072220595)
- **ACRS letters:**
 - ACRS letter on initial draft final rule (ML063190465): 11/16/2006
 - ACRS letter on NUREG-1829 and draft NUREG-1903 (ML073440143): 12/20/2007
 - ACRS letter on draft final rule (ML102850279): 10/20/2010
 - Sept. 2010 ACRS Subcommittee meeting transcript: ML102910759
 - Oct. 2010 ACRS Full Committee meeting transcript: ML102860120
- **SECY-10-0161 (ML102300252):** Draft final rule was submitted to the Commission – 12/10/2010
- **Email from Greg Bowman to SECY** requesting to withdraw 10 CFR 50.46a rulemaking (ML121500380; submitted in response to verbal direction by Chairman Jaczko) – 4/20/2012
- **SRM-SECY-10-0161:** Commission approved staff's request to withdraw SECY-10-0161 and re-evaluate it to ensure compatibility with future Commission direction related to recommendations following Fukushima – 4/26/2012
- **SECY-16-0009 (ML16028A189):** staff recommended stopping 10 CFR 50.46a rulemaking as a part of prioritization and re-baselining of agency activities – 1/31/2016
- **SRM-SECY-16-0009 (ML16104A158):** Commission approved staff recommendation to stop 50.46a rulemaking – 4/13/2016

Fuel Dispersal Path Forward


- The NRC staff plans to risk-inform LOCAs by modernizing 50.46a (based on Alternative 2) in the IE draft proposed rule to facilitate addressing fuel dispersal
 - Support for Alternative 2 expressed in many public comments
 - Smallest impact on the IE Rulemaking schedule of the alternatives that received support
 - Leveraged the technical basis and work performed in the original 50.46a
 - High level of technical maturity
- 10 CFR 50.46a was a draft final rule in 2010 that proposed to establish a transition break size (TBS), above which LOCAs would be recategorized as beyond-design-basis
 - Voluntary alternative to 50.46
 - Original philosophy being maintained with some changes
 - LOCAs below the TBS will not be affected by this rule
- The updated 50.46a is planned to include high-level, fuel technology neutral, performance-based Emergency Core Cooling System (ECCS) acceptance criteria

Addressing Fuel Dispersal

- The 50.46a approach is expected to facilitate safety demonstrations of fuel dispersal because true best-estimate modeling and realistic assumptions are expected to significantly reduce or eliminate the potential for fuel dispersal
- While this approach does not explicitly address non-mechanistic approaches to evaluating FFRD, as described in other alternatives in the IE Regulatory Basis, other licensing pathways exist
 - E.g., the topical report review process
 - The performance-based criteria are expected to provide relief to the prescriptive philosophy of the existing regulatory framework (including a less prescriptive definition of core coolability)

50.46c Background

- 50.46c was a draft final rule that revised the ECCS acceptance criteria to be performance-based and reflect research findings on embrittlement of zirconium alloy cladding under LOCA conditions
 - Submitted to the Commission via SECY-16-0033 in March 2016
 - 1997-2016 NRC LOCA research program is documented in NUREG/CR-7219
- Substantial ACRS interactions on 50.46c:
 - ACRS letter on draft final rule issued February 2016: ML16048A522
- The SECY-16-0033 research findings show that under the current regulations (17% MLO and 2200°F PCT), post-quench ductility is not assured following a postulated LOCA
- New embrittlement mechanisms discussed in SECY-16-0033:
 - Hydrogen-enhanced beta layer embrittlement
 - Cladding ID oxidation
 - Breakaway oxidation



SRM-SECY-16-0033 (50.46c)

The Commission returned the 50.46c draft final rule package (SECY-16-0033) to the staff in April 2024 without Commission action and directed the staff to do the following:

1. The staff should apply an appropriate risk-informed regulatory approach to address the research findings on cladding embrittlement effects under LOCA conditions described in SECY-16-0033.
2. The staff should evaluate Item 1 with other associated technical issues being addressed, such as fuel fragmentation relocation and dispersal, and risk-informed treatment of LOCAs, including the draft final 50.46a that had been provided in SECY-10-0161.
3. The staff should evaluate whether specific emergency core cooling system criteria such as cladding temperature should be codified or instead addressed in regulatory guidance.
4. Within six months of the date of this SRM, the staff should provide, through a Commissioner Assistant's Note, an action plan for the above items.

(SRM-SECY-16-0033, [ML24102A281](#), April 11, 2024)

50.46c Path Forward

The staff plans to include aspects of 50.46c in voluntary provisions of the Increased Enrichment (IE) proposed rule and assess the need for further action on the 50.46c rulemaking after the Commission votes on the IE final rule package.

- The staff is planning to risk inform LOCAs, as suggested in SRM-SECY-16-0033, with 50.46a in order to facilitate safety demonstrations of fuel dispersal in the IE proposed rule.
- The staff would use the public comments received on the 50.46c aspects of the IE rulemaking to inform any potential future action on the 50.46c rulemaking.
- Entities that elect to adopt 50.46a would be expected to address the embrittlement research findings
- The staff will continue to perform the annual ECCS Safety Assessments and evaluate the impacts of the cladding embrittlement research findings within the framework of existing regulatory requirements when reviewing industry submittals that could result in cladding embrittlement impacts (e.g., power uprates or burnup increases).

Scope of Work Associated with updated 50.46a Proposed Rule

- Confirmation of the transition break size (TBS)
 - NRC internal and external expert elicitation
 - xLPR runs of the NUREG-1829 bases cases
 - Evaluation of operating experience
 - Confirmation of NUREG-1903 technical basis
- Update of the following draft regulatory guides (previously part of the 50.46c rulemaking):
 - DG-1261, “Measuring Breakaway Oxidation”
 - DG-1262, “Determining Post Quench Ductility”
 - DG-1263, “Establishing Analytical Limits for Zirconium-Alloy Cladding Material”
- Development of the following draft regulatory guides:
 - DG-1426, “An Approach for a Risk-Informed Evaluation Process for Supporting Alternative Acceptance Criteria for Emergency Core Cooling Systems for Light-Water Reactors”
 - DG-1428, “Plant-Specific Applicability of the Transition Break Size”
 - DG-1434, “Addressing the Consequences of Fuel Dispersal in Light-Water Reactor Loss-of-Coolant Accidents”

Adequate Protection

While this rule relaxes the regulatory treatment of LOCAs above the TBS, the NRC staff believe that it maintains the adequate protection of public health and safety because:

- The initiating event frequency for such events are very low and the NRC will ensure that it is low and remains low on a plant-specific basis
- The NRC will ensure that risk increases from changes due to this rule are minimal and that there are not large increases in the overall plant risk
- The NRC will maintain regulatory control over such LOCAs, continuing to review ECCS evaluation models and plant-specific LOCA analyses, as done to date

50.46a and Fuel Dispersal Team

NRR/DSS:

- Joseph Messina
- Ashley Smith
- John Lehning
- Scott Krepel

NRR/DNRL:

- David Rudland
- David Dijamco
- Seung Min
- Eric Palmer

NRR/DRA:

- Kristy Bucholtz
- Michelle Kichline

NRR/DEX:

- Se-Kwon Jung

RES/DE:

- Robert Tregoning
- Matthew Homiack
- Christopher Nellis

RES/DSA:

- James Corson
- Andrew Bielen

Technical Basis of Original 10 CFR 50.46a Transition Break Size

Rob Tregoning
Senior Advisor for Materials
Office of Nuclear Regulatory Research, Division of
Engineering

Presentation Objective and Outline

- **Objective:** Summarize the historical (i.e., pre-2024) technical basis use to develop the transition break size (TBS)
- **Outline:** TBS development
 - LOCA frequency assessment (NUREG-1829)
 - TBS selection
 - Confirmation of seismic integrity (NUREG-1903)

NUREG-1829: Scope and Objectives

- Develop piping and non-piping passive system LOCA frequencies as a function of leak rate and operating time up to the end of the license extension period (i.e., 60 years) using expert elicitation
 - LOCAs which initiate in unisolable portion of reactor coolant system
 - LOCAs related to passive component aging, tempered by mitigation measures
- Determine LOCA frequency distributions for typical plant operational cycle and history
- Assume that no significant changes will occur in future plant operating profiles

NUREG-1829: Historical LOCA Frequency Evaluation

- LOCA frequencies previously developed from operating history
- Notable Previous Evaluations:
 - WASH-1400 (1975): Estimates largely based on experience in other industries
 - NUREG-1150 (1987): Updated the WASH-1400 distributions to account for the additional service since WASH-1400
 - NUREG/CR-5750, Appendix J (1998): Updated original WASH-1400 study for SB LOCAs while MB and LB LOCA frequencies were calculated from precursor leaks in class 1 systems
- Operating history, by itself, may not accurately reflect future performance and requires significant extrapolation for MB and LB LOCA frequencies

NUREG-1829: Expert Elicitation Process

- Classical approaches
 - Operating experience: LOCA events are rare
 - Plant modeling: Number and diversity of possible failure modes is too complex to accurately model
- Expert elicitation is a formal process for providing quantitative estimates for the frequency of physical phenomena when the required data is sparse and when the subject is too complex to accurately model
- Elicitation has been used often at NRC
 - Development of seismic hazard curves
 - Performance assessments for high-level radioactive waste repository
 - Determination of reactor pressure vessel flaw distributions

NUREG-1829: Elicitation Approach

- Conduct pilot elicitation
- Select panel and facilitation team
- Develop technical issues
- Quantify base case estimates
 - Develop quantitative estimates for well-defined piping conditions
 - Quantify non-piping precursors and targeted failure scenarios
- Formulate elicitation questions
- Conduct individual elicitations
- Analyze quantitative results and qualitative rationale
- Summarize and document results
- Conduct internal and external review of process and results

NUREG-1829: Pilot and Elicitation Team

- **Pilot Elicitation**

- Conducted using 11 internal (NRC) experts with broad knowledge-base
- Provided interim results for rulemaking development
- Developed possible framework for subsequent elicitation and its strengths and weaknesses
- Identified technical issues for subsequent consideration

- **Panel and Facilitation Team**


- Individual elicitations conducted for each expert, led and monitored by a facilitation team
- Twelve external experts assembled from nuclear industry, DOE laboratories, consultants, and international regulatory agencies with broad knowledge-base
- Facilitation team comprised largely of NRC subject matter experts

NUREG-1829: LOCA Size Classification

- LOCA sizes based on flow rate to group plant system response characteristics
 - First three categories similar to NUREG-1150 and NUREG/CR-5750
 - Three additional LBLOCA categories used to determine larger break frequencies
- Correlations developed to relate flow rate to effective break area
- Three time periods evaluated
 - Current day ~ 2004 (average 25 years of operation)
 - End of design life (average 40 years of operation)
 - End of first life extension (average 60 years of operation)

Category	Flow Rate Threshold (gpm)	LOCA Size
1	> 100	SB
2	> 1500	MB
3	> 5000	LB
4	> 25,000	LB a
5	> 100,000	LB b
6	> 500,000	LB c

NUREG-1829: General Issue Classification





- Elicitation focuses on passive system LOCAs
- Important piping and non-piping attributes identified
- Elicitation structure supported top-down and bottom-up analysis

NUREG-1829: Piping Base Cases

- The base cases were available for anchoring the elicitation responses.
- Base case conditions specify the piping system, piping size, material, loading, degradation mechanism(s), and mitigation procedures
- Five base cases defined
 - BWR
 - Recirculation System (BWR-1)
 - Feedwater System (BWR-2)
 - PWR
 - Hot Leg (PWR-1)
 - Surge Line (PWR-2)
 - High Pressure Injection makeup (PWR-3)
- The LOCA frequency for each base case condition is calculated as a function of flow rate and operating time
- Four panel members individually estimated frequencies: two using operating experience and two using probabilistic fracture mechanics

NUREG-1829: Piping Base Cases Summary Results



- Large variability due to inconsistencies in both the conditions evaluated and differences in approaches
- Each base case participant presented their approach and results to entire panel
- Each panel member was asked to critique approaches & results during their elicitation session



NUREG-1829: Non-Piping Base Cases

- The variety and complexity of the non-piping failure mechanisms makes the piping base case approach intractable
- Approach
 - Develop general non-piping precursor database
 - Use PFM modeling to develop LOCA frequencies for targeted degradation mechanisms
 - CRDM ejection
 - BWR vessel rupture: normal operating and LTOP
 - PWR vessel rupture: PTS
- Analysis method
 - Choose appropriate base case: non-piping precursor, piping precursor, piping base case, or non-piping base case
 - Determine relative likelihood of each non-piping failure scenario compared to chosen base case

NUREG-1829: Analysis of Elicitation Responses

- Calculate individual estimates for each panelist
 - Total BWR and PWR LOCA estimates
 - Approach is self-consistent and ensures that qualitative rationale and quantitative estimates match
- Aggregate individual estimates: Philosophy
 - Group results more accurate than any single estimate
 - Outliers should not dominate quantitative estimates
- Aggregate individual estimates: Approach
 - Combine parameters (i.e., mean, median, 5th & 95th percentiles) of individual distributions
 - Calculate confidence bounds associated with each parameter estimate
- Perform sensitivity analyses to evaluate calculation approach
- Final LOCA distributions reflect uncertainty and variability
 - Uncertainty: Individual panel member responses
 - Variability: Range of individual responses

NUREG-1829: Total LOCA Frequencies




- 95% confidence bounds (i.e., error bars) account for diversity among panelists
- Differences between median and 95th percentiles reflect individual panelist uncertainty

NUREG-1829: Summary

- Formal elicitation process used to estimate generic BWR and PWR passive-system LOCA frequencies associated with material degradation during normal operations
- Piping and non-piping base cases were developed and evaluated for anchoring elicitation responses
- Panelists provided quantitative estimates supported by qualitative rationale in individual elicitations for underlying technical issues
 - Generally good agreement on qualitative LOCA contributing factors
 - Large individual uncertainty and panel variability in quantitative estimates
 - Results are generally comparable to NUREG/CR-5750 estimates
- Group results determined by aggregating individual panelists' estimates
 - Geometric mean aggregated results are consistent with elicitation objectives and results are generally comparable with NUREG/CR-5750 estimates
 - Alternative aggregation schemes can result in higher LOCA frequencies

Selection of Transition Break Size (TBS)

- NUREG-1829 results used as starting point
- Range of pipe sizes correlate to break frequency $< 10^{-5}/\text{yr}$ (95th percentile)
 - BWRs: 13 to 20 inches
 - PWRs: 6 to 10 inches
- Selection should accommodate uncertainties
- Other types of LOCAs considered in determining TBS
 - Active LOCAs
 - Load-generated LOCAs (i.e., dropped heavy loads, water hammer)
 - Seismically induced LOCAs
- Actual plant piping design and operating experience considered in final selection



TBS Selection

- TBS is defined as a pipe break that is the size of the cross-sectional flow area of largest pipe attached to the main coolant loop
 - For PWRs, the size of the largest pipe attached to the cold or hot leg main loop piping (≈ 12 inches)
 - For BWRs, the size of the largest pipe in either of the RHR or Feedwater systems inside primary containment (≈ 20 inches)
- Supporting rationale
 - Next larger pipes are significantly less likely to break
 - Piping sizes $<$ TBS have experienced most significant degradation
 - Accommodates uncertainties and provides regulatory stability as variation in future LOCA frequencies estimates not likely to require new TBS definition to maintain acceptable risk

NUREG-1903: Objective and Approach

- **Objective**

- Determine if seismic risk is acceptable for breaks greater than TBS


- **Scope and Approach**

- Six supporting activities
 - Unflawed piping failure
 - **Flawed piping failure**
 - **Indirect piping failure**
 - Review of past earthquake experience
 - Review of past seismic PRAs
 - Review a mid-80s LLNL study of direct and indirect seismic piping rupture used to support GDC 4 revision
- Use mix of deterministic and probabilistic approaches

NUREG-1903: Approach, cont.

- Analyzed direct piping failure under rare seismic events
 - Evaluated unflawed and flawed piping systems with diameters $>$ TBS (e.g., hot leg, cold leg, and cross-over leg) using available design information
 - Used most-recent seismic-hazard curves for plants east of the Rocky Mountains
 - Determined stresses for 10^{-5} and 10^{-6} yr $^{-1}$ seismic event by scaling plant specific SSE stresses
 - Apply scale factors to address conservatisms in the design process, material behavior, and extrapolation to rare seismic loading
- Analyzed indirect piping failure under rare seismic events
 - Analyzed large component support failures that may lead to piping failure
 - Assumed that support failure leads directly to piping failure
 - Updated results from prior LLNL study to reflect new hazard and ground motion information
 - Determined mean failure probability of component supports

Direct Piping Failure: Surface Flaw Results



- 26 PWRs analyzed
- Critical flaw depth (a/t) for long flaw ($\theta/\pi \approx 0.8$) under 10^{-6} /yr seismic event

Indirect Piping Failure: Case Studies

NUREG/CR-3663 Sample Results

Group A Plants (Combustion Engineering)	Confidence Limit ⁽¹⁾		
	10%	50%	90%
Calvert Cliffs	2.3×10^{-8}	6.1×10^{-7}	6.1×10^{-6}
Millstone 2	9.0×10^{-10}	6.6×10^{-8}	1.2×10^{-6}
Palisades	5.0×10^{-7}	6.4×10^{-6}	5.2×10^{-5}
St. Lucie 1	1.2×10^{-8}	3.8×10^{-7}	4.1×10^{-6}
St. Lucie 2	6.6×10^{-8}	1.4×10^{-6}	1.1×10^{-5}
Westinghouse Lowest Capacity Plant	2.3×10^{-7}	3.3×10^{-6}	2.3×10^{-5}

(1) Confidence limit of 90% implies a 90% confidence that annual probability is less than value indicated

- Generic seismic hazard curves used in evaluation
- Group A had highest failure probabilities for CE plants

NUREG-1903

- Only 2 plants evaluated
- Mean result for Calvert Cliffs: $1.7E-6/\text{yr}$

NUREG-1903: Summary

- Unflawed piping: Failure frequency is much lower than $10^{-5}/\text{yr}$
- Flawed piping
 - Critical flaws for long, circumferential flaws ($\theta/\pi = 0.8$) are generally large
 - 40% of wall thickness for $10^{-5}/\text{yr}$ seismic event
 - 30% of wall thickness for $10^{-6}/\text{yr}$ seismic event
 - Conditional probability of breaks larger than the TBS should be less than $10^{-5}/\text{yr}$
- Indirect failures
 - Only two cases analyzed (one W and one CE plant)
 - Piping failure induced by major component support failure has a mean probability of approximately $10^{-6}/\text{yr}$

Historic TBS Technical Basis Development: Summary

- Passive System LOCA frequencies developed for generic BWR and PWR plants through an expert elicitation process (NUREG-1829)
 - Accounted for panelist uncertainty and variability among responses
 - Used results as the starting point for selecting the transition break size
- Increased TBS to address additional factors and to promote regulatory stability
 - Considered other types of LOCAs
 - Accounted for plant piping design and operating experience
- Performed confirmatory study to determine if risk of LOCAs > TBS due to rare seismic was acceptable (NUREG-1903)
 - Risk due to unflawed and flawed direct piping failures expected to be acceptable for most, if not all, plants
 - Risk due to indirect piping failures acceptable for two cases evaluated
 - Seismic risks, however, are plant-specific, making it difficult to completely generalize results

Recent Confirmation of the Transition Break Size Technical Basis

David Rudland

Senior Technical Advisor for Materials
Division of New and Renewed Licenses
Office of Nuclear Reactor Regulations

Confirmation Study

- Confirmation of the NUREG-1829 LOCA Frequencies
- Confirmation of the NUREG-1903 Results
- Determination of TBS impact

NUREG-1829 Confirmation

- Internal and External Elicitation
- Impact of Recent Operational Experience
- Probabilistic Fracture Mechanics Study
- International Operational Database Study

Qualitative

Quantitative

Details in “White Paper on Continued Applicability of NUREG-1829”
ML24205A015

Internal and External Elicitation

- **Motivation**

- NUREG-1829 based on formal expert elicitation
 - Pilot elicitation performed initially
 - External elicitation formulated based on lessons-learned from internal pilot
- Mimic process to evaluate the completeness and continuing viability of the NUREG-1829 and NUREG-1903 results

- **Objectives**

- Identify possible scenarios either not considered or under-estimated in NUREGs-1829 and 1903
- Assess likelihood and/or technical or rulemaking gaps associated with each scenario

Approach

- **Select appropriate internal and external panelists**
 - **Internal:** 13 senior staff with collective expertise in all relevant technical areas
 - **External:** Two NUREG-1829 panelists with complementary expertise pertaining to passive system reliability
- **Formulate initial set of questions and topics**
 - Focus on knowledge gained and operating experience since the mid-2000s
 - Consider direct, indirect, and potential common-cause failure scenarios
 - Identify important causal factors
- **Hold a kick-off meeting**
 - Present objectives, background and motivation of the effort
 - Discuss and clarify the elicitation topics and questions
 - Identify initial considerations
- **Develop initial independent responses**
- **Conduct follow-on meetings**
 - Collectively discuss the individual responses
 - Determine the path forward for dispositioning any open issues

Summary of Internal Elicitation Responses

- **Scenarios – 21 identified**

- **Addressed in applicability studies:** RPV embrittlement, SCC in main loop piping, increased seismic risk since NUREG-1903, evolution of ISI and relief requests
- **Addressed within 10 CFR 50.46a rulemaking:** Rulemaking motivation, effects of future plant changes, PRA representativeness, indirect failures from small pipe rupture, TBS margin, treatment of LBB piping, degraded supports and snubbers, NUREG-1829 uncertainties, BWR applicability, maintaining mitigative capabilities, definition of a pipe
- **Addressed within current regulations:** pilot-operated relief valve failure, common-cause maintenance errors, RPV through-wall cracking, water chemistry excursions, impact on plant security, degraded grid stability

Addressed later

Sample of Internal Elicitation Topics

- **Treatment of LBB piping**
 - **Issue:** Consideration of special treatment for plants with LBB approval
 - **Disposition:**
 - No explicit special treatment in rule although NUREG-1829 results reflect LBB margins
 - May be able to leverage approved LBB analysis as part of plant-specific applicability demonstration
- **Potential for degraded grid stability**
 - **Issue:** Higher risk could result if LOOP is not evaluated within LOCA analysis
 - **Disposition:**
 - LOOP event frequencies, while relatively sparse, don't indicate an increasing trend
 - PRA still needs to consider risk associated with such events and continually update data
 - Many plants currently employ load monitoring software to predict offsite power unavailability

Summary of External Elicitation Responses


- **Continuing Applicability of NUREG-1829 LOCA frequencies**
 - Frequencies for breaks < TBS are representative (one panelist) or conservative (one panelist)
 - Frequencies for breaks > TBS are conservative
 - Opinions are based on successful mitigation practices and increased knowledge pertaining to the structural integrity of large piping systems
- **Historical TBS remains viable**
- **Possible scenarios leading to breaks > TBS**
 - One panelist: no such credible scenarios envisioned
 - One panelist
 - Should continue to explore thermal aging, cold work, and residual stress effects
 - SCC leading to long, shallow surface flaws especially in either CASS or adjoining weld or cold-worked component are most credible
 - Likelihood of such scenarios is strongly plant-specific

Disposition of External Elicitation Responses

- **Continued research and monitoring**
 - Harvest representatively aged austenitic weld and CASS materials to validate current models, which are based largely on accelerated aging laboratory testing
 - Extend aging studies to represent properties at the end of subsequent license renewal period and beyond
 - Continue to monitor both U.S. and international operating experience relevant to potential for SCC cracking, especially in large diameter piping systems
- **Demonstrate plant-specific applicability of the TBS**
 - Proposed 10 CFR 50.46a rule requires that an entity demonstrate that plant-specific effects do not invalidate the applicability of the TBS for their plant before implementing the rule
 - Additional guidance proposed in DG-1428 providing several methods for demonstrating plant-specific applicability

Impact of Recent Operational Experience (OE)

- Thermal Embrittlement of Piping
- Stress Corrosion Cracking (SCC) of Stainless Steel in PWRs
- Carbon Macrosegregation
- Quasi-laminar Indications
- Small Surface Break Flaws
- Reactor Pressure Vessel Embrittlement
- Inspection Frequency changes
- Secondary-Side Piping Failure



Impact of Recent OE - Piping

Thermal Embrittlement of Piping

- Issue
 - Decrease in fracture toughness of cast austenitic stainless steel and austenitic stainless welds
 - Can this decrease impact failure frequencies
- Staff Action
 - Considered experimental testing, development of aging management, lack of active degradation, ongoing inspections
 - No safety concern

SCC of Stainless Steel in PWRs

- Issue
 - Many cracks identified in Safety injection and residual heat removal system in stainless welds in French Fleet – unexpected SCC
 - Could this occur in US and may it impact the failure frequencies
- Staff Action
 - Conducted Risk-informed analysis (LIC-504)
 - Reviewed industry actions
 - Determined reasonable assurance of integrity

Impact of Recent OE - Piping

Inspection Frequency Changes

- Issue
 - Ongoing efforts at ASME to optimize inspection frequencies resulting in less inspections for piping and components
 - Risk-informed ISI is in place, but some categories may change inspection frequency
- Staff Action
 - Continuing inspection of these welds is essential to the basis supporting the transition break size.

Impact on TBS

- Conclusion
 - Some issues were analyzed through our LIC-504 risk-informed process
 - Some issues were analyzed through research or licensing actions
 - No impact on the TBS
- Staff Action
 - However, the staff recommends that for those reactor coolant pressure boundary piping whose diameter is greater than the TBS, a 10 percent sample of the welds > TBS is needed each interval – Can leverage existing ISI programs

Minority View on Inspection Requirements

- Piping failure resulting in LOCA > TBS is highly unlikely, but possible
 - Most prominent concern is an SCC-like mechanism that causes a long-surface flaw with slow through-wall growth coupled with toughness decrease due to thermal aging
 - Increases likelihood of break before leak
 - Issue identified in internal and external elicitation
 - Characteristic of flaws leading to ruptures in PFM analyses
 - Flaws which such characteristics have been occasionally discovered (e.g., Duane Arnold and Penly 1)
 - Such a scenario is plant-specific, not generic
- Performance monitoring, through inspection, of piping with inner diameter greater than TBS provides assurance that failure likelihood remains extremely low
 - Rulemaking utilizes classical approach of defining a risk-informed inspection sample and then performing repeat inspections each ISI interval
 - Minority view recommends choosing a new risk-informed inspection sample every ISI interval to ensure that a greater population of such welds is inspected at least one time during operation

Impact of Recent OE - Vessels

Carbon Macrosegregation (CMAC)

- Issue
 - In early 2015 regions of (CMAC) were discovered in European Pressurized Reactor pressure vessel heads manufactured for a plant in Flamanville, Manche, France
 - Higher strength, lower toughness, may be more susceptible to embrittlement
- Staff Action
 - Conducted risk-informed analysis, considered EPRI and ASN analyses
 - Concluded that the safety significance of CMAC to the U.S. fleet is negligible

Quasi-laminar Indications (QLI)

- Issue
 - In July of 2012, ultrasonic inspections of RPV ring forgings at two nuclear power plants in Belgium revealed thousands of sub-surface, nearly-axial indications
 - Do the many flaws impact RPV integrity?
- Staff Action
 - Reviewed Electrabel PFM evaluation
 - Conducted independent risk-informed evaluation
 - Concluded the potential existence of QLI is not expected to affect structural integrity of U.S. RPVs.

Impact of Recent OE - Vessels

Small Surface Break Flaws (SSBF)

- Issue
 - 2016 ORNL analyses suggested that SSBF can produce a greater through-wall crack frequency than a 1/4T flaw
 - What are the impacts on P-T limits and PTS?
- Staff Action
 - PFM analyses conducted and determined that even though there is an increase in conditional probability of failure, the impact on through-wall crack frequency is minimal.
 - Realistic cooldown transient frequencies and their occurrence frequency was considered.

RPV Embrittlement

- Issue
 - The existing RG 1.99 (and 10 CFR 50.61) embrittlement trend curve (ETC) model may underpredict of RPV embrittlement under the high fluences
 - Licensees are allowed to defer surveillance capsule testing that is intended to confirm embrittlement predictions from the ETC model
- Staff Action
 - Staff developed a risk-informed analysis that suggested the staff's confidence in the integrity of the RPV for certain plants may be impacted
 - Staff proposed a change to the rule in SECY-22-0019
 - Staff waiting on Commission decision

Impact of Recent OE - Vessels

Inspection Frequency Changes

- Issue
 - Through 10 CFR 50.55a(z) many licensees have been granted approval to modify their inspection intervals for RPV, steam generator and pressurizer welds
 - Cumulative effect of these relaxation may impact the TBS
- Staff Action
 - Ensure reasonable assurance of safety
 - Verify appropriate performance monitor occurs within these components

Impact on TBS

- Conclusion
 - Some issues were analyzed through our LIC-504 risk-informed process
 - Some issues were analyzed through research or licensing actions
 - Cumulative effects were considered
- Staff Action
 - Impact of the embrittlement concerns on the TBS be revisited following Commission action on the rulemaking plan.

Impact of Recent OE

Secondary-Side Piping Failure

- Issue
 - Secondary side failure (<TBS), impacts larger piping (>TBS) and increases LOCA frequencies

- Staff Conclusion
 - GDC-4 and SRP 3.6.2 provide reasonable assurance safety is maintained
 - Piping is very flaw tolerant – probability of enough damage to rupture large piping is small
 - Guidance is needed to cover any possible impacts of secondary side failure causing indirect failure of piping greater than the TBS

Probabilistic Fracture Mechanics Study

- Base Cases from NUREG-1829 (2004) re-examined using improved the state of knowledge and PFM modeling capabilities
- LOCA frequencies recalculated for 4 piping systems relevant to transition break size
- Calculations performed using NRC's extremely Low Probability of Rupture (xLPR) PFM code

Case #	Weld location	Pipe Size	Plant Type	Degradation mechanisms
PWR-1	Reactor Vessel Outlet Nozzle	30-inch	PWR	PWSCC
PWR-2	Surge Line	10-inch	PWR	PWSCC
BWR-1a	Recirculation	28-inch	BWR	IGSCC
BWR-1b	Recirculation	12-inch	BWR	IGSCC

xLPR Approach




- General settings
 - 80 year reactor operation time
 - Sufficient sample size to detect a 10^{-6} probability event
 - Leak rate detection enabled
- Quantities of interest
 - Probability of leakage
 - Probability of rupture
 - Leak rate
- Post-processing converts these quantities to annual component-level LOCA frequencies


PWR	BWR
PWSCC crack growth	IGSCC crack growth <ul style="list-style-type: none"> • Generic crack growth model parameters set to match IGSCC model in 2023 ASME Section XI Article Y2310
Weld residual stress <ul style="list-style-type: none"> • PWR-1: set WRS to mirror profile from VC Summer leak event for conservatism • PWR-2: Generic representative WRS profile 	Weld residual stress <ul style="list-style-type: none"> • Generated using finite element analysis from EPRI data

The PWR probabilistic fracture mechanics analyses were within the range of the NUREG-1829 base case results.

PWR-1: Vessel Outlet Nozzle




PWR-2: Pressurizer Surge Line




The BWR probabilistic fracture mechanics analyses were also within the range of the NUREG-1829 base case results.

BWR-1: Recirculation System (28-inch)



BWR-1: Recirculation System (12-inch)



International Operational Database Study

- **Motivation**

- Participants in NUREG-1829 elicitation based their estimates in part from knowledge from operating experience
- The basis has changed 20 years later
 - More OE knowledge in the later post 25-year lifetime of reactors
 - New mitigation technologies

- **Objectives**

- Re-evaluate NUREG-1829 LOCA Frequency estimates with knowledge from post-2004 operating experience

Scope of OpE Review	Plant Type	NUREG-1829		Expert Elicitation 2024		ΔEFPY (2024 vs 2004)
		2004		2024		
		ROY	EFPY	ROY	EFPY	
Domestic Plant	BWR	987.8	839.6	1345.9	1144.0	304.4
	PWR	1615.4	1373.1	2735.4	2325.1	952.0

Analysis Procedure

(1) Calculate piping failure precursor frequencies from OE¹

(1) Up to 2004 (l_1)

(2) Up to 2024 (l_2)

(2) Calculate conditional probability of failure distribution

(1) Extract CFP from NUREG-1829 LOCA frequency estimates using 2004 precursor failure frequency l_1

(3) Calculate updated LOCA frequencies

(1) Find new LOCA Frequency uncertainty distribution estimates using found CFP and 2024 precursor failure frequency l_2

$$\rho = l \times CFP$$

ρ = LOCA Frequency Distribution

l = Precursor Failure Frequency –
(# failures/(Component x Year))

CFP = Conditional Probability of Failure

1. OE database developed under the Nuclear Energy Agency's Component Operational Experience, Degradation and Ageing Programme (CODAP) provided the source for the OE data.

The operating experience analysis results indicate at least an order of magnitude less than the NUREG-1829 results.

LOCA Category	Effective Break Size (inch)	Plant-Level LOCA Frequency (1/Year) – Statistical Mean Values			
		BWR - Piping		PWR - Piping	
		NUREG-1829	2024 Update	NUREG-1829	2024 Update
4	≥ 7	5.9E-06	2.4E-08	7.6E-07	6.0E-08
5	≥ 18	1.0E-06	4.3E-09	1.3E-07	2.6E-08
6	≥ 41	--	--	1.2E-08	4.0E-10

Improved mitigation technologies such as weld overlays attributed with the reduction


NUREG-1903 Confirmation

- NUREG-1903(ML080880140) addressed potential seismic effects on TBS.
- Evaluated three cases: unflawed and flawed piping failure and indirect piping failure by other components and component supports.
- Used LLNL seismic hazard curves for the assessment.
- For direct unflawed piping, failure probabilities were significantly low compared to the 1E-05 per year frequency used as a basis to establish the TBS.


NUREG-1903 Confirmation

- For direct flawed piping, the critical flaws associated with the stresses induced by the $1E-05$ and $1E-06$ probability of exceedance events were generally large, and the probabilities of pipe breaks larger than the TBS were determined to be less than the TBS frequency criterion.
- For indirect piping failure, the mean probability of failure of the lowest capacity component support was less than $1E-5$ for the CE and Westinghouse plants.
- All central and eastern US NPPs recently re-evaluated their seismic hazards (NUREG KM-0017).
- The original assessment results have been updated by using the latest site hazard information for each site (ML24323A205).


Direct Unflawed Piping Failure



Direct Unflawed Piping Failure




Direct Unflawed Piping Failure Probability



Indirect Piping Failure Probability

- Indirect failures are pipe ruptures caused by failures of major components (e.g., reactor pressure vessel, steam generators, and reactor coolant pumps (RCPs)) or component supports as a result of an earthquake.
- NUREG-1903 indirect piping failure fragility curve
- The results show that mean probabilities of indirect piping failure are all below the TBS frequency criterion of $1E-05$.

Indirect Piping Failure Probability



Summary from TBS Confirmation

- LOCA frequencies and TBS are applicable if plant specific applicability is demonstrated.
 - NUREG-1829 and NUREG-1903
 - New designs can develop plant specific TBS
- Inspection of the piping welds with diameters greater than the TBS are needed to ensure LOCA frequencies remain applicable
 - Plants can leverage existing ISI program as needed

Draft Proposed Rule Language for 10 CFR 50.46a

Joseph Messina
Reactor Systems Engineer
Nuclear Methods and Fuel Analysis

Draft Proposed 50.46a Rule Structure

- a) Definitions
- b) Applicability and scope
- c) Application
- d) Programmatic requirements
- e) ECCS performance
- f) Fuel performance criteria
- g) Use of NRC-approved fuel in reactor
- h) Changes to facility, Technical Specifications, or procedures
- i) Authority to impose restrictions on operation
- j) Reporting
- k) Significant change or error in the ECCS evaluation model

50.46a(a): Definitions

Highlighted definitions:

- Changes enabled by this section: means changes to the facility, Technical Specifications, and procedures that satisfy the alternative ECCS analysis requirements under this section but do not satisfy the ECCS requirements under § 50.46.
- Entity: means an applicant for or a holder of a construction permit, operating license, combined license, standard design approval, or manufacturing license, or an applicant for a standard design certification rule (including such applicant after NRC issuance of a final standard design certification rule).
- Loss-of-coolant accident: means the hypothetical accidents that would result from the loss of reactor coolant, at a rate in excess of the capability of the reactor coolant makeup system, from **breaks in the reactor coolant pressure boundary** up to and including a break equivalent in size to the double-ended rupture of the largest pipe in the reactor coolant system. LOCAs involving breaks at or below the transition break size (TBS) are design basis accidents. **LOCAs involving breaks larger than the TBS are beyond design basis accidents.**
- Transition break size: for reactors licensed under this part before December 31, 2015, is a break area equal to the largest cross sectional flow area of the reactor coolant pressure boundary piping excluding the hot leg, cold leg, or crossover leg piping for a pressurized water reactor, or the largest cross sectional flow area of either the feedwater line or residual heat removal line inside containment for a boiling water reactor. For reactors that are or will be licensed under this part after December 31, 2015, and for light-water reactors (LWRs) that are or will be licensed under part 52 of this chapter, the TBS will be determined on a plant-specific basis.

50.46a(b) Applicability

- OLs issued prior to Dec. 31, 2015
 - Entities whose reactor design is demonstrated under 50.46a(c)(2) to be similar to designs of reactors licensed under part 50 before Dec. 31, 2015
-
- ❑ NUREG-1829 and the TBS based on plants licensed before Dec. 31, 2015. LWRs licensed after may have different piping materials, configurations, and operational and service conditions, among other factors, that may impact the piping break frequencies and thus the TBS
 - ❑ **Paragraph 50.46a(c)(2)** states that for plants licensed after Dec. 31, 2015, an analysis should be submitted that demonstrates why the proposed reactor design is similar to the designs of reactors licensed under part 50 before Dec. 31, 2015, such that the provisions of this 50.46a may properly apply
 - ❑ The analysis must include a recommendation for an appropriate TBS and a justification that the recommended TBS is consistent with the technical basis of this section

50.46(b): Applicability (cont'd): Inspections

Paragraph (b)(3): A licensee must inspect, under § 50.55a(g), for those reactor coolant pressure boundary piping whose inner diameter is greater than the TBS, a sampling of at least 10% of the similar metal piping circumferential welds in a PWR and the circumferential welds in a BWR that are classified as Category A welds before implementation of this section and in every subsequent in-service inspection interval (as defined in § 50.55a(y)). The sampling must include those circumferential welds with the highest failure potential. Credit may be taken for welds inspected as part of established inspection programs (e.g., risk-informed inservice inspection programs). The effect on the TBS of any degradation identified during these inspections must be evaluated.

- ❑ This requirement is new from the 2010 draft final rule, added in response to public comments, to reduce the burden of demonstrating plant-specific applicability of the TBS, while providing assurance of safety. Allows licensee to leverage ongoing inspection programs to reduce burden.
- ❑ Verifies that analyses that predict component failure remain accurate through the time the component is analyzed, and provides a method to identify novel degradation that may impact the analysis and the structural integrity of the component

50.46a(c): Application

Entities electing to adopt 50.46a will need to provide:

- Evaluation of the applicability of the TBS to the facility
- Weld inspection report
- Description of the risk informed evaluation process for changes made under this rule to meet the risk acceptance criteria in paragraph (h)
- Description of the approach, methods, and decision-making process to be used to evaluate the continued applicability of the TBS
- Description of the non-safety systems credited for LOCAs > TBS and they must be placed in Tech Specs
- Evaluation of leak detection program
- For reactors licensed after 12/31/15, an analysis demonstrating that the reactor design is similar to those licensed before 12/31/15 and the appropriate TBS

50.46a(d): Programmatic Requirements

- 1) ECCS models and analysis methods are maintained per requirements in (e)(1), (2), and (3)
- 2) Leak detection systems must be available and used to identify, monitor, and quantify leakage
- 3) Changes made must be evaluated in a risk-informed evaluation
- 4) ~~Risk assessments must be maintained and upgraded risk assessments at least once every 5 years~~ – Removed from draft proposed rule during concurrence
- 5) The effect of all planned facility changes must be evaluated and any changes that would invalidate the evaluation demonstrating the applicability of the TBS cannot be implemented
- 6) During operation, licensees must perform the (b)(3) weld inspections every subsequent inservice inspection interval (as defined in § 50.55a(y)) on the same samples inspected to satisfy paragraph (b)(3) of this section and evaluate any additional degradation

50.46a(e): ECCS Performance

50.46a(e)(1) establishes two principle ECCS acceptance criteria:

- The ECCS must provide sufficient coolant so that the fuel remains in a coolable geometry during and following the LOCA heatup and quench.
- The ECCS must provide sufficient coolant so that decay heat will be removed for the extended period of time required by the long-lived radioactivity remaining in the fuel.

Maintaining coolability and removing decay heat has been fundamental to LOCA analysis since the origin of 50.46

50.46a(e)(2): ECCS Performance at or below the TBS

- A number of LOCAs must be analyzed such that there is assurance that the most severe LOCAs at or below the TBS are analyzed
- Uncertainty must be accounted for such that there is a high probability that the ECCS and fuel system acceptance criteria are met
- Changes in fuel geometry must be addressed

□ Analysis requirements for LOCAs at or below the TBS are essentially unchanged and (still require high probability modeling)

50.46a(e)(3): ECCS Performance above the TBS

- A number of LOCAs must be analyzed such that there is assurance that the most severe LOCAs larger than the TBS up to the double-ended guillotine rupture of the largest pipe in the RCS are analyzed
- There must be assurance to at least a **best-estimate** that the ECCS and fuel system acceptance criteria are met
- Changes in fuel geometry must be addressed
- Calculations may take credit for availability of offsite power
- Do not require assumption of a single failure
- Non-safety-related equipment may be credited if supported by plant-specific data or analysis, and provided that onsite power can be readily provided through simple manual actions to equipment that is credited in the analysis.

LOCAs > TBS would be beyond-design-basis accidents and be analyzed with best-estimate (best-estimate would refer to nominal and unbiased analyses) modeling, as other beyond-design-basis accidents are (e.g., ATWS and SBO)

50.46a(f): Fuel Performance Criteria

Fuel system designs must have NRC-approved limits that:

- i. Address cladding degradation phenomena
 - ii. Maintain fuel coolability
 - iii. Avoid explosive concentration of combustible gas
 - iv. Demonstrate that, after any calculated successful initial operation of the ECCS, the ECCS must provide sufficient coolant to remove decay heat and prevent further cladding failure for the extended period of time required by the long-lived radioactivity remaining in the fuel.
- Thermal effects of crud and oxide layers must be accounted for

Fuel-technology neutral requirements

Specific criteria for traditional Zr-UO₂ fuel is provided in DG-1263, which would state how the SECY-16-0033 embrittlement research findings should be addressed

Fuel Coolability

While the wording is not significantly different in regards to coolability than 50.46, the NRC staff added a discussion in the FRN Preamble (formerly known as Statements of Consideration) that adds clarification on the interpretation of coolability

- The NRC can envision that some amount of dispersed fuel can remain coolable and safe during a LOCA, therefore the NRC finds that if it can be shown to be safe, then it may be acceptable for LOCAs greater than the TBS
 - Departure from precedent
- The NRC outlined 2 scenarios that remain undesirable though:
 - Widespread brittle failure
 - Fuel or cladding melt
- DG-1434 provides guidance for analyzing the consequences of fuel dispersal

50.46a(g): Use of NRC-Approved Fuel

- 1) *Fuel load.* A licensee that is approved to use this section may not load fuel into a reactor unless the resulting core design satisfies the ECCS performance requirements of paragraph (e) of this section and the fuel system acceptance criteria and modeling requirements in paragraph (f) of this section, or otherwise complies with Technical Specifications governing lead test assemblies in its license.
- 2) *Operation.* If a licensee that is approved to use this section determines that fuel in the reactor no longer complies with the ECCS performance requirements of paragraph (e) and the fuel system acceptance criteria and modeling requirements in paragraph (f) of this section, then the licensee must take immediate action to come into compliance with paragraph (e) or (f) of this section, as applicable.

- Clarifies requirement on use of NRC approved fuel designs for which specific ECCS performance requirements have been established.
- Recognizes importance of LTAs for collecting irradiated data to approve new fuel designs.

50.46a(h): Changes Enabled by 50.46a

- Paragraph (h)(1): Changes enabled by this section (50.46a) without prior NRC approval
- Paragraph (h)(2): Changes enabled by this section not permitted under (h)(1)
- Paragraph (h)(3): Criteria that all changes enabled by this section under this section must meet
- Paragraph (h)(4): PRA requirements
- Paragraph (h)(5): Non-PRA requirements

50.46(h)(1): Changes without Prior NRC Approval

Changes enabled by 50.46a are allowed without prior NRC approval if:

- i. Change is permitted under 50.59
- ii. The NRC-approved risk-informed evaluation process demonstrates that any increases in estimated risk are minimal and the requirements in (h)(3) are met
- iii. There is no significant increase in LOCA frequencies and the evaluation demonstrating or establishing the TBS is not invalidated

50.46a(h)(2): Changes Not Permitted Under (h)(1)

For changes enabled by this section not permitted under (h)(1), entities need to submit:

- Information required under 50.90
- Demonstration from the risk-informed evaluation process that the total increases in CDF and LERF are very small* and the overall risk remains small
- Demonstration that the requirements in (h)(3) are met
- Risk-informed evaluation of the cumulative effect on risk on the plant change and all previous changes made under this section
- Demonstration that the ECCS performance criteria are met
- Demonstration that is no significant increase in LOCA frequencies and the evaluation demonstrating or establishing the TBS is not invalidated

*In SRM-SECY-07-0082, the Commission directed that the staff, in the 10 CFR 50.46a draft final rule, should restrict changes to a plant to very small risk increases. Very small risk increase corresponds to an increase in CDF of 1E-6 per reactor year and an increase in LERF of 1E-7 per reactor year.

50.46a(h)(3): Requirements for All Changes Enabled Under 50.46a

All Changes made under this section must meet the following criteria

- Adequate defense-in-depth is maintained
- Adequate safety margins are retained to account for uncertainties
- Adequate performance-measurement programs are implemented to ensure that the risk-informed evaluation continues to reflect actual plant design

50.46a(h)(4): PRA Requirements

PRAs used for the risk-informed evaluation must:

- i. Address initiating events, from sources both internal and external to the plant and for all modes of operation, that would affect the regulatory decision in a substantial manner;
- ii. Reasonably represent the current configuration and operating practices at the plant;
- iii. Have sufficient technical acceptability (including consideration of uncertainty) and level of detail to provide confidence that the total risk estimates and the change in total risk estimates adequately reflect the plant and the effect of the proposed change on risk; and
- iv. Be determined, through peer review, to meet industry standards for PRA quality that have been endorsed or otherwise found acceptable by the NRC.

Expect that low power and shutdown conditions will be addressed with non-PRA methods

50.46a(h)(5): Non-PRA Requirements

Whenever risk assessment methods other than PRAs are used to develop quantitative or qualitative estimates of changes to risk in the risk-informed evaluation, an integrated and systematic process must be used. All aspects of the analyses must reasonably reflect the current plant configuration and operating practices and applicable plant and industry operating experience.

50.46a(i): Authority to impose restrictions on operation

The Director of the Office of Nuclear Reactor Regulation may impose restrictions on reactor operation if the NRC finds that the submitted evaluations of ECCS cooling performance are not consistent with the requirements of this section.

- ❑ Maintains the authority of the director of NRR to impose restrictions on operation if there are problems found in a licensee's ECCS evaluation
- ❑ This authority has existed since the origin of 50.46 and in the draft final 50.46a and 50.46c rules

50.46a(j): Reporting

(j)(1) and (j)(2): ECCS Reporting and corrective actions

- Eliminates reporting requirements for changes or errors that do not result in an inability to assure compliance with § 50.46a until an SDA or a DC is referenced in an application for a CP, OL, COL, or ML.
 - Parallels what is proposed in the Part 50/52 Alignment rulemaking (ACRS letter: ML22069A269)
- Otherwise, it simply clarifies existing reporting requirements

(j)(3): Risk Assessment reporting

- ~~• As part of the risk assessment maintenance and updating required under 50.46a(d)(4), if the re-evaluation results in exceeding the acceptance criteria, must report and explain the changes in PRA modeling, plant, designs, or plant operation that led to the increase(s) in risk no more than 60 days after completing the PRA re-evaluation~~
- Removed from draft proposed rule during concurrence

50.46a(j): Reporting (Cont'd)

Minimal changes reporting

- Must report the changes made under (h)(1) involving minimal changes in risk and a brief summary of the basis for the changes not invalidating the plant's TBS every 24 months

Welding inspection reporting

- Must submit the weld inspection report within 120 days after completing the outage with details of the results of the inspections and the evaluation of the effects on the TBS of any additional degradation since the previous evaluation.
- Can be combined with the summary report required under 50.55a(b)(2)(xxxii)

50.46a(k): Significant changes/Error in ECCS Evaluation Models

For LOCAs at or below TBS, a significant change for UO₂ or MOX fuel within cylindrical zirconium-alloy cladding:

- i. A calculated peak fuel cladding temperature different by more than 50 °F from the temperature calculated for the limiting transient using the last acceptable evaluation model, or is a cumulation of changes and errors such that the sum of the absolute magnitudes of the respective temperature changes is greater than 50 °F; or
- ii. A calculated integral time-at-temperature different by more than 1.0 percent equivalent cladding reacted from the oxidation calculated for the limiting transient using the last acceptable evaluation model, or is a cumulation of changes and errors such that the sum of the absolute magnitudes of the respective oxidation changes is greater than 1.0 percent equivalent cladding reacted.

- Maintains threshold for significant change in calculated PCT at 50 °F
- Adds a new threshold for significant change in integral time-at-temperature of 1.0% ECR
 - Matches what was in draft final 50.46c rule

50.46a(k): Significant changes/Error in ECCS Evaluation Models

- 2) **For LOCAs above the TBS**, a significant change or error in the ECCS evaluation model for uranium oxide and mixed uranium-plutonium oxide pellets within cylindrical zirconium-alloy cladding is one that results in a significant reduction in the capability to meet the requirements of paragraphs (e)(1) and (f) of this section.
 - 3) For fuel that does not consist of uranium or mixed uranium-plutonium oxide pellets within cylindrical zirconium-alloy cladding, a significant change in the ECCS evaluation model is one that results in a significant reduction in the capability to meet the requirements of paragraphs (e)(1) and (f)(1) of this section.
- For breaks above the TBS, an entity could define alternative criteria for a significant change. If alternative criteria are not defined, then the same reporting criteria in proposed 10 CFR 50.46(k)(1) would be applied (50°F PCT and 1% ECR)
 - A new definition of significant change or error may be necessary for other fuel/cladding materials

Changes to Base 50.46

- Corresponding changes were made to 50.46
 - For example, that either 50.46 or 50.46a could be used along with applicability statements
- The 50.46(b) criteria (e.g., 2200°F PCT and 17% ECR limits) were not changed for licensees who do not elect to adopt 50.46 as an attempt to limit the scope of the rule and possible delays
- While the applicability of 50.46 criteria was not expanded from UO2 pellets within Zircaloy or ZIRLO cladding, a statement was added to say that the criteria in 50.46(b) or 50.46a(f)(1) must be met
 - 50.46(3)(i): “The ECCS system must be designed so that its calculated cooling performance following postulated loss-of-coolant accidents (LOCAs) conforms to the criteria set forth in paragraph (b) of this section or § 50.46a(f)(1)...”
 - **Therefore entities with that do not adopt 50.46a and have non-Zircaloy or non-ZIRLO fuel can either elect to submit an exemption to 50.46 to use the 50.46(b) criteria or elect to use the fuel-technology-neutral criteria in 50.46a(f)(1) without an exemption**
 - Entities that elect to use the 50.46a(f)(1) criteria would be expected to address the SECY-16-0033 embrittlement research findings

Questions

Draft Guide-1426
**An Approach for a Risk-Informed Evaluation Process Supporting
Alternative Acceptance Criteria for Emergency Core Cooling
Systems for Light-Water Reactors**

Kristy Bucholtz
Reliability and Risk Analyst
PRA Oversight Branch

50.46a Risk Approach

- 50.46a(c)(iii) requires a risk-informed evaluation to make any proposed change.
- 50.46a has two risk pathways:
 - (1) Individual submittals - risk-informed evaluation with a risk assessment of the proposed changes.
 - Multiple submittals are allowed
 - Initial adoption of the rule
 - Each future change enabled by 50.46a.
 - Initial and each enabled change submitted to NRC for review.
 - Paragraph (h)(2) applies → Acceptance guidelines in DG-1426, Section 2.2.3.1 apply.

50.46a Risk Approach

- 50.46a has two risk pathways:
 - (2) Risk-Informed Evaluation Process (RIEP) submittals - risk-informed evaluation with risk assessment of the proposed changes, **however, RIEP is also submitted for NRC approval.**
 - Multiple submittals are allowed
 - Initial adoption of the rule which includes the RIEP.
 - Each future change enabled by 50.46a.
 - Each future change enabled by 50.46a is evaluated with the RIEP.
 - Paragraph (h)(1) → if met, the change may be made without NRC approval. → DG-1426, Section 2.2.3.2.
 - Paragraph (h)(2) → if met, submit for NRC approval → DG-1426, Section 2.2.3.1.

DG-1426 Structure

- **DG-1426 follows the same structure as RG 1.174**
 - C.1 - Element 1: Define the proposed change
 - C.2 - Element 2: Perform Engineering Analysis
 - C.3 - Element 3: Define Implementation and Monitoring Program
 - C.4 - Element 4: Submit the License Amendment Request
 - C.5 - Quality Assurance
 - C.6 - Documentation

Element 1



- **C.1 - Element 1: Define the proposed change**
 - DG-1426 follows the structure of RG 1.174, which is written for licensees changing their licensing basis, with a few minor changes, identified below:
 - Modified from “licensee” to “entity.”
 - Modified from “licensing basis changes” to “proposed changes.”
 - Added sentences for entity to identify the aspects that may be affected, such as the licensing basis or entity-controlled documentation, and implementation pathway.
 - NRC review - license amendment via 10 CFR 50.90
 - Without NRC review

Element 2

- **C.2 - Element 2: Perform Engineering Analysis**
 - Section 2.1 - Risk-Informed Evaluation Process
 - Section 2.2 - Risk Assessment
 - Section 2.2.1 - Probabilistic Risk Assessment (PRA)
 - Addresses scope, level of detail, technical elements, and plant representation.
 - Based on RG 1.200.
 - Section 2.2.2 - Non-PRA risk assessments
 - Section 2.2.3 - Risk Metrics
 - Section 2.2.3.1 - Acceptance guidelines for risk-informed evaluations requiring prior NRC approval
 - Section 2.2.3.2 - Acceptance guidelines for self-approved risk-informed evaluations
 - Section 2.2.4 - Defense in Depth
 - Section 2.2.5 - Safety Margins

Element 2



- Section 2.2.3.1 - Acceptance guidelines for risk-informed evaluations requiring prior NRC approval



- In order to more closely follow the approach presented in Regulatory Guide 1.174, the staff should modify the proposed rule to ensure that any changes under this rule be further restricted to very small risk increases, notwithstanding the fact that they would otherwise be permitted under 50.59. Therefore, staff should add the word "very" before the word "small" in section (f)(1)(i) so that it reads "...the total increase in core damage frequency and large early release frequency are very small and the overall risk remains small..." or make other changes as appropriate to achieve the above objective.]

Element 2

- Section 2.2.3.2 - Acceptance guidelines for self-approved risk-informed evaluations



Element 3

- **C.3 - Element 3: Define Implementation and Monitoring Program**

- Pointer to the section in RG 1.174 for implementation and monitoring program
 - The periodic updating of the risk assessments was removed from the draft proposed 50.46a rule and DG-1426.
 - DG-1426 no longer includes re-evaluation of the risk assessment.
 - Staff removed the requirement to update the PRA every 5 years from the draft proposed 50.46a rule.
 - The update remains in DG-1426, but has been changed from a “must” to a “should.”

*Note: Staff is revising the version of DG-1426 that was originally submitted to the ACRS to address the four changes listed above.

Element 4

- **C.4 - Element 4: Submit the License Amendment Request**
 - Submit a summary of the PRA model and methods used to evaluate the proposed change.
 - which risk methods are used and why they are acceptable,
 - key modeling assumptions and consideration of uncertainty,
 - key operator actions, and
 - changes required to event or fault trees in the PRA model.
 - For RIEP submittals, submit details of the RIEP to be used to support changes without NRC approval.
 - Description of the entity's PRA model and any non-PRA risk assessment methods to be used.
 - Description of the entity's approach, methods, and decisionmaking process to evaluate:
 - Risk criteria
 - Defense in depth
 - Safety margins
 - Performance measurement and monitoring

Quality Assurance and Documentation

- **C.5 - Quality assurance**

- The same as RG 1.174, with no substantial changes.

- **C.6 - Documentation**

- Differs from RG 1.174
 - For each plant change, the entity should document the risk-informed evaluation, consistent with section C.4 of RG 1.200.

Questions

Proposed Rule: Increased Enrichment of Conventional and Accident Tolerant Fuel Designs for Light-Water Reactors

December 17-18, 2024

Opening Remarks

Theresa Clark
Director
Division of Safety Systems

Draft Regulatory Guides for Zirconium-Alloy Cladding Analytical Limits

James Corson
Senior Reactor Systems Engineer (Fuels Analyst)
Fuel and Source Term Code Development Branch




Overview

- As part of the 50.46c rulemaking, NRC staff developed 3 draft regulatory guides to address zirconium-alloy cladding analytical limits
 - DG-1261 (RG-1.222): Measuring Breakaway Oxidation Behavior
 - DG-1262 (RG-1.223): Determining Post-Quench Ductility
 - DG-1263 (RG-1.224): Establishing Analytical Limits for Zirconium-Based Alloy Cladding
- Staff have updated these documents to reflect the 50.46a proposed rule language
 - Updates reflect fact that aspects of the 50.46c rule language have been moved to guidance for 50.46a proposed rule
 - Otherwise, the guides are (mostly) unchanged from the versions included in the 50.46c draft final rule package

Relation of DGs to the Rule Language

- 50.46a(f)(1) *Fuel performance criteria*. Fuel system designs must have NRC-approved limits that:
 - i. Address cladding degradation phenomena;
 - ii. Maintain fuel coolability
 - iii. Avoid explosive concentration of combustible gas; and
 - iv. Demonstrate that, after any calculated successful initial operation of the ECCS, the ECCS must provide sufficient coolant to remove decay heat and prevent further cladding failure for the extended period of time required by the long-lived radioactivity remaining in the fuel.
- DGs 1261, 1262, and 1263 primarily address zirconium-alloy cladding embrittlement
 - Thus, they mostly address 50.46a(f)(1)(i), though DG-1263 includes a limit for 50.46a(f)(1)(iii)

Zirconium Alloy Cladding Degradation Mechanisms



Abbreviated History

- DGs 1261, 1262, and 1263 included in the 50.46c proposed rule published March 2014 ([ML12283A174](#))
 - Public comment period ended August 2014
 - Several public meetings held on 50.46c during public comment period
- Several public meetings held between close of public comment period and publication of draft final rule in 2016
 - Public meeting on regulatory guidance in April 2015 ([ML15132A743](#))
 - Overview of preliminary draft changes to the rule and guidance in October 2015 ([ML15321A004](#))
 - ACRS SC on the draft final rule package on November 3, 2015 ([ML15320A187](#))
 - ACRS FC meeting on the draft final rule package on December 3, 2015 ([ML15349A717](#))
- DGs included as RGs 1.222, 1.223, and 1.224 in draft final rule package published March 2016 ([ML15238A933](#))

DG-1261: Measuring Breakaway Oxidation Behavior

- Breakaway oxidation in zirconium alloy cladding associated with change from protective tetragonal oxide to non-protective monoclinic oxide
- Breakaway oxidation characterized by significant increase in oxidation rate and hydrogen pickup, both of which lead to cladding embrittlement
- NRC's LOCA program showed that minor changes in alloy composition or manufacturing processes can have significant impact on breakaway oxidation behavior

DG-1261

- Defines an experimental technique capable of determining the effect of composition changes or manufacturing changes on the breakaway oxidation behavior
- Experimental technique includes flexibility, where possible, to allow variation of equipment and procedures in use at other laboratories
- Discusses both initial testing and periodic confirmatory testing

DG-1261

- Initial testing includes examination of breakaway oxidation behavior at a range of temperatures to identify the critical temperature associated with the shortest time to breakaway oxidation
- Allows adoption of Argonne National Laboratory test data for initial implementation of 50.46a rule

DG-1261


- Periodic testing is used to confirm the initial testing (and associated analytical limit) remains applicable to manufacturing life-cycle
 - Periodic Confirmatory Test Program Plans (PCTPP) would be developed by each cladding vendor and submitted for NRC review and approval
 - Periodic testing is focused only on the critical temperature identified in initial testing
 - Vendors would define periodic testing frequency in the PCTPP; DG-1263 provides an optional default frequency (testing once per ingot) and states that other frequencies could be reviewed and approved
 - Guidance allows for relaxation of test frequency with time
 - Periodic testing results are not submitted but must be available for audit

DG-1262: Determining Post-Quench Ductility

- Defines an experimental technical to measure the ductile-to-brittle transition for the zirconium-alloy cladding material
- Experimental technique includes flexibility, where possible, to allow variation of equipment and procedures in use at other laboratories
- Provides detailed discussion of determining the ductile-to-brittle transition CP-ECR for a given hydrogen level, allows for binning results with similar H content
 - CP-ECR = equivalent cladding reacted calculated using the Cathcart-Pawel correlation


DG-1262

- Two approaches (set and curve-fit) are provided to address expected data scatter in a data “bin” and determine the ductile-to-brittle transition CP-ECR for a given hydrogen level
- Set approach



DG-1262

- Two approaches (set and curve-fit) are provided to address expected data scatter in a data “bin” and determine the ductile-to-brittle transition CP-ECR for a given hydrogen level
- Curve-fit approach



DG-1263: Establishing Analytical Limits for Zirconium-Alloy Cladding Material

- Describes an approach to establish limits to address zirconium-alloy cladding degradation phenomena
 - Analytical limits for post-quench ductility and breakaway oxidation
 - PCT limit to address post-quench ductility also protects against higher-temperature degradation mechanisms
- Provides guidance on how to consider the impact of oxygen diffusion from inside surfaces on cladding degradation
- Provides default cladding hydrogen uptake models for currently approved cladding models
- Provides an analytical limit for combustible gas generation

DG-1263

C.1.A – An acceptable limit for currently deployed alloys




Figure 2 of DG-1263. Acceptable analytical limits for peak cladding temperature and integral time at temperature (as calculated in local oxidation calculations using the CP correlation) for Zircaloy-2, Zircaloy-4, ZIRLO[®], M5[®], and Optimized ZIRLO[™]

DG-1263

C.1.B – Adopting Figure 2 for New Alloys

New alloys can adopt Figure 2 by providing the measured ductile-to-brittle transition level for cladding material in the following conditions:

1. As received
2. Unirradiated, pre-hydrated within 100 ppm of the maximum hydrogen content specified at end of life (EOL)
3. Unirradiated, pre-hydrated within 100 ppm of half of the maximum hydrogen content specified at EOL
4. Irradiated (unless the new alloy is “similar” to previously tested alloys)

DG-1263

- New cladding alloys are considered “similar” to alloys tested in NRC’s LOCA program (conducted at Argonne National Laboratory) if they:
 - Use the Kroll process
 - Operate less than or equal to the maximum fluence
 - Include only the alloying elements present in the materials tested
 - Have similar alloying content of each element to the materials tested in NRC’s LOCA program, whereby each alloy element is defined by less than or equal to 25 percent deviation from the alloying limits defined for the tested alloy

DG-1263

C.1.C & C.1.D – Adopting other post-quench ductility limits

- Analytical limits other than those defined in Figure 2 can be adopted for new and existing alloys to gain margin for superior alloy-specific cladding performance (C.1.C) or for slower embrittlement behavior at lower temperatures (C.1.D)

DG-1263

C.1.E – Hydrogen pickup models

- An alloy-specific cladding hydrogen uptake model should be used in conjunction with the hydrogen-dependent embrittlement threshold provided in Figure 2
- Appendix A of DG-1263 provides acceptable fuel rod cladding hydrogen uptake models for the current commercial zirconium alloys

DG-1263

C.1.F – Demonstrating compliance for PQD

- Identify the limiting conditions and assumptions that maximize predicted PCT and local oxidation
- Demonstrate PCT and max local oxidation are below PQD analytical limit
- Provides allowance for subdividing the ECCS evaluation based on cladding hydrogen content, burnup, fuel rod power, or a combination
- Provides allowance to use Figure 2 for legacy fuel to show compliance with 50.46a(f)(1) requirements

DG-1263

C.2 – Breakaway oxidation

- Provides allowance for legacy fuel to use analytical limit established for the current version of the alloy
- Applicants may elect to establish the analytical time limit for breakaway oxidation with conservatism relative to the measured minimum time (i.e., reduce the time) to the onset of breakaway oxidation
- The total time that the cladding is predicted to remain above the temperature that the zirconium-alloy cladding material has been shown to be susceptible to breakaway oxidation (800°C default) must be less than the analytical limit
 - Applicant may credit operator action to limit the duration at elevated temperatures provided these actions are consistent with existing procedures and the timing of such actions is validated by operator training on the plant simulator or via a job performance measure

DG-1263

C.3 – Hydrogen generation

- The calculated total amount of hydrogen generated from the chemical reaction of the cladding with water or steam should not exceed 0.01 times the hypothetical amount that would be generated if all of the metal in the cladding cylinders surrounding the fuel, excluding the cladding surrounding the plenum volume, were to react
- Same as existing requirement in 50.46(b)(3)

DG-1263

C.4 – Inner diameter oxidation

- ECCS evaluation models should consider oxygen diffusion from the cladding inside surfaces if an oxygen source is present on the inside surface of the cladding at the onset of the LOCA
 - Cladding rupture: calculate 2-sided oxidation using CP correlation, consider the reduced cladding thickness and the rupture mid-plane and apply Figure 2 (same approach used today)
 - Fuel-cladding bond: calculate 2-sided oxidation once the fuel-cladding bond layer is predicted to occur (default threshold is 30 GWd/MTU, but higher limits can be proposed for NRC review and approval)

Conclusions

- Three draft guides have been developed to support performance-based criteria related to zirconium-alloy cladding degradation in the 50.46a proposed rule. The DGs provide guidance to develop material-specific analytical limits on key embrittlement mechanisms.
 - DG-1263 also includes a hydrogen generation limit
- The DGs are based on the guides submitted as part of the 50.46c draft final rule package but have been updated to reflect requirements of the 50.46a proposed rule (e.g., removing specific limits from the rule language)
 - DGs reflect extensive interactions with industry stakeholders during the 50.46c draft final rule public comment period.


Questions

DG-1434: Addressing the Consequences of Fuel Dispersal in Light-Water Reactor Loss-of- Coolant Accidents

James Corson
Senior Reactor Systems Engineer (Fuels Analyst)
Fuel and Source Term Code Development Branch

Fuel Fragmentation, Relocation, and Dispersal (FFRD)

- At HBU experiments have shown that the fuel can fragment during a LOCA
- Differences in pressure across the cladding can lead to cladding ballooning and burst
- The fragmented fuel can relocate axially into the balloon region of the fuel rod and if burst occurs, disperse into the RCS





Segment from NRC's ANL LOCA program at 55 GWd/MTU before and after testing

No fuel relocation;
pellets remain in
concentric stack



Relocation assumed;
pellets move axially to
fill balloon region

Low gap conductance
High gap conductance



Burst openings from Studsvik LOCA tests (NUREG-2121)

FFRD: History

1974 –
10 CFR
50.46
criteria
for
LOCA's

1984-1995
– GI-92,
“Fuel
Crumbling
During
LOCA”

2008 –
RIL-
0801

2015 –
SECY-15-
0148 – No
imminent
safety
concern

2021 –
RIL-2021-
13

2024 –
NUREG/CR-
7307

1980 –
FFRD
Discovered

2006 –
FFRD
testing
showed
gross
fuel loss
at high
BU

2012 –
NUREG-
2121

2016 –
Draft
final rule
for
50.46c

2022 – SRM-
SECY-21-
0109 –
Include FFRD
in IE
Rulemaking

Fuel Dispersal: Background and Regulatory Issue

- The 50.46 acceptance criteria date to 1974 when FFRD were not known phenomena
- Acceptable approaches to demonstrate compliance with the regulations have ensured that catastrophic failure of the fuel rod structure and loss of fuel bundle configuration are precluded
 - Fuel dispersal would be a departure of precedent
- Fuel dispersal is not explicitly addressed within the current regulations
 - Proposed rule language (50.46a) allows for some flexibility regarding fuel dispersal
 - DG-1434 provides guidance for addressing fuel dispersal within the proposed rule

Draft Guidance for Fuel Dispersal

- DG-1434 provides guidance for addressing the impact of fuel dispersal on ECCS performance
 - Includes a model to estimate the mass of dispersed fuel
 - Provides high-level acceptance criteria for fuel dispersal
 - Lists analyses to perform to address consequences of dispersed fuel
- DG-1434 builds on recent research efforts and reflects the current state of knowledge
 - Research Information Letter (RIL) 2021-13, “Interpretation of Research on Fuel Fragmentation, Relocation, and Dispersal at High Burnup” ([ML21313A145](#))
 - NUREG/CR-7307, “PIRTs on High Burnup Fuel Fragmentation, Relocation, Dispersal, and Its Consequences” ([ML24155A058](#))
 - EPRI-sponsored [2024 White Paper](#), “Assessment of Existing Fuel Fragmentation, Relocation, and Dispersal Data: Best Estimate Interpretation”
 - Several recent publications from researchers at Oak Ridge and Idaho National Laboratories

Conclusions from the Fuel Dispersal PIRT

- Understanding how much material disperses is crucial to demonstrating coolability
 - Key parameters influencing dispersal include transient FGR, fuel fragment size distribution, cladding burst characteristics, spacer grid characteristics, core flow patterns during the transient, and core loading pattern
 - Some parameters can be calculated fairly accurately (e.g., core loading pattern, core flow)
 - Other parameters are less well known and highly uncertain (e.g., transient FGR, fragment size distribution, burst opening size, impact of spacer grids on debris trapping)
- Dispersal of fuel fragments remains poorly understood
 - However, the PIRT panelists believe it should be possible to perform simplified analyses to demonstrate coolability so long as the dispersed mass remains low


Structure of DG-1434

1. Limits on applicability
2. FFRD thresholds
3. Analytical limits for fuel dispersal
4. Methods for estimating the dispersed fuel mass
5. Impacts of fuel dispersal
 - a. Fuel particle transport and deposition
 - b. Fuel coolability and long-term cooling
 - c. Re-criticality
 - d. Radiological consequences and environmental qualification (covered by RG 1.183 Rev. 2)

Limits on Applicability

- FFRD thresholds and methods for estimating the mass of dispersed fuel apply to undoped UO_2 fuel in zirconium-alloy cladding
 - Extension to UO_2 fuel with dopants (e.g., gadolinia, chromia, alumina, and/or silica) or MOX will be considered on case-by-case basis
 - Recently completed SCIP-IV tests and upcoming tests under the Second Framework for Irradiation Experiments (FIDES-II) and SCIP-V could help address this limitation
- Other sections of the guidance are generally applicable to all fuel designs, unless otherwise noted
 - For example, some limits related to recriticality (see upcoming slides)

FFRD Thresholds




- NRC staff position is that fine fragmentation begins around a burnup of 55 GWd/MTU
- This is a simplification of complex processes in the fuel
 - Burnup is only a surrogate for microstructural changes
 - Other parameters (e.g., temperature) influence fragmentation behavior

Figure 3 from RIL 2021-13

FFRD Thresholds

- Relocation is limited below a cladding hoop strain threshold of 3%
- Thus, fuel rods with pellet-average burnups above 55 GWd/MTU that balloon and burst during LOCA are susceptible to fuel dispersal



NRC test #	Strain threshold, top (%)	Strain threshold, bottom (%)
189	6.0	3.0
191	6.0	4.0
192	5.0	4.0
193	1.0	4.0
196	3.0	5.0
198	4.5	9.0

Figure 4 and Table 1 from RIL 2021-13


Analytical Limits for Fuel Dispersal

- DG-1434 provides acceptance criteria for the dispersed fuel mass
 - No fuel dispersal for breaks $<$ TBS
 - Can be addressed by showing no ballooning and burst for rods peak pellet burnup $>$ 55 GWd/MTU
 - For breaks $>$ TBS, either show there is no fuel dispersal or show that other criteria are met (see upcoming slides)
- Dispersed fuel mass should be calculated using an approved evaluation model and fuel dispersal models
 - Evaluation model should include the impacts of transient fission gas release

Plausibility of the No Dispersal Criterion

- NRC staff analysis performed around 2013 provided fuel dispersal estimates for 3 plant designs (Westinghouse 4-loop PWR, CE PWR, GE BWR/4) (see [ML23086B272](#))
 - Based on current licensed burnup limits and fuel management practices
 - Using nominal (rather than intentionally conservative) initial conditions
 - No dispersal predicted for CE PWR or GE BWR/4
 - Core wide PCTs of 700°C and 500°C, respectively
- During the IE rulemaking regulatory basis public comment period, NRC staff received comments stating that it may be possible to show no dispersal using more realistic LOCA methods allowed for break sizes > TBS

Methods for Estimating Dispersed Fuel Mass



- Fuel dispersal is impacted by many parameters, most of which are highly uncertain
 - Fuel dispersal PIRT identified “burst opening size relative to the fuel fragment size distribution” as high importance / low knowledge level
 - Other parameters like rod internal pressure also impact dispersal
- DG-1434 proposes a surrogate model for fuel dispersal
 - Avoids mechanistically modeling transport of particles through burst opening

Figure A-4 from RIL 2021-13: Fragment size distribution for two SCIP-III tests, with relative burst opening size

Methods for Estimating Dispersed Fuel Mass

Figure A-6 from RIL 2021-13:
Mass fraction of fragments < 1 mm,
with RIL Model A for comparison





Figure A-1 from RIL 2021-13:
Mass of fuel dispersed during the
test



- RIL 2021-13 provided surrogate models for fuel dispersal
 - Model A assumes that the mass of fragments below 1 mm is a good surrogate for dispersed mass
 - However, this does not mean that all dispersed fragments are less than 1 mm, nor does it mean that all 1 mm fragments disperse
 - Still, Model A is consistent with observations that dispersal increases with burnup

Methods for Estimating Dispersed Fuel Mass


- DG-1434 recommends using RIL Model A to calculate fuel dispersal

$$\text{mass fraction} = \begin{cases} 0, & \text{BU} < 55 \\ 0.04(\text{BU} - 55), & 55 < \text{BU} < 80 \\ 1, & \text{BU} > 80 \end{cases}$$

- Mass fraction should be multiplied by the mass of fuel in the region with >3% hoop strain
 - Can credit grid spacers to limit axial length of fuel susceptible to dispersal
- Calculation should be performed for rods predicted to balloon and burst

	Difference between dispersal predicted by the model and dispersal observed in the experiment	
	A (mass, g)	A (%)
SCIP-III Test		
OL1L04-LOCA-2	29	314%
N05-LOCA	(10)	70%
VUR1-LOCA-1	(26)	76%
WZR0067-LOCA	(18)	75%
VUL2-LOCA1	34	169%
VUL2-LOCA3	142	874%
VUL2-LOCA4	99	259%

Methods for Estimating Dispersed Fuel Mass



- Methods for estimating mass of fuel dispersed should consider impact of transient fission gas release
 - Models should only consider gas release up to the point of ballooning and burst
 - Expected release at time of burst likely less than results shown in RIL 2021-13 due to burst temperatures being lower than test temperatures and impact of rod internal pressure in suppressing gas release
 - DG-1434 does not endorse any models but identifies potential starting points

Figure 7 from RIL 2021-13: Transient fission gas release as a function of burnup; note that peak temperatures for the Studsvik and single-pellet tests were between 1000 and 1200°C



Fuel Particle Transport

- The fuel dispersal PIRT panel noted that transport of irregularly shaped particles in multi-phase flow is poorly understood
 - Panelists suggested addressing impacts of dispersal through simplified, bounding calculations, using engineering judgement about where particles may deposit
- DG-1434 identifies several potential dispersed fuel configurations to use when addressing fuel coolability
 - For example: on spacer grid immediately below cladding burst location, lower plenum, RCS piping

Fuel Coolability

- Analyses should address impact of dispersal on PCT and maximum local oxidation
 - Assuming fuel collects on spacer grid immediately below the burst location
- Analyses should verify that the dryout heat flux is not exceeded for particle beds on spacer grids and for other locations
 - Should use the 0-D Lipinski model to calculate dryout heat flux (i.e., maximum heat that can be removed from surface of particle bed)
- Analyses should perform calculations using range of conditions
 - Fuel particle size: 0.125 – 4 mm
 - Bed porosity: 20% – 40%

Fuel Coolability: Lipinski Model



- OECD/NEA Working Group on Fuel Safety report on FFRD included dryout heat flux calculations
 - Showed dryout heat flux could be exceeded under some conditions (especially for small particle sizes)

Figs. 8.1-1 and 8.1-2 from the OECD/NEA Working Group on Fuel Safety [2016 report on FFRD](#)

Fuel Long-term Cooling

- Analyses should demonstrate that adequate coolant flow is provided to remove decay heat from within the core and from fuel dispersed out of the core
- Analyses should verify that the dryout heat flux is not exceeded for particle beds
 - Should consider potential impact of coagulants or other debris that could reduce bed porosity below 20%

Dispersed Fuel Recriticality

- The fuel dispersal PIRT panel believed that recriticality of dispersed fuel is not a concern
 - Panelists also stated this could be demonstrated using existing tools and engineering judgement
- Staff performed simple analysis to address the potential for recriticality ([ML24319A262](#))
 - Focused on simplified model for the lower plenum of Westinghouse 4-loop plant
 - Assumed all fuel was at 55 GWd/MTU (fine fragmentation threshold in DG-1434) and had initial U-235 enrichment of 8 weight percent
 - Did not credit soluble boron

Dispersed Fuel Recriticality

Pile Depth (cm)	K_{eff}	Fuel Mass (metric tons UO ₂)
20	0.725009 ± 0.000229	2.2
30	0.773866 ± 0.000261	4.0
40	0.800106 ± 0.000338	5.9
50	0.820710 ± 0.000286	7.9

- Staff calculations show mass needed for recriticality far exceeds expected dispersed mass
 - For context: if all fuel in one grid space (~10% of the rod length) from all high burnup rods (~1/2 the rods in the core) dispersed, this would result in < 5 metric tons of UO₂ (for Westinghouse 4-loop plant)



CSAS-Shift model of lower plenum/fuel mixture (grey- steel / blue- non-borated water / green- Fuel/water mixture)

Dispersed Fuel Recriticality

- Staff analysis shows that recriticality is very unlikely
 - This is consistent with analysis performed by the OECD/NEA Working Group on Fuel Safety
 - Staff only performed quantitative analysis for one configuration, but based on engineering arguments recriticality is unlikely for other configurations
- DG-1434 states that licensees should demonstrate that the potential recriticality is addressed for their plant configuration
 - Licensees can use qualitative engineering arguments if dispersed mass is significantly less than the amounts in the staff calculation
 - At the same time, staff is working on providing stronger basis to resolve recriticality concern for the draft final rule package

Conclusions

- DG-1434 provides guidance for addressing the impact of fuel dispersal on ECCS performance
 - Guidance relies on use of more realistic LOCA methods and less conservative models from RIL 2021-13 to limit dispersed fuel mass
 - Guidance also includes methods to address impact of dispersed fuel on coolability
- Guidance is only one method for meeting regulatory requirement to maintain fuel coolability (50.46a(f)(1)(ii))
 - Industry can propose alternative approaches for NRC review

Questions

Increased Enrichment Rulemaking for GDC-19 – Control Room and 10 CFR 50.67, Accident Source Term

Elijah Dickson, Senior Reliability and Risk Analyst

Dave Garmon, Health Physicist

Division of Risk Assessment

Office and Nuclear Reactor Regulation

December 18, 2024

Topics

Rulemaking Driver and Goal

Background and History

Regulatory Issues

Rulemaking Proposal

Rulemaking Approach

Rulemaking Driver and Goal

Legislative Driver:

- January 14, 2019, the President signed into law the Nuclear Energy Innovation and Modernization Act (NEIMA). Section 107, “Commission Report on Accident Tolerant Fuel,” of NEIMA defines ATF as a new technology that makes an existing commercial nuclear reactor more resistant to a nuclear incident (as defined in section 11 of the Atomic Energy Act of 1954 (42 U.S.C. 2014)) and lowers the cost of electricity over the licensed lifetime of an existing commercial nuclear reactor.

Purposes:

- Facilitate the use of light-water reactor (LWR) fuel containing uranium enriched to greater than 5.0 weight percent uranium-235 (U-235).
- Developed in response to nuclear power industry interest to use fuel enriched to greater than 5.0 weight percent U-235 and deploy accident tolerant fuels (ATFs).

Staff Response:

- Evaluated areas within the regulatory framework and considered whether the current weight percent limits can be adjusted while maintaining reasonable assurance of adequate protection of public health and safety. Additionally, considered whether this rulemaking would support a more efficient review of licensing actions.

Background and History

Both GDC-19 and 10 CFR 50.67(b)(2)(iii) provide a specific dose-based criterion of 5 rem TEDE for demonstrating the acceptability of the control room design.

Represent a distinct layer of defense-in-depth that assumes a major accident that results in substantial meltdown of the reactor core with subsequent release of appreciable quantities of fission products.

Classic performance-based regulations which require that a licensee or applicant provide a control room habitability design using traditional deterministic radiological consequence analyses methods to judge the acceptability of the design.

Consequence analyses are also used to verify other regulatory requirements, guide maintenance activities, and serve as a guideline for performing 10 CFR 50.59 analyses.

Regulatory Issues

Assess Applicability in Current Environment

- Control room design criteria is limiting between the three acceptance criteria (EAB, LPZ, CR) for current enrichments and burnups.
- Development during the 1960s did not foresee how licensees are currently operating their facilities and managing fuel.
- The history of fuel utilization fleet has seen a gradual progression toward higher fuel discharge burnups and increased enrichments.
- There has been enough margin in the facilities' design- and licensing bases to accommodate the criteria, even for power uprates of up to 120 percent of the originally licensed steady-state thermal power level.
- Impact on Commission's comprehensive radiation protection and emergency planning frameworks.

Considerations of Control Room *Design* Criteria Impact is multifaceted

- Designer margin and operational flexibilities.
- Maturity of the regulated industry and compliance infrastructure.
- Maintenance activities and controlling actual operational exposure.
- 10 CFR 50.59 and low safety-significant licensing actions.

Radiological Risk Communications


- Design Criteria vs. Occupational Dose Limit.
- Radiation Protection and Emergency Response Frameworks.
- Health Physics First Principles and Radiation Epidemiology.
- Insights from Category 9 events.

Regulatory Issues (Cont.)

- The preamble for the 10 CFR 50.67 (64 FR 71990; December 23, 1999), final rule included the Commission's rationale for establishing 5 rem (0.05 Sv) TEDE as the GDC-19 numeric design criterion for licensees using an alternative source term. That rationale comprised the following:

"The criteria in GDC 19 were based on a primary occupational exposure limit.

The use of 5 rem (0.05 Sv) TEDE as the control room criterion did not imply that this value would be an acceptable exposure during emergency conditions, or that other radiation protection standards of 10 CFR part 20, including individual organ dose limits, might not apply. This criterion was provided only to assess the acceptability of design provisions for protecting control room operators under postulated DBA conditions. The DBA conditions assumed in these analyses, although credible, generally did not represent actual accident sequences but were specified as conservative surrogates to create bounding conditions for assessing the acceptability of engineered safety features."



Regulatory Basis Alternatives

Regulatory Basis document assessed three Alternatives. (88 FR 61986)

- *Alternative 1: No Action*
- *Alternative 2: Pursue Rulemaking to Amend the Control Room Design Criteria and Update the Current Regulatory Guidance Accordingly with Revised Assumptions and Models and Continue to Maintain Appropriate and Prudent Safety Margins*
- *Alternative 3: Update the Current Regulatory Guidance with Revised Assumptions and Models and Continue to Maintain Appropriate and Prudent Safety Margins*

Public Comments

Regulatory basis document sought comments on the alternatives proposed and asked two questions. (88 FR 61986)

Question 1:

Would the numerical selection of the control room design criteria be better aligned with regulations designed to limit occupational exposures during emergency conditions (e.g., 10 CFR 20.1206, "Planned special exposures," and 10 CFR 50.54(x)), or regulations designed to limit annual occupational radiation exposures during normal operations (e.g., 10 CFR 20.1201, "Occupational dose limits for adults," specifically the requirements in 10 CFR 20.1201 (a)(1)(i))? Please provide a basis for your response.

Question 2:

Would a graded, risk-informed method, to demonstrate compliance with a range of acceptable control room design criterion values instead of a single selected value, such as the current 5 rem (50 mSv) TEDE, provide the necessary flexibilities for current and future nuclear technologies up to but less than 20.0 weight percent U-235 enrichment? Please provide a basis for your response.

Assessment of Regulatory Basis Alternative 2 to perform rulemaking

- **Option 2A**—Amend the codified numerical acceptance value from 5 rem total effective dose equivalent (TEDE) to a new single value of 10 rem TEDE, with conforming changes to guidance.
- **Option 2B**—Amend the codified numerical acceptance value from 5 rem TEDE to a range of values from 10 to 25 rem TEDE, with a graded, risk-informed, performance-based framework in guidance.
- **Option 2C**—Amend the codified numerical acceptance value from 5 rem TEDE to a new single-value 25 rem TEDE, with conforming changes to guidance.

Proposed Rulemaking Language

- High-level Changes
 - Increase from 5 rem to 10 rem TEDE.
 - If additional operational flexibilities are needed beyond 10 rem TEDE, facility-specific risk profile or information can be leveraged to justify a higher numerical value up to 25 rem TEDE with is provided in DG-1425 (RG 1.183 Rev. 2).
 - Clarify the purpose of the control room design criteria and distinguish it from the radiation protection and emergency preparedness frameworks.
 - Consistence with other regulations containing either dose-based design criteria or radiation exposure limits.
 - DG-1425 adopts a method that develops a framework for a graded, risk-informed, and performance-based control room design criterion. Approach is consistent with SECY 98-144.

Proposed Rulemaking Language

Example of 10 CFR 50.67(b)(2)(iii) proposed language:

“(iii) The necessary design, fabrication, construction, testing, and performance criteria for structures, systems, and components important to safety are provided to permit occupancy of the control room under accident conditions without calculated radiation exposures in excess of 0.10 Sv (10 rem) total effective dose equivalent (TEDE) or a higher design criterion limit established in accordance with paragraph (b)(3) of this section for the duration of the accident.

(3) The licensee may establish a design criterion limit higher than 0.10 Sv (10 rem) total effective dose equivalent (TEDE) but not greater than 0.25 Sv (25 rem) TEDE for compliance with paragraph (b)(2)(iii) of this section provided the licensee demonstrates that the specified limit is consistent with the plant risk-profile or commensurate with the risk of the plant.

Approach for Rulemaking for the Control Room Design Criteria



Policy and Regulation

Flexibility within Commission Policy

Radiation Protection and Emergency Response Framework



Evidence-based justifications

Scientific Recommendations

Radiation protection and radiation epidemiology



Ability to Provide Reasonable Regulatory Relief

Reduce regulatory burden while maintaining safety and compliance

Risk-informed and performance-based Rulemaking

Policy and Regulation

—

Flexibility within Commission Policy

- 10 CFR Part 20 puts into practice recommendations from the ICRP and NCRP. (56 FR 23360; May 21, 1991)
 - ICRP Publication 26, Recommendations of the ICRP (ICRP, 1977) subsequent ICRP publications.
 - NCRP Report No. 91, Recommendations on Limits for Exposure to Ionizing Radiation. (NCRP, 1987)
- From ICRP 26
 - Occupational exposure limit set to limit stochastic effects and prevent deterministic effects.
 - 5 rem/yr dose-equivalent to limit stochastic effects to an acceptable level.
 - 50 rem/yr dose-equivalent to all tissues except the lens to prevent deterministic effects.
- Both ICRP and Part 20 provide flexibility for planned special exposures.
 - ICRP proposal would have permitted a 15-rem dose in 1 year.
 - Part 20 condition theoretically possible to get a 10-rem dose in 1 year.
 - Concluded that an infrequent exposure of workers up to twice the occupational dose limit was adequately protective of radiation workers.

Finding: The system of dose limitation, as adopted by the Commission in 10 CFR Part 20, provides flexibility when considering risk-informing the dose-based control room design criteria.

Policy and Regulation — Radiation Protection and Emergency Response Framework

10 CFR Part 20,
*Standards for
Protection Against
Radiation.*

10 CFR Part 50.47,
Emergency plans.

Appendix E to Part 50—
*Emergency Planning
and Preparedness for
Production and
Utilization Facilities.*

10 CFR Part 55,
Operators' Licenses.

10 CFR Part 50.54,
Conditions of licenses.

10 CFR Part 50.155,
*Mitigation of beyond-
design-basis events.*

Finding: a range of regulatory dose-based occupational expose limits and design/siting criteria up to 25 rem TEDE. Understanding of their basis, purpose, and application helped inform IE rulemaking proposal.

Policy and Regulation – Radiation Protection and Emergency Response Framework (Cont.)

Original GDC-19 (1971)

- At the time that GDC-19 was established in 1971, 10 CFR Part 20 limited occupational radiation exposure to 3 rem (0.03 Sv) whole body dose per calendar quarter, provided the total lifetime dose was verified not to exceed 5 rem (0.05 Sv) times the individual's age in years minus 18. Thus, a worker could receive a radiation exposure of up to 12 rem (0.12 Sv) in a given year.

10 CFR Part 20.1201, “Occupational dose limits for adults,”

- An adult worker could receive occupational radiation exposure of up to 10 rem (0.10 Sv) TEDE over a 12-month period straddling two calendar years.

10 CFR Part 20.1206, “Planned special exposures,”

- Permits an adult worker to receive doses in addition to, and accounted for separately from, the doses received under the limits specified in 10 CFR 20.1201 of five times the annual dose limits during the individual's lifetime, not to accumulate faster than 5 rem (0.05 Sv) TEDE in any one year. As such, an adult worker could receive radiation exposure of up to 10 rem (0.10 Sv) TEDE within a single calendar year period.

Policy and Regulation – Radiation Protection and Emergency Response Framework (Cont.)

10 CFR 50.47(b)(11)

- Establish the means for controlling radiological exposures in an emergency and states that the means for controlling radiological exposures must include exposure guidelines consistent with EPA Emergency Worker and Lifesaving Activity Protection Action Guides (PAG).
- EPA PAG Manual, recommends that doses received under emergency conditions should be maintained ALARA and, to the extent practicable, limited to 5 rem (0.05 Sv).
- The guideline for actions to protect valuable property is 10 rem (0.10 Sv) where a lower dose is not practicable, the guideline for actions to save a life or to protect large populations is 25 rem (0.25 Sv) where a lower dose is not practicable, and exposures greater than 25 rem (0.25 Sv) may be appropriate for lifesaving or protecting large populations if the workers are volunteers who are fully aware of the risks involved.

Policy and Regulation – Radiation Protection and Emergency Response Framework (Cont.)

10 CFR 100.11, “Determination of exclusion area, low population zone, and population center distance”;

10 CFR 50.34, “Contents of applications; technical information”;

10 CFR 50.67; and

10 CFR part 52.

- The upper range of the proposed numerical values would be consistent with the Commission’s use of the 25 rem (0.25 Sv) TEDE limit primarily in regulations for power reactor siting to protect the public during emergencies.
- As discussed in the preamble for the final rule updating the NRC’s siting criteria (61 FR 65159; December 11, 1996),

“the Commission's use of 25 rem (0.25 Sv) TEDE does not imply that it considers it to be an acceptable limit for an emergency dose to the public under accident conditions, but only that it represents a reference value to be used for evaluating plant features and site characteristics intended to mitigate the radiological consequences of accidents in order to provide assurance of low risk to the public under postulated accidents.”

Evidence-based
justification
—
Scientific
Recommendations

- Reviewed several source materials to understand the current recommendations from national and international organizations responsible for making recommendations for radiation protection standards.
- Purpose of this review was to determine whether reexamining the scientific and technical basis for the numerical value of the control room design criteria would be warranted.


Finding - a range of international and national organization-based recommendations for radiation exposures for radiation workers under normal and emergency conditions up to 25 rem TEDE.

Source: Brock, Et al., NRC, White Paper, "Control Room Design Criteria and Radiological Health Effects (ADAMS ML23027A059)


Evidence-based justification – Scientific Recommendations




25 rem for
lifesaving or
protection of large
populations



2–10 rem acute for
emergency
exposure
situations



10-50 rem, 100 rad,
acute depending on
the severity of the
actions needed



50 rad to 10 rem,
depending on
actions needed



Substantial and convincing
scientific evidence of health
effects following high-dose
exposures. However, below
levels of about 10 rem above
background from all sources
combined, the observed
radiation effects in people
are not statistically different
from zero.

Evidence-based
justification

—

Radiation protection
and radiation
epidemiology

- Proposed rule recommendations are firmly founded on modern radiation protection- and health effects knowledge.
- **Deterministic Health Effects (rad)**
 - Significantly below the threshold for observable deterministic health effects such as acute radiation syndrome and hematopoietic syndrome which occurs at doses around 70 to 100 rad respectively.
 - Far below the mean lethal dose of ionizing radiation without medical treatment, estimates to be approximately 300 to 500 rad.
 - Part 20 exposure limit set low enough to protect against deterministic effects.
- **Stochastic Health Effects (rem)**
 - Far below individual estimates of radiation risks for cancer mortality given the relatively short time frame exposures would be incurred.
 - Radiation protection and emergency response programs would actively monitor and manage occupational exposure before the 10 CFR Part 20 limit.
 - Traditional DBA radiological consequence analysis will continue to provide additional defense-in-depth from the 10 CFR Part 20 occupational exposure limits.
 - Continues to ensure a high level of protection is still provided, minimizing long-term health impacts.

Ability to Provide Reasonable Regulatory Relief


—
Reduce regulatory burden while maintaining safety and compliance

- A very low design criteria value can result in an excessive amount of maintenance, leading to avoidable occupational exposure and unnecessary operational disturbances. Conversely, a very high value may allow for unacceptable degradation, potentially compromising overall safety and performance over time.
- Considerations of Control Room Design Criteria Impact is multifaceted:
 - Maturity of the regulated industry and compliance infrastructure.
 - Designer margin and operational flexibilities.
 - Maintenance activities and controlling actual operational exposure.
 - 10 CFR 50.59 and low safety-significant licensing actions.

Finding: Adequate protection of public health and safety and occupational radiological safety can still be achieved at a higher, but still safe, control room design criteria performance level while balancing both dose-savings to workers and providing some regulatory relief to maintain operational flexibilities.




Ability to Provide Reasonable Regulatory Relief – Reduce regulatory burden while maintaining safety and compliance



Histogram of Licensees' Analysis of Record DBA Result
Percent-Margin to Control Room 5 rem TEDE

Ability to Provide Reasonable Regulatory Relief – Reduce regulatory burden while maintaining safety and compliance



Histogram of Licensees' Analysis of Record DBA Result
Percent-Margin to Control Room 5 rem TEDE

Ability to Provide Reasonable Regulatory Relief

—

Risk-informed and performance-based Rulemaking

- Consider Commission-directed PRA-related policies which advocate certain changes to the development and implementation of its regulations using risk-informed, and ultimately performance based, approaches.
 - 1985 Severe Reactor Accident policy statement (50 FR 32138; August 8, 1985)
 - PRA Policy Statement (60 FR 42622, August 16, 1995)
 - **SRM-SECY-98-144, “Staff Requirements—SECY-98-144—White Paper on Risk-Informed and Performance-Based Regulations” (ADAMS Accession No. ML003753601)**
- SRM-SECY-98-144 defines the terms and Commission expectations for risk-informed and performance-based regulation. Item 8, “Risk-Informed, Performance-Based Approach,” reads as follows:

*“... Stated succinctly, a risk-informed, performance-based regulation is an approach in which risk insights, engineering analysis and judgment including the principle of defense-in-depth and the incorporation of safety margins, and performance history are used, to (1) focus attention on the most important activities, (2) **establish objective criteria for evaluating performance**, (3) **develop measurable or calculable parameters for monitoring system and licensee performance**, (4) **provide flexibility to determine how to meet the established performance criteria in a way that will encourage and reward improved outcomes**, and (5) focus on the results as the primary basis for regulatory decision-making.”*

Ability to Provide Reasonable Regulatory Relief – Risk-informed and performance-based Rulemaking

Break SRM-SECY-98-144 into Rulemaking- and Guidance Elements...

Element 1 – **Rulemaking** to design a rule which *establishes objective criteria for evaluating performance with developed measurable or calculable parameters for monitoring system and licensee performance.*

Element 2 – **Guidance** to design a regulatory framework which *provides flexibility to determine how to meet the established performance criteria in a way that will encourage and reward improved outcomes.*

Ability to Provide Reasonable Regulatory Relief – Risk-informed and performance-based Rulemaking

Element 1

- Increase control room design criteria by a factor of 2, from 5 rem to 10 rem TEDE and range up to 25 rem TEDE with consideration of the plant-specific risk profile and risk information.
 - Numerical values are risk-informed based:
 - Commission Policy and Regulations for infrequent- and emergency exposures.
 - Recommendations from national and international and organizations responsible for radiation protection standards and guidance.
 - modern radiation protection- and epidemiology.
 - Performance-based aspect of rule retained within guidance which historically requires traditional DBA radiological consequence analyses thereby retaining staff's experience and licensee's licensing basis.
 - Flexibility and scalability incentivizes safety improvements if additional margin is needed beyond 10 rem TEDE where a lower facility-specific risk-metric allows for a higher and still safe performance criteria.



Ability to Provide Reasonable Regulatory Relief – Risk-informed and performance-based Rulemaking

Element 2

- Establish in guidance, a framework for a graded, risk-informed and performance-based control room design criterion.
 - Enables a performance-based evaluation using traditional deterministic radiological consequence analysis methods within defined risk informed boundaries.
 - Boundaries are defined by acceptable radiation exposure guidelines for radiation workers during accident and emergency conditions and acceptable contemporary nuclear facility risk profiles using modern probabilistic risk assessment methods.
 - Provide flexibility when determining how to meet an established acceptance criterion in a way that encourages and rewards safety of the facility.
 - In practice, the method produces a framework that leverages in part, its safe design and operations to justify a higher control room design criterion with a lower plant-specific risk metric.
- Considerations:
 - Simple to understand and use.
 - Leverages well-known and understood methods and analyses.
 - Similar to other graded regulatory methods such as RG 1.174, SRP-specific DBA dose-based acceptance criteria, Frequency-consequence curves.

Source: Dickson, E., NRC, internal memorandum to K. Hsueh, “Method for a Graded Risk-Informed Performance-Based Control Room Design Criteria Framework,” Washington, DC, July 2024 (ML24212A254).c

Ability to Provide Reasonable Regulatory Relief – Risk-informed and performance-based Rulemaking

DG-1425 (RG 1.183 Rev. 2) Graded, Risk-informed and Performance-based Framework

Risk-Metric Range: Regulatory Guide 1.174 CDF Criteria within five-bins.

Criteria Range: 10 to 25 rem TEDE.

Like similar licensing actions, approved higher licensing basis criteria is a “snapshot” in time until the licensee needs approval for an amendment (e.g. 50.59 criteria).

Addressing framework defense-in-depth, safety margin, and uncertainty through license submittals.

Table 8. Guidelines for Control Room Location Based on a Graded, Risk-Informed, and Performance-Based Framework

Overall CDF	Graded Control Room Design Criteria (rem-TEDE)
$CDF \leq 1.E-5$	25
$1E-5 < CDF \leq 5E-5$	20
$5E-5 < CDF \leq 1E-4$	15
$CDF > 1E-4$; or licensee not adopting the graded framework to determine acceptance criteria	10

Reference: DG-1425, Table 8




Figure representing DG-1425, Table 8 Graded, Risk-Informed and Performance-Based Framework

Using risk-information as a sliding scale to identify a higher control room design criterion.

Recap: Approach for Rulemaking for the Control Room Design Criteria



Policy and Regulation

Flexibility within
Commission Policy

Radiation Protection and
Emergency Response
Framework



Evidence-based justifications

Scientific
Recommendations

Radiation protection and
radiation epidemiology



Ability to Provide Reasonable Regulatory Relief

Reduce regulatory burden
while maintaining safety and
compliance



Risk-informed and
performance-based
Rulemaking

Closing

- The NRC recognizes the challenges that licensees face to retain margin within their licensing bases for the purposes of operational flexibility and the small amount of margin to the control room design criteria itself.
- The key driver behind the proposal to amend the control room design criteria is to facilitate increased regulatory efficiency and consistency while continuing to provide adequate protection of public health and safety.
- Proposed rule and supporting regulatory guidance executes Commission SRM-SECY-98-144 defines the terms and Commission expectations for risk-informed and performance-based regulation.
- This rulemaking effort would also support increased consistency within the Commission's comprehensive radiation protection and emergency planning frameworks.
- Consistency among these regulations, 10 CFR 50.67 and GDC 19 would provide operational flexibilities to further limit actual occupational exposures while also realigning the numerical value as a design criterion with a potential reactor accident of exceedingly low probability.

Backup Slides

Policy and Regulation – Radiation Protection and Emergency Response Framework (Cont.)



Class 9 Accidents


NRC Assessments of Severe Accident Risk

- 10 CFR Part 51, *Environmental Protection Regulations for Domestic Licensing and Regulatory Functions*, implement the National Environmental Policy Act (NEPA).
 - Consideration of the costs and benefits of severe accident mitigation/design alternatives and the bases for not incorporating severe accident mitigation design alternatives.
- 10 CFR Part 54, *Requirements for Renewal of Operating Licenses for Nuclear Power Plants*, requires an application to include a supplement to the environmental report that complies with the requirements of Subpart A of 10 CFR Part 51.

Severe Accident Events of Western Designs

- Three Mile Island
 - Maximum whole body dose received by an actual individual during the TMI accident in March 1979, which involved major core damage, was estimated to be about 0.1 rem. (61 FR 65159; December 11, 1996)
- Fukushima Daiichi
 - Maximum effective dose was 67.9 rem, six received effective doses greater than 25 rem, and 168 workers between 10 to 25 rem. (UNSCEAR, 2021)
 - Internal contamination was attributed to the severe working conditions and the inadequate implementation of protective measures (e.g. improper use of respiratory protection, iodine thyroid blocking measures, actions that resulted in inadvertent ingestion of radionuclides), due primarily to the lack, or ineffectiveness, of training. (IAEA, 2014)

Accident Sequence Precursor Program



Source: U.S. Nuclear Regulatory Commission Accident Sequence Precursor Program Summary Description, Appendix B: Historical Precursor Occurrence Rates (ML24177A020)