



**James D. Blankenship**  
Site Vice President  
R.E. Ginna Nuclear Power Plant  
1503 Lake Rd.  
Ontario, NY 14519  
315-791-5205 Office  
james.blankenship@constellation.com  
www.constellation.com

January 13, 2025

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

R.E. Ginna Nuclear Power Plant  
Renewed Facility Operating License No. DPR-18  
NRC Docket No. 50-244

Subject: Transmittal of 2024 Owner's Activity Report for the R. E. Ginna Nuclear Power Plant

Enclosed is a copy of the R. E. Ginna Nuclear Power Plant Owner's Activity Report for the refueling outage conducted in 2024. This report is submitted as specified by ASME Code Section XI.

There are no regulatory commitments contained in this letter.

If you have any questions, please contact Claire Schmittinger at (315) 791-3203.

Respectfully,

A handwritten signature in black ink, consisting of several overlapping loops and curves, representing the name James D. Blankenship.

James D. Blankenship

Attachment 1: SIXTH INSERVICE INSPECTION (ISI) INTERVAL and THIRD CONTAINMENT INSPECTION INTERVAL (CISI), SECOND INSPECTION PERIOD (ISI AND CISI); 2024 OWNER'S ACTIVITY REPORT for RFO-45 INSERVICE EXAMINATIONS (October 1, 2024, through October 15, 2024)

cc: NRC Regional Administrator, Region 1  
NRC Project Manager, Ginna  
NRC Resident Inspector, Ginna

ATTACHMENT 1

---

SIXTH INSERVICE INSPECTION (ISI) INTERVAL  
AND  
THIRD CONTAINMENT INSPECTION INTERVAL (CISI),  
SECOND INSPECTION PERIOD (ISI AND CISI)

2024 OWNER'S ACTIVITY REPORT  
FOR  
RFO-45 INSERVICE EXAMINATIONS  
(October 1, 2024, through October 15, 2024)

---

**FORM OAR-1  
OWNER'S ACTIVITY REPORT**

Report Number: G1R45

Plant R.E. Ginna Nuclear Power Plant, 1503 Lake Road, Ontario, New York 14159  
(Name and Address of Plant)

Unit No. 1 Commercial service date June 1, 1970 Refueling outage no. G1R45

Applicable inspection interval Sixth Inspection Interval (ISI) & Third Inspection Interval (CISI)  
(1st, 2nd, 3rd, 4th, Other)

Applicable inspection period Second Inspection Period (ISI & Containment ISI)  
(1st, 2nd, 3rd)

Edition and Addenda of Section XI applicable to the inspection plans ASME Section XI 2013 Edition

Date and revision of inspection plans ER-GI-330-1001, Rev. 1(8/18/2021), Rev. 2 (9/23/2024)

Edition and Addenda of Section XI applicable to repair/replacement activities, if different than the inspection plans  
Same as above

Code Cases used for inspection and evaluation: N-716-1, N-722-1, N-729-6, N-731, N-864  
(if applicable)

Remarks None

**CERTIFICATE OF CONFORMANCE**

I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion of G1R45 conform to the requirements of the ASME Section XI.  
(refueling outage number)

Signed Daniel Moreno, Daniel E. Moreno, ISI Engineer Date 01/09/2025  
(Owner's Designee)

**CERTIFICATE OF INSERVICE INSPECTION**

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by The Hartford Steam Boiler Inspection and Insurance Company of Hartford, CT have inspected the items described in this Owner's Activity Report and state that, to the best of my knowledge and belief, the Owner has performed all activities represented by this report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair/replacement activities and evaluations described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions ANIR 17483 NY 5742  
(Inspector's Signature) (National Board Number and Endorsement)

Date 1/9/2025

**TABLE 1**  
**ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE**

Examination Category and Item Number	Item and Flaw or Relevant Condition Description	EVALUATION DESCRIPTION
B-P / B15.10	Dry Boric Acid Residue found on AOV-427 (Reference IR 04809085). No evidence of substrate materials wastage (Ref. E-Health 04809085).	Accepted by evaluation (Issue Report: 04809085)

**TABLE 2**  
**ABSTRACT OF REPAIR/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE**

CODE CLASS	ITEM DESCRIPTION	DESCRIPTION OF WORK	DATE COMPLETED	REPAIR/REPLACEMENT PLAN NUMBER
N/A	N/A	N/A	N/A	N/A