



# **SMR-300**

# **Accident Radiological Consequences**

# **Methodology**

February 18, 2025

**Presented by: Devshibhai Ziyad and  
Hovhannes Hovhannisyan**

**SMR, LLC, A Holtec International Company  
Krishna P. Singh Technology Campus  
One Holtec Boulevard  
Camden, NJ 08104, USA**

**[Not Export Controlled]**

# Meeting Agenda

- Purpose of Meeting
- Topical Report Scope & Applicable Regulatory Guidance
- SMR-300 Design Overview

# Purpose

- To provide an overview of the methodology for assessing radiological consequences of SMR-300 design basis accidents. The methodology will be used to:
  - ✓ Calculate radiation doses for EAB and LPZ boundary determination
  - ✓ Calculate radiation doses to the MCR and TSC
  - ✓ Meet the intent of 10 CFR 50.34(a)(1)(ii)(D) and 10 CFR 50.34(b)(11)
  
- The methodology is generalized and non-site-specific

# Topical Report Scope

- Seeking approval for overall methodology, which largely follows available Regulatory Guides, except for:
  - ✓ Use of **RG 1.183 R1 Assumption A-1.1** iodine chemical forms for pH > 6
  - ✓ Credit of partial flashing in steaming region of OTSG, inconsistent with **RG 1.183 R1 Assumption E-6.5**.
  - ✓ Use of sector-specific 95<sup>th</sup> percentile atmospheric dispersion coefficients for EAB and LPZ (based on **RG 1.194 R0**, inconsistent with **RG 1.249 R0**)
- Outside the scope of this topical report:
  - ✓ EPZ sizing methodology
  - ✓ Methodology to determine failed fuel fractions
  - ✓ Methodology for accident pH analysis

# Applicable Regulatory Guidance



- Regulatory Guides 1.183 R1, 1.194 R0, and 1.249 R0
  - ✓ Following unless otherwise noted and justified
- NUREG/CR-5950: Iodine Evolution and pH Control
  - ✓ Basis for iodine evolution for containment pH  $\geq 6$
- NUREG-0933 Issue 197: Iodine Spiking Phenomena
  - ✓ Basis for iodine release rate used to calculate design basis reactor coolant inventory
- NUREG/CR-6189: A Simplified Model of Aerosol Removal by Natural Processes in Reactor Containments
  - ✓ Acceptable natural aerosol deposition model (Powers Deposition Model); integrated into RADTRAD
- NUREG-0800, Section 6.2.6 R3: Containment Leakage System
  - ✓ Basis for minimum acceptable design containment leakage rate
- NUREG-0800, Section 6.5.2 R3, Containment Spray as a Fission Product Cleanup System
  - ✓ Basis for elemental iodine removal by natural wall deposition (SMR-300 does not have containment spray)



# SMR-300 Design Overview

## ■ Relevant Unique Features:


- ✓ Spent Fuel Pool inside containment
- ✓ Annular Reservoir surrounding above grade containment



# SMR-300 Design Overview

## ■ Relevant Unique Features:

- ✔ Once-Through Steam Generator





# Methodology



# Accident Duration

Receptor Location	Time Duration <sup>1</sup>	References
<b>Exclusion Area Boundary</b>	Worst 2 hours in 720 hours (30 days)	Table 7, Regulatory position 4.1.e, RG 1.183 R1
<b>Low Population Zone</b>	720 hours (30 days)	Table 7, Regulatory Position 4.1.f, RG 1.183 R1
<b>Main Control Room</b>	720 hours (30 days)	Table 7 note 2 of RG 1.183 R1
<b>Technical Support Center</b>	720 hours (30 days)	Table 7 note 2 of RG 1.183 R1


**Notes:**

1. SGTR, REA, REA-Secondary path release accident duration will be conservatively bounded by 30 days.

# Dose Acceptance Criteria

Accident	EAB and LPZ Dose Criteria (TEDE)	MCR and TSC Dose Criteria (TEDE)
MHA LOCA	25 rem	5 rem
DBA LOCA	25 rem	5 rem
<b>SGTR</b>		
Pre-Accident Spike	25 rem	5 rem
Concurrent Spike	2.5 rem	5 rem
<b>MSLB</b>		
Pre-Accident Spike	25 rem	5 rem
Concurrent Spike	2.5 rem	5 rem
Locked Rotor	2.5 rem	5 rem
<b>REA</b>		
Containment Release Path	6.3 rem	5 rem
Secondary Plant Release Path	6.3 rem	5 rem
FHA	6.3 rem	5 rem
Failure of Small Lines Carrying Primary Coolant outside Containment	6.3 rem	5 rem

# Analysis Flowchart: Inventory Calculations



1	Inventories (Core, Primary and Secondary Coolants)
2	Primary and Secondary Coolant Thermal-Hydraulic Conditions
3	Failed Fuel Fractions
4	Atmospheric Dispersion Factors
5	Containment, Plum and Filters Inventory
6	Inhalation and Ingestion Dose
7	Radiation Shine Dose

# Core Radionuclide Inventory

- **Regulatory Position 3.1 of RG 1.183 R1** followed for ‘at-instant’ core radionuclide inventory.
  - ✓ Activity values of radionuclides determined at the instant of the accident. The instant is chosen to be bounding for the accident type.
- Single assembly inventory is calculated based on:
  - ✓ Detailed geometry of the fuel assembly
  - ✓ Assembly Radial Power Factor (RPF)
  - ✓ Rated power with uncertainty
  - ✓ Assembly-average exposure
  - ✓ U-235 enrichment



# Coolant Inventory

## ■ Primary


- ✓ Principal mechanism is fission product leakage into the coolant, conservatively determined based on failed fuel fraction
  - No core damage – highest fuel defect level allowed during normal operation
  - Core damage – based on cladding failure and/or core melt

## ■ Secondary

- ✓ Principal mechanism is primary leakage to secondary side

# Source Terms: Accidents with Release from Containment

- LOCA
  - ✓ PWR release fractions from **Table 2** and timings from **Table 5 of RG 1.183 R1**
- REA Containment Release
  - ✓ All noble gases and half iodines and alkali metals assumed released from melted fuel in conformance with **Assumption H-1 of RG 1.183 R1**
- FHA
  - ✓ Only radionuclides in gap assumed released; gap release fractions from **Table 4 of RG 1.183 R1**
  - ✓ Instantaneous release timings conservatively assumed
- Chemical form fractions of iodine considered:
  - ✓ 95% cesium iodide
  - ✓ 4.85% elemental iodide
  - ✓ 0.15% organic iodide
- Although **Assumption A-1.1 of RG 1.183 R1** prescribes chemical forms for  $\text{pH} \geq 7$ , SMR-300 is designed to maintain  $\text{pH} \geq 6$ . **Figure 3.1 of NUREG/CR-5950** shows iodine evolution to elemental ( $\text{I}_2$ ) form is much less than 4.85% for  $\text{pH} = 6$ ; therefore, RG 1.183 R1 chemical form fractions are applicable to SMR-300 design.



Model calculations of fraction as  $\text{I}_2$  vs pH  
**Figure 3.1 of NUREG/CR 5950**

# Coolant Source Terms


## ■ Accidents with No Fuel Breach

- ✓ Only gap release considered given principal mechanism is quantity of fuel rods with defects; only noble gases, halogens and alkali metals isotopes considered. Release fractions from **Table 4 of RG 1.183 R1**.
- ✓ Instantaneous release conservatively assumed
- ✓ Chemical form fractions of iodines in conformance with **Assumptions E-5, F-5, and H-5 of RG 1.183 R1**

## ■ Accidents with Fuel Breach (REA with Secondary Plant Release Path)

- ✓ All noble gases and half iodines contained in the melted fraction are released to coolant in conformance with **Assumption H-1 of RG 1.183 R1**. This is in addition to gap release
- ✓ Instantaneous release conservatively assumed

# Analysis Flowchart: Radiological Transport



1	Inventories (Core, Primary and Secondary Coolants)
2	Primary and Secondary Coolant Thermal-Hydraulic Conditions
3	Failed Fuel Fractions
4	Atmospheric Dispersion Factors
5	Containment, Plum and Filters Inventory
6	Inhalation and Ingestion Dose
7	Radiation Shine Dose



# Radionuclide Transport: Spent Fuel Decontamination

- Filtered pathway modeled to simulate retention of radioactive material in spent fuel water column following FHA in conformance with **RG 1.183 R1 Appendix B**
  - ✓ Retention of noble gases is negligible (decontamination factor = 1)
  - ✓ Full retention of particulate radionuclides assumed (decontamination factor is infinite)
  - ✓ Retention of elemental isotopes occurs in two phases:
    - Phase 1 (0-2 hours) – decontamination factor conservatively calculated using Assumption B-2 of RG 1.183 R1.
      - SMR-300 SFP depth > 23 ft
    - Phase 2 (2 hours – 30 days) – no decontamination credited

# Radionuclide Transport: Natural Deposition

- Natural aerosol deposition credited for all accidents (including MHA LOCA) involving containment pathway releases in conformance with **Assumption A.2-2 of RG 1.183 R1**.
- Assumption A.2-2 of RG 1.183 R1 also allows credit to be taken for iodine removal due to iodine gas interaction with free surfaces inside containment. Removal coefficient determined using:

$$\lambda_d = \frac{K_{wA}}{V}$$

where,

$V$  = containment building free volume,  $m^3$

$A$  = wetted surface area,  $m^2$

$K_w = 4.9 \text{ m/hr}$  (NUREG-800, Section 6.5.2 R3)

# Radionuclide Transport: Secondary Path Release

- Three sources of radioactive material release to environment considered:
  - ✓ Primary-to-secondary normal leakage (all accidents involving secondary path release)
    - Assumed as Limiting Condition of Operation (LCO) provided in SMR-300 Technical Specifications (TS)
    - Assumed release direct to environment without mitigation or retention
  - ✓ Primary-secondary break flow due to SGTR (SGTR accident only)
  - ✓ Steaming of steam generator bulk water (all accidents involving secondary path release)

# Radionuclide Transport: Secondary Path Release (Cont.)

- HRELAP5 analysis used to determine:
  - ✓ SGTR break flow in steaming region
    - Only flashed portion assumed to leak to environment
    - Flashing fraction (deviates from intent of Assumption E.6-5 of RG 1.183 R1 given SMR-300 has OTSG):
 
$$\alpha = \frac{H_{RCS}^L - H_{SG}^L}{H_{SG}^V - H_{SG}^L}$$
  - ✓ Steam generator steaming rate
- Radioactivity in secondary water and non-flashed primary coolant is assumed to become vapor at a rate that is a function of steam rate and the partition coefficient (assumed 100)
- No credit taken for scrubbing in OTSG
- Credit applied for the decay of radionuclides, including the formation of decay daughters, until release to the environment




# Radiological Transport: Control Room Habitability

- Operation action not credited in SAR Chapter 15 (i.e., operators serve no safety-related function)
  - ✓ SMR-300 control room habitability is not a safety-related function
- SMR-300 control room habitability provided by two non-safety systems
  - ✓ Control Room Ventilation (CRV)
    - Normal HVAC to control room exclusion zone (CREZ); upon reaching high radiation set point, isolates normal air intake, routes air through filtration unit, and activates recirculation
  - ✓ Breathing Air and Pressurization (BAP) system
    - Isolates outside air and CREZ upon reaching very high radiation set point. CRV isolated, BAP provides emergency air for 72 hours
  - ✓ Both CRV and BAP maintain positive pressure in CREZ

# Accident Specific Assumptions

- MHA LOCA<sup>1</sup>
  - ✓ Full core melt postulated as result of a LOCA
- FHA
  - ✓ Release to environment assumed through open airlock
- Locked Rotor/REA Containment Release
  - ✓ Extent of fuel damage due to cladding breach and fuel melt will be determined by methodology to determine failed fuel fractions
- SGTR/MSLB/REA Secondary Plant Release
  - ✓ During normal operations, primary coolant leaks/ashes in secondary side at allowable LCO rate
  - ✓ Activity in the primary coolant escaping to the secondary side is assumed to immediately be airborne due to flashing and atomization; released without mitigation
- <sup>1</sup> Separate, less conservative MHA assumptions are being considered for use in EPZ sizing methodology, which is outside the scope of this topical report

# Analysis Flowchart: Atmospheric Dispersion



1	Inventories (Core, Primary and Secondary Coolants)
2	Primary and Secondary Coolant Thermal-Hydraulic Conditions
3	Failed Fuel Fractions
4	Atmospheric Dispersion Factors
5	Containment, Plum and Filters Inventory
6	Inhalation and Ingestion Dose
7	Radiation Shine Dose


# Atmospheric Dispersion

- No credit taken for depletion of radioactive materials in plume caused by decay or ground deposition
- **Regulatory Position 5.3 of RG 1.183 R1** identifies use of **RG 1.194 R0**, **RG 1.145 R1** and **RG 1.249 R0** for atmospheric dispersion factor calculations
  - ✓ SMR-300 radiological consequence methodology utilizes ARCON 2.0 to determine site-specific 95<sup>th</sup> percentile atmospheric dispersion coefficients for all dose calculations (consistent with **RG 1.194 R0**, inconsistent with **RG 1.249 R0**)
    - SMR-300 anticipates all potential future sites will have onsite EAB and LPZ
    - Quantification of plume dispersion will rely on site-specific meteorological data for atmospheric dispersion analysis




# Atmospheric Dispersion: Source-to-Receptor Distances and Directions

- Distances and directions between source buildings and receptor points at EAB and LPZ are evaluated across 16 directional sectors (22.5° each) using 90° directional wind windows to determine 95<sup>th</sup> percentile atmospheric dispersion values.
  - ✓ Largest atmospheric dispersion factors among those for source-receptor combinations used in conformance with **Regulatory Position 2 of RG 1.194, Revision 0.**
  - ✓ MCR and TSC are known locations allowing for direct determination of source-receptor distance and direction



Example of the closest point of a building within each of the 16 directional sectors from the release points to the EAB/LPZ boundaries , in 45-degree windows

# Analysis Flowchart: Radiation Transport



1	Inventories (Core, Primary and Secondary Coolants)
2	Primary and Secondary Coolant Thermal-Hydraulic Conditions
3	Failed Fuel Fractions
4	Atmospheric Dispersion Factors
5	Containment, Plum and Filters Inventory
6	Inhalation and Ingestion Dose
7	Radiation Shine Dose

# Radiation Transport

- MCNP used to calculate radiation shine dose using RADTRAD provided radionuclide concentrations for:
  - ✓ External radioactive plume released from facility
  - ✓ Radioactive material in systems and components inside or external to control room (e.g., radioactive material buildup in filters)
  - ✓ Radioactive material in containment
- Bounding scenario with highest activity from each source used

# Summary

- Methodology largely follows **RG 1.183 R1**
- Key unique features:
  - ✓ Use of **RG 1.183 R1** iodine chemical form fractions, justified based on NUREG/CR-5950 and bounding SMR-300 accident pH
  - ✓ Credit of partial flashing in steaming region OTSG
  - ✓ Use of sector-specific 95<sup>th</sup> percentile atmospheric dispersion coefficients for all accident dose analysis, justified based on onsite SMR-300 EAB and LPZ
- Not included in this methodology (to be covered in separate licensing actions):
  - ✓ Methodology to determine failed fuel fractions
  - ✓ Methodology for post-accident pH analysis
  - ✓ MHA LOCA assumptions to be used in EPZ sizing methodology



# Open Session

