

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Regulatory Rulemaking, Policies and Practices

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, January 14, 2025

Work Order No.: NRC-0182

Pages 1-141

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
+ + + + +
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)
+ + + + +
REGULATORY RULEMAKING, POLICIES AND PRACTICES
SUBCOMMITTEE

+ + + + +
TUESDAY
JANUARY 14, 2025
+ + + + +
The Subcommittee met via
Video/Teleconference, at 8:30 a.m. EST, David A.
Petti, Chairman, presiding.

SUBCOMMITTEE MEMBERS:

DAVID A. PETTI, Chairman
RONALD G. BALLINGER, Member
VICKI M. BIER, Member
VESNA B. DIMITRIJEVIC, Member
CRAIG D. HARRINGTON, Member
GREGORY H. HALNON, Member
WALTER L. KIRCHNER, Member
ROBERT P. MARTIN, Member
SCOTT P. PALMTAG, Member

1 THOMAS E. ROBERTS, Member

2 MATTHEW W. SUNSERI, Member

3

4 ACRS CONSULTANTS:

5 DENNIS C. BLEY

6 STEPHEN P. SCHULTZ

7

8 DESIGNATED FEDERAL OFFICIAL:

9 DEREK A. WIDMAYER

10

11 ALSO PRESENT:

12 LARRY J. BURKHART, ACRS/TSB

13 ANDERS F. GILBERTSON, NRR/DANU/UARP

14 WILLIAM D. RECKLEY, NRR/DANU/UARP

15 JESSE L. SEYMOUR, NRR/DRO/IOLB

16 NANETTE V. VALLIERE, NRR/DANU/UARP

17 MICHAEL J. WENTZ, NRR/DANU

18

19

20

21

22

23

24

25

CONTENTS

Opening Remarks, Dave Petti, ACRS	4
Staff Introduction, Mike Wentzel, NRR	8
Update on 10 CFR Part 53, "Risk-Informed, Technology-Inclusive Regulatory Framework for Commercial Nuclear Plants," Anders Gilbertson, NRR; Bill Reckley, NRR; and Jesse Seymour, NRR	10
Subcommittee Discussion, David Petti, ACRS	
Adjourn	

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

MEMBER HALNON: Okay, it's 8:30. The chairman for the subcommittee is online, Dave Petti.

CHAIRMAN PETTI: Thank you, Greg. The meeting will now come to order. This is a meeting of the Regulatory Rulemaking, Policies and Practices Subcommittee of the Advisory Committee on Reactor Safeguards.

I'm David Petti, chair of today's subcommittee meeting. ACRS members in attendance in person are Ron Ballinger, Greg Halnon, Craig Harrington, Robert Martin, Scott Palmtag, and Tom Roberts. The ACRS members in attendance virtually via Teams are Vesna Dimitrijevic, Matt Sunseri, Vicki Bier, Walt Kirchner, and myself.

We have two of our consultants participating, Dennis Bley remotely, and Steve Schultz in person.

If I've missed anyone, either ACRS members or consultants, please speak up now.

MEMBER HALNON: Hey, Dave, at this point, sorry, we don't have Dennis on just yet.

CHAIRMAN PETTI: Oh, okay.

MEMBER HALNON: That's the only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 correction.

2 CHAIRMAN PETTI: Thanks. Derek Widmayer
3 of the ACRS staff is the Designated Federal Officer
4 for this meeting. No member conflicts of interest
5 were identified for today's meeting. We have a quorum
6 for today's meeting.

7 During the meeting today, the subcommittee
8 will receive a briefing on updates made to 10 CFR Part
9 53 entitled Risk Informed Technology Inclusive
10 Regulatory Framework for Commercial Nuclear Plants.
11 The updates were mandated by the Commission following
12 its review of the proposed rule. The ACRS is
13 statutorily required to review all safety-related
14 regulations developed by the staff and this is the
15 most significant addition to nuclear safety rules done
16 by the staff in many years. The ACRS has held 17
17 subcommittee and full committee meetings with the
18 staff as they developed the rule language that went to
19 the Commission for its review. And this meeting is
20 intended to familiarize the committee on the revisions
21 made to the rule language as a result of the
22 Commission's review. The committee does not plan on
23 writing a letter report after this update.

24 The ACRS was established by statute and is
25 governed by the Federal Advisory Committee Act, or

1 FACA. The NRC implements FACA in accordance with its
2 regulations. Per these regulations and the
3 committee's bylaws, the ACRS speaks only through its
4 published letter reports. All member comments should
5 be regarded as only the individual opinion of that
6 member and not a committee position.

7 All relevant information related to ACRS
8 activities such as letters, rules for meeting
9 participation, and transcripts are located on the NRC
10 public website and can easily be found by typing About
11 Us ACRS in the search field on NRC's home page.

12 The ACRS, consistent with the agency's
13 value of public transparency and regulation of nuclear
14 facilities provides opportunity for public input and
15 comment during our proceedings. We have received no
16 written statements or requests to make an oral
17 statement from the public. And we have also set aside
18 time at the end of the meeting for public comments.

19 The ACRS will gather information, analyze
20 relevant issues and facts, and formulate proposed
21 conclusions and recommendations, as appropriate, for
22 deliberation by the full committee.

23 A transcript of the meeting is being kept
24 and will be posted on our website.

25 When addressing the subcommittee, the

1 participants should first identify themselves and
2 speak with sufficient clarity and volume so that they
3 may be readily heard. When you are not speaking,
4 please mute your computer on Teams or by pressing *6
5 if you are on the phone. Please do not use the Teams
6 chat feature to conduct sidebar discussions related to
7 the presentations. Rather, limit use of the meeting
8 chat function to report IT problems.

9 For everyone in the room, please put all
10 your electronic devices on the silent mode and mute
11 your laptop microphone and speakers. In addition,
12 please keep sidebar discussions in the room to a
13 minimum since the ceiling microphones are live.

14 For the presenters, the table microphones
15 are unidirectional and you will need to speak into the
16 front of the microphone to be heard.

17 Finally, if you have any feedback for the
18 ACRS about today's meeting, we encourage you to fill
19 out the public meeting feedback form on the NRC's
20 website.

21 We'll now proceed with the meeting and
22 I'll call on Mike Wentzel from the Office of NRR for
23 Opening remarks.

24 MEMBER HALNON: Hey, Dave, just real
25 quick. This is Greg. Dennis has joined us, we're

1 still waiting on Matt Sunseri so those are the two
2 corrections to the attendance. And just remind
3 everybody, the court reporter needs to know your name
4 so if you're talking and want to make a comment,
5 please start with your name. Good ahead.

6 MR. WENTZEL: Good morning. My name is
7 Mike Wentzel. I'm Chief of the Advanced Reactor
8 Policy Branch in the Division of Advanced Reactors and
9 Nonpower Production and Utilization Facilities in the
10 Office of Nuclear Reactor Regulation.

11 MEMBER HALNON: Mike, you need to speak
12 up. Get a little bit closer. There you go. That's
13 good. Thank you.

14 MR. WENTZEL: So as was mentioned, we're
15 here today to continue the staff's discussion with the
16 committee on the rulemaking for a Risk Informed,
17 Technology Inclusive Regulatory Framework for Advanced
18 Reactors, better known as Part 53. As a reminder,
19 this rule was developed in response to the Nuclear
20 Energy Innovation and Modernization Act and provides
21 an alternative framework for licensing inter-
22 commercial nuclear plants that is technology
23 inclusive, uses risk-informed and performance-based
24 techniques, provides an equivalent level of safety to
25 that of operating commercial and nuclear plants and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 provides flexibility for licensing and regulating
2 (audio interference) of technologies and design.

3 Our last meeting with the committee was in
4 the fall of 2022 and significant milestones have been
5 achieved since then. This includes the Commission's
6 approval of the proposed rule with revisions for
7 publication last March and publication of the proposed
8 rule for public comment last October.

9 The initial 60-day public comment period
10 was extended to February 28th based on several
11 requests for stakeholders. The staff has held two
12 public meetings since publication of the proposed
13 rule. The first was in November in last year and the
14 second one was just last week.

15 The purpose of today's informational
16 briefing is for the staff to provide an overview of
17 the changes that were made to the draft proposed rule
18 as a result of the direction from the Commission. We
19 will also provide some background material and discuss
20 key provisions of the proposed rule as a refresher and
21 potential aid to newer members of the committee.

22 And finally, we intend to discuss a draft
23 white paper on potential revisions for testing of fuel
24 manufactured reactors in the manufacturing facility.
25 This draft white paper was publicly released last

1 month and discussed with stakeholders during their
2 public meeting last week in response to direction from
3 the Commission.

4 Because the public comment period does not
5 close for another six weeks, the staff will not be
6 discussing any public comments received to date, nor
7 can we discuss the staff's thoughts about potential
8 changes to the final rule at this time. We will work
9 with the ACRS staff to schedule future interactions
10 with the committee between the close of the comment
11 period and the delivery of the draft final rule to the
12 Commission currently scheduled for no later than May
13 1st, 2026. And as a continued reminder, we do
14 appreciate the past interactions with the committee on
15 this important rule making and we're really looking
16 forward to the discussions today and your reactions to
17 the report. Thank you very much.

18 MEMBER HALNON: Okay, so go ahead, Anders.

19 MR. GILBERTSON: Thank you, good morning,
20 everyone. My name is Anders Gilbertson. I'm the
21 senior project manager in the Office of Nuclear
22 Reactor Regulation. I'm one of the technical leads
23 for the key NRC staff.

24 Today, a lot of the opening remarks here
25 have already addressed some of the points on the first

1 few slides, so you can go to the next slide, please,
2 Slide 2.

3 Today, I'll be presenting with Bill
4 Reckley and Jesse Seymour will be touching on
5 different parts of the rules here (audio
6 interference). I will be going through the majority
7 of the first portion of the presentation and then I'll
8 call on Jesse and then I'll close things out.

9 Next slide, please.

10 Okay, and so this is just a reference
11 slide to provide some hyperlinks to the proposed Part
12 53 rule published on October 31st of 2024 and the
13 various places it can be accessed, as well as
14 associated documents, guidance documents and such. The
15 explanation of what those documents are can be found
16 in Section 19 of the FRN under the Availability of
17 Documents. And then the white paper that Bill will be
18 touching on, Bill Reckley will be touching on later,
19 that can be sourced through the ADAMS accession
20 number.

21 And of course, just to reiterate that the
22 past ACRS interactions have been very informative and
23 instrumental to the formation and development of the
24 proposed Part 53 rule. So we greatly appreciate those
25 interactions.

1 Next slide, please.

2 And again, another sort of set of
3 references, just the SECY paper that was delivered to
4 the Commission March 1st that provided the draft
5 proposed rule and then the SRM that was approved and
6 the proposed rule with exceptions and clarifications.
7 And of course, we'll be talking about that relative to
8 direction that was given to the staff and the SRM and
9 the differences between the draft proposed rule and
10 the published proposed rule.

11 Next slide, please. Slide 5.

12 Okay, and so again, this is just to
13 reiterate the sort of timing that we're talking about
14 here, so the public comment period closes at the end
15 of February. We'll look forward to our subsequent
16 ACRS interactions between the end of that period and
17 when we start our internal concurrence May 2026. May
18 1st is when we'll be sending the schedule to send the
19 rule, the draft final rule to the Commission, and then
20 of course, the NEIMA deadline is the end of December
21 2027.

22 Next slide please. Slide 6.

23 Okay, so I'll get into a little bit of
24 background here just to set the stage where we are.
25 So this diagram is just provided to help illustrate

1 that there have been numerous activities that the NRC
2 has undertaken to address involving stakeholder needs
3 and prepare for licensing and oversight of advanced
4 reactors.

5 As was previously mentioned, the Part 53
6 rulemaking was directed by Congress through the
7 Nuclear Energy Innovation and Modernization Act and
8 the foundations of the proposed rule are built on
9 Commission rules, policies, and decisions on risk-
10 informed and performance-based regulations, as well as
11 lessons learned from experience with the Part 50 and
12 Part 52 regulatory frameworks. And the Part 53
13 proposed rule regulatory framework directly
14 incorporates the use of risk analyses to inform
15 identification of licensing-basis events and safety
16 classification of plant equipment and it leverages
17 performed-based approaches to enhance aspects such as
18 staffing flexibility and achieving adequate defense in
19 depth. So in that regard, the Part 53 proposed
20 regulatory framework would call for designers and
21 operators to enhance flexibility while allowing
22 different proposed approaches to satisfying high level
23 safety criteria versus meeting more prescriptive
24 requirements under the Parts 50 and 52 regulatory
25 frameworks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Slide 7, please.

2 To give a relatively brief, high-level
3 overview of the Part 53 draft proposed rule, it
4 consisted of two independent frameworks that were
5 referred to as Framework A and Framework B. So
6 broadly speaking, Framework A was developed to support
7 a top-down approach for developing a safety case where
8 an applicant would meet high level safety criteria by
9 performing analyses to define necessary safety
10 functions which, in turn, are fulfilled by design
11 features that lead to specified functional design
12 criteria identified in the analysis. So this
13 framework would feature probabilistic risk assessment,
14 or PRA, a key analysis tool for systematically
15 analyzing the risk of design for normal operations.

16 Framework B was developed to support the
17 bottom-up approach for developing the safety case. It
18 was based on adapting established design criteria,
19 design rules, and deterministic analyses approaches to
20 accommodate a wider range of reactor technologies.
21 And Framework B would have provided for more
22 traditional confirmatory uses of risk insights from
23 PRA or an alternative evaluation of risk insights
24 approach which has commonly been referred to as AERI.

25 MEMBER HALNON: Dave just raised his hand.

1 MR. GILBERTSON: Yes.

2 CHAIRMAN PETTI: Anders, just a question
3 of AERI. You know in our letters we're big fans of
4 that approach, particularly for potentially for
5 microreactors. Given that it still exists as a draft
6 Reg. Guide, but it doesn't sound like there's plans to
7 turn it into a Reg. Guide, what status does that mean
8 for a licensee that might want to use it? Does it
9 always stay draft forever if it never gets evolved?
10 Is there a time line that it just evaporates or
11 something? How does that work?

12 MR. GILBERTSON: So as I understand it,
13 when the staff published draft guidance, my
14 understanding that doesn't get withdrawn from the
15 public domain. It exists even if it's not formally
16 converted to a final regulatory guide. So I suppose,
17 in principle, that could be taken, it could be adapted
18 perhaps, understanding that, of course, it's very
19 specific to what was formally referred to as Framework
20 B and the requirements that had been proposed therein.

21 CHAIRMAN PETTI: Okay. Thanks.

22 MS. VALLIERE: Excuse me. This is Nan
23 Valliere on the Advanced Reactor Policy Branch. And
24 I just wanted to add a couple thoughts on this
25 response to the next question. So the first is that

1 recall, all of you were here, recall the Commission
2 directed us to remove Framework B from the rule which
3 is where AERI was cited in the draft final rule.
4 However, they also directed the staff to go forward
5 with an options paper on how to implement a Framework
6 B approach going forward and they specifically
7 directed the staff to include AERI in all of the
8 options. So it is not -- not quite that yet I guess
9 I would say.

10 (Laughter.)

11 The second point I wanted to make is that
12 it is the AERI guidance document, because it was
13 removed from the proposed rule, that draft guide was
14 not published for public comment with this rule. So
15 it has never even gone out as a draft guide. I just
16 wanted to provide that for everyone.

17 MEMBER HALNON: This is Greg. We did see
18 it as a draft guide though from an ACRS perspective,
19 so it's in the public domain.

20 Dennis?

21 DR. BLEY: Yes. Nan, what's the status of
22 that paper you said you were doing -- to put together?

23 MS. VALLIERE: Yes, it is due to the
24 Commission in March and we are actually having a
25 public meeting on it later this week. So it's due

1 shortly.

2 DR. BLEY: Okay. Will you be bringing
3 that to the committee?

4 MS. VALLIERE: Not at the options stage,
5 but I think once the Commission directs us which
6 option to go forward with, I think that would probably
7 be more the likely time that we would engage with the
8 committee.

9 DR. BLEY: Okay, thanks.

10 MEMBER MARTIN: This is Bob Martin.
11 Continuing on this theme option, is that potential
12 evolution of Part 53 or maybe in the 52-50 realm?

13 MS. VALLIERE: Yes, so the options that
14 the Commission discussed basically were added to Part
15 50, create a new part, or create a very high-level
16 rule, but most of what had been in the original
17 framework into guidance.

18 MEMBER HALNON: Go ahead, Anders.

19 MR. GILBERTSON: All right, thanks. Okay,
20 so -- again, this Anders Gilbertson. So Framework B,
21 just to finish off this slide, it also included
22 requirements to develop and use principal design
23 criteria similar to the general design criteria and
24 Appendix A to Part 50 and would have provided for
25 technology-inclusive approaches to meeting existing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 requirements developed for all 50 parts. So just to
2 cap that off and of course, we have emphasized that
3 there will be a subsequent meeting later this week,
4 public meeting on that options paper.

5 Slide 8, please.

6 Okay, so we want to start to get into the
7 SRM direction. The Commission included a total of 15
8 items shown here from the staff to address in the Part
9 53 proposed rule before its publication comment. In
10 the interest of time, what we are planning to do is
11 really just focus on the key items from the SRM that
12 were more complex to address, required a little more
13 depth of thought and are highlighted here on the list,
14 items 1 through 4 and 8.

15 And like Mike had mentioned earlier, this
16 will be set in the context of a broader presentation
17 of all of the subparts of the rule at a very high
18 level. Again, this is mostly just to express and
19 communicate what the updates are to the proposed rule.
20 So we'll touch on a few of these other SRM items, but
21 many of them were very straight forward to simply just
22 making the more clerical changes involved.

23 On subsequent slides, we have some purple-
24 colored boxes at the bottom just to help orient you to
25 what some of those key changes are based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 implementation of the SRM and to help provide a
2 general roadmap of those key changes.

3 Slide 9, please.

4 Okay, so this table just shows the general
5 organization of the Part 53 proposed rule relative to
6 the subparts of the rule text, going into a little
7 more detail on the next slide. A couple of the key
8 SRM items to note on this slide straight away are that
9 consistent with the first SRM item, the collection of
10 requirements referred to as Framework B were removed
11 entirely from the proposed rule and other rulemaking
12 documents as we just touched on. And then consistent
13 with the SRM item number ten, the draft proposed
14 requirements in subpart K related to quality control
15 were also removed and replaced with references to the
16 existing quality assurance requirements under Appendix
17 B to 10 CFR Part 50. So that's why subpart K is not
18 shown on this list. And again, both of these were --
19 they're fairly impactful to the rule. They will go
20 straight forward to implement.

21 Slide 10, please.

22 Okay, so this slide goes into a little
23 more detail on the structure of the rule and this is
24 set in the context of the overall project life cycle
25 as it would generally be sequenced through the process

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of licensing at a facility. This writing on the upper
2 left, that's subpart B would provide the high-level
3 technology, includes the safety criteria. Those would
4 serve as foundational performance standards for the
5 subsequent performance-based requirements in the other
6 subparts. And those other subparts would address how
7 specific activities during various stages of the
8 facility life cycle would contribute to satisfying the
9 high level performance standards.

10 Now the performance standards in subpart
11 B would also establish a means to determine
12 appropriate regulatory controls for SSCs, human
13 actions, and programs. And likewise, moving on to the
14 other portions of the diagram, subparts D, E, and F
15 would provide requirements related to consideration of
16 siting issues to construction and manufacturing and
17 operations, respectively. And of course, all as it
18 relates to meeting safety criteria that are defined in
19 subpart B.

20 Subpart G would provide requirements for
21 plant decommissioning activities and license
22 termination and subparts H and I would provide
23 requirements for information related to license
24 certification approvals and the maintenance of
25 licensing basis information.

1 And then toward the bottom here, subpart
2 A would provide the general provisions of the proposed
3 rule, in particular, includes terms and definitions as
4 they would apply for the proposed Part 53.

5 Subpart J would provide administrative and
6 reporting requirements for the entire life cycle and
7 subpart M would provide enforcement requirements.

8 So it's important to keep in mind that the
9 Part 53 proposed rule incorporates various concepts
10 from the current regulatory frameworks and the
11 licensing modernization project methodology in a
12 technology-inclusive, cohesive, and efficient manner.
13 As such, the concepts that would be incorporated into
14 the Part 53 proposed rule were integrated across and
15 serve as foundations for why different aspects of the
16 regulatory framework develops the way they were and we
17 will point out many of these areas as we go through
18 this presentation.

19 All right, moving on to Slide 11, please.

20 Okay, so getting into -- from this point
21 forward, we'll be getting into the substance of the
22 rule and touching on some of the SRM items, some of
23 the more detailed ones.

24 So subpart A is general provisions for
25 Part 53. It would be applicable to all applicants and

1 licensees and these requirements would be largely
2 equivalent to the related general provisions under
3 Part 50. More specifically, for example, the proposed
4 Sections 53.40 through 53.120 are equivalent to their
5 related requirements under Part 50. And general
6 differences between the proposed Part 53 and Part 53
7 frameworks include framework-specific references to
8 other portions of the Part 53 regulations versus
9 references to Part 50 regulations, of course, as well
10 as the definitions that are specific to Part 53.

11 Slide 12.

12 DR. BLEY: Anders?

13 MR. GILBERTSON: Yes.

14 DR. BLEY: Dennis Bley. You said I think
15 40 through 120 were equivalent to those under 50. Are
16 they identical or just supposed to be equivalent?

17 MR. GILBERTSON: They are -- I believe
18 they are nearly identical. I know Bill Reckley could
19 certainly publicly say more specifically off the top
20 of his head, but I believe they're almost identical.

21 DR. BLEY: Okay, because if they're
22 identical that raises a question to the possibility of
23 confusion occurring if they're meant to be the same.
24 It's just a concern.

25 MR. GILBERTSON: Okay. Understood. Thank

1 you.

2 Slide 12, please.

3 Okay, so the matter of fostering clarity
4 and consistency regarding the use of defined terms.
5 Most of the definitions under the proposed 50.20 --
6 sorry, 53.20 would be equivalent to definitions of
7 corresponding terms defined under 10 CFR 50.2, 10 CFR
8 52.1, and other existing NRC regulations. Also, NEI
9 18-04, Provision 1, as that's endorsed by Reg. Guide
10 1.233, Revision 0. Of course, both of those are the
11 documents that relate to the licensing modernizing
12 project methodology and definitions corresponding to
13 those in the ASME/ANS consensus PRA standard for non-
14 light water reactors. That's designated as ASME/ANS
15 RA-S-1.4-2021, and of course, as that's endorsed in
16 Reg. Guide 1.247.

17 Okay, so next slide, Slide 13, please.

18 So that's the general summary of subpart
19 A. So getting into the technical requirements here,
20 subpart B would provide the technology inclusive
21 safety criteria that again would serve as the
22 performance standards for the subsequent performance-
23 based requirements used throughout Part 53.

24 As they talked about these proposed
25 requirements under subpart B, I'll also touch on some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of the foundational concepts that form the basis for
2 the proposed requirements on the next slide.

3 Slide 14, please.

4 MEMBER MARTIN: Wait.

5 MR. GILBERTSON: Yes.

6 MEMBER MARTIN: This is Bob Martin. In
7 the earlier drafts some critique public comment
8 related to expansion, potential expansion of ALARA.
9 Are you going to address the evolution of ALARA as
10 safety criteria in your presentation?

11 MR. GILBERTSON: Yes. Yes. That is one
12 of the items. Those are items that the Commission
13 directed the Staff, so I'll, yes, I'll be talking
14 about that in a few slides here.

15 Okay, Slide 14. Here we go. Okay, so
16 this figure, as you might be familiar, the central
17 portion of the figure comes directly from Regulatory
18 Guide 1.174. And this is to help provide a visual
19 representation of how the different portions of the
20 Part 53 proposed rule would relate to the principles
21 of integrated risk-informed decision making described
22 in Reg Guide 1.174. And that would be foundational to
23 NRC determinations of reasonable assurance of adequate
24 protection under the Part 53 proposed rule.

25 So although the principles in Reg 1.174

1 are framed in terms of risk-informed licensing basis
2 changes for an operating reactor, specifically a light
3 water reactor, those principles can readily be
4 generalized to any risk-informed decision making. And
5 they have in many different contents. So this is
6 natural that it was brought into Part 53.

7 And of course, the use of plant risk under
8 the Part 53 proposed rule would be one of several
9 performance measures used in the subpart B. The
10 proposed rule would also use multiple performance
11 standards related to deterministic criteria and
12 defense-in-depth measures.

13 So in that way NRC's approval of using a
14 comprehensive risk metrics, metric, or sets of metrics
15 with associated risk performance objectives would not
16 be, by itself, an indicator of adequate protection.
17 They would be one piece of a suite of regulatory
18 requirements that when consider holistically would
19 inform the basis for NRC decision.

20 And this approach is analogous to that
21 used for plants licensed under Part 50 and Part 52 in
22 that no single regulatory requirement governs whether
23 a facility is determined to be safe enough.

24 DR. SCHULTZ: Anders, this is Dave
25 Schultz.

1 MR. GILBERTSON: Yes.

2 DR. SCHULTZ: Is this the way in which the
3 Staff has responded to the Commission's concern about
4 allowing flexibility in PRA acceptability
5 determinations or is that, you're going to talk about
6 that later?

7 It seems like it might be associated with
8 this description?

9 MR. GILBERTSON: Yes, I will talk about
10 that later. I have a slide on that. We don't, let's
11 see. It's certainly related to these principles, but
12 of course because it is one of the principles, a risk-
13 informed, you know, consideration of risk insights and
14 such. So yes. I mean, I it did inform that in part
15 I would say.

16 DR. SCHULTZ: Okay. I guess what I'm
17 looking for too, you deleted Framework B, and then I
18 looked at Framework A and looked at the various
19 descriptions associated with PRA. And I was looking
20 for something that would in fact address the
21 Commissions concern here. And I didn't see changes
22 that reflected a movement toward addressing the
23 concern.

24 And perhaps there is other documentation
25 that's going to be utilized in terms of reg guides and

1 so forth. But within the rule itself I didn't see
2 changes that address the Commissions concern.

3 MR. GILBERTSON: So specifically are you,
4 you are referring to the general concern that risk,
5 consideration of risk insights is just one piece of
6 the overall decision making process?

7 DR. SCHULTZ: That's right.

8 MR. GILBERTSON: Okay. Okay. So --

9 DR. SCHULTZ: I really didn't see, I
10 looked at everything associated with PRA in Framework
11 A. I didn't see changes that affected the
12 Commission's concern. And perhaps -- that's why I
13 pointed it out here. You got a lot of different
14 features associated with guidance that might address
15 the concern but it's not within, directly stated
16 within the Framework A, as far as I could see.

17 MR. GILBERTSON: Right. So I guess maybe
18 what I would offer, and I'll also talk about it a
19 little bit more when I get to that point is, I guess
20 the more general characterization of the rule that
21 it's risk-informed versus risk-based, that's something
22 that we've tried to focus on and make sure that we're
23 staying true to that notion.

24 Risk-based would be very different. I
25 think a different framework. We would have written

1 requirements differently to address something where
2 you are making decisions purely based on these
3 insights. Purely based on what the probabilistic risk
4 assessment is telling you.

5 My personal view is that requires a much
6 higher degree of pedigree of the PRA and such to be
7 able to even entertain that kind of decision making.
8 So I think it's inherent in the rule in the way you've
9 written it.

10 That point, you know, it is more embodied
11 in the guidance, which I think is why, for example,
12 for SRM Item 3 we opted to adjust the preamble and not
13 the rule language. We thought it was more appropriate
14 to talk about what those existed processes were and
15 explaining more about what pure acceptability is as it
16 currently stands in the practice.

17 DR. SCHULTZ: Thank you.

18 MR. GILBERTSON: Okay. Okay, we can move
19 on to Slide 15. Okay, so going now to the safety
20 criteria themselves we'll start with the proposed
21 53.210. We don't have any highlights on here, any
22 purple boxes, so again, this is going to be one of
23 those areas where I'm going to talk about this at a
24 higher level just to help set the context and orient
25 us to what this framework is doing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So the Part 53 proposed rule would
2 maintain an important role for deterministic analyses
3 of design basis accidents in the performance of
4 criteria for the proposed 53.210 and the related
5 analytical requirements provided in proposed
6 53.450(f).

7 So starting with the proposed 53.210.
8 This would provide a DBA safety criteria analogous to
9 the DBA, requirements for DBAs under 10 CFR
10 50.34(a)(1)(ii)(d) as it relates to the 25 rem
11 reference value for a potential radiological
12 consequences and other similar requirements under Part
13 52 and Part 100.

14 And SSCs relied upon to demonstrate
15 compliance with the criteria in 53.210 would be
16 classified as safety related. And the use of safety
17 related SSCs, and the 25 rem reference values for
18 potential radiological consequences, would align with
19 traditional deterministic approaches for LWRs from
20 Parts 50.34, 52.79 and 100.11 for evaluating the
21 effectiveness of plant design features relative to
22 possibly the reactor absence.

23 MEMBER HALNON: Vicki Bier has a question.

24 MR. GILBERTSON: Go ahead.

25 MEMBER BIER: Thanks. In the traditional

1 regulatory approaches there was always this
2 contradiction, not contradiction but paradox maybe, of
3 things that were safety significant but not safety
4 related if they were in the secondary systems. And
5 would that not be the case with this new definition of
6 what's safety related?

7 MR. GILBERTSON: I guess I would say not
8 necessarily because of, yes, I'll get into this on the
9 next slide as well when we talk about the safety
10 criteria for licensing basis events other than the
11 DBAs. Because the analyses that supports meeting
12 those safety criteria includes a broad survey of the
13 spectrum of risks that a facility might be exposed to,
14 that provides, would provide much more information
15 than I think some of the more prescriptive sets of
16 assumptions under Parts 50 and 52.

17 So it's -- the definition of safety
18 related under Part 53, it stems largely from what your
19 -- what the design basis accidents are showing and
20 demonstrating that you can meet the safety criteria,
21 but it's also underpinned by those other analyses for
22 the licensing basis events other than design basis
23 accidents. So I'm not sure if I answered your
24 question, but.

25 MEMBER BIER: Well, I think it was

1 actually a pretty clear explanation of why something
2 might be safety related or not. You know, it sounds
3 like it won't eliminate the possibility of that
4 situation where something is safety significant for
5 non-design basis, beyond design basis events, but not
6 safety related.

7 So in a way it's kind of too bad that it
8 doesn't resolve that, but I think the explanation of
9 what it's doing is pretty clear. Thanks.

10 MR. GILBERTSON: Okay. Yes. And maybe I
11 would just offer to finish that thought. That the
12 underlying analysis using the PRA perhaps would offer
13 more confidence that for those items that are
14 designated as non-safety related but safety
15 significance, we would have a better understanding of
16 that, and confidence in those designations because
17 they're underpinned by, again, a systematic analysis
18 provided by the PRA.

19 MEMBER ROBERTS: Okay. Anders, this is Tom
20 Roberts. There were no AOOs in this scheme? Are AOOs
21 a subset of DBAs in this definition?

22 MR. GILBERTSON: AOOs would be a category
23 of licensing basis event. I'll actually get into
24 that, I think maybe in a couple of slides. I provide
25 the definition of what licensing basis events are.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And yes, that's one of the categories. Along with
2 DBAs -- and I'm forgetting off the top of my head the
3 other, but there are four, four categories. And we'll
4 touch on that on a later slide.

5 MEMBER ROBERTS: Okay. Maybe it's the
6 next slide it will come up. But other than DBAs, I've
7 confused maybe, because that would seem to include
8 both AOOs and beyond design basis events. It seems
9 odd to have a category that includes both of those.

10 MR. GILBERTSON: Yes. So, and we can talk
11 about that. You know, the designation of essentially,
12 you know, LBE being sort of a design basis accident,
13 or not a design basis accident, it really relates to
14 this dichotomy of the safety criteria, how they're
15 defined for DBAs and for, I'll say, non-DBAs just to
16 latch that down a little bit more.

17 But yes. So the AOOs wouldn't be a class
18 of DBAs. The AOOs, again, I'm forgetting the next --

19 PARTICIPANT: Unlikely event sequence.

20 MR. GILBERTSON: -- unlikely, yes,
21 unlikely event sequences and the very unlikely event
22 sequences. I'm sorry, we use different terms in Part
23 53 than we do for LMPs so I trip over that sometimes.

24 But those three categories are their own
25 categories. Those are informed by the PRA analysis.

1 The DBA is a separate category that is informed by the
2 PRA analysis but it serves the deterministic piece of
3 the Part 53.

4 MEMBER ROBERTS: Yes, maybe it will become
5 clear on the next couple of slides. It seems odd that
6 an AOO, if you had SSCs that required to mitigate AOOs
7 those would not be safety related but they would be if
8 it was to mitigate a DBA. So an SCC that mitigates a
9 more than likely scenario, being, you know, subject to
10 less quality standards it seems odd to me. Maybe I
11 don't understand how the DBA and other DBAs would
12 apply.

13 MR. GILBERTSON: Okay. Yes. Maybe we
14 will, we can, we'll probably get to that on a later
15 slide. But yes, certainly if it's not coming back up
16 I expect you'll ask again, so.

17 Okay. So going back to 53.210. So like
18 I mentioned, the requirements there for the 25 rem
19 reference values are similar to what you would see in
20 Parts 50, 52 and 100. And as such we included a
21 footnote in the proposed 53.210 to similarly explain
22 that the use of the 25 rem reference value would not
23 be intended to imply that it constitutes an acceptable
24 limit for an emergency dose to the public under
25 accident conditions. But it is in fact just a

1 reference number that is used in evaluating plant
2 design features with respect to the DBA case.

3 And the inclusion of the safety criteria
4 for DBAs in subpart B would provide a lot of structure
5 supporting the identification and treatment of safety
6 related SSCs and establishing the corresponding
7 functional design criteria for those SSCs.

8 MEMBER ROBERTS: And, Anders, you're
9 saying that that criteria of 25 rem associated with
10 design basis accidents would be across the board for
11 all design basis accidents?

12 MR. GILBERTSON: That's correct. Yes.

13 MEMBER ROBERTS: Thank you.

14 MR. GILBERTSON: Okay. So, going to the
15 analysis. The DBAs analyzed under Part 53 would be
16 similar to the traditional DBAs analyzed under Parts
17 50 and 52. However, Part 53, the DBA analysis would
18 be more narrowly focused on selecting safety related
19 SSCs and determining functional design criteria for
20 those SSCs to ensure that a facility conservatively
21 meets the safety criteria in 53.210.

22 So the overall control of risks posed by
23 a commercial nuclear plant under the Part 53 proposed
24 rule would be provided by the analysis of and measures
25 taken for both DBAs and other LBEs, including the very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 unlikely event sequences. And so the analysis of DBAs
2 under the proposed 53.450(f) would be required to
3 address event sequences derived from those with
4 estimated frequencies below the expected lifetime of
5 a generation of reactors. So for example, event
6 sequences with frequencies as low as one in 10,000
7 years.

8 And as it's proposed in 53.450(f), DBAs
9 would need to be analyzed using deterministic methods
10 and ensure a safe, stable end state and only rely on
11 safety related SSCs. And if needed, human actions
12 performed by operators that would be licensed under
13 the provisions of Sections 53.760 through 53.795.
14 Jesse Seymour will be speaking about this later this
15 morning.

16 Now to draw a contrast to how DBAs are
17 analyzed under Part 50, the analysis of DBAs under
18 Part 50 are used to provide bounding assessments,
19 incorporate standard design rules, such as assumptions
20 related to single failures, and to define conservative
21 performance requirements for safety related SSCs. So
22 limitations related to the traditional deterministic
23 approach were addressed in Part 50 through case-by-
24 case assessments. And specific actions for beyond
25 design basis events such as anticipated transients

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 without SCRAM and station blackout. Which the
2 proposed Part 53 rule has been designed to avoid. The
3 limitations that is.

4 Slide 16 please.

5 MEMBER KIRCHNER: Anders, this is Walt
6 Kirchner. Before you go on --

7 MR. GILBERTSON: Yes.

8 MEMBER KIRCHNER: Have you kind of done a
9 mental or a tabletop equivalent exercise that using 53
10 would demonstrate a equivalent level of safety to the
11 assumptions used in 50 or 52 with regard to DBA
12 analyses?

13 And I'm thinking specifically of
14 assumptions like single failure, control room, maximum
15 worth control rod out or in, et cetera. Have you gone
16 through that for a tabletop exercise to actually
17 demonstrate that you could say you're providing an
18 equivalent level of safety?

19 MR. GILBERTSON: So I will take a shot at
20 answering that but I'll probably have to defer to
21 either Bill or Nan because they have a lot more of the
22 history.

23 Don't know that there were any specific
24 tabletop exercises done. The thinking that went
25 behind that was, I believe at more sort of conceptual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 level, and part of the integration of the PRA into the
2 Part 53 requirements, together with the analysis of
3 DBAs, those taken as a whole are sort, you know,
4 provide a foundation for the staff being able to make
5 those kind of conclusions that there is an equivalence
6 of level of safety.

7 As I discussed before because, you know,
8 in part the PRA provides such a systematic
9 understanding and interrogation of how a facility
10 would perform under those conditions. Bill or Nan,
11 would you offer any other thoughts to that point?

12 MR. RECKLEY: Yes. Anders this is Bill
13 Reckley. Walt, I would say we're confident that in
14 total we get there. But as we talked about in the
15 preamble the role of the design basis accident is a
16 little different in Part 53. As Anders mentioned,
17 more narrowly focused to define the design
18 requirements, performance requirements of safety
19 related SSCs whereas in Part 50 there is kind of a
20 bounding event kind of role for the DBA.

21 So in total, and Anders is going to get to
22 the licensing basis events other than the DBA in the
23 next few slides, in total we're confident that there
24 is an equivalent level of safety. But I would just
25 caution and refer you to the preamble discussion of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the DBA because it, itself, serves a slightly
2 different role.

3 MEMBER KIRCHNER: Okay, thank you.

4 MEMBER MARTIN: Okay, Bob Martin. Kind of
5 in the spirit of Walt's question, you know, I see, we
6 have this nice track changes version and I can see
7 what has been and has since been removed. I see
8 beyond design basis accidents and a lot of editing
9 associated with that and elevating the emphasis on
10 DBA's course, traditionally.

11 We've had Chapter 19 where deterministic,
12 beyond design basis accidents have been formed under
13 the best estimate sense. They do contribute
14 specifically in a defense-in-depth context.

15 I'm trying to wrap my head around whether
16 we have equivalence with Part 53 in that sense. I
17 mean, do deterministic beyond design basis accident
18 analysis go away or what does it look like in this
19 world?

20 MR. GILBERTSON: No, they wouldn't go away
21 they would be captured by the class of LBEs that are
22 the very unlikely events. So those would be the event
23 sequences that come out of the risk, the PRA and other
24 approaches and risk analyses to show what the more
25 extreme conditions that might be, a facility might be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 exposed to.

2 And like you said, those are informing
3 decisions from the start of the design to inform
4 defense-in-depth consideration, whether it's adequate
5 defense-in-depth. Which can allow flexibility to make
6 decisions about adding additional capability to a
7 facility to address particular conditions which may or
8 may not be performed or satisfied by SSCs that aren't
9 necessarily safety related, but you have extra layers
10 of defense. Whether it's physical equipment,
11 programmatic controls or operator actions.

12 MEMBER MARTIN: And now in the vision for,
13 you know, a Part 50, well, really not just Part 53
14 SARs we have like a 7 Chapter, or whatever, as opposed
15 to the traditional 19 Chapter SAR. And now, all of
16 these analyses, ones that land in three or, anyway.
17 One of those early chapters.

18 And I'm trying to, you know, think, well
19 now, we have an emphasis on design basis accidents
20 primarily for the purpose of demonstrating the
21 performance of safety related SSCs, and then we have,
22 as you just mentioned, the LBEs which might, which of
23 course include the DBAs, but get into the story of
24 defense-in-depth. I mean, does this kind of appear in
25 segregated sections there?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I mean, just like Chapter 19 is separate
2 from Chapter 15. I mean, do we, is there intention to
3 still have a holistic integration of all these
4 analyses or do we still kind of separate that out to
5 tell two different stories. One to support the safety
6 related aspects of the design and another to tell the
7 defense-in-depth story?

8 I mean, I'm not going to judge it one way
9 or the other. I'm leaning towards, you know, kind of
10 the old way of segregating because it's much more
11 transparent. Or is the idea to integrate the stuff
12 and then somewhere in there you can pick up both
13 stories.

14 MR. GILBERTSON: Right. Right. Yes, and
15 so, I think that it's -- the explanation will be more
16 of a holistic, integrated explanation. We're, you
17 know, part of how we're seeing that is as it relates
18 to the guidance that we provided on content of
19 applications for non-LWR applications using LMP under
20 Parts 50 and 52. Which we refer to as the ARCAP/TICAP
21 guidance. Which I think is a structure that you're
22 referring to. Which relates to NEI 21-07 and how
23 those chapters are laid out.

24 So I think it's kind of maybe a
25 combination of both of those things. There are, you

1 know, there needs to be an understanding of how
2 defense adequate defense-in-depth is achieved.
3 Whether that's through capabilities, programs, et
4 cetera.

5 But there is a sort of narrative I think
6 that needs to be put together to explain how that
7 relates to the other pieces of the process. Talking
8 about ARCAP/TICAP, the process of LMP as you're
9 talking about how you perform your licensing basis
10 even identification. How you did your structures
11 system component safety categorization.

12 MEMBER MARTIN: Right.

13 MR. GILBERTSON: Because all of that has
14 an interplay with defense-in-depth. They all relate
15 to each other. And of course, that's, it's a very
16 iterative process. So.

17 MEMBER MARTIN: Sure. I worry that maybe
18 the edits that made, you certainly have elevated the
19 intention on DBAs but the defense-in-depth story
20 almost takes a backseat to that where they really have
21 to be, you know, again, in a holistic view of these
22 things equivalent. At least in the articulation. And
23 it's all very hard too.

24 But I just was worried a little bit, but
25 de-emphasizing of the importance of the defense-in-

1 depth story and the beyond design basis, accidents,
2 you know, that maybe in some way there was less
3 burden, not to say there should be more, but to Walt's
4 comment about equivalence. You know, making it, you
5 know, easier because it remains, I would say, to more
6 important in the kind of technology inclusive approach
7 to have this holistic view of these things.

8 And here we are kind of emphasizing
9 traditional terms where I, you know, I think we had a
10 lot of support for NEI 18-06 and 21-07. And this
11 seems to be a little bit of a pull back to the way
12 things have been done. I mean, from what you had in
13 the original draft.

14 MR. GILBERTSON: So I guess --

15 CHAIRMAN PETTI: This is Dave. Let me
16 just, let me try something here. My view is that the
17 defense-in-depth under 53 and LMP takes a more
18 balanced view across the spectrum, the frequency
19 spectrum, where you don't necessarily know a priori
20 where your two risks lie in a deterministic world.
21 And it's a method to make sure that it's applied in a
22 balance way so that you get the proper safety, quote-
23 unquote, whatever that means.

24 And so that, to me, that's kind of like
25 the building block of the whole, of Part 53 and LMP.

1 And then you breakout this DBA role where you only
2 assume, you know, the safety systems work. And that's
3 just to demonstrate that they're doing their job.

4 And so the defense-in-depth is built in
5 from the beginning. Now it actually gets articulated
6 you won't know until we see the first application.
7 But that's always how I can remember it being
8 discussed in the earliest days when we had, for
9 instance, some of the guys who actually put LMP
10 together come in and talked with the committee.

11 MEMBER MARTIN: Well I absolutely agree,
12 Dave. I'm just kind of reacting to the changes in
13 the, from proposed to what we're seeing here today and
14 seeing a lot of removal of the content that, you know,
15 emphasized a beyond a design basis kind of on par with
16 everything else. Or really in the context of
17 licensing basis events.

18 Now, I just kind of worry this may be an
19 overreaction to comments that maybe, you know, beyond
20 design basis events is bleeding too much into design
21 basis. Where we are, you know, going back to Walt's
22 comment, it's about equivalence. We're always looked
23 at beyond design basis events but, you know, how this
24 gets interpreted by an applicant remains to be seen.

25 And I think the, if I think about an NE

1 18-06 model, and I have some experience doing that, I
2 can, you know, integrate a holistic type approach with
3 it. And then in the synthesis of the analyses answer
4 two questions. One is, what is the performance of the
5 safety related equipment that you care most about, and
6 then what is the defense-in-depth story.

7 But I would hate to think that someone,
8 okay, well let's just focus on design basis events and
9 then we'll throw in a few extra events here just
10 because it's mentioned. Again, we won't know until at
11 least the filing.

12 MEMBER HALNON: You're talking about 18-04
13 right?

14 MEMBER MARTIN: Yes. Yes, yes.

15 MEMBER HALNON: I have experience with 18-
16 06 translates into --

17 MEMBER MARTIN: Oh, 18-04, I am so sorry.

18 MEMBER HALNON: All right --

19 MEMBER MARTIN: That's a different, yes,
20 18-04.

21 MEMBER HALNON: So this is Greg. I just
22 wanted to, I've been thinking about this equivalent
23 stuff and you mentioned SBO or station blackout. Is
24 that, I'm thinking you can make a qualitative argument
25 that it's even more likely you could have a station

1 blackout with a new reactors because of less emphasis
2 on, less emphasis on switch yards and redundancies,
3 non-safety diesels, all the case.

4 But the equivalence is, is that they're
5 inherently more safe from the standpoint of needing
6 power, AC power. And so you have, you can either
7 prevent it, deal with it or mitigate it through your
8 inherent safety features. And that's the equivalency
9 that we're looking at, at this point, is that correct?

10 MR. GILBERTSON: Yes. Yes, I think that's
11 a fair way to characterize it.

12 MEMBER HALNON: I just want to get an
13 example out there. It's not that we're not
14 considering SBO it's that it's not as significant
15 impact to the reactor core or wherever the fuel is at
16 this moment.

17 MR. GILBERTSON: Right. And that's
18 something that you would expect to come through the
19 results of your PRA as you analyze the facility.

20 In addition to, you know, resolve step
21 could inform what, you know, degree of defense-in-
22 depth that you have. You can integrate the results of
23 the PRA, the event sequences themselves. You can make
24 characterizations about, you know, how much defense do
25 I have or classes of types of responses to different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 initiators and such. And then you can make decisions
2 about that in your design, so yes.

3 MEMBER HALNON: Okay, thanks.

4 MEMBER ROBERTS: Yes, probably should let
5 you move over to the next slide. This is Tom Roberts.
6 But thinking about Bob and Dave's comments.

7 But the primary saying is, there's a carve
8 out for DBAs, other than that there is like a
9 frequency consequence thought process. Because it's,
10 other than design basis accident events, because it's
11 not really beyond design basis because it also
12 includes AOOs and normal operation.

13 And so the principle is you want to have
14 the lowest likelihood of consequence with the higher
15 frequency events just a variation of that C-curve.
16 And so it seems like, the way Dave explained it, the
17 DBA is a carve out just to be able to, you know, I
18 won't say check the box, but have a basis for the
19 safety related equipment. But you still have the non-
20 safety and special treatments for any equipment for
21 the rest of the spectrum.

22 So is that the right thought process, that
23 the DBA is the carve out but in reality it's the other
24 than design basis that gets you the appropriate
25 quality versus risk?

1 MR. GILBERTSON: I think that's generally
2 a good way to frame that. Yes. That's in line with
3 what I think I've been trying to kind of explain
4 previously. Yes.

5 MEMBER ROBERTS: Because it seems like
6 it's largely consistent with LMP, except that LMP is
7 a lot more specific. It's got check points at ten to
8 the minus four, keep it common with BDBE, and parts of
9 ten to the minus seven you become a BDBE, whatever
10 they call it.

11 And there are requirements for each of
12 them. You got the cliff edge effects and the design,
13 defense-in-depth assessments required for even beyond
14 the five to ten minus seven. You got the BDBE
15 requirements and the special treatment requirements
16 for the BDBE range.

17 So it seems like you can accomplish that
18 and the, you know, the licensing route can give me
19 your standards. And you'd expect each application to
20 have the equivalent of LMP in terms of these are the
21 criteria that we expect to be versus frequency.

22 And, oh by the way, there are also DBAs
23 that have a different -- okay, it sounds like I
24 understand you now. So thank you.

25 One thing I noted, I did an electronic

1 search for the word cliff edge I the 800 page
2 document, I didn't find it. So it seems like the
3 concept is basically up to, we're going to have to
4 address. But there is also, you know, frequency bound
5 stated were implied in your next slide that defines
6 what a, other than DBA is. So it sounds like
7 basically, you know, the applicant can tell me what
8 you think you need to be. And then you'll assess that
9 on a case basis depending on what they tell you.

10 MR. GILBERTSON: Yes.

11 MEMBER ROBERTS: Okay, thanks.

12 MR. GILBERTSON: And then, yes. And then
13 that goes directly to the flexibility that was
14 intended in development as well.

15 MEMBER ROBERTS: You probably can move on.

16 MR. GILBERTSON: Okay. All right, we can
17 move to, I think I finished with this slide. Go to
18 Slide 16 please.

19 Okay. So moving on to the safety criteria
20 for LBEs other than DBAs. Section proposed 53.220
21 would provide safety criteria for those. The
22 identification and analysis of which would be required
23 by 53.240 and 53.450(e).

24 In addition, the criteria, the safety
25 criteria under 220 for LBEs other than DBAs, it would

1 consider a broader set of potential scenarios related
2 to both internal and external hazards. Just like
3 we've been talking about. It's a broader spectrum of
4 risk consideration.

5 And the requirements under 53.220(a) would
6 establish those connections between the capability and
7 reliability of SSC design, human actions and
8 programmatic controls for the wide spectrum of plant
9 conditions considered. And these requirements would
10 also explicitly address consideration of defense-in-
11 depths, such as the balance consideration of event
12 preventing and against, and mitigation of radiological
13 releases.

14 So Paragraph 53.220(b) is the subject of
15 the next SRM item, which is Item 2. And the safety
16 criteria in 53.220(b) of the draft proposed rule was
17 revised to remove the Commission's quantitative health
18 objectives for QHOs and their related risk matrix of
19 the individual early fatality risk and the individual
20 latent cancer fatality risk.

21 So the requirements in the Part 53
22 proposed rule would include the use instead of a
23 comprehensive risk metric, or set of metrics, and
24 associated risk performance objectives against which
25 the calculated values of the risk metric, or metrics,

1 would be compared.

2 So that's very -- That's similar to the
3 paradigm discussed relative to the QHOs and those risk
4 metrics.

5 So in that regard, an application to the
6 Part 53 proposed rule would be required to include a
7 description of the methodology for the use of the
8 proposed comprehensive risk metrics and that would
9 include, among other things, an explanation of the
10 initial boundary conditions, initial conditions, and
11 key assumptions that would be used to develop and
12 calculate the risk metrics.

13 The comprehensive risk metrics or set of
14 metrics and their associated risk performance
15 objectives would support a performance-based approach
16 to developing an appropriate combination of design
17 features and programmatic controls to prevent or
18 mitigate LBEs other than DBAs.

19 So that's another way of saying what we
20 sort of already have been talking about, it's all
21 working together, the analyses and form, how this, the
22 DBAs are selected, and then, which, of course, informs
23 your safety-related SSCs.

24 Okay, Slide 17, please.

25 MEMBER KIRCHNER: Anders, before you go on

1 this, this is Walt Kirchner again.

2 MR. GILBERTSON: Yes.

3 MEMBER KIRCHNER: Pragmatically, are you
4 thinking that it's the frequency consequence curve or
5 are you thinking that each reactor technology would
6 have its own set of metrics and performance
7 objectives?

8 MR. GILBERTSON: Well --

9 MEMBER KIRCHNER: What's the surrogate
10 that you see here versus things like, like I would
11 presume in the back of your mind is things like CDF
12 and LERF, but those don't necessarily work for other
13 technologies, so, you know, pragmatically how do you
14 see this playing out since this takes the place of
15 QHOs?

16 MR. GILBERTSON: Right. It could be the
17 frequency consequence curve that is described in NEI
18 18-04 and surrogates could be developed as well. Like
19 you mentioned, CDF and LERF is probably not going to
20 work for most technologies, but something could be
21 developed to that end.

22 That's certainly possible, but LMP is
23 certainly going to be one way that you could meet the
24 requirements. I will talk about that a little bit
25 more actually on the next slide as it relates -- Yes?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER DIMITRIJEVIC: Hi, there. This is
2 Vesna Dimitrijevic. I came into a problem here with
3 the just naming conventions, comprehensive risk
4 metrics because they could be interpreted as
5 comprehensive set of metrics or comprehensive risk
6 metrics which describe this overall risk.

7 So, you know, when I think about that I
8 try to visualize what would that be. I mean what --
9 In your opinion how does this, you know, we were
10 talking about the C-curve or the CDF and LERF, does a
11 different risk metric capture the uncertain risk?

12 So in your opinion what does actually a
13 comprehensive risk metric apply? Is this the
14 comprehensive selection of the metrics or we are just
15 talking about comprehensive risk?

16 MR. GILBERTSON: It would be the latter,
17 it's comprehensive risk. So the idea is that it would
18 represent the total risk of a facility of a design --

19 MEMBER DIMITRIJEVIC: Right.

20 MR. GILBERTSON: -- that it would be
21 exposed to.

22 MEMBER DIMITRIJEVIC: Right, but when you
23 say, comprehensive set of metrics, that could be
24 interpreted both ways. That's just my point, you
25 know.

1 MR. GILBERTSON: Yes.

2 MEMBER DIMITRIJEVIC: I mean it should be
3 just comprehensive risk or metrics which models
4 comprehensive risk, you know. So when you say
5 comprehensive risk metrics it could be talking about
6 a different selection of the, you know, metrics to
7 model the risk.

8 MR. GILBERTSON: Yes. So --

9 MEMBER DIMITRIJEVIC: That's just my
10 comment. I have a problem with terminology here.

11 MR. GILBERTSON: Sure. Okay, yeah, and I
12 appreciate the comment. We do have a guidance
13 document that is under development that eventually is
14 going to move forward with the draft final rule
15 package that goes to the comprehensive risk metrics,
16 the risk performance objectives, how those would be
17 evaluated by the Staff, et cetera, so --

18 MEMBER DIMITRIJEVIC: But I mean if you --
19 right, except for the overall risk metrics, I mean
20 that would make sense and just --

21 MR. GILBERTSON: Right. Right, yeah.
22 And, you know, we were taking language that borrowed
23 language directly from the SRM to stay consistent with
24 what the Commission has directed us to do.

25 So the further explanation of that will

1 come through in the guidance, okay.

2 MEMBER ROBERTS: But the term,
3 comprehensive risk metrics, is supposed to be say
4 capture, also say defense in depth considerations. I
5 could imagine, you know, you consider dose, obviously,
6 but maybe fuel temperatures and other metrics, you
7 know, that would all have criteria.

8 Is that idea? Or when you mean
9 comprehensive, it's not limited to, you know, a
10 frequency consequence with dose, for instance, it goes
11 beyond that to include other potential say engineering
12 limits --

13 MR. GILBERTSON: Well I guess --

14 MEMBER ROBERTS: -- and likelihoods?

15 MR. GILBERTSON: Yeah, so it's really more
16 focused on how those risk metrics are used to form the
17 PRA and the results of that and how that is integrated
18 into the design decisions.

19 There may be other design deterministic
20 risk metrics or something for defense in depth that
21 are used as part of the overall decision-making
22 process, but in terms of the evaluation of the event
23 sequences, the risk produced from that, whatever your
24 output is from the PRA, that's really what those risk
25 metrics are representing.

1 Now the PRA can be used in conjunction
2 with, and we talk about this in the proposed rule,
3 with other generally accepted approaches or
4 systematically evaluating engineering systems.

5 So there could be a blending of the PRA
6 together with other types of risk-informed analyses
7 that may use different metrics and those are brought
8 together to, again, use that in the overall design
9 decision-making process, if that makes sense.

10 MEMBER ROBERTS: Yeah. No, I understand.
11 I'm trying -- Yes.

12 MR. GILBERTSON: Okay. Okay, let's move
13 on to Slide 17 in the interest of time here. So I'm
14 going to try and cover a little more ground here so we
15 can keep moving forward.

16 So the Section 53.450(e) is addressing,
17 like it does for (f) in the DBAs, this is for the
18 LBEs, other than design-basis accidents, how those
19 would be analyzed and it provides requirements for
20 analyzing the LBEs, the evaluation criteria for LBEs,
21 a starting and end point for analysis of an LBE, and
22 the process for identifying risk significant event
23 sequences.

24 So, again, if you pair that, if you set
25 that side-by-side with the LMP methodology you can see

1 the commonalities that come out of that, the licensing
2 basis of the categories, for example, and how, you
3 know, the risk significance of event sequences are
4 determined.

5 So these requirements would address this
6 analysis to demonstrate the performance criteria in
7 53.220 are satisfied, but also to show that the
8 evaluation criteria to find for each LBE or category
9 of LBEs would also be satisfied.

10 So, again, that's the sort of binning into
11 these different categories of LBEs, the AOOs, unusual
12 event and very unusual event sequences.

13 So the evaluation criteria for specific
14 LBEs or categories of LBEs would be defined in terms
15 of limits on the release of radionuclides for
16 maintaining the integrity of one or more barriers used
17 to limit the release of radionuclides and would
18 reflect a graded approach of allowing lesser potential
19 consequences for more frequency events.

20 Again, the LMP would be one way to do that
21 and was used to inform the development of these
22 requirements.

23 Slide 18, please. Okay, so talking a
24 little bit more about the comprehensive risk metrics
25 and the associated risk performance objectives.

1 As was directed in SRM Item 2, the
2 preamble of the proposed rule was expanded to explain
3 that comprehensive risk metrics should consist of a
4 proposed plant risk metric or set of proposed risk
5 metrics that approximate the total overall risk from
6 the facility and that address the range of possible
7 plant configurations and associated internal and
8 external hazards to the extent practicable.

9 The risk performance objectives associated
10 with the proposed comprehensive risk metric or set of
11 metrics are pre-established acceptable values that are
12 used to compare against measured values of risk
13 metrics as part of risk-informed decision-making.

14 So as we have already talked about, one of
15 the most relatable examples of this are the
16 quantitative health objectives described in the
17 Commission Safety, well Policy Statement, and the
18 analogous comprehensive risk metrics would be i.e. of
19 the individual early fatality risk and the individual
20 latent cancer fatality risk.

21 So those could be used to form the basis
22 for meeting the proposed requirements of 53.218(b),
23 but, again, that could just be one way. There may be
24 other proposals and, of course, those would have to be
25 evaluated on a case-by-case basis.

1 So the use of the comprehensive risk
2 metrics and associated risk performance objectives
3 would provide a logical performance objective to
4 support risk management approaches described in the
5 various subparts of the Part 53 proposed rule and
6 applicants could choose to propose and seek NRC
7 approval of comprehensive risk metrics and their risk
8 performance objectives, including the use of surrogate
9 metrics as we previously discussed.

10 At the moment we don't, we haven't seen
11 any of any surrogates per se for non-LWRs, but they
12 could be developed and proposed.

13 Again, I will just emphasize that the
14 Staff are developing guidance on determining the
15 acceptability of proposed comprehensive risk metrics
16 and the risk performance objectives and that is
17 expected to go with the draft final rulemaking
18 package.

19 Slide 19, please. Okay, so the safety
20 functions are addressed under Section 53.230 and this
21 section would specify that limiting the release of
22 radioactive materials from the facility is the primary
23 safety function and would need to be maintained over
24 the life of the facility.

25 The primary performance metric used

1 throughout the Part 53 proposed rule would, therefore,
2 be limiting potential offsite consequences, so, for
3 example, dose to a hypothetical individual.

4 53.230 would also require identification
5 of additional or subsidiary safety functions that are
6 needed to limit the release of radionuclides, which
7 could include controlling processes related to
8 reactivity, heat generation, heat removal, and
9 chemical interactions.

10 So the primary and these additional safety
11 functions would be required to meet the safety, to
12 satisfy the safety criteria under 53.210 and 220 if an
13 assumed LBE were to occur at a facility and would be
14 fulfilled by the design features, human actions, and
15 programmatic controls that are addressed throughout
16 the Part 53 proposed rule.

17 So, again, as we have mentioned
18 previously, this proposed rule would provide
19 flexibility to applicants and licensees in
20 identifying, implementing, and maintaining the safety
21 functions supporting retention of radionuclides for
22 facilities of varying sizes and new technologies.

23 MEMBER HALNON: So, Anders, this is Greg.
24 The functional containment comes to mind. Have the
25 Staff counted on a succinct definition of that and we

1 understand that completely what that's going to look
2 like, it seems like there was some fuzziness earlier
3 on about definitions and what it actually looks like
4 from a nuclear perspective; have we settled on what
5 that is because it certainly falls into this first
6 bullet?

7 MR. GILBERTSON: Right. Well there is, of
8 course, the SECY paper I am not able to, I don't
9 recall the number off the top of my head, but that
10 specifically address functional containment.

11 Bill Reckley is the author of that paper
12 and that lays out the concept of how we think about it
13 and, of course, I think we're seeing what that looks
14 like with applications that are coming in and we're
15 having to assess that in that context.

16 MEMBER HALNON: Have you been awaiting
17 feedback from the Commission on that paper?

18 MR. GILBERTSON: That was --

19 MEMBER HALNON: That was awhile back?

20 MR. GILBERTSON: Yes, that's a little
21 while back.

22 MEMBER HALNON: Okay.

23 MR. GILBERTSON: So that was --

24 MEMBER HALNON: That's what we're still
25 operating off of then, right?

1 MR. GILBERTSON: Yes. Yes.

2 MEMBER HALNON: Okay. I remember what
3 you're talking about. Thanks.

4 MR. GILBERTSON: Yeah. Okay, we can move
5 on to Slide 20, please. Okay, so 53.240 would require
6 applicants to identify and analyze the LBEs for the
7 purpose of demonstrating that the safety requirements
8 in subpart B have been satisfied.

9 One or more of which of those LBEs must be
10 a DBA. The LBEs, as shown in the definition down
11 here, are those unplanned events that would fall into
12 one of the four categories and that includes
13 anticipated event sequences, unlikely event sequences,
14 very unlikely event sequences, and the design-basis
15 accidents.

16 So all of those were the four categories,
17 but we have been discussing how the DBAs serve a
18 different function than the first three mentioned
19 there.

20 The analysis of the LBEs under 53.450
21 would help ensure that the related estimates of
22 offsite consequences would be below the safety
23 criteria identified under 53.210 and 53.220 and that
24 the SSCs, personnel, and programs address the safety
25 functions identified in the proposed 53.230.

1 So this would reflect the historical and
2 continued importance of evaluating unplanned events as
3 part of the licensing of commercial nuclear plants.

4 And, finally, 53.240 would also require
5 that the analysis of LBES confirm the adequacy of
6 design features and programmatic controls in meeting
7 the safety criteria under 53.210 and 220 and that they
8 would be used to establish related functional
9 requirements for SSCs, personnel, and programs.

10 Okay, Slide 21, please. So getting to
11 defense in depth, this section, 53.250, would
12 establish requirements for defense in depth and those
13 are based on longstanding philosophy of providing
14 defense in depth to address uncertainties about the
15 design, operation, and performance of the commercial
16 nuclear plants.

17 As we have discussed previously this would
18 provide flexibility in how applicants would propose to
19 demonstrate compliance with the high-level safety
20 criteria as would be informed by defense in depth and
21 these requirements would include that no single
22 engineered design feature, human action, or
23 programmatic control, no matter how robust it is,
24 should be exclusively relied upon to address LBES
25 other than DBAs.

1 So the phrase, engineered design feature,
2 would not preclude crediting inherent characteristics
3 within the design and analysis, so, for example,
4 inherent characteristics of fuel performance, as an
5 example.

6 MEMBER ROBERTS: Anders, this is Tom
7 Roberts. That last bullet implies that you can rely
8 on a single engineered design feature for a DBA. Is
9 that the intent?

10 MR. GILBERTSON: No. There would still
11 need to be -- you wouldn't be able to do that and meet
12 the defense in depth requirement as it's proposed
13 here. So there still needs to be a demonstrated
14 balance between prevention and mitigation. So yeah.
15 Does that help?

16 MEMBER ROBERTS: I was thinking that the
17 words other than DBA don't really need to be in that
18 bullet. And I guess I'm wondering in general about
19 the definition, that a DBA is not really a DBE, and a
20 DBE comes out of a PRA that these are the event
21 sequences that could happen. A DBA is kind of a
22 deterministic combination to bound several of those
23 for the purpose of SSC determination, just -- so it
24 just seems like the concepts are different, LBE and
25 DBA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And maybe just something to think about is
2 to take out that word group other than DBAs. Just
3 make it DBA requirements and LBE requirements. Just
4 a thought.

5 MR. GILBERTSON: Okay. All right.
6 Appreciate that --

7 MEMBER HALNON: No, it's a good thought.
8 And I was looking at you thinking that you would
9 probably pounce on this one. The same point I was
10 making earlier, you know, there are two different
11 things, at least, we can try to tackle with your
12 analysis. And one, of course, is the deterministic
13 evaluation of the performance of safety-related
14 equipment, and then there's the other that's the more
15 holistic one that looks at the subject of defense in
16 depth.

17 So yeah. I'm with you, Tom, that the
18 other -- it just doesn't belong here because it -- you
19 know, of what we're talking about. The other reason
20 I was looking over -- I thought you might pounce on
21 cliff edge effects because this is where I think you
22 would put it -- you know, you put mention of it as far
23 as the search.

24 Oftentimes, I think applicants have a
25 difficult time with, what does it mean? What is the

1 defense in depth requirement? And they're really
2 looking for the actions that are expected of them for
3 that purpose. Now, granted, a rule is intended to be
4 higher level. You capture these things in guidance.
5 And we're doing better, certainly, seeing that a
6 number of examples of -- at least in regulatory
7 guidance where cliff edge effects comes in.

8 However, the rule is what kicks it all
9 off. And certainly, I would feel like this is a good
10 place at least to mention that there's an expectation
11 as part of defense in depth -- is there is this
12 comprehensive search for cliff edge effects. And this
13 is Engineering 101 where you create the box and you
14 protect the boundaries of the box. Cliff edge effects
15 are the boundaries.

16 MEMBER ROBERTS: And the reason I didn't
17 raise that is because I read the definition, very
18 unlikely, in the draft language. And it would
19 encompass basically any frequency. So it's up to the
20 applicant to figure out how to bound that, and that
21 would, I think, require a search for cliff edge
22 effects and the assessment of defense in depth down to
23 some sort of lower cutoff.

24 And, oh, the question of what the lower
25 cutoff is is yet another question we've discussed in

1 other meetings, and still waiting for the definition
2 of what that might be. But yeah, I think the language
3 here, Greg, would cover it, but it puts a lot of onus
4 on the applicant and the engagement with the regulator
5 to figure out where that bound is.

6 MR. GILBERTSON: Okay. Thank you. And I
7 guess, as far as a DBA being able to rely on a single
8 function or piece of equipment, put in the context of
9 the LMP methodology, the DBAs are derived from the
10 DBEs. So, if you impose the requirement on your DBEs,
11 there should be -- that should transfer into your
12 DBAs. You would necessarily not be able to have that.
13 You'd have some set of safety-related equipment. But
14 the point that you made about the language -- that's
15 a fair point. I'll definitely take that back.

16 Okay. Let's move on to slide 22. Okay.
17 So the next couple of slides are going to focus on
18 changes made in the Part 53 proposed rule to address
19 Item 4 from the SRM. This is -- relates to the
20 concept of as low as reasonably achievable, or ALARA,
21 and directed the staff to retain the use of design
22 objectives to demonstrate how effluent released would
23 be limited, consistent with 10 CFR 50.34(a), which
24 provides objectives related to control of radioactive
25 effluence.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So let's move to slide 23, please.

2 MEMBER ROBERTS: Real quick, Anders.

3 MR. GILBERTSON: Yes.

4 MEMBER ROBERTS: The definition of
5 commercial nuclear plant -- is that going to be
6 reiterated from, I guess, the recent NTAC patent
7 definition of labor -- or maybe it was the one before
8 that -- relative to the -- how much revenue goes into
9 operating the plant, that sort of thing? Is that
10 going to be reflected in the regulation, or are we
11 going to be arguing what's commercial versus not when
12 you're actually selling electricity and you're not
13 quite commercial?

14 MR. GILBERTSON: Right. I guess what I
15 would say at this point is that we are working closely
16 with the team that is addressing implementation of the
17 ADVANCE Act. Can't specifically say, as far as Part
18 53 rule is concerned, how we would necessarily
19 implement that. But there's close coordination.
20 Perhaps there will be comments on that that we'll
21 receive --

22 MEMBER ROBERTS: I'm interested in that
23 only because, being on the other side for most of my
24 life, the safety culture aspect of business objectives
25 versus commercial -- I mean safety objectives -- it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 always -- I'm not going to say a struggle, but there
2 sometimes can be -- and I'm interested in how we're
3 going to parse that out in the actual reviews of these
4 applications.

5 MR. GILBERTSON: Okay.

6 Okay. Let's move on to slide 23, please.

7 Okay. So this discussion, the SRM item
8 related to ALARA -- it cuts across a number of
9 different requirements. So we're kind of presenting
10 all of them here -- illustrate, talk a little bit
11 about how we address that.

12 53.260 and 270 were revised to more
13 directly reference to radiation protection
14 requirements for normal operations under 10 CFR Part
15 20. Section 53.25 was likewise revised to emphasize
16 that the design should support meeting the
17 requirements for radiation protection, the Radiation
18 Protection Program, and it also includes a footnote
19 related to the use of the 10 millirem per year design
20 objective, which serves the purpose of Appendix I to
21 Part 50 under the current requirements.

22 So this means that if an applicant can
23 show that the proposed design features will support
24 meeting the design objective, there should be no need
25 to look for additional improvements and terms of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 further reducing public doses from normal operation.

2 For Section 53.430, this was similarly
3 revised as it relates to worker protections. In
4 addressing the parallel to 10 CFR 50.34(a), there
5 would need to be an analysis of expected releases and
6 doses to the public. And this would address
7 inventories, or address the anticipated inventories,
8 their locations, controls thereof, to show that the
9 expected doses would meet the Part 20 requirements.

10 Section 53.50 on the Radiation Protection
11 Program was also revised and includes requirements
12 that are equivalent to environmental technical
13 specifications such as an off-site dose calculation
14 manual, because Part 53 does not include a proposed
15 requirement for environmental specifications.

16 Requirements on annual reporting under
17 53.1645 were also revised to address this item but are
18 largely consistent with current requirements. And the
19 next set of requirements, going to the end of --

20 MEMBER ROBERTS: Stop you on 1645.

21 MR. GILBERTSON: Oh. Sure.

22 MEMBER ROBERTS: So I asked you earlier
23 about the role of ALARA. And what it looked like in
24 the prior proposed language was ALARA working its way
25 more in design requirement space as opposed to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 operation space. Now a lot of that's been cut out.
2 But this section still says design requirements of
3 ALARA. And I don't know if that was an oversight.
4 That doesn't seem to jibe with everything else that
5 has been edited out.

6 But it still says ALARA and design
7 requirements in the same sentence, and it doesn't seem
8 consistent with the other edits that have been
9 performed. And I don't know if that was intentional,
10 unintentional, but it might be worth circling back on
11 1645.

12 MR. GILBERTSON: Okay. Okay. Thank you.

13 So, getting to the last portion of this
14 table here, this all relates to the different
15 licensing applications, and it becomes a little more
16 nuanced here when you're talking about differences
17 between pre-operational and operational stages with
18 licensing.

19 So, for pre-operational licensing stages,
20 most of the revisions to the draft rule were effected
21 to the design certification requirements because many
22 of those requirements are references in other portions
23 of the licensing requirements.

24 So, for design certification or
25 construction permit, the applicant describes the

1 feature, the design features, but does not need to
2 provide the functional design criteria. In addition,
3 an applicant would describe how programmatic controls,
4 including monitoring programs, would support meeting
5 the safety criteria and would be used to supplement a
6 given design feature.

7 So, for example, this would mean
8 describing that a filter, which would be the design
9 feature, would be used versus talking about how
10 efficient that filter necessarily needs to be, which
11 would be more the functional design criteria. And
12 similar revisions were made relative to requirements
13 for occupational exposures. So, again, that's in the
14 context of pre-operational stages, so construction
15 permit, design certification, other manufacturing
16 license, SDA, that sort of thing.

17 For licensing phases related to
18 operational stages, the applicant would need to
19 provide information about the design and the Radiation
20 Protection Program. So, in that way, the Radiation
21 Protection Program would address the functional design
22 criteria and how everything comes together to achieve
23 the safety function and meet the rule.

24 So, for example, a filter is used as the
25 design feature. It must perform within certain

1 specifications, and the performance of the filter is
2 monitored via programmatic controls. And all of that
3 would be described as part of that -- meeting those
4 requirements. And again, similar changes were made
5 relative to the requirements for occupational
6 exposures.

7 Okay. Slide 24, please.

8 MEMBER HALNON: So, Anders --

9 MR. GILBERTSON: Yes.

10 MEMBER HALNON: -- we had it down on the
11 agenda a 10:15 break.

12 Dave, I think this is an appropriate place
13 to take ten minutes, if you agree.

14 CHAIRMAN PETTI: Yeah. Sounds good.

15 MEMBER HALNON: Okay. So we'll be in
16 recess until 10:25.

17 (Whereupon, the above-entitled matter went
18 off the record at 10:15 a.m. and resumed at 10:25
19 a.m.)

20 CHAIRMAN PETTI: Are we ready to start
21 again?

22 MEMBER HALNON: Yes, Dave. We just got
23 ready to go, so. So you can go ahead and get started.
24 Anders, go ahead.

25 MR. GILBERTSON: Okay. So we'll get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 started again here. We're on slide 24, and this is
2 getting into subpart C, which is addressing design and
3 analysis requirements. Go ahead and move on to slide
4 25.

5 Okay. So this diagram is really just
6 intended to be kind of a helpful tool to put the
7 overall structure of the Part 53 requirements into a
8 general kind of framework. And it really kind of
9 illustrates the systems engineering approach that was
10 taken to develop the structure of the proposed rule.
11 I'll try and go through this relatively quickly
12 because I'll emphasize it as I get into the sections
13 under subpart C.

14 But the top level -- or the top chevron
15 there -- we've already talked about safety criteria on
16 210 and 220 and that the subsequent layers underneath
17 that safety functions and so forth are used to
18 demonstrate that those will be met.

19 The safety functions are necessary to
20 ensure that the safety criteria are met. So, again,
21 it's just asking, what are the functions that need to
22 be present to make sure that the radiological releases
23 are limited? So, for example, that's controlling
24 cooling, heat production, containing radionuclides.

25 The next are the design features which are

1 kind of requirements here in subpart C, and those are
2 used to fulfill the safety functions that have been
3 identified. So, for example, that would be whatever
4 the actual system is -- do control cooling, which
5 would be achieved with pumps, valves, et cetera --
6 heat exchangers.

7 And then at the bottom level would be the
8 functional design criteria, which we're going to
9 describe how this design feature is looking to perform
10 to satisfy their design function. So, for example, a
11 cooling system, functional design criteria would talk
12 about things like minimum flow rate of a pump, heat
13 exchanger capacity, et cetera.

14 Okay. Next slide, slide 26.

15 So what does this look like in subpart C?
16 Well, we've got Section 53.400, which requires design
17 features be provided to satisfy the safety criteria.
18 Section 53.410 would require that functional design
19 criteria be defined for design features relied upon to
20 demonstrate that the consequences of DBAs are below
21 the 53.210 safety criteria and of course will be
22 analyzed per 53.450(f).

23 53.415 would require that safety-related
24 SSCs be protected against or designed to withstand the
25 effects of natural phenomena, human-constructed

1 hazards, such that the safety-related SSCs remain
2 capable of performing their associated safety
3 functions under those conditions and up to the
4 magnitude of the design basis external hazard levels
5 as would be identified and characterized under 53.510,
6 which I'll get to in a few slides.

7 MEMBER MARTIN: I'll use this as my
8 opportunity to mention the word hazards analysis. And
9 this is not just Part 53, but obviously, the SSCs have
10 to be protected against all hazards. We do elevate
11 external hazards in particular, for good reason.

12 But I do think the emphasis and the
13 potential de-emphasis of internal process hazards is
14 confusing, if not unproductive, because of course they
15 do. I mean, hazards -- you know, anything that's
16 going to disrupt the operation of the power plant are
17 a concern, a concern to everyone.

18 And I just feel like when I went through
19 it, again, doing the same thing that Tom did,
20 searching for my favorite word, hazard analysis, other
21 than the sections with fire hazard -- which have been
22 cut out, and I still haven't quite figured out where
23 that went -- it doesn't show up other than external
24 hazards in particular.

25 There is one location, internal and

1 external, but I'm kind of sensitive to what I perceive
2 is de-emphasis on a holistic view of hazards. And of
3 course, part of that holistic view is the necessity
4 for hazards analysis. And that gets in the guidance,
5 and the guidance will talk about that.

6 But the main point here is not to
7 overemphasize a particular hazard at the potential
8 risk of de-emphasizing a broader -- and just like
9 there's a search for cliff edge, prior to that, there
10 is a search for hazards. And it is agnostic to what
11 causes the hazards.

12 And I just feel like what's been written
13 in there is -- you know, seems to put all the emphasis
14 on external hazards, when ultimately, hazards come in
15 different forms.

16 (Off-microphone comments.)

17 MR. GILBERTSON: All right. Moving here
18 -- so the requirements, Part 53.415 -- those would
19 support the use of traditional deterministic
20 approaches or probabilistic approaches for determining
21 and protecting against external hazards, including
22 probabilistic approaches under development for seismic
23 and some other external hazards.

24 I guess I might just add that while the
25 rule language does emphasize external hazards, the

1 foundation of the PRA is the plant -- or the facility
2 design performance as it relates to the internal
3 events model, which is fundamentally the individual
4 equipment failures. Other types of hazards are sort
5 of overlaid to that and then brought forward. But --

6 MEMBER MARTIN: I mean, as a historical
7 basis, if you go back 60-plus years ago, we had kind
8 of a technology-inclusive approach, right? Because
9 the technology -- whether it was light-water reactors
10 or sodium reactors, et cetera -- we hadn't quite
11 figured out what that was going to be.

12 Rather than a safety analysis report, we
13 headed a hazard evaluation organization at the AEC.
14 And that terminology, I think, was because -- you
15 know, when you don't know what the technology is that
16 might be proposed, it really comes about what are the
17 hazards -- the emphasis is what can hurt people and
18 what can cause that.

19 And personally, I have a bias towards the
20 term hazards evaluation, but it is in the DNA of the
21 regulator, whether it's NRC or the AEC, to use that
22 terminology -- begin with that terminology -- and
23 everything flows from hazards analysis.

24 Obviously, all these things that we're
25 talking about will show up when you do it. And you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 attack all those things in different ways. And yes,
2 we have reg guides that are already attacking all the
3 external hazards because, of course, it's been
4 emphasized in Part 50 and Part 52 already.

5 But there isn't a overarching view other
6 than you should do something. Now, more likely, that
7 just gets addressed in guidance, but I do feel like it
8 should be emphasized at that highest level of hazards
9 analysis without putting a label of external,
10 necessarily, in front or in part. We just -- you
11 begin at a higher level, and then the hierarchy flows
12 from there.

13 MEMBER HALNON: Walt, you had a question?

14 MEMBER MARTIN: Yeah. I'm a little
15 preachy, but --

16 MEMBER HALNON: I didn't mean to cut you
17 off, but Walt had a question.

18 Go ahead, Walt. Walter, you're muted.

19 MEMBER KIRCHNER: Thanks. I didn't hear
20 you, Greg.

21 I'm curious about the choice of wording
22 here on this sub-bullet for 53.415. Just for context,
23 the existing fleet -- many of the systems that are
24 relied on in a holistic sense for the overall safety
25 of the plant are protected by a hardened containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So -- and specifically, those that are safety-related
2 are also protected accordingly.

3 Why did you use safety-related -- this
4 sounds restrictive because my concern is this, that if
5 an applicant has a very limited number of safety-
6 related systems that are protected against external
7 hazards or has a very limited number of safety-related
8 systems, period, the plant as a whole may not be
9 adequately protected against external hazards.

10 The general design criteria uses the
11 terminology, important to safety. So SSCs important
12 to safety should be -- shall be designed and
13 protected. So do you really mean this, just safety-
14 related, those that come out of the SSC classification
15 process -- those will be protected against external
16 hazards, but the rest of the systems may not? I find
17 this a concern.

18 MR. GILBERTSON: Yeah. Yes, that is what
19 we mean. And I think that when that notion is taken
20 together with the things that would be done to satisfy
21 the requirements for defense in depth and
22 understanding that if on a plant-wide basis, you have
23 a limited set of or a smaller set of safety-related
24 SSCs that are protected against these external
25 hazards, and then a much larger set that are not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 necessarily or to a much lesser degree, that's the
2 type of thing that the PRA would hopefully reveal,
3 that okay, your layers of defense for the event
4 sequences that extend into the very unlikely event
5 sequence frequency range -- whatever that would be
6 defined as -- you have less capability there because
7 you're not protecting the systems against --

8 MEMBER KIRCHNER: Well, but wait a minute.
9 Stop. I mean, there are a lot of external events that
10 are highly likely. Tornadoes are a good example,
11 protecting against telephone poles and other tornado-
12 induced missile hazards. That's a very real, not
13 highly unlikely, event -- flooding, et cetera.

14 I have a general concern with this
15 because, especially as we go to smaller reactors,
16 these are not likely to have the kind of structure
17 that we see with the current fleet and the inherent
18 protection that comes from something like a large
19 containment structure.

20 So external hazards may be one of the
21 Achilles heels for some of these smaller microreactors
22 and other systems that are under consideration. And
23 so, to make this restrictive, if they were to use 53
24 -- I'm just concerned with the restrictive nature of
25 this.

1 Now, yes, you're correct, a thorough PRA
2 would look at those other natural hazards, whether
3 it's a natural phenomena, a fire, and/or -- you know,
4 I'm looking at criteria 2, 3, and 4 of the GDCs.
5 Those may be the dominant hazards for these smaller,
6 lightly deployed systems. So to just restrict it to
7 safety-related just seems to be not the holistic look
8 that one would expect.

9 And so, yes, you're right, if it's
10 thoroughly exercised, the PRA would look at that and
11 then tell you additional measures may be necessary.

12 MR. RECKLEY: Yeah. Anders, this is Bill,
13 if I can -- Bill Reckley, if I can chime in here a
14 little bit so people don't misinterpret what we're
15 saying here.

16 415 is saying safety-related SSCs have to
17 be protected at least up to the design basis external
18 hazard level, which would be the traditional approach
19 for safety-related equipment and defining a design
20 basis external hazard level, like a safe shutdown
21 earthquake.

22 However, non-safety-related but safety-
23 significant SSCs will be evaluated against seismic
24 events, as Anders said, through the PRA assessments,
25 and that could include external hazards that exceed

1 the design basis external hazard level -- an
2 earthquake that's stronger, for example, higher
3 magnitude. And the fragility of those SSCs will get
4 looked at and considered within that PRA. And
5 additional special treatments may be assigned to those
6 if they have to be in order to meet those criteria.

7 So I just don't want to leave the
8 impression that only safety-related SSCs are being
9 protected. No. They're being protected against a
10 minimum. All SSCs that are safety-significant or,
11 using the old term, important to safety will get
12 looked at from the effect of external hazards.

13 (Simultaneous speaking.)

14 MEMBER KIRCHNER: Okay. Thanks, Bill.
15 Maybe I just read too much into this safety-related
16 lead-up to that. But yeah. If, indeed, you feel that
17 the rule as you've got it, as written, is
18 encompassing, then I'm okay. I was just reacting,
19 maybe, to the graph presentation.

20 MR. RECKLEY: Right. And I'll say rule as
21 we intended -- comments and other things will say
22 whether we actually captured it correctly.

23 But sorry, Anders. Go ahead.

24 MEMBER KIRCHNER: Yeah. Thank you.

25 MR. GILBERTSON: Okay. Thanks, Bill.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Okay. So I'm going to keep moving here.
2 The proposed 53.420 -- so this just relates to the
3 functional design criteria for design features that
4 play a significant role in demonstrating that the
5 safety criteria in 53.220 would be satisfied. So,
6 again, you see this dichotomy between 410 and 420,
7 between the design basis -- licensing basis events for
8 other than design basis accidents.

9 As Bill was kind of alluding to here, the
10 SSCs that are determined to be safety-significant
11 would have associated requirements for special
12 treatments. Those would be provided for under 53.460.
13 We don't have a slide on that later on, but I'll just
14 generally say that in special treatments, it would
15 generally refer to those measures taken beyond the
16 procurement and installation of commercial-grade
17 products to provide confidence that the SSCs would
18 comply with the applicable functional design criteria.

19 Okay. Let's move to slide 27, please.

20 Okay. So this is now getting into the
21 design requirements. The proposed 53.440 would
22 provide various requirements specifically included to
23 ensure the design features required by 53.400 would
24 comply with the functional design criteria required by
25 53.410 and 420. So the requirements in 53.440 would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 be met through design practices, consideration of
2 testing and operating experience, and various
3 assessments of LBES and other potential challenges.

4 I think I'm going to emphasize here that
5 53.440(a) had an item that was added back to it that
6 related to SRM Item 7, and this directed the staff to
7 include the requirement for a design experience
8 program that corresponds to 10 CFR 50.34(f)(3)(I),
9 which is under the Three Mile Island-related
10 requirements. And we did that. That was a relatively
11 straightforward change.

12 Otherwise, 440(a) would provide
13 requirements to demonstrate that each of the design
14 features would -- well, I'm sorry. This -- it closely
15 aligns with the requirements for 10 CFR 50.43(e)
16 regarding the use of analyses, test programs,
17 prototype testing, and operating experience to
18 demonstrate the performance of a given design feature.
19 Just wanted to note that.

20 The rest of these -- I'm going to go
21 through these relatively quickly so we can start to
22 catch up a little bit. 440(b) would require that the
23 design features be designed using generally accepted
24 consensus codes and standards that would have been
25 endorsed or otherwise found acceptable by the NRC.

1 53.440(c) would require materials used for
2 the safety-related and non-safety-related but safety-
3 significant SSCs be qualified for their service
4 conditions over the design life of the SSC.

5 53.440(d) would require consideration of
6 possible degradation mechanisms for materials and
7 equipment to inform both the design processes and
8 development of integrity assessment programs. And
9 this would be active during the active operational
10 phase in accordance with those requirements in subpart
11 F of the proposed Part 53.

12 Sections 53.440(e) and (f) would provide
13 design requirements similar to the existing
14 requirements in Parts 50, 52, and 73 for protections
15 against fires and explosions and consideration of
16 safety and security together in the design process.

17 53.440(g) and (h) would require that
18 commercial nuclear reactors have the capability to
19 achieve and maintain subcriticality and long-term
20 cooling, which includes potential for further actions
21 to completely shut down and service a facility that
22 has already achieved a safe and stable end state.

23 53.440(i) would require consideration of
24 the number of reactor units and other significant
25 inventories of reactor materials riveting to the risks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 to the facility and public health and safety.

2 53.440(j) would provide requirements
3 similar to those in 10 CFR 50.150 as it relates to
4 possible impacts of large commercial aircraft.

5 MEMBER MARTIN: I'll just stop you on that
6 one. I find this one particularly interesting because
7 it effectively puts a deterministic design requirement
8 on plants that are supposed to be, you know, lower
9 profile, smaller. It doesn't seem to have the risk-
10 informed element to it.

11 And I wonder if this just forces everyone
12 to put their plant underground, you know, or firmed up
13 or -- we don't want hardened containments, right? I
14 don't know how much feedback you all have gotten on
15 this particular one, but I don't know what the right
16 answer is. I'm not going to judge it, per se, but I
17 do think it creates a design requirement that it's
18 going to be more expensive, for sure, if you want to
19 stay above ground, for instance.

20 I don't know. I mean, have you gotten
21 feedback particularly on this requirement, and is
22 there pushback? Or what's the conversation from your
23 engagement with industry folks, specifically on
24 aircraft impact?

25 MR. GILBERTSON: I don't think that we

1 have gotten any specific feedback, but I know that
2 other staff have been working specifically on this and
3 some other related stuff. I guess maybe I would ask
4 Nan or Bill if they have any additional insight to
5 share.

6 MS. VALLIERE: Yes. This is Nan Valliere
7 again from the Advanced Reactor Policy Branch of NRR.
8 So Anders is right that we did not get a lot of
9 feedback on this particular item from external
10 stakeholders during development of the draft proposed
11 rule.

12 However, since that time and with all the
13 activities related to microreactors that have been
14 undertaken, this area is an area of significant
15 discussion. So, yes, we are looking at what other
16 possibilities could be undertaken with regard to
17 aircraft impact requirements for microreactors. Of
18 course, the aircraft impact rules are directed by the
19 Commission. So it was -- we couldn't exactly leave it
20 out completely, but we are -- yeah, the staff is
21 looking at ways --

22 MEMBER MARTIN: Yeah, it's just more risk-
23 informed elements to it. And I don't -- no one knows
24 the answer today. Otherwise, I wouldn't have asked my
25 question. But nonetheless, it's good to hear that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 are getting some feedback now and that you're
2 synthesizing and processing it. So that answers my
3 question.

4 MR. GILBERTSON: Okay. Thanks, Nan.

5 Okay. Moving along here, 53.440(k) --
6 this would require risk to public health and potential
7 chemicals hazards of licensed material -- it would
8 prohibit the diversity of reactor technologies designs
9 that might be licensed. So this would be similar to
10 the existing requirements in Part 70 that address both
11 potential radiological and chemical hazards for
12 licensed materials at fuel cycles.

13 53.440(l) would require that measures be
14 taken during the design of commercial nuclear plants
15 to minimize contamination of the facility and the
16 environment, facilitate eventual decommissioning, and
17 minimize generation of radioactive waste in accordance
18 with 10 CFR 20.1406.

19 MEMBER BALLINGER: This Ron Ballinger.
20 With regard to K, that's kind of an iceberg. You say
21 licensed material. For some of these plants, they're
22 going to use chemicals that may not be licensed, but
23 they're there. And so those chemicals can create a
24 hazard which is maybe worse than the licensed
25 material. So does this account for that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. GILBERTSON: This -- I would have to
2 -- I think I'm going to have to get back to you.

3 Yeah, Nan?

4 MS. VALLIERE: So, again, this is chemical
5 hazards associated with a licensed radioactive
6 material and any chemical hazards that would be --

7 MEMBER BALLINGER: Okay.

8 MS. VALLIERE: -- intermingled with that.
9 It's not talking about regulating chemicals by
10 themselves.

11 MR. GILBERTSON: Yes.

12 MS. VALLIERE: This is consistent with how
13 this is handled in other parts of the NRC regulations,
14 division of duties between federal agencies.

15 MR. GILBERTSON: Yeah. Okay. Okay. So,
16 moving on to 53.440(m), this would include a
17 requirement equivalent to 10 CFR 50.68, providing
18 options to either have criticality monitoring
19 capabilities, meaning the requirements under 10 CFR
20 70.24, or to have restrictions on handling and storage
21 of special nuclear material that would prevent
22 inadvertent criticality events.

23 And finally, 53.440(n) would require that
24 the design of a facility would need to reflect state-
25 of-the-art human factors principles for safe and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reliable performance in all the settings that human
2 activities are credited.

3 Okay. Let's move on to slide 28, please.

4 So Items (e) and (f) I've already touched
5 on, so I'm going to talk about just some of the other
6 items here. 450 -- 53.450 -- these would establish
7 the requirements for analysis and would center on the
8 use of the PRA in combination with the other generally
9 accepted approaches for systematically evaluating
10 engineered systems.

11 As we talked about before, the PRA is a
12 key component in the proposed analysis requirements
13 and reflects decades of improvements in PRA
14 methodologies and the increase in use of PRA
15 techniques in design licensing and oversight.

16 The Part 53 proposed rule would maintain
17 a role for the NRC's traditional deterministic
18 approaches, particularly, as I mentioned before, as it
19 relates to DBAs and the defense in depth philosophy by
20 including proposed requirements previously mentioned.

21 Specifically, 53.450(a) would provide a
22 requirement for the use of a PRA, identifying
23 potential failures, susceptibility to
24 internal/external hazards, and other contributing
25 factors to event sequences that can challenge the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 safety functions and would otherwise support
2 demonstrating that the safety criteria for 53.220 are
3 met, or restricted alternative criteria essentially
4 adopted under 53.470.

5 53.450(b) includes requirements for the
6 specific uses of the PRA or specific uses of the
7 analyses, which would include using the PRA together
8 with those other acceptable techniques. And this
9 would relate to identifying and categorizing LBEs,
10 classifying SSCs, and evaluating defense in depth.
11 So, again, it parallels to LMP per our pre, here or
12 there.

13 And the increased role for the PRA
14 necessarily means it would need to be developed,
15 performed, and maintained in accordance with NRC
16 approved standards and practices. And to that point,
17 53.450(c) would require periodic maintenance and
18 upgrading of the PRA, which would ensure that there's
19 alignment between the supporting analyses and the
20 design and performance of plant equipment, programs,
21 and procedures and other factors associated with
22 meeting the 53.220 criteria.

23 These periodic assessments -- they would
24 be performed by licensees but would be supported and
25 complemented by NRC inspections and programs to assess

1 new or revised information for topics, such as
2 chemical hazards, operating experience, et cetera.

3 53.450(d) would require that computer
4 codes used to model the plant response and behavior of
5 the barriers to release of radionuclides -- that those
6 would all be qualified for the range of conditions
7 that are being simulated across the range of unplanned
8 events.

9 I'm going to skip now down to 53.450(g),
10 and this would require that the analyses are performed
11 to support the design requirements of 53.450(e) on
12 fire protection and 53.440(j) on aircraft impact
13 assessment, and the 53.425 requirements on using
14 design features and programs to control doses to
15 members of the public resulting from normal operation.

16 MEMBER MARTIN: The statement there --
17 doses to members of public -- how is that different
18 than E and F? I mean, ultimately doses is a principal
19 thing you look at. Is that something unique in other
20 required analysis associated with doses?

21 MR. GILBERTSON: I guess it gets just to
22 ensure that you're meeting the requirements for 10 CFR
23 Part 20 as it relates to normal operations, is
24 essentially what that's relating to.

25 MEMBER MARTIN: Okay.

1 MR. GILBERTSON: So your analysis was part
2 of -- analyses were supporting that and demonstrating
3 this.

4 And so I'll just note here, because we're
5 -- we'll move on now to the next subparts --

6 DR. BLEY: Anders, this --

7 MR. GILBERTSON: Yes.

8 DR. BLEY: This is Dennis Bley. I hadn't
9 thought about this in the past because we haven't
10 reviewed an application for -- I'm thinking
11 microreactors now. But in G, you flagged a few things
12 that are typically a measure of importance in the
13 analysis for our large LWRs.

14 But with these sometimes portable systems,
15 there's probably different hazards. They could get up
16 close to the chemical facility that might have a
17 BLEVE. That's a different kind of fire protection
18 where they could be hit by other things than aircraft
19 that might be very significant, and I think we're kind
20 of locked here on what we know from LWRs.

21 And I haven't searched that in my own
22 mind, but I wonder if you folks have. And I think you
23 ought to.

24 MR. GILBERTSON: Okay. I would just maybe
25 say that, you know, other types of hazards for those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 types of situations, they might be addressed through,
2 like, industrial transportation hazards that a smaller
3 reactor might be exposed to. Consideration of those
4 types of scenarios, just as a thought.

5 MEMBER HALNON: Hey, Dennis, this is Greg.
6 If you remember back to the reg guide that goes with
7 the new Part 50.160, which I believe this is going to
8 point back to, has you look at those types of hazards
9 for the emergency plan.

10 DR. BLEY: Yeah, and I don't remember the
11 details, if it's been really thought out. I was even
12 thinking of -- you know, we know the military is
13 looking to use microreactors. They might be impacted.
14 We don't usually think about weapons, but they might
15 be supporting a facility, and a testing of weapons
16 nearby could end up causing an impact, too.

17 So, if that covers it well, that's great,
18 Greg. But I don't remember the detail in that.

19 MR. RECKLEY: I'll go back and look to
20 make sure on the slides, but I'm pretty sure that that
21 was part of the development of the emergency plan,
22 which would be this portion of the regulation as well.

23 MR. GILBERTSON: Okay. I'll just wrap up
24 subpart C by saying I talked a little bit about the
25 requirements for safety categorization and special

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 treatments. Those would be under 53.460. The
2 requirements under 53.470 related to maintaining
3 analytical safety margins used to justify operational
4 flexibilities. That's using more restrictive
5 criteria. That as well as 53.480 on earthquake
6 engineering, there were no substantive changes to
7 those. But those provide requirements to help inform
8 those analyses that would -- just since we didn't
9 include those items on the slides here.

10 Let's go to slide 29 so I can talk about
11 PRA acceptability and then go through subpart D so I
12 can hand it off to Bill here.

13 So the item -- SRM Item 3, this directs
14 the staff, in part, to revise the proposed rule or
15 preamble as appropriate to convey that consensus PRA
16 standards should not be applied as a strict checklist
17 of requirements for PRA acceptability determinations
18 but should instead allow appropriate flexibility,
19 considering how PRA insights are used together with
20 other factors.

21 So the staff addressed this by revising
22 the preamble to address the Commission's direction and
23 provide additional explanation of how the NRC's
24 regulatory guidance on PRA acceptability is currently
25 used in decision-making and could be applied under the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Part 53 proposed rule.

2 And just to point out a few aspects of
3 this, there are existing regulatory guidance documents
4 -- Reg Guide 1.200 for light-water reactors and Reg
5 Guide 1.247 for non-light-water reactors -- that
6 provide guidance on acceptability of PRAs used in
7 risk-informed decision-making. Those are available.
8 They endorse light-water reactor and non-light-water
9 reactor PRA standards.

10 But the use of those standards and the
11 guidance is not regulatory requirement. And
12 applicants under Part 53 may not need to follow every
13 aspect of an applicable consensus PRA standard
14 endorsed by the NRC. And to that point, I'll
15 specifically talk about the non-LWR PRA standard. It
16 includes a process for defining the scope and
17 capability of a PRA supporting an application. And
18 that's as based on the needs of the application.

19 So this is intended to -- you know, offers
20 flexibility in determining the degree to which the PRA
21 needs to be developed. It may be informed by factors
22 such as design complexity and the degree of realism.
23 So we touch on that in the preamble and note that
24 those processes are available and that NRC
25 determinations of PRA acceptability would include

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 consideration of the appropriateness of the scope and
2 capability of the PRA defined by the applicant.

3 So that's essentially how we had addressed
4 that item. There were no changes to the rule text
5 itself.

6 MEMBER MARTIN: So basically, saying that,
7 you're standing by your existing guidance on PRA
8 acceptability.

9 MR. GILBERTSON: Yes, and that available
10 processes can be used to define what that scope is.
11 One could reduce the scope of the PRA and use that in
12 conjunction with other types of analyses, like I
13 talked about before, to create a sort of blended
14 explanation of how those different risk metrics -- or
15 whatever the outputs, how those work together to
16 justify the safety case.

17 MEMBER MARTIN: Thanks.

18 MR. GILBERTSON: Okay. Let's move to
19 slide 30, please.

20 Okay. So subpart D, it has the
21 requirements for siting. And just to touch on these
22 at a very high level, 53.500 would establish
23 requirements for licensees and applicants to assess
24 the impacts that a site and its environs may have on
25 a commercial nuclear plant and potential adverse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 health and safety impacts a plant may have on nearby
2 populations relative to the characteristics of a given
3 site.

4 53.510 relates to external hazards, and
5 this is a callback to the reference and define basis
6 external hazard levels; these have to be identified
7 and characterized based on site-specific assessments
8 of natural and human-constructed hazards with the
9 potential to affect plant functions and with a focus
10 on requirements related to seismic siting factors.

11 Section 53.520 would require applicants to
12 identify and assess site characteristics related to
13 topics such as meteorology, geology, hydrology, and
14 other areas in a design and analysis required under
15 subpart C.

16 53.530 would provide requirements for
17 population-related considerations and maintain
18 requirements and definitions similar to those used in
19 Part 100 for an exclusion area, low-population zone,
20 and population center distance.

21 And just to note, the NRC's longstanding
22 preference for siting reactors in areas of low-
23 population density would be maintained in Part 53 by
24 using the current language from Part 100 for
25 53.530(c).

1 And finally, the proposed 53.540 would
2 require that site characteristics be appropriately
3 considered with other activities, such as the design
4 and analysis performed and the (audio interference)
5 under proposed subpart F.

6 Okay. So that concludes my portion of the
7 presentation. Unless there are any questions, I would
8 -- I'll hand it off to Bill Reckley to take the next
9 of the slides.

10 MR. RECKLEY: Okay. Thank you, Anders.
11 Thank you, Anders.

12 This is Bill Reckley, and I'll be covering
13 subpart E.

14 If we go to the next slide, subpart E
15 addresses construction and manufacturing. And if we
16 can just go to the next slide on manufacturing, the
17 higher level requirements on organization, management,
18 and control for manufacturing under proposed 53.620 is
19 similar to that defined for construction under 610.
20 But the area highlighted here, fuel loading, is one we
21 wanted to focus on today.

22 I would just note at the bottom there --
23 when we came to the ACRS in late 2022, we had a
24 provision for fuel loading in the paper that you all
25 looked at. In between your review and sending up the

1 draft proposed rule, the staff removed that. And now,
2 basically, the Commission has instructed us to put it
3 back, or put something back in its place. So that's
4 what we're going to focus on in this section. Most of
5 the other areas in 620 and 610 for construction were
6 not changed.

7 So, got a question?

8 DR. BLEY: Yeah, Bill, Dennis Bley. I
9 think in the introduction, it was pointed out that you
10 folks were working on a white paper related to
11 manufacturing. Is that related to this or is it
12 related to something that might be changing in the
13 draft rule? What's it's --

14 (Simultaneous speaking.)

15 MR. RECKLEY: Yeah, I'll get to that in a
16 -- I'll get to that in a slide or two. But shortly,
17 what that relates to is that the SRM also directed us
18 to explore the potential to allow operational testing
19 within the manufacturing facility. So what we did
20 include was fuel loading. What we did not include was
21 testing in the factory. And I'll get to that in a
22 couple slides.

23 DR. BLEY: Okay, thanks.

24 MR. RECKLEY: So if we go to slide 33, we
25 did include in the proposed rule as released for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 comment, proposed 53.620(d), for fuel loading which
2 both authorizes the loading of fuel into a
3 manufactured reactor and sets some requirements for
4 that. The first requirement is that we're only at
5 this time addressing fresh or unirradiated fuel. And
6 that would be loaded into a manufactured reactor.

7 And we would use the provisions of Part 70
8 on the control of special nuclear material to
9 basically lay out what the requirements were for this
10 activity. One of the key provisions was that 620(d)
11 includes a requirement for two independent physical
12 mechanisms to prevent criticality. And another
13 important part of this proposed section is that the
14 Commission -- it includes a Commission finding that
15 the manufactured reactor module in the configuration
16 with those critical prevention features in place is
17 not in operation.

18 And this is just -- reflects that
19 historically if you look at the difference between the
20 construction permit, the operating license, the
21 difference between, in Part 52 when we make the
22 52.103(g) finding, those are keyed off of loading of
23 fuel. And so we wanted to include a provision that
24 says something different. You can load fuel. And as
25 long as these criticality prevention features are in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 place, you're not in operation. Dennis?

2 DR. BLEY: Yeah, I was just thinking about
3 spent fuel and the casks. And NRC's role in
4 certifying the casks is that any protections built in
5 the casks have to survive the drop test which were
6 pretty severe. Reactors moving across the country
7 could run into the same kind of problems. How does
8 that apply here?

9 MR. RECKLEY: Well, we're addressing in
10 this section the conditions in the factory or in the
11 manufacturing facility. For shipment, it would still
12 need to meet the requirements of Part 71 which
13 includes what you just mentioned. So --

14 DR. BLEY: Okay. So it'd be essentially
15 the same as for a spent fuel cask.

16 MR. RECKLEY: Yes, or fresh fuel as it's
17 being shipped.

18 DR. BLEY: Or fresh fuel, sure. Okay.
19 Thank you.

20 MR. RECKLEY: Okay.

21 MEMBER PALMTAG: This is Scott Palmtag.
22 I've got a question about this. So normally in a
23 reactor, you load the fuel and you have fuel power
24 physics testing to kind of confirm that it's loaded
25 correctly because you could have the wrong enrichments

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 or wrong BPs. How are you going to confirm that your
2 fuel is loading correctly if you don't allow testing?
3 I mean, it could be loaded incorrectly and then
4 shipped across the country in a wrong configuration.

5 MR. RECKLEY: Well, and that's part of the
6 argument to allow testing in the factory. And I'll
7 get to that in a couple slides. Short of that as
8 we've addressed it in the proposed rule as it was
9 released, you would do as much of the verifications as
10 you could.

11 And that could include both visual and
12 procedural controls, any non-nuclear testing that you
13 could do, or using non-criticality type testing, so
14 even if you were using radioisotopes to support some
15 of your verifications. But again, we stop short. The
16 additional testing would need to be done then at the
17 site, the final place of operation.

18 That's where -- under what we have
19 currently, that's where additional zero power physics
20 testing, confirmations would need to be done. As
21 you're alluding to, that could introduce problems
22 because now you're shipped it. You've installed it.

23 Now you find an error. And for small
24 microreactors, it might be problematic then because
25 the site to which you're shipping it may be a mining

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 facility, some remote location. May not want to have
2 full capability to do a reconfiguration or reloading.

3 And so that's the reason some people have
4 asked for factory testing. But again, we recognize
5 that. And if we go actually to the next slide, this
6 just has some additional things.

7 It's basically the same as I've already
8 mentioned. So we can go to the next one under slide
9 35 -- yeah, there we go -- that we included per the
10 directions in the SRM a question on factory testing.
11 And so this is the question that's included in the --
12 this is the direction in the SRM.

13 And then in response to this, we included
14 a question in the Federal Register Notice. And then
15 we also provided -- and this goes to Dennis' point --
16 a white paper that gave some initial thoughts on how
17 this would work. And as you can imagine, it adds
18 additional complications when you're proposing to load
19 fuel, do testing, then restore a manufactured reactor,
20 then ship it, and then install it at the final place
21 of operation.

22 From a licensing perspective, you're not
23 only dealing within special nuclear material and the
24 manufacturing license. You're dealing now with an
25 operating license and the introduction of byproduct

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 material. And so what we did in the white paper was
2 to lay out how we thought this might work.

3 And I wasn't going to get into detail in
4 the white paper. We can if time allows, maybe
5 afterwards. Because the white paper, we only issued
6 to solicit comments to see if this was a feasible
7 approach to help people think through all of those
8 interrelationships between parts.

9 And the comments that we received on that
10 might be it will work and then we'll take that up with
11 ACRS as we go through the comment resolution. But we
12 also might get a comment or comments from potential
13 users that say it was a nonstarter. So it wouldn't be
14 of much point to go through it today.

15 So if we go to the next, slide 36, this is
16 the question that we included in the Federal Register.
17 And basically it is, should we include provisions?
18 And as we've heard, there are some practical arguments
19 as to why it might be a good idea to allow that kind
20 of testing.

21 One of the things we were trying to get to
22 in the question in the Federal Register and also in
23 the white paper where we gave a possible approach is,
24 what would be the limits on operation? Could it be
25 done where you try to do it at low power levels in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 short durations? Because the more operation occurs,
2 the more byproduct material is introduced.

3 That introduces obviously shielding
4 questions. It raises the complexity of transport and
5 installation at the final place of operation. So, how
6 much could we limit operations associated with this
7 testing in order to minimize the amount of byproduct
8 material that would be introduced?

9 If you set out these kind of controls,
10 limited power levels, loading with fresh fuel, then
11 what current limitations on operations in Part 53, the
12 proposed Part 53, might be relaxed? For example, when
13 we had talked a little earlier about aircraft impact
14 assessment, if it's fresh fuel, if it's limited such
15 that there's limited byproduct material that has not
16 only release category -- I mean, the inventory, it
17 also is going to determine things like how much decay
18 heat. How much heat removal might I need?

19 But if I appropriately minimize all of
20 those operations, might aircraft impact assessments
21 not be needed? Might I revise even other external
22 hazards? So this is a question we ask in the FRN. Go
23 to slide 37.

24 One of the important areas that we asked
25 is within the requirements, what would be the role of

1 the actual manufacturing facility? And if the
2 manufacturing facility is playing a key role, then how
3 would it interplay with things like the definition of
4 construction, the operating requirements under subpart
5 F, the personnel requirements under subpart F? So
6 again, just to have people think through, on these
7 reactors that might be loaded and tested, what is the
8 role of the factory itself?

9 Would the testing be done in a special
10 area that would have the ability to isolate that area?
11 Maybe the ventilation system then becomes a design
12 feature that's credited in the licensing basis events.
13 In addition to the manufactured reactor, you would
14 have the ventilation system associated with the
15 testing room. So again, we're just asking people to
16 think through how all the puzzle pieces would fit
17 together.

18 MEMBER HALNON: Bill, this is Greg Halnon.
19 Did that puzzle go all the way to potential
20 decommissioning of the manufacturing facility?

21 MR. RECKLEY: Yes.

22 MEMBER HALNON: Okay, thanks.

23 MR. RECKLEY: And in the white paper, we
24 kind of addressed this with some various thoughts on
25 how that might be done and whether subpart G for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reactor facility is appropriate. Or maybe it could be
2 done more in line with Part 70 of a fuel cycle
3 facility. So all of those questions, again, this just
4 raises -- it basically brings all of the NRC reactor
5 regulations into play and everything needs to be
6 thought about, all the way through decommissioning, so
7 yes.

8 Then lastly on this slide, what licensing
9 mechanisms should be used? There's different
10 approaches. The staff put out a paper a year or two
11 ago on microreactors that brought up some of these
12 various possibilities. Every manufactured reactor
13 could receive its own license. So we could do this
14 individually.

15 There's also the capability to issue a
16 single combined license that would address the
17 manufacturing facility and it could support multiple
18 manufactured reactors. So kind of -- this is the
19 approach that we modeled in the white paper that we
20 released. So one COL would be issued, and then there
21 would be a process but not relicensing for each
22 manufactured reactor.

23 And then how to handle inspections, tests,
24 analyses, and acceptance criteria or ITAAC, keeping in
25 mind that Part 53 adopted much from Part 52. And so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 manufacturing licenses would include ITAAC. And it
2 makes sense that those ITAAC would -- some of those
3 ITAAC would need to be addressed if you were going to
4 do operational testing in the factory.

5 MEMBER HALNON: I think it's interesting.
6 I'm glad to see you're asking the right questions.
7 Just in my mind, I find it hard to believe that you
8 would not want to test this before you send it out.

9 I mean, like you said, if you manufacture
10 this, you send it out into the field into a remote
11 mine, you try to start up, it doesn't work. What's
12 your options? Ship it back to the factory? But I'll
13 wait and see what you come up with. Thank you.

14 MR. RECKLEY: Thank you.

15 DR. SCHULTZ: This is Steve Schultz. I
16 agree that this may have utility for certain reactor
17 types. You've really laid out a pretty good draft of
18 what will be the requirements moving forward for it,
19 what you presented here and what is in the detailed
20 descriptions which you prepared.

21 It just will be interesting to see what
22 utility of the testing within the manufacturing
23 facility will have for different types of reactor
24 designs. I can see if for a microreactor. When
25 you're looking for SMRs with nth of a kind type of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 design expectations and commercial expectations, it
2 may not be useful.

3 MEMBER HALNON: This is Greg. It seems
4 like the amount of time that you would be in, quote,
5 operational mode, versus the amount of time that it's
6 going to be on site operating, your risk numbers are
7 going to be different. I mean, you have to think, to
8 me, that period of time, if you're going to operate it
9 for hours and it's got a 40-year life, it seems like
10 the risk of it might be low. I don't know. So it
11 seems to me this needs to be looked at from a risk
12 informed perspective as well, not just all the
13 regulations apply. And some may not apply just
14 because of the low frequency potential.

15 MR. RECKLEY: Right. And we did try to
16 address that by saying the assessment, the safety
17 analysis, the risk assessment done for this operation
18 within the factory should reflect the manufactured
19 reactor as it's being tested. So that would mean low
20 decay heat, for example. If you have low decay heat,
21 then you have associated much reduced requirements for
22 heat removal system, right?

23 So it is possible that they could go
24 through this. And basically the identification of
25 possible malfunctions and events would result in there

1 not being nearly as much in terms of what needed to be
2 controlled and give them additional flexibility in
3 comparison to the long term operation at the place of
4 operation. So yes, we'll see.

5 And to Steve's point, this probably is a
6 niche, right, for SMRs that are going to be routinely
7 refueled, whether that would be anything that would be
8 done in the factory versus done at the site since
9 you're planning to do refuelings anyway. That may not
10 really come into play for many reactor designs. But
11 for the microreactors, this is a potential niche. So
12 if there's no more questions on this, I'll go to --

13 MEMBER PALMTAG: This is Scott Palmtag
14 again. I agree. That really is for microreactors.
15 If you have an SMR where you're going to be able to
16 refuel it on site, you can do more testing there.

17 But this is would be for microreactors.
18 What Greg said is correct. I mean, you're going to
19 have no dosimeters. There's basically going to be no
20 dose or decay heat.

21 But one way around it would be require the
22 manufacturing facility to have a site license. I
23 think that would cover it. It would be interesting to
24 see what you come up with.

25 MR. RECKLEY: Yeah, and so far, the white

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 paper reflects that, the low dose considerations.

2 MEMBER KIRCHNER: Bill, this is Walt
3 Kirchner. Forty years ago, I had to think through all
4 these issues. I think what we determined at the time,
5 we were looking at a first of a kind and then 13 more
6 microreactors.

7 And I'll just remind people that once --
8 depending on how these are transported, you pretty
9 much will have to repeat all your startup testing at
10 the actual deployed site. So our assessment at the
11 time was to approach criticality but not build up any
12 significant inventory because it turned out that
13 shielding considerations and transport and the size
14 container -- certified container needed pretty much
15 dominated the logistics considerations. And then as
16 you earlier pointed out, if it indeed is a very
17 modular small system like a microreactor, then you've
18 got to be concerned about exposure personnel at the
19 site when you erect it once it comes out completely
20 intact from the manufacturing facility.

21 But you would still have to look at the
22 transportation loads that the module was subjected to.
23 And so you would pretty much, I think, find yourself
24 repeating your ITACs as you point out. So just an
25 observation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I mean, obviously, if economics weren't an
2 issue for microreactors that were going to have a
3 large number nth of a kind, then having a prototype
4 and doing all of this and then actually replicating
5 that prototype, you wouldn't need to do further
6 testing. You'd just do your kind of startup testing
7 once you're at the deployed site for the nth of a
8 kind. You wouldn't do it with each individual one
9 other than the quality checks that you would do in the
10 assembly phase.

11 So just an observation. I think Scott's
12 observation is also appropriate here. Probably most
13 SMRs of any size are going to have to design for
14 refueling and decommissioning. And that's also a
15 consideration for the microreactors, depending on size
16 and shipping container availability that you may have
17 to disassemble in the field to deal with the spent
18 fuel. But it's likely that most SMRs of significant
19 size would have to design for refueling.

20 MR. RECKLEY: Yes, thank you. And a good
21 point that you made in there is that the ITAAC would
22 -- there would be ITAAC at the final place of
23 operation. And that would support the actual
24 operating at that location.

25 And to whatever degree it needed to also

1 verify that nothing was adversely done during
2 shipping. So if we go to slide 38, I think I want to
3 turn this over to Jesse and give him a chance to talk
4 about the unique operating staffing and operation
5 stuff that we put into Part 53. So moving from
6 subpart E to subpart F on operations, subpart F is
7 divided basically into three parts.

8 And that is the configuration control for
9 the plant equipment, making sure they have the
10 capabilities and availability and reliability that was
11 established through subparts B and C. Then there's
12 the personnel, and then there's the plant programs.
13 And so there in the bottom, it basically says the
14 first part is addressing the plant equipment.

15 The middle part that Jesse is going to
16 talk to momentarily is talking about the plant
17 personnel. And then the last sections in subpart F,
18 845 through 910 are dealing with the plant programs
19 like radiation protection, quality assurance,
20 emergency planning, security, and those things that
21 we're not going to talk about today just because they
22 didn't change very much. But we did want to refresh
23 everyone on the personnel requirements. So if we go
24 to slide 39. And Jesse, if you're around, if you
25 could take over.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. SEYMOUR: Thanks, Bill. I appreciate
2 it. My name is Jesse Seymour, and I'm an Operator
3 Licensing Examiner, Human Factors Technical Reviewer
4 in NRR.

5 And I'm going to be providing a relatively
6 brief overview of subpart F's provisions for personnel
7 and human system considerations. These span 53.725
8 through 53.830. And I'm just going to be highlighting
9 some of the more significant elements of those
10 sections.

11 At a high level, I'd like to say that most
12 of the substance of these sections did not change in
13 response to the SRM. We had previously integrated
14 Framework A and B under this particular section. So
15 the same requirements applied with respect to the
16 framework.

17 But we did have to go through and make
18 some editorial changes to pointers and so forth and
19 also remove provisions for AERI. However, there are
20 some elements in here that garnered a lot of interest
21 by both the committee and stakeholders. So I do want
22 to highlight those as we go through.

23 Again, this will be relatively brief. So
24 Sections 53.725 begin with some general requirements
25 that apply to facilities. These include content of

1 applications requirements. The key things I'd like to
2 point out, human factors engineering is approached
3 differently under Part 53.

4 And there's a focus on where humans are
5 involved with the fulfilment and support of safety
6 functions versus generic applications or a control
7 room. Additionally, there's a facility-specific
8 staffing plan requirement that's employed which
9 instead of having a prescriptive staffing level akin
10 to what we see in 50.54 currently. Instead, it looks
11 at an approved staffing plan that's been supported by
12 human factors engineering insights and also points to
13 engineering expertise.

14 And these are items that I'll go into a
15 bit more detail on the next two slides. Conditions of
16 facility licenses are covered under 53.740. Again,
17 this is somewhat analogous to 50.54.

18 And some key provisions we introduce there
19 are provisions for automatic load following by plants
20 with some restrictions, additionally provisions for
21 the oversight of online refueling as well. Part 53
22 contains standalone frameworks for the licensing of
23 senior reactor operators and reactor operators. And
24 within that framework, we introduce a number of new
25 flexibilities.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So this includes the use customized
2 Commission approved operator licensing programs, both
3 through the training and examination of operators by
4 facilities. Again, this is a way to have right sized
5 and technology inclusive programs that focus on what
6 those operators need to do based on the designs of the
7 plants, both the human role and safety. Additionally,
8 it allows for facilities to administer licensing exams
9 with the presence of the NRC and also with NRC
10 approval of the exams themselves.

11 Additionally, Part 53 introduces
12 provisions for a new type of licensed operator. This
13 would be the generally licensed reactor operator which
14 would be a departure from our history of only
15 specifically licensing SROs and ROs. This type of
16 operator would only apply at a limited set of
17 facilities that we refer to as self-reliant mitigation
18 facilities.

19 And these are facilities that by virtue of
20 meeting a set of criteria have determined to be of a
21 design such where humans do not have a significant
22 role in the fulfilment of safety functions or in
23 achieving the safety outcomes that the plant needs to.
24 So again, the general license for those operators is
25 contained within that section. And I'll touch upon

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that in the latter slides as well.

2 Lastly, plant staff training requirements
3 covered under 53.830 which is essentially a modernized
4 version of the training rule that we see under 51.20.
5 If we could move to the next slide, please. So
6 digging into some of the highlights that I touched
7 upon from the previous slide.

8 So under 53.740, load following would be
9 permitted provided the plants have appropriate design
10 considerations that are built into it. So these are
11 touched upon at a very high level in the rule. We do
12 tend to expand upon this further within guidance
13 documents that we're working on developing under the
14 content of application regulatory guidance under
15 development.

16 At the level of regulation, what we would
17 essentially mandate is that one of three measures has
18 to be in place to keep the plant from departing from
19 acceptable operating regime during load following.
20 And that would either have to be an automatic
21 protection system that's dedicated. Again, something
22 separate from the credited reactor protection system,
23 and able to essentially truncate those transients
24 before you get to an RPS actuation set point.

25 The use of an automated control system, so

1 again, the use of automation to manage plant systems
2 and to limit transients caused by load following such
3 that you don't depart from the acceptable operating
4 band. Lastly, something more akin to what we see
5 utilized over in Europe, the continuous oversight and
6 ability for immediate intervention by a licensed
7 operator. So again, that operator that's there to
8 arrest that transient and to take manual control
9 should it be necessary.

10 Another modification that we make is under
11 the 53.830 plant staff training set of requirements,
12 what we do is we depart from the past practice of
13 having prescriptive time frames where those programs
14 have to be in place. So right now, there's an 18
15 month timeline where you have to have a SAT-based
16 training program in effect for plant staff. What we
17 do instead is we update that to instead be marked off
18 of when those personnel are needed to support plant
19 operations.

20 So again, when you get up to the point
21 where you're getting ready to bring that plant online,
22 when you're getting ready to begin operational testing
23 and so forth, that's the milestone, right, the need
24 date that drives when those personnel programs have to
25 be in place. Additionally, what we do is we go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 through and we are more flexible in the personnel
2 categories to reflect that there can be some unique
3 roles and assignment of tasks to personnel in
4 nontraditional manners at advanced reactors. So
5 again, combining roles, operations, maintenance,
6 radiation protection, at facilities that have small
7 staff and complements, we wanted a rule that was
8 capable for accommodating that.

9 Under 53.730, staffing plans will be
10 proposed by applicants. Again, so in lieu having us
11 establish a prescriptive staffing requirement at the
12 onset, staffing plans would be submitted to the NRC
13 supported by agency analyses and performance based
14 tests. So again, this is a very similar process to
15 what's currently done under NUREG-1791 to justify
16 exemptions from the prescriptive staffing
17 requirements.

18 But this would be the starting point under
19 Part 53. Once we review and approve those staffing
20 plans, that would become the condition of a facility
21 license. New staffing plans would establish the
22 operator numbers qualifications and locations of the
23 personnel that are needed to fulfill plant safety
24 functions.

25 Additional features that are included in

1 the staffing requirements are a flexible requirement
2 for engineering expertise that is used in lieu of
3 traditional shift technical advisor staffing.
4 Importantly, and this is articulated under guidance
5 that we have for staffing that was released as part of
6 the proposed rule package, so again, the DRO-ISG-2023-
7 02 documents for staffing plan reviews. The
8 engineering expertise would not necessarily need to be
9 co-located with the plant.

10 It could be remotely located if there's
11 provisions for the receipt of data and for
12 communications with the facility and for having those
13 individuals in place within a ten-minute time frame
14 which is akin to current SDA practices. Additionally,
15 those individuals would be capable of covering more
16 than one facility provided that they have the
17 requisite training and familiarity and plant data and
18 procedural access needed to do that. Also, we
19 introduced the location neutral approach to operator
20 staffing.

21 So the results of the staffing plan will
22 allow for facilities to provide justification as to
23 where those operators should be located. Yes, Mr.
24 Kirchner. I think you have a question.

25 MEMBER KIRCHNER: Thank you, Jesse. I

1 didn't mean to interrupt. But could I go back to the
2 -- just clarification on the first main bullet. The
3 first sub-bullet 1 says an automatic protection
4 system.

5 So when we think of a reactor protection
6 system, we're usually thinking of the safety-related
7 standalone system. So the first one makes sense to
8 me. The second one suggests that since you used or,
9 this automated control system, what kind of quality
10 would be required of that?

11 Would it be equivalent to a reactor
12 protection system? Would it be vulnerable to the
13 internet and cybersecurity concerns? And then the
14 intervention of the RO, SRO, GLRO presumes that
15 there's always a person at the control system. So
16 just clarification is what I'm looking for. The
17 middle bullet is the one that's of concern.

18 MEMBER ROBERTS: This is Tom. Before you
19 answer, I have a similar question. I was going to
20 expand that. It seems like it's got an issue of
21 separation, control, and protection because you would
22 have known that a control system if you had load
23 following that was commanded by something other than
24 inherent characteristics of the reactor.

25 And so that control system could be the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cause of the command to go to excessive power. And so
2 it would seem like you would need one if you had two
3 or at least the capability of one built into two to
4 credit the automatic control system as capable of
5 stopping what might be the source. Thanks.

6 MR. SEYMOUR: This is Jesse. And I'll
7 provide the discussion of this. And again, there is
8 some complexity here. A key item that I want to point
9 out is that what we want to do is make sure that load
10 following which is, I think, a good way to put that is
11 it's an operational nice to have, right?

12 It's not allowed to interfere with
13 protection which is something that must be there. So
14 again, we don't want load following to credibly be
15 challenging the reactor protection system. We want
16 other features to be in place that are going to
17 prevent a reactor protection system from being the
18 bumpers on this process.

19 So when we see an automatic protection
20 system under one, what we were envisioning there is
21 something kind of akin to what we see on generators at
22 facilities right now. And what you'll see are certain
23 features that are there to protect overexcitation of
24 the generator. In some cases if, you know, reactive
25 load conditions on the grid get to a certain point, an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 automatically set generator voltage regulator can go
2 into a regime where there's, you know, overexcitation
3 concerns, potentially overheating the machine.

4 And what you'll have is protection systems
5 that will kick in. Again, these are not on safety.
6 This is on the balance of plant that will kick in.
7 Essentially, if that is not corrected within a certain
8 period of time, try to limit how far you can go with
9 an excitation.

10 And if it's subsequently not corrected, to
11 go ahead and trip the generator itself. Now obviously
12 that induces initiating events. And the reactor
13 protection system may respond to that as needed if
14 you're above a certain power set point, the
15 limitations it steam dumps.

16 So in this discussion under one, what we
17 are seeing from my perspective was that this would be
18 more of a non-safety, you know, kind of deterministic
19 set point built into certain balance of plant
20 components that would essentially truncate that
21 transient, right, not let you go further. But that
22 was the paradigm we had in mind with one. With two,
23 with automated control systems, again, when you look
24 at the ability of the control system to potentially
25 comprehensively manage output of the generator to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 manipulate reactivity control systems which is
2 something we've seen in existing plants where certain
3 plant designs have automatic rod withdrawal and so
4 forth to maintain temperature.

5 In that case, what we anticipated there is
6 that the control system would receive for all intents
7 and purposes a request from the load dispatcher or if
8 this is the single source of power on a microbit, for
9 example, you know, input from existing load
10 conditions, that would come in, in the form of a --
11 again, for all intents and purposes, a request to the
12 system that the system would then have to determine if
13 it could meet. And if it could, you know, what the
14 ramp rate would be and so forth to go through and to
15 meet that safely.

16 So again, this was not meant to enable the
17 non-licensed load dispatcher, you know, on a grid to
18 send demand to the plant and just begin moving the
19 generator under two. What it was meant to do is
20 essentially put a middle man there for lack of a
21 better way to put it that would receive that request
22 and then it would go ahead. And if it was able to
23 meet that, to go ahead and implement it and then, in
24 many regards, acting as a surrogate for the operator.

25 But this is more of a control function

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 versus a truncation. Under one, what we are
2 envisioning is that the load change request would come
3 into the plant. And the plant would begin to respond
4 to meet it.

5 Again, it would be sort of a direct
6 control of the power generation side of the plant with
7 protective features that would truncate that before
8 you reached RPS. Two would be more of a fine control
9 where a request comes in and the plant implements that
10 acting as a surrogate for the operator with three
11 being the operator acting as that middle. In all
12 cases, there would always be the normal reactor
13 protection system in effect, you know, as required by
14 other plant design characteristics.

15 So again, and we can revisit that if
16 there's further questions on it. But I'll go ahead
17 and I'll move on with some of the other bullets here.
18 Prescriptive time frames being used to establish
19 training programs, as I mentioned earlier, that's
20 another modification that we've made.

21 And also, you know, as we go through and
22 we talk about the staffing analysis as mentioned,
23 there are other improvements that we've looked to make
24 and other flexibilities we've looked to introduce. So
25 again, the flexible requirement as I mentioned earlier

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 for the shift technical advisor, the location neutral
2 approach taken to operator staffing. Again, if
3 fulfillment of safety functions is something that
4 humans have a role in doing at a plant, there's going
5 to be a driver where the onus is going to be on the
6 applicant to demonstrate where that needs to be
7 achieved from.

8 And then it can credibly be achieved from
9 that location. So again, if there's a proposal to not
10 have a control room and to, say, control from some
11 alternate location in the plant, that's all going to
12 be factored into the human factors engineering
13 analysis and the staffing plan validation that's
14 submitted to the NRC. Lastly, when it comes to self-
15 reliant mitigation facilities, these are facilities
16 where we don't envision that the human would have a
17 credible role in the fulfillment of safety functions.

18 That by virtue of the plant design, the
19 plant itself would be largely insulated from the
20 influences of operator performance. And so there, you
21 know, on the basis of these plants as the name implies
22 are self-reliant from a safety standpoint without the
23 human role. We would not be necessarily interested in
24 the staffing being adequate to fulfill safety
25 functions since the humans would not have a role

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there.

2 So here what we do is we step away from
3 that HFE-based staffing analysis requirement. And
4 instead we have simplified requirements that really
5 just pertain to the administrative oversight of a GLRO
6 and also to have that engineering expertise
7 requirement available as well too. If we could move
8 on to the next slide, please.

9 Okay. And again, so this is my final
10 slide. And here I wanted to dig further into the
11 generalized reactor operator area as this has been an
12 area of interest. So I mentioned the self-reliant
13 mitigation facility which would among other things be
14 eligible to be staffed by these generally licensed
15 reactor operators.

16 Beyond that, these facilities would also
17 have significant modifications to the application of
18 human factors engineering and, you know, what's
19 required for the operator licensing program, again,
20 all respecting that there's a diminished role in the
21 fulfillment of safety by humans there. So the
22 criteria -- and again this is a simplification -- to
23 achieve this would be that, you know, no human actions
24 could be necessary to meet radiological consequence
25 criteria as discussed by Anders earlier to address

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 licensing basis events or to provide for adequate
2 defense in depth. Additionally, safety functions
3 could not be allocated to human action.

4 And lastly, there would have to be
5 reliance upon robust, highly reliable safety features.
6 So here we'd be looking for safety features that
7 aren't going to be subject to human failures, again,
8 errors of omission and commission. And the most kind
9 of readily available examples of those would be things
10 that are inherent or robust passive nature, you know,
11 in nature.

12 However, what I would also say is that
13 this doesn't exclude the possibility for different
14 types of passive features or potentially even active
15 features to be used, provided that there's a
16 demonstration of how those are going to be robust
17 enough to not be subject to those human failures. So
18 again, engineer measures to enforcing performance and
19 so forth. Yes, Member Bley?

20 DR. BLEY: Yeah, Jesse. Just as you go
21 through this list, things seem almost a little inside
22 out to me. Visually, I think of designers coming up
23 with ways they want to do this and submitting with you
24 folks reviewing it.

25 It seems like you're getting a big jump on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thinking of different ways this would work, I don't
2 know how thorough you've worked through all these
3 ideas. Have you gotten additional ideas from
4 designers and maybe potential operators of ways this
5 could work? Or is this pretty much all things that
6 have thought through at least to some extent by the
7 staff?

8 MR. SEYMOUR: At this stage, we have
9 received some input along the way that was informal
10 during the course of stakeholder actions. But at this
11 stage now that we have the proposed rule out for
12 comment, we're expecting kind of the main body of
13 feedback to come in. So what you're seeing here and
14 what we've discussed previously was largely generated
15 by the staff with regards to the self-reliant
16 mitigation facility.

17 And a lot of that was a function of this
18 being a new class facility, new type of operator and
19 so forth. What I'd like to say is that this is really
20 the synopsis of the rule language here. And the rule
21 language itself tries to be performance-based and
22 tries to leave the door open to how this could be met
23 by a variety of means.

24 As I mentioned, the safety features used
25 to meet this aren't necessarily limited to being

1 inherent or passive. They could potentially be
2 active. But again, we'll leave it to the designer to
3 make that case for how these are credibly not going to
4 be subject to those human failings.

5 And the reason being is that under this
6 type of framework, we're not even staffing these
7 facilities potentially with individuals that we would
8 tend to credit to take those actions. The GLRO, for
9 example, would not be an individual that receives a
10 medical exam. So, could there be a medical issue that
11 incapacitates them when they take an action
12 potentially.

13 So we don't want them to be credited. So
14 I would say that we are expecting significant feedback
15 from the industry on different thoughts on this.
16 There has been some allusion to that from different
17 stakeholders that we've talked to. And we're
18 definitely receptive to different ways we could go
19 about this.

20 But fundamentally, the self-reliant
21 mitigation facility is just one kind of subtrack
22 within Part 53. If a facility does not meet the
23 threshold to be considered a self-reliant mitigation
24 facility, they still -- even staff by SROs and ROs
25 have access to flexible staffing requirements,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 tailored operator licensing programs that they can
2 modify to meet their specific needs and so forth.
3 Just great flexibility as improvements over Part 55.

4 So I just want to point out that, you
5 know, it is a high bar to be considered within this
6 category. There are a lot of kind of loosening of the
7 regulatory footprint and so forth happens when you get
8 there. But just because a facility doesn't screen
9 doesn't mean that they don't potentially see a lot of
10 benefits, I think, and improvements over the existing
11 framework.

12 DR. BLEY: Okay. Thanks. That's pretty
13 good. I guess the thing that I'm not fully
14 comfortable with yet is given we've written this into
15 the regulation, it kind of says these things are
16 actually reasonable and could be licensed. And I just
17 wondered if you really thought that fully through. I
18 know there is current and past members of this
19 committee who've expressed a little skepticism along
20 the lines of self-reliant systems.

21 MR. SEYMOUR: That's an excellent
22 question. Again, this is Jesse. And what I would say
23 is that the way that we've tried to approach that
24 because this is a new area for us to go into is we try
25 to think through the potential for an autonomous

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reactor, for example, where you would not have a human
2 there.

3 And so you begin to think of what would
4 the machine -- what types of criteria and performance
5 characteristics would the machine need to be able to
6 meet to operate safely in the absence of many
7 opportunity for human intervention, right? Because no
8 one is there. And as we thought through that, what we
9 began to see is that different measures all have their
10 own vulnerabilities.

11 Again, if you look at a measure that was
12 strictly based on what was credited within PRA, well,
13 what if the PRA methodology was deficient? If you
14 looked at mandating that it had to be reliant upon
15 only inherent safety characteristics, what if there
16 was some analytic uncertainty in some of those
17 inherent characteristics such as the construction of
18 the fuel in the first of the kind build and so forth?
19 So what we did is we used a set of five criteria that
20 has some -- it has some synergy between them but at
21 the same time have enough independence such that you
22 are providing that ability to have some resilience
23 against some of those vulnerabilities.

24 And it looks like we jump back in slides
25 here. So we'll catch back up. But again, it is an

1 area where we've tried to tread carefully. What we've
2 tried to do is to envision where we see the technology
3 going over the long term which is, again, you know, a
4 greater drive to inherent safety, a greater drive
5 towards remotely located facilities, autonomous
6 reactors. And then to say what are those performance
7 characteristics that -- and again, I use the term
8 performance there very, very explicitly because we're
9 looking at it in a performance-based way, right? But
10 what are those outcomes you need to be able to achieve
11 to do that safely?

12 DR. BLEY: Yeah, thanks, Jesse. It'll be
13 interesting to see where we end up here.

14 MR. SEYMOUR: Okay, yeah. Thank you. So
15 again, just moving on and going through some of these
16 other areas, 53.805 talks about facility license
17 requirements for GLROs. So again, here very different
18 than ROs and SROs. The license would be located
19 within the regulation.

20 It is truly a general license. That
21 doesn't mean that there isn't the capability for
22 individual enforcement. There absolutely is, and
23 that's written as a condition.

24 So there would be the same avenue the NRC
25 could take to take action against an individual who

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 does something inappropriate or even to bar them from
2 being able to operate under that general license.
3 That's all built in there. Additionally, the facility
4 would be on the hook for implementing the training and
5 examination programs.

6 And we envision that those activities
7 would still be subject to NRC inspection. And in all
8 cases, they would be subject to NRC approval. Under
9 -- again, I talked about the general license for GLROs
10 under 53.810 as well.

11 Under 53.813, in a similar manner to the
12 SRO and RO training programs. GLRO training and exams
13 proficiency would be customized based on facility
14 needs submitted to the NRC for approval. The NRC
15 would provide approval of those training programs and
16 of the examination programs as well too.

17 And then once that was done, you know, the
18 facility would be responsible for administering both
19 of those. Now the facility, because of the
20 requirements of 53.805 would have some regulatory
21 hooks that would hold them to the appropriate
22 implementation of those approved programs. So again,
23 that would enforceable.

24 But here with the GLRO plant, we envision
25 that the NRC would largely assume an inspection role

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of coming in and confirming that those programs are
2 being implemented versus coming in and looking at the
3 individuals for their examinations on an individual
4 basis like we currently do. And again, this is just
5 for the sumps of self-reliant mitigation facilities.
6 And lastly, 53.820 just deals with the cessation of
7 this.

8 As a general license, it would only
9 pertain to individuals that are employed at that
10 facility. So that concludes my slides. We can
11 transition on. But I just wanted to pause and see if
12 there are any further questions from the committee.

13 MEMBER HALNON: Jesse, this is Greg.
14 First of all, I think where you are now does reflect
15 this evolution from the certified operator to where we
16 are now. I'd appreciate you taking a lot of our
17 comments and kind of modifying them as necessary but
18 working those thing in such as the STA and some of the
19 training and some of the training issues that we
20 brought up.

21 One question I have, I wasn't sure about
22 is we had recommended that there be -- it was back in
23 certified operator. But we recommended that there be
24 at least one person with the -- that everybody
25 reported to that had the same level license, the GLRO.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 It is in your thinking that in the fleet of GLROs
2 there would still be one person that would be
3 accountable for the license aspect of this? Right
4 now, usually the office manager has an SRO or inactive
5 at best but they're licensed.

6 MR. SEYMOUR: Yes, and that's a feature
7 that we see appear in the administrative section of
8 tech specs which is driven if memory serves me by
9 commitments to -- I believe to Reg Guides and ANS
10 standards to maintain that senior license position.
11 So again, if we look at standard tech specs for
12 plants, that's where we'll see that. And we see it
13 emerge there.

14 What I'll say, that's an item that we did
15 consider as we went through and looked at this. And
16 what we -- where we fell out on that was that it was
17 something that it currently doesn't exist at the level
18 of regulation under the existing framework. So
19 consistent with that, we didn't want to introduce that
20 at the level of regulation here within this framework.

21 Now again, it still does appear. It
22 appears as a commitment for other plants. But our
23 thinking had been that was something that would be
24 better served by existing at the level of guidance to
25 keep it consistent with where things currently are.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Again, not taking something that's
2 currently at the level of guidance and then emerges as
3 a commitment and elevating it to the level of
4 regulation. But that's definitely an item. And I
5 know exactly what you're talking about.

6 There's an operations manager and an
7 assistant operations manager. And generally what we
8 see in tech specs, in fact, universally, I think, is
9 that there's a commitment that one of those two will
10 hold a senior reactor operator license for the plant.
11 And that puts them into this role we refer to as
12 senior license holder.

13 And it grants them kind of a unique
14 position where they can be the final say on some of
15 those technical debates that you get into in the SRO
16 role and serve authoritatively. So I think it's what
17 you're referring to. And that's something that's
18 still -- it's still on our table to work through the
19 guidance. But that's where we fell out on our side
20 was that it just seemed better served to have that be
21 a guidance matter.

22 MEMBER HALNON: Fair enough. Certainly
23 could be outlined in the staffing plan. I would
24 imagine you could ask the questions there if you
25 needed to. But again, I want to thank you for taking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a lot of our comments and making it work through the
2 regulation, how you intertwined those was good. So we
3 can move on. I guess you need to wrap it up. Anders?

4 MR. GILBERTSON: Yes, we can move on to
5 slide 42. And I'll just be very brief. Not a whole
6 lot more to say here other than just outside of the
7 SRM related provisions that we talked about earlier
8 this morning, other changes were made as appropriate
9 to subparts G, H, I, J, and M and their related
10 portions to the preamble to address crosscutting SRM
11 items like some of the ones I mentioned earlier,
12 references to the subpart K and the framework problem.
13 So beyond that, that really concludes the staff's
14 presentation. And I'll hand it back to you.

15 CHAIRMAN PETTI: Great. Thank you.
16 Members, any other comments?

17 MEMBER HALNON: I see Vicki has her hand
18 up.

19 CHAIRMAN PETTI: Okay. I can't see that.
20 Vicki, please.

21 MEMBER HALNON: Vicki, you're muted if you
22 hear us. Vicki, we don't hear you if you're talking.
23 Dave, apparently Vicki is having some technical
24 problems. We can't hear her. So --

25 CHAIRMAN PETTI: Yeah.

1 MEMBER HALNON: -- trying to get her
2 comments on the record somehow.

3 CHAIRMAN PETTI: We'll give her a minute.
4 I just want to thank the staff again for giving us
5 this briefing and letting us know where they are. I
6 joke that we could talk about Part 53 one hundred
7 times and we'd still generate lots of questions on the
8 100th time as we did on the first time.

9 It's just the nature of the beast, I
10 think. But again, thank you all for the discussion.
11 It was good. Vicki, one last time. If not, let's go
12 for public comments. Anyone online who wants to make
13 a comment, please raise your hand and we'll identify
14 you and let you make your comment.

15 MEMBER HALNON: I don't see any, Dave.

16 CHAIRMAN PETTI: Okay. Then one last
17 call, Vicki. Is her hand still raised? I can't see
18 it.

19 MR. BURKHART: This is Larry Burkhardt with
20 the ACRS staff. Vicki did log out. I asked her to
21 try to log back in. So give her a minute, perhaps.

22 MEMBER HALNON: Yeah, she was having
23 technical difficulties like you were, Dave, earlier.

24 MEMBER BIER: Hi, yeah. I managed to
25 unmute finally. Thanks for the advice, Larry. I had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 just one minor comment which I don't expect to be
2 addressed in a big way.

3 But it's coming back to the issue that I
4 raised earlier and that Vesna and I have discussed
5 about the issue of safety-related versus safety
6 significant. And I've been kind of pondering and
7 mulling over it. And I'm wondering whether when the
8 term is first introduced it would make sense to state
9 that this is essentially equivalent to design basis
10 related.

11 And I don't expect anybody to change the
12 terminology because safety-related obviously has a
13 long history. And you want to be consistent with
14 other regulations that use those terms. But it might
15 be helpful to just, you know, translate the first time
16 that this is really design basis related, safety
17 items. And there can, of course, be other safety
18 items for people who are new to the whole dilemma.
19 Anyway, that's my only comment.

20 CHAIRMAN PETTI: Okay. Well, I guess with
21 that, we can close the session. I want to thank
22 everybody again and we'll see you all at tomorrow's
23 subcommittee meeting. Thank you.

24 (Whereupon, the above-entitled matter went
25 off the record at 12:11 p.m.)



ACRS Subcommittee on Regulatory Rulemaking, Policies, and Practices:

**Information Briefing on Updates to
Proposed 10 CFR Part 53, "Risk-Informed,
Technology-Inclusive Regulatory
Framework for Advanced Reactors"**



January 14, 2025

List of Speakers

- Anders Gilbertson – NRR Technical Lead
- Bill Reckley– NRR Technical Lead
- Jesse Seymour - NRR Plant Operator Licensing & Human Factors

Proposed Rule

- [89 FR 86918](#) (published October 31, 2024)
- <https://www.regulations.gov/document/NRC-2019-0062-0310>
- [ML24095A161](#)

28 Associated Documents

- [89 FR 86918](#), Section XIX. Availability of Documents
- <https://www.regulations.gov/docket/NRC-2019-0062/document?postedDateFrom=2024-10-31&postedDateTo=2024-10-31>

White Paper

- Subpart H, DRAFT Section 53.1480 – Combined license supporting testing of manufactured reactors ([ML24344A037](#))

Past ACRS Interactions on Part 53

- 16 ACRS meetings during development of draft proposed rule in 2020, 2021, and 2022
- 4 Interim Letter Reports
- Final Letter Report dated November 22, 2022 ([ML22319A104](#))
- NRC Staff Response dated February 10, 2023 ([ML22341A047](#))

Key Rulemaking Documents


- SECY-23-0021, “Proposed Rule: Risk-Informed, Technology-Inclusive Regulatory Framework for Advanced Reactors,” dated March 1, 2023 (ADAMS [ML21162A093](#))
- In SRM-SECY-23-0021, dated March 4, 2024 (ADAMS [ML24064A047](#)), the Commission approved, in part, the NRC staff’s draft proposed rule with exceptions and clarifications

Part 53 Final Rule Milestones

- Close of public comment period: February 28, 2025
- ACRS Interactions: will work with ACRS staff to set up dates for late 2025 and early 2026
- Final Rule to the Commission: May 2026
- Final Rule Published: NEIMA Deadline – December 2027

Recent & Ongoing Activities

Modernizing the Regulatory Framework



Draft Part 53 Proposed Rule (SECY-23-0021)

Part 53 Licensing Frameworks

Subpart A - General Provisions
Subpart X - Enforcement

Subpart B - Safety Requirements
Subpart C - Design Requirements
Subpart D - Siting
Subpart E - Construction/Manufacturing
Subpart F - Operations
Subpart G - Decommissioning
Subpart H - Application Requirements
Subpart I - License Maintenance
Subpart J - Reporting
Subpart K - Quality Assurance

Framework A

- PRA in foundational role
- Uses risk metrics
- Functional design criteria for SSCs

Subpart N - Siting
Subpart O - Construction/Manufacturing
Subpart P - Operations
Subpart Q - Decommissioning
Subpart R - Application Requirements
Subpart S - License Maintenance
Subpart T - Reporting
Subpart U - Quality Assurance

Framework B

- Traditional use of risk insights
- Principal design criteria
- Includes AERI approach

Staff Requirements Memorandum Summary

- 1) Remove Framework B from Part 53 and provide new options
- 2) Replace references to QHOs with comprehensive risk metrics
- 3) Allow flexibility in PRA acceptability determinations
- 4) Revise requirements related to as low as reasonably achievable (ALARA)
- 5) Remove facility safety program
- 6) Explain process for ongoing evaluations of external hazards in preamble
- 7) Include requirement for design experience program
- 8) Include provisions for factory fuel loading and engage stakeholders on possible operational testing of fueled manufactured reactors
- 9) Harmonize consideration of security-related events within security and emergency preparedness requirements
- 10) Replace Subpart K QA requirements with reference to Appendix B to Part 50
- 11) Remove safety objectives section
- 12) Include question on processes for similar designs at multiple sites
- 13) Consider suggested edits in Commission vote sheets
- 14) Provide final version of Federal Register Notice within six months
- 15) Consider administrative rulemaking for potential errors in Parts 50 and 52


Proposed Part 53 Licensing Framework

Part 53 Organization	
Subpart A	General Provisions
Subpart B	Technology-Inclusive Safety Requirements
Subpart C	Design and Analysis Requirements
Subpart D	Siting Requirements
Subpart E	Construction and Manufacturing Requirements
Subpart F	Requirements for Operation
Subpart G	Decommissioning Requirements
Subpart H	Licenses, Certifications, and Approvals
Subpart I	Maintaining and Revising Licensing-Basis Information
Subpart J	Reporting and Other Administrative Requirements
Subpart M	Enforcement

SRM-RELATED DELTA

- *Framework B and related references removed*
- *Subpart K removed (added references to Appendix B to Part 50)*

Part 53 Structure - Project Life Cycle



Subpart A

General provisions

- § 53.015 Scope.
- § 53.020 Definitions.
- § 53.040 Written communications.
- § 53.050 Deliberate misconduct.
- § 53.060 Employee protection.
- § 53.070 Completeness and accuracy of information.
- § 53.080 Specific exemptions.
- § 53.090 Standards for review.
- § 53.100 Jurisdictional limits.
- § 53.110 Attacks and destructive acts.
- § 53.115 Rights related to special nuclear material.
- § 53.117 License suspension and rights of recapture.
- § 53.120 Information collection requirements: OMB approval.

Subpart A

General provisions

New or Revised Terminology Compared to Parts 50 & 52 (§ 53.020)

- Event categories & related terms
- Commercial nuclear plant/reactor
- Consensus code or standard
- Construction
- Defense in depth
- Functional design criteria
- Licensing basis information
- Safety classification categories
- Probabilistic risk assessment
- Programmatic controls
- Special treatment

Subpart B

Technology-inclusive safety requirements

§ 53.210 Safety criteria for design-basis accidents.

§ 53.220 Safety criteria for licensing-basis events other than design-basis accidents.

§ 53.230 Safety functions.

§ 53.240 Licensing basis events.


§ 53.250 Defense-in-depth.

§ 53.260 Normal operations.

§ 53.270 Protection of plant workers.

Subpart B

Technology-inclusive safety requirements



*Regulatory Guide (RG) 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis"

Subpart B

Technology-inclusive safety requirements

§ 53.210 Safety criteria for design-basis accidents.

- Design features and programmatic controls provided such that the identification and analyses of design-basis accidents (DBAs) demonstrate that the calculated offsite doses are below established reference values

§ 53.450(f) Analysis of design-basis accidents.

- DBAs address possible challenges to the safety functions required to be identified by § 53.230 and include events that, if not terminated, have the potential for exceeding the safety criteria in § 53.210.
- DBAs analyzed using deterministic methods that address event sequences from initiation to a safe stable end state and assume only the SR SSCs and human actions addressed by the requirements of Subpart F to perform the safety functions
- The analysis must conservatively demonstrate compliance with the safety criteria in § 53.210.

Subpart B

Technology-inclusive safety requirements

§ 53.220 Safety criteria for licensing-basis events other than design-basis accidents.

- Design features and programmatic controls provided such that the identification and analysis of licensing-basis events (LBEs) other than DBAs demonstrate the following:
 - a) Plant SSCs, personnel, and programs provide the necessary capabilities and maintain the necessary reliability to address LBEs other than DBAs and provide measures for defense in depth, and
 - b) The analysis of risks to public health and safety resulting from LBEs other than DBAs under § 53.450(e) includes comprehensive risk metrics that satisfy associated risk performance objectives that are acceptable to the NRC and provide an appropriate level of safety.

SRM-RELATED DELTA

Subpart B

Technology-inclusive safety requirements

§ 53.450(e) Analysis of licensing-basis events other than design-basis accidents.

- The analyses must use insights from a PRA in combination with other generally accepted approaches for systematically evaluating engineered systems to identify and analyze equipment failures and human errors.
- The analysis of LBEs other than DBAs must include definition of evaluation criteria for each event or specific categories of LBEs to determine the acceptability of the plant response to the challenges posed by internal and external hazards to provide an appropriate level of safety.
- The analyses of LBEs other than DBAs must address event sequences from initiation to a defined end state and be used in combination with other engineering analyses to demonstrate that the functional design criteria required by § 53.420 provide sufficient barriers to the unplanned release of radionuclides to satisfy the evaluation criteria defined for each LBE other than DBAs, to satisfy the safety criteria specified in accordance with § 53.220 and provide defense in depth as required by § 53.250.
- The methodology used to identify, categorize, and analyze LBEs must include a means to identify event sequences deemed significant for controlling the risks posed to public health and safety.

Subpart B

Technology-inclusive safety requirements

Comprehensive risk metrics and associated risk performance objectives

- Consist of proposed plant risk metric or set of proposed risk metrics that approximate the total, overall risk from the facility and that address the range of possible plant configurations and associated internal and external hazards to the extent practicable.
- The associated risk performance objectives are preestablished, indicative values of the comprehensive risk metrics that are used as part of risk-informed decision-making.
- The methodology for developing and using proposed comprehensive risk metrics and associated risk performance objectives is defined by the proposed requirements for analyses in § 53.450.

SRM-RELATED DELTA

Subpart B

Technology-inclusive safety requirements

§ 53.230 Safety functions.

(a) The primary safety function is limiting the release of radioactive materials from the facility and must be maintained during normal operation and for LBEs over the life of the plant.

(b) Additional safety functions needed to support the retention of radioactive materials during LBEs—such as controlling reactivity, heat generation, heat removal, and chemical interactions—must be identified for each commercial nuclear plant.

(c) The primary and additional safety functions are required to satisfy the safety criteria defined in §§ 53.210 and 53.220, or more restrictive alternative criteria adopted under § 53.470, and must be fulfilled by the design features, human actions, and programmatic controls specified throughout this part.

Subpart B

Technology-inclusive safety requirements

§ 53.240 Licensing-basis events.

- (a) *Licensing-basis events must be identified for each commercial nuclear plant and analyzed under § 53.450 to demonstrate that the safety requirements in this subpart have been satisfied.*
- (b) *The identified LBEs, ranging from anticipated event sequences to very unlikely event sequences, must collectively address combinations of malfunctions of plant SSCs, human errors, facility hazards, and the effects of external hazards.*
- (c) *The analysis of LBEs must—*
 - (1) *Include analysis of one or more DBAs under § 53.450(f);*
 - (2) *Confirm the adequacy of design features and programmatic controls needed to satisfy the safety criteria defined in §§ 53.210 and 53.220, or more restrictive alternative criteria adopted under § 53.470; and*
 - (3) *Establish related functional requirements for plant SSCs, personnel, and programs.*

§ 53.020 Definitions.

- *Licensing-basis events means a collection of event sequences considered in the design and licensing of the commercial nuclear plant. Licensing-basis events are unplanned events and include anticipated event sequences, unlikely event sequences, very unlikely event sequences, and DBAs.*

Subpart B

Technology-inclusive safety requirements

§ 53.250 Defense in depth.

(a) Measures must be taken for each commercial nuclear plant to ensure appropriate defense in depth is provided to compensate for uncertainties in the analysis of the safety criteria such that there is reasonable assurance that the safety criteria in this subpart are met over the life of the plant.

(b) The uncertainties that must be addressed under paragraph (a) of this section include those related to the state of knowledge and modeling capabilities, the ability of barriers to limit the release of radioactive materials from the facility during LBEs other than DBAs, the reliability and performance of plant SSCs and personnel, and the effectiveness of programmatic controls.

(c) The safety analysis may not rely upon a single engineered design feature, human action, or programmatic control, no matter how robust, to address the range of LBEs other than DBAs.

Subpart B

Technology-inclusive safety requirements

§ 53.260 Normal operations.

Holders of licenses to operate commercial nuclear plants under this part must control public doses and dose rates in unrestricted areas from normal plant operations to meet the requirements in 10 CFR part 20.

§ 53.270 Protection of plant workers.

Holders of licenses to operate commercial nuclear plants under this part must control occupational doses to meet the requirements in 10 CFR part 20.

SRM-RELATED DELTA

Subpart B

Technology-inclusive safety requirements

Requirements related to radiation protection programs	
53.260	OL/COL holders meet 10 CFR part 20 (public doses)
53.270	OL/COL holders meet 10 CFR part 20 (plant workers)
53.425	<ul style="list-style-type: none"> Define design features and functional design criteria ALARA design objective of 10 mrem TEDE annual dose
53.430	Define design features and functional design criteria
53.450(g)(3)	Analysis of expected releases and doses to the public
53.850	Radiation protection program
53.1645	Reports of radiation exposure to the public
53.1239(a) (DC)	<ul style="list-style-type: none"> Design features supporting normal operations How programmatic controls support meeting requirements Design features supporting the protection of plant workers How programmatic controls support meeting requirements
53.1209(b) (SDA)	
53.1279(a) (ML)	
53.1309(a) (CP)	
53.1369 (OL)	<ul style="list-style-type: none"> Design features supporting normal operations Radiation protection program Design features supporting the protection of plant workers Radiation protection program
53.1416(a) (COL)	

SRM-RELATED DELTA

Subpart C


Design and analysis requirements

- § 53.400 Design features for licensing-basis events.
- § 53.410 Functional design criteria for design-basis accidents.
- § 53.415 Protection against external hazards.
- § 53.420 Functional design criteria for licensing-basis events other than design-basis accidents.
- § 53.425 Design features and functional design criteria for normal operations.
- § 53.430 Design features and functional design criteria for protection of plant workers.
- § 53.440 Design requirements.
- § 53.450 Analysis requirements.
- § 53.460 Safety categorization and special treatments.
- § 53.470 Maintaining analytical safety margins used to justify operational flexibilities.
- § 53.480 Earthquake engineering.

Subpart C

Design and analysis requirements

Part 53 Hierarchy



Subpart C

Design and analysis requirements

§ 53.400 Design features for licensing-basis events.

- Design features must be provided such that, when combined with corresponding human actions and programmatic controls, the plant will satisfy the safety criteria and ensure that safety functions are fulfilled during LBEs.

§ 53.410 Functional design criteria for design-basis accidents.

§ 53.415 Protection against external hazards.

- Safety-related (SR) SSCs must be protected against or must be designed to withstand the effects of external hazards up to the design-basis external hazard levels.

§ 53.420 Functional design criteria for licensing-basis events other than design-basis accidents.

Subpart C

Design and analysis requirements

§ 53.440 Design requirements.	
(a)	<ul style="list-style-type: none"> • Demonstrate functional design criteria via analysis, test, etc.; • Evaluate operating, design and construction experience
(b)	Consensus codes and standards acceptable to NRC
(c)	Materials qualified for conditions
(d)	Evaluate possible degradation mechanisms
(e)	Design and locate to minimize probability and effects of fires and explosions
(f)	Consider safety and security together during design process
(g)	Subcritical condition during normal operations and after LBE
(h)	Long-term cooling during normal operations and after LBE
(i)	Design, analysis, staffing and programs cover all units, inventories
(j)	Physical barrier(s) maintained assuming aircraft impact
(k)	Control risk from chemical hazards of licensed material
(l)	Minimize contamination to facilitate eventual decommissioning
(m)	Criticality monitoring (alternative to § 70.24)
(n)	Consider human factors, functional analysis and function allocation

SRM-RELATED DELTA

Subpart C

Design and analysis requirements

§ 53.450 Analysis requirements.	
(a)	Requirement to have a probabilistic risk assessment (PRA)
(b)	Specific uses of analyses using PRA in combination with other generally accepted approaches for systematically evaluating engineered systems (LBEs, classification, defense in depth)
(c)	Maintenance and upgrade of analyses
(d)	Qualification of analytical codes.
(e)	Analyses of licensing-basis events other than design-basis accidents. <ul style="list-style-type: none"> • Evaluation criteria for each event or specific categories of LBEs • Means to identify event sequences significant for controlling risks
(f)	Analysis of design-basis accidents. <ul style="list-style-type: none"> • Deterministic methods from initiation to a safe stable end state
(g)	Other required analyses. <ul style="list-style-type: none"> • Fire protection • Aircraft impact • Doses to members of the public

Subpart C

Design and analysis requirements

PRA Acceptability

- Development, use, and maintenance of a PRA would be a key component in the proposed analysis requirements.
- The PRA, together with other techniques, would have required uses such as –
 - identify and categorize LBEs,
 - classify SSCs, and
 - evaluate defense in depth.
- Consistent with the current state of practice, acceptability of a PRA would be assessed based on the required uses of the PRA and the needs and scope of the application.
 - Consensus PRA standards would not be applied as a strict checklist of requirements for PRA acceptability determinations under the Part 53 proposed rule.
- NRC guidance on non-LWR PRA acceptability is currently available, which includes NRC-endorsed processes on the use of consensus PRA standards and PRA peer review.

SRM-RELATED DELTA/CLARIFICATION

Subpart D

Siting requirements

§ 53.500 General siting and siting assessment.

§ 53.510 External hazards.

§ 53.520 Site characteristics.

§ 53.530 Population-related considerations.

§ 53.540 Siting interfaces.

Subpart E

Construction and manufacturing requirements

§ 53.600 Construction and manufacturing – scope and purpose.

§ 53.605 Reporting of defects and noncompliance.

§ 53.610 Construction.

§ 53.620 Manufacturing.

Subpart E

Construction and manufacturing requirements

§ 53.620 Manufacturing.

- Management and control
 - Provides programmatic and organizational requirements
 - Supports compliance with the design and analysis requirements in subpart C
- Manufacturing activities
 - ML holder has the authority to establish controls at facility(s)
 - Manufacturing processes must be performed in accordance with the ML and the referenced codes and standards
 - A post-manufacturing inspection and acceptance process
- Control of radioactive materials
- *Fuel loading*
- Transportation
- Acceptance and installation at final place of operation

SRM-RELATED DELTA*

* *Delta between ACRS Review and SECY-23-0021*

Subpart E

Fuel loading for manufactured reactor module

§ 53.620(d) *Fuel loading.*

- A manufacturing license may include authorizing the loading of fresh (unirradiated) fuel into a manufactured reactor under Part 70
- Specifies required protections to prevent criticality
 - At least two independent physical mechanisms in place, each of which is sufficient to prevent criticality assuming optimum neutron moderation and neutron reflection conditions
- Commission finding that a manufactured reactor module in required configuration is not in operation

SRM-RELATED DELTA

Subpart E

Fuel loading for manufactured reactor module

§ 53.620(d) *Fuel loading.*

- Holders of these Part 70 licenses must comply with the requirements of Subpart H to Part 70
- Procedures, equipment, and personnel required by the Part 70 license must be in place before the receipt of SNM at the manufacturing facility
- The loading or unloading of fresh fuel into or from a manufactured reactor and any changes to the configuration of reactivity control and prevention systems for the fueled manufactured reactor must be performed by a certified fuel handler meeting the requirements in Subpart F of this part
- For a manufactured reactor that is to be loaded with fresh fuel before transport to the place of operation, the ML must specify that transportation will be in accordance with Parts 71 and 73 of this chapter
- Security requirements

Factory Testing of Fueled Manufactured Reactors

- Proposed § 53.620(d) would allow and establish requirements for the loading of fuel into a manufactured reactor at the manufacturing facility for transport to a site with a combined license

Staff Requirements Memorandum (SRM)-SECY-23-0021

8. The staff should include factory fuel load provisions in the proposed rule. The staff should work with stakeholders following publication of the proposed rule to develop regulatory text that would also allow a holder of a manufacturing license to accomplish operational testing on a fueled manufactured reactor at the factory prior to delivery to the site where it will ultimately be used.

- Included question in *Federal Register* Notice
- Prepared and released preliminary draft material (i.e., not complete NRC management or legal review) to support discussions
 - ADAMS Accession No. [ML24344A037](#)
- Public meeting – January 8, 2025
- Consideration of comments received

SRM-RELATED DELTA

Question in *Federal Register* Notice

- Should Part 53 include provisions for the testing of fueled manufactured reactors in the manufacturing facility?
 - What would be both practical and safe?
 - What tests are expected to collect data on fuel or other structures, systems, and components (SSCs)?
- What would be appropriate limits on operations?
 - Power levels
 - Durations (limit creation of byproduct material)
- What requirements could be revised given limitations on operation?
 - Licensing basis events, aircraft impact assessments, external hazards (seismic)

Question in *Federal Register* Notice

- What regulations would be appropriate for manufacturing facility?
 - Construction (proposed § 53.610)
 - Operations (proposed §§ 53.710 and 53.715)
 - Personnel (proposed § 53.730)
- What licensing mechanism(s) should be considered for in-factory testing of manufactured reactors?
 - License for each manufactured reactor
 - License for manufacturing facility/multiple manufactured reactors
 - Inspections, tests, analyses, and acceptance criteria (ITAAC)

Subpart F

Requirements for operation

§ 53.700 Operational objectives.

- (1) Each holder of an OL or COL under this part must maintain the **capabilities, availability, and reliability of plant SSCs** to ensure that the safety functions identified in § 53.230 will be performed if called upon during licensing-basis events (LBEs).
- (2) Each holder of an OL or COL under this part must ensure that **plant personnel have adequate knowledge and skills** to perform their assigned duties that support the performance of the safety functions identified in § 53.230.
- (3) Each holder of an OL or COL under this part must implement **plant programs** sufficient to ensure that the safety functions identified in § 53.230 will be performed if called upon during normal operations and LBEs.

Subpart F Organization of Sections	
§ 53.710 - § 53.720	SSCs
§ 53.725 - § 53.830	Personnel
§ 53.845 - § 53.910	Programs

Subpart F

Requirements for operation

§§ 53.725 - 53.830: General staffing, training, personnel qualifications, and human factors requirements

Sections 53.725 – 53.830 include the following key areas:

- Content of application requirements (§ 53.730)
 - Human factors engineering (HFE) has a safety function focus (versus generic application to a control room)
 - Facility-specific staffing plans and “engineering expertise”
- Conditions of license for facility licensees (§ 53.740)
 - Allows for automatic load following
 - Addresses online refueling oversight
- Operator licensing requirements for specifically-licensed Senior Reactor Operators (SRO) and Reactor Operators (ROs) (§§ 53.760-53.795)
 - Addresses use of customized operator licensing programs
 - Allows facility licensees to administer license exams
- Requirements for Generally Licensed Reactor Operators (GLROs) (§§ 53.800- 53.820)
 - Establishes criteria for “self-reliant-mitigation” facilities.
 - Contains the general license for GLROs
- Plant staff training requirements (§ 53.830)

Subpart F

Requirements for operation

Other highlights from §§ 53.725 - 53.830

- Load following is permitted under 53.740 if one of the following is immediately capable of refusing unsafe demands:
 - 1) an automatic protection system that utilizes setpoints more conservative than those otherwise credited for the purposes of reactor protection; or
 - 2) an automated control system; or
 - 3) intervention of an RO, SRO, or GLRO.
- Prescriptive timeframes for establishing training programs are no longer used; 53.830 requirement is based on needs.
- Staffing plans are proposed by applicants under 53.730, with HFE analyses and performance-based tests being used to determine operator numbers, qualifications, and locations (approved plan then becomes license condition).
 - A flexible requirement for engineering expertise is used in lieu of traditional Shift Technical Advisor staffing.
 - A location-neutral approach is taken to operator staffing; for example, control room staffing is not prescribed.
 - “Self-reliant-mitigation” facilities do not require these HFE-based staffing analyses and, instead, only have GLRO oversight and engineering expertise requirements.

Subpart F

Requirements for operation

Self-reliant-mitigation facilities and GLROs

- § 53.800 – Criteria for self-reliant-mitigation facilities
 - No human actions to meet radiological consequence criteria, address LBEs, or provide for adequate DID
 - Safety functions not allocated to human action
 - Reliance upon robust and highly reliable safety features
- § 53.805 – Facility licensee requirements for GLROs
 - Facilities must continue to meet the criteria of 53.800 (failure would be a reportable unanalyzed condition)
- § 53.810 – General license for GLROs
 - Grants similar level of administrative authority as an SRO
 - No application needs to be submitted for GLRO licensing
 - Individuals operating under license subject to conditions
 - License can still be suspended on an individual basis
- § 53.815 – GLRO training, exams, & proficiency
 - SAT-based training program is required
 - Uses customized, Commission-approved exam programs
 - After approval, GLRO programs are facility-administered
 - Facilities determine requalification exam periodicity
 - Simulation facilities do not require Commission-approval
- § 53.820 – Cessation of individual applicability

Subparts G, H, I, J, and M

- Subpart G — Decommissioning Requirements
- Subpart H — Licenses, Certifications, and Approvals
- Subpart I — Maintaining and Revising Licensing-Basis Information
- Subpart J — Reporting and Other Administrative Requirements
- Subpart M — Enforcement



Wrap Up Discussion and Questions



Acronyms

ACRS	Advisory Committee on Reactor Safeguards	FRN	<i>Federal Register</i> Notice
ADAMS	Agencywide Documents Access and Management System	GLRO	generally licensed reactor operator
AEA	Atomic Energy Act of 1954	GEIS	Generic Environmental Impact Statement
AERI	Alternative Evaluation for Risk Insights	HFE	human factors engineering
ALARA	as low as is reasonably achievable	ITAAC	Inspections, Tests, Analyses, and Acceptance Criteria
ARCAP	Advanced Reactor Content of Application Project	LB	licensing basis
CFR	<i>Code of Federal Regulations</i>	LBE	licensing-basis event
COL	combined license	LWR	light-water reactor
COL-TMR	combined license for testing of manufactured reactors	ML	manufacturing license
CP	construction permit	mrem	millirem
DBA	design-basis accident	NEIMA	Nuclear Energy Innovation and Modernization Act
DC	design certification	NRC	U.S. Nuclear Regulatory Commission
DID	defense in depth		
EP	emergency planning		
FR	<i>Federal Register</i>		

Acronyms

NRR	Office of Nuclear Reactor Regulation	SR	safety-related
NUREG	U.S. Nuclear Regulatory Commission technical report designation	SRM	Staff Requirements Memorandum
OL	operating license	SRO	Senior Reactor Operator
OMB	Office of Management and Budget	SSC	structure, system, or component
PRA	probabilistic risk assessment	TICAP	Technology-Inclusive Content of Application Project
QA	quality assurance	TEDE	total effective dose equivalent
QHO	quantitative health objectives	TS	technical specifications
RG	Regulatory Guide		
RO	Reactor Operator		
SAR	safety analysis report		
SAT	systems approach to training		
SDA	standard design approval		
SECY	Office of the Secretary		
SNM	special nuclear material		

Backup Slides

White Paper (ML24344A037)

- Provided to support discussions
- Should not be interpreted as official agency positions

- White Paper organized to provide:
 - Description
 - Draft preliminary rule text (§ 53.1480)
 - Combined license for testing manufactured reactors (COL-TMR)
 - Commission findings on operating states*

* See also FRN Question 7. under Part 53, Subparts E and H—Manufacturing Licenses

7. Some stakeholders have suggested that a fueled manufactured reactor with appropriate protections against criticality should not be categorized as a utilization facility under NRC regulations or Section 11cc. of the AEA.

The NRC is seeking comment on possible approaches where the NRC could find that a fueled manufactured reactor would not be a utilization facility, the basis for such a finding, and the potential benefits of and potential issues with such a finding.

White Paper

- Provided to support discussions
- Should not be interpreted as official agency positions

- White Paper basic approach
 - Building from proposed § 53.620(d)
 - Unirradiated fuel loaded (manufacturing license; Part 70)
 - Limit introduction of byproduct material
 - Radioactive inventory, decay heat
 - Assume in-factory conditions for licensing-basis events
 - Limited consequences assumed in categorizing hazards
 - Consideration of various regulations and licenses
 - Part 53 (Manufacturing license, combined license)
 - Part 70 (Special nuclear material)
 - Part 30 (Byproduct material)
 - Parts 71, 73, 74 and others as needed

White Paper

- Provided to support discussions
- Should not be interpreted as official agency positions

- Selected White Paper examples (technical requirements)
 - Limit power level ($\leq 5\%$ rated thermal power (commercial))
 - Limit inventory (indirectly via defining restrictive safety criteria (Part 20 annual dose))
 - Licensing-basis events
 - Identified for reactor as tested (e.g., fresh fuel)
 - Mitigated without reliance on human actions
 - Consistent with use of generally licensed reactor operators (GLROs)
 - Design features of manufacturing facility and manufactured reactor
 - Holder of manufacturing license ensures testing does not adversely affect downstream activities (storage, transport, deployment)

White Paper

- Provided to support discussions
- Should not be interpreted as official agency positions

- Selected White Paper examples (technical requirements)
 - Possible alternatives mentioned in draft paper:
 - § 53.440(j) (*aircraft impact*) would not apply
 - §§ 53.415, 53.480, and 53.510 (*external hazards*) would not apply
 - Based on limited consequences, commercial codes
 - § 53.610 (*construction*) would apply to portions of manufacturing facility
 - §§ 53.710 and 53.715 (*SSC configuration control*) would apply for testing
 - §§ 53.730(a) through (e) (*human factors*) would apply
 - § 53.730(f) (*staffing plan*) would be supplemented
 - Test Engineer, Reactor Engineer, GLRO
 - §§ 53.870 and 53.880 (*ISI/IST, Integrity assessment*) would not apply
 - Alternate decommissioning funding requirements (such as Parts 70 and 30) might apply

White Paper

- Provided to support discussions
- Should not be interpreted as official agency positions

- Selected White Paper examples (licensing construct)

- COL-TMR

- Applicable to portions of manufacturing facility and each manufactured reactor (1 through n)

	Testing criteria for first reactor	Testing criteria for subsequent reactors	Criteria for final place of operation
Manufacturing facility	ITAAC (COL-TMR)	§§ 53.710 and 53.715	n/a
Manufactured reactor	ITAAC (COL-TMR (incl ML))	ITAAC (COL-TMR (incl ML))	ITAAC (COL (incl ML))

- Updates to the ITAAC schedule under § 53.1449(a) and ITAAC closure notifications under § 53.1449(c) may address multiple manufactured reactors that are under fabrication or planned to be fabricated under the ML and tested under the COL-TMR
- Conforming changes (e.g., § 53.620(d))