

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 NuScale Design-Centered Review
 Open Session

Docket Number: (n/a)

Location: teleconference

Date: Wednesday, January 15, 2025

Work Order No.: NRC-0183

Pages 1-93

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

NUSCALE DESIGN-CENTERED SUBCOMMITTEE

+ + + + +

WEDNESDAY

JANUARY 15, 2025

+ + + + +

The Subcommittee met via Teleconference,
at 8:30 a.m. EST, Walter L. Kirchner, Chair,
presiding.

COMMITTEE MEMBERS:

WALTER L. KIRCHNER, Chair

RONALD G. BALLINGER, Member

VICKI M. BIER, Member

VESNA B. DIMITRIJEVIC, Member

CRAIG A. HARRINGTON, Member

GREGORY H. HALNON, Member

ROBERT P. MARTIN, Member

SCOTT P. PALMTAG, Member

DAVID A. PETTI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

THOMAS E. ROBERTS, Member

MATTHEW W. SUNSERI, Member

ACRS CONSULTANTS:

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

MICHAEL SNODDERLY

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CONTENTS

Opening Remarks 4

Discussion of SDAA Chapter 3 and 16 12

Staff's Evaluation of NuScale SDAA
Chapter 16 (NRR) 19

Discussion of NuScale LOCA Evaluation Model
Topical Report and Status of High-Impact
Technical Issues 61

Staff's Evaluation of NuScale LOCA Evaluation
Model Topical Report 79

Public Comment 92

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR KIRCHNER: The meeting will now come to order. This is a meeting of the NuScale Design-Centered Review Subcommittee of the Advisory Committee on Reactor Safeguards.

I am Walt Kirchner, chair of today's subcommittee meeting. ACRS members in attendance in person are Ron Ballinger, Greg Halnon, Craig Harrington, Bob Martin, Scott Palmtag, and Tom Roberts. ACRS members in attendance virtually via Teams are Vicki Bier, Vesna Dimitrijevic, David Petti, Matt Sunseri, and myself. We have one of our consultants participating in-person, Steve Schultz, and one of our consultants participating virtually via Teams, Dennis Bley. If I have missed anyone, either ACRS members or consultants, please speak up now.

(No response.)

CHAIR KIRCHNER: Michael Snodderly of the ACRS staff is the Designated Federal Officer for this meeting.

No member conflicts of interest were identified for today's meeting, and I note that we have a quorum, as well.

During today's meeting, this Subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 will receive a briefing on the staff's evaluation of
2 NuScale Power LLC's US460 Standard Design Approval
3 Application; Chapter 3, Design of Structures, Systems,
4 Components, and Equipment; Chapter 16, Technical
5 Specifications; and Loss-of-Coolant Accident
6 Evaluation Model Topical Report. We will also be
7 briefed on the status of high-impact technical issues
8 by the NuScale staff.

9 We previously reviewed the certified
10 NuScale US600 design, as documented in our July 29,
11 2020 letter report, "Report on the Safety Aspects of
12 the NuScale Small Modular Reactor." Like the staff,
13 we are performing a delta review between the two
14 designs, including a power uprate from 50 to 77
15 megawatts electric per module.

16 We are reviewing these chapters as part of
17 our statutory obligation under Title 10 of the Code of
18 Federal Regulations, Part 52, Subpart E, Section 141,
19 referral to the Advisory Committee on Reactor
20 Safeguards to report on those portions of the
21 application which concern safety.

22 The ACRS was established by statute and is
23 governed by the Federal Advisory Committee Act, or
24 FACA. The NRC implements FACA in accordance with our
25 regulations. Per these regulations and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Committee's bylaws, the ACRS speaks only through its
2 published letter reports. All member comments should
3 be regarded as only the individual opinion of that
4 member and not a Committee position.

5 All relevant information related to ACRS
6 activities, such as letters, rules for meeting
7 participation, and transcripts are located in the NRC
8 public website and can be easily found by typing
9 "about us ACRS" in the search field on NRC's homepage.

10 The ACRS, consistent with the agency's
11 value of public transparency and regulation of nuclear
12 facilities, provides opportunity for public input and
13 comment during our proceedings. We have received no
14 written statements or a request to make an oral
15 statement from the public, but we have set aside time
16 at the end of this meeting for public comments.

17 Portions of this meeting may be closed to
18 protect sensitive information, as required by FACA and
19 the Government in the Sunshine Act. Attendance during
20 the closed portion of the meeting will be limited to
21 the NRC staff and its consultants, applicants, and
22 those individuals and/or organizations who have
23 entered into an appropriate confidentiality agreement.
24 We will confirm that only eligible individuals are in
25 the closed portion of the meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The ACRS will gather information, analyze
2 the relevant issues and facts, and formulate proposed
3 conclusions and recommendations, as appropriate, for
4 deliberation by the full Committee.

5 A transcript of the meeting is being kept
6 and will be posted on our website. When addressing
7 the Subcommittee, the participants should first
8 identify themselves, and speak with sufficient clarity
9 and volume so that they may be readily heard. If you
10 are not speaking, please mute your computer on Teams,
11 or by pressing star-6 if you're on your phone.

12 Please do not use the Teams chat feature
13 to conduct sidebar discussions related to the
14 presentations; rather, limit the use of that function
15 to report IT problems. We ask everyone in the room,
16 please put all your electronic devices on silent mode
17 and mute your laptop microphone and speakers. In
18 addition, please keep sidebar discussions in the room
19 to a minimum, since the ceiling microphones are live.

20 For the presenters, your table microphones
21 are unidirectional and you'll need to speak into the
22 front of the microphone to be heard.

23 Finally, if you have any feedback for the
24 ACRS about today's meeting, we encourage you to fill
25 out the public meeting feedback form on the NRC's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 website.

2 And now I just want to make a personal
3 note. Here in Santa Fe, it's a nice, balmy 15
4 degrees. It's dark. We have a full moon out. On the
5 West Coast, where our colleagues from NuScale are,
6 it's probably much darker out there. I hope the
7 moon's out, it's spectacular.

8 Thank you. We normally try and schedule
9 the NuScale meetings for afternoon sessions, but,
10 given the amount of material we want to cover today,
11 NuScale has agreed to join us at -- I think it's about
12 5:30 a.m. out there in Oregon.

13 So, with that, thank you. And we'll now
14 proceed with the meeting. I think we'll start with a
15 opening statement from the NRC staff.

16 Greg, if you could direct things from
17 there?

18 MEMBER HALNON: Go ahead.

19 MR. JARDANE: Good morning, Chair
20 Kirchner, Vice Chair Halnon. Good morning to the ACRS
21 Subcommittee members, NuScale participants, NRC staff,
22 and members of the public. My name is Mahmoud
23 Jardane, and I serve as the branch chief of the New
24 Reactor Licensing Branch, responsible for the
25 licensing of NuScale US460 design, in the Division of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 New and Renewed Licenses, NRR.

2 Thank you for the opportunity --

3 CHAIR KIRCHNER: Could I interrupt you for
4 a minute? Sorry. Would you pull your microphone
5 closer? Those of us on Teams are not getting a good
6 audio signal.

7 MR. JARDANE: All right, is that any
8 better?

9 (No response.)

10 MR. JARDANE: Thank you for the
11 opportunity today for the staff to present on their
12 review of select NuScale US Standard Design Approval
13 Application, SDAA, Chapters and topical reports. As
14 you are aware, the staff is reviewing all chapters of
15 the SDAA concurrently, with staggered completion dates
16 based on the complexity of the chapter and the extent
17 of the change from the certified NuScale US600 design.

18 Today, the staff will be presenting on
19 their review of the fourth group of SDAA chapters and
20 topical reports, including Chapter 16, Technical
21 Specifications, and the Loss-of-Coolant Accident
22 Evaluation Model Topical Report.

23 Earlier this year, the staff presented to
24 the Subcommittee on Chapter 2, portions of Chapter 3,
25 Chapters 7, 8, 9, 10, 11, 12, 13, and 14, portions of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Chapter 17, and Chapter 18. Staff is finalizing their
2 review of the remaining SDAA chapters and topical
3 reports and will inform the ACRS on the safety
4 evaluation of the remaining chapters. Topical reports
5 are available to the ACRS.

6 In today's meeting, the staff will focus
7 on the deltas from the design specification that the
8 NRC has approved and this Committee -- and the
9 Committee reviewed in the past. Once again, thank you
10 for the opportunity, and we look forward to a good
11 discussion.

12 MEMBER HALNON: Thank you, MJ.

13 CHAIR KIRCHNER: Thank you. Greg, if I
14 may, I noticed I made a mistake. We are not covering
15 Chapter 3 today. That will be taken up next month, on
16 February -- let me just get the date -- it will be on
17 Tuesday, February 4. So, just Chapter 16, the LOCA
18 Topical Report, and the HITI status. Thank you.

19 MR. TESFAYE: Excuse me. This is Getachew
20 Tesfaye. Chair, I thought we were going to be
21 following up on the past presentation on Chapter 3, to
22 close up some --

23 (Simultaneous speaking.)

24 CHAIR KIRCHNER: Oh, yes. Yes, you're
25 correct. I misspoke. Go ahead. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Right. We have just a
2 quick follow-up on Chapter 3. The Chapter 3 on
3 February 4th will be the 3.7, 3.8, and 3.9.2 aspects
4 of it. So it's a little confusing, the fact that we
5 split Chapter 3 up in a couple different places.
6 That's the clarification.

7 Tom, it's to you now, I believe.

8 MR. GRIFFITH: Yeah, good morning. Thomas
9 Griffith, Licensing Manager, NuScale Power. I wanted
10 to thank you for the opportunity to present on Chapter
11 16, the Loss-of-Coolant Accident Evaluation Model, and
12 for the opportunity to present an update for the high-
13 impact technical issues.

14 I would like to recognize the efforts by
15 both the NRC staff and NuScale staff, and express my
16 appreciation of the efforts that have gone into the
17 review thus far. Furthermore, I would like to thank
18 my NuScale counterparts for supporting such an early
19 meeting. It is much appreciated for you all to be on
20 the phone at such an early time, but it is essential
21 that we have the opportunity to adequately discuss the
22 topics that we're going to talk about today.

23 So, in conclusion, thank you for this
24 opportunity, and thank you to the NRC staff, as well
25 as NuScale.

1 MEMBER HALNON: Okay. Do you have --
2 who's presenting at this point?

3 MR. GRIFFITH: I have Gary Becker on the
4 line.

5 MEMBER HALNON: Okay. Gary, you're up.

6 MR. BECKER: Good morning. Make sure I
7 can be heard over there.

8 MEMBER HALNON: Yes. Give your name so
9 the court reporter, too.

10 MR. BECKER: Thank you. Gary Becker. I
11 am NuScale's Senior Regulatory Affairs Counsel. I've
12 been with NuScale for almost 15 years, where I serve
13 as our nuclear and licensing attorney. And, Walt, I
14 can report that it is, indeed, 5:30 in the morning
15 here, but unfortunately the moon is obscured, so it's
16 just very dark.

17 I appreciate the opportunity to -- before
18 you get into the heart of today's meeting - the
19 opportunity to discuss the Subcommittee's draft
20 Chapter 3 memorandum on the topic of standardization
21 and downstream licensing reviews. We don't have any
22 specific concerns with the memo's content, but I did
23 want to take a few minutes to share our views on the
24 topic and put those on the record.

25 NuScale recognizes the Subcommittee's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 concerns for standardization and efficient licensing
2 reviews. We agree. We were concerned with, and paid
3 a lot of attention to, achieving standardization in
4 our SDA application. We applied lessons learned from
5 prior design reviews, up to and including the NuScale
6 DCA, and from recent reactor construction projects.
7 We drew upon the extensive experience of our
8 engineering licensing personnel in those efforts.

9 Just a high level on our application
10 approach, the NuScale design philosophy ensures
11 standardization by consolidating as much of the
12 safety-related SSCs as practical into the factory-
13 fabricated NuScale power modules and the standardized
14 reactor building, which will be constructed using
15 modular construction.

16 Our SDAA follows a graded approach to
17 design information, providing detailed descriptions in
18 areas that are more important to safety and less
19 information in areas of lesser safety significance.
20 Reducing the bulk of our application in some areas
21 optimizes the user's and NRC's attention on what is
22 important versus what isn't.

23 As just one example, because our ultimate
24 heat sink is inside of a protected seismic Category 1
25 structure, it doesn't really matter, for the sake of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 safe shutdown considerations, if a plant is water-
2 cooled or air-cooled, next to a lake or in a desert.
3 So we have left some of those specific design details
4 to a downstream user.

5 The Subcommittee's Chapter 3 draft
6 memorandum discusses some COL items in Chapter 3 as
7 examples with respect to standardization. The design
8 information provided in the SDAA prescribes a complete
9 and final design, essentially complete and final
10 design, that must be built by a licensed applicant
11 referencing it, with limited and targeted allowances.
12 One of those allowances: where final design
13 information is not yet known or is not included in the
14 FSAR description.

15 So, generally speaking, these are cases
16 where it's not practical for NuScale to complete the
17 design at this stage, or it's commercially prudent to
18 provide some flexibility for the applicant. In such
19 cases, the SDAA prescribes the safety implications, if
20 any, that must be considered and completed in the
21 detailed design.

22 Another allowance is where a license
23 applicant changes an aspect of the design that is
24 described in the FSAR, what we refer to as a
25 departure. Where departures are anticipated, the SDAA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 prescribes confirmatory considerations in safety-
2 significant areas. In all instances, the general
3 requirements to address safety considerations for
4 departures will apply.

5 I wanted to comment on -- note those
6 areas, because these allowances and processes are
7 central to making the standard design usable. While
8 a high degree of standardization is important to
9 realize the safety benefits intended by the
10 Commission, and standardization is essential to
11 achieve efficient plant licensing reviews, as you've
12 noted, we view that undue stringency and rigidity in
13 standardization would likely bring about the opposite
14 result. That is, if standardization processes are too
15 burdensome for future design applicants to use, they
16 won't.

17 As the Subcommittee's draft memo observes,
18 we expect a first-of-a-kind reference COL to complete
19 any necessary design details and address site-specific
20 features, and then commercial considerations will
21 drive that design to be repeated to the extent
22 possible in subsequent COLs. So these COL mechanisms
23 compliment the SDAA to ensure standardized, as-built
24 designs.

25 One comment on the topic of efficient

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 downstream licensing reviews. As noted in the
2 Subcommittee's draft memo, efficient, nth-of-a-kind
3 licensing reviews are essential to meeting the ADVANCE
4 Act objectives, and processes to focus review on
5 safety-significant issues would help in that regard.

6 For example, I discussed a moment ago the
7 potential for COLA departures. If a departure doesn't
8 alter the methodology or conclusions of the referenced
9 design, then it should be dispositioned quickly in the
10 staff and ACRS reviews. The design certification
11 rules provide a 50.59-like process for that purpose,
12 but NuScale has noted the SDA regulations do not
13 provide something similar.

14 We've urged in a ongoing rulemaking to
15 consider this issue, for the NRC staff to consider
16 this issue, and that's the Alignment of Licensing
17 Processes and Lessons Learned From New Reactor
18 Licensing rulemaking, addressed by SECY-22-0052, and
19 recently approved to go forward in a Commission Staff
20 Requirements Memorandum.

21 I note that the staff's position in their
22 draft-proposed rule falls short of our recommendation,
23 and we look forward to weighing in on that when the
24 proposed rule is published for comment. I bring it up
25 because that might be -- that rulemaking might provide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 an area for efficient nth-of-a-kind licensing reviews
2 to be considered and approved, and might warrant
3 attention.

4 So, in conclusion, the NuScale SDAA
5 provides a highly standardized, optimized licensing
6 basis for future license applicants to follow. We
7 agree the reference in subsequent COL processes are an
8 important aspect of turning the standard design into
9 standardized plants, and in ensuring timely and
10 efficient licensing reviews in the process.
11 Allowances for limited variations in site-specific
12 designs are essential to using standardized designs,
13 and commercial incentives will minimize, and licensing
14 controls will address, the safety of such variations.

15 Importantly, our SDAA, and the standard
16 design processes more generally, would not allow the
17 degree of design divergence that occurred in earlier
18 standardization efforts under Part 50.

19 And, finally, we agree that an efficient
20 NRC review process for license applicants will be
21 important for the industry and the agency to meet the
22 objectives of the ADVANCE Act, while supporting our
23 objectives for efficiently building safe nuclear
24 facilities.

25 Thank you for the opportunity, and happy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to answer any questions that -- if you have them.

2 MEMBER HALNON: Any questions from members
3 in the room?

4 (No response.)

5 MEMBER HALNON: Online, any questions?

6 (No response.)

7 MEMBER HALNON: Gary, thank you. That was
8 an excellent summary and conclusion. This is -- I'm
9 sorry, James, this is Greg Halnon. Since I was the
10 primary author of the memo, we'll be going through the
11 memo in the next, I believe, full Committee meeting,
12 during our P&P session, our Practices and Procedures
13 session, so we'll get it fine-tuned there.

14 But I think the learning process that
15 we're going through, both in this one and what we did
16 in Kairos, and probably in the next couple, on what an
17 NOAK, or nth-of-a-kind, looks like, will be a key
18 input to the rulemaking coming up. So, I appreciate
19 that plug there, Gary. We think that's going to be
20 important, and incumbent on us as an agency to define
21 and understand how that's going to impact our
22 resources going forward so we can meet the ADVANCE
23 Act.

24 One last chance, any questions or
25 comments?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 (No response.)

2 MEMBER HALNON: Okay, Tom, it sounds like
3 -- Walt, if you're okay, we'll proceed on with Chapter
4 16.

5 CHAIR KIRCHNER: Yes, go ahead, Greg.

6 MR. GRIFFITH: All right. This is again
7 Thomas Griffith. Appreciate the opportunity to
8 present Chapter 16. We will have Karl Gross
9 presenting Chapter 16 in lieu of Gene Eckholt. And so
10 at this point I'll turn over to Karl Gross to begin
11 the presentation of Chapter 16.

12 MR. GROSS: Thank you, Tom. My name is
13 Karl Gross. I'm with NuScale. I joined them back in
14 2014, originally, primarily working on the technical
15 specifications. I'll be covering the tech specs and
16 the changes that have occurred to those tech specs
17 since the DCA was submitted.

18 Can I have the next slide, please? And we
19 can go -- do that again. There we go. That's the DOE
20 acknowledgment, of course, supporting our work. Next
21 slide. There we go.

22 NuScale included a Part 4 Generic
23 Technical Specifications with the SDAA, consistent
24 with the statements of consideration for the 2007 rule
25 change to 10 CFR 52, where the Commission expressed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 its expectation for the contents of the application
2 for design approvals to contain, essentially, the same
3 technical information required by a DCA.

4 We recognize that it's difficult to
5 perform a review of a design without having
6 accompanying technical specifications. Subpart E of
7 10 CFR 52 does not require technical specifications
8 for consideration, but, as I said, we went ahead and
9 included them.

10 We can go to the next slide, please.
11 These are several -- there were several changes that
12 resulted in changes to the GTS. Obviously, the most
13 noteworthy driver was the increase in thermal power
14 from 160 to 250. We'll cover the rest of these as we
15 go through the slides.

16 Next slide, please. Development of the
17 SDAA GTS, as we mentioned, started with the DCA model
18 tech specs as a model, and then we incorporated
19 changes resulting from the design and analyses using
20 criterion 50.36, applying those criteria. We also
21 considered industry Travelers, used the writer's
22 guide, the industry writer's guide, for format and
23 content, as appropriate, with, obviously, some little
24 differences there, since that was written for the
25 large PWRs and BWRs. And provided a summary of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discussions of this process in our technical report
2 which was submitted to the staff. That tech report
3 highlights the differences between the DCA and the
4 US460 GTS at the time of the SDAA submittal.

5 Next slide, please. The next couple
6 slides highlight some of the differences and changes
7 that occurred between the two sets of technical
8 specification GTS. One of the important ones on this
9 one I'd like to highlight is the remote shutdown
10 station LCO was removed from the tech specs because of
11 our passive design -- did a more careful review of it,
12 the way we implement it.

13 And next slide, some more changes. A
14 couple things to note here, one of them -- and most of
15 these will be addressed in other discussions,
16 obviously, the design itself or the analyses. But we
17 reduced the number of reactor vent valves, those are
18 the valves above the -- up high on the reactor vessel
19 from three to two. We also added an LCO, or what we
20 call ECCS Supplemental Boron System, which is
21 important for extended cooling periods to maintain
22 shutdown margin -- maintain a reactor shutdown.

23 Next slide, please. The NRC review of the
24 Chapter 16 and the proposed GTS resulted in 68 audit
25 items, which have all been resolved. There are no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 RAIs outstanding specifically related to the tech
2 specs, however, other changes are driving, or have a
3 potential to drive, additional changes. So, as other
4 RAIs are resolved, we're watching those carefully.

5 MEMBER SUNSERI: This is Matt Sunseri. I
6 have a question about the review process.

7 MR. GROSS: Go ahead.

8 MEMBER SUNSERI: I know you're referring
9 to the NRC review there. You know, when I look at the
10 topical -- or the technical report and how they
11 construct these tech specs, you know, you outlined
12 clearly how you followed those. And I think, you
13 know, in many cases this individual limiting
14 conditions for operation, or whatever, are derived
15 from technical, specific, you know, ways that the
16 system functions. But some of them you have to put
17 more thought into the situation or the circumstances
18 or the operating parameters or, you know, what can or
19 cannot happen at the plant. So it requires some
20 careful thought on, you know, thinking about the
21 scenario and then what would be bounding for including
22 in a technical specification.

23 So, it looks like you did a really good
24 job on that. But my question is, did you have any
25 kind of independent peer review to validate that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 didn't miss anything? Because you took out a lot of
2 stuff, based on your experience. You added a few
3 things, but, you know, it's the devil's in -- I don't
4 want to say that -- but, you know, sometimes it can be
5 hard to not know what you do not know from your
6 internal perspective, so having that peer, independent
7 peer, can open your eyes for things. Did you have a
8 peer review or anything?

9 MR. GROSS: Not so much independent, but
10 we do work very closely with our operating group and
11 also with our safety analysis group. They spend
12 extensive time, I'll say it this way, picking apart
13 our proposed tech specs. As you know from working
14 with operators, probably, versus licensing, we spend
15 a lot of time working with them to make sure that our
16 intent is clear and what the -- that it aligns with
17 the safety analyses. So, that was carefully
18 considered and we spent untold hours doing that.

19 It was -- the 50.36 identification
20 process, as described in the DCA tech report, was
21 basically reapplied for the SDAA. So there was also
22 a, I won't call it a clean sheet, but it was close to
23 a clean sheet review during the development of these
24 tech specs.

25 MEMBER SUNSERI: Okay, that's good. Just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a short follow-up, then. A lot of -- not a lot of
2 times, but it is possible that when you go into
3 operation you get similar scrutiny like this, so
4 should you find, when the plant is in operation, that
5 you have a tech spec that doesn't quite cover you --
6 I don't want to use the word, inadequate tech spec,
7 like it's commonly used, but, you know, you find
8 something that you might have missed that you need to
9 include, how would that be dealt with?

10 MR. GROSS: Depending on when it's
11 identified, you know, if we were actually at the
12 operating, where we've got fuel loaded -- in either
13 case, we're going to have to go through NRC approval,
14 obviously, to get a change identified.

15 I, personally, happen to have been through
16 that. And you're right, there's a -- there will be
17 changes. I hate to say it that way, but that's my
18 experience, anyway, every plant I've ever heard of,
19 and clarifications. Sometimes they can be made at the
20 basis level, which we can do ourselves, under the
21 rules. But if a change to the actual technical
22 specifications, we'll have to get Commission approval
23 beforehand. There'll be a continual feedback loop
24 during that process.

25 MEMBER SUNSERI: Okay, perfect. Thank

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you.

2 MEMBER KIRCHNER: Karl, this is Walt
3 Kirchner. The third sub-bullet on the slide that's in
4 front of us right now under "noteworthy changes,"
5 maybe this is a question for the closed session, but
6 what caught my eye was that the geometric form of the
7 boron pellets, could you elaborate on that?

8 I am presuming that just is a time,
9 depending on the form of the pellets that would
10 perhaps impact the time that it would take for that to
11 dissolve and go into solution, is that what you are
12 referencing here?

13 MR. GROSS: That's basically what it
14 amounts to is the dissolution rate that was assumed in
15 the safety analysis.

16 MEMBER KIRCHNER: Okay.

17 MR. GROSS: Our safety analysis people
18 maybe can jump in if they feel they want to.

19 MEMBER KIRCHNER: But it manifested itself
20 in the form of a time specification?

21 MR. GROSS: Actually I think we modeled it
22 based on an expected and demonstrable dissolution
23 rate.

24 MEMBER KIRCHNER: Right.

25 MR. GROSS: But we didn't, you know -- it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 will be in the COLA is where we are including that
2 requirement, the actual specifics.

3 MEMBER KIRCHNER: Okay.

4 MR. GROSS: Right now it's kind of like,
5 you all remember the baskets in the bottom
6 containments and there was issues early on about them
7 turning into a big slug, I guess is a nice way of
8 saying it.

9 MEMBER KIRCHNER: Right.

10 MR. GROSS: We are trying to avoid that
11 and we have avoided it by including requirements for
12 the form to ensure that they dissolve in an
13 appropriate timeframe.

14 MEMBER KIRCHNER: Okay, all right. Thank
15 you.

16 MR. GROSS: Mm-hmm.

17 DR. SCHULTZ: Karl, this is Steve Schultz.
18 Your last bullet here, the change that you had to make
19 associated with the generic tech specs with regard to
20 the steam generator program, could you expand on that,
21 what was it that you had to address there?

22 MR. GROSS: I'll defer some of this to
23 others, but it basically boiled down to the Staff had
24 concerns with the initial inspection to ensure that we
25 had adequate inspections during the early operational

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 days. I don't know --

2 MR. SNUGGERUD: This is Ross Snuggerud
3 with NuScale.

4 MR. GROSS: Thank you, Ross.

5 MR. SNUGGERUD: Yeah. What Karl said is
6 basically correct. There was a desire to make sure
7 that in support of our position on how the steam
8 generators would function and how the steam generator
9 would potentially be impacted by density wave
10 oscillations at low power, the industry's behavior of
11 spacing out the steam generator inspections is more
12 implied than stated, and so in our generic tech specs
13 it will state that we need to do certain fractions of
14 the inspections every refueling outage.

15 So, even though that's the way the
16 industry does it generically, it's implied in the
17 industry and its industry behavior. For NuScale, they
18 wanted to ensure that we actually have our owners
19 doing partial inspections following the first and
20 subsequent and not just waiting for the full
21 inspection period to do the entire steam generator
22 inspection.

23 MS. BLUMSACK: This is Erin Blumsack from
24 NuScale. I just wanted to clarify what Ross said. We
25 have a COL item in Chapter 5 indicating that we will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 do inspections in a staggered basis until full
2 inspection of the tubes is complete.

3 In the technical specifications we didn't
4 change that, we reduced the amount of time between 100
5 percent tube inspections and we also bracketed the
6 tube plugging criterion.

7 DR. SCHULTZ: Thank you.

8 MEMBER BIER: Quick question from Vicki
9 Bier. Can you talk about whether the staggered steam
10 generator inspections have adverse cost implications
11 for users or do you think the cost is about
12 equivalent?

13 MS. BLUMSACK: This is Erin Blumsack from
14 NuScale. We haven't evaluated the potential cost,
15 however, the steam generator program indicates that we
16 will complete a degradation assessment and that will
17 inform future inspections.

18 So we're not expecting that anyone would
19 do anything they --

20 (Audio interference.)

21 MEMBER BIER: Thank you.

22 MEMBER MARTIN: This is Bob Martin. I had
23 a question, and I was planning on using it for the
24 LOCA but I'll bring it in here, are there tech specs
25 -- Someone's got a hot mic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Anyway, are there tech specs associated
2 with leak rates of the RVVs and RRVs and then the
3 other part of the question that would be a stretch is
4 how do you mitigate excessive leaks, leak rate?

5 MR. GROSS: This is Karl Gross again. The
6 RVV and RRV leak rates would be the same as those for
7 the RCS as a whole. So, yes, that is addressed in
8 Section 3.4 of the tech specs.

9 As far as mitigation, as you know probably
10 the containment is operated under vacuum conditions
11 and we have systems to maintain it there and monitor
12 the pressure there and remove leakage --

13 (Simultaneous speaking.)

14 MEMBER MARTIN: Okay.

15 MR. GROSS: Okay. So I guess those --

16 MEMBER MARTIN: Is that also for say
17 possible air ingress? You have a vacuum, so
18 presumably you have a line to, you know, vacate it.

19 MR. GROSS: Yeah.

20 MEMBER MARTIN: Same kind of thing, you
21 monitor for potential air ingress into the
22 containment?

23 MR. GROSS: Yeah, not specifically as air
24 but we watch the pressure, I believe, unless something
25 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: Okay. That would be the
2 same thing.

3 MR. GROSS: Yeah.

4 MEMBER MARTIN: Yeah.

5 MR. GROSS: Next slide, I guess, if we're
6 ready. One change that has occurred as we determined
7 it appropriate to include an LCO for the passive auto
8 re-combiner, that it will be discussed further in the
9 Chapter 6 presentation.

10 I know that's coming up in the future as
11 to why it was included. I want to point that out
12 there is a new LCO for that.

13 Next slide. I think that's it. Thank
14 you, unless anybody has any more questions.

15 MEMBER SUNSERI: This is Matt Sunseri.
16 I've got maybe one or two more. Excuse me. I noticed
17 that the introduction to the technical report stated
18 that the tech specs are for a single module and I
19 understand that.

20 So I presume that each module would then
21 have its own technical specifications, would that be
22 accurate?

23 MR. GROSS: That is correct. The intent
24 is to keep them aligned as much as possible. I
25 recognize I think over the life of a facility there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 may be some small variations as changes are
2 incorporated into the design.

3 If they are, that's obviously not our
4 intent, but, yeah, there would be a complete set for
5 each module.

6 MEMBER SUNSERI: Yeah. So -- yeah, well
7 that's where my question, and I wouldn't call it,
8 maybe concern is too strong of a word, but at least my
9 experience with multiple reactor sites, I'll call it
10 that, that, you know, in some cases you have a common
11 control room but they are segregated enough such that,
12 you know, you have Unit 1 operators, you have Unit 2
13 operators, you have Unit 1 tech specs, you have Unit
14 2 tech specs, whatever, and they are pretty separate
15 and the operating crew can, you know, pretty much
16 guarantee they know which unit they're on and which
17 set of tech specs they're in, but the way your control
18 room is going to be operated you're going to a few
19 operators covering as many as six modules with six
20 different tech, potentially six slightly different
21 tech specs. That seems like a pretty challenging
22 human performance challenge.

23 What are your thoughts on how you're going
24 to manage that and is there anything that needs to be
25 put back into the tech specs, into a single unit tech

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 spec. Single module for you guys.

2 MR. GROSS: Right now we're obviously
3 we're not aware of anything that would be required to
4 distinguish between them. However, recognizing that
5 there's a potential for that in the future, we're
6 going to leverage heavily I think our automated
7 systems.

8 As you know the control room is very, can
9 be automated, almost all the functions. It's kind of
10 spooky if you're used to old plants. But, yeah, so
11 hopefully any changes we can address that way or
12 incorporate appropriate controls to ensure alignment
13 that way to support our operators.

14 Ross, would you like to jump in on any of
15 this?

16 MR. SNUGGERUD: I mean I think the most
17 likely condition and the one we have talked to our
18 potential operators about is the fact that we are
19 going to be implementing some change on a module and
20 that's going to require us to cycle through the tech
21 specs, which is one of the advantages about having
22 individual tech specs.

23 If we need to make a modification and then
24 we're implementing that modification systematically
25 throughout the modules over a course of refueling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 outages we can keep the tech specs up to date for the
2 individual modules that have had that configuration
3 change.

4 We don't really expect a lot of module-
5 specific technical specification changes, so, you
6 know, at most I think we would have two versions of
7 the tech specs at any given time.

8 But, you know, as Karl suggested, we are
9 going to be providing the operators with lots of
10 support through the interface and there are lots of
11 different ways to address that.

12 Certainly it's not -- you know, your
13 concern is valid if we started to have deviations
14 between the tech specs, but the idea of keeping the
15 tech specs individual to the modules was intentional
16 and largely to support operations at the plant.

17 MEMBER SUNSERI: Yeah, that's good and I
18 appreciate that. You know, having been in these kind
19 of control rooms, or situations before, you might just
20 give some consideration to how it would flag or
21 highlight, you know, any potential differences so that
22 you guys -- human performance, right, you know how
23 that goes.

24 MR. SNUGGERUD: Yeah, absolutely, we
25 agree.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER SUNSERI: Yeah. Hey, and I have
2 one more technical question that I'm not sure it's
3 going to come up in an individual chapter review so
4 I'm going to ask it now.

5 It deals with the definition of MODE 2 and
6 MODE 3, hot shutdown and safe shutdown and there is a
7 various combination of passive cooling or not passive
8 cooling, minimal temperature for criticality,
9 whatever.

10 I understand all that, but I just want to
11 ask one question. Is there a reactivity -- are both
12 those conditions limited to less than 0.99 or, yeah,
13 0.99 k-effective?

14 MR. GROSS: That is correct.

15 MEMBER SUNSERI: Okay. It was -- I
16 thought it was when I read the GTS, but, you know,
17 some of the documentation I read it wasn't clear that
18 that condition was always -- so it is truly less than
19 0.99, okay. I'm good. Thank you.

20 MR. GROSS: Yeah. Yeah, it's specified
21 that way in the definition of MODES, that table at the
22 end of Section 1.1 of the tech specs.

23 MEMBER SUNSERI: Yeah, I saw that but then
24 I also know that those aren't the real tech specs,
25 right, that's just a generic one that you submit for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reference?

2 MR. GROSS: Yes. But the intent is that
3 that's where it will be.

4 MEMBER SUNSERI: Okay, all right.

5 MR. GROSS: The MODE tables are pretty
6 well defined.

7 MEMBER SUNSERI: Okay. That's all I had.
8 Thank you.

9 MEMBER KIRCHNER: Members, any further
10 questions of NuScale before we turn to the staff?

11 (No response.)

12 MEMBER KIRCHNER: Mike, correct me if I've
13 got the agenda wrong. Are we going to complete 16?

14 MR. SNODDERLY: No, you're right. You're
15 right, Walt. We found that --

16 MEMBER KIRCHNER: Okay.

17 MR. SNODDERLY: Unless the Committee gives
18 us other feedback, but we find it's best to complete
19 a chapter and then the staff going --

20 (Simultaneous speaking.)

21 MEMBER KIRCHNER: Right. Right. So if
22 there is no further questions I think we're ready to
23 move to the Staff's presentation.

24 MEMBER HALNON: Okay. Give us a few
25 minutes to change the seats and computers and I'll let

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you know when we're ready, Walt.

2 MEMBER KIRCHNER: Okay, mm-hmm.

3 (Pause.)

4 MEMBER HALNON: Okay, Walt, we're going to
5 get started again.

6 MS. SCHILLER: My name is Alina Schiller.

7 MEMBER HALNON: Please turn your
8 microphone on. Speak right into it.

9 MS. SCHILLER: Good morning.

10 MEMBER HALNON: That's not close enough.

11 MS. SCHILLER: Good morning.

12 MEMBER HALNON: That's better. Thank you.

13 MS. SCHILLER: My name is Alina Schiller.

14 I am a project manager with the Office of Nuclear
15 Reactor Regulation, Division of New and Renewed
16 Licensees, New Reactor Licensing Branch.

17 I would like to thank the ACRS
18 Subcommittee, NuScale Power, LLC, and the general
19 public for entertaining the NRC for the presentation
20 of the Staff's safety evaluation of NuScale Standard
21 Design Approval Application from Chapter 16 and the
22 Part 2, Revision 1.

23 NuScale 70 Part 2, the Final Safety
24 Analysis Report, Chapter 16, Technical Specifications
25 and Part 4, Generic Technical Specifications, Revision

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 0, in December 2022 and Revision 1 in October 2023.
2 From March 2023 to August 2024 the NRC conducted a
3 regulatory audit of FSAR Chapter 16 and Part 4 which
4 generated 68 audit issues. All audit issues were
5 resolved in the audit.

6 Fifty-two audit issues resulted in NuScale
7 submitting supplemental information to address
8 questions raised during the audit. No requests for
9 additional information were issued in Chapter 16.

10 We are here today to discuss the Staff's
11 advanced safety evaluation of Chapter 16 and Part 4.
12 The contributors were Craig Harbuck, the lead
13 technical reviewer and today's presenter, supported by
14 Steve Smith, Clint Ashley, Josh Wilson, all with the
15 Technical Specifications Branch, and the project
16 manager for Chapter 16 and Part 4 supported by
17 Getachew Tesfaye, the lead PM for NuScale SDAA.

18 This slide lists the sections in the FSAR
19 Chapter 16 and Part 4. I am turning it over to the
20 NRC subject matter expert, Craig Harbuck.

21 MR. HARBUCK: Good morning.

22 MEMBER HALNON: Craig, you're going to
23 have to move that real close, as close as you can move
24 it to yourself comfortably.

25 MR. HARBUCK: How's that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: That's good if you keep it
2 that way.

3 MR. HARBUCK: Okay. So I am going to go
4 through changes that we thought were worth mentioning
5 outlining the differences between the DCA certified
6 generic tech specs, the US600 design, and then
7 reviewed the SDA.

8 This slide is to point out one of the key
9 differences in the definition of MODE 3. It was
10 adopted in the SDA. Essentially what has happened is
11 that the MODE 3 in the DCA began at the minimum
12 temperature for criticality, but the MODES 1 and 2
13 covered temperatures above that.

14 There is one thing I would like to point
15 out that might not be obvious to everyone about the
16 MODE 1 definition. It actually corresponds to MODES
17 1 and 2 that you see in normal PWR plant for the
18 operating fleet.

19 So as was mentioned earlier in NuScale's
20 presentation, you can enter MODE 3 from 1 or 2 by
21 initiating passive cooling without first cooling down
22 the module to below the, well the minimum temperature
23 for criticality.

24 That particular temperature which that is
25 was lowered in the SDA from the DCA value of 420

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Fahrenheit to 3.5 and the way you initiate passive
2 cooling when you are at the normal operating
3 temperatures would be to either open up the ECCS
4 valves or by initiating the decay heat removal system.

5 Both of these would result in a
6 significant transient and a fairly quick cool down and
7 so if you're in an action statement and it says shut
8 the plant down to MODE 3 and a lot of times it will
9 indicate, it may give a caveat on a lower temperature
10 range than MODE 3, but typically you wouldn't
11 implement that action statement by initiating passive
12 cooling.

13 The preferred method would just be to use
14 secondary heat sink systems to do that.

15 MEMBER HALNON: So, Craig, this is Greg.
16 What was the purpose then, I mean if the normal
17 shutdown is going to be 48 -- or whatever, a k-
18 effective less than 0.95 and you cool it down to less
19 than 345 is that in there for an operational transient
20 situation or reactor trip of like a loss of power or
21 something?

22 MR. HARBUCK: I can speculate about what
23 the operational conditions might be where this would
24 be appropriate, but --

25 (Simultaneous speaking.)

1 MR. HARBUCK: There must be some
2 operational advantage to being able to say that you're
3 in safe shutdown until you run actually your MODE 2
4 and not have to move that MODE change as long as
5 you're being passively cooled, but I would have to
6 refer to NuScale to address that question.

7 MEMBER HALNON: Okay, that's fine. It's
8 not a game changer, it was just more of curiosity. Go
9 ahead.

10 MR. HARBUCK: Okay. But it is the cycle
11 that the nature of the design and how to operate it
12 because you do have to think about these things when
13 you are deciding what's the appropriate way to account
14 these information constraints from the definitions.

15 I also want to point out that the MODE 3
16 definition before you get to -- well there is a
17 footnote on some instrumentation functions which tell
18 you that certain reactor trip and ECCS functions or
19 PSF functions don't have to be operable if you have
20 just one control rod mechanism being energized in any
21 fast term is being capable of withdrawal and typically
22 that particular footnote is stated as any (audio
23 interference) fairly unique NuScale design features
24 related to coupling and uncoupling control rods.

25 They changed the footnote so that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 could have one rod that you were trying to couple or
2 uncouple would not by energizing the control rod drive
3 to manipulate the rod to do that would necessitate
4 that then goes, is corresponding to instrumentation
5 functions probabilities and that's one difference from
6 the rule, that normal caveat in the footnote in
7 operating.

8 Then going to the next slide, there was
9 one that was adopted recently, recently approved,
10 relatively recently, that clarified the definition of
11 pressure boundary leakage and NuScale elected to adopt
12 those changes.

13 So this mark up here shows the change from
14 what we had in the DCA and what we have now and this
15 is consistent with the industry's understanding of
16 how, and the Staff's understanding of what,
17 particularly that last added sentence.

18 It's something that actually in the bases
19 for the LCO related to leakage that is simply up and
20 made part of that definition.

21 Next slide. And going to the safety
22 amendments chapter, this shows you that the comparison
23 of the different correlations from the DCA to the SDA
24 and the NSP4 correlation was maintained but the other
25 ones were not and then for certain operational

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 aspects, which NuScale could elaborate on, there was
2 an additional correlation that was added on.

3 The other reactor safety limit on peak
4 center line temperature, the fuel did not change,
5 that's quoted there as saying that, and then because
6 of the higher operating pressure in the higher powered
7 design we moved from 1850 to 2000 psi.

8 So the safety limit under, on the reactor
9 coolant system pressure has increased as noted there
10 on the slide.

11 DR. BLEY: This is Dennis Bley. Could you
12 back up a slide to Number 6? Thank you. No. There
13 we are.

14 MR. HARBUCK: Yes.

15 DR. BLEY: Leakage past seals piping
16 gaskets is defined here as not a pressure boundary
17 leak and I don't know that you have specified
18 equipment to the level that would allow us to know how
19 big such leaks could be.

20 I've seen some pretty big ones, like if
21 seals blow out or something like that. Why do you
22 express it this way rather than in terms of maybe a
23 pounds per hour or something, you know, a quantitative
24 definition of what you mean by pressure boundary leak.

25 MR. HARBUCK: The way your point is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 addressed is in the LCO for a leakage for the reactor
2 coolant system --

3 DR. BLEY: And --

4 MR. HARBUCK: And so there is no pressure
5 boundary leakage, that's not allowed. If you identify
6 that then you would be on a shutdown track.

7 That brings up another point, is that
8 currently NuScale in their containment evacuation
9 system it's just what maintains the vacuum in the
10 containment of their operation.

11 They don't currently have a way of
12 determining any leakage that is collected about what
13 the source of that leakage is in terms of is it
14 pressure boundary leakage or is leakage past some,
15 like this phrase says, or is it, you know, is it
16 coming from a secondary system, is it coming from a
17 leaky external system like that containment flood and
18 drain system, or is it, let's see, is it coming from
19 the CVCS, or is it coming from like a feedwater line
20 or something, which is not part of the pressure
21 boundary within the CF.

22 So they essentially will treat any leakage
23 that's detected if I understand correctly, and correct
24 me if I'm wrong, but I think it would essentially
25 treat any leakage they collected in their containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 evacuation system as unidentified leakage, and there
2 is a limitation on that in the LCO.

3 MEMBER HARRINGTON: Dennis, this is Craig
4 Harrington. That added sentence is consistent with
5 the ASME code treatment of pressure boundary that
6 packing seals, gaskets, that's not pressure boundary.

7 DR. BLEY: Okay.

8 MEMBER HARRINGTON: It is, but --

9 DR. BLEY: They are being consistent. I
10 understand, but they are being consistent with the
11 standard. Okay. You know, it just felt funny to me.
12 Thanks, Craig.

13 MR. HARBUCK: Okay, now we can go to the
14 next slide. I think we've covered this, yeah, so
15 let's go to Chapter 3 now. The remaining slides will
16 roughly focus on Chapter 3.

17 So earlier it was alluded to that some
18 specifications were, some LCOs were removed that would
19 have been an additional DCA to your tech specs and
20 then the renewal LCO had it in the SCA and this
21 provides a list of those.

22 The bullets under the two sections that
23 were removed continue to provide some, point to some
24 of the rationale for why those removed and why it is
25 acceptable to do that and I'll just briefly mention

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 those.

2 A remote shutdown station in a typical
3 operating plant would have the ability, would have
4 controls as well as indications that from which
5 personnel who had evacuated the control room be able
6 to shut down the plant and monitor its condition in a
7 safe shutdown situation.

8 In the DCA, the imagined remote shutdown
9 station was only going to have indication and no
10 controls per se because of the envisioned scenario was
11 that if there was a need to evacuate the control room,
12 part of doing that would be to shut down all the
13 reactors, and because of the design, where there
14 really is no operator action needed to ensure you are
15 in safe shutdown after that, then there did not seem
16 to be a need for any duplicate controls in a separate
17 station outside the control room.

18 The indication monitor, it was pointed out
19 during the review that the I&C equipment rooms
20 associated with each module will have, also have
21 indications that are explained in the control room and
22 you can find those in the same information and,
23 therefore, that was seen as being sufficient to
24 monitor the status of the modules in the event of a
25 control room evacuation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 There was also -- and typically the
2 controls you need to make sure that you achieve safe
3 shutdown and operating plants would require, you would
4 have in the safety analysis you might have some
5 assumptions about actions that operators would take
6 and for those you have what's called Type A post-
7 accident monitoring variables that would be seen as
8 needed to provide information the operators would need
9 in terms of to properly conduct that shutdown, but
10 there are no such, there are no Type A variables in
11 the NuScale design, which is another reason they don't
12 have a main LCO also.

13 The in-containment secondary piping
14 leakage in the DCA we address this idea to monitor the
15 leakage and you can use the leak-before-break method
16 to provide yourself assurance that you would be able
17 to recognize when you had the potential for a high
18 energy line break into avoiding any resulting pipe
19 movement that could damage any other equipment in
20 containment and you'd be able to shut down and address
21 that because there would be enough time to do that.

22 In the SDA they have determined that based
23 on the Staff guidance note on the BTP 3-4 and
24 industry's guidance, the standards, that address
25 certain pipes, size of pipes, and that sort of thing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that they have this exclusion criteria and it was
2 determined that the high energy lines in containment
3 satisfy those criteria, so that LCO was deemed not
4 being necessary and the Staff has agreed to that.

5 So that's what we have removed or omitted,
6 but what's been added was, as they mentioned before,
7 the ECCS Supplemental Boron System and that's for
8 assuring that you have adequate shutdown margin for
9 long-term cooling.

10 That system is also implemented to make
11 sure that it's implemented after a reactor trip if you
12 are in a situation where a combination of xenon
13 transients and cool down could get you starting to
14 approach your re-criticality situation with water
15 flowing from the containment.

16 The idea was to make sure that the system
17 actuated and that's a passive design, it's hands off
18 for 72 hours. So after eight hours, unless the
19 operator has determined it's not necessary and they
20 can block the system from actuating, there is an 8-
21 hour post-reactor trip actuation time on ECCS
22 primarily to be able to initiate the dissolving of ESB
23 pellets.

24 That timer is addressed, the verification
25 is addressed in the actuation logic LCO in SR-3333.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The other, another LCO that was added that could very
2 well have been included in the DCA but there was, or
3 I guess NuScale recognized that during MODE 4 when you
4 are moving the module, the passage of decay heat
5 during that evolution is, requires there to be a
6 sufficient volume of water in the containment and so
7 to preclude also any inventory in the containment met
8 within diminished heat transfer capability. They
9 wanted to make sure that any isolation valves from the
10 containment to the outside would be closed.

11 So that is what this LCO is designed to
12 do. It doesn't have to meet the same leakage
13 requirements that you have for like containment
14 isolation valves in that LCO or to make containment
15 operable.

16 It's just designed to maintain the
17 critical inventory to ensure you have adequate cooling
18 and to what the module on the disassembly stand over
19 the refueling area and you've unseated the containment
20 off of its lower portion and, therefore, then
21 everything is filled up to whatever the pool level is.

22 Okay. Then it was also mentioned that the
23 passive auto catalytic be combined and it was
24 determined to satisfy Criterion 3. It was determined
25 to be a safety-related system and it was also somehow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 justified as meeting this criterion in 50.44.

2 If anyone has a question about that I
3 would ask NuScale to respond as I am not that familiar
4 with what those very non-specific words in 50.44
5 correctly say. Any questions about that? Okay.

6 So next slide. So there were -- to me it
7 would be I guess one more significant change was an
8 instrumentation in terms of the instrumentation fluxes
9 that actuate the ECCS and also decay heat removal
10 system, which will be on the next slide.

11 But they changed the way they're measuring
12 level in the riser in the SDA over what they had in
13 the DCA and, therefore, they have ECCS initiation
14 primarily occurring on the riser level.

15 A low level which is designed to protect
16 and trying to prevent uncovering of the top of the riser
17 is blocked and if you go below 500 degrees it's
18 interlocked and it does that.

19 The low riser level is designed to actuate
20 ECCS before you uncover these holes that are in the
21 side of the riser down lower in the vicinity of the
22 steam generator in the downcomer to make sure that
23 there is adequate flow of the high, relatively high
24 concentration reactor coolant in the riser into the
25 downcomer region to alleviate any dilution effects

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 caused by evaporation that any of them had which ECCS
2 has now furnished. As was also mentioned --

3 (Simultaneous speaking.)

4 MEMBER MARTIN: Question real quick. This
5 is Bob.

6 MR. HARBUCK: Okay.

7 MEMBER MARTIN: And maybe this is a
8 NuScale question, but the level instrumentation is
9 that really a DP or is it --

10 MR. HARBUCK: That is done with a
11 specialized kind of discreet -- There are probes that
12 detect --

13 MEMBER MARTIN: Okay.

14 MR. HARBUCK: And those functions actually
15 have like a 60-second delay on when you actually get
16 a change in the signal.

17 MEMBER MARTIN: Okay.

18 MR. HARBUCK: So I think that's built into
19 the substance of the safety analysis. I don't know if
20 there is any software or other I&C magic going on that
21 would interpolate between those discrete levels
22 because they're not that far apart.

23 MEMBER MARTIN: Okay. That's just
24 something I wanted to clarify.

25 MR. HARBUCK: And that's another question

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 which will have, may warrant further investigation for
2 a COL applicant, but --

3 MEMBER MARTIN: Okay. All right, that
4 answers my question. Thank you.

5 MR. HARBUCK: Yes. Okay. Again, they
6 reduced the number of reactor vent valves from three
7 to two and I don't know if that was a change in the
8 size of the valve or if the third valve had simply
9 been there for some other redundancy reason, but to
10 accomplish the ECCS function you need only one reactor
11 vent valve and one recirculation valve.

12 So from that standpoint they are redundant
13 and then each valve itself is also doubly redundant
14 on, that's redundant itself. There are two actuation
15 solenoids on each valve that are separate to the
16 channels of the module protection system that have to
17 be de-energized because you reached the ECCS actuation
18 setting level for those valves to open.

19 Now there is one thing I want to -- this
20 was the subject that we were hitting on and I just
21 wanted to mention it.

22 For most events your reactor vent valves
23 continue to remain shut so that you don't introduce
24 the containment into the initial response to the event
25 and handle it like the decay heat removal system, a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactor trip, what have you, then you may not need to
2 change anything with the containment.

3 And so to maintain those valves shut
4 during those kinds of transients and also during
5 normal operation, the EDAS to which is, that implies
6 special available or quality controls, you know,
7 augmented quality is what they call it.

8 So that -- because before the DC those
9 valves would not open until the pressure difference
10 between the containment and the RCS reached a certain
11 level, a certain level, thereby that had the effect of
12 -- even if you would -- if the actuation set point
13 until you reach that IAB, which was the more
14 mechanical kind of inhibiting of the opening of the
15 valves, the valves wouldn't open.

16 But that's been removed in the SDA with
17 the DES liability has been, combining the system and
18 all of that has been in these areas in which it needs
19 to be addressed or there was any kind of concern that
20 was resolved here.

21 But the reactor recirculation valve still
22 has an IAB and it's helping to still be delayed even
23 if you get to set point. So that's all I wanted to
24 say about that. Next slide.

25 MEMBER ROBERTS: Hey, Craig, it's Tom

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Roberts. Can you clarify, you said there were two
2 solenoids in each of the vent valves and recirculation
3 valves?

4 MR. HARBUCK: That's correct.

5 MEMBER ROBERTS: Is there a tech spec that
6 they both have to be in service?

7 MR. HARBUCK: Yes.

8 MEMBER ROBERTS: Okay. So the intent is
9 that either one will trip a valve or either one will
10 heat it up?

11 MR. HARBUCK: You would need both of them
12 to actuate to cause the valve to open.

13 MEMBER ROBERTS: Okay. So from a tech
14 spec perspective let's say the safety position of the
15 valve would be open and so why would there be a tech
16 spec that says those solenoids have to be in service?

17 MR. HARBUCK: Well if the solenoid -- if
18 they are not in service they would de-energize and the
19 valves are going to open. This is a fail/safe design
20 on all valves to go to their safety position, so this
21 result was not, did not be -- I suppose you could
22 operate with one of them out of service.

23 As long as one of them's keeping it
24 closed, but it's not seen as being a safety-related
25 function. It's called the ECCS holds function. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the -- we could put NuScale on to address this. They
2 would probably do a better job.

3 MEMBER ROBERTS: I guess we'll renew the
4 question later. It just seemed a bit odd. Certainly
5 it's prudent, right, definitely it's prudent if you
6 have the redundancy to have it because you don't want
7 to add inadvertent actuation, but I'm not sure why
8 it's a tech spec because the -- unless there is some
9 concern that inadvertent actuation is a safety
10 concern.

11 MR. HARBUCK: Well the tech spec is
12 focused on not having both of them for the purposes of
13 keeping the valve shut. It's there to make sure that
14 they really de-energize than actuate it.

15 So for tech spec purposes the valves would
16 be inoperable if for some reason you removed power and
17 they didn't change position and, therefore, the valve
18 could not, it would not open.

19 Those basically have a hydraulic lock on
20 the valve keeping it shut and then you de-energize the
21 solenoids the valves open and that removes the lock,
22 so it is kind of complicated in terms of the logic,
23 thinking about it. Anything more to add?

24 (No response.)

25 MR. HARBUCK: Okay. Next slide, decay

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 heat removal system. There is not much to say about
2 this other than that we added a few more
3 instrumentation functions which would cause an
4 actuation of the decay heat removal system.

5 At the bottom there I list the three,
6 those three functions and the events that those
7 functions are designed to mitigate and they all boil
8 down to putting yourself in a safe shutdown situation.

9 That's when you set your MODE to 1 and you
10 would initiate a decay heat removal system that's
11 going to put you in MODE 3, and so that -- any other
12 questions about that?

13 (No response.)

14 MR. HARBUCK: I believe that's the last --
15 oh, yeah, there's one more slide. So we'll go to the
16 next slide. Oh, there's two more slides. Maybe this
17 is it. Yes.

18 Okay. Another change that happened,
19 another change that I want to mention was the boron
20 dilution control, LCO-319. There is a system in
21 NuScale that allows you to heat up the RCS called
22 module heat up system and the way the system works is
23 you have the heat exchanger that on one side is
24 supplied with steam from the non-safety source that
25 generated that, then you take the discharge out of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CVCS and the discharge, I mean the injection line, and
2 the diverted flow by the heat exchanger and then it
3 comes back downstream of where it left back to the
4 injection line warmer and then the injection line
5 terminates in the riser section of the reactor vessel.

6 So in that way you can heat up the unit
7 since there are no reactor coolant pumps to do that
8 sort of thing or to heat up the coolant, but they
9 don't have a module heat up system heat exchanger for
10 each module.

11 There is a common one, so it was
12 recognized there was a potential that if you had
13 errors in alignment you could connect one CVCS system
14 from one module onto another module.

15 So this was added to the LCO and clarified
16 in the surveillance requirements to check the
17 alignment to make sure, you know, you never had more
18 than one module aligned with the module heat up
19 system.

20 That's usually for a relatively brief time
21 when you're starting up and you want to heat up the
22 system. So it's not a likely thing to occur, but it
23 was to see if that was a potential error that could be
24 addressed where safety could be made operationally that
25 could be addressed by highlighting it in the LCO for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 boron dilution control.

2 In the -- I think I mentioned earlier
3 about the MODE 3 applicability of selecting a reactor
4 trip in a de-mineralized water system isolation
5 instrument functions and that the footnote for those
6 functions for MODE 3 is incapable of withdrawal of
7 more than one control rod assembly.

8 So that was a difference from your
9 regular, the usual definition, and also a difference
10 from what they had in the DCA, because I think this
11 particular concern was not identified in the DCA or it
12 was not being needed to -- it just didn't come up.

13 The last thing, it was alluded to earlier
14 there were some changes from what was in the standard
15 tech spec and what was in the DCA relative to the
16 steam generator requirement and some items here that
17 were changed was the period between of having to
18 inspect all of the tubes after the initial -- I think
19 at the end of the first refueling outage there is, or
20 at the first refueling there was supposed to have been
21 another full inspection of all the tubes.

22 But subsequent to that you have 72
23 effective full power months in which I remember they
24 were going to do staggered in the sense of the valves
25 on the tubes until, so by the end of 72 effective full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 power months you would have all your tubes expected to
2 be in.

3 So that's -- and previously had been like
4 96 months, so it was reduced. We have folks in the
5 room that maybe could address why that is. The other
6 parts of the description of the inspection discussion
7 in this program specification talked about the fact
8 that RCS pressures on the outside of the tubes and the
9 tubes are susceptible primarily to collapse from
10 collapse or buckling rather than bursting.

11 So that does allow for some other
12 differences that, you know, I think it's Chapter 4,
13 five, Chapter 5, where they go into more detail about
14 this.

15 Then this -- as we did in the DCA we put
16 a value of 40 percent for the criteria recognizing
17 that a COL applicant might have a different -- might
18 have had new information or new rationale and might
19 have a different number, so that's what the use of the
20 bracketed information is in the tech specs and in the
21 bases also. That falls under COL item 60.1-4.

22 I believe that's the last information
23 slide and this is a conclusion listing the regulations
24 that govern the tech specs that we have determined
25 that we are in compliance with those.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: This is Bob Martin. Now
2 did you have RAIs --

3 MR. HARBUCK: We have no RAIs as far as
4 the process.

5 MEMBER MARTIN: Yeah.

6 MR. HARBUCK: I think we've managed to
7 resolve everything in the context of audit follow-up.

8 MEMBER MARTIN: Okay, all right. A pretty
9 straightforward review?

10 MR. HARBUCK: Yes, it was. A lot of our
11 issues were related to problems in other chapters, but
12 we always hear about it last. That concludes --

13 MEMBER HALNON: We have a NuScale person
14 with their hand up. Did you have a clarification,
15 Tyler?

16 MR. BECK: Hi. This is Tyler Beck with
17 NuScale. I just wanted to clarify about the ECCS trip
18 valve and the solenoids. So for the ECCS valves to be
19 operable they need to be closed and capable of opening
20 and that is the operability requirement straight from
21 the tech spec bases.

22 So, you know, technically I guess you
23 could say that one trip valve was not energized but
24 one was and in that case the ECCS valve would still be
25 operable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: Okay. Thank you. Yeah,
2 in the meantime I was looking through the tech spec
3 document and that's consistent with the document that
4 operable is not really defined in that level of
5 detail, and so that does make sense.

6 MEMBER HALNON: Thank you, Tyler. Walt,
7 we are in your time.

8 MR. BOWMAN: I have one more thing to say.

9 MEMBER KIRCHNER: Dennis has his hand up.
10 Dennis, go ahead.

11 MEMBER HALNON: I don't think that's
12 Dennis. It's another one of the NuScale folks.

13 DR. BLEY: No, it's not me.

14 MEMBER HALNON: Doug from NuScale, do you
15 want --

16 MR. BOWMAN: This is Doug Bowman.

17 MEMBER HALNON: Go ahead, Doug.

18 MR. BOWMAN: Can you hear me?

19 MEMBER HALNON: Yes. Do you have a
20 clarification?

21 MR. BOWMAN: Yes. This is Doug Bowman.
22 I am the plant manager for Service, thank you, for
23 Services Operation, wow -- Services Manager for Plant
24 Operations at NuScale.

25 We did want to make one clarification for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the record. Monitoring during a control room
2 evacuation event occurs at the alternate operator work
3 stations and those are located at either the module
4 maintenance center or in the rad waste control room.
5 Thank you.

6 MEMBER HALNON: Thank you, Doug. Okay,
7 Walt, now it's to you.

8 MEMBER KIRCHNER: Matt, you are our lead
9 on this, have you any further questions of the Staff?

10 MEMBER SUNSERI: Thank you, Walt. I don't
11 have any. I think the Committee has asked all the
12 appropriate questions. Thanks.

13 MEMBER KIRCHNER: Other members?

14 (No response.)

15 MEMBER KIRCHNER: Well, then at this point
16 we have come to a logical break point in our schedule,
17 and so let's take a break until 10:15. That will
18 allow those of us on Mountain and Pacific Time to get
19 some coffee and refuel. And we'll reconvene at 10:15
20 and we'll take up the LOCA TR. Thank you.

21 (Whereupon, the above-entitled matter went
22 off the record at 9:59 a.m. and resumed at 10:14 a.m.)

23 CHAIR KIRCHNER: Okay. The meeting will
24 come back to order, and we are going to turn to the
25 topic of the Loss of Coolant Accident Topical Report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and turn to NuScale.

2 Sarah, are you ready?

3 MS. TURMERO: Yes. Good morning.

4 CHAIR KIRCHNER: Good morning. Go ahead.

5 MS. TURMERO: All right. Thank you. My
6 name is Sarah Turmero. I'm a licensing engineer for
7 NuScale covering topics on Chapter 4, 9, 15, and the
8 related topical reports. I've been with NuScale for
9 about two-and-a-half years and have a background in
10 PWR reactor engineering.

11 And with me, I have Meghan McCloskey and
12 Ben Bristol from the System Thermal Hydraulics Group
13 to assist with any questions if needed.

14 We'll be covering a summary of the
15 significant changes since the approval of the Revision
16 2 LOCA Topical Report. These changes include those
17 related to the scope, relevant design changes from
18 NPM-160 to NPM-120, and changes to the phenomena
19 identification and ranking table evaluation model
20 structure assessment basis updates and adequacy
21 assessment updates.

22 So the LOCA analysis method for a pipe
23 break inside containment and the associated event
24 classification figure of merits and key regulations
25 were maintained from the approved topical report. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 scope that was modified from the approved topical
2 report includes the incorporation of the analysis
3 method for the inadvertent opening of a reactor valve
4 scenario. And with that the event classification
5 figure of merit and associated key regulation was also
6 incorporated into the scope. Some key updates
7 associated with the IORV analysis is the
8 implementation of the new NSPN1 critical heat flux
9 correlation and modeling cross-flow between the hot
10 and average channel, and of course the scope that is
11 associated with the valve opening and inadvertent ECCS
12 actuation.

13 For NuScale from the approved topical
14 report the containment vessel pressure and temperature
15 response analysis methodology was incorporated into
16 this topical report. It was previously a separate
17 technical report and the associated figures of merit
18 and key regulations were also included as it relates
19 to the containment response methodology.
20 Additionally, the response to the LOCA pipe break,
21 secondary line breaks, and valve opening events --
22 those are added scope specifically related to
23 crediting DHRS.

24 Scope that is outside of the LOCA Topical
25 Report related to long-term cooling and subcriticality

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are covered in the Extended Passive Cooling and
2 Reactivity Control Topical Report.

3 And the figure on the left shows how we've
4 defined phases of the event progression for the LOCA
5 and IORV events with Phase 0 being where NSPN1 is
6 implemented, and it's the first 10 seconds of the
7 transient. And then it occurs in conjunction with
8 Phase 1.

9 Since the DCA submittal, NuScale made
10 incremental improvements to the design and analysis
11 methods, resulting in margin improvement from overly
12 conservative methods or assumptions while maintaining
13 the same level of safety. So we have the power uprate
14 with no significant changes to the module, system,
15 structures, and components. The operating conditions
16 listed are nominal conditions and changes are a result
17 of the power uprate. And then for the containment
18 vessel the design pressure and temperature increased
19 and the upper material was changed.

20 Next slide?

21 MEMBER MARTIN: Just real quick, for the
22 open session we're oftentimes quiet because we get to
23 jump on you during closed, but given that we just
24 talked about Chapter 16, the tech specs, could you
25 briefly give an overview how you integrated the tech

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 spec into safety analysis? I know in the report
2 itself obviously you have. You may kind of highlight
3 maybe the major kind of the usual suspects as far as
4 initial conditions. I'm not sure there was a lot of
5 mention of how it relates back to tech specs, but of
6 course I know that they do. But I wanted to give you
7 the opportunity to just kind of talk about how you
8 incorporated the uncertainties which ultimately get
9 integrated into tech specs and into your initial
10 conditions, and that gets vetted to your safety
11 analysis.

12 MS. TURMERO: I was going to ask a
13 clarifying. Is there a specific tech spec or in
14 general?

15 MEMBER MARTIN: Well, maybe in closed
16 session.

17 MS. TURMERO: Okay.

18 MEMBER MARTIN: But just again this is a
19 public meeting. We just had a discussion on tech
20 specs and I thought it might be appropriate just to
21 segue from one to the other with this point, otherwise
22 -- I didn't want to save all my questions for closed
23 session.

24 MS. TURMERO: I think I'll start and then
25 we'll ask Karl to jump in from the tech spec side of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 things.

2 But from the safety analysis perspective,
3 our initial conditions and the ranges of initial
4 conditions and the SSCs that we credit in the safety
5 analysis are largely consistent between the DCA and
6 the SDA, and we focused -- and the design changes have
7 changed operating conditions for design limits to
8 accommodate the increased power, but that structure is
9 largely the same. And then the one -- the new piece
10 of the system is related to the supplemental boron in
11 the ECCS that was incorporated into the tech specs.

12 Ben or Karl, do you want to add to that?

13 MR. BRISTOL: Sure, this is Ben Bristol.
14 So I think generally the flow goes the other direction
15 in our view, so safety analysis works pretty closely
16 with the design team on understanding the constraints
17 around the actual module itself as well as the system
18 team with the constraints around power production
19 targets things of that nature. And then we integrate
20 that with the I&C team, right, that helps set up and
21 establish what types of measurements we have, what
22 protections then we can derive from that. And all of
23 that package then goes into what ends up in tech
24 specs. Because it's a PWR, it largely looks a lot
25 like PWR tech specs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But we work closely with the tech spec
2 group on defining where those operational boundaries
3 are that accommodates the safety margins that we
4 demonstrate along with the consideration of the
5 required operational margins necessary to support the
6 plant systems and power production requirements.

7 MEMBER MARTIN: And there are a couple
8 other facets. Tech specs, some people might say, oh,
9 well, LOCA drives tech specs. That's not completely
10 true. LOCA is a limiting for all things, right? So
11 you get a mix of LOCA and non-LOCA informing tech
12 specs. When it comes to initializing for safety
13 analysis, you also -- contemporary approach is
14 following PIRT. You'll talk about that of course.
15 And not everything would justify biasing with all the
16 uncertainties and best estimates.

17 So part of the answer I guess I was kind
18 of probing was something to say that, well, you know,
19 we look at the PIRT and we kind of look at what's
20 important with regard to the influences coming in from
21 the initial conditions and we select -- you don't have
22 to bias everything because then it kind gets to become
23 a administrative nightmare if you try to be too cute
24 about it. But I was looking for a if-we-do-
25 everything-kind of answer, but at least an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 acknowledgement that there are priorities when it
2 comes to initializing the problem and it ties back to
3 obviously the physics of what to -- the problem that
4 you're solving and their influences throughout the
5 event. But that's fine.

6 MR. BRISTOL: Yes, and to build on that,
7 Sarah mentions the three different avenues of analysis
8 that's covered by the LOCA TR being the pipe break
9 scenarios and their figures of merit, which are
10 different than the containment analysis and its
11 figures of merit or the IORV in the short-term
12 transient core response figures of merit. And the
13 bias is -- the conservative bias directions are not
14 consistent between those three different (audio
15 interference).

16 MEMBER MARTIN: Of course. You have to
17 reconcile that sometimes, yes. Thanks.

18 MS. TURMERO: Next slide? All right. So
19 there were ECCS actuation signal modifications. So
20 with decreased RCS inventory, ECCS actuates on riser
21 level early in the transient progressions. The Tcold
22 interlock prevents ECCS actuation for extended DHRS
23 cooldown events. And the RCS level indication of
24 decreasing RCS inventory can generate ECCS signal
25 before significant containment level increase.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 To highlight some of the ECCS valve design
2 changes, the inadvertent actuation block was removed
3 from the vent valves and flow venturis were added to
4 the reactor vent and recirculation valves and the
5 third reactor vent valve was removed.

6 For long-term cooling, which is covered
7 with the scope of the Extended Passive Cooling Topical
8 Report, one of the relevant design changes is the
9 lower pool level. And even with the lower pool level,
10 the containment surface area below the pool level
11 provides ample core cooling and maintains ECCS
12 cooling.

13 DR. SCHULTZ: Sarah, this is Steve
14 Schultz. Could you just provide a general overview?
15 A lot of changes that you've described here, they just
16 came about as good ideas or did they come about as a
17 result of analysis evaluations that pertain to the
18 uprate?

19 MS. TURMERO: I can't speak to the
20 specific changes, but the improvements in the design
21 and analysis methods were done to gain margin
22 improvement, improve our analysis methods so that we
23 could spread margin across the design, operation, and
24 analysis.

25 But if you would like to -- Meghan?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 DR. SCHULTZ: Could you speak also to the
2 design changes themselves?

3 MEMBER MARTIN: I had a very similar
4 question, Steve.

5 PRA. Some changes are going to be
6 strictly to accommodate the power uprate and other
7 changes, given that of course you had a mature PRA at
8 DCA, that you might be able to go here I have an
9 opportunity to take advantage of this new insight.
10 And that could be another set of changes of a
11 different sort. So I think that was the perspective
12 that I was coming from was a very similar idea that
13 Steve had.

14 MR. BRISTOL: This is Ben Bristol again.
15 So we have a list. Maybe I'll just start with the
16 top. The removal of the IAB from the vent valves.
17 This was a key safety improvement that we found. Now
18 there are trade-offs. Depressurizing the vessel from
19 high pressure is something that we add -- that we
20 weigh very heavily. However, what we found -- Bob
21 mentioned the PRA insights -- the ability to actuate
22 ECCS on demand was a feature that we had precluded to
23 some degree with the IAB in the DCA design.

24 So it was a big improvement for accident
25 scenarios to have some assuredness on the timing of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ECCS actuation. There were event sequences where we
2 had a broad range of uncertainty based on when the IAB
3 would release due to its pressure-based lockout-
4 blockout-type physics.

5 Generally for safety, right, we want lots
6 of water over the core, so we recognize that keeping
7 the IABs on the recirc valves was a good feature.
8 However, also part of safety is being able to
9 depressurize the reactor on demand. So removal of the
10 IABs from the vent valve allows us to depressurize the
11 reactor on demand, which allows us to reduce the
12 uncertainty of the timing of ECCS for a broad range of
13 events. And it really improves the response for
14 certain event sequences that we found to be very
15 beneficial. So that's just one. I could keep going.

16 Maybe another one of interest is the pool
17 level change that gets a lot of kind of consideration,
18 right? Seems like higher pool level would be better
19 for safety. As it turns out, the containment surface
20 area is ample. And we had plenty of heat removal
21 capability in the containment with margin to reduce
22 the pool level.

23 What we recognized in the design is that
24 -- you'll notice on the module here, we've got these
25 -- the big covers are access ports. And so one of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 challenges we had with the other design was the
2 ability to get in and service the equipment on top of
3 the reactor head. So dropping the pool level allowed
4 us to add those access ports that really improved the
5 maintainability of the design and some of the required
6 sequences.

7 And back to a different consideration of
8 safety, right, ALARA considerations where operators
9 are getting dose, getting them in and out of the
10 vessel effectively, efficiently was something that we
11 recognized is also a consideration of safety. And so
12 that was one of the trade-offs there, where we took
13 some of the margin that existed in the design from a
14 safety perspective and added it to a different element
15 of consideration of the design.

16 MEMBER HALNON: So, Ben, this is Greg.
17 How did you deal with the uncertainty at the tail end
18 of an accident when you're needing that extra volume
19 and (audio interference)?

20 MR. BRISTOL: Yes, that's a good question
21 and gets actually to one of the other bullets there is
22 the venting capacity. Very late in the design, we
23 depressurized the whole vessel down to sub-atmospheric
24 conditions. The containment effectively is a big
25 condenser, and so it can really draw the pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 down. The physics of what happens there is it
2 actually adds stress to the venting capacity of the
3 vent valves. So the long-term core level response is
4 directly related to the flow or the pressure drop
5 across the vent valves.

6 So having a reduced pool level actually
7 allowed us some more margin in the sizing of the
8 venting needs, and that's what allowed the removal of
9 one of those valves, which has knock-on effects of
10 improving maintenance in space on top of the reactor
11 vessel with two valves instead of three and simplifies
12 the design, the number of components. It also reduces
13 the effect of the depressurization transient we talked
14 about if we were to have an inadvertent ECCS
15 actuation.

16 MEMBER MARTIN: Just a clarification. As
17 a matter of fact, you brought up that access ports
18 facilitate inspections and maybe maintenance on the
19 top. Now they have the RRBs below. Is that also
20 accessible for inspection at least and maybe some
21 maintenance if there was any issue down there?

22 MR. BRISTOL: Yes, so as part of refueling
23 we have a space where the upper module inclusive of
24 the recirc valves goes over to a dry dock essentially.
25 And I think most of those maintenance activities are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 performed there.

2 MEMBER MARTIN: Okay.

3 MR. BRISTOL: But that's about as deep as
4 I can go on that topic.

5 MEMBER MARTIN: Okay. Yes, that's why --
6 you brought it up, so I -- you opened the door.

7 MR. BRISTOL: Sure. Most of the
8 components are located on the reactor head, which is
9 sort of where we identified that optimization.

10 DR. SCHULTZ: Thank you, Ben and Meghan.
11 That additional information is very helpful. Thank
12 you.

13 MS. TURMERO: Next slide, please? The
14 NuScale PIRT was reviewed for the NPM focusing on
15 topics like the break spectrum comparison, some
16 scaling analyses. The PIRT panel convened for a
17 focused evaluation on the phenomena associated with
18 valve opening events during initial rapid
19 depressurization. And regarding the impact of design
20 changes to LOCA, NuScale evaluated changes to the PIRT
21 geometric parameters and system state parameters, such
22 as pressures and temperatures, and found that these
23 changes did not introduce new phenomena or
24 significantly impact phenomena ranges.

25 DR. SCHULTZ: Sarah, this is Steve

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Schultz. Was there overlap between the first PIRT
2 panel and this one, or was it the same panel that you
3 invited through the process?

4 MS. McCLOSKEY: There were a couple of
5 different PIRT panels as the design evolved and its
6 LOCA methodology evolved. I believe that the first
7 PIRT panel was actually in 2010. And then it was
8 updated in 2013 and updated in 2015. And so some of
9 the folks who were involved in the 2015 work were also
10 involved in the IORV-focused PIRT as well as the
11 review of the LOCA PIRT. So there was a little bit of
12 overlap. It wasn't a total reconvene of all of the
13 members. The updates were -- the PIRT panel members
14 were all internal to NuScale at this point in the
15 update space.

16 DR. SCHULTZ: So in this case, they
17 reviewed your -- NuScale's conclusions first that you
18 listed here, and then they looked specifically at the
19 topics that you provided?

20 MS. McCLOSKEY: I'd say we went the other
21 way around in terms of looking at the design changes
22 and the event progressions and the body of work that
23 NuScale had developed in terms of the NPM-160 work
24 that was done to support the DCA submittal and review.
25 And then we could build on that and compare it to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 -- what the break spectrums looked like with the
2 updated design and all the design changes incorporated
3 and evaluate whether there were significant changes
4 that warranted an update in the PIRT space.

5 DR. SCHULTZ: And in the last bullet, the
6 methodology changes identified, is that meaning that
7 the PIRT panel identified some changes that you then
8 implemented and evaluated, or is that something that
9 they evaluated?

10 MR. BRISTOL: So just to clarify, the IORV
11 phenomena were reviewed by a NuScale internal --
12 internally staffed PIRT panel.

13 DR. SCHULTZ: Okay.

14 MR. BRISTOL: The LOCA PIRT was reviewed
15 by our team essentially looking back through what the
16 PIRT panel had originally identified, the basis of
17 those rankings compared with the updated analysis
18 results to confirm that they were consistent. And the
19 limited scope methodology changes -- we'll get into
20 more detail on that in the closed session.

21 DR. SCHULTZ: Fine.

22 MR. BRISTOL: I don't think they were
23 primarily driven from phenomena rankings. Largely
24 they were driven by either needs of the power uprate
25 and assessment basis for areas where the margins had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 required pencil sharpening or margin improvement.

2 DR. SCHULTZ: That helps. Thank you.

3 MS. TURMERO: Next slide, please? For the
4 DCA, NRELAP5 Version 1.4 was approved, and the current
5 evaluation model uses Version 1.7. The NIST-2 test
6 facility was upgraded -- the NIST-1 test was upgraded
7 to NIST-2, which allowed us to expand the NRELAP5
8 assessment bias by using the NIST-2 LOCA and IORV test
9 series. Additional benchmark calculations or
10 sensitivity cases were performed as needed to support
11 these evaluation model changes.

12 MEMBER MARTIN: Question. Bob again. I
13 saw on their topical that the RELAP5 that you received
14 from Idaho is Version 4.13, one I'm familiar with.
15 It's also 13 years old, and there's been many updates
16 since that time. And I've worked with that code. I
17 know some of the limitations and that they were
18 resolved in some of the later condensations. Always
19 a challenge, particularly under low pressure. Of
20 course, you own NRELAP5. I mean, so as part of these
21 updates are you working with Idaho or are you --
22 you're taking their changes and incorporated it. So
23 it's really not 4.13 anymore. It actually embodies
24 some of the newer versions, and you're kind of keeping
25 up with what's going on with the development at Idaho.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I see you nodding, but you can go ahead
2 and say it for the record.

3 MS. McCLOSKEY: Yes, so I'll say for the
4 record we -- I know that we do continue to get the bug
5 reports and code fixes that Idaho -- INL publishes to
6 the users group and incorporate that as part of our
7 normal (audio interference).

8 MEMBER MARTIN: All right. Some would
9 certainly be more important than the others if your
10 code was crashing. I mean, it's a reality of working
11 with system codes. I think it would be challenging.
12 And low pressure has always just been a huge
13 frustration. They're a lot better than they were when
14 we all started.

15 MS. TURMERO: Next slide, please? For the
16 evaluation model adequacy assessment, the bottom-up
17 and top-down evaluations that were performed for the
18 NPM-20 builds on the previously approved LOCA adequacy
19 assessment and the non-LOCA evaluation model
20 development for the steam generator and DHRS heat
21 transfer phenomena.

22 The top-down scaling analyses demonstrate
23 the important PI group similarity between the NPM-160
24 and NPM-120. There were no significant changes to the
25 field equations or numerical solutions and NRELAP5,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 with the overall conclusion being that NRELAP5 and the
2 updated evaluation model are applicable and adequate
3 for our defined scope.

4 Next slide? To conclude, the updated LOCA
5 Topical Report describes the evaluation model using
6 NRELAP5 to analyze the NPM-20 LOCA and valve opening
7 events for Phase 0 and Phase 1A/B and the secondary
8 pipe break for the containment pressure and
9 temperature response.

10 We've covered a high-level summary of
11 relevant design changes that drive changes to NRELAP5,
12 including an expanded validation basis using the NIST-
13 2 tests, and overall the LOCA Topical Report continues
14 to provide a robust methodology to analyze the NPM
15 response to LOCA valve opening events and the
16 containment pressure and temperature response
17 analysis.

18 With that, are there any additional
19 questions?

20 MEMBER HALNON: Walt, I don't see any
21 questions.

22 CHAIR KIRCHNER: Okay. Greg, then I think
23 at this point if there are no questions from the
24 members, we would turn to the staff for their open
25 presentation on the TR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. SNODDERLY: Walt, we're going to --
2 Tom Griffith is going to give us the HITI open slides,
3 and then we're going to go to the staff since
4 NuScale's all set up right now.

5 CHAIR KIRCHNER: Okay. Yes, that's more
6 efficient. Okay. Thank you, Mike.

7 MEMBER HALNON: Go ahead, Tom.

8 MR. GRIFFITH: Thank you. Thomas
9 Griffith, Licensing Manager of NuScale Power.

10 Just a little bit of background about
11 myself. Roughly 15 years' experience in the nuclear
12 industry. I held former positions as a senior reactor
13 operator, I&C manager, worked in safety analysis,
14 reactor engineering, and now work for -- in licensing
15 at NuScale. In charge of the US460 standard design
16 approval application.

17 What I intend to present here in the open
18 session is some high-level updates on the high-impact
19 tactical issues. There is a set of slides for the
20 closed session, where we can discuss some of the
21 aspects than what I'm going to present right now in
22 more detail.

23 Next slide, please? So if you recall, in
24 August when we discussed last the high-impact
25 technical issues. We have not identified any new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 high-impact technical issues since that time. And at
2 this point there are effectively two high-impact
3 technical issues: No. 2 and 10 related to LOCA break
4 spectrum that we continue to work through defining a
5 clear path forward.

6 I did mark on this slide that the high-
7 impact technical issue related to the IFR design
8 changes and the ASME qualification, the helical coil
9 steam generator, considered resolved by NuScale and
10 NRC management, that decision does officially take
11 place during our quarterly meetings which is next
12 week, but my understanding in discussions with my
13 counterparts at the NRC is that both sides do
14 recommend closure of the item, and enhanced with the
15 timing here in the presentation I wanted to at least
16 highlight that.

17 The high-impact technical issues related
18 to DWO we would consider resolved and we look forward
19 to presenting the material related to DWO here in some
20 of the upcoming ACRS meetings.

21 Next slide, please? So I do want to take
22 an opportunity here to provide an overview of the
23 approach to DWO. The purpose of this is kind of to
24 start some conversation. And we do have closed slide
25 presentations that accompany this presentation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 material, but for the purpose of transparency in the
2 open session I want to walk through kind of what --
3 how NuScale views the resolution of DWO.

4 And so effectively what I'm showing here
5 is that NuScale's approach to DWO -- and we're calling
6 it our safety case -- by establishing three separate
7 pillars. We consider those pillars to be analysis,
8 real-time monitoring, and physical inspection. And
9 our approach is not limited to one specific area. So
10 for example, in analysis we've defined a DWO
11 transient. We have analyzed the steam generator
12 integrity with that transient, and we've defined a
13 time under which the steam generator can handle the
14 transient that we've analyzed.

15 We have also defined real-time monitoring,
16 which is -- I think I would characterize it as -- it
17 was a lot of feedback that we've gotten from both the
18 staff, our internal NuScale individuals, and in
19 discussion that we had in August with the ACRS. We
20 took a hard look at what we were providing to
21 operators, and we've now defined a pillar that we're
22 calling real-time monitoring. And that's effectively
23 a way for the operating team to infer where the steam
24 generator is operating with respect to DWO.

25 And then the last piece is physical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 inspections. And so to accompany the analysis of the
2 real-time monitoring that's provided we've also
3 defined a set of inspections in intervals to provide
4 another layer of confidence that the steam generator,
5 being that it's a reactor coolant pressure boundary --
6 its integrity is maintained.

7 Next slide, please? So as I stated
8 before, we'll walk through some of the pillars a
9 little bit here. I do have more detailed slides in
10 the closed session, but effectively under analysis,
11 like I said, we've defined a DWO transient. We've
12 done the evaluations with the transient to demonstrate
13 steam generator structural integrity. We've defined
14 real-time monitoring using a comparison between our
15 RCS hot temperature and main steam temperatures, which
16 are safety-related indications. And then we've also
17 defined a limit, and that limit is required by tech
18 specs for how long a particular steam generator could
19 operate in a region where there's the potential for
20 DWO.

21 Next slide?

22 MEMBER MARTIN: Bob Martin. A
23 clarification. My understanding is that with the DWO,
24 you were going to more or less design it out of
25 normal/abnormal operation or design-basis conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And of course part of that would be you would have
2 protection systems to otherwise ensure that this
3 doesn't happen, as opposed to conditions, or allowing
4 for conditions that would result in DWO, right? To
5 clarify, basically take it out of a DBA space or DBE
6 space. Is that correct? Do I understand that
7 properly?

8 MR. GRIFFITH: So a current approach to
9 DWO, the way I would define it, is that we have
10 established what we -- a representative transient for
11 DWO and analyzed the steam generator for a particular
12 time frame that that transient could occur.

13 MEMBER MARTIN: Could occur with
14 assumptions that make it a DBE-kind of thing, or is it
15 a beyond-design-basis condition?

16 MR. GRIFFITH: I think some of the
17 specifics you -- we would want to get into are
18 probably more appropriate for closed, but I would say
19 that the loads induced from the phenomena are
20 relatively low and not impactful. In fact, when we
21 look at the expected operation -- and we have the
22 figure up right now that has been placed in the FSAR
23 5.1-16 -- we expect the majority of operation to occur
24 in Region II, and Region II is defined as the region
25 that precludes DWO.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 That does not mean -- and I don't want to
2 misrepresent -- Region I does not mean you have DWO.
3 Region I simply is that there is less margin to DWO.
4 And there are some slides in the closed session that
5 walk through exactly how those margins are defined.
6 But what we've done is in that Region II -- even if --
7 based upon the total amount of time that we would
8 expect an applicant to operate, there is sufficient
9 margin that roughly seven years or so of additional
10 margin that DWO could continue or could occur
11 continuously before hitting our acceptance criteria
12 for wear.

13 So what I'm trying to say is that 90-
14 percent-plus of the operation would be in this DWO is
15 precluded. We had to set an analysis limit somewhere
16 with acceptance criteria. The amount of margin in
17 there before we would -- we would say internally, hey,
18 we need to look at this further is such that there --
19 or there's on the order of multiple years or many
20 years. And it's kind of tricky because there's
21 different impacts from DWO like, you know, for
22 example, sliding wear is different than thermal
23 fatigue. So I think that we need -- we would need to
24 get into some of those finite details, but there is
25 substantial margin before DWO would cause any sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 concern with the steam generator integrity.

2 MEMBER MARTIN: I guess where I was going
3 with it, although your answer is what I expected,
4 we've gone through a lot of discussion on design
5 changes. Were there any design changes to support the
6 strategy and specifically related to I&C monitoring
7 that might result in some sort of protective action?

8 MR. GRIFFITH: I think I can get into that
9 in the closed session.

10 MEMBER MARTIN: Okay. I mean yes or no
11 might work, but --

12 MR. GRIFFITH: To some extent the answer
13 is yes.

14 MEMBER MARTIN: Good enough.

15 MR. GRIFFITH: Next slide, please? So
16 lastly, the other piece we'd talked through a little
17 bit is we've set a number of physical examinations
18 that include the steam generator and associated
19 components and specified frequencies that would inform
20 what future inspections may need to look at and
21 provide the assurance of steam generator integrity.

22 Next slide?

23 MEMBER HARRINGTON: One question real
24 quick. This is Craig Harrington. Are you envisioning
25 that inspection schedule as specific to the first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 module that operates or something that would be
2 appropriate long term?

3 MR. GRIFFITH: So we do have specifics on
4 the first module.

5 Erin, I don't know if you can step here on
6 the exact language for the first module?

7 But there are specifics for the first
8 module under operation. And the frequency is set to
9 complement what we've done for analysis.

10 MS. BLUMSACK: Yes, this is Erin Blumsack
11 from NuScale. For the first NPM that undergoes a
12 refueling outage, after the first 100 percent tube
13 examinations at the first refueling outage they're
14 required to inspect at least 20 percent of the steam
15 generator tubes at each outage with the tech spec
16 requirement that they have to get to 100 percent of
17 tube inspection by 72 EFPM after the first outage.
18 That is a COL item in Chapter 5. Tech specs have not
19 changed and that's only for the first NPM that
20 undergoes refueling.

21 MEMBER BALLINGER: This is Ron Ballinger.
22 I'm not sure -- I don't remember, so I'll ask the
23 question: Since it's externally pressurized tubes, a
24 lot of the inspections for various phenomena that
25 occur in a commercial PWR -- it's not applicable. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there are others. For example, dimensions. Is there
2 inspection going to occur that looks at the ID? In
3 other words, just to find out if there's any kind of
4 pre-collapse or creep-down that's going on in the
5 tubes?

6 MS. BLUMSACK: Details of examinations
7 will be developed for a COL applicant as part of the
8 Steam Generator Program.

9 MEMBER BALLINGER: I guess -- okay.

10 MS. BLUMSACK: Does that address your
11 question?

12 MEMBER BALLINGER: Yes, I guess. We have
13 -- a lot of us have issues every time somebody says
14 that's up to the COL applicant, so --

15 MS. BLUMSACK: Understood. We expect to
16 be able to use examination techniques that the
17 industry uses, but that will be developed in more
18 detail during the Steam Generator Program.

19 MEMBER BALLINGER: You'll find out the
20 first time a bobbin coil gets stuck in one of the
21 tubes.

22 MS. BLUMSACK: That is true.

23 MR. GRIFFITH: And I believe that that was
24 the last slide that I had, so if there's any further
25 questions for the open session, any update?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Walt, I don't see anything
2 in the room.

3 CHAIR KIRCHNER: Other members, any
4 questions?

5 (No response.)

6 CHAIR KIRCHNER: Okay. Bear with me. I'm
7 on a small NRC computer screen. I have to move so I
8 can look at the agenda, so bear with me.

9 Okay. With that then, I believe we are
10 ready, Mike, to go to the staff's evaluation of the
11 LOCA TR in the open session.

12 MR. SNODDERLY: Yes, sir, that's --

13 CHAIR KIRCHNER: Is that correct?

14 MR. SNODDERLY: I just need a minute to
15 switch presenters.

16 MEMBER HALNON: I'll let you know when
17 we're ready, Walt.

18 CHAIR KIRCHNER: Okay. So when you're
19 ready, just go ahead. I can't see --

20 MR. SNODDERLY: I'll let you know. And
21 then also an opportunity for public comment after the
22 staff's presentation. And then --

23 CHAIR KIRCHNER: Yes.

24 MR. SNODDERLY: -- that will be end of the
25 open session.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Right. Correct. Okay.

2 MEMBER HALNON: Okay. Just give us a
3 minute.

4 (Pause.)

5 CHAIR KIRCHNER: Okay. Staff, whenever
6 you're ready.

7 MR. VIVANCO: Good morning, everyone. My
8 name is Ricky Vivanco, and I'm a project manager in
9 the NRR New Reactor Licensing Branch. I am the PM
10 assigned to the staff's review of NuScale's Loss of
11 Coolant Accident Evaluation Model Topical Report.

12 The technical reviewers a part of this
13 review are: Dr. Shanlai Lu, Dr. Sean Piela, Dr. Dong
14 Zheng, Mr. Carl Thurston, Mr. Ryan Nolan, Dr. Syed
15 Haider, Dr. Joshua Kaizer, Dr. Peter Lein from the
16 Office of Research, and Dr. Leonard Ward from Numark.
17 Again, I am the project manager assigned to this
18 topical report supported by (audio interference) for
19 the overall project.

20 A review of this topical report. The
21 Revision 3 of the LOCA Evaluation Topical Report was
22 submitted on January 5th, 2023, and the topical report
23 was accepted for review on July 31st, 2023.

24 The staff conducted an audit from March
25 2023 to August 31st, 2024. Fifty-seven audit issues

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 were generated resulting in supplemental information
2 submitted by NuScale. Of those items not resolved
3 during the audit, four RAIs were generated. I want to
4 be clear here, all audit items and RAIs were
5 resolved/closed that were specifically related to the
6 LOCA Topical Report. I do want to point out though
7 there are confirmatory items that are awaiting
8 confirmation and upcoming revisions or related to open
9 items in other areas of the review -- in other topical
10 reports.

11 Due to the technical and proprietary
12 nature of the topical report, the details of the
13 staff's review are going to be covered in the closed
14 session, however we will go over the conclusions here.

15 Subject to the closure of those open and
16 confirmatory items I noted, and along with 11
17 limitations and conditions identified, the staff
18 concludes that the methodology is acceptable for
19 meeting the requirements of 10 CFR 50.46 and the
20 associated portions of Appendix K evaluated in the
21 topical report.

22 For evaluation of the ECCS performance in
23 the NuScale NPM-20 for design-basis LOCAs, the
24 proposed LOCA evaluation model is conservative to
25 determine CHF and collapsed liquid level above the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactor core. Further, the staff finds that the
2 containment response analysis methodology is
3 conservative and acceptable and that the NRELAP5
4 computer code and the NPM-20 model are acceptable to
5 evaluate the MCHFR and IORV in LOCA events.

6 And that's the end of the staff's
7 presentation. I'll defer any questions to Dr. Shanlai
8 Lu.

9 DR. LU: As our project manager mentioned,
10 there are a lot of details we can present in the
11 proprietary session, but if there are any questions
12 for the staff at this point in open session, I'm here
13 to answer.

14 MEMBER HALNON: I don't see any in the
15 room, Walt.

16 CHAIR KIRCHNER: Members online, any
17 questions?

18 Hearing none, I think we are at a juncture
19 where we should ask for any public comment.

20 So members of the public either in the
21 room or online -- just those of you online, un-mute
22 yourself and state your name and affiliation as
23 appropriate and ask your question. Or make your
24 comment. Excuse me. Not question.

25 MEMBER HALNON: We have no one in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 room, Walt.

2 CHAIR KIRCHNER: Okay. Online, any
3 comments from the public?

4 (No response.)

5 CHAIR KIRCHNER: Okay. I think, Greg, we
6 don't have any public input today.

7 With that, then, I think we're at the
8 juncture where we can close this open session and move
9 to an actual closed session. And that will take up
10 the LOCA Evaluation Model first.

11 So with that, for those of you that
12 attended on the open session, thank you.

13 Again for the record, I want to thank
14 NuScale for joining us so early this morning. And
15 this open session is closed. Thank you.

16 MEMBER HALNON: Okay. We'll be logging
17 off this one and be logging on -- there should be a
18 new link for those that are invited to the closed
19 session. This session will be closed.

20 (Whereupon, the above-entitled matter went
21 off the record at 11:04 a.m.)

22

23

24

25

January 09, 2025

Docket No. 052-050

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Material Entitled "ACRS Subcommittee Meeting (Open Session) Chapter 16, Part 4, LOCA LTR, and HITI Status," PM-177830, Revision 0

The purpose of this submittal is to provide presentation materials for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Subcommittee Meeting on January 15, 2025. The materials support NuScale's presentation of the subject chapter, topical report and status of the US460 Standard Design Approval Application.

The enclosure to this letter is the nonproprietary presentation entitled "ACRS Subcommittee Meeting (Open Session) Chapters 16, Part 4, LOCA LTR, and HITI Status," PM-177830, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Jim Osborn at 541-360-0693 or at josborn@nuscalepower.com.

Sincerely,



Thomas Griffith
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Mahmoud Jardaneh, Chief New Reactor Licensing Branch, NRC
Getachew Tesfaye, Senior Project Engineer, NRC
Michael Snodderly, Senior Staff Engineer, Advisory Committee on Reactor Safeguards, NRC

Enclosure 1: ACRS Subcommittee Meeting (Open Session) Chapters 16, Part 4, LOCA LTR, and HITI Status, PM-177830, Revision 0



Enclosure 1:

ACRS Subcommittee Meeting (Open Session) Chapters 16, Part 4, LOCA LTR, and HITI Status, PM-177830, Revision 0



ACRS Subcommittee Meeting

(Open Session)

January 15, 2025

Chapter 16, Part 4, LOCA LTR and HITI Status



ACRS Subcommittee Meeting (Open Session)

January 15, 2025

Chapter 16 Technical Specifications

Presenter
Gene Eckholt

Acknowledgement and Disclaimer

This material is based upon work supported by the Department of Energy under Award Number DE-NE0008928.

This presentation was prepared as an account of work sponsored by an agency of the United States (U.S.) Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

NuScale SDAA Part 4, US460 Generic Technical Specifications (GTS)

- Subpart E of 10 CFR 52, Standard Design Approvals, does not require submittal of Technical Specifications for consideration.
- In the Statements of Consideration for the 2007 rule change to 10 CFR Part 52, the commission expressed its expectation that the contents of applications for design approvals should contain essentially the same technical information that is required of design certification applications.
- NuScale included Part 4, Generic Technical Specifications, in the SDAA.

Noteworthy US460 Design Changes Affecting GTS

- Rated thermal power increase from 160 MWt to 250 MWt
- Modification of ECCS design from three to two reactor vent valves
- Addition of ECCS supplemental boron system
- Addition of passive autocatalytic recombiner in containment

US460 GTS Development

- Started with NuScale US600 Certified Design Technical Specifications as model
- Addressed US460 design changes
- Applied 10 CFR 50.36 criteria to plant design, operations, and safety analyses
- Used industry STS Writer's Guide format and guidance
- Incorporated recent industry STS changes as appropriate
- Technical Report TR-101310 Rev 0 describes the differences between US600 and US460 GTS at the time of SDAA submittal

Noteworthy GTS Changes Described in TR-101310 Revision 0

- The MODE definition revised to better align with the plant response behavior
- The reactor core critical heat flux correlations and limits, and the RCS pressure safety limits revised to reflect the increased reactor power and changes to the plant design
- New Surveillance Requirement to ensure isolation of Module Heatup System between modules
- Module Protection System requirements modified to align with design changes
- Remote Shutdown Station LCO removed
- RCS Operational Leakage LCO and definition modified to align with industry standards to the extent appropriate for the NuScale Design

Noteworthy GTS Changes Described in TR-101310 Revision 0 (continued)

- LTOP and ECCS LCOs modified to reflect reduced number of reactor vent valves
- UHS LCO modified to reflect design changes
- New LCO to ensure OPERABILITY of ECCS Supplemental Boron System
- New LCO to ensure containment closure during module movement between operating location and containment closure tool
- LCO 3.7.3 removed due to change from leak-before-break to break exclusion
- Chapter 5 Administrative Controls modified to reflect approved control room staffing plan

US460 GTS Review

- Audit Results
- 68 audit items resolved
- Most changes were editorial or clarifications
- Noteworthy changes included
 - Core reactivity balance surveillance frequency clarified
 - Module Heatup System flow paths added to Boron Dilution Control specification
 - ECCS Supplemental Boron specification revised to include requirements for the geometric form of boron pellets
- RAI Results
- No RAI questions on Chapter 16 or GTS
- GTS change resulting from RAI associated with another FSAR Chapter
 - Steam Generator Program revised to update the SG tube integrity discussion

Noteworthy GTS Change Not Associated with SDAA Review

- Added LCO to ensure OPERABILITY of passive autocatalytic recombiner (PAR)
 - NuScale determined the PAR mitigates design-basis events, making the component safety-related and appropriate for inclusion in the GTS

Acronyms

| | |
|------|--|
| CFR | Code of Federal Regulations |
| ECCS | Emergency Core Cooling System |
| FSAR | Final Safety Analysis Report |
| HVAC | Heating, Ventilation, and Air Conditioning |
| LCO | Limiting Condition for Operation |
| LTOP | Low Temperature Overpressure Protection |
| MWt | Megawatts Thermal |
| PAR | Passive Autocatalytic Recombiner |
| RAI | Request for Additional Information |
| RCS | Reactor Coolant System |
| SDAA | Standard Design Approval Application |
| STS | Standard Technical Specifications |
| TS | Technical Specifications |
| UHS | Ultimate Heat Sink |



ACRS Subcommittee Meeting

(Open Session Session)

January 15, 2025

Loss-of-Coolant Accident Topical Report

Presenter: Sarah Turmero

Agenda

- Summary of significant changes since TR-0516-49422-P Revision 2 approval
 - Analysis scope addressed by topical report
 - Design changes from 160 MWt NPM-160 design to 250 MWt NPM-20 design
 - Summarize effects on PIRT
 - EM structure and assessment basis updates
 - Adequacy assessment process and conclusions
- Conclusions


LOCA Topical Report: Analysis Purpose and Transient Class

- Scope maintained from DCA Topical Report:
 - Loss-of-coolant accident (LOCA) pipe break inside containment analysis method
 - Event classification: Postulated accident
 - Figures of merit: Phase 1a, 1b collapsed liquid level (CLL) over top of fuel, minimum critical heat flux ratio (MCHFR)
 - Key Regulations: 10 CFR 50.46, 10 CFR 50 Appendix K, GDC 35
- Scope modified from DCA Topical Report:
 - Inadvertent opening of a reactor valve (IORV) analysis method
 - Event classification: conservatively classified as Anticipated Operational Occurrence (AOO)
 - Realistically not expected to occur during a module lifetime
 - Figure of merit: MCHFR during 'Phase 0' initial blowdown
 - Key Regulations: GDC 10
- Scope added from DCA Topical Report:
 - Containment vessel (CNV) pressure/temperature response analysis method
 - Similar to method used in DCA technical report
 - Response to LOCA pipe break, secondary line breaks, IORV events, or inadvertent ECCS actuation
 - Figures of merit: Maximum CNV pressure, maximum CNV wall temperature, CNV pressure reduction over time
 - Key Regulations: GDC 16, PDC 38, GDC 50
- Scope addressed elsewhere:
 - Extended passive cooling and reactivity control (XPC) topical report addresses long-term core cooling and subcriticality

| < Event Initiation | < RTS | < ECCS Actuation | < Recirculation |
|--------------------|-------|--|-----------------|
| Phase 0 | 10 s | (*ends 10 seconds after rods are fully inserted) | |
| Phase 1a | | Phase 1b | LTC |


Power Uprate and Design Changes Summary NPM-160 to NPM-20

- Power uprate from 160 MWt to 250 MWt
- Module SSC design essentially maintained
- Operating conditions
 - Increased primary pressure from 1850 psia to 2000 psia
 - Primary and secondary side design pressures increased from 2100 psia to 2200 psia
 - Use T_{avg} control instead of T_{hot} control (RCS T_{avg} change from $\sim 545^{\circ}\text{F}$ to 540°F)
 - Decreased secondary side feedwater temperature at 100% power from 300°F to 250°F
 - Reduced minimum temperature for criticality from 420°F to 345°F
- Containment vessel
 - Design pressure increased from 1050 psia to 1200 psia
 - Design temperature increased from 550°F to 600°F
 - Upper containment material change from SA-508 to SA-336 F6NM



Power Uprate and Design Changes Summary NPM-160 to NPM-20, cont'd

- ECCS actuation signals modified
 - Low RCS level (top of riser), Tcold interlock
 - Low-low RCS level (mid-riser) always active (no interlocks)
 - Timers:
 - 8-hour timer on all reactor trips; operators can block the actuation if subcriticality at cold conditions is confirmed and combustible gas mixture in RPV is precluded
 - 24-hour timer after loss of AC power supply (unchanged from DCA)
- ECCS valve design changes
 - Removed IAB from vent valves to enhance depressurization capability in DBE and BDBE
 - Modified IAB threshold/release pressures on recirculation valves
 - Added second trip valve to each ECCS valve to prevent inadvertent opening on solenoid failure
 - Added flow venturi to RVVs and reactor recirculation valves (RRVs)
 - Removed third RVV
- Long-term passive cooling enhancements for collapsed liquid level and subcriticality FOM
 - Addressed by Extended Passive Cooling and Reactivity Control methodology
 - Design changes reduce but maintain ample CNV cooling capacity:
 - Lowered reactor pool level from ~68 ft to ~53 ft
 - Reduced conductivity in upper CNV due to material change
 - Mitigation of boron redistribution during DHRS and ECCS cooling with riser hole flow paths
 - Supplemental ECCS Boron (ESB) to maintain subcriticality during extended passive cooling



Phenomena Identification and Ranking

- NuScale reviewed the NPM-160 LOCA PIRT for applicability to the 250 MWt NPM-20 design based on:
 - Plant break spectrum comparisons
 - Scaling analyses
 - Other NPM-160 work subsequent to the PIRT development
- NuScale convened a PIRT panel for focused evaluation of IORV phenomena during rapid initial depressurization
- Overall conclusions:
 - Existing phenomena identification and rankings applicable for 250 MWt NPM-20 design
 - Clarified phenomena importance based on work for NPM-160 and NPM-20 designs performed after development of NPM-160 LOCA PIRT
- Limited scope of methodology changes identified, and supported by additional NRELAP5 validation and sensitivity analyses

EM Structure and Assessment Basis

- NRELAP5 v1.4 previously approved in DCA
- Current EM employs NRELAP5 v1.7
- Upgraded the NIST-1 integral effects test facility to NIST-2
- Expanded NRELAP5 assessment basis:
 - NIST-2 LOCA test series
 - NIST-2 IORV test series
- Additional benchmark calculations, sensitivity cases as needed to support EM changes

EM Adequacy Assessment

- Bottom-up and top-down evaluations performed
 - Builds on LOCA EM adequacy assessment performed for DCA
 - Builds on the non-LOCA EM development for SG/DHRS heat transfer phenomena
- Compared NPM-160 and NPM-20 geometry, operating conditions, range of conditions for LOCA spectrum
- Evaluated scope of NRELAP5 code changes since v1.4
- Top-down scaling analyses demonstrated important PI group similarity between NPM-160, NPM-20, NIST-2
- No significant changes to NRELAP5 field equations or numerical solution
- NIST-2 LOCA and IORV tests expand the NRELAP5 assessment basis for NPM integral response
- **Conclusion:** NRELAP and updated EM are applicable and adequate for the defined scope.

Conclusions

- Updated topical report describes evaluation model for use of NRELAP5 to analyze:
 - NPM-20 LOCA or valve opening events, to assess Phase 0 MCHFR, Phase 1a/1b MCHFR, collapsed liquid level,
 - NPM-20 LOCA, valve opening, and secondary pipe break containment pressure response
- Design changes from NPM-160 to NPM-20 evaluated for effect on LOCA or valve opening transient and important phenomena
- NRELAP5 code changes incorporated as necessary to support the NPM-20 EMs
- NRELAP5 validation basis expanded with NIST-2 tests
- Topical report provides robust methodology to analyze NPM response to LOCA and valve opening events, and for containment pressure/temperature response analysis.

Questions?

Acronyms

| | | | |
|------|-------------------------------------|-------|--|
| AC | Alternating Current | LOCA | Loss-of-Coolant Accident |
| AOO | Anticipated Operational Occurrence | MCHFR | Minimum Critical Heat Flux Ratio |
| BDBE | Beyond Design Basis Event | NIST | NuScale Integral |
| CLL | Collapsed Liquid Level | NPM | NuScale Power Module |
| CNV | Containment Vessel | PDC | Principal Design Criteria |
| DBE | Design Basis Event | PIRT | Phenomena Identification and Ranking Table |
| DCA | Design Certification Application | RAI | Request for Additional Information |
| DHRS | Decay Heat Removal System | SDAA | Standard Design Approval Application |
| ECCS | Emergency Core Cooling System | SDA | Standard Design Approval |
| EM | Evaluation Model | SSC | Systems, Structures, and Components |
| ESB | ECCS Supplemental Boron | RCS | Reactor Coolant System |
| FOM | Figure of Merit | RPV | Reactor Pressure Vessel |
| IAB | Inadvertent Actuation Block | RRV | Reactor Recirculation Valve |
| IORV | Inadvertent Opening of an RPV Valve | RVV | Reactor Vent Valve |
| GDC | General Design Criteria | XPC | Extended Passive Cooling |



ACRS Subcommittee Meeting

(Open Session)

January 15, 2025

Update – High Impact Technical Issues

Presenter: Thomas Griffith


High Impact Technical Issues (HITIs)

1. Design and classification of the augmented DC power system (EDAS)
2. Loss-of-Coolant (LOCA) break spectrum
3. Incorporated by reference (IBR)
4. Containment Vessel (CNV) material change
5. Lower reactor pressure vessel (RPV) material change
6. Secondary side controller design for density wave oscillation (DWO) events
7. DWO and steam generator inlet flow restrictor (IFR) design changes
8. ASME qualification of the helical coil steam generator for the onset of DWO-induced loads
9. Upper-to-lower RPV flange bolted joint shear loading that results from differential thermal expansion
10. LOCA break at CVCS/CIV connection

- Note: Green indicates issues that have been considered resolved by NuScale and NRC Management

Density Wave Oscillation Safety Case

- Analyses – DWO transient, which is used to assess SG structural integrity. SG structural integrity ensured for longer than NPM lifetime limit for time in DWO.
- Real-Time Monitoring – Defined operational space where DWO is precluded and where time in DWO is conservatively accounted for against the NPM lifetime limit.
- Physical Inspections – Examinations of SG tubes and IFRs ensure RCPB integrity is maintained. Degradation assessment will ensure that any damage to the tubes will inform future examination locations and frequencies.



DWO Safety Case (Continued)

- Analyses

- DWO transient defined in SDAA FSAR Section 3.9.1 and lifetime limit specified in Table 3.9-1
- SG structural integrity is evaluated beyond the DWO lifetime limit for the NPM 60-year design life.


- Real-Time Monitoring

- SG approach temperature
 - Comparison between RCS hot temperature and main steam temperature
- Time is counted in DWO against FSAR Table 3.9-1 “Summary of Design Transients” 60-year US460 design life limit of 2840 days in DWO.
 - Technical Specifications 5.5.3 cyclic limits

DWO Safety Case (Continued)

- Real-Time Monitoring
 - DWO is precluded during normal operations by maintaining an adequate SG approach temperature.
 - DWO is precluded in Region 2
 - Margin between normal operation and the Region 1/Region 2 boundary; Margin between the Region 1/Region 2 boundary and DWO onset.
 - Operation with DWO is avoidable for most of the NPM operating life.

SDAA FSAR Figure 5.4-16



DWO Safety Case (Continued)

- Physical Examinations

- SG tube examination requirements in Technical Specifications 5.5.4

- 100 percent SG tube examination at first refueling outage
 - 100 percent SG tube examination over 72 EFPM (~ 6 years) after first refueling outage:
 - Maximum time below approach temperature boundary (2840 days or >7 years) is greater than maximum time between SG tube examinations.
 - Additional requirement to inspect at least 20 percent of tubes per outage for the first NPM to undergo a refueling outage
 - Degradation assessment program will ensure that examination results factor into future examination frequency and location.
 - VT-3 examination of IFRs

Acronyms

| | | | |
|------|--|------|--------------------------------------|
| ASME | American Society of Mechanical Engineers | RCS | Reactor Coolant System |
| CIV | Containment Isolation Valve | RPV | Reactor Pressure Vessel |
| CNV | Containment Vessel | SDAA | Standard Design Approval Application |
| CVCS | Chemical and Volume Control System | SG | Steam Generator |
| DWO | Density Wave Oscillation | | |
| EDAS | Augmented DC Power System | | |
| EFPM | Effective Full Power Months | | |
| FSAR | Final Safety Analysis Report | | |
| HITI | High Impact Technical Issue | | |
| IBR | Incorporate by Reference | | |
| IFR | Inlet Flow Restrictor | | |
| LOCA | Loss-of-Coolant Accident | | |
| NPM | NuScale Power Module | | |
| RCPB | Reactor Coolant Pressure Boundary | | |

**Presentation to the ACRS Subcommittee
Staff Review of NuScale SDAA
Part 2, Chapter 16, “Technical Specifications,” and
Part 4 , “US460 Generic Technical Specifications,”
Volume 1, Specifications, and Volume 2, Bases
Revision 1**

**January 15th, 2025
(Open Session)**

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Overview

- NuScale submitted Part 2 (FSAR), Chapter 16, “Technical Specifications” (TS), and Part 4, “US460 Generic Technical Specifications” (GTS), Revision 0, of the NuScale SDAA on December 29 and December 31, 2022, respectively, and Revision 1 on October 31, 2023
- NRC regulatory audit of FSAR Chapter 16 and Part 4 was performed from March 2023 to August 2024, generating 68 audit issues
- All audit issues were resolved in the audit
- 52 audit issues resulted in NuScale submitting supplemental information to address questions raised during the audit
- No RAIs issued
- Staff completed review of FSAR Chapter 16 and Part 4 and issued an advanced safety evaluation to support today's ACRS Subcommittee meeting

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Contributors

- **Technical Reviewers**
 - Craig Harbuck, Lead Reviewer, NRR/DSS/STSB
 - Steve Smith, NRR/DSS/STSB
 - Clint Ashley, NRR/DSS/STSB
 - Josh Wilson, NRR/DSS/STSB
- **Project Managers**
 - Alina Schiller, PM, NRR/DNRL/NRLB
 - Getachew Tesfaye, Lead PM, NRR/DNRL/NRLB

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Part 2, FSAR Chapter 16, TS

- Section 16.1 Technical Specifications
- TR-101310-NP, Revision 0, “US460 Standard Design Approval Technical Specifications Development”

Part 4, GTS Volume 1, Specifications

- Chapter 1.0 Use and Application
- Chapter 2.0 Safety Limits (SLs)
- Chapter 3.0 Limiting Conditions for Operation (LCOs) and Surveillance Requirements (SRs)
- Chapter 4.0 Design Features
- Chapter 5.0 Administrative Controls

Part 4, GTS Volume 2, Bases

- Chapter B 2.0 SLs
- Chapter B 3.0 LCOs and SRs

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Significant Changes from DCA to SDA GTS Chapter 1

Definition of MODE 3 – Safe Shutdown

DCA

Module is shutdown ($k_{\text{eff}} < 0.99$)

All indicated reactor coolant temperatures < 420 °F (minimum temperature for criticality)

SDA

Module is shutdown ($k_{\text{eff}} < 0.99$)

All indicated reactor coolant temperatures < 345 °F (minimum temperature for criticality)

OR

PASSIVELY COOLED

- Any indicated reactor coolant temperature may be ≥ 345 °F

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Significant Changes from DCA to SDA GTS Chapter 1 (cont'd)

Definition of Reactor Coolant System (RCS)

pressure boundary LEAKAGE

- Industry Technical Specification Task Force (TSTF) traveler 554, Rev. 1, approved on December 18, 2020 (ML20324A083) and incorporated into Revision 5 of NUREG-1431, “Standard TS Westinghouse Plants,” changed the definition – as shown:

“LEAKAGE (except primary to secondary LEAKAGE) through a ~~nonisolable~~ fault in an RCS component body, pipe wall, or vessel wall. LEAKAGE past seals, packing, and gaskets is not pressure boundary LEAKAGE.”

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Significant Changes from DCA to SDA GTS Chapter 2 Reactor Core Safety Limits

DCA US600

Critical Heat Flux Ratio

| <u>Correlation</u> | <u>Safety Limit</u> |
|---------------------|---------------------|
| NSP2 | $\geq [1.17]$ |
| NSP4 | $\geq [1.21]$ |
| Extended Hench-Levy | $\geq [1.06]$ |
| ----- | |

SDAA US460

Critical Heat Flux Ratio

| <u>Correlation</u> | <u>Safety Limit</u> |
|--------------------|---------------------------------|
| ----- | |
| NSP4 | $\geq [1.21]$ |
| ----- | |
| NSPN-1 | $\geq [1.15]$ |

Peak fuel centerline temperature $\leq \{ 4901 - (1.37E-3 \times \text{Burnup, MWD/MTU}) \}$ °F.

Reactor Coolant System Pressure Safety Limit

Pressurizer Pressure ≤ 2285 psia

Pressurizer Pressure \leq **2420** psia

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Significant Changes from DCA to SDA GTS Chapter 3

LCO Subsection Omissions and Additions

DCA LCOs Omitted in SDAA

- **3.3.5 Remote Shutdown Station**
 - Indication-only monitors in I&C equipment rooms
 - No Type-A PAM variables
- **3.7.3 In-Containment Secondary Piping Leakage**
 - Leak-before-break (LBB) methods not used
 - High energy pipe break exclusion criteria met (consistent with BTP 3-4)

Additional LCOs in SDAA

- **3.5.4 Emergency Core Cooling System Supplemental Boron (ECCS ESB)**
 - 3.3.3 Function 1 ECCS – 8-hour post reactor trip actuation timer; SR 3.3.3.3
- **3.6.3 Containment Closure**
 - Mode 3 and Passively Cooled; Mode 4 before unseating of upper module assembly from lower containment vessel flange
 - Maintain reactor coolant inventory to ensure adequate core cooling
- **3.6.4 Passive Autocatalytic Recombiner**
 - Meets 10 CFR 50.44(d)

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Significant Changes from DCA to SDA GTS Chapter 3

Instrument Functions that Initiate ECCS

DCA Revision 5

22.a **High Containment Water Level**

23.a **Low RCS Pressure**

Three reactor vent valves (RVVs)

Two reactor recirculation valves (RRVs)

- Inadvertent Actuation Block (IAB) on each valve delays valve opening on ECCS actuation signal until RPV-CNV pressure difference below unblock setting

SDAA Revision 2 (draft)

23.a **Low RPV Riser Level** (*if above 500 °F*)

24.a **Low Low RPV Riser Level**

25.h **Low AC Voltage to EDAS Battery Chargers**

Two RVVs

Two RRVs

- No IAB on RVVs; EDAS DC power ensures ECCS hold function until ECCS actuation signal or reactor trip occurs
- RRV opening delayed by IAB

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Significant Changes from DCA to SDA GTS Chapter 3

Instrument Functions that Initiate DHRS

DCA Revision 5

7.b High Pressurizer Pressure

13.b High Narrow Range (NR) RCS T_{HOT}

16.b High Main Steam Pressure

25.b Low AC Voltage to ELVS Battery
Chargers

Low Pressurizer Level

- Steam Generator Tube Failure

High Under-the-Bioshield Temperature

- High-energy line breaks under the bioshield

SDAA Revision 2 (draft)

7.b High Pressurizer Pressure

11.c Low Pressurizer Level

13.b High Narrow Range (NR) RCS T_{HOT}

17.b High Main Steam Pressure

22.c High NR Containment Pressure

25.c Low AC Voltage to EDAS Battery
Chargers

26.c High Under-the-Bioshield Temperature

High NR Containment Pressure

- Loss of containment vacuum
- Feedwater System pipe break
- Inadvertent RVV opening

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Significant Changes from DCA to SDA GTS Chapters 3 and 5

SDA GTS Improvements Over DCA GTS

- **3.1.9 Boron Dilution Control**
 - Added configuration constraints on the Module Heatup System (MHS) to **ensure the MHS is never aligned** to the CVCS injection line of more than one NuScale Power Module
- **3.3.1 MPS Instrumentation** - accommodating control rod coupling and uncoupling
 - Mode 3 Applicability of selected reactor trip and DWSI instrument functions
 - “when capable of withdrawal of more than one control rod assembly (CRA)”
- **5.5.4 Steam Generator (SG) Program**
 - 72 effective full power month inspection interval for all SG tubes
 - RCS pressure is on the outside of the SG tubes, so the tubes are susceptible primarily to collapse or buckling rather than burst
 - Tube plugging criterion of 40 percent through-wall thickness is bracketed as part of COL Item 16.1-1

NuScale SDAA Part 2 Chapter 16 and Part 4 Review

Conclusion

NuScale US460 Standard Design GTS and Bases are acceptable because they comply with

- 10 CFR 50.34, “Contents of Applications; Technical Information”;
- 10 CFR 50.36, “Technical Specifications”; and
- 10 CFR 50.36a, “Technical Specifications on Effluents from Nuclear Power Reactors.”

**Presentation to the ACRS Subcommittee
Staff Review of NuScale's Loss-of-Coolant Accident (LOCA)
Evaluation
Model Topical Report
(TR 0516-49422-P)**

**January 15th, 2025
(Open Session)**

NuScale LOCA Topical Report Review

Contributors

- **Technical Reviewers**
 - Dr. Shanlai Lu, Lead, NRR
 - Dr. Sean Piela, NRR
 - Dr. Dong Zheng, NRR
 - Mr. Carl Thurston, NRR
 - Mr. Ryan Nolan, NRR
 - Dr. Syed Haider, NRR
 - Dr. Joshua Kaizer, NRR
- **Project Managers**
 - Ricky Vivanco, PM, NRR
 - Getachew Tesfaye, Lead PM, NRR

NuScale LOCA Topical Report Review

Overview

- NuScale submitted Loss-of-Coolant Accident (LOCA) Evaluation Model Topical Report (TR 0516-49422-P), rev. 3, on January 5, 2023. The topical report was formally accepted for review on July 31, 2023
- NRC conducted an audit of the topical report from March 2023 to August 31, 2024
- 57 audit issues were generated, resulting in supplemental information being submitted by NuScale
- For items not resolved during the audit, 4 RAIs were generated
- All audit items and RAIs are resolved closed
- Staff completed review of the LOCA Topical report and issued an advanced safety evaluation to support today's ACRS Subcommittee meeting

NuScale LOCA Topical Report Review

Conclusion

NRC staff completed the review of “LOSS-OF-COOLANT ACCIDENT EVALUATION MODEL” topical report. Subject to the closure of the open and confirmatory items noted in the draft SER, and, with eleven limitations and conditions identified, the NRC staff finds the following:

- The proposed LOCA analysis methodology is acceptable for meeting the requirements of 10 CFR 50.46 and the associated portions of Appendix K* evaluated in this TR, for evaluation of the ECCS performance in the NuScale NPM-20 for design-basis LOCAs. The proposed LOCA EM is conservative to determine CHF and collapsed liquid level above the reactor core.
- The proposed containment response analysis methodology is conservative and acceptable.
- The proposed NRELAP5 computer code and the NPM-20 model are acceptable to evaluate the MCHFR for IORV and LOCA events.

*Note that certain portions of Appendix K require exemptions as specified by limitation/condition (post-CHF phenomena).

Meeting Title

Open Session NuScale Subcommittee on Staff's Evaluation of NuScale Standard Design App Chapters 3, 16 and LOCA Evaluation Topical Repo

Attendees

| | |
|---------------------------|----------------|
| Michael Snodderly | ACRS (DFO) |
| Thomas Dashiell | ACRS |
| Sandra Walker | ACRS |
| Larry Burkhart | ACRS |
| R Snuggerud | NuScale |
| Jim Osborn | NuScale |
| Rob Meyer | NuScale |
| Scott Barnes | |
| Tyler Beck | NuScale |
| Kyle Hoover | NuScale |
| Freeda Ahmed | NuScale |
| Cindy Williams | NuScale |
| Andrea Torres | ACRS |
| Dennis Bley | ACRS |
| Karl Gross | NuScale |
| Dave Petti | ACRS |
| Doug B | NuScale |
| Shandeth Walton | ACRS |
| Kevin Spencer | NuScale |
| JJ Utberg | NuScale |
| Kevin Lynn | NuScale |
| John Fields | |
| Wendy Reid | NuScale |
| Meghan McCloskey | NuScale |
| James Cordes | Court Reporter |
| Eric Lantz | NuScale |
| Yi-Lun Chu | NRR |
| Craig Harbuck | NRR |
| Leonard Ward | NRR |
| Ron Ballinger | ACRS |
| Erin Blumsack | NuScale |
| Tom Case | NuScale |
| Emily Larsen | NuScale |
| Alina Schiller | NRR |
| Thomas Griffith - NuScale | NuScale |
| Mahmoud -MJ- Jardaneh | NRR |
| Matt Sunseri | ACRS |
| Andrea Mota | NuScale |
| Elisa Fairbanks | NuScale |
| Gary Becker | NuScale |
| Vicki Bier | ACRS |
| Steven Bloom | NRR |
| Ricky Vivanco | NRR |

| | |
|----------------------|---------|
| Walt Kirchner | ACRS |
| Robert Martin | ACRS |
| Kamal Manoly | NRR |
| Allyson Callaway | |
| Gregory Halnon | ACRS |
| Vesna B Dimitrijevic | ACRS |
| Angelo Stubbs | NRR |
| Raul Hernandez | NRR |
| Warren Erling | NRR |
| Gordon Curran | NRR |
| Prosanta Chowdhury | NRR |
| Thomas Hayden | NRR |
| Joy Jiang | |
| Milton Valentin | NRR |
| Jorge Cintron-Rivera | NRR |
| Upendra S. Rohatgi | |
| Kenneth Armstrong | |
| Stacy Joseph | NRR |
| David Benson | NuScale |
| Sarah Bristol | NuScale |
| Kaihwa Hsu | |
| Rob Krsek | ACRS |
| Tammy Skov | |
| Leslie Terry | |
| Jeff Luitjens | NuScale |
| Timothy Polich | |
| John Bozga | |
| Derek Widmayer | ACRS |
| Brian Wolf | NuScale |
| Marie Pohida | NRR |
| Kris Cummings | NuScale |
| Sarah Turmero | NuScale |
| Ben Bristol | NuScale |
| Ata Istar | NRR |
| Clint Ashley | NRR |
| John Honcharik | NRR |
| Greg Makar | NRR |
| C Basavarajh | NRR |
| Sunwoo Park | NRR |
| Shanlai lu | NRR |
| Sean Pieta | NRR |
| Mike Swim | NRR |
| Rebecca Patton | NRR |
| Carl Thurston | NRR |
| Antonio Barrett | NRR |
| Joshua Kaizer | NRR |
| Syed Haider | NRR |
| Justin Coury | RES |
| Cole Takasugi | RES |

Alfred Krall
Getachew Tesfaye

ERI
NRR

| Chapter 16 and Technical Specifications | |
|---|---|
| Noteworthy Changes from DCA to SDA | Discussion |
| <p>Technical Report TR-101310, "US460 Standard Design Approval Technical Specifications Development," Rev 0 describes differences between US600 and US460 Technical Specifications at the time of SDAA submittal.</p> | <p>The reasons for changes are described in general terms, and includes removals, relocations, and new requirements.</p> |
| <p>LCO 3.1.2 Core reactivity balance surveillance frequency was clarified.</p> | <p>The response to Audit Item A-16.3.1.2-1 revised SR 3.1.2.1 by removing the note associated with adjustment of predicted reactivity values to correspond to measured core reactivity prior to exceeding a fuel burnup of 60 EFPD. NuScale has no basis for the inclusion of this note other than consistency with the Standard Technical Specifications. The note implied that adjustment of predicted reactivity values is prohibited beyond 60 EFPD. There is no restriction on the timing of the revision of predicted reactivity values.</p> <p>The revision to SR 3.1.2.1 also removed a note in the frequency column. The note described when the surveillance is to be performed, and was unnecessary. The Surveillance Frequency Control Program (SFCP) establishes the surveillance frequency.</p> |
| <p>TS 3.1.9 modified to incorporate additional controls on possible dilution flow paths associated with the Module Heatup System (MHS).</p> | <p>Responses to Audit Items A-16.3.1.9-2 and A-16.3.1.9-3 revised TS 3.1.9 to include:</p> <ul style="list-style-type: none"> • New LCO related to MHS flow paths • Revision to Mode 3 Applicability to include "with any dilution source flow path not isolated" • Changes to Actions to address new MHS LCO • Changes to SR 3.1.9.5 to clarify verification that MHS flow paths to and from cross-connected systems are isolated. • Supporting Bases changes |

| | |
|---|---|
| | <p>The MHS heats the RCS to assist in developing natural circulation through the core before nuclear heat addition. The MHS is shared among NPMs and, when in service for a module, could represent an inadvertent dilution source for other modules. The revisions to LCO 3.1.9 ensure the modules not being heated by MHS are isolated from the MHS by two closed valves.</p> |
| <p>TS 3.5.4 modified to address the form of the emergency core cooling system supplemental boron (ESB) pellets and the associated requirements to be specified in the core operating limits report.</p> | <p>Response to Audit Item A-16.3.5.4-1 revised TS 3.5.4 and associated Bases to address the form of boron pellets and the associated requirements to be specified in the core operating limits report.</p> <p>The pellet dissolution rate depends on the geometric form (dimensions and shape) of the boron pellets.</p> |
| <p>TS 5.5.4, "Steam Generator (SG) Program," revised to update the tube integrity discussion, plugging criterion and inspection requirements.</p> | <p>To determine an appropriate steam generator tube plugging criterion for the US460 design, NuScale performed a finite element analysis specific to the US460 design. TS 5.5.4 was updated to reflect the analysis, and bracket the tube plugging criterion</p> <p>Revisions to inspection requirements increased inspection frequency and specificity.</p> |

**Supplement - ACRS – Loss-of-Coolant Accident Evaluation Methodology Topical Report
Review Presentation – Closed Session, January 15, 2025**

The staff is providing this supplement to highlight differences between the draft Advance Safety Evaluation Report (ASER) for NuScale, LLC. Topical Report "Loss-of-Coolant Accident Evaluation Model," TR-0516-49422, Revision 3 that was submitted to the Advisory Committee for Reactor Safeguards (ACRS) for review on December 14, 2024 and the version that was published on January 7, 2025 (ML24312A002). These differences do not change any of the staff's conclusions. The staff's presentation during the January 15, 2025 ACRS subcommittee's closed session accurately reflected the staff's conclusions in the published version of the ASER.

In summary, the differences include editorial changes, clarifications, and refinement of language in the limitations and conditions. The technical differences are the inclusion of additional supporting evidence of the staff's conclusions, specifically for scaling analysis of the LOCA EM, N-RELAP5 code version use, and containment response analysis methodology (CRAM). The changes are mainly due to additional information submitted by the applicant that supported the staff's conclusions in the draft ASER.

The table below lists the SE sections where changes were made, summary of the changes , and the slide number where this information was presented during the January 15, 2025, closed subcommittee meeting:

| <u>SER Section</u> | <u>Summary of Change</u> | <u>Presented on Slide #</u> |
|---|--|------------------------------------|
| Section 4.4.2, Phenomenon Identification and Ranking Table Rankings | As a result of additional information submitted by NuScale and confirmatory analysis performed by the staff, the staff found the existing PIRT for the in-vessel flow and heat transfer is not impacted by the generation and transport of the small amount of radiolytic gas. | 14 |
| Section 4.5.1.5, Helical Coil Steam Generators (HCSG) | The staff confirmed that the DHRS modeling and coupled pool nodalization is sufficient to model the overall decay heat removal responses and heat transfer capability. | 15 |
| Section 4.5.1.6, Containment Vessel and Reactor Pool | The staff confirmed that the uncertainty in natural convection heat transfer modeling from the CNV and DHRS to the pool due to thermal stratification would not be safety-significant with respect to the containment pressurization and DHRS capacity. | 29 |
| Section 4.6, NRELAP Computer Code | The staff confirmed code update and basemodel version-to-version benchmark results and determined that the code version update and model changes are acceptable and consistent with this NPM methodology. | 9 |

| SER Section | Summary of Change | Presented on Slide # |
|--|---|-----------------------------|
| Section 4.7.5.1, Test Facility | The staff confirmed, based on the results of the various assessment sensitivity studies, the applicant's conclusion that the NRELAP5 model responses are consistent with physics-based expected results and that there are very negligible effects on the event FOMs. | 11-12 |
| Section 4.8.2.7, [[]] | The staff confirmed that heat transfer from the lower head to the reactor pool has a minor impact on the CNV pressure response and that using the [[]] for modeling heat transfer from the lower hemispherical CNV head does not have any safety-significance with respect to the CNV T/H response. | 29 |
| From Section 4.8.3.2.4, Reactor Coolant System Depressurization Scaling | The staff confirmed [[]] and conservatism. Therefore, the conclusion in the distortion analysis is acceptable. | 12 |
| Section 4.8.3.3, Assessment of NuScale Facility Integral Effect Test Data | The staff confirmed that the applicant's extensive assessments in the LTR with these NIST-2 tests, and the code-to-data agreement is excellent for the figures of merit. | 12 |
| Section 4.8.3.4, Evaluation of NuScale Integral Effect Tests Distortions and NRELAP5 Scalability | As a result of additional analysis and justification provided by the applicant, the staff confirmed that NIST-2 chronology scaling is maintained as it was in the NIST-1 scaling. | 11 |
| Section 7. Limitation and Condition Section 4.5.2, Analysis Setpoints and Trips. | L/C modified to include " <i>unless the method is followed that is described in section 5.2 of the LOCA EM TR that models the riser level instrument setpoint based on mixture level in the riser, using one of the approaches described in detail in section 5.2 (not including the application – specific alternate approach).</i> " (This addition is also reflected in Section 4.5.2.). Additionally, L/C #4 and #9 were combined into one L/C. | 13 |