

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguard
Regulatory Rulemaking, Policies and Practices

Docket Number: (n/a)

Location: teleconference

Date: Thursday, January 16, 2025

Work Order No.: NRC-0184

Pages 1-318

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)

+ + + + +
REGULATORY RULEMAKING, POLICIES AND PRACTICES
SUBCOMMITTEE

THURSDAY
JANUARY 16, 2025

+ + + + +
The Subcommittee met via Video conference, at
8:30 a.m. EST, Ronald Ballinger, Chairman, presiding.
SUBCOMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman
GREGORY H. HALNON, Vice Chairman
VICKI M. BIER, Member
VESNA B. DIMITRIJEVIC, Member
CRAIG D. HARRINGTON, Member
WALTER L. KIRCHNER, Member
ROBERT P. MARTIN, Member
SCOTT P. PALMTAG, Member
DAVID A. PETTI, Member
THOMAS E. ROBERTS, Member

1 ACRS CONSULTANT:

2 DENNIS BLEY

3 STEVEN SCHULTZ

4

5 DESIGNATED FEDERAL OFFICIAL:

6 WEIDONG WANG

7

8 ALSO PRESENT:

9 VICTORIA ANDERSON, NEI

10 KEVIN BARBER, Westinghouse

11 LARRY BURKHART, ACRS/TSB

12 JONATHAN CHAVERS, Southern Nuclear

13 THERESA CLARK, NRR/DSS

14 PAUL CLIFFORD, Framatome

15 JAMES CORSON, RES/DSA/FSCB

16 AL CSONTOS, NEI

17 ELIJAH DICKSON, NRR/DRA/ARCB

18 LISA GERKEN, Framatome

19 SE-KWON JUNG, NRR/DEX

20 JEFF KOBELAK, Westinghouse

21 GUANGJUN LI, GE Hitachi Nuclear Energy

22 TARA MATHENY, Duke Energy

23 JOSEPH MESSINA, NRR/DSS/SFNB

24 BRIAN MOUNT, Dominion/PWROG

25 KURSHAD MUFTUOGLU, EPRI

1 CHARLEY PEABODY, NRR/DSS/SNSB
2 JASON PIOTTER, NMSS/DFM/NF
3 DAVID RUDLAND, NRR/DNRL
4 BARIS SARIKAYA, Constellation
5 FRED SMITH, EPRI
6 JIM STAVELY, PSEG
7 ROBERT TREGONING, RES/DE
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A-G-E-N-D-A

ACRS SC Chairman Introductory Remarks	5
NRR Staff Leadership Opening Remarks	9
Discussion of DG-1428 Guidance	12
Changes since Dec. SC meeting	93
Industry and EPRI Presentations	143
Follow ups from Dec. SC meeting	233
Public Comment	307
Adjourn	

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR BALLINGER: Good morning, the meeting will now come to order. And I think I'm getting feedback.

This is a meeting of the Regulatory Rulemaking, Policies and Practice Subcommittee of the Advisory Committee on Reactor Safeguards. I'm Ron Ballinger, the Chair of today's subcommittee meeting.

The ACRS members in attendance in person, myself, are Bob Martin, Tom Roberts, Craig Harrington, Greg Halnon, and Scott Palmtag. ACRS members in attendance virtually via Teams are Dave Petti, Walt Kirchner, Vicki Bier, and Vesna Dimitrijevic. I expect that Matt Sunseri will probably join us as well.

We have two consultants participating, Steve Schultz, and Dennis Bley, today. Dennis Bley is virtual. If I've missed anybody, I'm sure I'll get notice of that.

Weidong Wang from the ACRS staff is the designated federal officer for this meeting. No member conflicts of interest were identified for today's meeting. We have a quorum for today's meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 During today's meeting, the subcommittee
2 will receive a presentation on technical topics
3 regarding increased enrichment of conventional and
4 accident tolerant fuel designs for light-water
5 reactors rulemaking.

6 The NRC is proposed to amend its
7 regulations related to the use of conventional and
8 accident tolerant light-water reactor fuel design.
9 The NRC goal is to establish effective and efficient
10 licensing for the use of fuels enriched to greater
11 than five weight percent uranium-235 while continuing
12 to provide reasonable assurance of adequate protection
13 to public health and safety.

14 The new requirements also would address
15 fuel fragmentation, relocation, and dispersal in
16 relation to the key accident tolerant fuel components
17 of increased enrichments and burnup limits.

18 We had a subcommittee meeting in December
19 2024 on specific draft guide DG-1428, Plant-Specific
20 Applicability of Transition Break Size. That one was
21 not ready for discussion in December. In today's
22 meeting we'll hear discussion on that one.

23 I might add that, if you look at the
24 agenda, it's very full. And there are times allocated
25 for various stakeholders' presentations. And I would

1 ask that people do their best to stick to their
2 schedule, because we also will have a meeting,
3 basically a continuation, tomorrow. So any additional
4 issues that may come up, I think we can deal with that
5 tomorrow.

6 The ACRS was established by statute and is
7 governed by the Federal Advisory Committee Act, or
8 FACA. The NRC implements FACA in accordance with our
9 regulations. Per these regulations and the committee
10 bylaws, the ACRS speaks only through its published
11 letter reports. All member comments should be
12 regarded as only the individual opinion of that
13 member, not the committee position.

14 All relevant information related to ACRS
15 activities, such as letters, rules for meeting
16 participation, and transcripts, are located on the NRC
17 public website and can be easily found by typing about
18 us ACRS in the search field on the NRC's home page.

19 The ACRS is consistent with the Agency's
20 value of public transparency, and regulation in
21 nuclear facilities provides opportunity for public
22 input and comment during our proceedings. We have
23 received written comments provided to the committee by
24 two members of the public, Mr. Ralph O. Meyer, who was
25 a former NRC employee some time ago, and Mr. Wolfgang

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Wiesenack, in the form of a slide presentation. We
2 have set aside time at the end of this meeting for any
3 other public comments.

4 The ACRS will gather information, analyze
5 relevant issues and facts, and formulate proposed
6 conclusions and recommendations as appropriate for
7 deliberation by the full committee. The transcript of
8 the meeting is being kept and will be posted on our
9 website.

10 When addressing the subcommittee, the
11 participant should first identify themselves and speak
12 with sufficient clarity and volume so that they may
13 be readily heard. If you're not speaking, please mute
14 your computer on Teams or by pressing star six on your
15 phone.

16 Please do not use the Teams chat feature
17 to conduct sidebar discussions related to the
18 presentations, rather limit use of the meeting chat
19 function to report IT problems.

20 For anyone in the room, please put all
21 your electronic devices in silent mode and mute your
22 laptop microphone and speakers. In addition, please
23 keep sidebar discussion in the room to a minimum
24 since the ceiling microphones are live, and they are
25 very sensitive.

1 For presenters, your table microphones are
2 unidirectional. That's an understatement. And you'll
3 need to speak into the front of the microphone
4 directly to be heard.

5 Finally, if you have any feedback for the
6 ACRS about today's meeting, we encourage you to fill
7 out the public meeting feedback form on the NRC's
8 website.

9 And I'll proceed with the meeting. And I
10 think Theresa Clark, Theresa, there you go, will have
11 some opening remarks.

12 MS. CLARK: Thank you, sir.

13 Good morning, everyone. It's a pleasure
14 to be here. I'm Theresa Clark, the Director of the
15 Division of Safety Systems, and I'm one of the leads
16 for the management review of this rule, which is
17 really a momentous effort by the staff. And we
18 appreciate all of the committees' engagement in
19 thinking through the broad nature of the rule and how
20 it can be implemented.

21 We think it's really helpful that there's
22 going to be these additional comments from industry
23 and the public, remarks that you mentioned. All of
24 that is going to help us make an even better product.

25 We also particularly appreciate the

1 flexibility of the committee, for example, to provide
2 this presentation today on the draft guide that wasn't
3 ready in December. That allowed us to finish that up
4 and to have a lengthy discussion today and tomorrow,
5 which we think will be really useful.

6 And this is broad scope rule with a lot of
7 envisioned benefits for both safety and operations, as
8 well as cost optimization. And we really do see it as
9 a way to advance the adoption of accident-tolerant
10 fuel, increased enrichment fuel, and to be able to get
11 to high burnup safely.

12 So it's very important, but it's also been
13 a really ambitious effort by the staff on a tight
14 schedule. One of the ways we were able to do that was
15 by leveraging information to prior rule makings, from
16 2010 and 2017. That's helpful for everyone, because
17 there's a lot of public record on the prior ACRS
18 review of those that we could use to think through the
19 process.

20 And, as you heard in December, and you'll
21 hear again from Joe today, there were a few things
22 that felt right in 2010 or 2017 that just weren't
23 hitting right in 2024. So we've made some adjustments
24 to deal with that.

25 Just a couple of other things I'd like to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 mention really quickly, we know that the guidance
2 we're putting down is one way of doing things. We're
3 totally open to workshopping other ways. And
4 licensees may prefer alternatives on a case by case
5 basis. But we are planning to have intensive
6 engagement during the public comment period as is
7 possible for every public meeting.

8 And at the same time, we recognize that
9 there's other options facilitated by (audio
10 interference). The performance based requirements
11 that appear at 50.46a would be able to be used by
12 anyone, whether they're adopting the transition break
13 size risk-informed approach or not. And that could
14 pave the way for some other options.

15 For example, the staff currently has under
16 review EPRI's alternative licensing strategy, that's
17 been one thing that could be facilitated by the rule
18 language. And there's other options that were talked
19 about in the regulatory basis that could also be
20 facilitated by that rule language. So we're committed
21 to continuing to think about how those could be
22 adopted.

23 But it's a rule that we're proud of, and
24 really proud of the staff, and I look forward to
25 continuing to go back to those as we go forward.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Thank you.

2 CHAIR BALLINGER: That's it. Thank you.

3 Who is going? Dave? Okay, the floor is yours.

4 MR. RUDLAND: Thank you. Good morning.

5 CHAIR BALLINGER: For better or for worse.

6 MR. RUDLAND: Yes, thanks. My name is Dave
7 Rudland, and I am a senior technical advisor in the
8 Division of New and Renewed Licenses, NRR. I'm joined
9 by Rob Tregoning from of Office of Research and,
10 online, Se-Kwon Jung from NRR, our Division of
11 Engineering.

12 And the three of us will be presenting the
13 basis for a draft Regulatory Guide DG-1428 which will,
14 when published, will be Regulatory Guide 1.258, plant-
15 specific applicability of the transition break size.

16 Next slide, please. I wanted to start this
17 presentation by first getting a little bit of
18 background on the basis for the transition break size.
19 And then I'm going to go into a bit of history.
20 Theresa alluded a little bit to some of the past work
21 that was done, so I kind of wanted to lay the
22 groundwork for what that was and how it fed into the
23 development of this DG.

24 So, first of all the background for the
25 transition break size, the basis, as we talked about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 in December, is on two published NUREG documents.
2 Those NUREG documents were published in the early
3 2000s, NUREG-1829 and -1903.

4 1829 was a generic evaluation to provide
5 best estimate LOCA frequencies. And that was done
6 through the expert elicitation process that used both
7 qualitative and quantitative processes to develop LOCA
8 frequency estimates that were then combined to come up
9 with the LOCA frequencies that are in 1829.

10 It used a ten to the minus five per year
11 conservative LOCA frequency, and it was based on
12 operating experience but also on a lot of engineering
13 judgment and geometry. And it was chosen to try to
14 promote regulatory stability in the definition of the
15 LOCAs.

16 1903 came afterwards, and it was an analysis
17 that looked into verifying the risks associated with
18 seismic induced breaks that were greater than the
19 transition break size and whether or not that was
20 still a reasonable analysis given leak results.

21 1903 looked at two different things. It
22 looked at direct piping failures and indirect piping
23 failures. We'll talk a little bit more about that
24 later on. And the NUREG concluded that both those
25 indirect and direct failures had a mean failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 probability on the order of ten to the minus six. So,
2 it was well below the ten to the minus five criteria
3 that was used for selecting the transition break size.

4 Okay, move to the next slide. So, the
5 initial motivation for regulatory guidance back in
6 the early 2000s was it was really noticed up front
7 that all of the analyses conducted, both 1829 and 1903
8 were driven, could be driven by plant-specific
9 attributes, and that those plant-specific attributes
10 might influence LOCA frequencies that were calculated
11 in those documents.

12 So, it was important to ensure that the TBS
13 was applicable to each plant that may want to apply
14 it. In fact, the Commission directed us, in SRM-SECY-
15 07-0082, to develop regulatory guidance that would
16 provide a method for establishing this justification.

17 And the staff interpreted that to be both
18 for NUREG-1829 and 1903. So they developed DG-1216,
19 which at the time was entitled plant-specific
20 applicability of the transition break size specified
21 in 10 CFR 50.46a.

22 Okay, next slide, please. So the scope at
23 the time, the initial scope of DG-1216 applied to the
24 primary loop piping and reactor coolant pressure
25 boundary components whose failures would be greater

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 than the proposed TBS.

2 It gave one acceptable method for
3 demonstrating applicability to NUREG-1849 and 1903 for
4 direct piping failures only. The effects of plant
5 changes on both of those NUREGs was also present in
6 the original draft guide.

7 The history of the guide itself, there were
8 a lot of public interactions on that. We had initial
9 public meetings, we had ACRS subcommittee meetings, we
10 had main committee meetings, and we went through an
11 extensive public comment period on the draft guide
12 itself.

13 We had scheduled, actually, a Commission
14 briefing on the DG itself, but as we talked about in
15 December, the DG was withdrawn in 2016 after the staff
16 and the Commission requested that the rule be
17 abandoned.

18 Okay, next slide, please. So like I said,
19 we got a lot of feedback, so I kind of want to go over
20 some of that feedback. Our initial feedback from the
21 ACRS is shown on this slide.

22 As it pertains to the rule itself, the ACRS
23 concluded that the work that was in the DG-1216
24 provided an acceptable method and acceptance criteria
25 for evaluating applicability to 1829. And it provided

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a good framework for analyses to demonstrate
2 applicability to 1903 for direct piping failures.

3 But the ACRS indicated that we should expand
4 1903 to include applicability to indirect piping
5 failures too, and how that may affect in the
6 transition break size, as well as exploring
7 methodologies or other efforts to reduce the effort
8 that's required to demonstrate that applicability.

9 So the staff went forward and adopted those
10 recommendations to add to the guidance for indirect
11 piping failures, modified the FRN, and presented some
12 initial ideas on how we may update the guidance to
13 include indirect piping failures.

14 And that was presented in a public meeting
15 in 2010. And how we plan to evaluate the
16 acceptability could be done possibly as part of pilot
17 study was recommended at that time.

18 Okay, let's go to the next slide. We
19 received public comments also from both NEI and the
20 PWR Owners Group. From NEI, they commented that the
21 guidance was complex and proposed maybe a simple check
22 list or something like that. They were concerned
23 about this update to account for seismically induced
24 indirect piping failures.

25 They requested that more reliance be placed

1 on programs such as 50.59 and other existing programs
2 to help reduce the plant change analyses. They
3 suggested that we leverage the margins to provide
4 competence that, sort of, it applies to all plants and
5 that plant applicability maybe would not be required.

6 And they also suggested a pilot study prior
7 to the final issuance of the draft guide to work out
8 some of these issues.

9 The Owners Group had a lot of very similar
10 comments. But in addition, they commented that they
11 felt that the current inspections on these pipes
12 provided adequate protection against large LOCA. They
13 also recognized the complexity of the license renewal
14 process but were concerned about plants that had not
15 yet applied for license renewal. Because at that
16 time, plants were just starting to do that.

17 And they suggested that plants that were in
18 low seismic zones be exempt from demonstrating plant-
19 specific applicability for 1903. They also had some
20 questions about several of the requirements to
21 acceptance criteria that were a part of the rule and
22 some of the guidance.

23 Okay, next slide. So at the time, our next
24 steps, at the time of the comments, the next step was
25 to wait until the Commission voted on SECY-10-0161,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 which was the draft final rule before modifying the DG
2 at all.

3 At the time, the plan was to not finalize
4 the guidance until after the final rule was published
5 and then to have these public interactions, and maybe
6 a pilot study in place before finalizing the draft
7 guide.

8 And some of the things that we planned to do
9 as part of that was, again, add this method to address
10 the indirect seismic analyses, conduct this pilot
11 study that we talked about, address the comments, and
12 modify the guidance. But as we pointed out in
13 December, the Commission approved the staff's request
14 to discontinue that rulemaking, and DG-1216 was
15 withdrawn in 2016.

16 Okay, next slide. That's the history. So
17 if we fast forward to a couple of years ago, the staff
18 requested to pursue a rulemaking to develop a
19 regulatory basis to amend the requirements to use
20 light-water reactor fuel containing uranium enriched
21 to greater than five weight percent.

22 And the Commission approved that in SRM-
23 SECY-21-0109 but stated that FFRD, fuel fragmentation
24 relocation disbursal, should be appropriately
25 addressed.

1 Within the basis that was published, the
2 staff included five options, which we talked about in
3 December, and based on feedback, chose Alternative 2
4 which was basically the development to resurrect the
5 work that was done in the early 2000 framework on the
6 50.46a rule that the draft guide that I just mentioned
7 was meant to provide guidance for. And that was all,
8 again, described in December.

9 And to support this rule, the staff decided
10 to go ahead and revamp that DG and follow the
11 Commission guidance to develop this type of guidance.
12 And that's DG-1428 which is now titled Plant Specific
13 Applicability of the Transition Break Size. And
14 that's the main point of this discussion today.

15 Okay, next slide.

16 MEMBER MARTIN: I've been too quiet. You
17 know, I can't stand --

18 (Simultaneous speaking.)

19 MEMBER MARTIN: -- you know, silent for too
20 long.

21 So forgive me if this is kind of inane, but
22 given the background, obviously pretty busy up until
23 2016. Since 2016, obviously, you highlight kind of
24 the reboot of policy initiatives. Now prior to that,
25 through today, have there been any really research

1 initiatives or otherwise, you know, the high burnup
2 uncertainties, and seismic impacts, that sort of
3 thing, outside the policy space --

4 MR. RUDLAND: Sure.

5 MEMBER MARTIN: -- that the --

6 MR. RUDLAND: Yes, there's a --

7 (Simultaneous speaking.)

8 MR. RUDLAND: -- so in terms of LOCA
9 frequencies and pipe failure, and all that, there has
10 been an awful lot of work done in the 2000s, 2010s,
11 and even into 2020s, looking at the failure, the
12 probability of failure of these large pipes.
13 Especially for the PWRs, we've had this issue, as you
14 all know, on PWSCC for years and how that may impact
15 the leak before break analyses that were done.

16 Both the industry and the NRC developed
17 extensive analyses to look at the LOCA frequencies and
18 the failure frequencies of these pipes as they may be
19 impacted by PWSCC. A lot of the work that Theresa
20 mentioned that the EPRIs suggested for ALS leveraged
21 that work. So, a lot of that's been done. So, we
22 understand more about LOCA frequencies and pipe
23 failures than we did back in 2010 time frame.

24 MEMBER MARTIN: So while policy kind of
25 stopped --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: Yes, policy kind of stopped.

2 MEMBER MARTIN: -- knowledge development --

3 MR. RUDLAND: That's right, technical work

4 --

5 MEMBER MARTIN: -- continued.

6 MR. RUDLAND: -- continued. That's right.

7 Not so much for the BWRs but mainly for the PWR pipes,
8 yes.

9 Okay, let's move to the next slide. So, I
10 wanted to kind of talk a little bit about where in the
11 proposed rule that we presented in December are the
12 areas that are supported by this particular DG.

13 So if you look through the rule in the
14 application section in 50.46a[©], there is a requirement
15 that for the existing plants they must demonstrate the
16 applicability of the transition break size.

17 For new plants, they have to demonstrate
18 similarity in plant design and recommend and justify
19 plant-specific TBSs. For both new and existing
20 plants, if changes are made, there is a requirement
21 that they must demonstrate that the TBS remains
22 applicable. And there is a requirement that they
23 demonstrate applicable leak detection programs.

24 There's also an optional process that they
25 can go through, a self-approval process, where they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 can make changes without NRC approval. But they still
2 need to describe the process for how they're going to
3 demonstrate TBS applicability.

4 Under the 50.46a(d), there's a requirement
5 to, again, to identify, monitor and quantify leakage,
6 and to perform evaluations to demonstrate the TBS
7 remains applicable through any plant changes that may
8 occur.

9 50.46a(h) proposed changes enacted with or
10 without the approval must demonstrate continued
11 applicability of the TBS. And in the reporting
12 section in 50.46a(j) it must document the basis for
13 determining that changes enacted without prior
14 approval don't invalidate the TBS. So, all of those
15 different rules in there are supported by this work in
16 the draft guide.

17 CHAIR BALLINGER: This is Ron Ballinger. I
18 didn't know when to ask this question or comment this
19 way, but all of the work that's been done during that
20 interval period, one of which is the mitigation of all
21 these welds, in some way, and combined with the leak
22 rate requirement, what do you think the probability is
23 of LOCA now?

24 MR. RUDLAND: So, I'll make -

25 CHAIR BALLINGER: Want to think in real

1 world.

2 MR. RUDLAND: So, I'll make the first
3 comment, that not all the welds are mitigated. The
4 Inconel welds, some of the Inconel welds are
5 mitigated, but others are being periodically inspected
6 to make sure that they --

7 CHAIR BALLINGER: That's what I meant by
8 mitigated in some way, N-770, or something like that
9 --

10 (Simultaneous speaking.)

11 CHAIR BALLINGER: -- and I'm talking about
12 dissimilar metal welds.

13 MR. RUDLAND: It's just the dissimilar metal
14 welds.

15 CHAIR BALLINGER: Yeah.

16 MR. RUDLAND: So what do I think the LOCA
17 frequencies are? It's a little bit of a loaded
18 question. I mean --

19 CHAIR BALLINGER: It was supposed to be.

20 (Laughter.)

21 MR. RUDLAND: I think for the PWRs that have
22 been shown to have PWSCC, I think both the industry
23 analyses and the NRC analyses have demonstrated that
24 they are extremely -- they're the order of ten to the
25 minus six types of annual frequency of rupture.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 That's what most of the analyses have shown. Does
2 that answer your question?

3 CHAIR BALLINGER: Sort of.

4 MR. RUDLAND: Well, ask it one more time,
5 I'll see if I can answer it next.

6 CHAIR BALLINGER: You used the word zero in
7 one of the previous meetings, so I'm just curious as
8 to how far below ten to the minus six.

9 MR. RUDLAND: I will never say zero when
10 talking probabilities.

11 CHAIR BALLINGER: Okay.

12 MR. TREGONING: And just recognize that the
13 similar metal welds are a very small percentage of the
14 type of welds that are in these systems. Most of the
15 welds are similar metal welds that are not mitigated
16 in any way other than they're part of their --

17 MR. RUDLAND: And significantly --

18 (Simultaneous speaking.)

19 MR. TREGONING: -- typically a risk-informed
20 inspection program, okay? A risk-informed ISI
21 program. They're not in 770 welds. That's only a
22 very small percentage in welds. That's only the
23 dissimilar metal welds.

24 CHAIR BALLINGER: But how many of those are
25 the TBS, beyond TBS welds?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. TREGONING: All of the similar metal
2 stainless steel welds that run in the hot leg, cold
3 leg, cross upper leg, and the recirc stuff --

4 MR. RUDLAND: That's the propensity of the
5 welds.

6 CHAIR BALLINGER: In BW?

7 MR. RUDLAND: BW.

8 CHAIR BALLINGER: Those are the similar
9 metal welds you're talking about.

10 MR. RUDLAND: That I will talk about here in
11 a few minutes.

12 CHAIR BALLINGER: Those are the -- somebody,
13 is there a hand up?

14 VICE CHAIR HALNON: No, I was going to
15 remind Robert to state your name.

16 MR. TREGONING: Sorry, Rob Tregoning, NRC.

17 VICE CHAIR HALNON: The court reporter
18 doesn't know --

19 MR. TREGONING: Understand, thank you.

20 MR. RUDLAND: Okay, let's move to the next
21 slide. So, the purpose of this particular draft
22 guide, again, lies in the fact that the proposed rule
23 requires an evaluation to demonstrate plant-specific
24 applicability to TBS. And this draft guide provides
25 one acceptable way.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And as Theresa pointed out earlier, there
2 are other methods through the rule where other things
3 can't be used to do this demonstration. But if it
4 can't be demonstrated through whatever means, they can
5 develop, a plant-specific entity can develop a plant-
6 specific transition break size. And this guide may
7 also help them in doing that.

8 MEMBER MARTIN: Bob Martin, just a
9 clarification, so the 1216 ended 2016. And here we
10 are with 1428. You, of course, mentioned that you
11 had, you know, re-booted some stakeholder engagement
12 after 2021. Those comments that came in at the end of
13 1216, now they informed what we have here today so --

14 MR. RUDLAND: Yes.

15 MEMBER MARTIN: -- you know, the concerns
16 about complexity and seismic failure, that's been
17 responded to and --

18 (Simultaneous speaking.)

19 MR. RUDLAND: We tried the best we could to
20 reduce the amount of burden that they suggested in
21 their comments.

22 (Simultaneous speaking.)

23 MR. RUDLAND: Yeah, and tried to simplify
24 the process, especially for those approved programs
25 that they have at the plants, now, that maybe they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 didn't have back at the time.

2 MEMBER MARTIN: And we might hear more about
3 that?

4 (Simultaneous speaking.)

5 MR. TREGONING: Even though we did consider
6 those comments and we tried to address this, it
7 doesn't mean that we might not get some of those same
8 comments associated with this draft copy.

9 MEMBER MARTIN: I know who my audience is
10 right now, so I'm taking advantage of it.

11 MR. TREGONING: So, believe me, we're not
12 naive enough to expect that this is a perfect reg
13 guide that all the stakeholders are going to readily
14 embrace. There'll be some things that we'll need to
15 work through.

16 MEMBER MARTIN: I do have --

17 MR. TREGONING: Oh, yes.

18 MEMBER MARTIN: -- you did ignore it.

19 (Simultaneous speaking.)

20 MEMBER MARTIN: It's gotten in here.

21 MR. RUDLAND: And I'll try to point those
22 out as we --

23 MR. TREGONING: We'll point it out. But
24 again, we -- the point that Dave's trying to make, we
25 did a lot of work to get out 1216, and jumped through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a lot of hoops including going through a public
2 comment. So we wanted to leverage that work as much
3 as we could. Because we weren't starting from a blank
4 slate here. You'll see the 1428, you know, owes its
5 existence to 1216.

6 MEMBER MARTIN: And that's why I think it
7 was important to get it on record here. There's a
8 continuity, and it might have been a few years of
9 policy lapse, but there is some continuity from all
10 that work to what you have today.

11 MR. RUDLAND: Okay, next slide. So, I
12 wanted to give a quick overview before we go into the
13 details of 1428. As we just talked about, 1216 was
14 used as a starting point. And then you -- thank you
15 for being my straight man there and setting me up for
16 this slide.

17 We tried to leverage a lot of the programs
18 that they have in place, like license renewal, leak
19 before break, those kinds of things, as well as
20 required inspections to really streamline and simplify
21 the guidance from 1216.

22 We considered the 1216 comments in doing
23 that. We provided guidance to address indirect
24 seismic failures, tried to address the recommendation
25 of the ACRS from 2010, and tried to keep the guidance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 consistent with the rulemaking requirements and
2 leverage the DG-1426 guidance as much as we can.

3 And just a reminder, the 1426 guidance is
4 the -- we had a brief on that in December also, and it
5 was the risk-informed evaluation process supporting
6 this acceptance criteria for the ECC systems and LWRs.

7 And the other thing we wanted to do with
8 this guidance is provide a multitude of options so
9 that we weren't just giving one particular
10 recommendation for guidance, but we're giving
11 licensees options on how they can meet these different
12 criteria.

13 And we do propose again to try to use a
14 pilot study, or workshops, or something like that in
15 between the draft and final to work out the details on
16 this type of guidance.

17 Next slide, please. So, this is just a
18 graphical overview of what we're going to be talking
19 about for the remainder of the morning. I'll start
20 talking about the NUREG-1829 applicability and its
21 attributes. Se-Kwon, who is on virtual, will be
22 talking about the 1903 applicability, and then Rob
23 will be talking about map changes and LOCA frequencies
24 toward the end of this presentation.

25 VICE CHAIR HALNON: Dave, this is Greg

1 Halnon. I'm just going to get this one question off
2 my chest again. I think it's been answered, and I
3 don't know if it's been answered to where I don't have
4 the question again.

5 Back in the last meeting, we talked about
6 the initiating event frequency being very low for
7 LOCAs above the transition break size. And then also
8 that the risk increases for plant changes is very
9 minor. But then the third bullet was what is going to
10 maintain regulatory control of these LOCAs.

11 MR. RUDLAND: Consistency, I think is what
12 --

13 VICE CHAIR HALNON: I still don't
14 understand, in a risk-informed thought process, why
15 LOCAs greater than a transition break size specific to
16 the plant, why we have to maintain regulatory control
17 over this?

18 MR. RUDLAND: Well, I think the point was
19 regulatory consistency. So, we wanted to publish the
20 transition break size so that we would have the same
21 rules for every plant, right. If we allowed -- which
22 is a process we could do, we could allow the
23 calculation of their own transition break size, but
24 that provides, across the industry, different things
25 from different plants --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR HALNON: This is not --

2 (Simultaneous speaking.)

3 MR. RUDLAND: -- consistency from a
4 regulatory framework. It's not --

5 VICE CHAIR HALNON: -- on a current
6 licensing basis specific to the plant does flow for -

7 (Simultaneous speaking.)

8 MR. RUDLAND: And they have the opportunity
9 to do that.

10 VICE CHAIR HALNON: They have the
11 opportunity to say I'm above this transition, or these
12 plants are above the transition break line, therefore
13 I don't have to worry about them anymore. We're not
14 giving them that option at his point.

15 MR. RUDLAND: No, again, I think, you know,
16 the selection of the transition break size was done
17 through a variety of analyses, right. And so, even if
18 the probability of something is low, we need to
19 continue to monitor to make sure that the analyses
20 that we did was still representative in the future.

21 VICE CHAIR HALNON: See, that seems contrary
22 to the risk-informed -

23 MR. RUDLAND: No, that's actually part of
24 the risk-informed decision making process, is that
25 performance monitoring needs to be done --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR HALNON: Performance monitoring
2 is one thing, but maintaining regulatory control over
3 it -

4 MR. RUDLAND: By regulatory control you're
5 talking about the LOCA analyses?

6 VICE CHAIR HALNON: Yes. Well, we're going
7 to get into this in the diagrams coming up.

8 MR. RUDLAND: And we talked a lot about that
9 in December, right, the notion that we're creating --

10 (Simultaneous speaking.)

11 VICE CHAIR HALNON: Right. I still don't
12 understand why we're even here if the plant can
13 justify TBS and it's --

14 VICE CHAIR HALNON: I'm going to phone a
15 friend about that.

16 MR. MESSINA: Yeah, this is Joseph Messina
17 from the staff. And we did that to maintain
18 consistency with other beyond design basis actions
19 such as ATLAS and station blackout which we still do
20 the analysis for.

21 VICE CHAIR HALNON: Okay. I'm not convinced
22 yet, but we'll go through it and maybe I'll stay a
23 skeptic, I don't know.

24 MR. RUDLAND: I just want to make sure that
25 we're clear. In this particular guidance, we're not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 talking about the LOCA analyses at all, right? We're
2 talking mainly about the calculation of the transition
3 break size --

4 VICE CHAIR HALNON: Right.

5 MR. RUDLAND: -- just to be clear.

6 VICE CHAIR HALNON: I get that. We're
7 talking about all the other industry and stuff going
8 on, like ALS and stuff that will eliminate these large
9 break LOCAs. I'm not sure why we just don't eliminate
10 the large break LOCA and say we're done. Same thing
11 with what Ron was saying, relative to the mitigated,
12 in some way.

13 So, it seems like all the cards are stacking
14 up to where we're saying we don't need to be concerned
15 about breaks involved with TBS, and even if you put
16 some margin on it.

17 Go ahead, I got it off my chest and I'm
18 good, we're good to go.

19 MR. BLEY: This is Dennis Bley. More than
20 getting it off your chest, the argument, if we believe
21 the results of these analyses, it used to be spelled
22 out. I forget where it's spelled out. But design
23 basis accidents are things that have frequencies of
24 occurrence bigger than about, in the range of ten to
25 the minus three to ten to the minus four per year.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And if we're saying these are much lower
2 than that, we don't need to be consistent with other
3 design basis accidents. This shouldn't be a design
4 basis accident anymore.

5 VICE CHAIR HALNON: I don't think there's an
6 answer to that --

7 (Simultaneous speaking.)

8 VICE CHAIR HALNON: I think we're in
9 agreement. I appreciate that.

10 CHAIR BALLINGER: We never promised you a
11 rose garden.

12 MR. BLEY: Well, I think --

13 (Simultaneous speaking.)

14 VICE CHAIR HALNON: The question to ask when
15 EPRI presents on ALS this afternoon, I think they made
16 the point at a meeting we had several months ago that
17 the real problem is how much the LOCA is buried in
18 regulation, how much effort it would be to get it out
19 of regulation.

20 And so they chose an alternative that still
21 keeps it a regulation but still has a solution to the
22 civic FFRD problem for break line, transition breaks.
23 I think we have to revisit this question when they're
24 up.

25 Okay, thanks, Tom. It's a burning question

1 in my mind that I wanted to reconcile. So go ahead.

2 MR. TREGONING: And I think it's a good
3 question, right. And it's a good discussion point.
4 The one thing I will say is one of the reasons that
5 the risk associated with large break LOCAs is low is
6 the fact that the plant's designed specifically to
7 combat that.

8 And potentially, under this rule, they'll be
9 allowed to make changes that might peel back some of
10 the things that they did to mitigate the large break
11 LOCA. So by definition, then, the risk will increase
12 by some degree.

13 And I think what we're trying to do is make
14 sure, as part of this rule, that those increases in
15 risk due to the large break LOCA remain acceptable. So
16 that's the balance that I think we're trying to strike
17 here.

18 But your point, it's almost as philosophical
19 in a policy discussion as much as anything, you know,
20 how much relaxation is appropriate. Should there be
21 a regulatory book at all? Those are all, I think,
22 part of this debate.

23 And as this rule continues to wind its way
24 through, hopefully to the Commission and out to the
25 public, I'm sure that particular point will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 discussed quite vigorously.

2 VICE CHAIR HALNON: That's not why we're
3 here.

4 MR. RUDLAND: No. And again, whether or not
5 there's regulatory components that will allow large
6 break LOCAs, it doesn't, again, it doesn't change how
7 this break between a smaller break and a large break
8 occurs. And that's kind of what we're here to talk
9 about today.

10 So, let's go to the next slide. For each of
11 these topics that I talked about there's going to be
12 this flow chart. This flow chart is in the draft
13 guide. And it's basically just to kind of give a
14 visual flow for how the approach works. And there's
15 a couple of things I want to point out about this
16 before I get into the nitty gritty details.

17 It's trying -- the approach is trying to
18 leverage, the best that it can, the processes that
19 have been used and approved in the past with the
20 Agency for the different topics.

21 So the two main topics, aging management and
22 analyzing plant-specific attributes, are the two main
23 topics in describing 1829 applicability. However, if
24 a plant has an approved license renewal, an approved
25 license renewal submittal, and they have an adequate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 leak -- which most plants do, when they have an
2 adequate leak detection system, which most plants do,
3 and have an approved LBB analysis, which most PWR
4 plants do, the flow through this goes right to
5 accepting the NUREG-1829 applicability.

6 To follow the flow through all of that, they
7 note there's no additional analyses that are needed.
8 So, we try to leverage those programs, the license
9 renewal program, the leak before break programs, the
10 leak detection systems, to get through this without
11 any additional analysis.

12 If there isn't those things in place, then
13 the DG describes the analyses required to match the
14 same requirements that were in those that were
15 accepted. So for instance, in Option 3 under aging
16 management, perform alternate evaluations, is
17 basically doing the same kind of thing, in developing
18 the goal and developing these management programs,
19 that was done as part of the license renewal or
20 subsequent license renewal process.

21 On the other side, if a plant doesn't have
22 leak before break analysis, they have the option to do
23 a probabilistic fracture mechanics analysis or a
24 deterministic style LBB type of analysis which has all
25 of the rules in the DG that they need to follow. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the process was set up to be able to do that to allow
2 them to leverage those programs without doing any
3 additional analysis.

4 As you'll notice at the very bottom is
5 developing an inspection sample. I'll go into that in
6 a little bit more detail, and the goal of that and the
7 gains that are brought forward because of that
8 requirement. So in the next few slides, I'll go
9 through some of these details.

10 So next slide, please. So again, before
11 NUREG-1829, aging management, leak detection, and
12 plant-specific attributes are the main things that
13 need to be examined and strengthened.

14 For aging management, again, there's three
15 options. In the draft guide, to be able to read that,
16 first one is you can take credit for a license renewal
17 or subsequent license renewal approval if your plant
18 has that.

19 If you've submitted license renewal but have
20 not been approved, you adopt the relevant aging
21 management programs that are in your submittal that
22 would meet that -- that would show applicability.

23 And if you don't have either of those, then
24 you have to demonstrate that the Part 54 requirements
25 are met for the applicable primary loop piping or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reactor coolant pressure valve components.

2 For leak detection, again, there's a couple
3 of options. The first is to demonstrate adherence to
4 REG Guide 145 which most plants have done. Or if they
5 haven't done that, then they can demonstrate
6 compliance with JAC 30 and 50.46a(d)(ii) criteria.

7 The plant-specific attributes, which I'll
8 talk about in more detail in the next slide, ensure
9 that the piping attributes are acceptable. And if you
10 are a new plant, which is one that's licensed after
11 December of 2015, you've got to conduct these
12 component evaluations to demonstrate that things are
13 similar. And then you have to develop this acceptable
14 risk-informed primary loop piping inspection sample.

15 Okay, let's go to the next slide. All
16 right, so for the plant-specific attributes, again,
17 before I get started on this I've got to make the
18 comment that this slide was modified just recently, I
19 believe, just a day or two ago. And so, the version
20 that you may have had did not have -- might not have
21 this. But it's been updated in public ADAMS and such
22 like that. So I just wanted to make that clear.

23 For the PLP attribute evaluation there are
24 three options in the draft guide. The first is to
25 credit existing LBB programs or conduct a new LBB

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 evaluation. If the plant decides not to do that, then
2 they conduct a PFM evaluation. And the details of how
3 to do that in the acceptance criteria are in the DG.

4 Or they can do those identifying attributes
5 and conduct a more deterministic analysis which,
6 again, the details and the acceptance criteria are in
7 the DG.

8 If they're a new plant, they have to
9 identify the unique plant-specific attributes and
10 assess whether those impacts to those differences
11 occur at all on the TBS applicability.

12 And finally, this risk informed inspection
13 sample, the rule calls for ten percent of similar
14 metal piping welds in PWRs or IGSCC Category 4 welds,
15 that PWRs with diameters greater than the TBS be
16 inspected periodically.

17 We also allow in the rule the option to
18 leverage ongoing inspection programs so that if a
19 plant is able, they can move their inspections around
20 and not require any new inspections to meet this
21 particular rule.

22 And again, the highest failure potential
23 welds need to be chosen. The advantage of these welds
24 are twofold -- the advantage of these inspections are
25 twofold.

1 First of all, for the analyses conducted in
2 1829, which are typically fracture mechanics type-
3 based analyses that use assumed criteria, assumed
4 craft mechanisms, and such, it allows us be able to
5 continually monitor those particular welds that were
6 used in the basis for 1829.

7 Like I mentioned earlier, it becomes kind of
8 our performance monitoring to be able to make sure
9 that the analyses conducted don't change and that
10 there's nothing impacting those particular pipes that
11 may not be part of -- may not have had inspections in
12 the past.

13 It also allows us to leverage greatly in the
14 1903 analysis, which Se-Kwon will talk about later,
15 that allows us to leverage those inspections to remove
16 any additional analyses for the seismic analyses also.
17 And Se-Kwon will talk about that in a bit.

18 So the advantage is twofold. And the hope
19 for these analyses is that no really additional
20 inspections will have to be performed, that the
21 industry will be able to revamp the risk-informed
22 programs to include these particular welds in their
23 program.

24 I should point out that these particular
25 welds are in a risk informed category right now. And

1 there are ongoing efforts and code to change the
2 inspection requirements of that particular category.

3 And we want to ensure that those particular
4 high failure potential welds remain inspected through
5 the course of the plant life that are using this
6 particular --

7 CHAIR BALLINGER: This is Ron Ballinger
8 again. You may not know the answer. I'll maybe ask
9 the same question this afternoon. But how many of the
10 plants -- where would the plants that currently exist,
11 is there a map that puts them somewhere in those block
12 diagrams?

13 MR. RUDLAND: Yes. They have. I'm sure
14 they have.

15 CHAIR BALLINGER: The inspections you're
16 talking about?

17 MR. RUDLAND: Overall 1829 -- Yeah, yeah,
18 yeah, yeah.

19 CHAIR BALLINGER: Or you know which plants
20 where they sit?

21 MR. RUDLAND: For the most part. I know
22 that all of the, all of the PWRs have approved LBB
23 programs, for instance. None of the BWRs, and we know
24 that. Every plant except for one have a license
25 renewal and, yeah, that one is coming in. So, I know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 where all the plants are.

2 I know that all the plants have taken the
3 leak rate detection reg guide and incorporated that in
4 their plants. So, I know that most of the plants will
5 be able to easily sift through these flowcharts
6 without doing additional analysis.

7 CHAIR BALLINGER: Okay. So that where is
8 the hard point?

9 MR. RUDLAND: The hard point is that I don't
10 know for sure. I don't know exactly.

11 CHAIR BALLINGER: Before, the inspection
12 sample was the hard point.

13 MR. RUDLAND: Well, the hard point is also
14 that I don't know exactly where these welds fall in
15 their risk-informed inspection programs. So, the
16 category that I talked about consists of all of the
17 stainless steel welds in the reactor coolant, not just
18 the ones rated in the TBS.

19 I don't know if plants are inspecting these
20 welds as part of their programs, for instance. Some
21 may, some may not. Some plants may be doing these
22 inspections and so there's no additional burden
23 whatsoever. Some plants might be doing zero of these
24 sets.

25 CHAIR BALLINGER: That's what I'm trying to

1 get at.

2 MR. RUDLAND: I don't know.

3 MR. TREGONING: We don't know, we don't know
4 that. That's not something we know.

5 MR. RUDLAND: That's why we want to make
6 sure that we gave them the opportunity to leverage
7 their programs and modify their programs to include
8 these welds, if possible.

9 CHAIR BALLINGER: Thank you.

10 MR. RUDLAND: The goal, again, is not to
11 impose new inspections on the issue. That's not,
12 that's not the goal. The goal, again, is to let them
13 leverage their programs, but we still want to be able
14 to performance monitor those welds we think are most
15 important for defining what this TBS is.

16 Okay. If there's nothing else, I think
17 that's about all I'm going to say about 1829.

18 I'm going to turn the floor over to Se-Kwon
19 who is going to talk about 1903.

20 MR. JUNG: Thank you.

21 (Audio malfunction.)

22 MR. JUNG: -- progress covering the plant-
23 specific applicability of the NUREG-1903 analysis
24 results.

25 The outline of the presentations is as

1 follows:

2 First, I will talk about acceptable methods
3 for conducting analysis of direct flawed piping
4 failure. This includes discussion of general
5 approach, limiting locations selection, applicability
6 demonstration through inservice inspection program,
7 component stress determination, material properties
8 selection, and surface flaw analysis.

9 Then I will discuss acceptable methods for
10 the analysis of seismic risk associated with indirect
11 seismic failures.

12 Next slide, please.

13 The flowchart on this slide is showing the
14 general approach taken for direct flawed piping
15 analysis.

16 As shown in that first top box on the left
17 slide of the slide, the approach starts with
18 establishing the analysis scope by identifying what
19 piping systems, what locations have an inner diameter
20 that is greater than transition break size.

21 This is followed by determining limiting
22 locations within in-scope primary piping for the
23 remaining steps of the analysis.

24 For each of the new locations there are two
25 possible actions. There are pathways available to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 demonstrate the applicability of the NUREG-1903
2 analysis results.

3 Someone is talking. Can you press them on
4 mute, please.

5 CHAIR BALLINGER: We're getting some
6 feedback somewhere.

7 MR. JUNG: Yeah.

8 Thank you. Appreciate that.

9 So, again, for each of the limiting
10 locations there are two possible options or pathways
11 available to demonstrate the applicability of the
12 NUREG-1903 analysis results. It depends on whether
13 the selected limiting locations are part of the
14 existing inservice inspection program or not.

15 If the limiting location is part of the
16 existing inservice inspection program, the approach is
17 greatly simplified.

18 As shown on the leftside branch of the
19 slide, the only remaining step is to check whether the
20 limiting location meets the requirements of the ASME
21 Section XI IWB-3500 or 3600.

22 If these requirements are met, then NUREG-
23 1903 results are directly applicable to the limiting
24 location of interest, and no new analyses are
25 required. This will significantly reduce the amount

1 of time and efforts for the entity, for applicant to
2 demonstrate the applicability of the NUREG-1903
3 analysis results.

4 We anticipate that many entities or
5 licensees will take advantage of this option by
6 passing through that analysis.

7 However, if the IWB-3500 or 3600 parameters
8 are not met, or the limiting location is not part of
9 the existing inservice inspection program, more
10 detailed analyses are required, as shown on the
11 rightside branch of this slide.

12 This includes determination of component
13 stresses, material properties, and conducting either
14 a deterministic analysis or best estimate
15 probabilistic pressure mechanics analysis, as shown on
16 this chart.

17 In subsequent slides I'm going to discuss
18 each of these areas discussed in more detail.

19 Next slide, please.

20 Limiting locations selections. As mentioned
21 in the previous slide, for all piping system locations
22 having an inner diameter greater than the transition
23 break size we should find all limiting locations that
24 are represented by combinations of high component
25 stress and low material fracture toughness. We also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 account for aging effects over the licensing period.

2 Susceptibility to service-induced cracking
3 is another consideration.

4 Multiple limiting locations may need to be
5 delineated if the limiting location is not obvious.

6 The key requirement in the selection of
7 limiting location is the entity or licensee should
8 strive to include all limiting locations in the
9 inservice inspection program.

10 Next slide, please.

11 Operators looked at the demonstration
12 through inservice inspection program. As mentioned
13 earlier, for those limiting locations that are part of
14 the existing inservice inspection program the plant-
15 specific acceptability of the NUREG-1903 results can
16 be demonstrated through the successful application of
17 the program.

18 In other words, no other variation of
19 analysis is required if there are no new or
20 preexisting indications larger than the ASME Section
21 XI IWB-3500 acceptance criteria.

22 Next slide, please.

23 However, if significant limitations
24 exceeding the IWB-3500 acceptance criteria exists,
25 additional analyses are required to demonstrate their

1 acceptability by performing an analytical evaluation
2 of flaws for IWB-3600.

3 Obviously, if the limiting locations are not
4 part of the existing inservice inspection program,
5 then analyses must be used to demonstrate the
6 applicability of NUREG-1903.

7 Next slide, please.

8 Component stress determination:

9 For limiting locations not part of the
10 existing inservice inspection program, the next test
11 is to determine component stresses used in the
12 subsequent steps of the analysis. There are three
13 possible options:

14 Option 1 is to use the NUREG-1903 results.
15 This option is available for entities whose plans were
16 analyzed in NUREG-1903 considering the following three
17 conditions are met.

18 The first condition is that the critical
19 piping locations reported in the plant's leak-before-
20 break submittal are applicable, after accounting for
21 cracking susceptibility and as related to toughness
22 degradation at these locations.

23 The normal operating and the safe shutdown
24 earthquake stresses in the leak-before-break analysis
25 are either accurate or conservative at these limiting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 locations.

2 And the third condition is the site-specific
3 hazard curve. And we know from hazard spectrum
4 contained in the current specific sizing hazard and
5 report are either conservative or represented by the
6 applicable sizing hazard curve within the NUREG-1903.

7 If these are conditions are satisfied, the
8 entity or licensee can use the plant-specific total
9 stresses developed in the NUREG-1903 analysis through
10 the remainder of this analysis.

11 Option 2 is to use the NUREG-1903 scale
12 factor method. This option uses the scale factor
13 method described in the NUREG-1903 to determine the
14 total component stresses at each limiting location.

15 The entity should first develop seismic
16 hazard information, as mentioned earlier, by
17 determining site-specific seismic hazard curve. And
18 we know from hazard spectrum using the current seismic
19 hazard screening report information tied out to 10 to
20 minus 6 probability resiliency.

21 Next, at each limiting location the entity
22 should determine the axially oriented, normal
23 operating and safe-shutdown earthquake stresses for
24 service level A and D respectively.

25 Finally, the entity should extrapolate the

1 SSE or safe-shutdown earthquake stresses to seismic
2 stresses representative of the 10 to minus 6
3 probability of exceedancy.

4 Option 3 is the most accurate option as it
5 requires direct seismic response analysis. But, at
6 the same time, the most complicated and time consuming
7 approach.

8 For this analysis the entity should first
9 determine the axially-oriented owner operating
10 stresses at the limiting locations.

11 Then the entity should determine
12 seismically-induced component stresses by completing
13 following tests:

14 First, develop an updated representative
15 site-specific hazard curve and ground motion hazard
16 spectrum for the 10 to minus 6 probability of
17 exceedancy based on the latest seismic hazard
18 information.

19 Then model the site-specific foundation
20 properties corresponding to 10 to minus 6 seismic
21 hazard curve.

22 And then construct a reactor building
23 dynamic model, including all major structures and also
24 anti-blast systems.

25 And then perform a soil structure

1 interaction analysis for the given site on seismic
2 motion using applicable soil, rock and structure
3 models.

4 And, finally, also we need to address
5 modeling and input uncertainties and the effects on
6 the primary piping stress at the limiting locations.

7 Next slide, please.

8 For determination of material properties,
9 one acceptable approach is to use the properties
10 associated with either the conservative base and well
11 materials, or stainless steel submerged aqueal
12 materials used in NUREG-1903 by demonstrating that
13 these properties are conservative or representative of
14 actual plant-specific properties at the limiting
15 locations.

16 Alternatively, the entity or licensee can
17 develop representative or conservative plant-specific
18 material properties based on ASME code, generic, or
19 measured properties.

20 The acceptability of the NUREG-1903
21 properties or the appropriateness of the developed
22 properties can be demonstrated by accomplishing the
23 following three steps:

24 First, account for any age-related
25 degradation of strengths, toughness, and, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 applicable, crack growth rate properties;

2 Second, considering effects on these
3 material properties caused by the elevated loading
4 rates associated with a seismic event, and;

5 Third, assess the effects of uncertainty and
6 variability on the material properties.

7 Next slide, please.

8 Once component strengths of the material
9 properties are determined, there are three options for
10 surface flaw analysis.

11 The first two options are deterministic, and
12 the third option is probabilistic.

13 Option 1 or the first deterministic analysis
14 option is bounding analysis.

15 This option directly utilizes NUREG-1903
16 results if the material properties used in NUREG-1903
17 appropriately represent plant-specific material
18 properties.

19 And the axially oriented combined normal
20 stresses plus 1 to the minus 6 stress.

21 Proper consideration of seismic stress
22 factor and elastic stress factor, if the stress is
23 less than 35 ksi.

24 Option 2 is the second deterministic option.
25 It's perform plant-specific deterministic analysis, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the full stress is greater than 35 ksi or if plant-
2 specific material properties are not appropriately
3 bounding or representative of the NUREG-1903 material
4 properties.

5 This analysis utilizes plant-specific
6 material properties and stresses with appropriate
7 consideration of plasticity correction factor to
8 account for plasticity within components on the
9 seismic loading.

10 A critical flaw depth is calculated using
11 the corrected limit load analysis or a Z-factor
12 approach or elastic plastic mechanics using a long
13 surface flaw lengths of 80 percent of the component
14 circumference, which is quite conservative.

15 If the critical flaw depth exceeds 25
16 percent of the wall thickness at each limiting
17 location, then NUREG-1903 results are directly
18 applicable to the plant.

19 Next slide, please.

20 The third and most sophisticated option is
21 to perform a plant-specific probabilistic fraction
22 mechanics analysis.

23 As shown on this left side of the slide,
24 this probabilistic analysis should be consistent with
25 Reg Guide 1.245. This is concerned with preparing

1 probabilistic fraction mechanics summaries.

2 And the acceptable probabilistic fraction
3 mechanics analysis should include the following six
4 considerations:

5 First, the analysis for the limiting
6 locations should be determined following that of the
7 deterministic analysis as described previously;

8 Second, an applied stress distribution
9 should be developed for each limiting location. One
10 of the three options described previously to develop
11 component stresses for the deterministic analysis can
12 be used to pick out the mean value of this
13 distribution;

14 Third, the analysis should use property
15 distributions for key analytical parameters such as
16 material strengths, crack growth rate associated with
17 the applicable degradation mechanisms, and fracture
18 toughness;

19 Fourth, the analysis should assume an
20 initial flaw distribution based on either known flaw
21 distribution or distribution corresponding to the flaw
22 detectability size from the non-destructive
23 determination method;

24 Fifth, the analysis should select an
25 appropriate failure criterion, such as defective

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 criterion or failure criteria such as failure
2 assessment diagram or inherent instability;

3 The sixth consideration is the analysis
4 should apply applicable leak detection limits with a
5 known uncertainty.

6 Taking all these six considerations
7 together, the analysis should be run up to 80 years.
8 And this guidance recommends that the resulting mean
9 failure probability of the piping system contained in
10 the limiting locations should be less than 1 minus
11 six. This is to ensure that it does not inadvertently
12 contribute to the overall total LOCA risk.

13 In addition, as shown on the right-side of
14 this slide, this guidance recommends performing a
15 series of sensitivity analysis studies for key
16 analytical parameters such as seismic stress and flaw
17 lengths distributions, as well as other key parameters
18 that may significantly affect the analysis results in
19 accordance with Reg Guide 1.245.

20 In addition, recommendations of limiting the
21 resulting probability of failure increased no more
22 than two orders of magnitude.

23 Next slide, please.

24 Seismically induced risk of indirect
25 component failures.

1 The original NUREG-1903 study results, as
2 well as the recent evaluation study results have shown
3 that the seismic risk associated with primary low
4 piping failure is dominated by indirect component
5 failures leading to piping failure.

6 Acceptable methods for this mode of piping
7 failure should consider most up-to-date plant-specific
8 seismic hazard information;

9 Plant-specific component and support
10 fragilities;

11 And the effects of age-related degradation
12 on these fragilities.

13 This analysis can be performed in a graded
14 manner:

15 First, the most sophisticated approach is to
16 develop the first seismic PRA that complies with Reg
17 Guide 1.200.

18 Typically, the assessment of the seismic
19 risk associated with the indirect piping failure
20 leading to LOCA scenarios should be part of this
21 analysis.

22 Additional guidance and acceptable
23 guidelines performing risk-informed evaluation of the
24 indirect piping failures are described at DG-1426.

25 Last, the request compared to seismic PRA

1 are more efficient and simplified acceptable
2 approaches available such as seismic margin assessment
3 to perform the same analysis, if that analysis is
4 appropriately justified.

5 This concludes my portion of the
6 presentation. And then I'll turn it over to Robert.

7 CHAIR BALLINGER: This is Ron Ballinger
8 again.

9 My memory is a little bit fuzzy, but
10 recently the plants were asked to reevaluate the
11 seismic risk based on the new GMRS some time -- I
12 forget how many years. That being the case, would
13 that evaluation satisfy 1903?

14 I don't know. I'm just saying some analysis
15 had to be done as a result of that new ground motion
16 response spectrum.

17 MR. JUNG: Yes. As part of this reg guide
18 development we evaluated the effects of updating
19 seismic measures on the results of NUREG-1903. And I
20 presented the results in the last month's
21 presentation.

22 Basically, overall the seismic risk
23 associated with the indirect piping failure were all
24 generally less than 1 to minus 5. That was the high
25 level conclusion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. TREGONING: So, that would be part.
2 That would be part of what would be required in the
3 analysis. So, they would leverage -- Rob Tregoning
4 again from the staff. Sorry.

5 So, yes, that would be part of the analysis.

6 I want to, I want to sort of harken back to
7 one of Bob's earlier points when he asked, you know,
8 how much work have you done in this area since, you
9 know, the early two thousand naughts?

10 And as Dave articulated, we, we've done a
11 lot of work that's given us more insights in terms of
12 what we studied, in terms of LOCA frequencies in 1829,
13 and applicability with respect to TBS.

14 But these analyses of direct piping failures
15 due to rare seismic events, that's not something we've
16 done any additional work on since NUREG-1903 was out.

17 And NUREG-19 -- and seismic evaluations,
18 NUREG-1829 can be a generic evaluation for developing
19 LOCA frequencies makes sense. Can't say anything
20 generic about seismicity and seismic sensitivity.
21 It's a very -- it's entirely plant specific.

22 So, when we developed 1903 we used the best
23 available plant-specific information that we had to
24 date, 26 PWRs. But that used seismic hazard curves
25 from, I think '97, which at the time was the most

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 recent, but even when we did 1903, plants, we knew
2 plants were in the midst of re-doing their seismic
3 hazard curves.

4 And then we used the best available material
5 information that we had and some loading information
6 we had from LBB submittals. But even those were
7 dated. A lot of those LBB submittals were from, you
8 know, the Nineties.

9 So, you know, there was a recognition at the
10 time that -- you know, and this is my opinion -- you
11 know, that we think this is an area that if there was
12 some more technical work done using up-to-date plant-
13 specific information, that would really go a long way
14 in addressing this applicability.

15 And to get to Ron's point of, well, how many
16 plants fall into different bins, you know, we set the
17 DG-1428 for demonstrating 1903 applicability. It's a
18 graded approach; right?

19 If you pick the simplest option, you just
20 have to demonstrate that the analysis that was already
21 done for your plant for 1903 remains bounding. Right?

22 You have to say, oh, the stresses that they
23 used in 1903 were higher than my stresses with my
24 revised seismic hazard curves. And the material
25 properties that they used either bound or represent my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 material properties, so I'm good.

2 So, that's one step.

3 But then, you know, if you can't, if you
4 can't do that, then there's another step which is to
5 use the scale factor method. So, you actually go
6 through the 1903 analysis but use all your plant-
7 specific inputs for doing that analysis. And then
8 that's another way to demonstrate applicability.

9 And then the third way is, well, if I don't
10 want to do either one of those, I've got to do a
11 complete plant model and develop my stresses from the
12 ground up. And that's, that's onerous, but that's an
13 option.

14 And then the fourth option is this
15 probabilistic fracture mechanics analysis. Because
16 1903 only looked at -- it's only a deterministic
17 analysis.

18 So, there's a recognition that while we were
19 able to simply DG-1428, even quite significantly to
20 deal with the NUREG-1829 applicability question, we
21 weren't able to do as much simplification to deal with
22 the NUREG-1903 applicability question just because
23 looking at piping, looking at degraded piping
24 fragilities under rare seismic events is just not a
25 topic that we really looked at more extensively since

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 we did it in the mid-2000s.

2 So, that's, that's some --

3 MR. RUDLAND: I can also add which is why we
4 -- why they put the option is that they can include
5 those limiting welds in their ISI program, then they
6 don't have to do any of this.

7 MR. TREGONING: Right. So, you can inspect
8 your way out.

9 MR. JUNG: Yeah. And that's why the
10 analysis studies done originally in NUREG-1903 were
11 kind of representative. And the results show that
12 indirect seismic failure was one zero of 10 to minus
13 6.

14 However, due to the seismic hazard updates
15 since then, we recognize that the risk would be hard
16 to compare. And we performed, actually,
17 representative, you know, analysis considering the
18 seismic hazard and the results have shown that overall
19 most of the plants in the United States, in the
20 central part of the United States, their indirect
21 piping failures would be less than the transition
22 break size. That was the conclusion.

23 But that analysis used actually represents
24 -- representative component seismic fragilities. So,
25 that needs to be confirmed by some sort of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 considerations.

2 MEMBER MARTIN: And I'm going -- this is Bob
3 Martin -- I'm going to show my ignorance, I'm not a
4 seismic person per se -- but what I understand with
5 1903 that's kind of different from the past, it's all,
6 it's past referring to existing inservice inspections
7 which I focus more on stress versus cracking, you
8 know, like, like topics. Should we bring in more of
9 the seismic failure analysis and at the same time
10 we're saying it's risk informed and we'll be looking
11 at events, loads that go down to 10 to the minus 6.

12 It's really kind of back to, to Greg's
13 question, why don't we, you know, under risk informed
14 you might say 10 to the minus 4 events, which of
15 course mean it's under TBS type events. It almost
16 seems deterministic, except where we stick a number 10
17 to the minus 6, one in a million.

18 It seems like it's a misnomer almost to say
19 10 to the minus 6 other than the fact that, you know,
20 we can put a number on it and we're not going to look
21 at, you know, 10 to the minus 8. I'm not sure what's
22 different than a deterministic approach. You just
23 kind of slap a --

24 MR. TREGONING: Oh, right. We're not
25 subtracting; right. If you use the 10 to the minus 6

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 seismic hazard --

2 MEMBER MARTIN: Really for everything --

3 MR. TREGONING: Yes.

4 MEMBER MARTIN: But what do you do, there's
5 no relaxation, no graded approach.

6 Now, this is the kind of things. I've been
7 looking. You know, we've all been asked to bring in
8 more risk informed insights into this sort of stuff.
9 And here we go, I think we're almost adding a little
10 bit more than what we've always been doing.

11 And, you know, I'm not someone to make -- I
12 mean, I guess I am on this committee making a
13 recommendation -- but I'm not the lead person on this,
14 you know, Ron is. But it's a challenge dealing with
15 the stakeholders on both sides here, really it's
16 pinched.

17 MR. RUDLAND: And, again, I had to give as
18 many options as possible so that a deterministic
19 analysis is an opinion. They can do probabilistic
20 analyses as an option. They can do the inspections as
21 an option.

22 So, they have a variety of different options
23 to choose from. Whatever --

24 MEMBER MARTIN: Well, true. Obviously
25 you've elevated a couple options here. But the two

1 NUREGs, and of course you had the slide earlier where,
2 you know, you, you had the stakeholder, the industry
3 stakeholder engagement and you pick Option 2. And I
4 don't think everyone here is, you know, completely a
5 fan.

6 But, of course, as you know, you opened the
7 door for other options. I just wonder if we don't
8 find ourselves in a position to say -- and this is
9 just opinion by one member -- but why not have, like,
10 we originally did with Reg Guide 183 where, I'll say
11 it aloud, we kind of held our nose to Reg 1 and said
12 get to Reg 2. I mean, we may find ourselves in a
13 situation here where, you know, Reg 0 is an
14 improvement.

15 But maybe we need to, you know, you might
16 recommend that we continue and get to a better place
17 with more insight. And maybe requires more research,
18 or more engagement, or something, but they still seem
19 burdened which may not be completely justified under
20 the umbrella of risk informed.

21 But there's some just skepticism as more of
22 a comment than a question.

23 CHAIR BALLINGER: I think I need to make
24 sure that we understand that this is a draft guide
25 that it's recent, let the cat out of the bag, if you

1 will, about workshops and the like. So, that the
2 final rule that goes out for public comment is a ways
3 away. And there's a fair amount of work to be done.

4 MR. RUDLAND: Yes. And, again, like I
5 mentioned, the staff tried the best we could to
6 provide as many options as we could in a risk-informed
7 manner to be able to meet this. It wasn't like, it
8 wasn't like -- like the, like the requirement or a
9 recommendation. And again, the DG was always to be a
10 sophisticated deterministic seismic analysis. Right?
11 We wanted to make sure.

12 But, again, the inspection of these pipes
13 that we're talking about are risk significant pipes.
14 Right? We're not talking about insignificantly risk
15 -- insignificant risk pipings we're talking about.
16 We're talking about the reactor coolant piping; right?
17 So, it's highly risk-significant.

18 So, we have to make sure that we are -- that
19 we maintain the stability and the integrity of those,
20 those pipings throughout.

21 MEMBER MARTIN: But it's not like we don't
22 do anything now.

23 MR. RUDLAND: No, that's right. Right.

24 MEMBER MARTIN: The addition of the seismic
25 failure analysis --

1 MR. RUDLAND: That's exactly why we have the
2 inspection path. And, hopefully, it's not any large
3 additional burden so that, you know, that they're able
4 to cover that. You can't analyze it for seismic
5 things and use factors.

6 MEMBER MARTIN: In criticisms I'm sure you
7 heard it, but, yeah, anything new like this will
8 appear very academic; right? And, you know, been in
9 the industry long enough that it just ruffles
10 feathers, you know.

11 Now, in many cases I think, you have a
12 point, we're applied science here. There is an
13 academic element and there are, you know, we've seen
14 it integrated in, you know, 50.46 already to some
15 extent. So, this is in addition. And at some point
16 it's just what is enough?

17 And that's I think what ruled risk-informed
18 in the first place is to come to some sort of
19 consensus on how we have to judge that. And, yet,
20 we'll still debate the uncertainties for that sort of
21 thing.

22 MR. RUDLAND: And regulatory guides are only
23 one way of doing that, so. That's the other thing.
24 So, there may be other methods that we come up with
25 during the public comment period or after the fact.

1 VICE CHAIR HALNON: This is Greg.

2 And I realize it's blasphemous to say don't
3 worry about large break LOCAs anymore. I think we're
4 having a hard time letting go, even though everything
5 I've heard hasn't really convinced me that we need to
6 do anything but let go, in addition to any kind of
7 process on top of something and the work is more. It
8 doesn't mean we get less, unless we eliminate, that's
9 when it gets less.

10 But since I'm not an expert in materials or,
11 you know, I'm an operator. So, I always look at it
12 from a perspective is in the control room what
13 difference is this going to make to me operating the
14 plant? I mean, that's what I'm going to be listening
15 for throughout the day here.

16 Right now they've been tying up my engineers
17 doing a lot of work, inspections and analysis. I
18 don't see anything that's of value yet to the
19 operator.

20 So, and I realize that this is a design
21 space and whatnot, but I just wanted to say I
22 understand the seriousness of safety significance of
23 piping. I was at V.C. Summer with the hot leg crack.
24 I get it. And it still was complementary to this in
25 the fact that we're still worried about our break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 LOCAs.

2 And I just want to continue as you go
3 through today and tomorrow, and continue to discuss
4 it, help me understand what value, benefit to the
5 operators I'm going to see. We're talking about more
6 margin, operating margin, more margin here, more
7 margin there, but that's in design space.

8 MR. RUDLAND: I think we, you know, in
9 December talked considerably about what advantages
10 come with approval of this rule. And we could go
11 through those details again this afternoon or
12 tomorrow.

13 VICE CHAIR HALNON: Yeah. We asked for an
14 overview. What does this mean? And I think that
15 we're going to catch that later this afternoon.

16 So, I'll ask the same question again to get
17 it clear in my mind that to give you the reason I'm
18 asking these questions, like, I'm not trying to push
19 you to ignore large break LOCAs.

20 CHAIR BALLINGER: I keep trying to figure
21 out how many of the plants would check the box "done"
22 and not have to do anything?

23 MR. RUDLAND: Again, the inspections are the
24 ones that are -- that I'm unsure about, that we need
25 feedback from, from the industry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER HARRINGTON: This is Greg Harrington.

2 Just both paths, 1829 and 1903, involve some
3 determination of limiting locations. How similar and
4 how different are the criteria for those limiting
5 locations?

6 And in the draft guide they're talked about
7 entirely separately.

8 MR. RUDLAND: Overall I think the topics are
9 similar. But I think the systems that we're talking
10 about, stress, material degradation, are all going to
11 be about the same.

12 So, I would suspect that the limiting
13 locations for 1903 would be the same as what we're
14 talking about 1829.

15 MR. TREGONING: The only way they wouldn't
16 is if you had some location that is susceptible to
17 some very large seismic stress at a well, just because
18 of where it was located within the piping system.

19 That would be the only distinction
20 characteristic that I can envision that would lead to
21 a different limiting location for sort of the 1829
22 versus the 1903 analysis.

23 MR. RUDLAND: But, again, we're talking
24 about, like, for BWRs the hot light and the cold
25 light. And those designs are different. There are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 some plants I guess they have some valves that hang
2 off the steam generator, and stuff like that, and may
3 impact the seismic behavior. But most of the time
4 these are very straight, uniform sections of pipe.
5 They're not going to be unique for the seismic.

6 VICE CHAIR HALNON: That's sort of where my
7 head was at when I was reading this. And, yet, it
8 seemed like, you know, like there was no, no
9 connection between the two. And that seemed like an
10 improvement that could be built into the draft guide
11 to bring those together and note that there may be
12 limited differences, but.

13 MR. RUDLAND: And I agree with that. The
14 problem is that we're not necessarily privy to all the
15 design seismic impacts on all the different plants.
16 It would take, you know, an effort maybe for industry
17 to be able to pull all that information together to
18 make that determination.

19 CHAIR BALLINGER: Even these oddball plants,
20 as you call them, with the valve hanging off
21 somewhere, they've had to do a seismic analysis --

22 MR. RUDLAND: Yes.

23 CHAIR BALLINGER: -- to start with.

24 MR. RUDLAND: Yes, yes.

25 They necessarily had to do a crack type

1 analysis; right? They had to do some kind of design
2 analysis, yes. They've done fragility analysis.

3 CHAIR BALLINGER: Fragility, sure.

4 MR. RUDLAND: But usually those fragilities
5 do not consider, you know, possibility of reasonably-
6 sized cracks.

7 CHAIR BALLINGER: Yeah, I keep coming back
8 that those welds were mitigated.

9 MR. RUDLAND: Or if they're part of the
10 inspection programs, which I don't know, maybe they
11 are, maybe they aren't.

12 MEMBER HARRINGTON: Yeah, but not all the
13 welds need to be mitigated. If there's no known
14 degradation in the mechanism appropriate for that, why
15 would you mitigate?

16 CHAIR BALLINGER: And then they would need
17 --

18 MEMBER HARRINGTON: Yeah.

19 CHAIR BALLINGER: -- you know, a similar
20 metal weld.

21 MEMBER HARRINGTON: No. Or we know they
22 should --

23 MR. TREGONING: So, I just want to get back
24 to Bob's point about and why we're even doing this.
25 Right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 The whole premise for 1903, and really the
2 essential question that we're trying to answer is we
3 want to make sure that the risk associated with large
4 break LOCA, which we already think is low, but we want
5 to make sure that it's bounded by the 1829 evaluation;
6 right?

7 Sort of that that risk is driven by the
8 things that we deal with every day in normal operation
9 mode. Because those are things that we have a better
10 handle on.

11 So, the whole premise is that, with 1903, is
12 then demonstrating that your plant's applicable to
13 1903, but if you do that you're able to demonstrate
14 conclusively the seismic risk is not a consideration.

15 So, that's, that's really the essential
16 question that we're trying to answer here. Just we're
17 trying to have a demonstration you don't have to worry
18 about effect due to these relatively rare 1 to the
19 minus 4, the 1 to the minus 6, whatever number you
20 want to put on it, but that these rare larger seismic
21 loads that are above the safe shutdown or it's played
22 through ESSC loading that's part of the design basis
23 already.

24 So, that's, that's the question we're trying
25 to answer. Yes, we want to do it in a way that plants

1 can answer it with a minimal amount of burden.

2 So that's, and that's -- you said, did we
3 get that right? Well, probably not. But that's,
4 that's the objective.

5 Okay. I don't know, can we move on?

6 I guess I'm on.

7 All right. So, I'm going to talk about the
8 last facet of 1829 -- or DG-1829? Got that on the
9 brain.

10 DG-1428, right, there's three pieces of it:
11 1829 applicability, 1903 applicability, and then
12 making sure that when you do plant changes they don't
13 invalidate any of those previous invalidities.

14 Now, the thing that we struggled with with
15 plant changes is 50.46a is a very broad rule. But you
16 can make any change to the plant as long as you can
17 demonstrate that you meet the change criteria. So,
18 basically, through the PRA requirements that are
19 detailed in the rule itself. And then what we talked
20 about in December in 1426.

21 So, there's a broad suite of changes that
22 can be made. And there's a recognition that the large
23 majority of this, those changes will have nothing to
24 do whatsoever with the 1829 or the 1903 analyses.

25 If you're going to change your diesel

1 generator maintenance requirements, and you're allowed
2 to do that because of this rule, it has no bearing
3 whatsoever on the 1829 or the 1903 analysis; right?

4 So, that's, that's this trouble.

5 However, you could do other things; right?
6 You could incorporate, you could go in for something
7 like a power uprate. You could maybe increase my
8 operating temperatures. You could increase flow
9 rates.

10 And those things may potentially have an
11 impact.

12 So, when we were trying to figure out how to
13 assess plant changes, just recognize that it's
14 challenged by the fact that, you know, under 50.46a
15 there's really no limit, other than from a risk
16 perspective, the types of changes that can be made.

17 So, the hope would be that if your changes,
18 if any of the changes aren't applicable to those 1829
19 or 1903 analyses, then that's the extent of your plant
20 change evaluation. Basically, you document that and
21 say this is why there's no impact. And then you move
22 on.

23 But then we also tried to accommodate the
24 fact that, well, some plant changes might have an
25 impact. And the thing that we leaned on the most --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 and I think you'll see that in the guidance -- is we
2 said, well, what, what is the biggest possible change
3 that we think that a plant could make under this rule
4 that we would need to be worried about?

5 And then, you know, we sort of settled on
6 power uprates. That was something in 50.46a that, you
7 know, we knew a lot of plants could get benefits out
8 of that. If we do power uprates, if there was
9 anything that was going to have an impact on, you
10 know, LOCA frequencies it could be power uprates.

11 So, we modeled a lot of the plant change
12 guidance on existing guidance that's in place for
13 reviewing power uprates.

14 Now, look, if a plant's going to come in for
15 a power uprate they've got to come in separately for
16 that anyway. So, if they're coming in separately for
17 a power uprate, this wouldn't be a different analysis
18 that would be required. This would be part of that
19 analysis. At least that's how we would envision it.

20 But we tried to draw heavily and leverage
21 from that existing guidance in developing this
22 guidance. So, what we did when we looked at that, we
23 said, all right, let's look at those things in the
24 power uprate guidance that could affect the systems
25 that could lead to breaks greater than the TBS. Just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 recognize that the draft guidance only applies to
2 breaks in systems that are bigger than the TBS.
3 Everything else remains within the existing design
4 basis.

5 So, that's really -- and I don't want to go
6 through the flowchart. These flowcharts make it look,
7 I think sometimes, more complex than it is. But I'm
8 a visual person, so I like having the flowcharts so
9 that people can sort of peck their way to get through
10 this.

11 There's really a couple of different ways,
12 you know, this is the common theme, multiple different
13 ways to get through this guidance and demonstrate that
14 your plant change is okay. And it's no different with
15 this section of it.

16 We can do a direct evaluation that your
17 plant change doesn't upset anything that they did in
18 1829 in terms of any of the variables associated with
19 things that cause LOCA. And those things are
20 identified in these variables to consider block.

21 And those are also the same things that
22 would affect the 1903 evaluation in terms of your
23 plant's susceptibility to failure under a rare seismic
24 event.

25 So, you can directly assess the effects on

1 those, on those variables. Or you can, or you can use
2 this analysis using the review standard for extend
3 power uprate. And there might be a few specific
4 standard review plan areas that need to be addressed.

5 So, all of the boxes in this, in this
6 technical area to consider, those are all areas that
7 are covered by an existing standard review plan that
8 would be appropriate for systems that are greater than
9 the TBS.

10 So, that's one aspect of it, you know, for
11 evaluating effects on direct failure.

12 And then there's a couple of things to
13 consider for indirect failure. There's prior indirect
14 failure analyses that the plants already do or already
15 have in hand to demonstrate compliance with GDC-4.
16 And those are things like making sure that the systems
17 are adequately protected against missiles and dynamic
18 effects of fracture.

19 So, so those are things that already, you
20 know, these evaluations should already exist. And one
21 option is to make sure that you've done nothing to
22 call into question that existing basis as a result of
23 the plant change.

24 If you don't want to leverage your existing
25 analyses, you can also with indirect failures, as with

1 direct failures, do a more direct evaluation of how
2 your plant changes has affected some of the variables
3 that would make it more likely potentially to be
4 impacted by dynamic effects for missile protection.

5 So, that's the flowchart in essence.

6 Next slide, please.

7 I'll go through this in a little bit more
8 detail.

9 So, I think I've covered this. You know,
10 the whole point of this portion of the reg guide is
11 for plants to demonstrate that their changes do not,
12 or their proposed changes do not significantly
13 increase LOCA frequencies.

14 They have to consider both direct and
15 indirect failures.

16 And failures under not only normal load, but
17 then also these rare seismic loadings as in 1903
18 should be considered.

19 And then the other thing to take into
20 account, as with these other analyses, is to just make
21 sure that you're accounting for age-related
22 degradation.

23 And then, again, as part of 1426 they're
24 already required under the, under the current proposed
25 50.46a to do a risk-informed evaluation to demonstrate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that the plant changes don't significantly increase
2 LOCA frequencies.

3 Next slide, please.

4 So, in terms of plant changes and LOCA
5 frequencies, again they need to demonstrate that they
6 don't -- There's, sorry, a couple different options
7 here.

8 Again, and the whole purpose here is to
9 demonstrate that you have continued applicability to
10 both reg 1829 and 1903.

11 Option one is to directly evaluate the
12 effects of the change on those variables that are most
13 important that affect both the frequencies that are
14 articulated in 1829. And these are things like, you
15 know, did the change affect the plant materials, the
16 environment, the loading, degradation rates, the
17 geometry, and then either the maintenance or the
18 mitigation practices associated with that particular
19 system?

20 So, that's, you know, that's, those are some
21 of the -- those are the prime variables.

22 And then you want to make sure that you at
23 least assess if that change is going to introduce a
24 new degradation mechanism that maybe wasn't previously
25 in place.

1 And we've seen this in the past; right?
2 We've seen it where, you know, you've had power
3 uprates and they've induced vibrations in systems that
4 weren't there before.

5 And then you've had enhanced susceptibility
6 to fatigue, vibration fatigue.

7 So, it's all sorts of things that you want
8 to make sure that the plants are aware of, and you're
9 considering when, you know, when they're thinking
10 about implementing a particular change.

11 And then the other thing they have to do is
12 they have to assess to make sure that the performance
13 monitoring that they're doing on that system will
14 remain acceptable after the plant change. And then
15 they just have to describe what that performance
16 monitoring system is.

17 Again, if there's no changes to degradation
18 rate -- rates, or no new mechanisms, then they're no
19 reason that their performance monitoring that they're
20 doing already shouldn't remain effective.

21 The other option, if they don't want to look
22 at the direct effects on the NUREG-1829 variables, is
23 to sort of lean on that review standard for extended
24 power uprates.

25 And, again, we've sort of pulled out some of

1 the guidance that's already existing for conducting
2 these EPU's and reviewing them. But it's focusing on
3 those things that, again, that are -- that relate to
4 plant robustness against failures that are beyond the
5 TBS.

6 So, it's things like making sure your RPV
7 surveillance program's not affected, right; that your
8 P-T limits having been changed or modified any way;
9 that your upper shelf energy, PTS requirements, leak-
10 before-break, piping materials and supports, chemical
11 volume and control system, all of these things that,
12 you know, could affect susceptibility in these large
13 systems are not changed in any meaningful way.

14 And if you follow this option, you still
15 have to also assess and describe performance
16 monitoring.

17 CHAIR BALLINGER: So, again, this is Ron
18 Ballinger again. Plants that have done an EPU, PWRs,
19 they've already done this pretty much. In other
20 words, is the form any different?

21 MR. TREGONING: Well, again, again this
22 would only come into play if they're going to do, if
23 they're going to do another EPU that relies on this
24 new rule; right?

25 CHAIR BALLINGER: But it's the same -- are

1 you doing anything have to go against?

2 MR. TREGONING: No, no new guidance. Again,
3 we're trying to leverage existing guidance as much as
4 we can. They've talked about leveraging existing
5 programs, guidance. So, all of this is sort of
6 standard, you know, rote evaluation that they would
7 have done as part of an EPU.

8 Next slide, please.

9 Then with respect to 1903, this is similar
10 to the 1829 evaluation. They just have to verify that
11 they changes they don't have any impact on any
12 inspections that you're doing at limiting locations;

13 Making sure that the changes don't increase
14 the degradation rates.

15 And then you just have to verify that the
16 analyses that you did to demonstrate that the seismic
17 risk was acceptable is not, are not invalidated in any
18 sort of way, so that the stresses don't change.
19 Again, that the aging of the components doesn't get
20 worse, just to demonstrate that the analyses that you
21 did previously to demonstrate that your plant was
22 applicable for 1903 has not become, has not become
23 invalid.

24 Next slide.

25 And then, finally, then the last piece of it

1 is making sure that your indirect failure frequencies
2 haven't been impacted in any way. And, again, these
3 are largely governed already by the GDC-4
4 requirements.

5 And, so, really you just have to demonstrate
6 or document that you have continued adherence to GDC-
7 4; right? And there's, you know, GDC-4 talks about
8 dynamic effects as well as missile protection.

9 There's two options for doing this. You can
10 just demonstrate that your prior analyses were
11 unaffected by the plant changes that you're proposing;
12 and that your existing analyses remain sufficient.

13 Or, you can supplement those existing
14 analyses or conduct new analyses, if those are needed.
15 And there's existing guidance already in place if
16 that, you know, if that level of evaluation is
17 required for any sort of plant changes.

18 We've already talked about, Se-Kwon talked
19 about indirect seismic failure risk. That's going to
20 be governed under the change control process that's
21 already been delineated and described in DG-1426.

22 So, that guidance would be levered when
23 making sure that any plant changes that you have will
24 not have a demonstrable impact on the risk associated
25 with indirect seismic failures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Next slide, please.

2 We have a slide on appendices because,
3 again, there's a recognition -- you know, Bob said
4 this is, some of this is academic. And, yeah, it
5 certainly is. It's rare seismic events, it's very
6 much of an academic analysis.

7 So, you know, if plants need to go to that
8 route, we try to provide much help along that lines as
9 possible.

10 So, in Appendix A we've provided all the
11 information that we used in 1903 to do the plant-
12 specific evaluations that were done in 1903. And
13 recognizing that those plants could hopefully, not
14 only those plants but other plants potentially could
15 leverage that information.

16 So, Appendix A basically applies a lot of
17 the information that plants would need to gather or
18 get together as part of doing the seismic analysis.

19 And then Appendix B is just a sample
20 problem. Say, okay, if you have to do a sample
21 problem, use a critical location. We're going to work
22 through it on a particular location, under a
23 particular load, and with a particular material. So,
24 it's a step by step calculation approach.

25 So, we retained those appendices. We

1 debated whether to keep them from 1216 and move them
2 into 1428. We thought, you know, we're going to put
3 them out in the draft guide, get feedback from
4 industry if they think that sort of information is
5 going to be useful or not.

6 And then if we agree that it's not, then,
7 you know, that will another way to streamline the reg
8 guide before it's finalized. But at least initially
9 we wanted to make sure that that information was
10 available.

11 Next slide, please.

12 So, this is really the last slide. So,
13 since I went last, I get the opportunity to summarize,
14 which I greatly appreciate.

15 Again, we've talked about a lot of this.
16 But really the evaluation is there to support the
17 requirements in the rule to demonstrate that breaks
18 greater than the TBS remain unlikely.

19 And there's two aspects of that, not only
20 direct failures but then indirect failures. Right?

21 And so DG-1428 provides the guidance
22 necessary for conducting these evaluations.

23 As I mentioned previously, we didn't start
24 with a blank sheet of paper, we started from 1226 and
25 modified that as we thought was appropriate. We tried

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 to streamline and simplify it as much as possible.

2 But I think there's a recognition that,
3 sure, there's additional streamlining and simplifying
4 that could be possible. Certainly with this, DG-1428.

5 We also increased the scope, as Dave talked
6 about, to make sure that we included some guidance for
7 addressing indirect seismic failure in this guidance.
8 That was something that we agreed to do to address
9 prior ACRS comments from back in 201.

10 We did receive very few comments on DG-1216
11 during its development. And that, that helped us, I
12 think, 1428, it helped focus us and at least,
13 hopefully, helped iterate, to triangulate to where,
14 you know, this final guidance might ultimately end up
15 being.

16 I think there's a hope and expectation that
17 once, assuming that DG-1428 goes out for public
18 comment, that we'll get similarly very good and
19 constructive public comments that we'll be able to use
20 in refining this guidance and, ultimately, you know,
21 hitting on the final guidance that will be associated
22 with this rule.

23 As we've talked about, really ad nauseam
24 now, we've not only leveraged 1426, but we tried to
25 leverage as much as we could other longstanding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 guidance as well as applicable industry programs. And
2 Dave talked a lot about that.

3 And on this third bullet, you know, there's
4 a lot of options or graded approaches. You know, you
5 might say it's overly complex, we've got too many
6 options. But that's okay, we thought, at least from
7 my perspective, we thought having better -- more
8 options was better. And then we can winnow those down
9 based on what we think those options that are going to
10 most useful and helpful for the industry moving
11 forward.

12 Reg guides provide one acceptable way. We
13 feel like if you looked at all the different
14 permutations, we've probably provided about a thousand
15 different ways people can demonstrate applicability
16 through these various options.

17 But we can talk about flexibility. If we
18 can support it, we think that's important because not
19 every plant is going to be in the same situation.

20 And if we knew where every plant was in this
21 space, then we could tailor guidance appropriately.
22 But that's just information that we don't have.

23 And then, as Dave talked about, no
24 differently than we were going to do with 1216, you
25 know, once we get this out there, assuming we get it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 out there for public comment, we'll immediately start
2 engaging with the other stakeholders.

3 We really, you know, we planned this in
4 1216. We'd like to propose it now. We're really
5 hoping that we do at least one pilot study, maybe even
6 more than one pilot study if a couple of plants are
7 interested.

8 We know that that's a big burden to get a
9 plant to want to volunteer for a pilot study. So, I
10 don't take that naively or lightly. That's a big
11 commitment. But we think it could really provide some
12 value because one of the things the staff struggles
13 with, again not having coming from an industry
14 perspective, we know what we think the staff needs to
15 see. And we think we understand, at least at a high
16 level, what the implementation burdens are. Until you
17 actually work through it, you really don't have a good
18 sense for what those burdens really are.

19 And to try to find out where the hard spots
20 are and say, okay, if that's a hard spot, how do we
21 get around that hard spot in a way that we still think
22 is going to leave us in a good place in terms of
23 making sure that the TBS remains applicable and valid
24 for those -- that particular plant.

25 So, that's really it, I think.

1 Next slide's acronyms which, you know, Lord
2 knows we used plenty of acronyms, as we always do in
3 this presentation.

4 MR. RUDLAND: There are a couple extra
5 slides at the end. And basically it's just the
6 details in the rule where DG would be applicable. So,
7 it's just a bunch of words with the actual, the actual
8 proposed rule call-outs so that you can see what is
9 correct.

10 CHAIR BALLINGER: Thank you.

11 We're actually only 1 minutes behind, well,
12 12 minutes behind schedule. So, we're scheduled for
13 a break.

14 MR. RUDLAND: Dave has a question.

15 CHAIR BALLINGER: Yeah.

16 MEMBER PETTI: This is Dave. Rob and Dave,
17 so, let me -- I'm trying to formulate the question.
18 But as I look at everything I get a sort of sense that
19 there were bounding conditions allowed in the rule and
20 the guidance, most of it related to the inspections
21 the plants do, the amps, their tech specs, this need
22 to maintain regulatory control of large break well
23 failures even though it's not beyond design basis.

24 And the thought process is, okay, what do we
25 have to do? Well, yeah, they can use, they can use,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 they can use all these things.

2 I'm thinking about the problem the other
3 way. If industry came in, is there a way to use the
4 rule and the guidance to make changes and reduce
5 burden in the areas of inspections in terms of amps?

6 You know, what does the rule do to any of
7 the amps that are out there, and tech specs? My
8 favorite is let's change the diesel generator start
9 time tech spec because this is beyond design basis
10 LOCA. Why do I need it to start so quickly?

11 These things are running through my mind and
12 I haven't heard anybody talk about, you know, where
13 this can go. Because LOCA's everywhere in the rule
14 set. Have you guys given any thought to this?

15 So, this may be appropriate for our broader
16 discussion at the very end when we think about that.

17 MR. TREGONING: We think about that all the
18 time.

19 MR. RUDLAND: As a regulator, those are
20 things that we're concerned with. As a regulator,
21 it's those things that kind of make you sweat, but we
22 don't really know what the possible future
23 implications are for -- from this rule.

24 So, we're thinking about that constantly.
25 You know, we think about that constantly. And we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 had discussions internally about where we think the
2 licensees may go once this rule is in place.

3 And, you know, it's difficult to tell. And
4 it's something that I expect that we will talk about
5 during this public interaction period after the
6 proposed rule, you know, that to figure out exactly
7 where they would want to go with this.

8 Now, back in, you know, the mid-2000s when
9 we were originally working through 50.46a we had a lot
10 of workshopping with industry. And that was a broad
11 enabling one as well.

12 So, they indicated some things that were
13 important to them. Now, some of those things since
14 that time they've been actually able to achieve
15 through other means.

16 So, there is certainly uncertainty in terms
17 of what plants and stakeholders might want to achieve
18 with this rule. And that's something that we
19 certainly, we're certainly interested in.

20 Some of the big ticket items like power
21 uprates remain on the table, though. We're certainly
22 aware of that. But, yeah, you could concoct a lot of
23 things that could be done with this rule.

24 MR. TREGONING: Especially, you know, if
25 there are future reactors that are similar that it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 could in fact affect, you know, the design or the
2 original licensing basis and such like that, or the
3 area like the ECCS and such. So, yeah, those things
4 are on our minds.

5 MEMBER PETTI: Okay.

6 CHAIR BALLINGER: Okay. So, now we're at
7 1:16. I'll call it 1:15. Let's take a break until
8 1:30.

9 Thank you.

10 (Whereupon, at 1:16 a.m., the above-entitled
11 matter went off the record, and reconvened at 1:30
12 a.m.)

13 CHAIR BALLINGER: Okay, we're back in
14 session. We have a slight modification to our agenda
15 in that we're going to, on Agenda 6, if you have the
16 agenda. The changes to the rule since the last
17 subcommittee meeting we had in December. That's going
18 to go now. And then any additional follow-up, we'll
19 have a discussion with that.

20 And then we have -- we think that we're
21 going to -- if you look at Item 7, there's a follow-up
22 discussion. There's a list of topics and the staff
23 has asked that the TBS size discussion also be part of
24 before-lunch discussion. So unless members have
25 additional comments, that's the way we're going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 proceed. So I think -- I don't know who the presenter
2 is.

3 MR. MESSINA: Me, Joseph Messina.

4 CHAIR BALLINGER: Yeah.

5 MR. MESSINA: Yeah, so, hi. I'm Joe Messina
6 in the Nuclear Methods and Fuel Analysis Branch in
7 NRR, and I just have one slide this morning to talk
8 about some of the -- a couple of the changes that
9 we've made since December.

10 We thought it was important to get this in
11 before lunch in light of the industry presentations
12 that we saw. So maybe this will limit some of the --
13 reduce some of the discussion in -- by industry, so.

14 CHAIR BALLINGER: I got a bridge to sell
15 you.

16 MR. MESSINA: So the two changes are on the
17 slide. The first one was there was a requirement
18 that any of the non-safety-related equipment credited
19 for LOCAs above the TBS be placed in tech specs. And
20 I have the, this first sub-bullet is the wording that
21 was originally in the draft proposed rule. But we
22 have since removed it in concurrence.

23 And then we state that, you know, licensees
24 should consider on a plant-specific basis whether they
25 should be included in tech specs according to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 current requirements under Criterion 4 of
2 50.36c(2)(ii). And so --

3 VICE CHAIR HALNON: Joe, this is Greg. Can
4 you just tell us what that criteria is?

5 MR. MESSINA: That is the criteria that --
6 equipment that's important to plant safety based on
7 the operating experience or the risk has to be placed
8 in tech specs. So this is used for some of the
9 justification for placing some of the ATWS equipment
10 that's credited into tech specs.

11 VICE CHAIR HALNON: Okay, so it's not just
12 a play on words, you actually can eliminate or not
13 have to put this non-safety equipment in tech specs.
14 You don't have to do it. There's a criterion that --
15 it doesn't just --

16 MR. MESSINA: There's a criterion that,
17 yeah, is not a new, not a new analysis. They would
18 just do it under their hazard they currently do, yeah.

19 MEMBER HARRINGTON: And so this is Craig
20 Harrington. And just to be clear, the first sub-
21 bullet is what's -- what was originally --

22 MR. MESSINA: Yeah.

23 MEMBER HARRINGTON: The second sub-bullet is
24 what it's being replaced by.

25 MR. MESSINA: The first sub-bullet was

1 originally in the rule that we sent you guys in
2 December. The second sub-bullet is in the -- in the
3 preamble. That first sub-bullet was struck
4 completely, not --

5 MEMBER HARRINGTON: So we're just left with
6 --

7 MR. MESSINA: Yes.

8 MEMBER HARRINGTON: The second.

9 MR. MESSINA: And then the second change was
10 we had changed the LOCA definition from breaks in
11 pipes in the reactor coolant pressure boundary to
12 breaks in the reaction coolant pressure boundary.

13 We placed end pipes back in to align with
14 the current 50.46 definition. Because we think we
15 need to evaluate that a little more and consider if
16 there are any unanticipated effects of that change as
17 we -- yeah.

18 And that's all I have for the change.

19 VICE CHAIR HALNON: Joe, this is Greg. When
20 you took the -- when they took pipes, end pipes out,
21 what did you have in mind? Flange condensed break,
22 you know?

23 MR. MESSINA: So that was mainly -- we made
24 that change not -- with the anticipation that we would
25 not affect the operating fleet at all, but that it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 would be to -- for future reactors. Because some of
2 these reactors, the designs are different, and you
3 know, they have long, cylindrical things that move
4 fluid, and maybe they don't call them pipes. So it
5 was to avoid legalistic arguments.

6 MR. RUDLAND: Greg, this is Dave Rudland.
7 I can also say a lot of these analyses that were done
8 in what we're talking about, for the TBS 1829 and 1903
9 focused on breaks and not just breaks adjusted pipes,
10 so we looked at a lot of non-pipe leak breaks also in
11 determining those LOCA frequencies.

12 So that was one of the reasons why we
13 undertook that. But it does need to be consistent
14 with, you know, the code of regulations.

15 VICE CHAIR HALNON: Thanks.

16 MR. TREGONING: Rob Tregoning, just to add
17 a little bit more onto that, there was a -- when we
18 did 50.46a, and like Dave said, we looked into non-
19 piping breaks, that was a very significant part of the
20 evaluation. And it was just a recognition that the
21 LOCA is any sort of rupture of the primary coolant
22 pressure valve. It doesn't necessarily have to be in
23 a pipe.

24 So that's why in 50.46a, we had originally
25 not included piping. And then at the time, we said,

1 well, let's go back and make 50.46 consistent so that
2 we have consistent LOCA definitions in 50.46 versus --
3 and 50.46a.

4 But like Joey said, I don't think we really
5 appreciated some of the potential regulatory
6 implications associated with that. So that's why
7 we've ended up putting back in pipes into both
8 definitions so that they're consistent, recognizing
9 that there are some challenges to making sure that
10 everyone can agree on what a pipe is and isn't, so.

11 MR. MESSINA: And that's all I have.

12 MEMBER MARTIN: This slide is just changes
13 to the rulemaking document and not to the draft
14 guides, is that right?

15 MR. MESSINA: Correct.

16 MEMBER MARTIN: Are there any significant
17 changes to the draft guides that are worth talking
18 about?

19 MR. MESSINA: I don't believe we made any
20 significant changes to the draft guides since
21 December. You've received -- there were some changes
22 to the, I think the risk-informed guide, but that was
23 discussed in December and we've since sent that
24 revision to the ACRS.

25 MR. WANG: Yeah, we have it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Yeah, and I think you put
2 those new documents, if you hold the new side by side,
3 there's really no substantive change. What is it,
4 1426?

5 MR. WANG: Yes, that's what Joey talked
6 about.

7 MEMBER MARTIN: It was 1426, I had asked for
8 that last month. And I guess I'll look for it this
9 year. I didn't know we had an update yet. Just kind
10 of delta document.

11 CHAIR BALLINGER: Okay, now we're --

12 (Simultaneous speaking.)

13 VICE CHAIR HALNON: I think Dennis has his
14 hand up.

15 CHAIR BALLINGER: Okay Dennis, proceed.

16 MR. BLEY: So at least in the PRAs, if
17 people look at the reactor coolant pump seal LOCAs, I
18 guess we can't call those LOCAs anymore?

19 MR. MESSINA: We're not anticipating on
20 changing how we're treating LOCAs in 50.46 in terms of
21 what the break is considered to be.

22 MR. BLEY: Fair enough.

23 MEMBER KIRCHNER: This is Walt Kirchner. I
24 just volunteer that the existing 50.46a has a much
25 more generic definition for specifying the breaks that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are analyzed. And that fits in with Dennis's comment.

2 MR. MESSINA: But we changed it to include
3 the end pipes because to be more specific to align
4 with what's currently in 50.46.

5 MR. RUDLAND: I think his comment was that
6 it was originally more generic.

7 MR. MESSINA: Yeah.

8 MEMBER KIRCHNER: Yes.

9 MR. MESSINA: In December it was more
10 generic and now it's now it's more specific again.

11 MR. BLEY: So I don't know, I understand
12 what you did and why you did it. But does this
13 somehow limit applicability to some of the new designs
14 we're going to be seeing?

15 MR. MESSINA: No. We do not expect it to
16 limit applicabilities to some of the new designs. For
17 example, some of the new designed reactors are using
18 the current 50.46, which has this definition of breaks
19 in pipes in the reactor coolant pressure boundary.
20 And we, you know, we're working with them to address
21 LOCA.

22 MR. BLEY: Okay.

23 MR. MESSINA: The difficulty with new
24 designs is to define exactly what "pipes" means. You
25 know, I think that's the things. You know, in some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 cases they may have a forging and is that a pipe or is
2 that not a pipe and stuff like that. So I think those
3 are some of the discussions that are ongoing.

4 CHAIR BALLINGER: Other questions? Okay,
5 we're about to enter the grey area. We had, the
6 committee had, after the December meeting, we got, had
7 communications, and we had identified areas that we
8 might need a little bit more clarity on, discussion,
9 the like and stuff. And those concerns were codified
10 in a -- in a paper, which is in ADAMS, which
11 delineates the various areas that the comments were in
12 related to the rule.

13 And those areas include the items in number
14 7 here, one of which is TBS size. And we had thought
15 that this afternoon, that discussion that we would
16 have would be related to those areas and the staff was
17 planning on being available for doing that.

18 But the staff has also asked that the TBS,
19 which is item No. 3 in our list, get moved back up
20 into the discussion we're having now, because Dave has
21 is already -- they're still here, so we might as well
22 just ping him a little bit more. But that's a
23 discussion with the committee.

24 And so that's -- we'll save the rest of the
25 discussion until after lunch. But are there comments

1 or discussions we have to have among the members and
2 consultants related to the TBS size discussion that we
3 pretty much had most of the morning?

4 So I guess we just need to open it up to
5 discussion among the members. If there are no
6 comments or issues or discussion topics, then we can
7 just move on.

8 MEMBER PETTI: Ron?

9 CHAIR BALLINGER: Yes, sir.

10 MEMBER PETTI: This is Dave. Just to tell
11 the other members, if they hadn't seen it on
12 SharePoint, I collated all of the comments into those
13 bins that are showing on the slide, except for stuff
14 that's more administrative or editorial. So the staff
15 kind of knew in advance what some of our concerns
16 were.

17 But that doesn't of course stop us from
18 going somewhere else with the discussions. It never
19 has. But I didn't, I particularly didn't pick up any
20 administrative things in the language, so feel free to
21 bring those up.

22 But I thought I'd tell you the three that I
23 picked up. And they didn't know -- I did not say who
24 made these comments, so I just expect members to carry
25 the ball, they should recognize them. In some cases

1 more than one member made the comment, which is why I
2 also put it on the list, because that means, you know,
3 there's some consensus.

4 The first one is a comment but not a, I
5 don't know one that needs a lot of discussion. I
6 think we'll probably say in our letter that the
7 technical basis for TBS is strong. You know, we have
8 the expert elicitation and the seismic risk work that
9 was done and then now the probabilistic fracture
10 mechanics. So it, you know, I think it's a fairly
11 healthy technical basis.

12 That said, there's a whole discussion about
13 inspection of piping above the TBS in light of the
14 fact that, you know, it is now considered beyond
15 design basis. And so it's the same question that Greg
16 raised earlier that we're talking about, you know, is
17 there an internal consistency there in terms of the
18 inspection schedule relative to the risk that we're
19 talking about.

20 And then the last one I had is analysis of
21 LOCAs beyond the TBS. You know, there's still
22 requirements for containment analysis and defense-in-
23 depth, and so there may be some discussions there that
24 members had. Those are the three that we had, so.

25 CHAIR BALLINGER: Okay, that's a good basis

1 for the start. Did the staff have -- I mean I don't
2 know that you need to respond or anything, but feel
3 free to do though.

4 MR. RUDLAND: Well, I'll touch on the, start
5 with the inspection.

6 CHAIR BALLINGER: We beat the inspection
7 thing to death.

8 MR. RUDLAND: Yeah, I just want to make a
9 comment about that again. You know, the idea that we
10 have done these analyses that make a demonstration
11 that the piping that's greater than the TBS is a very
12 low likelihood of failure does not -- it does not
13 remove our need to be able to continue to verify that
14 those analyses remain valid throughout the course and
15 the life of the plants.

16 And so you know, while we do understand that
17 the chances of failure are really low, we do think
18 that -- we think we need to continue to monitor those
19 things for novel degradation as well as a continued
20 assurance of the accuracy of the analyses that we'll
21 conduct.

22 VICE CHAIR HALNON: Are we inspecting them
23 to the same level that we would have inspected them if
24 we didn't have a TBS?

25 MR. RUDLAND: It would be inspected during,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 through the normal ASME Section 11 process.

2 VICE CHAIR HALNON: So what does it gain me
3 from an inspection perspective?

4 MR. RUDLAND: It doesn't gain you anything.
5 It's not meant to gain you anything.

6 VICE CHAIR HALNON: That's my point, is that
7 we're pushing it -- it just seems like there's an
8 opportunity for a graded approach relative to risk.
9 I get to 10 to the minus 6, whatever. There's some
10 going to be less than that, maybe significantly less.

11 MR. RUDLAND: But the gains are elsewhere,
12 not in the inspection.

13 VICE CHAIR HALNON: Well, from an outage
14 perspective and dose perspective, there's a lot to be
15 gained from reducing the number of inspections if
16 there's no changes, no changes in analysis, no change
17 at the plant, no transients of concern. I could
18 probably list a few more things.

19 Why not allow an inspection regime that says
20 okay, I've done my ten percent or whatever is
21 required, found no problems. If that gives me another
22 10, 15, 20 years rather than continue to inspect at
23 the same level as if it was a design-basis event.

24 MR. RUDLAND: And again, that's the whole
25 philosophy behind these risk-informed programs, right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So they're -- they have received the credit for the
2 fact that there are locations within the piping
3 systems that are low risk. And that -- and so they're
4 only inspecting those higher risk locations. That's
5 part of the risk-informed program.

6 So what we're asking for them to do here,
7 just include these particular welds or a sampling of
8 these particular welds into that program.

9 VICE CHAIR HALNON: They're already in the
10 program.

11 MR. RUDLAND: Well, the piping groups are,
12 but not necessarily those particular welds, right.
13 Because the piping groups we're risk-informing are a
14 much bigger sample, much bigger population of welds
15 than those welds that are greater than the TBS.

16 CHAIR BALLINGER: So I'm coming back. If
17 the plant is in compliance with Section 11, what else
18 do they need to do? They're already inspecting the
19 welds that are in Section 11.

20 MR. RUDLAND: Right, the only requirement
21 difference is that they need to include these
22 particular welds in their sample, or a percentage of
23 those in their sample, in their inspection sample.

24 CHAIR BALLINGER: So what you're saying is
25 that some of these welds are not part of Section 11.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. RUDLAND: No, they're just not part of
2 the sample. Section 11 is a sample group.

3 CHAIR BALLINGER: Yeah, yeah.

4 MR. RUDLAND: So you inspect a certain
5 percent --

6 CHAIR BALLINGER: Oh, oh, I see, okay. I
7 get it now.

8 MR. RUDLAND: So typically for the Class 1
9 piping welds, a typical Section 11 program is 25%.
10 You have to inspect 25% of the welds. The risk-
11 informing programs allow them to reduce that to about
12 10% but only look at those really important welds.

13 CHAIR BALLINGER: Okay.

14 MR. RUDLAND: So what we're saying here is
15 take the welds that are in, that are greater than the
16 TBS and make sure 10% of those are included in your
17 program, of a sample part of your program. And that's
18 consistent --

19 CHAIR BALLINGER: Eventually in Section 11,
20 that weld will get inspected anyway. It just might
21 not be for a long time.

22 MR. RUDLAND: It may never get inspected.

23 MR. MESSINA: It's not part of their
24 inspection sampler, it never gets inspected, ever.

25 VICE CHAIR HALNON: So the logic, help me

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 with the logic. You're taking a 10%, which are all
2 very important welds, and you're putting some
3 unimportant welds in it --

4 MR. RUDLAND: No, I'm not saying -- they're
5 not unimportant welds. That's the whole point.

6 VICE CHAIR HALNON: But they're not in it.

7 MR. RUDLAND: They're in the thing, they're
8 just maybe -- I don't know if they're in it. That's
9 the point. They might be in it, because that's --

10 (Simultaneous speaking.)

11 VICE CHAIR HALNON: I follow you, Craig, I'm
12 just saying --

13 MR. RUDLAND: That's a plant specific
14 determination.

15 VICE CHAIR HALNON: It feels like you're
16 displacing some very important stuff, that you've
17 already determined is very important.

18 MEMBER HARRINGTON: I get your point, but
19 still, and I really struggle with this, the, you know,
20 it's very presumptuous of us to assume that all of our
21 analysis of degradation mechanisms and materials, all
22 this work that we've done means that nothing will ever
23 happen.

24 Because there are unknown unknowns. And we
25 could be surprised. I don't expect us to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 surprised, but if we don't look, then that surprise
2 will find us before we find it. And that's not good.

3 VICE CHAIR HALNON: But the point that I'm
4 making is that, and I don't want to sound flippant
5 and, you know, negative safety culture, but it's
6 almost a okay, so what. You have defense-in-depth,
7 you have leakage detection, you have analysis that
8 said it's not going to be a double-ended, you know,
9 break.

10 You still have at least half of your safety
11 systems that are still available because you have two
12 trains typically, you only need one for the large
13 breaks. It's very rare, you know -- I get to, almost
14 to the point of so what. Not from a safety, I mean,
15 and I'm not sure why --

16 MEMBER HARRINGTON: The inspection sample
17 one way or another.

18 VICE CHAIR HALNON: Yeah.

19 MEMBER HARRINGTON: But it may well be that
20 the inspection sample right now, and it may not. But
21 it is possible that the inspection sample that they've
22 chosen right now is chosen as much for convenience as
23 it is for the distribution of sizes, for example.

24 CHAIR BALLINGER: Yeah, the cynical approach
25 is plant owner says we needed to inspect x welds 25%

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 or what number, but weld number y-3 --

2 MEMBER HARRINGTON: You're not going to go
3 inspect the hardest weld in the entire plant.

4 (Simultaneous speaking.)

5 CHAIR BALLINGER: We're not going to do
6 that, we're not going to put that in this. But the
7 rule comes back and says by the way, you need to
8 analyze all these welds and you need to determine
9 which ones are the most at risk, if you will. And you
10 need to include those welds in the 25%, if they're not
11 there already.

12 MR. RUDLAND: So if you talk about this
13 particular category of welds in the risk-informed
14 program, this particular category of welds is similar
15 metal welds that have high consequence but no known
16 degradation. That's the category of welds that we're
17 talking about.

18 So if you think about what's driving those
19 welds to be in the risk-informed program, it's the
20 welds probably that have the highest stress and maybe
21 the highest usage factor, right. They may have a
22 teeny issue or something.

23 So the chances of a weld not greater than
24 the TBS and a weld greater than TBS probably have
25 about the same values for those criteria. It's not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 question. They chose the other weld for some other
2 reason. Maybe it's ease of inspection or they have
3 other welds that they're inspecting that are in the
4 same location, so when they set up their scaffolding
5 they don't have to move the scaffolding.

6 There may be other things like that that are
7 financial that may be driving why they chose welds
8 other than those that are greater than the TBS. But
9 there's probably not some big issue with degradation
10 that we would be neglecting if they were to move one
11 weld smaller than the TBS to one weld greater than the
12 TBS in the sample.

13 CHAIR BALLINGER: But I keep coming back to
14 those, most of those welds you would think would have
15 been mitigated in some way.

16 MR. RUDLAND: Well, again, they're not
17 instigated because --

18 CHAIR BALLINGER: Some way.

19 MR. RUDLAND: They're mitigated by the fact
20 that there's no known degradation at this point. So
21 their inspections are limited based on that knowledge.

22 MR. TREGONING: These are not in 770 welds.

23 CHAIR BALLINGER: They're not --

24 MR. RUDLAND: No.

25 MR. TREGONING: We said at the beginning,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that's a small percentage of the welds we're talking
2 about.

3 MEMBER HARRINGTON: 770 welds already have
4 their own --

5 (Simultaneous speaking.)

6 MR. TREGONING: Can I -- Rob Tregoning,
7 staff. There's -- this is totally analogous with
8 what's done now, right. We approved risk-informed
9 break exclusion region. That was an EPRI program,
10 right. It's based on risk-informed ISI. But it's
11 risk-informed ISI with a twist. It not only considers
12 risk propensity, but it also considers the propensity
13 of a high consequent component failure.

14 And risk-informed break inclusion region,
15 the way that, the philosophy works is you have a
16 sampling population that you do, just like with risk-
17 informed ISI, just like the ASME program.

18 But it says that you need to retain some
19 percentage of high consequence welds that you're
20 inspecting, so that part of your inspection sample
21 should make sure that you have at least some
22 percentage of high consequence weld. That's all that
23 we're saying here, and it's entirely analogous what
24 we're already doing in other risk-informed inspection
25 programs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Industry's coming in now and looking at
2 risk-informed high energy line break. Same exact
3 principles, right. It's a sampling population, but it
4 makes sure that it elevates certain pipes or certain
5 welds that have a higher consequence of failure to
6 just make sure that you have a certain percentage of
7 those welds in your inspection program. That's all
8 we're saying here. That's all we're saying
9 whatsoever.

10 Because we know the consequence of failure
11 between a six-inch branch line made of stainless --
12 with a stainless steel weld is much less significant
13 than if we had, you know, a main piping coolant line
14 that would break with a stainless steel weld. Much
15 different consequence of failure.

16 So that's all we're doing here, entirely
17 analogous with what, and you know, consistent programs
18 that we've been doing out with, you know, with that
19 industry and the NRC have been -- that the industry
20 has proposed and the NRC has approved.

21 MEMBER DIMITRIJEVIC: Hi, this is Vesna
22 Dimitrijevic. I just want to help a little with this
23 because I was part of EPRI risk-informed ISI team. So
24 this is how it worked and how this changed.

25 So first it changed from 25 to 10 percent,

1 and it was based to select the welds with the highest
2 risk. Since these old welds lead to LOCA from the
3 consequence point of view, this is the same approach.

4 So the only thing which contribute was the
5 degradation mechanism, but then there is not too many,
6 as somebody already said, degradation mechanisms in
7 the Class 1, the piping. So they only couple thermal
8 fatigue or something.

9 So the 10% of inspection were select in the
10 areas where there is degradation mechanisms, there is
11 some -- and other percentage was selected from
12 convenience. And main goal was to reduce exposure
13 during inspection. So this -- so usually we are
14 talking here between 400 and 600 welds in the Class 1
15 piping, so we are talking about like 40 to 60
16 inspections.

17 I don't really have, even I participated
18 over 30 of those, I really don't have a good feeling
19 about what size this piping, you know, was. You know,
20 was it bigger than TBS or not. How that was approved
21 so fast is the main reason is that there was not
22 really reason to, you know, to require 25% when there
23 was nothing really found in the years of inspection.

24 So inspection intervals of 10, yes, and they
25 always inspect same 10% of the welds. So this is what

1 is the status currently with this risk-informed ISI.
2 So I don't really see the benefits of adding these,
3 you know, the bigger size welds. But, and changing
4 current risk-informed inspection program.

5 But I mean, so the main thing is not just
6 convenience. I am sure the convenience was battling
7 reduced exposures during the inspection.

8 VICE CHAIR HALNON: Thanks, Vesna. I just
9 have one -- I realized my question is not from the
10 expert perspective, but so we have roughly 4500
11 reactor years of operation in our fleet.

12 Do you see a path forward in another 4500
13 reactor years to say large break LOCAs are no longer
14 of concern above the TB if nothing has happened?

15 MR. RUDLAND: So when I was a little bit
16 earlier in my career and my division director came to
17 me, I had done an analysis for him. I took the CODAP
18 database and I plotted the behavior of material
19 degradation in the existing passive components.
20 Showed him how it changed and how the industry's
21 response to that decreased the occurrences.

22 And so he said to me, Well, tell me what the
23 next degradation is. Tell me what's coming. I told
24 him, I said I don't have a crystal ball. This is not
25 going to tell me what's going to happen. I can only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 look at what's past happened. I have to have
2 regulations in place to guard against those things
3 that I just don't know.

4 So in the next 4500 hours, again, if nothing
5 else happens, I would feel more confident. But I
6 don't know if I would have --

7 VICE CHAIR HALNON: So your branch chief
8 probably wrote on his little pad of paper D-I-D.

9 MR. RUDLAND: Yeah --

10 (Simultaneous speaking.)

11 VICE CHAIR HALNON: -- the unknowns.

12 MR. RUDLAND: I thought you were going to
13 say D-E-A-D on his little paper.

14 VICE CHAIR HALNON: And just, you know, from
15 where my head is at, and I know it's probably, again,
16 blasphemy, but we've got a lot of years of experience.
17 We've got a lot of material experience with existing
18 materials and there's new materials coming out every
19 day, maybe every decade.

20 My point is that in today's environment,
21 with the maturity of our PRA and our risk tools that
22 we have, the knowledge we have with a lot of operating
23 experience -- and I realize some of the new reactors,
24 we don't have that operating experience. The
25 environment, political environment with Congress and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 in some cases the Commission is well behind making a
2 bold change to our regulatory process going forward.

3 Why is not now the time to say defense-in-
4 depth, linkage monitoring is enough, and let's not
5 worry about breaks above TBS?

6 MR. MESSINA: Joe Messina. I first would
7 say that this could be a stepping stone to getting
8 there one day, this rule. Everything --

9 VICE CHAIR HALNON: That's why I asked about
10 another 4500 reactor years.

11 MR. MESSINA: Yeah, it could be, maybe. But
12 there's also a lot of work that we would have to look
13 at that we don't have the time for in this rulemaking
14 if we wanted to take out large break LOCA from
15 complete analysis.

16 So that's a major change, you know, a lot of
17 -- as some members have mentioned, there's a lot of
18 intertwining regulations that are even, you know, have
19 we considered them fully in this rulemaking people are
20 questioning.

21 And so if we fully remove it, we have no
22 control over that. At least with this, we -- when
23 plants try to adopt this rule, we would be able to say
24 oh, did they invalidate any assumptions of existing
25 guidance when we're reviewing this. So we have that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 regulatory control that we've been saying over these
2 large breaks still.

3 VICE CHAIR HALNON: That's a good answer.
4 I just want to make sure there is an industry to be
5 able to do that next stepping stone. Enough said.

6 MR. RUDLAND: I'm a materials engineer, you
7 know, and so I think about it in terms of the
8 materials. And we all know that materials age and
9 damage happens quickly in life. You know, then
10 there's an area where we're at pretty steady state and
11 then there's an end where the material begins to
12 degrade again.

13 And people always say, you know, where is
14 that point where things start really falling apart at,
15 and I've got to give it to the industry, because it's
16 been their proactiveness in materials-related issues
17 that have kept us, I think, at this steady state. And
18 again, as long as their continued diligence moves into
19 the future, we could have a very long time before
20 anything bad happens.

21 If that's the case, that gives us a better
22 basis for continuing that. But you know, as
23 homeowners and as a, you know, a person that's
24 entering his sixties, we know things fall apart as we
25 get older. So we don't want to stop looking just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 because we think everything's --

2 (Simultaneous speaking.)

3 VICE CHAIR HALNON: -- 500 years, yeah, I
4 get it.

5 MR. TREGONING: Rob Tregoning. Sorry.

6 CHAIR BALLINGER: Apropos of what Greg was
7 saying, I mean, Appendix K provided what I call an
8 ejection seat. If something really goes wrong, we got
9 it, right.

10 But to me, we now have another ejection
11 seat, and that is 1.45, leak detection. You know,
12 apart from abject stupidity, which is I suppose
13 possible, the chances of us having a rupture due to a
14 leak that's not detected, I don't know what the
15 probability of that is, but it's got to be pretty darn
16 low.

17 MR. RUDLAND: So we look at that, you know.
18 And again, I think the scary thing is these, I mean
19 that is getting a little bit off topic, the scary
20 thing are these stress corrosion cracks that can
21 produce very long but shallow flaws that become
22 critical before they leak.

23 So and that occurs more in small diameters
24 than it does in large diameter pipes. So that's why
25 the probability of rupture without taking credit for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 leak detection, you know, is much higher for small
2 diameter pipes than --

3 CHAIR BALLINGER: Not that we are taking
4 credit for leak detection.

5 MR. RUDLAND: I'm just making the comment,
6 I'm just making the comment that it's much higher in
7 low -- small diameter pipes than --

8 (Simultaneous speaking.)

9 CHAIR BALLINGER: Your analysis says, I read
10 somewhere, that you have to have a very large through-
11 wall crack from a circumferential crack before a
12 rupture.

13 MR. RUDLAND: Yeah, that's correct.

14 CHAIR BALLINGER: Regardless of the size of
15 the pipe.

16 MEMBER HARRINGTON: Or very large surface
17 crack, it could be very large surface.

18 CHAIR BALLINGER: Yes, but --

19 MEMBER HARRINGTON: They're just very
20 unlikely.

21 CHAIR BALLINGER: But the probability of it
22 leaking beyond, well, not being detected because of
23 the -- you're talking about a gallon -- very low leak
24 rates that are now being able to detect it -- detect
25 it. That's pretty darn low. It's got to be, again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 very low.

2 MR. RUDLAND: Yeah, and I think of leak
3 detection as our defense-in-depth against the analyses
4 that we had and so yeah, I agree.

5 CHAIR BALLINGER: So we have this very low
6 probability already event, plus we have leak
7 detection.

8 MR. RUDLAND: But the leak detection was used
9 as the basis for the low probability event. So you're
10 double counting a little bit, you know. Because those
11 leak detection probabilities are built into those
12 analyses.

13 CHAIR BALLINGER: 1428 was the first DG that
14 had leak detection in it. Of all the DGs that we've
15 been reviewing, the first time 1.45 was mentioned was
16 in 28.

17 MR. TREGONING: So Rob Tregoning, staff.
18 Just a couple of things. Ron, to get to your point,
19 yes, if a crack is going to -- if a pipe is going to,
20 the mechanism is going to leak before it breaks,
21 there's no -- I have zero concern about those sorts of
22 failures because of leak detection.

23 It's the non-leak-before-break degradation
24 mechanisms that are --

25 CHAIR BALLINGER: But what are they?

1 MR. RUDLAND: Well, SVC is one of those. We
2 haven't degraded it, and we've seen it in operating
3 experience. It can get long surface cracks.

4 CHAIR BALLINGER: Small diameter pipes.

5 MR. RUDLAND: Well, you can get long surface
6 cracks in a large diameter pipe too, but they just
7 don't get that long before they --

8 (Simultaneous speaking.)

9 MR. TREGONING: The Duane Arnold was a
10 fairly big pipe that had very extensive SVC. Now,
11 again, it was in a similar metal weld. But I mean, it
12 was about 85% through-wall cracked over the entire
13 circumference.

14 CHAIR BALLINGER: Yeah, it was almost a lawn
15 sprinkler.

16 MR. TREGONING: And you know, this notion
17 that big pipes can't fail is just, it's just a false
18 narrative. We've seen big pipes fail, even in nuclear
19 applications. Now, due to different mechanisms.
20 We've never had a LOCA. But we've had fatalities due
21 to large pipe failures.

22 CHAIR BALLINGER: FAC.

23 MR. TREGONING: Okay. Ron, we've --
24 internationally there have been hydrogen events, where
25 we had detonation events that, you know. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 depending on where the detonation occurred, in Germany
2 they were very close to having LOCA.

3 This notion that you can't get a large break
4 or that you can't get a failure that won't exhibit a
5 leak a priori is just, I'm sorry, I don't agree with
6 it.

7 CHAIR BALLINGER: Well, but Section 11, it's
8 there for that reason.

9 MR. TREGONING: Section 11 is partially
10 there for that reason. Again, Section 11 didn't
11 address FAC, right. I mean, there was no FAC --

12 CHAIR BALLINGER: Well, it wasn't supposed
13 to.

14 MR. TREGONING: Okay, that's what we're --
15 that's what we're trying to guard against, right.

16 CHAIR BALLINGER: You have to talk to Bindi
17 Chexal or his relatives.

18 MR. TREGONING: Because again, I think
19 there's a recognition that look, even though there's
20 no disagreement that the likelihood of failure in
21 these pipes is low. There's no disagreement. But the
22 consequences if a failure could occur are significant.

23 Even though we've got plans in place, even
24 though you have to do the analysis, if there -- if
25 this happened in a plant, it would be detrimental, not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 just from potentially a safety perspective, but even
2 from an optics perspective.

3 CHAIR BALLINGER: It doesn't event need to
4 be a rupture, to be honest, it just needs to be a
5 large break.

6 MR. TREGONING: You know, I mean, yeah. So
7 I think, so you know, so making sure that we have
8 sufficient performance monitoring in place to make
9 sure that we're doing risk-informed changes and not
10 risk-based changes is ultimately what I come back to
11 at the end of the day.

12 CHAIR BALLINGER: So it comes down to a
13 discussion of how much monitoring do we need, that's
14 really what it comes down to.

15 MEMBER HARRINGTON: This is Craig
16 Harrington, hi. I think that really is the crux of
17 this. How do you set up a monitoring program that has
18 the lowest footprint possible but gets you the most
19 information possible, the most relevant information.

20 MR. RUDLAND: And we talked to the materials
21 subcommittee.

22 CHAIR BALLINGER: That would be us.

23 MR. RUDLAND: Yes, in November was it, Ron?
24 About that, right. And how we want -- how we propose
25 to design those types of programs to get the minimum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 number of inspections that are needed.

2 MR. TREGONING: And to get to Greg's point,
3 I mean, inspections are a great one, right, I mean,
4 and you're like, well, if we have another 4500 years,
5 would that be good enough. Of course, we're a
6 learning organization, we're a learning industry,
7 right. And inspection's been a great one, right.

8 We've reduced significantly the amount of
9 inspections that have been done, especially over the
10 last 30 years. And look, if we started doing
11 something under this rule and we started to gather
12 information, and the information tells us that, you
13 know, maybe we don't need to do as many inspections,
14 and maybe they don't need to be done infrequently.

15 We've got a history as an industry, and as
16 a regulatory body of looking at the technical basis,
17 looking at the evidence, and saying yes, there is a
18 strong basis for maybe doing some relaxation. So none
19 of these things are intended to be static. None of
20 them are necessarily intended to be set in stone.

21 But you know, we want that evidentiary based
22 sort of method moving forward to make sure that when
23 we do make changes that we feel like at the end of the
24 day, that they're appropriate to give us reasonable
25 assurance.

1 This is right, Craig's right. I mean, it's
2 really just -- it's the debate about how much
3 performance monitoring is enough.

4 MEMBER MARTIN: This is Bob, Bob Martin.
5 Your arguments ring a bell for me when I was doing
6 severe accident. Yes, there was always someone that
7 said you can do better. You know, you could put in
8 more guardrails and what have you.

9 And then you're in this beyond-design-basis
10 space. And the consensus eventually led to, you know,
11 the SAMA, SAMDA programs, where you had cost-benefit
12 analyses that were performed ultimately leveraging
13 PRAs. Has that been done?

14 I mean, tabletop -- I know you've already
15 said it would be great to have somebody go off and,
16 again, volunteer to implement these programs and see
17 where it goes. But it seems to me that this kind of
18 argument has come before.

19 And it came down to okay, well, I mean we
20 can make a judgment, you know, based on some sort of
21 cost-benefit analysis leveraging PRAs, as opposed to
22 just, man, it seems more deterministic from what I
23 said earlier given the way we're talking about it
24 today, even though we might label it risk-informed.

25 But there are methods that we already

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 considered, you know, when we were moving beyond the
2 design basis, that lead to decisionmaking that seems
3 very practical. You know, has that really entered the
4 conversation prior? Looking at what other people have
5 done that your other parts of the agency has accepted
6 in this space.

7 MEMBER KIRCHNER: Ron, this is Walt.

8 MR. MESSINA: So, I'll say that we have,
9 we've talked with a lot of people when developing the
10 initial licensing pathways, alternatives that were
11 presented in the reg base, including our friends over
12 in the Division of Risk Assessment, and this, we ended
13 up going with this option. But we did talk to some of
14 the more people that do risk stuff.

15 MEMBER MARTIN: Right, right. But I mean,
16 so when -- obviously not addressed in what we've seen.
17 But if, you know, I'm looking down the road, someone
18 comes back and goes, well, we did the cost-benefit
19 analysis and it just doesn't beat the threshold that
20 we would otherwise consider for something equivalent
21 in a severe accident space.

22 Problem solved, you know? No change? I
23 mean, would that be enough to go, what we've got is
24 enough?

25 MR. MESSINA: I would also, I think it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 important to note that, you know, the operating fleet
2 was designed to prevent a LOCA. If we're no longer
3 designing for that LOCA, how much does that --

4 MEMBER MARTIN: No, no, no, you're taking it
5 too far, right. We, you know, industry's been around
6 enough, long enough. We've done a -- we have a lot of
7 knowledge about, you know, what we do and why we do
8 it.

9 And you know, with the -- since Three Mile
10 Island, the expansion of our understanding of severe
11 accidents as beyond-design-basis events has led us to
12 policy that, you know, provides a, I would say,
13 objective decisionmaking approach.

14 And you know, I think it can apply in this
15 space as well, even though you're coming at it from a
16 different direction, right. You're coming at it from
17 what we've always done, and then here's, you know,
18 maybe a new consideration for, you know, seismic
19 failures. And well, okay, we also have the pressure
20 of risk-informed. Where are we at with that?

21 Well, the way I see it, we've moved the line
22 a little bit with TBS. And you've just entered this
23 space that a lot of people in the severe accident
24 world already understand and already have solutions
25 for making decisions. It seems like we should be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 looking at how those methods can influence, you know,
2 this particular question or these particular
3 questions.

4 MR. TREGONING: Rob Tregoning. I think it's
5 an interesting point, right. And it's a very valid
6 consideration. But we're sort of -- you're entering
7 into the policy realm in some sense there. And you
8 know, so while I think the framework is there, I think
9 you know, we would need appropriate direction and sort
10 of you know, direction to sort of head in that area.

11 I certainly think it's possible, right.
12 It's how important you think the risks are and how
13 much you want to -- and how much mitigation you want
14 to have associated with those risks at the end of the
15 day.

16 VICE CHAIR HALNON: That's a Commission
17 issue.

18 MR. TREGONING: Well, right.

19 VICE CHAIR HALNON: That's a policy
20 practice.

21 MR. TREGONING: Well, that's why I think --
22 I think, right. So but you're right, we've certainly
23 done it in the past. And we can leverage or lean on
24 those past experiences if indeed we decide to do
25 something similar here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So it could be done, but it's not something
2 obviously for me --

3 MEMBER MARTIN: It's out of scope,
4 basically.

5 MR. TREGONING: Yeah.

6 MEMBER MARTIN: But.

7 CHAIR BALLINGER: Well, I think by the way
8 that they're -- Walt had his hand up, or didn't have
9 his hand up but started talking.

10 Walt?

11 MEMBER KIRCHNER: Yes, Ron, thank you.
12 Notwithstanding all the, just I'll make an
13 observation. We're not going to give up on the ASME
14 code and inspections for the existing fleet.

15 How we do those and how we target those to,
16 as I think Dave was pointing out, looking at the areas
17 where a failure has the most consequence and tradeoff
18 for then using TBS as the means for 50.46a valuations
19 of ECCS I think is an important -- I'm not saying this
20 correctly. Is an important -- that tradeoff is
21 worthwhile because I don't think in looking at the big
22 picture the next part of this puzzle is how does TBS
23 influence increased enrichment going forward in the
24 fleet.

25 So if we have an acceptable means for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 implementing TBS, and if that requires targeted
2 inspections, that may be -- some of them may be more
3 difficult than those that we do for convenience or
4 dose considerations.

5 I think that tradeoff is going to prove to
6 be worthwhile. Because without the TBS, I have
7 serious reservations about whether we can meet the
8 expected ECCS performance requirements and prevent
9 FFRD.

10 So that's my observation at this point. So
11 I would be very interested at some point today, do we
12 get to the 56a language, and specifically how TBS is
13 in the regulation, the rulemaking. That to me is
14 extremely important next step to look at for the
15 committee.

16 We're just not going to give up ASME
17 inspections for public confidence and for insurance
18 purposes. So targeting those and addressing those
19 high consequence issues that are the unknown in going
20 away from double-ended guillotine break strikes me as
21 a very intelligent move by the Agency.

22 MEMBER MARTIN: I think getting to what Bob
23 was talking about, we had a presentation on Tuesday on
24 the 10 CFR 53. And just thinking through how this
25 compared to that, 10 CFR 53 you would start with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 essentially the PRA and go figure out how your
2 licensing basis events screen out and you know, put
3 your mitigations in based on that.

4 Here, because the plants were designed for
5 the deterministic requirements and the design-basis
6 LOCA, it's kind of hard to get there. Now, maybe in
7 an ideal world, you'd take that Draft Guide 1426 and
8 say that's good enough for anything, you know, that's
9 enabled by the break -- the TBS rule and say just can
10 we get there.

11 It's just a question of whether there's
12 enough fidelity to the PRAs and enough, you know,
13 understanding for the existing plants. Some I guess
14 are better understood than the new plants. But you
15 know, do you get there in terms of the equivalent
16 safety with, you know, defense-in-depth as a
17 substitute for maybe some of these deterministic
18 requirements.

19 Again, one specific is the containment
20 pressure calculation. Because right now it's based on
21 the double-headed break using conservative
22 assumptions. The rule would enable the containment
23 pressure to be calculated best estimate for above the
24 TBS, then TBS lower be a design.

25 So that would seem to have the potential of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 lowering the design pressure. However, the design
2 pressure would allow for higher leakage because your
3 tech spec requires the peak pressure to be maintained
4 for 24 hours. That peak pressure goes down, you'd
5 have more leakage.

6 So is there some, you know, counteracting
7 degradation safety because you've released your
8 containment. Well, maybe if 1426 would tell you that,
9 it'll tell you whether or not you captured it all.

10 But again, it's taking on a fundamental
11 aspect of plant safety for the existing plants. And
12 whether you get there with a cost-benefit analysis, I
13 don't know. I'm not sure whether that's the
14 appropriate model or whether 1426 is the appropriate
15 model or just how you get there.

16 That's where I think the example with Joe,
17 he was talking about, is just the existing 10 CFR 50
18 is so based on the deterministic, you know, double
19 ended guillotine break LOCA that extracting it out of
20 the regulation would be very complicated. And that
21 said -- To me, it's one of the major attractive points
22 of the LS approach, which says well maybe that's worth
23 taking on. That would be a lot of work. So let's not
24 mess with the fundamental, you know, aspects of the
25 regulatory structure, just, you know, focus on FFRD.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Anyway, it's maybe some thoughts. I think
2 like everybody said, the -- I think the justification
3 for the transition break size seems very well-founded.
4 And the idea of having a different regulatory approach
5 above the TBS seems perfectly reasonable.

6 It's just how do you do that without, you
7 know, blowing up the whole regulation? To me that's
8 where the biggest problem is.

9 CHAIR BALLINGER: More discussion?

10 MEMBER HARRINGTON: This is Craig. To Tom's
11 point, it seems to me that what's -- this gets into
12 the bigger discussion of the day. But it seems that
13 going and removing large break LOCA from the
14 regulations, that that's a huge lift.

15 But the approach that's presented in the
16 draft rule doesn't go remove it, it just starts to
17 chip away at its role and does so in a, what seems to
18 be a structured, thoughtful, controlled way with
19 reasonable guardrails and tools around that.

20 VICE CHAIR HALNON: This is Greg again. I
21 think certainly making a full blown removed large
22 break LOCA from regulations is one way of doing it.
23 But we've seen an a la carte approach in the past like
24 for alternate source term aspects where you go in and
25 you can change certain parts of your licensing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I don't think that -- or like for
2 containment pressure, that was a good example.
3 Containment's designed to 60 psi. Well, other than
4 maybe the integrated test that I do every 15 years
5 that I have to pump it up to 50 instead of 60, it
6 might be some savings.

7 But I'm not trying to change the design of
8 the plant, I'm trying to change maybe certain aspects
9 of my controls around that design that could provide
10 me some cost-savings flexibility with no degradation
11 in safety at all.

12 And my point is, you know, there's ways of
13 doing that. You don't have to go through and revise
14 every other regulation in Part 50 to do that. But you
15 can make it an option and say hey, if you want to
16 change this, you have a basis now to go and change it,
17 much like we did with the ultimate source.

18 So the -- again, there's extreme ways of
19 doing it and there's other ways providing benefit.
20 And you know, I get the incremental changes over time.
21 My point was we've got the environment now because of
22 the new set of reactors coming in, trying to save the
23 -- save, that's a good way of putting it. They're
24 trying to preserve the existing industry.

25 Now there's a lot of capital, political

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 capital, behind making a bold change. And I get it
2 that this is down the road a little bit, but it seems
3 to me that as an agency, we would want to not just say
4 yeah, there could be something next, but start working
5 on that next, with a mindset that -- And I get it Rob,
6 you got to -- you got to believe it can happen just
7 because you don't want it to happen. And I don't want
8 to, again, sound flippant on safety because it's not
9 a necessarily a so-what. But we still have our safety
10 trainings. We still have the equipment and the design
11 in the plant.

12 We're not going to let low pressure
13 injection phones get mothballs on it and say we don't
14 have to use them anymore so we're not going to
15 maintain them, we're not going to poke holes in a core
16 flood tank because I only need one instead of two.
17 You know, they're all going to be there.

18 But the operational flexibility, LCO times,
19 outage time. Other things can be quite advantageous.
20 I'm not suggesting that we don't monitor for the
21 problem. It seems like this is a time to do some bold
22 changes.

23 MR. MESSINA: I'll note that -- remember the
24 schedule. We did not have a ton of time for the
25 schedule. We tried to leverage existing frameworks,

1 steps have been previously vetted and well-
2 established.

3 VICE CHAIR HALNON: I think you guys have
4 done a great time in -- great job. As a matter of
5 fact, I've never seen this much work done in a short
6 period of time.

7 MR. MESSINA: Thank you.

8 VICE CHAIR HALNON: From what you all have
9 done. It's just rather than -- it seems like there
10 needs to be a phase II, and we need to start working
11 on that as well. And given two years, three years,
12 four years down the road, I don't know what the answer
13 is there, but at least acknowledge it and go. And
14 then say maybe.

15 CHAIR BALLINGER: More discussion?

16 DR. SCHULTZ: I'd just make a comment, and
17 that is that as we've just discussed here, that this
18 in fact in terms of a risk-informed approach, which is
19 all of what we've been talking about here, this in
20 fact is a bold move.

21 And as was mentioned by Walter, retaining,
22 retaining the inspection capability and responsibility
23 by the existing fleet is an important piece of that
24 when you think about dealing with not just those that
25 want to move forward with removing the event, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 dealing with those that wonder why we are able to make
2 this move.

3 And to retain the inspection capability that
4 has been established and the monitoring capability
5 that has been established is important. But part, I
6 think, of explaining why are we able to take this
7 approach and allow a lot of different improvements to
8 be made to the overall system in a risk-informed way.

9 CHAIR BALLINGER: And the reason we're able
10 to do this is because of the last 20 years of research
11 addressing issues --

12 DR. SCHULTZ: Exactly, we're taking full
13 advantage of that.

14 CHAIR BALLINGER: Again, just to not do that
15 would be almost stupid.

16 DR. SCHULTZ: I agree.

17 CHAIR BALLINGER: We ought to do something
18 like that. And the only thing that changes slower
19 than the Agency is probably the ASME code. So to
20 think that all of a sudden Section 11 is going to
21 allow no inspections? Not happening.

22 MR. RUDLAND: I would say it's not going to
23 happen, but they're moving towards that. Because in
24 a lot of cases, they are changing inspection
25 frequencies, right, so that there's longer time

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 between inspections.

2 CHAIR BALLINGER: But that would be
3 justified. I mean --

4 (Simultaneous speaking.)

5 MR. RUDLAND: -- justification for it all,
6 but I'm just saying is that there's efforts ongoing
7 that are looking to how to optimize these inspections.
8 Because again, the ten year inspection interval and
9 stuff. There was no real basis for all of that,
10 right.

11 It was just a bunch of guys sitting in a
12 room, a bunch of guys and gals sitting in a room and
13 saying ten years is about right. Boilers fail in
14 about ten years, you know, so a ten-year inspection is
15 good.

16 CHAIR BALLINGER: So now we have a new bunch
17 of guys and gals sitting in a room saying --

18 MR. RUDLAND: I don't know -- they're using
19 a little bit more sophisticated computers, but --

20 CHAIR BALLINGER: Okay, unless there's more
21 discussion.

22 MEMBER PETTI: So the only thing -- yeah,
23 this is Dave -- on my list was this comment from one
24 of our members about analysis. That somehow in
25 guidance, there should be a focus on what the analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 be for beyond the TBS should focus on. Like defense-
2 in-depth and containment analysis.

3 I just ask the member who wrote that, expand
4 on my cryptic notes on that.

5 Bob, Bob. Bob.

6 MEMBER MARTIN: There are two aspects of
7 that, I think. One is the containment analysis, which
8 I did mention. The other one I think belongs more
9 under FFRD, which is the role of the best estimate
10 analysis in --

11 MEMBER PETTI: That's coming.

12 (Simultaneous speaking.)

13 MEMBER MARTIN: -- in FFRD is precluded. Or
14 if we were to, yeah, include that we were favoring an
15 approach that precludes FFRD as opposed to, you know
16 allow, again, modeling. But then the fidelity of the
17 modeling becomes more important. I think I will defer
18 that part of the --

19 MEMBER PETTI: Yes.

20 MEMBER MARTIN: -- of that comment to the
21 next topic.

22 MEMBER PETTI: That's on my list for FFRD.
23 It was Bob who had this comment, so.

24 MEMBER MARTIN: Right, and some of it was
25 just kind of teeing off some of the comments Tom had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 last time. I mean, the top one seemed to be the
2 ambiguity associated with the definition of best
3 estimate when you're in this space.

4 MEMBER PETTI: We'll talk about that.

5 MEMBER MARTIN: Right, so I didn't know when
6 we were going to, you know, work that into, but yeah,
7 that kind of opens up the whole conversation about
8 what is in analysis. So I don't know if it goes here
9 in the discussion, I don't know how we're organizing
10 it.

11 MEMBER PETTI: I put it into FFRD, so.

12 MEMBER MARTIN: You put it into FFRD, okay.

13 MEMBER PETTI: Yeah, yeah, so we can wait.

14 Okay, then that at least -- the other
15 comment I have is that members who made comments in
16 the first round should go back and decide if they
17 still want the comment to stand, or based on this
18 discussion they want to, you know, rework their
19 comment, or they want to, you know, they're satisfied
20 and they don't want it as a comment.

21 Because we're going to come up with a, sort
22 of a boiled-down list of, as I view the letter, you
23 know, we're going to just have things that the staff
24 should consider as they're also obtaining public
25 comment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 CHAIR BALLINGER: Okay, more comments?
2 We're scheduled for lunch at noon, and if this were an
3 academic faculty meeting, we would be forced to
4 discuss until noon. But we're not. So in the next
5 presentation is with the industry and EPRI.

6 And so I would propose that we stick to that
7 schedule and recess until one o'clock, at which time
8 the industry and staff presentation will happen. So
9 unless there are other comments that we need to
10 consider --

11 MEMBER PETTI: Could we just -- could we
12 have Weidong make -- email to the members my binning
13 so that they can see how we're going to keep it
14 focused this afternoon?

15 CHAIR BALLINGER: I think we have it.

16 MEMBER PETTI: Okay, okay.

17 CHAIR BALLINGER: I think we have it. For
18 the public, though, this thing that we're talking
19 about is in the ADAMS, but it's not public yet but it
20 will be. So I don't know when that's going to happen.
21 But that color-coded table, if you want to call it
22 that, is going to be available.

23 MEMBER PETTI: Okay.

24 CHAIR BALLINGER: Okay, once again, let's
25 recess until one p.m.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 (Whereupon, the above-entitled matter went
2 off the record at 11:31 a.m. and resumed at 12:59
3 p.m.)

4 CHAIR BALLINGER: We're back in session and
5 we're going to hear from the industry/EPRI folks, I
6 should say gang, but anyway, the floor is yours.

7 MR. CSONTOS: Okay, thank you.

8 CHAIR BALLINGER: Well, I don't know who's
9 going to speak first so.

10 MR. CSONTOS: Yes, I'll go ahead and speak
11 first and then we have basically a chorus here. We
12 had heard the interest, and also hearing about the
13 industry plans and strategic plans, so we have four
14 utilities that will provide an update on their plans
15 to give you a microcosm of what's going around the
16 industry.

17 I'll give you one slide that talks about it
18 generically, but you're going to hear from four
19 different utilities specifically. Both their
20 interests and what they're planning to do but also the
21 concerns that they have. Okay?

22 We have also have the BWR and PWR Owners
23 Group represented here as well and EPRI represented.
24 EPRI will be presenting on the ALS after this
25 discussion, but we also have Brian Mount from the BWR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Owners Group and Baris Sarikaya online, who is also a
2 representative of the BRW Owners Group and, Brian,
3 you're on the PWR's group, sorry.

4 We also have two members who got COVID last
5 week and so that's why they're not able to be here in
6 person, but they'll be online to answer any questions.

7 VICE CHAIR HALNON: Your chorus needs to
8 sing their name before they start.

9 MR. CSONTOS: Sure. Al Csontos, NEI
10 director, fuel.

11 CHAIR BALLINGER: Remember, we have until
12 2:15 so you don't have to speak like normal radio
13 announcer that speaks at 500, 1,200 watt or something.

14 MR. CSONTOS: Okay. Let me go to the next
15 slide. What are our key messages? LARs are coming.
16 They're coming for both advanced fuels and that's what
17 the latest ADVANCE Act changes. Both advanced fields
18 are, quote, advanced reactors fuels, but it is also
19 talking about ATF requirements for higher burnup. So,
20 now they're tied together. There's a section on the
21 ADVANCE Act for fuels and so what you're seeing here
22 is plants are already looking to implement some of the
23 ATF dopants as early as 2026 as deployments and going
24 on after that to '27, '28 and we have a graphic. It's
25 more just pictorial but it shows that after 2026,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 we're starting to see basically a ramp-up of these
2 LARs coming in for advanced fuels.

3 Now, I'll go ahead and talk about uprights
4 and the connection between that and the advanced fuels
5 and how it connects the IE -- the advanced notice for
6 rulemaking, but the key here that we want to make sure
7 that we express to you all is that the rule and
8 schedule is really important to those strategic plans.
9 You'll get more of that from the utility members in a
10 second here.

11 We did appreciate that you all had that
12 meeting in December. We did present after everything
13 was over on the reg guide 1.183 and we did see a lot
14 of positive and appropriate improvements in the rules.
15 There are still some major concerns and we'll go into
16 them today. We did have this letter and we wanted to
17 make sure that that letter is shared with the ACRS
18 members. Their ML was down there.

19 This is a letter that we sent to them back
20 in March 2023 as a follow up to the Commission ATF
21 briefing that we had with the Commission and there
22 were some questions asked about 50.46c. We responded
23 and provided some feedback and how we thought the
24 50.46a and 50.46c could be modernized and incorporated
25 to the increase in regulatory rule making. Those were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 some comments we made way back then and a lot of them,
2 I think, are apropos to what we heard today and also
3 back in December. We wanted just to highlight that we
4 had that letter.

5 The second to last bullet here just
6 highlights to meet the schedule, we really would like
7 to have this public comment period, this rule to go
8 out for public comment, so that we can start engaging
9 with the staff, maybe even providing white papers and
10 whatnot on a variety of these topics that we're
11 hearing about today. Similar to reg guide 1.183,
12 where we had multiple workshops after rev one came
13 out, we had those engagements.

14 What it did, was really it highlighted -- it
15 did a lot that before the ADVANCE Act came out, we did
16 a lot of those workshops before the ADVANCE Act came
17 out, but what it did was really create those
18 efficiencies and talk about implementation with the
19 staff to get a better reg guide 1.183 in rev two.
20 Next.

21 What are the benefits that we see? One, it
22 enables the improved safety with less generated waste
23 and Fred will talk about that with respect to the 24-
24 month cycles. It allows the increased enrichments to
25 LEU+ to 10 percent enrichment. The UF6 packet that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a big deal right there when Jason Piotter at the
2 December meeting talked about what they were doing
3 there with the UF6 packet being approved up to 10
4 percent. That saves a significant amount of effort
5 and time in getting the enriched products to the
6 market.

7 The improved risk informed control rule,
8 those design criteria, those that were changed, those
9 were very useful and also very risk-informed. Those
10 were really a really good by the staff. Reg guide
11 1.183 also was a fantastic job by the staff. More
12 realistic modeling and also considerations of all the
13 things that we talked about in those workshops and
14 those workshops did a great deal to develop more
15 predictable, durable, and also usable guidance by the
16 industry.

17 We talked about it this morning a little
18 bit, this openness to large break LOCAs beyond design
19 basis. I know that we may be disagreeing over some of
20 the particulars and the details, but the NRC staff's
21 openness to consider large break LOCA as a beyond
22 design basis event has the potential for both existing
23 and new reactors for major improvements.

24 Lastly, the work that the staff did on
25 NUREG-2266, think of the showing of the GEIS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 throughout there were okay to be used and not having
2 to be redone other than a weight percent enrichment
3 and 80 gigawatt-days burn up was a big deal. That
4 really saved us a lot of time. We were very concerned
5 about that.

6 Nevertheless, we're here to talk about some
7 of the areas that we see that remain deterministic,
8 prescriptive, and really not risk-informed with
9 additional burdens and you're going to hear this from
10 the utility members about the high uncertainty to
11 implementation.

12 I don't want to belabor this. We've briefed
13 you on this in the past, but basically the advanced
14 fuels are complementary to uprates in some cases and
15 you're going to hear that from a couple of the
16 utilities today about how they're trying to employ
17 both. We believe that this has got an improved safety
18 basis from the current fuel and also we believe that
19 we're moving forward and the LARs are coming. They're
20 already started. We have plans to deploy and that's
21 where we're moving forward with this and we're hoping
22 to get the IE rulemaking done by 2027 to support those
23 strategic aspirations of the industry.

24 At a high level, 70 percent of the plants,
25 and it's probably more than that now, more and more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 plants are getting involved. This is the latest as of
2 last fall, 70 percent of the plans out there have an
3 interest in doing power uprates, up to 3 gigawatt
4 electric. That has gone from 2 a year ago, to 2-1/2
5 half a year ago, to 3 now. If I did it again this
6 summer, I'd probably go up a little more. Nearly half
7 of the fleet are also looking into ATF/LEU+ higher
8 burn up and the 50.46a risk-informed LOCA type of
9 analysis approach.

10 With that, I wanted to turn to our utility
11 colleagues for their perspectives.

12 MR. STAVELY: Jim Stavelly, nuclear fuels
13 director, PSEG. PSEG is concerned about the 50.46a
14 rule --

15 CHAIR BALLINGER: Can you speak a little
16 closer to the --

17 MR. STAVELY: Is that better?

18 CHAIR BALLINGER: Hopefully.

19 MR. STAVELY: Okay. PSEG is concerned that
20 the draft 50.46a operations --

21 (Simultaneous speaking.)

22 MEMBER KIRCHNER: Ron, this is Walt. Could
23 we ask the speakers to identify themselves and use the
24 microphone? Get the microphones closer. Thanks.

25 CHAIR BALLINGER: Message transmitted.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. STAVELY: Okay, this is really close.
2 Is that much better?

3 CHAIR BALLINGER: Yes.

4 MR. STAVELY: Okay, Jim Stavely, Nuclear
5 Fuels Director, PSEG. Good afternoon.

6 PSEG is concerned that the draft 50.46 rule
7 and supporting regulatory guidance as currently
8 written may not support implementation of increased
9 enrichment and higher burn ups required to achieve 24-
10 month fuel cycles. It may also impact the
11 implementation of advanced fuel designs. Portions of
12 proposed requirements and processes are not risk-
13 informed, do not sufficiently leverage existing risk-
14 informed processes and would create a burden reducing
15 and perhaps eliminating the basis for implementing the
16 voluntary rule.

17 Some aspects originally defined require
18 significant analysis, do not provide sufficient
19 flexibility and alternative approaches and create
20 significant regulatory uncertainty. As an example of
21 alternate approaches, the draft focuses on alternate
22 2, as we heard this morning and back in December,
23 utilizing transition break size without providing
24 guidance for potential implementation of Alternatives
25 4 and 5. As drafted, this rule does not effectively

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 support BWRs. Modified attached Alternative 4
2 supports both BWRs and PWRs, EPRI ALS, we'll talk
3 about again a little bit later, already under review
4 by the staff supports modified Alternative 5 for PWRs.

5 Examples of burdens include the requirements
6 for additional inspections as we discussed this
7 morning with the associated increase in dose, as well
8 as the creation of a new risk assessment process to
9 evaluate plant changes for potential 50.46a impact.
10 We recognize that the rulemaking schedule does not
11 permit resolution of all these issues, but critical
12 changes are required to improve the potential for
13 implementation.

14 Utilities are actively planning and we're
15 making commitments that depend upon meeting the
16 rulemaking schedule with a rule and supporting
17 guidance that are implementable. Without changes to
18 the rule and the supporting guidance, these plans will
19 likely be reassessed. The changes should be made
20 prior to the comment period if possible, as we
21 discussed the potential for the workshops, to ensure
22 that the rulemaking is completed on schedule. The
23 upcoming presentation will discuss the industry's
24 perspective and some of these required changes.

25 With respect to the path forward and Al did

1 mention it and it was mentioned this morning as well
2 by staff, is we recommend an approach similar to
3 revision 2 to reg guide 1.183. I have been the
4 industry sponsor for that revision to the reg guide
5 and this approach worked very well. It encouraged
6 active and constructive interaction with the result
7 being more effective, implementable, risk-informed
8 regulatory guidance while maintaining the focus on the
9 health and safety of the public.

10 In closing, we have been making plans and
11 decisions based on the assumption that the IE
12 rulemaking process would result in implementable
13 regulatory structure and maintain the attractiveness
14 of implementing 24-month fuel cycles and advanced fuel
15 designs. Based on the current drafts, we have some
16 doubts whether this assumption is still valid. Thank
17 you.

18 MR. CSONTOS: Tara for Duke.

19 MS. MATHENY: Good afternoon, can you hear
20 me okay? All right. Good afternoon, I'm Tara
21 Matheny. I work with Duke Energy and I am the fuel
22 cycle extension project manager.

23 Duke Energy is currently making investments
24 in its nuclear fleet to pursue fuel cycle extensions
25 for five units and to add approximately 250 megawatts

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of capacity through power uprates for the next six
2 years. We are concerned with the draft language, the
3 timing of the final rule and the uncertainty of the
4 implementation requirements.

5 Duke Energy is planning to have the first
6 24-month core online in the spring of 2029. These
7 cycle extensions and power uprates are a foundational
8 part of Duke Energy's plan to reliably meet current
9 and future customers' energy needs and achieve the
10 company's carbon reduction goals. This plan has been
11 submitted and approved by the North and South Carolina
12 Public Utilities Commissions.

13 We look forward to the presentation of the
14 challenges that the industry has identified with the
15 draft rule language that if not adequately addressed
16 by the staff would result in our need to reconsider
17 our strategy to meet these commitments. Thank you.

18 MR. CSONTOS: Thank you, Tara. Jonathan for
19 Southern.

20 MR. CHAVERS: Good afternoon, this is
21 Jonathan Chavers, director nuclear fuel analysis at
22 Southern Nuclear, speaking.

23 As Southern Nuclear has demonstrated with
24 our licensing engagements and our numerous lead test
25 assembly programs to date, our fleet has intentions to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 leverage ATF technologies, including increased
2 enrichment and burn up extensions. Based on our
3 experiences to date and scoping for future reload
4 applications, Southern believes this rulemaking is
5 timely and the scope is aligned with our means.
6 Across stakeholders in commercial nuclear fuel,
7 engineering work and investments are underway which
8 aligns our planning schedules with the assumption that
9 the increased enrichment rulemaking and supporting
10 regulatory guidance is complete in accordance with the
11 Commission-directed schedules.

12 The substantial efforts by the staff and
13 industry cannot be understated in the progress made to
14 date. It is important that this rulemaking is
15 structured with the durability for decades to come in
16 the future. That being said, as was discussed this
17 morning, we fully anticipate that some of the
18 regulatory guidance will be a living product that will
19 evolve as our understanding grows in the expanded
20 operating domains of the future.

21 The codified language should exhibit
22 adequate durability to facilitate many of the future
23 states possible as discussed this morning. Our most
24 substantial concerns about the viability of the
25 proposed regulatory infrastructure and proposed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 implementation burdens, they do not appear to have a
2 strong technical basis or align with maintaining or
3 increasing the existing safety performance.

4 Industry experts will give you much more
5 detail than I will right now in the subsequent
6 presentations, but in general there are three broad
7 areas of note: Implementation burdens. An example is
8 the increased inspection frequencies, expectations for
9 established programs potentially resulting in
10 increased occupational dose for our workers. There is
11 missed opportunity for more generic assessments. Some
12 of the proposed plant-specific analyses supporting
13 activities that could be generically addressed by
14 industry or generically addressed together, increase
15 the burden for all stakeholders without a demonstrated
16 safety benefit and the discussions around risk-
17 informed applications. The potential for more
18 restrictive risk-informed change framework that's
19 currently in use does not seem to be prudent or
20 justified.

21 Southern has demonstrated that licensing of
22 enrichments above 5 weight percent uranium-235 and
23 commercial nuclear power reactors is possible. We've
24 done that for lead test assemblies within the existing
25 regulatory infrastructure. However, based on our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 experience and future scoping, this approach that we
2 took for these lead test assemblies is not an
3 efficient use of resources for NRC or industry to
4 implement reloads or enable broad industry adoption of
5 higher enrichment technology prior to the completion
6 of the increased enrichment rulemaking.

7 That being said, utilities will make every
8 effort to make our commitments to our stakeholders.
9 In a final rule delay situation, it could result in a
10 large number of exemptions or a disparate licensing
11 submittals, which could be mitigated through timely
12 issuance of this rulemaking and associated regulatory
13 guidance. That being said, this is a clear example of
14 this rulemaking being implemented on the timelines
15 proposed and associated guidance to correspond with it
16 per the Commission-directed timelines would embrace
17 the mindset as described in the ADVANCE Act. Thank
18 you.

19 MR. CSONTOS: Thank you, Jonathan. Baris
20 for Constellation.

21 MR. SARIKAYA: Good afternoon, my name is
22 Brais Sarikaya, principal engineer, Constellation.
23 I'm also the BRW Owners Group safety analysis
24 subcommittee chair.

25 The draft rule has great potential for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 industry, especially for those utilities considering
2 power uprates, cycle extensions, and/or high burnup
3 increased enrichment implementation. It also provides
4 a potential to improve operating units for some of
5 those LOCA-limited stations.

6 Maybe more importantly, an opportunity to
7 focus on the right area to improve plant safety where
8 it matters the most. We are also encouraged with the
9 discussion around combined license applications. Just
10 like the previous utility members discussed earlier,
11 Constellation is also considering power uprates, MUR,
12 and/or cycle extension potentials within the fleet.
13 We appreciate the level of flexibility available to us
14 in the draft guide; however, we are equally concerned
15 about the uncertainty around the implementation
16 requirements for some of those flexibility options.
17 For example, we do support ALS for PWRs, that's a
18 great path forward; however, lack of a similar
19 solution path for BWRs concerns us.

20 Indeed as discussed earlier, lack of BWR
21 considerations is a common theme for a number of
22 areas. For example, the requirements to identify
23 transition break size or demonstrate applicability of
24 NUREG-1829 and -1903 to the individual stations are
25 challenging. We are concerned about the uncertainty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 in this area, especially for those plans as we heard
2 this morning that do not currently have leak before
3 break approach.

4 We believe Alternative 2 has great
5 potential, as I mentioned at the beginning of my
6 discussion, for large break limited PWRs and BWRs, but
7 it does not consider the fact that we have small break
8 limited LWRs in our fleet. Therefore, we believe the
9 modified Alternative 4 as proposed by NEI and PWR
10 Owners Group should be considered as part of this
11 discussion. If you look at even the basis document,
12 this option is technology-neutral and could benefit
13 both BWRs and PWRs.

14 Overall, we are hopeful with this efforts,
15 but concerned about the unpredictability in
16 implementation which, as discussed several times
17 earlier, significantly increases uncertainty and risk
18 for major projects, such as power uprates. We are
19 looking forward to the detailed discussion later today
20 and further collaboration in future workshops. Thank
21 you.

22 MR. CSONTOS: Thank you, Baris. What we're
23 going to do next, we're going to have Victoria talk
24 about the LOCA risk significance.

25 MS. ANDERSON: Thanks, Al. Victoria

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Anderson, a technical advisor for engineering and risk
2 at NEI. Risk-informed regulation calls for us to
3 examine the plant and focus on what's most important
4 to plant safety, which is what we've used risk-
5 informed regulation for, and if you look at the graph
6 on the top right there, that's a graph of the average
7 industry CDF starting in 1992 and going through, I
8 think it's 2020.

9 In that time, we've decreased CDF by a
10 factor of 20 and that's in large part due to the risk-
11 informed programs that are highlighted above. The
12 graph comes from NEI-20-04 if you're interested in
13 more details and what goes into this. The units on
14 the left are just the baseline average CDF of 1992, so
15 it's just showing a comparative average CDF. Keeping
16 that lens for our regulatory oversight and operational
17 activities is vital to continuing that kind of
18 progress and continuing to drive down the CDF and
19 improve plant operations.

20 For this specific activity, we're interested
21 in the context of LOCA contributions to total plant
22 risk. We took a look at a NUREG on initiating events
23 to look at the relative contribution and found that
24 the relative contribution of LOCA events is under one
25 percent of the total core damage frequency and we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 confirmed that this comports with currently licensee
2 PRA models. So, you're looking at less than one
3 percent.

4 Also, consider the that NUREG is from a time
5 that's over towards the left side of that graph so the
6 actual CDF impact is even lower than would have been
7 suggested by that NUREG. Adding even more into that
8 insight on the relative contribution of LOCA events to
9 total plant risk is that our PRA models are more
10 detailed and higher quality than they were 20 to 30
11 years ago and on that left side of the graph, so we
12 have even more confidence in our results and more
13 confidence in our PRA models than we did when this
14 portion of the rule was initially developed.

15 You can also see this continued improvement
16 in the increased capacity factor which is on the
17 bottom right. We've gone from the low-60s to the mid-
18 90s in the past 45 years and overall plant
19 reliability, as you can see from that, has improved
20 substantially no doubt with much credit due to risk-
21 informed regulation.

22 When you add of this together, it shows that
23 it is reasonable to treat these as beyond design basis
24 events and it is, in fact, in the best interest of
25 overall plant safety to do based on what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 information we have from the plant PRAs tells us.
2 That's to say we can't ignore it, but it may not be
3 where we need to devote a large amount of our focus in
4 maintaining CDF operation of the plants and as part of
5 a risk-informed regulatory frame work, which has
6 enabled safety and operational improvements fleet-wide
7 for several decades, we need to be mindful of where we
8 devote our attention.

9 VICE CHAIR HALNON: Victoria, where's the
10 footnote, any time you have a number there you get a
11 footnote. Is that a --

12 MS. ANDERSON: I have a foot -- oh, no
13 that's per year inverse year. It's not a footnote,
14 it's a minus one.

15 VICE CHAIR HALNON: It's a minus one? Oh,
16 okay.

17 MS. ANDERSON: Yes.

18 CHAIR BALLINGER: A very faint minus one.

19 MS. ANDERSON: Yes, sir. Sorry. I think we
20 needed to -- yeah, it looks like a big R with a one,
21 but it's a minus one.

22 VICE CHAIR HALNON: Okay, got it.

23 MS. ANDERSON: We need a darker font.

24 MR. CSONTOS: Okay, so next please
25 understand that the feedback we're going to give you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 is early. We want to get this into the public comment
2 period so that we can provide more details and we were
3 even thinking about writing a letter with more details
4 in it. This is really a review of what we saw back in
5 December. It's about a month and really we had last
6 week to see 14.28, so what you're going to see here is
7 very early. With that, I'm going to turn it over to
8 Brian.

9 MR. MOUNT: Good afternoon, my name is Brian
10 Mount. I'm a consulting engineer at Dominion Energy.
11 I'm also the analysis committee chair for the
12 Pressurized Water Reactor Owners Group.

13 You heard mention earlier that the public
14 workshops on the reg guide 1.183 revision led to a lot
15 of benefits. Those benefits are going to help with
16 our implementation as well of that reg guide and the
17 NRC review of our implementation because we're
18 following the guidance, we're not having to take
19 deviations from it. We are looking forward to
20 additional public workshops on the following areas.

21 For the first slide, the 2010 draft 50.46a
22 had a substantial implementation burden and we feel
23 that a lot of that burden still remains in new draft
24 rule package. Now granted, this was also from what we
25 read in the draft rule language and in the DG. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 was before we had seen the NRC's presentations. We
2 feel that one of the areas that there could be some
3 implementation burden relaxation is in the risk-
4 informed evaluation process.

5 We've mentioned that there have been several
6 regulatory interactions in the risk arena that could
7 benefit from the efficiencies and the learnings we
8 have gained such as risk-informed tech spec completion
9 times. The draft rule does still require the low
10 power and shutdown PRA models, which the industry had
11 addressed with the NRC passed 2010 alpha rule and that
12 was with the interactions on the NUMARC 91-06.

13 Similarly, the 50.46a(h), the risk-informed
14 process paragraphs in the regulation duplicate a lot
15 of the information that is in reg guide 1.200 and
16 1.74. This duplication does not appear to be
17 necessary from the industry's perspective because the
18 information has been in the reg guide and we've been
19 following it. Those reg guides, as they continue to
20 evolve and be updated, it could create a difference
21 between what's in the LOCA rule for defense-in-depth
22 and risk-informed regulation compared to what would be
23 the reg guide's which are going to be updated to keep
24 improving with our state of knowledge. Next slide.

25 Another item is that the NRC robust PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 management program that we submitted as part of our
2 license renewals, we do not feel that those were
3 getting significant recognition in the draft guide
4 language. Following the NRC's presentation and
5 hearing their perspectives on it, we'll go back and
6 relook at the language. Again, this was informed out
7 of what we read in the rule language and read in the
8 draft guide and was not informed with our interactions
9 or based on interactions from the NRC staff.

10 DG-1428 does acknowledge that the industry
11 did significant seismic risk assessment following the
12 Fukushima-Daiichi event. That was highlighted in the
13 NEI letter. Victoria, do you have the specific item?

14 MS. ANDERSON: Yes, so as we've noted that
15 rule language was developed back in 2010 which was
16 before any of that work was done, so it would be
17 logical to update that language and that approach to
18 reflect the work that's done so that we don't need to
19 either duplicate work or potentially conflict with
20 work that has already been done and already been
21 accepted by the NRC.

22 MR. MOUNT: As far as the additional in-
23 service inspection frequency requirements, the way the
24 industry had read what was in the rule language in the
25 draft guide previously was that this would be in

1 addition to the sampling of 10 percent of the welds in
2 pipes larger than the transition break size was going
3 to be, in addition and above the 10 percent of the
4 sampling we currently do as our ISI programs. We had
5 considered that to be not consistent with risk-
6 informed regulations with the clarification that staff
7 provided that that was meant to be substituted into
8 part of your risk-informed inspection programs, we
9 will be reconsidering that. Regardless, the welds
10 that we've selected this time are based off of our
11 plant-specific risk profiles. Areas where we already
12 know have the high stress so to replace the welds that
13 we're currently inspecting with other welds that are
14 above the transition break size does not seem to be
15 consistent with how we want to implement a risk-
16 informed regulation.

17 CHAIR BALLINGER: This is Ron Ballinger. I
18 thought this morning we had a discussion about this
19 that the difference between 10 percent and 10 percent
20 might be overlapped but not separated.

21 MR. CSONTOS: Yes.

22 CHAIR BALLINGER: So, it's not like all of
23 a sudden you've got to find 10 percent more welds to
24 --

25 (Simultaneous speaking.)

1 MR. CSONTOS: That's where we were -- we
2 didn't have the indication back then. We only had
3 this last Tuesday, I believe, so we only read what we
4 read and we thought that's what was meant with the
5 official --

6 CHAIR BALLINGER: Okay, so that's been
7 cleared up as far as I'm concerned.

8 MR. CSONTOS: That's what Brian was talking
9 about. The other part to this was that the hard
10 wiring, that 10 percent number, into -- codifying it
11 into the rule, I'm not sure if that's a wise thing
12 either. That's something where you have a learning
13 aging management program where you assess what you get
14 and then you change as a function, that's all that
15 aging management programs do.

16 But requiring 10 percent, it's kind of going
17 outside of what ASME code is doing as well as what a
18 learning aging management program would do, it's to
19 hard wire it into the rule language. There may be
20 other ways to address it, but just hard wiring it in,
21 it just seems like it's a little too far.

22 MR. MOUNT: And similarly, as we had read
23 through the options in the draft guide, we had not
24 seen as much credit as we would have liked to have
25 seen for the leak before break program. That will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 another item that we, as the industry, will have to go
2 back and look through again and hope as we go through
3 workshops with the NRC staff, we can make sure that
4 our concerns are heard and make sure we have the
5 language clean and clear for our constituents.

6 I think a number of the items on this can be
7 cleaned up through the workshops with the NRC to make
8 sure that what we're reading and what they intended
9 that we get that from what the words are in there.

10 MR. CSONTOS: Right, and I'm crediting, you
11 know, we have susceptible welds. We have non-
12 susceptible welds. We have unknown unknowns is what,
13 I think, the term novel degradation means and in that
14 way, you might be able to sample other welds that are
15 of similar types that also have the same potential
16 degradation mechanisms in the future. You don't have
17 to go with just the largest lines out there beyond VBS
18 to get to understanding whether you have a degradation
19 mechanism.

20 On top of that, there are a lot of things in
21 there that could be helpful to have a workshop to
22 discuss what this looks like and what's palatable in
23 terms of making sure we have an eye to dose and --
24 dose to workers, and what is an optimized approach to
25 look at what the NRC is trying to address in this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 inspection.

2 VICE CHAIR HALNON: Brian, this is Greg.
3 Your first bullet up there, NRC clearly looked at
4 aging management. We used aging management that's not
5 credited, but to use the adjective robust, which is a
6 very bad thing to do because now I'm going to ask you
7 what above and beyond guidance in your aging
8 management programs deserves more credit in the NRC's
9 giving it? Typically, every license renewal aging
10 management program we see come in leads to guidance.
11 Are you saying that the robustness is beyond the
12 guidance? Are you going well beyond it? That's what
13 it implies.

14 MR. MOUNT: So --

15 VICE CHAIR HALNON: Or do you want to take
16 that word back?

17 MR. MOUNT: That's probably a better way to
18 do that would be probably to look to take that word
19 back out of this slide, but if it's already put in.
20 Al, was there anything particular that we were going
21 with, with the robust word there?

22 MR. CSONTOS: I think that it was just meant
23 to highlight that there are --

24 VICE CHAIR HALNON: You might use colors
25 instead of adjectives --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. CSONTOS: Yeah.

2 VICE CHAIR HALNON: That don't necessarily
3 -- okay, I just wanted to make sure because the NRC
4 does talk about the first block in their program
5 process for 1829 was aging management programs.

6 MR. CSONTOS: So, that's where it gets
7 that, you see it on the flow charts and what does
8 constitute acceptance in those blocks. And when you
9 have that basically analytical gauntlet there, I heard
10 someone talk about the analysis paralysis at the last
11 -- in December's meeting, and those flow charts what
12 constitutes -- is it just a check box? We don't know
13 and that's the thing here. We saw the presentation
14 this morning. We haven't had a time to discuss what
15 are the expectations from the staff. Are these check
16 boxes that do you have an aging management plan,
17 that's easier or is it how robust is your aging
18 management plan? What do those boxes constitute? In
19 that way, there are differences into how we would
20 respond based upon what the expectations are from
21 staff.

22 VICE CHAIR HALNON: That's where the
23 workshops will come out --

24 MR. CSONTOS: Correct.

25 VICE CHAIR HALNON: -- for a brief which I

1 heard them say they want to have. While I've got the
2 floor down over to Walt because he has a question for
3 the industry folks, is the schedule inflexibility that
4 you all are kind of alluding to a combination of
5 business plan an added schedule? Is that -- basically
6 you have a five-year or 10-year plan, it's pegging
7 things on different added schedules and schedules
8 obviously can't change on the outages all that much.
9 Is that basically it? Each one of you said something
10 about schedule and plans and stuff like that.

11 MR. STAVELY: Yes, Jim Stavely with PSEG and
12 the answer is yes. It includes the sequencing of the
13 activities for the outage schedule, because that -- it
14 means we have to coordinate the multiple refueling
15 outages and staff and all the resources.

16 VICE CHAIR HALNON: And typically you design
17 your cores about, what, a year in advance to get the
18 orders in?

19 MR. STAVELY: We do design them in advance.
20 We also have to provide in advance all of the uranium
21 conversion enrichment requirements for that, also in
22 advance of that is (audio interference) markets, so it
23 all influences -- it's a very integrated schedule.

24 VICE CHAIR HALNON: Okay. I wanted to get
25 that on the record because I knew that there was a lot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that goes into these dates well before the date that
2 you're talking about.

3 MR. CSONTOS: And let me just add one thing.
4 Tara, you might add to this if you want. What we're
5 talking about also is when you do a fleet-wide
6 implementation of this, it's not just the event for
7 that first plant, it's every other plant and if you
8 miss that first one, you then cascade down 18-, 36-
9 month delays. If we miss this time frame, we could be
10 with that fifth plant, for example, that Tara was
11 talking about, you could be out, way out there. It
12 could change the entire plan that you have with the
13 PACs.

14 VICE CHAIR HALNON: And you're spending your
15 resources on things that you shouldn't be --

16 MR. CSONTOS: Exactly.

17 VICE CHAIR HALNON: Because it's going to be
18 down, okay. Walt, I'm done if you wanted to go.

19 MEMBER KIRCHNER: Yeah, thanks, Greg. Just
20 looking at these both, they kind of all make sense to
21 me and it would be interesting to hear how industry
22 would suggest improvements to 14.28.

23 I just wanted to ask on the last bullet, how
24 many plants have approved LBB programs? Just a rough
25 order number.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. CSONTOS: I believe all the PWRs. I'm
2 looking at Dave Rudland. He knows best.

3 MEMBER KIRCHNER: That's what I thought.

4 MR. CSONTOS: Except for one PWR, I believe.

5 MR. RUDLAND: At least one PWR.

6 MR. CSONTOS: Yes, one PWR that hasn't
7 gotten LBB, but no BWRs and to the point this morning,
8 I think there was a question about mitigation, all the
9 BWRs do hydrogen water chemistry, noble metal
10 chemistry, that's a mitigation. In that way, I think
11 that we could probably go with getting LBB hopefully
12 approved for BWRs with two mitigations and many of
13 them have MSIVs and overlays on the other susceptible
14 lines. So, maybe there's a way there, but that's
15 something that as, I can't remember who brought it up,
16 oh, Jim, I think you brought up option 4, Alternative
17 4, as another way for the BWRs.

18 MEMBER KIRCHNER: Yeah, so on the first sub-
19 bullet here, do you feel that the industry has
20 addressed this generically after Fukushima or -- I'm
21 just trying to see how you would envision modifying
22 14.28.

23 MR. CSONTOS: We have a -- the parentheses
24 has the -- I gave an ML earlier in the presentation,
25 the first page, first slide. We had a letter that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 sent in and we had a full paragraph and a half
2 basically that we can provide to you on what the
3 recommendation was.

4 MEMBER KIRCHNER: Great.

5 MR. CSONTOS: And so, you know --

6 CHAIR BALLINGER: I think --

7 (Simultaneous speaking.)

8 MEMBER KIRCHNER: Okay. Weidong, could we
9 get this letter? Could the members get this letter
10 that NEI is referring to?

11 MR. WANG: Okay.

12 MR. CSONTOS: Yeah, they're actually in the
13 summary slides. I have two letters. The first letter
14 was what we did back in March of 2023 which is this
15 attachment. This NEI 2023 Attachment 1. Item two is
16 the bullet that has that recommendation. Then there's
17 a second letter that we sent in for the reg guide
18 basis. The BWR Owners Group, PWRs Group, the fuel
19 vendors and the utilities agreed on, it's an NEI
20 letter and this is where we suggested option 5 and
21 option 4; modified 5, modified 4 depending upon what
22 4 did. Four could help us with the BWRs fairly
23 quickly we think.

24 Option 2 at the time was not considered
25 because it was this longer term concept and then the

1 staff has done a lot of work in a short period of time
2 to try to get 2 brought in now and I think that that's
3 where we getting some of these. There are areas that
4 I think we can work on to get a better implementation,
5 but longer term there's that longer term getting a
6 large reg on a design basis like you were talking
7 about this morning. That's what we wrote in the
8 letter.

9 MEMBER KIRCHNER: And then on the second
10 sub-bullet, you have specific suggestions on targeting
11 the inspections to perhaps address the kind of
12 vulnerabilities that the staff was concerned with in
13 going to TBS.

14 MR. CSONTOS: We had a dialogue this morning
15 while we were listening to the presentations going
16 back and trying to decide how to go about looking into
17 that exact question. Like, how do we go about
18 optimizing this for minimizing dose but getting what
19 NRC needs, if they feel like they need it for this
20 activity. But it's going to be something that we have
21 to do in the future.

22 MEMBER KIRCHNER: Yeah, well to your points,
23 I mean for the staff as a challenge to craft an
24 enduring rule that supports your needs as well as the
25 staff's assessment on adequate safety, so any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 constructive things for each of these sub-bullets
2 would, I'm sure, be welcome in the next phase when you
3 go to the public comment period. Thank you.

4 CHAIR BALLINGER: I'm thinking that you're
5 establishing an agenda for the first workshop.

6 MR. CSONTOS: We think that one of these,
7 you'll see basically three different areas and I think
8 you'll see that there are right now at least three
9 different workshops that we see out of the concepts
10 here, so I'll let you know.

11 MR. MOUNT: This is the last slide on the
12 presentation pieces that I have. There are additional
13 analysis requirements that are going to be needed.
14 The new true best estimate LOCA analysis for above the
15 transition break size, there is hinting at the need
16 for a LOCA 50.46 dose analysis. It appears that is
17 tied only if you would have dispersal or would be
18 predicting rupture and dispersal for high burnup fuel
19 above the transition break size, but that's not clear.

20 Both of these are new-ish analyses. The
21 50.46 LOCA would probably require some sort of NRC
22 vendor interaction. That can take a couple of years
23 to get an approved EM, or approved evaluation model,
24 for a utility to follow and use and that would
25 normally be again, another two year-ish process. By

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that time, we would have model built, analysis
2 completed, submitted to the NRC. So, these are items
3 that we see as kind of long schedule hauls that would
4 challenge our implementation on the time frames
5 mentioned earlier.

6 Similarly, the staff this morning did
7 discuss that they have made changes to the rule that
8 removes or acknowledges that the 50.36 regulation
9 already has a process for identifying when non-safety
10 grade equipment should be added to the tech specs, so
11 we appreciate the NRC's updating of that when they
12 remove the explicit requirement from the 50.46a rule
13 and just left it with how we were going to do it under
14 50.34 currently.

15 Similarly, looking forward, the NRC staff
16 heard during our public workshops on reg guide 1.183
17 we had a concern with updates to the radiological
18 source term for equipment qualification purposes and
19 the staff is looking at the continued use of the TID
20 source term and we look forward to future interactions
21 with them on that. This is an item that could be
22 another large implementation burden that could
23 challenge or prevent the industry from moving forward
24 with these initiatives.

25 MR. CSONTOS: This one issue with EQ and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 TID source term is one that could be a show stopper
2 for moving forward with uprates, so this is one that
3 we highlight as being a really big topic for us to
4 consider going forward. The staff is understanding of
5 that.

6 Okay, so I'll go into flexible and durable.
7 Again, please remember that we heard 14.28 this
8 morning and so that may change some of the comments
9 that we have here, but really we do have concerns that
10 right now the 50.46a is really rigid and prescriptive
11 defining and requiring definitions in the codifying of
12 the language of the rule. When you codify it directly
13 into the rule language, we don't see how it allows you
14 to do an alternative approach. Sort of like ALS and
15 others that if you say this is what the TBS is and
16 explain it and you have another alternative to it,
17 we're not sure how you get around.

18 I heard this morning about putting it into
19 the guidance, but if it's in the rule we're not sure
20 how you get out of that requirement and that's
21 something that we need to think about in terms of
22 discussions with the staff. Like I said, we know NRC
23 has developed all these options and want to open up
24 the door for these options. We appreciate that. It's
25 just really the implementation path that you heard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 earlier of those options and the uncertainty
2 associated with those options and all those boxes that
3 I talked about and what is going to constitute
4 acceptability by the staff.

5 We think that small changes in the rule
6 language, taking some of it out and putting it into
7 guidance would allow for more a flexible and durable
8 path. Some of this would be that by taking out, for
9 example, the definition of TBS out of the rule and
10 putting it into guidance. It allows for alternatives,
11 like the ALS. In the future, we may even try a full
12 risk-informed metric down the road. Maybe there are
13 other ways to evaluate break frequency with xLPR.
14 Maybe there's an xLPR for BWRs in five to 10 years.
15 Do we want to come back and go through exemptions or
16 do we also want to go and make this rule flexible
17 enough so it accommodates those other options in the
18 future, but also not having us go back and do another
19 rulemaking to allow those options.

20 VICE CHAIR HALNON: Just to make sure you're
21 arguing with the right group of people, have you
22 compared your desires against the language in the SRM
23 to make sure because, you know, the staff lives and
24 dies by the --

25 MR. CSONTOS: Right.

1 VICE CHAIR HALNON: -- specific language in
2 the SRM. If it doesn't allow one of these things,
3 you're arguing with them won't do any good.

4 MR. CSONTOS: Right. I think what the SRM
5 was talking about was incorporating 50.46a and one of
6 the things that happened with 50.46a back in 2015-2016
7 time frame was that it became too onerous for
8 utilities to really use it to develop a risk-informed
9 frame work to go through to get our uprates. That's
10 kind of where we are again 10 years down the road.

11 VICE CHAIR HALNON: I get that. My point is
12 that if the SRM doesn't allow them to do one of these
13 things that you're talking about, you need to go the
14 Commission --

15 MR. CSONTOS: I agree, I agree. I think
16 that the way that I read the SRM was to incorporate
17 50.46a and that's essentially what we wrote in that
18 first letter that I talked about. It talks about what
19 we think, how you modify, alpha.

20 VICE CHAIR HALNON: I don't know, I didn't
21 read the SRM so it's ingrained, but if it just says
22 choose an option, they don't have an option of saying
23 well, we'll give you options, allow him to go with the
24 other options. That's what I'm trying --

25 MR. CSONTOS: Yes.

1 VICE CHAIR HALNON: -- to add some nuance
2 here.

3 MR. CSONTOS: Yes, I agree, yes. I think
4 that's all I wanted to say with these. We think it's
5 small changes, that's all. We don't think it's major
6 changes. I think it's more of a where you place some
7 of these definitions.

8 Now, this one, what we do see on this one is
9 that there is an Alternative 4 out there and we were
10 supportive of it because the BWRs do need it, okay, as
11 an option for a faster path towards implementations to
12 get power uprates. In this case, what we see is that
13 the DG-1425 appears to provide the guidance for
14 implementing Alternative 4; however, the draft rule
15 does not include the regulatory framework for this
16 alternative means of addressing fuel dispersal by
17 using Alternative 4.

18 So, it's out there and it's a more rigid and
19 restrictive compliance limit, but we may be able to
20 live with this if we were able to get this Alternative
21 4. That's the issue right now, is that there seems to
22 be a disconnect between the guidance and not having
23 Alternative 4 as an option.

24 I'll turn it over to you.

25 MR. BARBER: Kevin Barber from Westinghouse,

1 a fellow engineer in the LOCA analysis area. I think
2 a lot of this lies maybe a little bit repetitive from
3 what we've been discussing really all morning and
4 afternoon. The black text there is a quote from the
5 letter that Al was mentioning, that March 2023 letter
6 that industry supported and really the idea that again
7 that when he just said two minutes ago related to the
8 fact that 50.46a 10 years ago stopped because it was
9 too onerous.

10 Really what we're trying to highlight on
11 this slide are the things that we've been discussing
12 and I think there is a recognition within this room
13 that clearly the workshops are the better way to work
14 with the staff and industry to figure out, for
15 example, the seismic rate so that's something that
16 when we listen to the staff talk and when we read this
17 separately, there seems to be somewhat of disconnect
18 so workshops clearly are the way to find the most
19 viable path forward. And so the idea is that what we
20 really want to do is just capitalize right on what the
21 industry has found out and what we've done in the last
22 10 years to make sure that we clear some of these
23 hurdles for implementation which is really kind of
24 hand-in-hand with modernization.

25 Okay, the next one is industry standards and

1 the three sub-bullets kind of step through a shared
2 process. Some of these are owned by utilities, the
3 inspections that go on, all the risk-informed programs
4 that utilities have really implemented and lived by
5 now. The second bullet is this reporting where the
6 vendors and the utilities work together, whether
7 errors and changes and how we can change local
8 methodologies, how we can change for, you know, it's
9 hot in Alabama in the summer and things like that.

10 What we want to account for is we have
11 processes in place now. We've been following these
12 processes for decades and as we look to transition
13 part of the LOCA analysis into beyond design basis, we
14 should be looking to also relax on these reporting
15 requirements because, again, it's beyond design basis,
16 that is, a non-basis accident. For example, when
17 you're looking at inputs to a LOCA analysis and
18 something might change like, again, it's hot in
19 Alabama in the summer, how does that change a best
20 estimate beyond design basis analysis and how does
21 that change below the transition break size? Design
22 basis accident, how do those reporting requirements?

23 Right now, a lot of that is very much in the
24 rule and I feel like that is something that is
25 something as the industry we can work together with

1 the staff to kind of figure out a better way, an
2 efficient way forward.

3 The third sub-bullet there is breakaway
4 oxidation testing. This is something that was
5 discussed during the December meeting. The fuel
6 vendors, we talked about members were discussing
7 obviously this has kind of come from Russian fuel, but
8 within the U.S., we have these very controlled
9 manufacturing processes. We have newer analysis
10 methods that have kind of improved on where we are in
11 analysis space and where our testing would be if we
12 look back to the draft reg guides that were most
13 recently issued in 2016.

14 (Simultaneous speaking.)

15 VICE CHAIR HALNON: Go ahead, Kevin, you
16 weren't going by a script anyway.

17 MR. BARBER: No. So we're kind of back to
18 modernization right and I think this is something the
19 industry commented back in 2016 too. We're talking
20 about putting a facility, like for Westinghouse for
21 example, at our Specialty Metals Plant where we have
22 to test these ingots and go through and do with this
23 additional testing. We have to come up with an
24 analytical limit and frankly, we will likely set
25 analytical limits way lower than where the testing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 showed and so it's an aspect that once modernized is
2 realized what field vendors do in our country and make
3 sure that we're being efficient and spending resources
4 in a meaningful manner.

5 Then, cladding embrittlement is the last
6 one. The draft reg guide 1263 is there and I think
7 the important aspect for Westinghouse and GE as well,
8 we've licensed cladding alloys since 2016. I sat in
9 this seat when we licensed AXIOM and discuss how we're
10 addressing research findings that were the
11 underpinning of the 50.46c rule. We have approved
12 topical reports now that consider these and so what
13 we're really looking for is when we update these reg
14 guides with the final rule package, we kind of bring
15 in what we've done, the interactions between industry
16 and staff so that we're not accounting for it, we're
17 not re-doing work that we've done. Paul?

18 MR. CLIFFORD: Paul Clifford, contractor.
19 I'd like to talk about regulatory stability and
20 predictability. This slide is actually really a good
21 example of how quickly the NRC staff is moving on this
22 rulemaking, as this slide is only seven days old and
23 it's already outdated.

24 We don't have to go through the slide, but
25 I really appreciate the NRC going back and restoring

1 the long-accepted definition of LOCA. Thank you.

2 Next slide.

3 Okay, so stability and predictability become
4 very important. We heard from the industry of all
5 these licensing actions they plan on submitting. They
6 need to understand what the expectations are when they
7 submit. So, stability and predictability are very
8 important. There's a regulation, 10 CFR 50.109, it
9 governs how or when or if the NRC imposes or backfits
10 new regulatory requirements and positions. Because
11 this is a voluntary alternative, the backfit
12 assessment within the rule package, really exits the
13 backfit assessment because it is voluntary. It's not
14 being mandated. There are some good words that are in
15 there. The assessment states that licensees would not
16 be required to comply with the proposed amendments and
17 would have the option to continue their current
18 treatment of LOCAs. Those are very important words.

19 The voluntary designation for the rule, it
20 really is based upon the NRC staff's assessments and
21 that concluded that the LOCA fuel dispersal at current
22 burn up limits and the 50.46c research findings were
23 not safety significant. That's the basis why they
24 didn't then backfit the industry with these new
25 requirements. Now, if the new requirements were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 designated as mandatory, the staff would have been
2 required to complete a rigorous backfit assessment
3 which requires consideration of risk, safety margins
4 and even costs.

5 I worked at the NRC for 20 years and I was
6 involved in rulemaking. I was involved in
7 implementing new regulatory positions. Rarely did we
8 go into a formal backfit assessment and the reason for
9 that is because 50.109 allows exceptions from the
10 backfit and those exceptions are based on adequate
11 protection and compliance. If you meet those
12 exception requirements you then don't have to go into
13 a formal backfit assessment and consider risk, safety
14 margins and costs.

15 Management Directive 8.4 provides the staff
16 with guidance, really direction for implementing
17 50.109 and with respect to forward fit, the management
18 directive states that backfit has not been imposed for
19 cases where a forward fit is being considered. It is
20 unlikely that the change could be justified to be
21 necessary to ensure adequate protection of public
22 health and safety. What that means is, if you don't
23 backfit the industry based on a certain topic, you
24 then cannot forward fit them without proper
25 consideration of costs, risks and safety margins.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 That same logic would also apply to a compliance
2 exemption from them.

3 VICE CHAIR HALNON: Paul, this is Greg. I'm
4 not sure I understand your point. Are you worried
5 that they're going to backfit you or not going to
6 backfit you or they're going to --

7 MR. CLIFFORD: My concern is we're going to
8 be forward fit.

9 VICE CHAIR HALNON: Okay.

10 MR. CLIFFORD: But we're not going to see it
11 coming. In other words, there's going to be an LAR
12 that comes in place, say for a power uprate or any
13 other licensing action, not involving high burnup, not
14 involving an increase in enrichment and when it comes
15 in for review, the staff is going to try to forward
16 fit some of these issues onto that licensing action.

17 VICE CHAIR HALNON: Is this what you would
18 have done when you were at the staff?

19 MR. CLIFFORD: I was guilty of that but in
20 2019, if I'm being honest. I think we're all a little
21 guilty of that.

22 VICE CHAIR HALNON: Paint a C on his
23 forehead.

24 MR. CLIFFORD: But in 2019, everything
25 changed because the management directive was revised

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 and this concept of forward fitting was really
2 structured just similar to what backfitting is.

3 VICE CHAIR HALNON: It's still there, but
4 now it's got some structure behind it.

5 MR. CLIFFORD: Yes. It's got much more
6 structure --

7 (Simultaneous speaking.)

8 VICE CHAIR HALNON: This is just a concern,
9 it's not necessarily written in the rule, the language
10 doesn't encourage it, you're just concerned that this
11 could happen?

12 MR. CLIFFORD: I'm concerned it would happen
13 and it would really slow things down. We're going to
14 have a lot of licensing actions. Those licensing
15 actions are going to be on rigid schedules and if we
16 submit something and then all of a sudden we realized
17 that we didn't meet the expectations because something
18 has changed then that challenges the schedule.

19 VICE CHAIR HALNON: Okay, fair enough.

20 MR. CLIFFORD: So, that's really the second
21 to last bullet here. Based upon the guidance that's
22 in Management Directive 8.4 and the backfit assessment
23 that's in the rule, we wouldn't expect, we don't
24 expect that our future LARs and vendor topical
25 reports, which comply with the existing 50.46 would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 subjected to any of the new requirements. In other
2 words, we would continue our current treatment of
3 LOCAs.

4 The last bullet is really to emphasize that
5 we don't want our fuel vendor topical reports to be
6 forward fit with these requirements. Sometimes, fuel
7 vendor topical reports are a vehicle for the staff to
8 impose new requirements on the industry and so we
9 don't think that should be allowed.

10 Okay, so the purpose of this slide is really
11 to begin the conversation on what constitutes an
12 acceptable best estimate methodology for evaluating
13 above the transition break size. The staff expects
14 that using best estimate methods and more realistic
15 assumptions that the quantity of the calculated amount
16 of fuel dispersal would be eliminated or greatly
17 reduced. So, there's an expectation that using best
18 estimates is going to help solve the problem of fuel
19 dispersal; however, obviously relaxing some of the
20 assumptions is going to have positive impact on the
21 calculated amount of fuel dispersal, but really it's
22 the implementation. The details of what are the
23 requirements of the best estimate can have a dramatic
24 effect on the usefulness of best estimate vending.

25 I just wanted to highlight that beyond

1 design basis analyses are used to fully understand the
2 capabilities of the plant design rather than
3 establishing tech specs or LCOs based upon fuel
4 performance. Beyond design basis conclusions should
5 not be obscured by artificial biasing and so based
6 upon the beyond design basis categorization of the
7 above transition break size, we think that there are
8 certain characteristics of best estimate methods which
9 should be acceptable and, again, this is to start the
10 discussion because if we don't have a good
11 understanding of what will be acceptable, then that's
12 going to lead to regulatory instability and
13 uncertainty.

14 If you want to know that we've met the mark,
15 it would be good to know what the mark is. Here are
16 just some examples of what we think would be
17 acceptable that you would use nominal initial
18 conditions when running your transients. Beyond
19 design basis events are not the basis for tech spec
20 LCOs, those are design basis accidents, so we
21 shouldn't be evaluating whether or not the ranges, the
22 extremes of LCOs are acceptable. We should be using
23 nominal and that's been practice for some other beyond
24 design basis accidents.

25 The break conditions and the considerations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of the envelope and considerations for the break
2 should reflect actual physical plant characteristics
3 and that includes the frequencies and relative
4 frequencies of occurrence of the break, location,
5 size, et cetera, and that the mitigation systems, the
6 safety-related systems and the non-safety-related
7 systems that can be credited at their full capacity.
8 There's no single failures. The off-site power is
9 available. Finally, the code methods should be best
10 estimate and applied without bias.

11 MR. CSONTOS: Okay, so if I could just
12 summarize here so we can move on the EPRI slides next,
13 that we believe that the Increased Enrichment Rule
14 with the addition of the 50.46a and c, and modified
15 50.46a and c, could enable more realistic operational
16 margins for these new LEIs coming in, for new margins
17 for going in and getting uprights and 24/1 cycles.

18 The IRA came out and incentivized us to go
19 get those. The latest IRS tax guidance came out last
20 week as well, and also further incentivized us to go
21 forward.

22 So, all I can say is that there may be even
23 more interest in IRAs after the IRS guidance change
24 last week.

25 And so, with the intent of the Advance Act

1 we're here to increase efficiency of the regulatory
2 process here.

3 And so, one of the things we would like to
4 do is make sure that we have alignment between the
5 Commission direction in the SRMs as Member Halnon
6 said, and that is that direction plus the intent of
7 the Advance Act to develop this more modern risk
8 inform.

9 And to really keep the point, Kevin brought
10 it up, efficient process.

11 These are the two ML numbers for the NEI
12 letters. We provide all the details in there of
13 basically, our comments are, remain consistent from
14 those, those two letters.

15 And really, this is really important for the
16 utilities, and the implementation. And this is what
17 we talked about in December is this holistic
18 implementation plan.

19 If we can get a better understanding of
20 that, then it reduces the risk, and it's really a risk
21 mitigation approach for going forward with these
22 uprates, and 24-month cycles if we get a more
23 predictable and stable path.

24 And so like is said, that can be done in
25 workshops. And I think we all got agreement that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there's a real good basis to go to workshops.

2 And with that, I'll take questions or we can
3 bring Fred over, or do you want to just do it there?

4 MEMBER PALMTAG: Yes, this is Scott Palmtag.

5 I just want to clarify one thing. I think
6 you were pretty clear on it, but option 2. Lot of
7 discussions on option 2.

8 From what you're saying, that's not going to
9 help BWRs at all, right?

10 MR. CSONTOS: So, the way that we see, so
11 again, this is, this is early, early. We just got the
12 1428 last week, okay?

13 They're not approved for LBB, so there's a
14 lot of things that are not going to be in that flow
15 chart that will hit them, all right, or they'll be
16 able to use.

17 There are some things that they'll have to
18 use but then there's also a line that was incorporated
19 into 1428 that when we read it, looked like there was
20 a more, a much bigger hurdle to climb.

21 Or much bigger mountain to climb with
22 respect to doing all of the analytical analysis to
23 address these issues for BWRs.

24 So, we think that the only way to get there
25 in a reasonable time period right now, is alternative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 4.

2 MEMBER PALMTAG: So if option, if we keep
3 pursuing option 2, the NRC's, I guess, option 2 were
4 basically ignoring 130 completely, is that right?

5 MR. CSONTOS: Could be. Yes, so we wrote
6 this all in the letter, the second letter here.

7 MEMBER PALMTAG: I just want to clarify --
8 (Simultaneous speaking.)

9 MR. CSONTOS: Yes, so --

10 MEMBER PALMTAG: You've said that but it was
11 kind of hidden, correct?

12 MR. CSONTOS: Yes, so I mean I could, we
13 could pull in some GE folks here if you want to, or
14 the BW Interest Group, but that's one of the reasons
15 why we wrote -- oh, Baris, go ahead, Baris.

16 MR. SARIKAYA: Yes, can you hear me?
17 Thanks, Al.

18 That's a great question, Dr. Palmtag. As Al
19 mentioned, BWRs indeed, would benefit from, at least
20 half the fleet would benefit from option 2.

21 But the path to option 2 is significantly
22 more challenging for BWRs, and frankly, not existent
23 today.

24 So, to make a business decision to go to
25 option 2 with that much uncertainty, is we need to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 include that risk in our considerations.

2 And with that as Al mentioned, we are
3 looking into alternatives, which is like option 4.
4 The way that NEI proposed in the alternative option
5 modified alternative 4, is a solution that may be
6 achieved quite a bit faster for BWRs.

7 MEMBER KIRCHNER: This is Walt Kirchner.

8 Could you be more specific about what the
9 major challenges for the BWR fleet --

10 (Simultaneous speaking.)

11 MR. SARIKAYA: I do not have --

12 MEMBER KIRCHNER: -- under option, under 2
13 or 4. What is the technical issue that is the
14 problem?

15 MR. SARIKAYA: I do not have leak-before-
16 break for boilers. So, how I demonstrate compliance
17 or continue the applicability of NUREG-1829 and -1903,
18 is challenging.

19 MEMBER KIRCHNER: And specifically, how?

20 MR. SARIKAYA: In --

21 (Simultaneous speaking.)

22 MEMBER KIRCHNER: Let's say you get an
23 exemption from the leak-before-break provision in the
24 guidance or the Rule, then what would you do as a
25 surrogate for a BWR?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. CSONTOS: So, we have Guangjun Li, from
2 GE here behind you, and he can answer some of those
3 questions.

4 MR. LI: This is Guangjun Li, I'm the
5 Principal Engineer with the Hitachi.

6 For BWR, we have probably have half is a
7 license plant, and small break limited plant.

8 So, for this option 2 as we transition break
9 side, based on the NRC's evaluation actually, it's
10 largely over the filament line, or the RHR line.

11 This goes like from 13-inch to 20 inches.
12 So that's basically if you cut this area, it's lined
13 into the larger brick, traditionally light brick. It's
14 greater than 1 square feet.

15 So basically, option 2 only have help for
16 some of the BWRs but will not, will not be working for
17 half of the BWRs.

18 So, because we are small break limited. So
19 basically, the temperature is pretty high and the
20 intermediate break and the large break -- small break.

21 So, you, the competition over there with the
22 pressure, all of this and ADS, all of this dependent,
23 so we did a preliminary calculations. We found that
24 intermediate break actually, we see the preparation.

25 So, this is only preliminary. We haven't

1 considered everything not yet. So, basically that's
2 why in 2023 we had it centered.

3 We have modified alternate 4, so which will
4 be working not only for BWR, actually for TWR, too.

5 MR. CSONTOS: And let me just, this is Al
6 Csontos, NEI.

7 One of the things that's nice about the
8 option 4, alternative 4, is that it's for the full
9 break spectrum, not just large break LOCA, okay?

10 So, that's one of the reasons why we looked
11 into it and it also is technology neutral to the Bs
12 and Ps.

13 But we believe, still believe in EPRI ALS,
14 and, you'll hear that next, is the fastest path for
15 the Ps to get to the 24-month cycles, which is what,
16 who is really going to be at the benefit of the 24-
17 month cycles.

18 Did we answer your question?

19 MR. SARIKAYA: And one more thing to add to
20 Guangjun's explanation. This is Baris Sarikaya again,
21 Constellation.

22 Even for the half the fleet that benefits,
23 that could benefit with large breaks on the BWR end,
24 the identification of transition break size with, in
25 the absence of leak-before-break, is significantly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 more challenging.

2 MR. CSONTOS: Walt, did we answer your
3 question?

4 MEMBER KIRCHNER: Thank you.

5 MR. CSONTOS: Okay.

6 MEMBER PALMTAG: So, this Scott Palmtag
7 again.

8 I'm not that familiar with option 4. In
9 terms of schedule, is option 4 still something that we
10 could be pursued with the schedule, or?

11 MR. CSONTOS: That's an interesting
12 question. So, when we wrote our letter, the second
13 letter here in January of this year, we were under the
14 impression that option 2 was too far out.

15 In fact, when you read the Reg basis, is
16 stated that it was something that may be done later.
17 And 4 and all the other options were achievable now.
18 That's the staff writing that, not us.

19 And so, we, the way that we wrote the letter
20 was we believe option 4 and 5, modified option 4 and
21 5, could be done in the time period.

22 And that option 2 could be pursued at a
23 later date, kind of like what we talked about this
24 morning in terms of taking large frame load out of
25 full end of the design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 But then the SRM, Commissioner of SRM came
2 down and I believe April, for incorporation of 50.46a
3 and c, and the staff said they could still, they could
4 go and often do option 2, and they proposed 2.

5 And we were like well, that's great. That's
6 fantastic. And so, we, from what I remember reading
7 and that's all I know, is that it was able to be done
8 in the time period for the rulemaking.

9 MEMBER PALMTAG: Okay, thank you.

10 MR. CSONTOS: And that's the staff's words,
11 not.

12 MEMBER ROBERTS: Yes, Tom Roberts. I have
13 a question probably for Kevin.

14 You went through all the analyses that are
15 considered to be onerous. You didn't talk much about
16 the dispersion analysis. You did mention the LOCA
17 dose.

18 But is that because you expect all the
19 analyses to show a no dispersion, or because you think
20 the reg guide on how to model dispersions gives you
21 enough information?

22 I'm just trying to get a sense of who you
23 think the importance is of the modeling dispersion.

24 MR. BARBER: Yes, I think that's a good
25 comment. I think picking up from the discussion in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 December, I think this maybe has to be maybe a little
2 bit more vendor specific, so I can give you my point
3 of view from the Westinghouse for the most part, BWR.

4 And Paul touched on it, too. Like, the true
5 best estimate, what does that mean? And, for the most
6 part, the GEI, the best estimate plus uncertainty
7 method for large break, Framatome has the best plus
8 uncertainty method for large break, and as did we.

9 And so, the question of what is it, the 55th
10 percentile, is it the nominal models and how does that
11 all come out.

12 And what I can say a couple things. We're
13 actively working on figuring out like what exactly we
14 think it might be, right?

15 So from our experience, we know there's
16 certain plant classes, certain plant design features,
17 that are going to push the LOCA analysis results
18 higher and obviously push it, push it to that
19 threshold, or that rupture criteria.

20 So, we're looking at that now and that's
21 certainly something that we want to work back and
22 forth with the staff.

23 I think it's premature to bring it up in
24 this forum of what exactly we, the percentage of what
25 we think plants would be able to make it and not make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 it.

2 Certainly, there are some plants right now
3 that we don't think they'll have any issue making it.

4 And then back to regulatory certainty aspect
5 on the 1434, the draft REG Guide 1344 -- 1434.

6 I think due to the regulatory uncertainty,
7 it would be our goal to demonstrate a rupture. I
8 think that the draft REG Guide in its certain state,
9 in its current state, would add a lot of risk.

10 Talking to a number of utility folks at the,
11 obviously we need to prep for these slides. There's
12 a pretty clear indication that the utility would want
13 to take a risk adverse stance of that. Not want to go
14 down that path, given there's a lot of uncertainty.

15 And in my personal opinion, I also feel that
16 trying to analyze dispersed fuel even though as Mr.
17 Corson said from the staff in December, you might be
18 able to kind of do a high-level conservative count.

19 I think the whole devil in the details type
20 stance there would certainly come to bear, so I think
21 we would do what we could to avoid that.

22 MEMBER ROBERTS: And the devil in the
23 details mean potential for analytical paralysis?

24 MR. BARBER: Right, exactly.

25 MEMBER ROBERTS: Okay.

1 MR. BARBER: Yes, perception that we think
2 this is okay approach to demonstrate again, core
3 coolability I think is what that all comes down to in
4 the definition.

5 Kind of in the 50.46 context of certain
6 vendors might have different approaches for that, but
7 and what we think and what the staff thinks is
8 acceptable, could certainly not align.

9 And so, there's a lot of uncertainty there.

10 CHAIR BALLINGER: So you're saying no
11 dispersal, that's the best path forward?

12 MR. BARBER: In the near term, and that's my
13 personal opinion, yes.

14 CHAIR BALLINGER: Okay, we have succeeded in
15 getting ourselves a bit behind but actually, we're
16 not. Because we discussed item 3 on TBS earlier this
17 morning.

18 So, we have time, a little bit of leeway.
19 So, you have aced out equity except for now we have
20 time for equity.

21 MR. CSONTOS: Okay, great. All right, let's
22 go ahead and swap out.

23 (Pause.)

24 MR. SMITH: Good afternoon, I'm Fred Smith,
25 the Senior Technical Executive with EPRI Fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Reliability Program, and Project Manager for the ALS
2 Program.

3 Kurshad, you want to introduce yourself?

4 MR. MUFTUOGLU: My name is Kurshad
5 Muftuoglu. I'm a Technical Executive at Fuel
6 Reliability Program at EPRI. And working with Fred
7 Smith on ALS.

8 MR. SMITH: So, in June we came and spent a
9 whole day talking about ALS and some time before that,
10 we joined NRC. EPRI interaction spent several hours
11 talking about it.

12 So, I don't intend to try to condense 8
13 hours of material into 15 minutes.

14 So, I want to talk about status where we
15 are, and then talk about a couple of points that are
16 hopefully of interest to you, particularly considering
17 the discussion that you all had this morning.

18 So, the ALS purpose is to develop a
19 technical basis for dealing with FFRD, primarily for
20 TWRs generated in LOCA.

21 The traditional approach would involve
22 experimentation, particularly to evaluate dispersal
23 effects.

24 And we are attempting to do that as a backup
25 to this, but years away to try to measure the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 fragmentation velocity in the fluid for size of
2 fragments, and mobility of fragments.

3 That kind of empirical approach is very time
4 consuming, and does not really align with the
5 industry's schedule.

6 So, we developed ALS to be a more timely
7 approach. And the basic approach divides the break
8 spectrum into two pieces, similar to the transition
9 break size but you don't use transition break size.

10 So, for the main coolant loops, we use LBB
11 credit to justify the probability of risk of disbursal
12 using significant.

13 And for the small intermediate breaks, we
14 use updated deterministic LOCA analysis that include
15 effects high burnup and clad burst -- clad ballooning,
16 to analyze dispersal and demonstrate that no clad
17 rupture and no disbursal occurs.

18 So, next slide, please.

19 So, this is just mostly for reference. This
20 is the ALS submittal. We submitted it in April of
21 last year, and here are all the reports for your
22 reference.

23 It was accepted for review in June, and we
24 also, the NRC was generous enough to grant us a fee
25 waiver in August, and so it's undergoing review as we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 speak.

2 Next slide, please.

3 So, this is the NRC's review schedule, and
4 without going into a lot of detail, you'll notice that
5 the first area they're focusing on is LOCA.

6 And we have already begun audit works, work
7 with them. We have two meetings next week to talk
8 about initial discussions, then we'll focus more,
9 shift the focus to the fracture mechanics, and then
10 finally to the leak-before-break justification.

11 Next slide, please. So, this is a little
12 bit of overview repeating what I said in the
13 beginning. So, but it bears repeating here.

14 So, for the main coolant loop piping, we
15 would credit leak-before-break. That credit is
16 informed by the probabilistic fracture mechanics
17 results. That results demonstrates that the timeframe
18 between detectable leakage and a rupture, LOCA rupture
19 event, is at least 19 months.

20 And so, the time for operators to execute
21 their technical specifications, identify the leakage,
22 respond as required to shut down the plant, and then
23 subsequently investigate and fix the leak, is much
24 less than the time that we would expect a rupture to
25 occur.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Now, that 19 months assumes that they don't
2 shut down and continue to operate at full power, and
3 a fracture grows during that time. But, of course, if
4 you shut down, that's going to curtail that growth,
5 so.

6 For, again -- it's for smaller breaks, I
7 mean for smaller piping breaks we expect to be able to
8 demonstrate that no rupture will occur. And the net
9 result is that we would not have to evaluate going to
10 this analysis paralysis. I think that you coined the
11 term in December, and we have thought about that
12 analysis paralysis for a long time, and we certainly
13 agree it's a very challenging domain to enter, so.

14 Now, because leak-before-break is only
15 available at this point for PWRs, this framework while
16 it could be expanded to BWRs, right now it's only
17 applicable to PWRs.

18 Next slide, please.

19 So, this is a little thought experiment. If
20 you think back, and I guess it's four decades or more
21 when large break LOCA was initially developed as a
22 hypothetical event, bound other design basis criteria,
23 it essentially is almost an instantaneous rupture of
24 the largest coolant line in sight, informing a double-
25 ended guillotine break.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So, that is a scenario that I think we,
2 listening to the discussion this morning, is certainly
3 in question as to how, how realistic is that.

4 So, with the ALS approach, you would first
5 see just, just as with the traditional approach, you
6 would see flaws begin to grow. And they would grow
7 over years or decades until they come through the
8 through-wall crack. Small leakages will begin to
9 occur.

10 The amount of fluid would increase and
11 before it reaches the expect to identify the leakage
12 level, which is 1 g.p.m., the operators would take
13 action. It would show up in any number of parameters.

14 So, you would see core inventory balance
15 changes, potential make up flow increases, sump levels
16 increasing.

17 Containment temperature pressure, moisture
18 particulate activity would increase, and a number of
19 other phenomena could be observed.

20 And so, we have relatively small leakage
21 indicated by a number of independent parameters easily
22 detectable by the plant staff.

23 And this is desirable for this application
24 because all, I think that we said all but one PWR has
25 this already licensed and procedures in place, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 equipment in place, the processes in place, the
2 training in place.

3 And so, it's already working. So, it makes
4 it a faster pathway for implementation.

5 So, the operator response for almost all
6 plants tech spec requires you to go to Mode 3 and in
7 8 hours, and to go to a cold shutdown in 36 hours.
8 There are a few that only go to Mode 4 in that last
9 phase.

10 But even if you're only required to go to
11 Mode 4, if you're going to investigate a steam leak in
12 your containment, it will eventually cool down. And
13 certainly if you're going to make any kind of major
14 repairs, you're going to continue to cool down.

15 So in this condition, you reduce the
16 pressure to the extent that the driving force to force
17 a crack into a rupture, to a LOCA, has been removed.
18 And so, you would not expect LOCA to occur in these
19 conditions.

20 And then, finally, even if it did occur, the
21 decay heat reduction and stored energy reduction is
22 very quick, certainly much less than 19 months.

23 The temperature increase on the cladding
24 would be nominal, and you would not expect FFRD to
25 occur.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So, this is in my view a realistic sequence
2 of events for what would happen with regard to break
3 piping, not what we've been analyzing traditionally.

4 And so, in this scenario a large break LOCA
5 would not result in fuel dispersal.

6 Next slide, please.

7 So, LBB applications there have been I don't
8 know maybe a dozen or so. They are a little unique in
9 their characteristics.

10 They focus on specific attribute of
11 consequence of a LOCA. So, it's not broadly based.
12 It's not everything associated with ECCS systems.

13 It's one specific performance parameter. We
14 limit it to individual piping systems, or subsystems.
15 You have to analyze the entire pipe but you don't have
16 to analyze all pipes. And they're plant-specific
17 qualified on a plant-specific basis.

18 And so, in conclusion with LBB analysis, is
19 that they demonstrate that the probability that fluid
20 is just a piping rupture, is extremely low.

21 So, we talked in June about the xLPR
22 analysis. And the NRC talked about their own xLPR
23 analysis.

24 That's a different and independent
25 assessment, and reaches the same conclusion that large

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 break LOCA rupture is extremely unlikely.

2 So, some examples where it would be is, has
3 already been accepted or somewhat similar to our
4 application.

5 There's an evaluation of fuel fragmentation
6 due to baffle-former bolts. This is a different type
7 of fragmentation. This is fretting driven, but it's
8 a fuel cladding failure event nonetheless.

9 The exclusion of blowdown loads on control
10 rod insertion, and thermal mechanical loads on the
11 fuel structure integrity.

12 So, these are examples of other LBB
13 applications that are somewhat similar to our proposed
14 application.

15 Next slide, please.

16 So, there is a potential challenge to this
17 methodology, and that is related the LBB policy on
18 application to ECCS systems.

19 So, in '89 the NRC evaluated the potential
20 to extend LBB to ECCS systems. And this is a quote
21 from the Federal Register.

22 And essentially public comments, the
23 industry did not identify sufficient safety benefits
24 to merit the investment of time and resources for the
25 NRC to extend this technology to ECCS systems.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Well, a lot of things have changed. And so,
2 some of which are that many of the things that needed
3 to be done, are in progress with this rulemaking.

4 Also, the value of the ALS approach is that
5 it's already under review. And certainly going to be
6 implemented much faster than option 2, or probably
7 option 4.

8 And so, in that framework you wind up with
9 a transition to high burnup fuel, which reduces the
10 batch size, which reduces your discharge.

11 And so, your dry cask requirements are
12 significantly reduced some for 20 percent. So,
13 occupational dose to site workers who are managing
14 these cask campaigns are reduced.

15 Site boundary doses are reduced because you
16 don't have as many casks being loaded to the pad.

17 And when we get and I didn't put it in
18 there, but when we get repository, the transportation
19 risk with fuel casks to be transported, are also
20 reduced.

21 Many of the PWRs cannot reasonably implement
22 24-month cycles without higher burnup, and so this
23 would allow that to happen in a more timely fashion.

24 So, that reduces the number of outages by 25
25 percent. So again, that's this benefit of

1 occupational dose and also a potential for site, for
2 outage related risk is also reduced.

3 And y'all said it in December. This rabbit
4 hole with chasing the, potential rabbit hole, chasing
5 the dispersal effects is a potentially enormous burden
6 on the industry, and the staff.

7 And the number of skilled, highly trained
8 industry staff members who can do the kind of analysis
9 and work that would be needed to be supported,
10 diminishing all the time.

11 And so, this would fully tie, tying those
12 individuals up. And so, they could focus on more
13 efficient, I mean more safety significant activities.

14 CHAIR BALLINGER: Walt?

15 MEMBER KIRCHNER: Yes, I just wanted to
16 underscore the presenter's point that once you get
17 into fuel dispersal, the uncertainties are huge. The
18 analysis, it would be your analysis applicant against
19 the staff.

20 So, the question I really wanted to ask is,
21 where is your transition for the PWRs you're looking
22 at, in terms of break size where you think going to
23 these advanced fuels, claddings, and higher
24 enrichment, where is that transition point and break
25 size where you will not likely see significant fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 dispersal?

2 MR. SMITH: Yes, so --

3 (Simultaneous speaking.)

4 MEMBER KIRCHNER: What size break?

5 MR. SMITH: Yes, so we didn't use exactly a
6 break size. And we did it in a conservative way
7 because of the uncertainties associated with the work
8 when we began.

9 So, for the main coolant loop piping, hot
10 and cold legs.

11 MEMBER KIRCHNER: Yes.

12 MR. SMITH: That would be evaluated under
13 LPD. The branch lines and all smaller legs, would be
14 evaluated using deterministic LOCA report.

15 MEMBER KIRCHNER: So, the first order is
16 that comparable to what the staff's TBS size is?

17 MR. SMITH: I understand --

18 (Simultaneous speaking.)

19 MEMBER KIRCHNER: For PWRs?

20 MR. SMITH: -- that's similar, yes, it's
21 very similar.

22 MEMBER HARRINGTON: Hey Walt, this is Craig.
23 It maps.

24 MEMBER KIRCHNER: Yes, that's what I
25 thought.

1 MEMBER HARRINGTON: Very close with. Not
2 because of the intent, it just does.

3 MR. CSONTOS: That's why we brought up the
4 point about defining TBS in the Rule, as opposed to in
5 the guidance, that this approach, we'd have to have
6 Legal review it like what could or couldn't be done
7 it.

8 But we don't want whatever we do in that, to
9 preclude the use of ALS.

10 MR. SMITH: So, couple more points on --
11 (Simultaneous speaking.)

12 MEMBER KIRCHNER: One more question.

13 MR. SMITH: Oh.

14 MEMBER KIRCHNER: If I may. I get the LBD
15 part of it. How do you account for seismic events?

16 MR. SMITH: The xLPR analysis that we did
17 included a seismic load at the end of each time step.
18 And so, so that those seismic loads are factored into
19 the capacity for the likelihood of the pipe to
20 rupture.

21 And the sensitivity studies that were done
22 showed that the seismic loads didn't materially impact
23 the conclusion. So, it wasn't sensitive to seismic.

24 So, couple other points. The smaller batch
25 size shrinks the entire fuel cycle, not only just the

1 back end but the front end.

2 So, there are benefits to uranium miners who
3 won't be exposed to alpha radiation from uranium dust.

4 Transportation risk throughout the front end
5 of the fuel cycle is reduced because you're shipping
6 less material around.

7 Oh, sure.

8 MEMBER PALMTAG: Hi, this is Scott Palmtag.

9 I just wonder if you can explain that a
10 little bit better because when you have the lower
11 batch sizes, your economy, your fuel economy is going
12 to go down.

13 MR. SMITH: My fuel what?

14 MEMBER PALMTAG: Economy is going to go
15 down. You're going to have some higher burnups, but
16 your average, batch averages, are going to go lower.

17 MR. SMITH: Fuel economies will be better.
18 Yes, so we published --

19 (Simultaneous speaking.)

20 MEMBER PALMTAG: Fuel economies will be
21 better with smaller cycles?

22 MR. SMITH: Smaller batch size. Reduce the
23 batch size by 20.

24 MEMBER PALMTAG: Okay, size of the batch.

25 MR. SMITH: The number of assembly is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 roughly 20 percent less.

2 MEMBER PALMTAG: So when you go to a 24-
3 month cycle --

4 MR. SMITH: A 24-month cycle --

5 MEMBER PALMTAG: -- you're still going to
6 have three batches?

7 MR. SMITH: Well, yes, maybe two, but.

8 MEMBER PALMTAG: When you go to two batches,
9 your efficiency is going to go down.

10 MR. SMITH: Yes, that's a separate decision.
11 So, if you were going to go to 24-month cycles, the
12 batches would go up but not as much as it would if you
13 didn't have the higher burnup fuel.

14 So, higher burnup fuel reduces the cost --

15 MEMBER PALMTAG: Your ecos going to go up,
16 but your averages are going to go down. It peaks with
17 the 24-month cycle, your peak exposures will go up.

18 MR. SMITH: Peak exposures will go up for
19 across the board. But they will not go up as much
20 with a 24-month cycle.

21 Still, they'll go over the current 62 limit.

22 MEMBER PALMTAG: I'm not sure I agree with
23 that. Every 24-month cycle I've looked at, your
24 average discharge burnup's going to go down.

25 MR. SMITH: That's relative to an 18-month

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 cycle, that's correct. But on a apples to apples
2 comparison, if I have a plant that I can do 18-month
3 cycles or 24-month cycles, higher burnup fuel on the
4 24-month cycle is going to be cheaper than lower
5 burnup fuel on 24-month cycle.

6 PARTICIPANT: They do have a couple reports
7 on that.

8 MEMBER PALMTAG: Yes, I have not seen that.

9 MR. SMITH: We can provide you those
10 analyses. There was a NEI report and there's also an
11 EPRI report that we can provide to you.

12 MEMBER PALMTAG: Every 24-month cycle I've
13 ever seen, your fuel costs are going to go up.

14 MR. SMITH: I agree. If you compare an 18-
15 month cycle to a 24-month cycle, it goes up. And if
16 you compare a 24-month cycle with current burnup to a
17 24-month cycle with a higher burnup, costs go down.

18 MEMBER PALMTAG: I'd like to see that when
19 you have it.

20 MR. SMITH: Okay, certainly.

21 And so to that point, after you look at that
22 report the fuel costs go down and plants that may be
23 marginal economically, would have more margin and we
24 can provide more assurance that we can continue to
25 generate carbon-free energy for the country.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So, next slide, please.

2 PARTICIPANT: Do you want to talk about the
3 ECCS policy?

4 MR. SMITH: No, let's forget that.

5 So in summary, the large break LOCA-induced
6 FFRD is extremely low likelihood of occurrences,
7 supported by NUREG-1829 as we talked about today
8 already.

9 The xLPR analysis that we performed, and
10 also that the NRC performed and discussed in December.

11 The LBB pipe qualification process using a
12 different deterministic method, reaches the same
13 conclusion that the probability of rupture is
14 extremely low.

15 There are multiple layers of defense with
16 this approach. So you begin with the basic system
17 design material selection, pipe geometry, et cetera.

18 System fabrication, QA program, welding
19 procedures, qualification, inspection, et cetera.

20 NSSS, nominal and admirable operating
21 procedures that limit pipe system loads. In-service
22 inspection that we talked about today.

23 And leak rate detection. So, leak rate
24 detection is a key feature. We have many months to
25 detect a small leak.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 That leak would if undetected, would become
2 more evident because the leak would increase
3 gradually.

4 Our results show that increase is fairly
5 linearly until it gets near rupture condition, then it
6 accelerates.

7 And so, the methods of detection and
8 multiple independent methods of detection, we did not
9 include a HRA-type analysis of the detection because
10 the results, the HRA methods have a minimum risk and
11 won't go below a certain level, N to the -6.

12 You would have blown through that so it, to
13 us, the 19 months and a tech spec in place using
14 independent methods, it appears self-evident that it's
15 virtually not credible that operators would miss this
16 and not shut the plant down.

17 VICE CHAIR HALNON: Fred, at 19 months, can
18 it be 24, 25 months? Because the Davis-Besse,
19 granting it was a lot of other indications should have
20 been seen, I get that. But it was 24-month cycle.

21 MR. SMITH: So, the 19 months is a 95/95
22 lower limit on the results of samples, sampling in
23 probabilistic methods. It's the PR Monte Carlo type
24 method.

25 So, many of the scenarios would be that, but

1 the Davis-Besse issue, there's a lot of changes in the
2 industry and certainly I count on those changes
3 personally to protect.

4 VICE CHAIR HALNON: Okay, I don't disagree
5 with you. The V.C. Summer at 18 months, it was not
6 detected in any way except for that last one.

7 MR. SMITH: No.

8 VICE CHAIR HALNON: And so, a lot of times
9 is that you've got to be careful of.

10 MR. SMITH: Yes.

11 VICE CHAIR HALNON: And for taking credit
12 for all those, you said independent and I'm glad you
13 said that, but they are dependent and somewhat because
14 it's all people looking at them.

15 MR. SMITH: Yes, and multiple people
16 unidentified leak rate detection in a plant, you know
17 how important this is.

18 It's a morning report. The industry
19 guidance on it shows you, tells you that you begin
20 looking at the leak rate when it's the 10th of the
21 tech spec limit.

22 And you trend it and so, the procedures that
23 implement this LBB tech spec, are very, very well
24 thought out.

25 VICE CHAIR HALNON: Yes, it's been a while

1 since I've done a leak rate, but we also are very good
2 at rationalizing it if it was coolant leakage or
3 something else, so just saying.

4 MR. CSONTOS: Yes, much has changed in the
5 industry since Davis-Besse and NEI 03-08, aging
6 management. There's a lot of things that have gone
7 on.

8 We've worked on them for decades now to
9 recover from that. Because of.

10 MR. SMITH: Next slide I think is maybe the
11 last. So --

12 MEMBER ROBERTS: Fred, to understand ALS
13 versus what the draft rulemaking is obviously a very
14 large amount of similarity. They're both predicated
15 on there being a break size above which is highly
16 unlikely.

17 And so, some degree of relaxed requirements
18 is appropriate.

19 So, it seems like ALS, the difference is ALS
20 does not use the beyond design basis for proof for the
21 existing requirements, just adds to the LBB provision
22 for FFRG.

23 And so that way, it's more conservative than
24 the staff proposal. The staff proposal would require
25 an assessment and analysis, which you don't do because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 you use the LBB and leverage that.

2 Is that a fair summary?

3 MR. SMITH: Yes.

4 MEMBER ROBERTS: So, if there was a subset
5 of assessment analyses that supported no dispersion
6 criteria and consequently further support the ALS
7 approach, or would also support the staff's approach.

8 Is that right? Did I get that right?

9 MR. SMITH: Yes, yes, you're right. The ALS
10 is not equally applicable to 50.46 and 50.46a. It
11 doesn't require and of course we're not opposed to
12 50.46a, but it doesn't rely upon it as a basis. But
13 if both were implemented, there would be some
14 additional defense-in-depth.

15 MR. CSONTOS: Okay, what we wrote in the
16 letter, the second letter that I had on the summary
17 chart of my slides, was that we're pretty consistent
18 that what we said is that to be more realistic, okay?

19 When you're talking about these large beyond
20 design basis type of considerations that we're talking
21 about here, the large break LOCA, we wanted to think
22 about it in a more realistic manner.

23 I think that if we go at it in a more
24 realistic manner like in terms of this case, what a
25 realistic flaw would do in terms of how it would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 really progress and not just this double-ended
2 guillotine break, that we can now see there's value,
3 significant value out of that.

4 And to getting more (telephonic
5 interference).

6 MEMBER ROBERTS: Yes, thanks. I also
7 gathered Al, what you said that the ALS wouldn't
8 really help with power uprates for plants that are
9 limited by a large break.

10 And so, you wouldn't --

11 (Simultaneous speaking.)

12 MR. CSONTOS: Yes, your right.

13 MEMBER ROBERTS: -- just stick with ALS.
14 Because at least as currently proposed, that only
15 deals with FFRD, not with a desire for power uprates.

16 MR. CSONTOS: Correct.

17 MEMBER ROBERTS: So you would need something
18 like what the staff has with those options.

19 MR. CSONTOS: Or option 4. That was the
20 other alternative 4 was one of the other options for
21 us that we considered. And we wrote it all in that
22 letter.

23 MEMBER ROBERTS: Okay, thanks.

24 MR. CSONTOS: We may need to think about the
25 policy. There's an uncertainty, there's another

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 uncertainty in this, which is the policy
2 considerations.

3 And we can talk about that later. We're
4 unsure where the staff is at this point with the, with
5 respect to needing a policy change, or not.

6 And so, that's the only thing that's out
7 there that's a risk mitigation that we need to think
8 about in the future, to adopt ALS.

9 CHAIR BALLINGER: I have a question, and
10 that is for, what is your opinion as to the long pole
11 in the tent for option 2?

12 MR. CSONTOS: I think that what you all
13 talked about in December, is what our concerns are,
14 okay? And in particular, it's about this analysis
15 paralysis.

16 We really like that term, because what we
17 get is the same thing that we saw with the three flow
18 charts that were discussed this morning.

19 It's in a similar vein where each of those
20 boxes are a staff determination of whether you have
21 complied or not, or you met what they were asked for.

22 Now in some cases, we don't know what the
23 1428, is it a check box or if it might, what level of
24 detail.

25 But we heard today about stresses and are we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 going to have to come with you with multiple stress
2 analyses, residual stress analyses or whatever it is,
3 that you have to go through to get approved, okay?

4 CHAIR BALLINGER: But you may have to go for
5 it. There's a short circuit around each one of those
6 things.

7 MR. CSONTOS: That's right. And so the
8 question is, is that there's a part of this that you
9 take a look at and you see what is that
10 implementation.

11 Have we taken a look at this to see whether
12 or not we can take what the staff has provided, and go
13 through and find a stable and predictable path to
14 getting SER done. And LAR approved for that.

15 Right now, we're very uncertain about that,
16 and that's what you heard this morning.

17 CHAIR BALLINGER: Yes, for everybody.

18 MR. CSONTOS: Right. And that's the
19 ultimate, because everyone's on a schedule and on a
20 clock. And in a lot of cases for regulated utilities,
21 they're on a clock with their PACs, okay?

22 So, this is where there's a plan and if we
23 have an uncertain path, and that's the whole point of
24 the advance act is to try to get us to a more
25 efficient path here. And predictable path.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And that's where we are right now. And
2 that's why we're coming to you to talk about these
3 concerns that we have.

4 Again, many of these could be fixed in a
5 workshop meeting. We're not sure. But at least we
6 came to you to describe what the utility concerns are.

7 And one other thing I forgot to bring up
8 that we could also have four utilities tell you that
9 they want ALS.

10 But if you want to, we can also have them at
11 the end, we had that also out there so to tell you
12 that they would like it.

13 So, if you want that, we can do that. If
14 you don't, it's no big deal.

15 CHAIR BALLINGER: And lastly, so we have the
16 long pole in the tent. Is it too long?

17 MR. CSONTOS: I would say the way we wrote
18 the letter, the second letter on the Reg basis,
19 provided that concern.

20 We were very concerned over option 2 being
21 something that was near-term deployable, or able to
22 deploy.

23 And so, we really applaud the staff for
24 going forward with alternative 2 because that, we
25 think that could probably solve a lot of things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 But the concern again is implementation, and
2 implementability if that's a word of the, of the REG
3 Guide, that the draft guides, but also the rule itself
4 and moving forward with that in a timely way.

5 MR. SMITH: Let me ask. So Kevin said that
6 we don't yet know, we don't yet know what a true best
7 estimate LOCA is.

8 MR. CSONTOS: Right.

9 MR. SMITH: And so, we don't yet know
10 whether or not if it's a sufficient margin to carry
11 the whole PWR fleet forward.

12 Certainly, it would be better results, but
13 you may still have plants that would have dispersal
14 and would have to deal with this analysis paralysis
15 issue.

16 MR. CSONTOS: What is best estimate? I
17 mean, each reviewer has different perspective on that.
18 And so, that's the concern that we have is that we are
19 just not sure what it will take.

20 And that's really the uncertainty of this
21 licensing path.

22 CHAIR BALLINGER: I mean, I'm looking at REG
23 Guide 1.157, which has the title, best estimate
24 calculations for emergency core cooling system
25 performance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I don't know. Doesn't say true.

2 (Simultaneous speaking.)

3 MR. SMITH: I think Jeff would like to
4 comment.

5 MR. KOBELAK: Yes, Jeff Kobelak,
6 Westinghouse.

7 I would say REG Guide 1.157 defines best
8 estimate in the context of best estimate plus
9 uncertainty.

10 CHAIR BALLINGER: Yes.

11 MR. KOBELAK: And those calculations are
12 still done typically to a 95x95 level. If you reel
13 that back to kind of what we call true best estimate,
14 I would say there's a very substantial benefit and
15 difference between those two outcomes.

16 CHAIR BALLINGER: So, what's your definition
17 of true?

18 MR. KOBELAK: I think it goes back to the
19 slide Paul presented where everything is most likely
20 expected operating conditions, nominal midpoint of
21 range, 50th percentile, not 95x95.

22 CHAIR BALLINGER: Okay.

23 MR. KOBELAK: I did also want to clarify one
24 other point. I think there was a question earlier
25 about if plants want to operate, would they need the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 50.46a versus ALS. And I would say most plants are
2 not large break LOCA limited for operate. So, I do
3 think a vast majority of the fleet could operate with
4 ALS and not need that 50.46 outcome.

5 Thank you.

6 MR. CSONTOS: And we did talk about best
7 estimate, and we referred it back. So, in and I can't
8 remember which letter it was.

9 I think it was the first letter back in
10 March, we did highlight that a small change in a
11 couple words in the prior 50.46 output, made the Rule
12 go from usable to unusable, or unimplementable.

13 And we wrote it in that letter, and we
14 talked about it, and with respect to going from one
15 criteria to I believe it was higher level of best
16 estimate plus uncertainty.

17 And so, originally it was written in the
18 full package as a certain I can't remember what the
19 word was, but it was written in a certain way.

20 And in the last final stage, it was changed,
21 added a couple words in there and then all of a sudden
22 it went to well, no, no one's going to implement it
23 now because it was just too, too onerous.

24 And so, that's the kind of thing that caused
25 that Rule to not be used. So but again, I would just,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 it's been a long time; it's been years.

2 CHAIR BALLINGER: There is a true, there is
3 a path, I'm going to use the word true. There is a
4 path to true best estimate.

5 MR. CSONTOS: That's what we're hoping for.

6 CHAIR BALLINGER: It's not a iterative loop
7 that's going to happen. It would happen for months
8 and months at a time.

9 MR. CSONTOS: And we suggested that in the
10 letter. And reiterated it here.

11 CHAIR BALLINGER: Well, other questions from
12 members? I don't see Walt's hand up. I sort of
13 expected it, but.

14 MEMBER KIRCHNER: I'll take a bye at this
15 point. Thanks, Ron.

16 CHAIR BALLINGER: Okay.

17 Okay, we've succeeded in putting ourselves
18 --

19 (Simultaneous speaking.)

20 MEMBER PETTI: Ron?

21 CHAIR BALLINGER: -- right back on schedule.
22 Trouble is we're in the wrong --

23 (Simultaneous speaking.)

24 VICE CHAIR HALNON: There's one more.

25 CHAIR BALLINGER: Oh, Dave? I don't see any

1 hands.

2 MEMBER PETTI: Sorry, I didn't raise it.

3 So, just one question that maybe the
4 industry folks can answer in terms of these power
5 uprates.

6 When I think about moving large break LOCA
7 to beyond design basis, I think about that there's
8 going to be huge margin to peak clad temperature. And
9 I might want to increase the linear power and get 10
10 percent more out of the reactor.

11 Is that an unrealistic? I understand there
12 may be changes outside the core to make that happen.

13 MR. CSONTOS: Baris, do you want to answer
14 that?

15 MR. SARIKAYA: Yes, the linear regeneration
16 rates does not real, all solely depend on the LOCA
17 response.

18 We would get benefit for the things like
19 FFRD resolution, however, in order to change the
20 linear regeneration rate, you need to look way beyond
21 LOCA.

22 One thing that also that I like to remind
23 everybody that not every plant is large break limited.
24 So, half the BWR fleet is small break limited.

25 Therefore, it's not going to be a flat path

1 to improving thermal limits. The only plants that I
2 can think of benefit the way that you're talking about
3 are the currently LOCA limited plants. LOCA set down
4 plants.

5 That they have significant set down and then
6 they are large break limited, they may benefit from
7 this.

8 But other than that, the rest of the fleet,
9 they cannot go beyond their currently approved
10 thermal-mechanical limits. Not just because of LOCA
11 but other reasons, as well.

12 MEMBER PETTI: Okay, my question another way
13 is if I take this off the table, what limits the
14 design? And the answer is it really depends, right,
15 I guess. There are other transients that do that,
16 that limit things.

17 Okay.

18 CHAIR BALLINGER: Okay, like I said we're
19 exactly on schedule except we're in the wrong topic.

20 MEMBER PETTI: Ron, you really got to do a
21 better job of managing.

22 CHAIR BALLINGER: Well, but you know, I made
23 it to 3:00 and it's time for a break. Kidding aside,
24 we have plenty of time. There's a lot of, we're
25 having discussions that we would have had anyway.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So, I would propose that we take break until
2 3:15 and then what happens next is this sort of more
3 or less open discussion amongst the members and the
4 staff, and whoever else we can ask, related to the
5 what we thought were open, not open items but items
6 that we needed to have further discussion on from the
7 December subcommittee meeting.

8 So, that would be the plan going forward, so
9 we will please come back here at 3:15.

10 (Whereupon, the above-entitled matter went
11 off the record at 2:59 p.m. and resumed at 3:15 p.m.)

12 CHAIR BALLINGER: Okay. We're back in
13 session. And now we're at the point where we go back
14 and forth a bit on the list of issues which were
15 identified based on the December subcommittee meeting.
16 And I would propose that while that little one-pager
17 we have doesn't match the order that's on the screen,
18 then we just stick to the order on the screen for
19 other people in the room that don't have this page.
20 And so Dave, do you want to do something? Or should
21 we just wade into it?

22 MEMBER PETTI: I think just the first two,
23 I didn't have any -- I don't think anybody had
24 comments on --

25 CHAIR BALLINGER: Yeah.

1 MEMBER PETTI: -- this. But once we get to
2 three -- to four, I think we can have a more directed
3 discussion with each of us --

4 (Simultaneous speaking.)

5 CHAIR BALLINGER: Yeah, I think three we've
6 done --

7 MEMBER PETTI: Right.

8 CHAIR BALLINGER: -- unless other members
9 want to continue that discussion. Four is an
10 important one.

11 MEMBER KIRCHNER: Ron, not to regress, but
12 number two --

13 CHAIR BALLINGER: Sure.

14 MEMBER KIRCHNER: -- we did kick around why
15 the 10 percent knowing that there -- this is primarily
16 an LWR focused rule. I understand that. But knowing
17 that advanced reactors are coming and these changes
18 are outside of 50.46a which is the focus, the
19 acceptable ECCS performance for LWRs. The changes to
20 71, for example, I just don't understand why that
21 wouldn't be changed while the staff is doing it to 20
22 percent.

23 CHAIR BALLINGER: Yeah, I think that
24 question was actually asked pretty directly in
25 December. So is there somebody that can address that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that's on the staff?

2 MR. PIOTTER: Jason Plotter, I'm with NMSS.
3 So just for everybody's recollection, the original
4 staff recommendation for this was to not pursue
5 rulemaking at all. And the primary reason for that is
6 71.55(c) has a provision in it that would allow for
7 approval of fissile material packages with no
8 enrichment limit.

9 So that rule already exists. What's
10 required there is a special design feature so that no
11 single package failure results in a leakage. So
12 you'll note, sodium 155(c) and with (g) which is the
13 one that's specific to UF6 packages, both are focusing
14 on leakage of moderator into the containment space.

15 From the staff's perspective, we did get
16 public comment that suggested that LWR level
17 enrichments that would be expected for ATF in the 7 to
18 8 percent range would be helpful for industry right
19 now. So in light of that, in light of the ADVANCE
20 Act, the staff had some discussions to determine what
21 would be an appropriate incremental approach to
22 support those LWR producers in the near term given
23 that we do have a certification pathway already
24 encoded in the regulations in 71.55(c). We do have a
25 question, however, as part of this draft rule

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 requesting input from the public and from industry if
2 they can provide us additional information for those
3 enrichments in the 10 to 20 weight percent range that
4 would be beneficial for them if they can provide us a
5 basis for that as well.

6 One other thing I do want to note, we've
7 already approved a fissile material transportation
8 package for UF6 enriched up to 20 weight percent. So
9 there is an existing package already. It used
10 71.55(b) meaning that it included the moderator
11 inclusion as part of that approval.

12 The delta there is that because it's using
13 moderator inclusion, there's a moderator present. The
14 total payload capacity ends up getting reduced. And
15 that's really the driving factor here really is when
16 you get to a transportation campaign for this
17 material, if you can only transport somewhere between
18 55 percent and 64 percent of what you might otherwise
19 be able to ship.

20 And this is on a first cylinder basis, not
21 a per conveyance basis. Then you would have to have
22 more transportation evolutions with this 20 weight
23 package that's already been approved. So the basis
24 behind the 10 weight percent was a starting point, not
25 necessarily a finishing point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And it really had to do with the fact that
2 we didn't want to be redundant in creating an
3 additional prescriptive rule that was not technology
4 inclusive which is what 71.55(g) is. It's not
5 technology inclusive because it's specific to existing
6 technology. We didn't want to stray too far from what
7 we already had in addition to recreating a redundant
8 regulation.

9 CHAIR BALLINGER: Is that good enough for
10 you, Walt?

11 MEMBER KIRCHNER: Yeah, thank you.

12 MEMBER ROBERTS: I was wondering if you
13 could provide perspective on the incremental risk
14 between 5 percent and 10 percent.

15 MR. PIOTTER: So we haven't actually done
16 the calculations in terms of what it looks like in
17 terms of overall risk. And I think part of the issue
18 there and I'm glad you actually brought the question
19 up. We're moving toward in Part 71 at least a partial
20 consideration of a risk framework.

21 I know some of you probably -- and if not
22 all of you have listened to the microreactors
23 presentation on the transportation risk framework.
24 Ideally, I think over time, we would look at that.
25 But we just made the assumption from the get-go that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 as you move up in enrichment, your criticality
2 consequences increase.

3 Your risk increases. We didn't actually do
4 a calculation to determine what those values are. I
5 think if we were to look at this more -- in a more
6 fulsome way, particularly if we had to start looking
7 at moderator exclusion on a bigger scale.

8 We would have to start looking at that from
9 a risk perspective and start doing some calculations
10 on that front. But even if you go back to the
11 original promulgation of 71.55(g), there was not --
12 that did not do any sort of risk-based analysis to put
13 that 5 weight percent value in there. It was standard
14 practice at the time.

15 There were public comments, not unlike what
16 we're receiving now that we should just go up to a
17 higher enrichment level, whether it's 10 or 20 weight
18 percent. Staff at the time didn't feel like they had
19 enough technical basis with respect to critical
20 experiments, for example, to be able to justify going
21 above 5 weight percent at the time. Similarly now
22 we're in a similar situation where if you go above
23 roughly about 10 weight percent doing the
24 calculations, we don't have enough critical
25 experiments for dry UF6 that are really going to give

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 us a lot of confidence in what our criticality
2 calculations are going to show which is going to have
3 to result in more conservatism as it relates to
4 setting the values of the payload capacities.

5 MEMBER ROBERTS: Okay. Thank you. So the
6 20 percent enrichment, there's no moderator exclusion
7 assumption. So if it's poison -- the container is
8 poison --

9 MR. PIOTTER: Correct.

10 MEMBER ROBERTS: -- to preclude criticality
11 at 5 percent. There's a historic requirement that
12 says you don't have to worry about that. And all
13 you've done is extend that to 10 percent with an
14 initial defense in depth requirement?

15 MR. PIOTTER: Correct. And again, because
16 the focus is on whether or not moderator can get into
17 the package or not, that's why we try to continue that
18 same line of thinking with the expansion to 10 weight
19 percent rather than to try to make an argument on a
20 risk perspective with respect to criticality.

21 MEMBER ROBERTS: All right. Thanks.

22 MEMBER HARRINGTON: This is Craig
23 Harrington. In the rulemaking package this table is
24 for, it's 8 percent. And I couldn't find much
25 discussion explaining why the difference and what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 implications were and is that temporary. Can you
2 speak to that?

3 MR. PIOTTER: So that's actually outside of
4 my particular area. But it did get asked as part of
5 the concurrence process from my portion. I don't know
6 if Don Palmrose is on the line to answer that
7 particular question. I can speak to it generally.

8 MEMBER HARRINGTON: He left you on your own.

9 MR. PIOTTER: That's fine. And this is the
10 environmental piece of --

11 CHAIR BALLINGER: We don't have phone a
12 friend here.

13 MR. PIOTTER: That's okay. I'm sort of used
14 to it at this point. With respect to that,
15 essentially there was a guidance document that had
16 come out that basically limited the value that they
17 were evaluating up to 8 weight percent. It was
18 necessarily there was a disconnect between what we're
19 doing at 10 weight percent and what they're doing in
20 that table at 8 weight percent.

21 It just, I think, happened to be a
22 coincidence of timing and how that guidance document
23 was developed in picking that 8 weight percent. Now
24 what I would mention is the public comment we did
25 receive for the 71.55 portion of this. I think it was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 7 or 8 weight percent was the value that we were
2 quoted.

3 And I think that's roughly the limit that we
4 expect to see is the 7 to 8 weight percent. Since
5 we're talking about nice, clean cutoff points, the 10
6 weight percent was the limit that we picked. But
7 there's not necessarily a connection to that 8 weight
8 percent limit piece. And so I can see how it looks
9 like there's a disconnect there. But they are, in
10 fact, a disconnected activity.

11 MEMBER HARRINGTON: Does that make it
12 practical to ship it at 10 percent?

13 MR. PIOTTER: That's a question we'll have
14 to take back. But I think your question is certainly
15 a valid one. And it's one that we've been wrestling
16 with our senior management as we're going through the
17 concurrence process.

18 CHAIR BALLINGER: More questions about this
19 topic? And I think we're basically discussing one and
20 two.

21 MR. PIOTTER: I don't know if Charley is
22 online. Charley is remote. And so the 50.68 item was
23 his.

24 MR. PEABODY: This is Charley Peabody, NRR,
25 Division of Safety Systems. I'm doing the 50.68

1 question on the rulemaking if anybody has any
2 questions or discussions on that.

3 CHAIR BALLINGER: What is 50.68?

4 MR. PEABODY: Criticality.

5 CHAIR BALLINGER: Oh, that's the criticality
6 part?

7 MR. PEABODY: Yeah.

8 CHAIR BALLINGER: Okay.

9 MR. PEABODY: Yeah, I think there was only
10 one question that was on the paper that was circulated
11 that I saw. And that had to do with why we're making
12 it an option between the existing 5 percent enrichment
13 limit and the value specified in the operating license
14 rather than just making it the value specified in the
15 operating limit or doing away with that E7 requirement
16 entirely. The reason for that which I did mention in
17 December, the BWR standard tech specs offer two
18 methodologies to comply with the criticality safety
19 requirements.

20 One of them has an enrichment limit and the
21 other does not. The k-infinity one does not have an
22 enrichment limit. So that's essentially why we opted
23 to keep the enrichment limit because the BWRs would
24 then not have a specific regulatory limit if we took
25 it out of the rule. We still -- the staff still feels

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 based on the research that you can use either the k-
2 infinity or the k-effective plus the enrichment limit
3 method and still apply that with the higher
4 enrichments under the proposed rule.

5 CHAIR BALLINGER: Yeah, nobody is going to
6 fess up to that. Other questions or comments from
7 members? I'm not sure who -- it's not on our list.
8 I'm not sure which member -- maybe, I don't have the
9 detailed one with me. I'm not sure which member
10 commented. But since nobody is on that, I think we're
11 done. Okay, okay. Now --

12 MEMBER ROBERTS: I think I had a comment.
13 I've already discussed that with Jason. The
14 observation I had last month, again, just for your
15 consideration is 75.155(c) is written, I think, pretty
16 well in terms of it gives you a performance-based
17 requirement. The slide where we shown was protect the
18 valve as opposed to having a performance-based
19 requirement and show that there's no single factor
20 that can cause leakage. So it's something to think
21 about is to have the language be more performance-
22 based and not be so specific to a particular
23 configuration.

24 MR. PIOTTER: Understood. Thank you.

25 MEMBER ROBERTS: And I understand what you

1 did, the comparison to Part C I think answered my
2 question.

3 CHAIR BALLINGER: Okay. Now the bigger one,
4 FFRD. There you go. There you go. And yeah, so --

5 MEMBER PETTI: Let me lay out the three
6 major comments. This is Dave. The idea of having a
7 hard line of no burst as opposed to what's there now
8 which I agree is flexible. But it's a slippery slope.

9 And the second is we've talked about it a
10 little bit on best estimate definition and industry's
11 concern. We also raise that. And then the issue of
12 core degradation and the definition and consistency of
13 the definition in other parts of the rule compared to
14 what's in the new rule -- new parts of the rule.

15 Those are the three areas. So why don't we
16 start first with the no burst. At least what I'm
17 hearing is that they think no burst is doable for at
18 least the PWR reactors.

19 And opening the door to allowing some
20 relocation and dispersal is just fraught with a
21 calculation uncertainty. And although I appreciate
22 wanting to be flexible, it can be viewed as a trap, I
23 guess, in the worst case, right? You get going and
24 then you find out you can't get where you want to go.

25 MEMBER KIRCHNER: Well, compared to -- Dave,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 compared to the requirements for DG 1428 and the
2 commentary that we had, paralysis by analysis or vice
3 versa, going into dispersion of fuel. And that is a
4 much, much more difficult region to enter with any
5 kind of evaluation model that would be comparable to
6 what's currently used for ECCS evaluations. I mean,
7 it's the stochastic nature of the burst, the amount of
8 material that is dislodged and dispersed, where it
9 winds up.

10 I mean, you get to orders of magnitude,
11 complexity and uncertainty vis-a-vis a nominally
12 intact geometry. Just so it becomes a major
13 analytical challenge. And then both for the applicant
14 and for the staff, it's your analysis against my
15 analysis. The degree of uncertainty is just use. So
16 I throw that out as not insurmountable but as a
17 caution.

18 MEMBER PETTI: Well, and you weren't the
19 only one. I'd say there were at least four members
20 that had concerns around this area. So this is going
21 to be in our letter just because I think there's such
22 a strong consensus among the members.

23 CHAIR BALLINGER: I would mention that we
24 wrote a letter on the RIL quite a while ago. And that
25 was also one of our concerns then, uncertainty and

1 things like that. So it's been a topic that we've
2 been mentioning quite often.

3 MEMBER MARTIN: This is Bob. I think
4 there's also -- there's a backfit question, right,
5 that's come up earlier. There are analyses or up to
6 62 gigawatt days per metric ton that have burst,
7 right? We've accepted that.

8 The RIL back in the day said it wasn't --
9 these weren't significant issues. Whether it was
10 accurate or not is debatable. It adds burden and adds
11 this to the industry, these people that rely on
12 analyses and support their licenses that have these
13 results.

14 I had to reflect my opinion. I think below
15 the 62 threshold is not as much of a safety issue as
16 it is above. And you can draw a hard line that above
17 a certain level, we go with -- you recommend no burst.

18 I mean, that's the easy button in the
19 presence of the uncertainties maybe that still exist.
20 But at the same time, we've been under a different
21 paradigm. And I think the research kind of supports
22 that's probably okay and in a more holistic view of
23 safety.

24 MEMBER PETTI: I also think, Bob, that the
25 saying, no burst, it also takes that question of what

1 about we've already licensed reloads that go to 62.
2 And you're saying 55 is the starting point. It would
3 just take all that off the table. It'd just be a
4 cleaner licensing approach. Just my opinion.

5 (Simultaneous speaking.)

6 MEMBER MARTIN: I don't think you raised
7 that. Cleaner wasn't really my issue. It is cleaner.
8 I would agree to that.

9 MEMBER PETTI: Yeah.

10 CHAIR BALLINGER: Some of our accident
11 analysis allows burst. But at the time, we didn't
12 anticipate dispersal and the like. And now we have
13 new data that says, well, if you burst, you can get
14 dispersal under certain sets of conditions. So that
15 argues for the no burst if you can do it.

16 (Simultaneous speaking.)

17 CHAIR BALLINGER: But the way things are
18 drafted -- go ahead, Dave.

19 MEMBER PETTI: The best estimate should drop
20 those temperatures so that you're not going to burst,
21 assuming we can get a good definition of best
22 estimate.

23 MEMBER ROBERTS: And that gets to the
24 question we're talking about -- the interview is
25 talking about there in the last session which what do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 we expect to get for best estimate analysis? Part of
2 it is what is the best estimate analysis. And then do
3 we have a sufficient range of best estimate analyses
4 once we get a prescription to say, okay, we're
5 competent that a no burst criteria is suitable. And
6 that's the unknown at this point.

7 CHAIR BALLINGER: But we've seen some
8 analysis by a particular vendor which has a no burst
9 criteria. And as far as we can tell, it worked and
10 we're okay with that.

11 MEMBER ROBERTS: Right. And I found the
12 1999 and 2005 analyses should significant margin to
13 burst.

14 CHAIR BALLINGER: Right.

15 MEMBER ROBERTS: A best estimate basis
16 burst, whatever they were doing, use for best estimate
17 25 and 20 years ago. So there's some history that you
18 can get there, and if the staff were to impose a no
19 burst criterion without having that information, that
20 would be a potential showstopper in a different way.

21 VICE CHAIR HALNON: Again, you know more
22 about this than I do. These plants that are small
23 break LOCA limited if this criteria or this FFRD
24 caused them to suddenly switch to the large break LOCA
25 limited because they have additional issues they got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 to deal with. That could be a significant issue from
2 the standpoint of how you operate your systems and
3 tech specs and other things that you take care of.
4 Doesn't mean you don't have to enter the LOCA. But I
5 don't know what the --

6 CHAIR BALLINGER: Is there anybody on the
7 staff that can speak to that?

8 MR. MESSINA: I think it's a -- Joe Messina
9 from the staff. I think it's a very plant specific
10 question.

11 MEMBER MARTIN: This is Bob Martin. When it
12 comes to what's limiting, it's always been a bit of a
13 whack-a-mole with methods. And again, to Joe's point
14 about plant specific, each plant has its own
15 association with a vendor or maybe some do it
16 themselves. Methods are unique.

17 And some are more modern than others. And
18 so there's always an onus on the utility and the
19 relationship with their fuel vendor to balance the
20 economics of all these things. But if they, of
21 course, continue to push for more, whether it's more
22 power, longer cycles or what have you, it does put
23 that burden on methods.

24 And I know some of the fuel methods are
25 ready for this and some are not ready for this. So

1 there's going to be continued development. So the
2 answer is a definite maybe.

3 CHAIR BALLINGER: So what I'm hearing is I
4 have to write a letter or somebody has to write a
5 letter. And that is that no burst is preferable. But
6 if you can't do that, then you need to be careful.

7 The analysis is going to become a lot more
8 complicated. Not undoable, but a lot more
9 complicated. So that's just what you're saying?

10 MR. MESSINA: Yeah, and in 20 years, maybe
11 there's a lot of research where they could track
12 particles all throughout the RCS. I don't know for
13 sure. But --

14 CHAIR BALLINGER: But the EPRI folks did say
15 that they're doing research to explore this. I don't
16 know what that means in terms of actual experiments or
17 calculations or what. I don't know if the EPRI folks
18 are here.

19 MR. MUFTUOGLU: Kurshad Muftuoglu, EPRI. So
20 the current research is looking at the transport into
21 the containment and where the particles will be
22 collected and not necessarily how they are cooled and
23 particularly what's in the primary system. So there's
24 ongoing research on that part. You want to ask more?

25 MEMBER MARTIN: I couldn't hear what you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 said.

2 CHAIR BALLINGER: What I heard was -- or I
3 think what hear that you're doing analysis or
4 experiments related to -- at least to the containment
5 -- transport to the containment, not so much the
6 nitty-gritty of burst pressures and all this kind of
7 stuff. Is that right?

8 MR. SMITH: This is Fred Smith from EPRI.
9 You're mostly right. We're looking at particle
10 transport within the fuel, so to spacer grids and on.

11 CHAIR BALLINGER: With respect to bursts.
12 Some of us have been around long enough, Steve in
13 particular and myself, to know that these burst tests
14 have been going on since --

15 DR. SCHULTZ: '70s.

16 CHAIR BALLINGER: -- the '70s. And to this
17 day --

18 DR. SCHULTZ: Early '70s.

19 CHAIR BALLINGER: And to this day, nobody
20 has ever been able to correlate a real thing. They
21 can do burst tests. But after that, they kind of look
22 at it and toss up their hands. So it's not an easy
23 thing to do, to get something this quantitative that
24 you could use for an analysis, right? I mean, it's
25 tough.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. MESSINA: I will say a lot of models
2 today do have polluting and burst models.

3 CHAIR BALLINGER: Oh, they all do.

4 MR. MESSINA: Yes, exactly. And NUREG-630,
5 it's old. But it still can be used.

6 CHAIR BALLINGER: Right. If we ask the
7 people that did 0630 what the uncertainty was.

8 MR. MESSINA: No, it's -- those lines are
9 interesting.

10 CHAIR BALLINGER: They go blank.

11 DR. SCHULTZ: This is Steve Schultz. Those
12 evaluations don't tell you what happens to the fuel
13 after the burst. It just tells you that the burst
14 occurred and here's the size of the burst.

15 MR. MESSINA: Yeah, and I guess the Studsvik
16 testing in the SCIP projects would come into play.

17 VICE CHAIR HALNON: So this is Greg. Why
18 don't we ever talk about what happened to TMI-2 and
19 the fact that a third of the core burst and turned out
20 okay? I mean, and I know okay is a relative term.

21 MEMBER HARRINGTON: A really bad day.

22 VICE CHAIR HALNON: It was a bad day. But
23 it was frugal. It was transported throughout the RCS
24 into a containment basement. I get it that it only
25 had 90 EFP days, if that. But it certainly showed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 where it was going to go. Can't we bound this and say

2 --

3 (Simultaneous speaking.)

4 MEMBER KIRCHNER: You can bound it. That's
5 what MELCOR can do. Not the dynamics and the
6 stochastics of how a core would melt down and so on.
7 But yes, it's coolable, Greg. But can the industry
8 have that as a design basis accident? No, I don't
9 think so. It would set the industry back on its
10 heels.

11 VICE CHAIR HALNON: It's more of a
12 qualitative argument why it's okay --

13 (Simultaneous speaking.)

14 MEMBER KIRCHNER: Yeah, so coolability of a
15 debris bed is probably not the issue. It's the
16 intractability of saying what happens once you get to
17 a large scale disruption of the core. I think we have
18 reasonable confidence about you can terminate the
19 event.

20 But you're now in a very severe accident
21 state. And nominally, the 50.46a was to prevent large
22 scale disruption of the core and maintain coolability.
23 And that coolability definition is going to be
24 stressed in this rulemaking.

25 MEMBER PALMTAG: And it considers the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 economics. If you have burst, your plant is done. If
2 you could non-burst, you can recover without really
3 any safety issue. Maybe it is something to consider
4 another reason to have the non-burst criteria.

5 I just want to follow up with what Bob
6 started on is right now the dispersion happens at 55,
7 right? We say it's okay to 62. There's a little
8 check with units.

9 CHAIR BALLINGER: Dispersion doesn't happen.
10 Fragmentation --

11 MEMBER PALMTAG: Fragmentation happens.

12 CHAIR BALLINGER: Fragmentation and
13 relocation happens. You have the burst to get
14 dispersion.

15 MEMBER PALMTAG: So the fragmentation
16 happens at 55. Currently we're ignoring that up to a
17 rod burnup at 62. But that is the rod burnup which
18 you can have a LOCA burnup at 70.

19 CHAIR BALLINGER: But I think we're actually
20 ignoring anything until the clad burst.

21 MEMBER PALMTAG: Well, the new rules will go
22 in effect over 62 it's my understanding.

23 CHAIR BALLINGER: Right, but the clad has to
24 burst first.

25 MEMBER PALMTAG: Right. Whatever we do,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 though, I'm not sure why we can say it's okay over 62
2 and not between 55 and 62. If it's a safety concern,
3 I think it is. I think we need to cover the range
4 where it occurs.

5 And I realize there's going to be pushback.
6 No one wants to forfeit rules. But if it is a safety
7 concern, I think we have trouble ignoring between 55
8 and 62. I should be ignoring between 55 and 70.

9 MEMBER PETTI: And that came up in the RIL
10 when we heard that because that was discussed which is
11 I like no burst because it just cleanly handles
12 everything.

13 MEMBER PALMTAG: No burst, yeah, I agree
14 completely. I confirm no burst. But it would put
15 some limitations below 62 which we currently do not
16 have now.

17 MEMBER MARTIN: This is Bob. We were
18 talking a moment ago with regard to -- and we can
19 maybe transition to the best estimate -- definition of
20 best estimate. For the most part, the missing
21 information here for us is that none of us have any
22 experience with whatever true best estimate is.

23 Folks in the room, online, we apply the
24 methodologies. The methodologies have the biases.
25 And they give us -- biases are intuition about what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 really happens. Now if we come in with a definition
2 of best estimate, and mine is not going to be as
3 articulated earlier -- I'm sorry. I'm missing your
4 name over there.

5 MR. KOBELAK: Jeff.

6 MEMBER MARTIN: Jeff, Jeff, Westinghouse,
7 right, has said. But nonetheless, I think the big
8 hitter with these analyses and large break in
9 particular is like single failure. It's huge.

10 And maybe that by itself or just initial
11 conditions in general might solve the 55 to 62 issue.
12 But we don't know. We don't know that unless someone
13 goes off and starts playing around with the codes.

14 And I don't know if that requires -- I mean,
15 I guess all would be methodology changes coming in
16 with their post-TBS methodologies crediting. But I
17 will say since I'm here and I'm talking about best
18 estimate, Reg Guide 1.157, 98 percent of it is about
19 phenomena uncertainties. And I absolutely believe
20 that you retain phenomenological certainties in these
21 analyses that you don't look at 50/50 as being the
22 metric.

23 You still look at a 95/95 with these
24 phenomenological uncertainties because that is the
25 uncertainty that remains that you cannot do any better

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 with. We can say stuff about single failure and
2 initial conditions. And we've got lots of data of how
3 plants operate.

4 We have a lot of confidence. We can never
5 say anything really about the phenomena to the extent
6 the state of knowledge in any one of those phenomena
7 today. And to be honest, there's plenty of precedent
8 in beyond design basis of considering phenomenological
9 uncertainties at 95/95. The labs do it. I can tell
10 when I was at Framatome, I did it.

11 MEMBER PETTI: But Bob, that's inside the
12 design basis. I completely agree with best estimate
13 plus uncertainty. When you go beyond design basis, I
14 don't understand the rationale to go with best
15 estimate at 95/95 as opposed to pick the mean or the
16 median of the statistical analysis.

17 MEMBER MARTIN: The rationale is that it's
18 the uncertainty range. And as much as we like to
19 think we understand all these phenomena to a great
20 extent, we only understand it to the extent of the
21 uncertainty models that we have. And it's still
22 realistic.

23 And the rub here is what's best estimate,
24 what's realistic. And I'm leaning towards realistic.
25 What's within the realm of possibilities. And then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 you still cover yourself for those things that are
2 kind of out of your control.

3 You put best estimate of what you can
4 control and you stay realistic with what you can
5 control. And we can't control the laws of nature.
6 You can control the operations of power plants.

7 MR. MESSINA: So by best estimate in this
8 rule, we do not mean 95/95.

9 MEMBER MARTIN: I know. Well, I mean, you
10 were ambiguous and that's why we're debating this.

11 MR. MESSINA: Yes, almost intentionally
12 ambiguous to possibly allow for different ways to do
13 this. Someone might want to be a little more
14 conservative in how they do their --

15 MEMBER MARTIN: But I would say that's
16 unprecedented outside of universities and labs because
17 I think so. When I was considering accidents where it
18 was AREVA, we considered 95/95. This is before USABR.
19 And it continued for other plans that came along
20 which, I mean, never going anywhere.

21 But nonetheless, we considered uncertainties
22 of severe accident phenomena and then did the
23 statistical analysis at 95/95 and those set boundaries
24 for design. Now granted, they're not setting design
25 basis requirements on safety-related SSEs. It's a lot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 easier to apply those kind of constraints. But
2 there's precedent. And to do a straight up best
3 estimate, there's too much subjectivity for that.

4 CHAIR BALLINGER: Well, we heard -- one of
5 the presenters, I think, talked about what it would
6 take to define what best estimate is as part of the
7 discussion. So that -- if you can agree on what is
8 best estimate, then that provides certainty for the
9 applicants. And that is something that probably
10 should be done if you're going to do that.

11 MEMBER PALMTAG: I agree with Bob, though.
12 What a best estimate is, I mean, it's inherently
13 subjective, right? There's lots of knobs, lots of
14 tunes, lots of different correlations.

15 What's best estimate for Bob may not be best
16 estimate for me. When you do best estimate, you have
17 to include uncertainties. Now whether you take it to
18 95/95, that's different.

19 But I do think best estimate doesn't make
20 sense unless you have some sort of uncertainties in
21 there that just sort of limits you on your choices on
22 what you can make that you have to include. The other
23 issue I have with best estimates is how do you define
24 best estimates. But definitely, it's current
25 knowledge.

1 Current knowledge is evolving. We learn new
2 things. We have new correlations. Is your best
3 estimate method going to change over time? How do you
4 account for that? I do think you have to account for
5 uncertainties. Maybe not 95/95, but you have to have
6 uncertainties in the definition of a best estimate.

7 MEMBER PETTI: I have a question for the
8 staff. How was ATWS and station blackout down? It's
9 done on a best estimate basis now because the beyond
10 design basis? Is there anything there that can help
11 in the discussion?

12 MR. MESSINA: Yes, so we don't have strict
13 guidelines on those. And there is a variety of
14 approaches a lot of times for those types of analysis.
15 Vendors, they prefer to do something maybe a little
16 more conservative than we would accept to make it
17 easier for the review and quick in the review because
18 they don't need all that margin.

19 MEMBER HARRINGTON: This is Craig. This is
20 a quick question. In the rule package, all the times
21 the best estimate used twice is true best estimate.
22 Was that intended to imply anything different?

23 MR. MESSINA: It was intended to imply as
24 opposed to Reg Guide 1.157 which says best estimate
25 and uses for 95/95.

1 MEMBER HARRINGTON: Okay.

2 DR. SCHULTZ: This is Steve Schultz. Is
3 there a definition then for true best estimate?

4 MR. MESSINA: I'd say we're relatively open.
5 I think what industry presented today on their
6 understanding of what best estimate today aligns very
7 closely with what we think other than possibly the
8 sampling over the break size -- entire break size
9 range based on frequency.

10 VICE CHAIR HALNON: I would consider using
11 another one besides true because that leaves the other
12 one as untrue.

13 (Laughter.)

14 DR. SCHULTZ: And as you just said, for
15 different applications, the applicant will come in
16 with different definitions of what their best estimate
17 evaluation might be or how they're going to apply
18 conservatisms or no in various aspects of the
19 analysis.

20 MR. MESSINA: Yeah, exactly. And those
21 would be figured out in the evaluation model reviews
22 and/or LARS.

23 DR. SCHULTZ: So you would be open to that.
24 We talked about certain ways which the best estimate
25 is defined could be applied in this circumstance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR HALNON: Yeah, Joe, I would
2 encourage that if there's some commonalities which
3 everybody agrees on that you would at least provide
4 some guidance from the standpoint of some boundaries.
5 There may be some other areas that you write, some
6 innovative ways may come in or more conservative
7 bounding methods could be used. But it seems like you
8 should be able to package that up and give them some
9 guidance that's somewhat consistent.

10 MR. MESSINA: Yeah, and that's a good point.
11 And I think through these conversations, we've
12 realized that as part of -- after this rule hopefully
13 goes out, we can have workshops and really fine tune
14 an agreement on this and put it in writing.

15 CHAIR BALLINGER: We've heard from the
16 industry the word, implementation, almost used as a
17 swear word. But the enemy of that is subjectivity.

18 MR. MESSINA: That's true. But there's two
19 ways to go. There's regulatory flexibility and
20 regulatory certainty. And we're trying to find the
21 balance here. And we don't want to be
22 overprescriptive and not allow advanced thinking or
23 other methods, but yeah.

24 CHAIR BALLINGER: Because I'm just wondering
25 if Option A, not Option 1, 2, or 3, or 4, somebody

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 says we're not going to have any burst. And then they
2 come in with that and they argue that we won't have
3 burst based on some analysis that's done which has
4 whatever estimate, not bad estimate, but whatever
5 estimate they use. But if they come in and say, we
6 are going to allow burst and dispersal, then it seems
7 to me the uncertainty of that analysis has got to be
8 much higher, much higher than trying to argue against
9 the burst. Am I reading this wrong?

10 DR. SCHULTZ: Well, yeah. The uncertainty
11 to analyzing fuel that's dispersed would be very high.

12 DR. SCHULTZ: Well, this is Steve Schultz
13 again. The other point here -- and this is a more
14 general comment. But we talked a lot this morning
15 about different options that would be allowable and
16 making a case or the treatments here.

17 And we're talking again about different
18 definitions of best estimate of the evaluation
19 analyses. One of the -- there's two major goals of
20 the overall effort here. One is to maintain safety
21 and alleviate some of the restrictions that are
22 associated with the large break LOCA.

23 The other is efficiency. And I've become
24 concerned that we allow so many options and so many
25 ways of doing things that the overall process for both

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the staff as well as the industry will be very
2 efficient in a global sense. But I think the
3 workshops that you just mentioned could -- should be
4 oriented to get by that and make the process more
5 uniform from applicant to applicant and to reviewer to
6 reviewer as well because that's where we got into the
7 analysis paralysis issues when a reviewer might have
8 a different opinion than another reviewer and nothing
9 gets done. And the same thing could be applied when
10 you're talking about the industry applications too.
11 It can become very inefficient if there's not some
12 clear direction as to what will be acceptable.

13 CHAIR BALLINGER: I thought it was going to
14 take a lot longer. I thought it was going to take a
15 lot longer than this.

16 MEMBER PALMTAG: I'll just throw out one
17 more thing. When we talk about best estimate and
18 whether you have uncertainty, I doubt that's how the
19 utilities are actually going to do this. So they
20 would always have some sort of bounding calculation
21 that would have some conservatism in it would be my
22 expectation.

23 You'd have some bounding calculation, some
24 conservatism that can draw a box around everything
25 because you're not going to run a LOCA calculation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 every time you have a reload analysis. So that may
2 take out some of this uncertainty if you can show
3 you're conservative. So I guess what I'm saying is
4 you can be conservative would be another way of doing
5 it instead of being best estimate.

6 CHAIR BALLINGER: But the utilities, they're
7 going to use a vendor. And if it's a no burst
8 criteria or whatever they use, they're going to be
9 presented with that rule.

10 MEMBER PALMTAG: Right.

11 CHAIR BALLINGER: And they're going to have
12 use that as part of a submittal. So --

13 MEMBER PALMTAG: I suspect they'd have some
14 bounding calculation. They come up with some bounding
15 calculation. As long as you're underneath that bound,
16 you're okay. You're not going to want to rerun the
17 LOCA calculation for every reload. But that would
18 take away -- if you can show you're conservative, then
19 you won't necessarily meet the uncertainties.

20 CHAIR BALLINGER: Well, why don't we ask
21 them? They're here. The industry is here. Is there
22 anybody -- a utility -- where's my Duke person? How
23 are you going to do the analysis?

24 MR. BURKHART: Please speak so you the court
25 reporter can hear you, including you, Chair.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 (Laughter.)

2 CHAIR BALLINGER: I'm singling her out.
3 Guys, you got to know she's the spitting image of my
4 sister.

5 MS. MATHENY: Hello. How we would do the
6 analysis, I would think that we would be going back to
7 our field support on the analysis.

8 CHAIR BALLINGER: Okay. So we knew that
9 would happen. But give your name, please.

10 MS. MATHENY: Well, excuse me. Tara
11 Matheny, Duke Energy.

12 CHAIR BALLINGER: But what Scott is saying
13 is that you would probably apply some conservatism on
14 it around --

15 MEMBER PALMTAG: Let the fuels guy come in.

16 MR. MOUNT: Brian Mount, Dominion Energy,
17 PWROG Analysis Committee Chair. Scott, you asked the
18 question would we keep some margin in the back of our
19 pocket. During the presentation from the industry, I
20 think Kevin Barber gave you a really good answer to
21 this one.

22 I would not expect a utility to bring
23 forward a LOCA analysis that shows burst in the near
24 future simply because of the uncertainty that you guys
25 have all talked about with the extra analysis and what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 would that do. So I would not expect a utility. I
2 would think we would go back and try to bring in or
3 maybe not hold back margin or but see what we would do
4 working with the vendor to get to the no rupture case.

5 MEMBER HARRINGTON: This is Craig
6 Harrington. Is there benefit with that? And I think
7 that's a very logical answer. But is there a benefit
8 to have the opportunity as allowed under this rule?
9 Or would simply having a no burst criteria be kind of
10 --

11 MR. MOUNT: So there's two answers to that
12 one. For the no burst case, the benefit there would
13 be regulatory certainty with the analysis in the
14 reviews. What would it take, what would we have to
15 give up, what operational restrictions might be placed
16 on our core designs?

17 That would be the flexibility of allowing
18 burst. We might come up with our reduction factors on
19 the high burnup fuel that would prohibit or remove the
20 benefit and require us to larger batch sizes that the
21 higher enrichment in burnup would then become negated.
22 So having that burst feature could allow some
23 utilities that might be constrained by burst
24 additional flexibility. But there is then the
25 additional regulatory uncertainty. And I think, Lisa,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you want to add to that.

2 MS. GERKEN: I want to add -- my name is
3 Lisa Gerken and I work for Framatome. So my concern
4 with all of this discussion is that we're talking
5 about cladding burst because that's easy and we don't
6 want to deal with something. But we're talking about
7 a phenomena that happens in a LOCA event.

8 The LOCA rule is for ECS performance, right?
9 So we shouldn't go in and set limits that are
10 prescribing. We don't want this phenomena to happen
11 because we don't want to deal with it or because we
12 don't know.

13 You look back at the original 50.46
14 regulation. You're looking at core melt. We said,
15 oh, well, wait a minute. We have this phenomena that
16 2,200 -- or we have this phenomena where you get the
17 increased metal water reaction.

18 And we don't know. So what are we going to
19 do? We're going to set limits at 2,200. But that
20 gets lost, right? Fifty years later, I'm here and
21 people are, like, I don't know what 2,200 is.

22 So I don't think we should be writing
23 regulation that precludes phenomena while uncertainty
24 with the actual value of what particular uncertainty
25 is might be large. You can still do something with 2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 sigma. It's just that it may be really, really big
2 because of that point in time you don't have enough
3 knowledge to reduce that uncertainty.

4 And I don't think we should prescribe a way
5 the phenomena that can happen in LOCA because, like,
6 we mentioned relocation. Well, we already have
7 relocation. It's not in the regulation that we cannot
8 have relocation.

9 You won't find it anywhere. It's not in
10 Appendix K. It's not in Reg Guide 1.157. But the
11 vendors have been able to come up with methodologies
12 and give them to the NRC.

13 And the NRC has said, yes, these are
14 acceptable within the framework of our expectation for
15 methodology. So I don't think we should sit down and
16 say, we don't know. We haven't heard about it. It
17 might be crazy. There's a lot of really good work
18 going on right now to understand this stuff better.
19 And we hate to put out something to prescriptive in
20 the regulation about transient phenomena.

21 MR. KOBELAK: Can I interject as well? Jeff
22 Kobelak, Westinghouse. Bob, I wanted to speak maybe
23 to what you outlined earlier. I think there's a
24 perception that the relaxation in the single failure
25 assumption of boundary conditions could be this really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 big benefit.

2 That was something that was permissible
3 largely under the prior 50.46a rule and didn't really
4 get the benefits that we need. There is a time tied
5 up in the models, in the biases, and the uncertainty
6 associated with the physics. That is really where
7 there's a lot of margin tied up.

8 And then we know there's even conservatism
9 beyond. that when we compare our predictions, excuse
10 me, to integral effects data. And we do statistical
11 analysis, even our nominal cases well overpredict the
12 experimental data. So I do want to just emphasize
13 that I think just looking at the single failure
14 assumption, the boundary conditions for the accident
15 is really not enough to be a success path because of
16 the large amount of margin that's ties up inherent
17 into the EMs when we need to consider all the biases
18 of uncertainty.

19 MEMBER PALMTAG: So noted.

20 MR. MOUNT: Brian Mount again. The reason
21 why I started my initial response in the near term is
22 because of that uncertainty. And as the research
23 progresses, the ability to analyze dispersal I would
24 expect to become better.

25 That's why the current framework that is

1 laid out where there's the option you can analyze
2 burst. But I think it's something that'd be in the
3 future. I don't think you would see near term
4 submittals coming in with that. So I like the
5 flexibility of the burst. But I just wouldn't expect
6 somebody to try to use immediately.

7 MEMBER HARRINGTON: That's what I would
8 expect. That's the kind of input I was looking for.
9 I believe that's consistent with what the staff is
10 saying. And what I heard was we'll allow burst. It's
11 up to you to show. So if the bidders come and say,
12 well, we want to do no burst, then that will certainly
13 simplify things. But it takes the margin away.

14 MEMBER ROBERTS: Ron, in terms of your
15 letter being -- having practical responses, I'm
16 thinking something along the lines of we would prefer
17 no burst because of the simplicity. Therefore, we
18 would recommend that the work on the true best
19 estimate LOCA would be prioritized during the
20 rulemaking period with the workshops being planned.
21 And we're trying to get better understanding of what
22 kind of description might be acceptable and what the
23 result would be.

24 (Simultaneous speaking.)

25 CHAIR BALLINGER: I mean, that's -- yeah, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 think you can come in with no burst if you want to and
2 show us how it works and you don't have to. You can
3 offer dispersal. But you've got to show us that as
4 well.

5 MEMBER ROBERTS: I think our recommendation
6 would be to try to settle the question and get some
7 sample results relatively early in the rulemaking
8 period to help inform --

9 CHAIR BALLINGER: Sample results.

10 MEMBER ROBERTS: Yeah, with the like Jeff
11 Kobelak analysis, Framatome, what do they produce with
12 a true best estimate? To see if there's a pathway to
13 no burst as a criterion or whether the flexibility
14 will need to be there.

15 CHAIR BALLINGER: And again, that --

16 MEMBER ROBERTS: That would trigger more
17 research to understand the --

18 CHAIR BALLINGER: But that would be up to
19 the submitter. That's up to the applicant. They can
20 do no burst or not. And that may spurn more
21 additional research on dispersal and probably would
22 depend on the benefit or what you're forced into
23 doing. But you're right.

24 MEMBER ROBERTS: Yeah, I think in terms of
25 a recommendation in the letter --

1 CHAIR BALLINGER: No, you're right.

2 MEMBER ROBERTS: -- it would actually
3 prioritize this work so we could have this more
4 fulsome discussion.

5 CHAIR BALLINGER: Prioritize the best
6 estimate.

7 MEMBER ROBERTS: Yes.

8 CHAIR BALLINGER: The best estimate
9 estimate. The best estimate definition --

10 (Simultaneous speaking.)

11 CHAIR BALLINGER: -- estimate definition.

12 MEMBER ROBERTS: To better understand what
13 kind of results we would get.

14 CHAIR BALLINGER: That argues for the
15 workshops this will work itself out.

16 MEMBER PETTI: That's exactly how I had in
17 my notes just listening to the discussion, Tom.

18 CHAIR BALLINGER: All right. Have we gotten
19 enough on the FFRD issue to go forward, I hope?

20 MEMBER PETTI: Well, there was this comment
21 on core degradation.

22 CHAIR BALLINGER: Yeah, did that come as a
23 result of the very last presentation in the
24 subcommittee where there was -- and I keep saying I'm
25 going to go look it up but I don't do it. Where the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 person who made the presentation pointed out the fact
2 that there is not a lack of consistency between
3 various analysis that need to be done regarding fuel
4 failure or burst as part of the analysis. Is that
5 what I'm remembering?

6 MEMBER PETTI: So what I remember was
7 comments from some members about the existing rules
8 are kind of set up to vent core degradation. And here
9 by allowing it, by allowing FFRD, you've got an
10 inconsistency with core degradation basically and
11 these two different parts of the rule.

12 CHAIR BALLINGER: Okay. I mean, I thought
13 the issue was their current analysis -- Appendix K
14 analysis allows fuel failure.

15 MEMBER PETTI: Failure, yes. I guess this
16 is this definitional issue. Degradation versus
17 failure, that's where it may just be coming up with a
18 different word or something to help.

19 MR. MESSINA: So I'm not -- Joe Messina from
20 NuScale. I'm not entirely sure -- if you're referring
21 to rule language. But in the rule language, we say,
22 cladding degradation phenomena. We don't say core
23 degradation.

24 MEMBER KIRCHNER: I think -- this is Walt.
25 Historically, the idea of the criteria was that the

1 core would remain largely intact. So Joe, when you --
2 with the rule language, you've got cladding
3 degradation and then coolability.

4 I'm sorry I don't have the rule language in
5 front of me so I can double check. But how are you
6 going to define coolability if indeed you were to have
7 any significant dispersion. Is that what you mean by
8 coolability or coolability just of what's left of the
9 core?

10 MR. MESSINA: Coolability, it could be the
11 significant fuel dispersal. It could be -- yes, they
12 would have to demonstrate coolability. It could be --
13 it's meant to be pretty broad that you have to show
14 that it's coolable. I don't know to define that
15 better.

16 MEMBER KIRCHNER: It seems to me that's the
17 big branch point that if you get large scale
18 dispersion and you lose geometry, you're into as we've
19 belabored the point already large uncertainties and
20 lack of experimental data and such to verify an
21 evaluation model and test against and so on. So it
22 becomes complicated. Is it possible to have a
23 threshold in the rule?

24 So you had a clean sheet of paper. We often
25 talk about that. So you have the existing rule which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I have right in front of me. And basically things
2 remained intact.

3 It doesn't really talk about FFRD because
4 when this was written, that phenomenon wasn't really
5 known, et cetera. But you got a branch -- you got a
6 major branch point in my estimation. And that's where
7 these alternatives that the industry are talking about
8 come into play.

9 It may turn out that with some of the ATF
10 fuel even for the large break LOCA, they don't see a
11 burst, so no dispersion. So I don't want to say no
12 problem. But basically the rules that exist are then
13 adequate and they'll demonstrate that they can meet
14 50.46a and Appendix K.

15 Once you go beyond the -- once you start
16 dispersing fuel, once the geometry is no longer
17 intact, things get a lot more complicated. This seems
18 to be then allowing the applicants to -- and the staff
19 in the reg guide we heard about today, the draft reg
20 guide provides one way to put a cap if you will on the
21 size of the break that you analyze. And that's risk
22 informed.

23 So it seems to me that the rule structure
24 might be that first assume that these advanced ATF
25 fuel that the fuel manufacturers and the design, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 survives. It's good. It meets the criteria. No
2 problem.

3 You don't even -- the fact that you have
4 increased enrichment and burnup, it can accommodate
5 it. If you get to burst, if you get to significant
6 deformation and dispersal and uncertainty, then it
7 seems to me that's the branch point where you then
8 invoke these alternate -- whether it's Option 2 or
9 Option 4 that we heard about this afternoon. And then
10 you, the staff, lay out in guidance one acceptable way
11 of demonstrating that which you pretty much have done
12 and opened the door also to the industry alternatives.

13 That's rather simplistic on my part. But it
14 seems to me we're trying to tailor a rule assuming
15 that we can't meet the existing criteria currently if
16 we go to high burnup with the existing fuel design and
17 a large break LOCA. So we're trying to tailor the
18 rule.

19 It's kind of backwards in my mind. Set out
20 some criteria objectives, whether they're functional
21 or there's prescriptive limits or both. And then if
22 you can't meet that, then say, okay, this is an
23 alternative way that's acceptable to the staff to
24 demonstrate that the probability of risk informed
25 approach of such a great size that would lead to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 clad burst and dispersion is not likely. And then
2 invoke those risk metrics to define what the cutoff
3 is.

4 CHAIR BALLINGER: Do I recall reading a rule
5 or the preamble that doing what Walt is suggesting is
6 allowed? In other words, you can pick and choose.
7 You can use parts of 46 and then take a pick a piece,
8 use part of 50.46a.

9 MR. MESSINA: Well, I would say yes. You
10 could use 50.46 and use the fuel performance based
11 criteria of 50.46a.

12 CHAIR BALLINGER: Yeah.

13 MR. MESSINA: But in 50.46a, yes, there are
14 those fuel performance criteria, performance based.
15 We need to envision that could allow the branches,
16 like you said, different ways to possibly address some
17 of these phenomena.

18 MEMBER KIRCHNER: I'm thinking assume
19 success that the applicants are going to look at this
20 as someone just said. Probably not going to come
21 forward with an analysis that shows significant burst
22 and dispersion. There may be a penalty involved.

23 But we've invested all the -- or not we, but
24 the DOE and the industry has invested a lot of money
25 in ATF. I mean, I'm presuming that they're going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reap some rewards from that in terms of cladding
2 performance that will benefit increased burnup. And
3 if there's a problem because the large break LOCA
4 results in burst under nominal evaluation model
5 assessment parameters, then allow the applicant to use
6 a risk informed basis for demonstrating that that
7 large break LOCA can't happen or is highly unlikely --
8 let me put it in those terms in probability space --
9 and go from there as a general structural approach and
10 not get caught up Option 2 versus Option 4.

11 You've laid out a credible path if one were
12 to pursue the -- what's outlined in BG -- let me get
13 the number right, 1426, right? Twenty-eight, sorry,
14 1428. And it seems there's a fair amount of overlap
15 for you and the industry to look at in your workshops
16 because you do have the LBB as a prominent part of
17 that draft reg guide.

18 I think what I'm hearing from the industry
19 presentation today is they would want to stop with the
20 LBB and not have all the follow-on analyses that are
21 required. But it seems to me that and likewise with
22 regard to inspections there's some room there for
23 negotiating and coming up with a plausible approach to
24 both the inspection question as well as the analyses.
25 That would allow you to bring in the risk informed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 approach to capping the size of the break.

2 MEMBER HARRINGTON: Walt, this is Craig.
3 That would seem like, the approach you're outlining,
4 would tackle increased enrichment and some of those
5 key aspects. But it would not allow for the broader
6 range of possible licensing basis, design basis, and
7 plant operational changes that could come from the
8 50.46a rule as proposed which is --

9 (Simultaneous speaking.)

10 MEMBER KIRCHNER: Well, I don't think it
11 would preclude it, Craig. I didn't mean it in that
12 sense anyway, certainly. I was just trying to address
13 the immediate problem I had which is 50.46a is mainly
14 ECCS performance and core coolability, et cetera.
15 Yes, there are other ramifications to be explored.

16 CHAIR BALLINGER: More discussion? Are we
17 satisfied? Well, maybe we're not satisfied for today.
18 Are we at a point where we have to move on? Okay. I
19 would suggest that the next topic is clad testing
20 which might just -- might be as contentious as well.

21 So I recall that in our original 50.46c
22 discussion one of the -- and we wrote a letter to that
23 which is somewhere in the hole where we questioned --
24 we did question the amount of testing that would be
25 required to satisfy 46c at that time. And I thought

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that the revised DG that came from the DG 50.46c did
2 allow more flexibility in testing. But I didn't have
3 a chance to go back and read it. But I didn't get the
4 impression from one of the presenters -- industry
5 presenters that was the case. So maybe we can hear
6 from -- I think it was --

7 MR. MESSINA: James Corson is online.

8 CHAIR BALLINGER: Okay.

9 MR. MESSINA: He's the --

10 (Simultaneous speaking.)

11 CHAIR BALLINGER: That was a big problem.
12 We actually went and visited -- I think we visited
13 Westinghouse. And they had a set up going on there.
14 They were going to do testing of individual cladding
15 batches and the like.

16 And I thought that the new -- the revised DG
17 would allow more generic testing that wouldn't require
18 more specific testing going forward because of the
19 quality -- because of the stuff that they mentioned,
20 quality control, the way we did it. And anyway,
21 that's the impression I got. But I don't know. I
22 probably was wrong.

23 MEMBER PETTI: Ron, the concern that I had
24 was that this is a set of requirements that's a little
25 bit outside the fuel vendor's typical day-to-day stuff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that they do. And it would be better if you could
2 come up with other surrogate metrics that you could
3 use to say this clad is good.

4 CHAIR BALLINGER: And that's what I meant by
5 the quality control and manufacturing --

6 MEMBER PETTI: Right, right. I mean --

7 CHAIR BALLINGER: -- process that sort of
8 brackets everything and guarantees that you don't --
9 the cladding performs appropriately.

10 MEMBER PETTI: Right. I mean, with these
11 advanced clads, we've had hundreds and hundreds of
12 batches I'm assuming. And so there's good data on
13 what the impurities are. There's good data on some of
14 the other fabrication stuff.

15 And collectively, I mean, that probably
16 tells a pretty good consistency story. And couldn't
17 that be used to say there's low risk that you're going
18 to get this type of oxidation that occurred with the
19 Russian cladding. And yet I didn't see that sort of
20 flexibility in the guidance.

21 MR. BARBER: Yeah, this is Kevin Barber from
22 Westinghouse. I think what you just mentioned is
23 exactly what we were hoping for. I think that the
24 bullets to be put in the industry presentation slide
25 we're trying to highlight those exact points.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And as Joe Messina mentioned, James Corson
2 is on. And he certainly did speak to the fact that
3 it's a draft reg guide and industry could take other
4 alternatives to make this argument that really has
5 just been discussing. I think that we just think
6 they'd be more efficient to bypass that given all the
7 quality control that we have and the manufacturing
8 process. And we've talked about this with Framatome.
9 I think it's a united front from all three vendors.

10 (Simultaneous speaking.)

11 CHAIR BALLINGER: I'm sure we had that
12 discussion in our earlier letter about this topic
13 about the issue of quality control and being able to
14 guarantee performance based on --

15 (Simultaneous speaking.)

16 MR. BURKHART: Chair, the court reporter
17 can't get you if you're --

18 CHAIR BALLINGER: Oh, I'm sorry. But I
19 think in our 50.46c letter, the earlier one, we did
20 have a discussion in there about using consistent
21 manufacturing process, all the quality issues and
22 everything to argue that the cladding will perform
23 without this breakaway, if you want to call it,
24 oxidation. And I think we were hamstrung by that
25 figure of E110.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I can guarantee you that you don't get that
2 kind of breakaway oxidation. You just get a knee in
3 the curve where it goes from parabolic to linear. And
4 it's not one of these catastrophic things that occur.

5 MR. CSONTOS: So this is Al Csontos, NEI.
6 The letter that I mentioned is one of the ML numbers,
7 I think you got them or got one of them. The last
8 bullet, the March 2023 letter, talks about this
9 breakaway testing.

10 And we recommend it be removed due to these
11 exact same points you're mentioning here. And if you
12 need more information on that, then we can provide it.
13 But we believe it's --

14 (Simultaneous speaking.)

15 CHAIR BALLINGER: For ATF fuel, if you've
16 coated cladding, where's the breakaway oxidation?

17 MR. CSONTOS: And that's where --

18 (Simultaneous speaking.)

19 MR. CSONTOS: That's where there's a lot of
20 new -- the newer alloys also take advantage of
21 different additions for the fuel to be less -- to have
22 less oxidation. So there's a lot of things that we
23 talked about in the letter that talked about how the
24 manufacturing and the fabrication, especially the
25 newer alloys really are resistant to this. And if you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 take a look at that last session, it talks about the
2 fuel and not just ATF fuel but new fuels.

3 CHAIR BALLINGER: Yeah, I mean, again, I'm
4 sure we've had this discussion with the original 46c
5 letter.

6 MEMBER PETTI: But I think -- I mean, I
7 think it's worth including here, Ron, because in
8 December we talked about it a lot. And now we're
9 hearing industry still thinks it's an issue. So I
10 think it's worth keeping in our letter that we think
11 --

12 CHAIR BALLINGER: Oh, yeah.

13 MEMBER PETTI: -- more flexible guidance is
14 needed.

15 CHAIR BALLINGER: Okay, good.

16 MEMBER PETTI: We're making progress.

17 CHAIR BALLINGER: Don't you hate it when
18 that happens.

19 MR. WANG: James Corson has his hand up.

20 CHAIR BALLINGER: Oh, we have a hand up.
21 James?

22 MR. CORSON: Yes, this is James Corson from
23 the staff. And I would just like to say that
24 originally early in the 50.46c process there was a
25 pretty inflexible of the draft guide that required a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 lot more testing. What ended up being submitted with
2 the final package as a little bit more flexible.

3 The idea was that you would have some vendor
4 plan or vendors would come up with their own plan
5 where they could make perhaps the sort of arguments
6 that you say about manufacturing processes and so on
7 that would dictate what they would need to do going
8 forward, like, additional testing or what have you.
9 So that's what's in the current guide. It's more
10 flexible than the very early days of 50.46c.

11 But certainly, I understand your point. It
12 would be good perhaps to be a little more clear about
13 expectations there. That's something we'll think
14 about.

15 CHAIR BALLINGER: Yeah, I think that
16 softening of the original 50.46c rule was probably
17 resulting in some part from our letter. Okay. Other
18 comments, discussion on clad testing? Did Paul
19 Clifford leave? Hiding out back there or what.
20 You're the culprit. Okay. Let's move on to 1.183.
21 And I think control room dose are probably packaged.

22 MEMBER PETTI: Yeah, but my first comment on
23 1.183 is not.

24 CHAIR BALLINGER: Oh, okay. All right.

25 MEMBER PETTI: It's something that industry

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 has talked about twice. And it wasn't really
2 discussed in the December meeting. Someone has to
3 explain to me what this DBA LOCA with an AOO dose
4 limit of what, six and a quarter rem, when everything
5 that we think about, LOCA now is beyond -- largely
6 goes beyond design basis.

7 So I'm just confused. So I'd like to see if
8 1.183 authors could enlighten me a little bit about
9 that. It's in the table, but I must've -- we had so
10 much to read.

11 I must've just skimmed over it when I was
12 reading that reg guide since I've done it four or five
13 times it seems. Could you tell me what's going on
14 there? What do you mean by that?

15 MR. DICKSON: This is Elijah Dickson with
16 the staff. For the 1.183 working group and writing
17 this Version 2 of the guide, DG 1425, the development
18 of the language in regards to handling the
19 radiological consequences of FFRD stem from
20 Alternative 4 in the regulatory bases. And the dose
21 acceptance criteria that we included in -- I believe
22 it's Table 7 in DG 1425 stuck with the well within
23 dose acceptance criteria for other DBAs that also can
24 result in fuel damage.

25 So for the non-LOCA DBAs that we look at, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 do assess them from a radiological consequence
2 perspective. And effectively was limiting the amount
3 of cladding damage for these other non-LOCA DBAs. You
4 can think of, like, control rod injection, power
5 excursion type of events. It's that consequence
6 analysis -- dose based consequence analysis. So it's
7 not AOOs. It's within DBAs.

8 MEMBER KIRCHNER: Seems to be -- this is
9 Walt Kirchner -- just an arbitrary one-fourth of the
10 25 rem criteria for siting based on MHA and the design
11 containment leakage. So why one quarter of that 25
12 rem?

13 MR. DICKSON: We're effectively just being
14 consistent with the other non-LOCA DBAs that we've
15 assessed with the well within criteria 6.3 rem. So
16 all those other non-LOCA -- well, except for some of
17 the ones that you might be in an LCO that have a 25
18 rem. We simply put the 6.3 rem there.

19 MEMBER PETTI: But I guess I'm still
20 struggling. You are talking about a large break LOCA
21 DBA. Isn't that a contradiction in terms now? A
22 large break LOCA is a BDBA.

23 (Simultaneous speaking.)

24 MEMBER PETTI: Do you mean some smaller
25 LOCA?

1 MR. DICKSON: It's effectively the 50.46
2 analysis. Large break LOCA would have this dose
3 acceptance criteria 6.3. We needed to put something
4 out there, and the rationale was stick with what we've
5 been doing now for 40 some odd years and putting some
6 type of acceptance criteria there with the 6.3. And
7 we kicked around half, maybe 12.5. But we stuck with
8 6.3, limiting the amount of -- well, making even, I
9 suppose, the -- from a consequence analysis
10 perspective similar to the other DBAs that we assess.

11 DR. SCHULTZ: Elijah, this is Steve Schultz.
12 Isn't this the event, the case where you haven't been
13 able to demonstrate that you don't have a large break
14 LOCA? You haven't used the opportunity to claim that
15 there is no break.

16 MR. DICKSON: That's right, yeah.

17 DR. SCHULTZ: And therefore, you got --
18 you're still doing the standard LOCA evaluation. Only
19 in this case, you also have to take into account the
20 dispersal --

21 MR. DICKSON: That's right.

22 DR. SCHULTZ: -- of the relocated material.

23 MR. DICKSON: From a consequence analysis
24 point of view, it's very similar to -- so in the
25 standard review plan, we have 1565 that is the LOCA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 resulting from special postulated breaks. Within the
2 standard review plan for these analyses, it does kick
3 you off into doing consequence analyses if you can do
4 breach fuel. So it's effectively patterned off of
5 that line of thinking.

6 MEMBER PETTI: But this would only be in the
7 event that it's -- so I'm going to ask this
8 differently. Before this rulemaking, there was a line
9 in the table called DBA LOCA and had to meet 6.25 rem.
10 Is that true?

11 MR. DICKSON: Yeah, before this, there was
12 no DBA LOCA dose acceptance criteria.

13 (Simultaneous speaking.)

14 MR. DICKSON: Now we have the MHA LOCA dose
15 acceptance criteria. We talk extensively about that,
16 last month and for all of the other source term
17 presentations that were given to us. The intent of
18 having this dose acceptance criteria for a 50.46
19 analysis that does predict fuel damage, you would then
20 be kicked off into doing the dose analysis. The
21 acceptance criteria that we decided to put into the
22 Regulatory Guide for one of these types of analyses is
23 6.3 rem.

24 MEMBER PETTI: Yeah, I'm still struggling
25 with -- okay, now I understand what you did. It's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 DBA LOCA that has fuel damage. So you have a source
2 term.

3 MR. DICKSON: Right.

4 MEMBER PETTI: And you meet the criteria.
5 But if it's a large break, isn't that a beyond design
6 basis event? I could see, like, a medium LOCA or
7 something. Maybe this -- are you trying to cover the
8 case of some sort of a LOCA right around the TBS where
9 you could get damage?

10 MR. DICKSON: It's separate from the TBS.
11 So the standard review plan, again, 1565, has one go
12 and do the spectrum of accident LOCA analyses. And
13 you have to meet the 50.46 acceptance criteria. And
14 if you do predict fuel failure in that analysis, this
15 is your traditional 50.46 analyses, you then go do a
16 consequence analysis.

17 The consequence analysis has the acceptance
18 criteria of in this case 6.3 rem for, like, the other
19 non-LOCAs to such as control rod ejection. What
20 limits the amount of damage to that fuel is eventually
21 limited when you go do the consequence analysis. So
22 let's say, for instance, a control rod ejection
23 accident.

24 The performer calculations and if the --
25 just recently for one of the ASTs that I've done

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 pretty recently for that particular PWR. They assumed
2 anything over a certain burnup limit with 62 gigawatt
3 days per MTU failed. For that particular DBA, it's
4 not an AOO. It's a DBA, design basis accident.

5 You then use Reg Guide 1.183. I think it's
6 Appendix K. And follow the dose analysis there.
7 Calculate your EAB and LPZ does results. And if
8 you're below that acceptance criteria, that amount of
9 fuel damage that would be found acceptable for a DBA.
10 Not for an AOO, but for a DBA. That's the standard
11 practice.

12 So the thought was under Alternative 4, if
13 we're going to start going down the route of doing
14 50.46 analyses that do predict some amount of fuel
15 failure, well, Technical Specifications Criterion 2
16 tell you to go do a consequence analysis. Put in an
17 LCO or borrow information from the COLR report to then
18 go do the dose analysis.

19 So this is how -- and I didn't really get a
20 chance last month to really describe how this all
21 works under this Alternative 4. We ran out of time.
22 But I can go through a bit of that. I guess I'm
23 trying to do that now without a set of slides which is
24 -- and at the end of the day too, by the way. I don't
25 feel like I'm being terribly effective. But going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the SRP 1565 really does describe how you go about
2 doing this analysis.

3 MEMBER PETTI: Okay. So it's really only in
4 the event that you do burst. All the stuff we talked
5 about with no burst, you wouldn't need to do this.

6 MR. DICKSON: That's right.

7 MEMBER PETTI: Okay. So my guess is a
8 simple footnote or something that would tie that
9 together would maybe help. But you guys can decide
10 that. Okay. I understand.

11 MR. DICKSON: It wasn't a longer discussion
12 in the proposed rule language to really hear all this
13 information out so you can read it and understand it
14 as how it's being executed in the regulatory guidance.
15 So I understand.

16 VICE CHAIR HALNON: This is not the only
17 mechanism that's going to get a source term.

18 MR. DICKSON: Right, yeah.

19 MEMBER PETTI: No, I'm okay. That's fine.

20 MR. DICKSON: Okay.

21 MEMBER PETTI: Let's move on to control rod
22 dose then.

23 CHAIR BALLINGER: Do you remember who the
24 author of that comment was?

25 VICE CHAIR HALNON: Bob, Dave, and Walt.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Oh, you got the --

2 VICE CHAIR HALNON: And Ron.

3 CHAIR BALLINGER: -- the extended version.

4 VICE CHAIR HALNON: Everybody but me.

5 MEMBER KIRCHNER: Ron, this is Walt. I'll
6 start off. I thought in the preamble of -- and the
7 nice presentations we had in December that those were
8 quite thorough. I thought there was ample
9 justification for the 10 rem and up to 25 rem not as
10 a special assignment but under emergency and accident
11 conditions, et cetera, et cetera.

12 I won't repeat the preamble. But given
13 that, I thought that was sufficient justification. I
14 just personally felt the table of graded level of
15 doses allowed versus a CDF calculation. I get it, but
16 I mean, it should be a LERF calculation, not a CDF
17 calculation.

18 But I think for the purposes at hand, that
19 is just not necessary and raises a lot of questions
20 that would draw I think the wrong kind of attention to
21 what the staff is trying to do here with the rule. I
22 think the 10 and 25 under accident conditions is
23 defensible, justifiable, and let it go at that. But
24 having a sliding scale based on CDF calculations, I
25 don't think that's the best use of risk informed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 results from PRAs.

2 MEMBER ROBERTS: Yeah, I think I agree
3 exactly with that. I mean, why do you need that if
4 you meet the criteria by the sliding scale? When you
5 say 25 under accident conditions, are you referring to
6 severe accidents or hypothetical accident? Because I
7 assume the difference in terms of whether or not
8 containment is assumed to be intact as a deterministic
9 assumption or whether you allow the progression of the
10 accident to determine whether or not containment is
11 intact. So I wasn't sure when you said accident
12 whether you meant MHA with the containment intact
13 assumption or --

14 MEMBER KIRCHNER: Well, from my standpoint,
15 I know this is not being very rigorous. But if we've
16 got that kind of dose coming out of the containment,
17 whether it's a severe accident or not, no, I was just
18 thinking in terms of a major hypothetical accident.
19 You got the containment leak rate and you've got an
20 exposure.

21 So there you have it. Then with 1.183, you
22 have a modification to the older TID dose. Again,
23 you're looking at a severe accident and get these
24 kinds of doses.

25 MEMBER ROBERTS: I wasn't sure what your

1 construct was of the 10 versus 25. The 10 rem already
2 assumes that you're at accident. So what were you
3 saying the 25 would apply to?

4 MEMBER KIRCHNER: No, 10 as a design limit
5 for the control room and 25 under accident conditions.

6 CHAIR BALLINGER: That's what I thought it
7 is.

8 (Simultaneous speaking.)

9 MEMBER KIRCHNER: GDC-19 is 5.

10 MEMBER ROBERTS: It's 5. The proposal was
11 10, but that's for accident conditions. So the 10
12 applies to accident conditions, and the 15 through 25
13 apply based on the underlying CDF that the licensee
14 calculates. So again just Walt, when I read your
15 proposal, I wasn't quite sure how you would get from
16 10 to 25 because the 10 already assumes an accident.

17 CHAIR BALLINGER: But the 10 assumes -- I
18 don't know.

19 MEMBER KIRCHNER: No, 10 is a limit.

20 CHAIR BALLINGER: Yeah, 25 is for special
21 case.

22 MEMBER ROBERTS: Right. That's the
23 emergency response and not in the draft rule. The
24 draft rule would have 10 to 25 all apply to accident
25 conditions. So again, I just want to be clear what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the criteria was again from 10 to 25 and was in CDF or
2 LERF.

3 MEMBER PALMTAG: Isn't that the design of
4 the control room that we have?

5 MR. DICKSON: That's right.

6 MEMBER PALMTAG: That was my concern with
7 the control rod dose is the way it was written with
8 the CFDs is it would take the current fleet up to 25.
9 That seemed like a large jump to me, go from 5 all the
10 way up to 25, a factor of 5 of the maximum dose. I'd
11 be more in favor of a maximum dose of 10 on an
12 accident scenario.

13 MR. DICKSON: So what we did in this
14 rulemaking is we went and reassessed the bases for
15 this rule that goes all the way back to 1972. Looked
16 at what could be possible in regards to design
17 criteria given today's understanding of radiation
18 protection and EP. And we didn't want to approach the
19 -- knowing that there's a range, right, we didn't want
20 to approach the rulemaking to say, well, we can give
21 you a factor of 2 and just stick with 10 because then
22 that would lead us to a bit of criticism.

23 Well, you have other acceptance criteria
24 that go up to 25. Why can't you have 25 for the
25 control room? So we are trying to provide some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 flexibility.

2 And what really drove us down this route of
3 trying to leverage some PRA information to provide
4 some flexibility. You have very, very low CDF numbers
5 to go up to 25. Was this SRM-SECY-98-144 that I
6 discussed continuously during those two days that asks
7 us to do performance-based and risk informed
8 regulations? And this was an attempt to do that. So
9 to bridge this range of 10 to 25 rem, that's what you
10 came up with.

11 MEMBER KIRCHNER: There's no justification
12 for exposing people to more radiation just based on a
13 CDF calculation. I mean, decide what limit you can
14 withstand under normal design conditions and then
15 under accident conditions. Once the accident happens,
16 you're not in a situation where you say, oh, we can
17 only go to 15 rem now. I don't see the logic. That's
18 --

19 MR. DICKSON: Again, this is --

20 MEMBER KIRCHNER: -- my problem.

21 MR. DICKSON: -- our design criteria under
22 Part 20. We are not messing around with the actual
23 occupational exposure limits under Part 20. This is
24 specifically design criteria in trying to provide some
25 additional flexibility here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 When you get into these beyond design
2 events, very severe accident events, this goes back
3 large uncertainties under severe accident conditions.
4 You may not have the control room as designed
5 operating under those types of conditions. And
6 Fukushima was an excellent example of that in which
7 they had an ELAP event, extended loss of offsite
8 power.

9 It did not have onsite power, onsite
10 emergency power. Nothing in those control rooms were
11 operating, period, that would be protecting the
12 individuals other than the intrinsic concrete that was
13 built around the control room to protect against the
14 skyshine. It was the RP programs that effectively
15 protected the workers during the actual event, doled
16 out dose to go do mission doses. And they did a very
17 good job of protecting the operators. When we get
18 into this discussion between, like, severe accident
19 and design basis, things start to really do get cloudy
20 and --

21 (Simultaneous speaking.)

22 MEMBER KIRCHNER: Oh, I agree with
23 everything you said.

24 MR. DICKSON: Right.

25 MEMBER KIRCHNER: That's why I'm saying

1 don't invoke CDF -- differences in CDF from plant to
2 plant and have a sliding scale. Just say if you're in
3 a severe accident, up to 25. And then as you said,
4 the rad protection program then you're going to move
5 people in and out and do whatever you need to keep the
6 exposures under that level.

7 MEMBER DIMITRIJEVIC: This is Vesna
8 Dimitrijevic. I have to say I completely agree with
9 Walt's discussion on this. That's absolutely doesn't
10 make any sense.

11 It looks very artificial. It doesn't have
12 a logical connection. So just that will look risk
13 informed. It doesn't even meet this. Core damage
14 frequency presents the risk to general public.

15 I mean, we are computing -- there is no --
16 as I said in my previous discussion, there is not
17 really risk measures here. So I think just keep it
18 simple. We don't know too much about some of those
19 things, dose effect and things like that. So
20 splitting in the four regions does not really make any
21 sense logically.

22 VICE CHAIR HALNON: I think -- this is Greg
23 -- we're still conflating a design structure and
24 problematic controls. First is occupational dose.
25 You're still going to have to have special exceptions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and permission to go to 25 rem if you're going to do
2 that. This is not an allowance for an operator
3 sitting in a control room until he gets 24.99 rem,
4 then he has to go home. This is how you're designing
5 your programs and your structure relative to leakage
6 and other things. So it makes sense to me as a layman
7 to say the safer the plant, the less robust design you
8 need to have.

9 MEMBER HARRINGTON: This is Craig. That's
10 all we're saying for the plant. But the less likely
11 that kind of an event could occur.

12 VICE CHAIR HALNON: That's another way -- a
13 better way of putting it.

14 MEMBER ROBERTS: There's a precedent in NEI
15 18-04 and it's got the frequency-consequence curve so
16 that the curve that -- and the logic came up with
17 actually parallels pretty well with the curve that's
18 in 18-04 in terms of slope.

19 MR. DICKSON: It's similar to other graded
20 dose based graded approaches, absolutely.

21 MEMBER ROBERTS: And it's important to keep
22 in mind here is that the 25 rem, 10 rem, whatever is,
23 is it artifice because the scenario that drives it
24 probably can't happen. It's certainly very unlikely
25 because the scenario has a severe accident release

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 from the core in the containment where the reactions
2 there soon stop immediately before containment damage
3 essentially. And so the containment is not degraded
4 by a severe accident.

5 The combination of events, it probably
6 cannot happen together. And so if you had a design
7 basis accident, that's kind of the 6.3 we were just
8 discussing a few minutes ago, much smaller source term
9 and a much smaller dose for the control room operator.
10 Consequently, if you had the severe accident, it'll be
11 a lot more than 25 rem probably because you don't have
12 the benefit of containment. So it's really just kind
13 of a figure of merit, and you can make up almost any
14 number you want as long as the control room you get
15 from that number is reasonably leak tight and protects
16 the operators.

17 MR. DICKSON: There are programs in which we
18 are testing the control rooms and its leak tightness.
19 So when we see a license come in for an AST and
20 they're changing all sorts of different types of
21 design and licensing basis assumptions. And
22 unfiltered in leakage is a prime example of an input
23 parameter in the dose analysis that has margin.

24 So let's say, for instance, a licensee comes
25 in with their dose analysis and they assume 400 CFM

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 unfiltered in leakage, right? Well, they use that
2 value for -- we call it operational flexibility
3 purposes, right? And so often what we'll see in these
4 license amendments is their control room habitability
5 testing program where they're doing tracer gas tests.

6 There's a Reg Guide 1.196, I believe, that
7 talks about this and talks about these programs. This
8 program is controlled within technical specifications,
9 administrative controls. And they'll show us the
10 results of these tracer gas tests.

11 And one recently I looked at, they assume
12 400 CFM in the control room as an unfiltered leakage.
13 But their tracer gas test results show zero, 11, and
14 12 or maybe it was 15 CFM. But effectively showing
15 that they do have a leak tight control room.

16 These are things that we consider and look
17 at for defense in depth purposes when we're doing
18 these types of analyses. So yes, they have a bunch of
19 -- from a design point of view, from a design basis
20 point of view, not so much maybe from a severe
21 accident point of view plenty of margin to these
22 figures of merit, I suppose. Providing additional
23 flexibility from 5 rem to 10 rem doesn't necessarily
24 mean we're going to be providing or resulting in leak
25 in control room. We have programs that if you test

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 these control rooms. And often, it's very, very low
2 values.

3 MEMBER PALMTAG: I'm still concerned about
4 the amount. I mean, just going from 5 to 25 just
5 seems like a huge jump. I mean, I understand you want
6 some operational margin or flexibility.

7 But I would think going from 5 to 10 would
8 give the utilities that. Just arbitrarily changing
9 maximum dose by a factor of 5. And the argument
10 wasn't really compelling to me. There's five papers,
11 and they range from 10 to 25. And therefore, we
12 picked 25. I didn't think that was really compelling.

13 VICE CHAIR HALNON: Are these consistent
14 with the emergency dose?

15 (Simultaneous speaking.)

16 MEMBER PALMTAG: You made the distinction
17 between the design and containment or the control room
18 design versus maximum dose that they're actually going
19 to get. It kind of seems like we're double counting
20 it because how you design it should depend on the dose
21 or the accident scenario. If there's a low
22 probability, it should be easier to design. But I
23 don't understand why --

24 VICE CHAIR HALNON: That's why you go
25 higher.

1 MEMBER PALMTAG: -- the probability --
2 right. I don't understand why the probability would
3 correspond to the dose.

4 VICE CHAIR HALNON: Risk informed is a
5 thought process, not necessarily numerical.

6 MEMBER PALMTAG: But there's also
7 considerations, Tom and I were talking about, is the
8 control room not just about the dose of the operators
9 too. It's also you need sort of a safe space. You
10 need a way to planning --

11 VICE CHAIR HALNON: You need accountability.

12 MEMBER PALMTAG: Yeah, I mean, I think it's
13 something you want the operators to feel safe. Now
14 we're saying, okay, we're going to take the maximum
15 dose and multiply by five kind of arbitrarily.

16 VICE CHAIR HALNON: In severe accident,
17 design basis accident, and how people feel is not
18 always that important.

19 (Simultaneous speaking.)

20 VICE CHAIR HALNON: Yeah, you don't have to
21 come in happy if you're experiencing a DDA.

22 MEMBER PALMTAG: To design something.

23 VICE CHAIR HALNON: Not really.

24 MEMBER PALMTAG: Or you could do planning.

25 VICE CHAIR HALNON: I get it. I understand.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 That's why you have TSCs in the U.S. that are away and
2 have their ventilation system requirements.

3 CHAIR BALLINGER: I hate to try to cut this
4 off a little bit. But it is 5:00 o'clock, and we do
5 have -- on our agenda, we have to go out for public
6 comments. We have remaining Item No. 8 which unless
7 we plan on staying past whatever to do this, we're
8 probably going to have to leave that till tomorrow.

9 And I think the only thing we have to do
10 tomorrow plus other discussions related to letters and
11 stuff, I think we're in very good shape actually. So
12 I would propose that we now go out for public
13 comments. And we leave the victims and start back up
14 tomorrow morning on broader impacts.

15 And that's a very open ended discussion. So
16 I'm not exactly sure who would we would need to have
17 here if we're having an open ended discussion. But I
18 can't say anything more than that.

19 I don't know what we would have. Staff and
20 the industry have been extremely good about
21 participating and doing presentations and everything.
22 So we really appreciate that.

23 But that's my proposal. So if that's
24 agreeable. Now we need to go out for public comments.
25 And that would end it. So unless we have other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 comments by members, that's my plan. So if there are
2 members of the public that would like to make a
3 comment, please state your name. And that, by the
4 way, includes in the room --

5 MEMBER PALMTAG: Ron, you may want to try
6 that internal and external.

7 CHAIR BALLINGER: Yeah, yeah. That's what
8 I was going to -- as soon as I realized it was
9 somebody breathing down my neck. So let's go outside
10 first.

11 VICE CHAIR HALNON: The external folks raise
12 your hand and we'll catch you in sequence. So it's
13 Kalene Walker.

14 CHAIR BALLINGER: We have one.

15 VICE CHAIR HALNON: You need to unmute
16 yourself and then state your name and any affiliation
17 you may have and then go ahead and make your comment.

18 MS. WALKER: Thanks. it's Kalene Walker,
19 public citizen, no affiliation. I just had a couple
20 of quick clarifying questions before comment. When
21 you say burst, no burst versus allowing burst, what
22 exactly are you talking about doing, allowing burst of
23 what? And could you just clarify, high level, what
24 you're talking about here?

25 CHAIR BALLINGER: Well, I'm afraid that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 have to sort of punt that because we are only taking
2 public comments, not questions. If you have a
3 question, we have a vehicle for that. That is please
4 communicate with Weidong Wang on this topic because --
5 and he will get back to you. And you can have a
6 dialogue that will satisfy you in a setting which is
7 not as rushed as what we're here.

8 MS. WALKER: Okay. Is that contact in the
9 meeting notice?

10 CHAIR BALLINGER: Yes, it is.

11 MS. WALKER: Okay, great. Okay. Well, my
12 comment would be along the lines of when I was hearing
13 the discussion about inspections, you're saying you'll
14 decide what to inspect based on the convenience of
15 access and radiation dose. But what thought came to
16 my mind was, well, what if there's degradation piping
17 or whatever you were inspecting for. If that's in a
18 really hard place with a high dosage, does the NRC
19 require that there be a mitigation plan, a doable plan
20 and in response to some kind of aging process or
21 degradation?

22 And I was wondering I guess it sounds like
23 you're allowing increased enrichment for existing
24 reactors. So we're talking about older reactors. The
25 increased enrichment is obviously to allow higher

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 burnup.

2 And this NUREG whatever it was recently said
3 that burnup might go up as high as 80 in these older
4 reactors. And this is purely for economic reasons
5 that that's being done. But I don't think the safety
6 case is complete.

7 And regarding FFRD, the bottom line,
8 everything you do leads to spent fuel management. And
9 so if you have FFRD on any kind of level that's been
10 released, I've asked this numerous times at numerous
11 of these meetings. How the heck are you going to
12 store that fuel if you pulverize fuel pellets with a
13 large break in the cladding?

14 And the final comment is that a NUREG -- no,
15 an ISG or ATF ISG that came out, they outlined a lot
16 of problems with these new fuels. And they had not
17 been proven within this latest ATF ISG. So relying on
18 this ATF fuel to be able to withstand one of these
19 LOCA incidences is not necessarily a viable path
20 forward if you're concerned about public safety. I
21 guess that'll do it for the moment. Thank you.

22 CHAIR BALLINGER: Thank you. I'll restate.
23 Please communicate with Mr. Weidong Wang and he can
24 have a dialogue with you. It'll be much more
25 complete. I don't see any other hands up at least.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 But even if your hand is not up, if you're
2 a member of the public and you'd like to make a
3 statement, please unmute yourself, I guess. And then
4 give us your name and your organization, if you will,
5 if you want to, and make your statement. Okay. Thank
6 you.

7 MR. LYMAN: Hi, this is, sorry, Edwin Lyman
8 from UCS.

9 CHAIR BALLINGER: Yes, Ed.

10 MR. LYMAN: Yes, sir. Can you hear me? I'm
11 on the phone today.

12 CHAIR BALLINGER: Yes.

13 MR. LYMAN: Okay. I guess one comment I'd
14 like to make is that when you talk about risk
15 informing, I think there needs to be more careful
16 examination of the holistic application of risk
17 informing everything to make sure that you don't end
18 up with circular reasoning. I'll point out one
19 example. When NEI raised the issue of the post-
20 Fukushima seismic hazard reevaluations have all been
21 resolved and why don't they get credit for that. What
22 do they have to do?

23 Why is the draft reg guide saying they have
24 to do further seismic analyses? And in this case,
25 look at what the resolution of the post-Fukushima

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

reevaluated hazards actually were. I'm not aware that a single plant was actually required to make any modifications even though quite a few of them ended up with a reevaluated hazard curve that exceeded their design basis -- their GMRS of record in various frequency domains.

And in each case, this was resolved by essentially saying it wasn't risk significant or wouldn't need a backfit test. So there were no actual changes made. So then if you take credit for that and then to exclude -- to come up with a transition break size, something like that, then you might be engaged in circular reasoning because the analyses that were done to the extent there were any seismic PRA, for example, did not take into account the potential for the additional phenomena that you're concerned about here.

So I think it's really important that risk informing does not double count it in a way that would end up leading to some consequences that are outside of the risk spectrum that was evaluated. Another example is sabotage. And I know that's outside of the committee's domain to a large extent.

But that is another way in which the large break LOCA could occur. And the NRC is giving credit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 now to security programs for what's called the
2 security bounding time. That may require analyses of
3 the time to core damage so that some damage to SSCs is
4 allowed provided that there can be mitigation.

5 And I haven't thought through the
6 implications of that. But is there potentially some
7 circular reasoning going on there as well would change
8 to the -- let's say the large break LOCA analyses have
9 an impact on that time to core damage which may impact
10 whether or not it was appropriate to give credit to
11 security. So it can get very complicated, I think.

12 And I just want to -- I'm sure there are
13 more examples of this. And I just wanted to point out
14 those two. So thank you for listening.

15 CHAIR BALLINGER: Thank you. Okay. Since
16 I missed one, there may be others. So if there's
17 anybody else out there, excuse me, that would like to
18 make a comment, please identify yourself and make your
19 comment. I'm doing better this time. I can feel the
20 heat on the back of my neck.

21 MR. CSONTOS: Al Csontos, NEI. Just wanted
22 to say thank you. Just wanted to say thank you for
23 the opportunity to present today and provide our
24 feedback. We do have a couple of comments to answer
25 I think some of the questions that were raised and get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a better answer for you. So I wanted to go ahead and
2 open the door for those answers.

3 MS. MATHENY: Tara Matheny, Duke Energy. So
4 first comment relating to your question that you had
5 earlier when we were talking about schedule impacts.
6 So I think the discussion that we had was really good,
7 talking about the impact in the nuclear fleet and how
8 a schedule push could impact multiple sites.

9 But we didn't talk holistically about for
10 our power companies what that looks like in their
11 planning. So a lot of planning is going into
12 increased demand for customers and things like that.
13 And so incorporating all of that into holistically not
14 just for the nuclear fleet but schedule impacts impact
15 our plans to be able -- to get power reliably to our
16 customers. So I wanted to make sure we highlighted
17 that as well.

18 And then also a second comment, we would
19 like to -- Duke would like to verbalize our support
20 for ALS, particularly for the staff to continue their
21 review of ALS and how ALS could risk inform FFRD and
22 fit into the framework of the draft guide that we have
23 and the rulemaking that we have and make it help with
24 implementation. I wanted to verbalize that. Thank
25 you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR HALNON: Thank you.

2 MR. STAVELY: Jim Stavely, PSEG Nuclear.
3 Just two things. I'd also like to reinforce the
4 importance we put at PSEG ALS. It's a path forward
5 that has a solid timeline to allow us to move with our
6 plants. So I appreciate again as Tara said with the
7 reviews being performed by the staff.

8 Also, I'm lucky enough -- honored enough to
9 be the technical chair for the EPRI Fuel Reliability
10 Program Research Integration Committee. So in terms
11 of the importance that -- I'm not quite speaking for
12 EPRI but kind of like speaking for the committee is
13 there's a lot of emphasis and value placed behind ALS.
14 I think you've heard over the last number of months
15 the amount of effort we've done to try to support not
16 only the generation of the submittal itself but also
17 the additional documents that lay behind the
18 submittal.

19 So it is very important to the PWRs. And we
20 again encourage from that aspect for the Research
21 Integration Committee of the importance and the
22 continuing review of that submittal. So thank you.

23 MR. LI: Guangjun Li from GEH. Yeah, just
24 want to echo was Lisa just discussed. FFRD is
25 phenomena. So we don't want to try to limit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 phenomena. It happens. And I think the rule should
2 be flexible enough to know this is working for one
3 type of the plant or one plant. But it should have a
4 way actually for everybody to use.

5 You cannot open the door for one plant and
6 close the door for others. That's just something
7 basically especially BWR. I think we have to realize
8 BWR is different from PWR.

9 And PWR, yes, there's something like a leak
10 before break and ALS, all of this. And for BWR, it's
11 really hard to do. And I think the rule should be
12 flexible enough basically, just the criteria for if
13 you have dispersion. What should you do?

14 Basically, what we really care here, it's
15 consequences. So it's probability, loss long term
16 cooling. And you have the threat (phonetic) case, of
17 course. Eventually, you have the dose.

18 So that's why I would have this NEI letter,
19 2023. Basically, it's a modified Alternative 4. So
20 basically, so the alternate offer. So that's
21 basically -- that's my comment. Thank you.

22 CHAIR BALLINGER: Thank you.

23 VICE CHAIR HALNON: Anyone else need to get
24 something off their chest?

25 (Laughter.)

1 VICE CHAIR HALNON: I think you wore them
2 out, Ron.

3 CHAIR BALLINGER: I think we're -- yeah,
4 that's probably a good way to put it. So unless there
5 are other comments from members --

6 MEMBER PETTI: Ron?

7 CHAIR BALLINGER: Yeah?

8 MEMBER PETTI: I didn't want you to close
9 the meeting. I think we should talk about I don't
10 necessarily think industry needs to be here tomorrow
11 unless they want to. And I think even the staff could
12 participate remotely.

13 CHAIR BALLINGER: Yeah, I was -- we were
14 going to have that discussion, yeah.

15 MEMBER PETTI: Okay. Oh, good. Okay.

16 CHAIR BALLINGER: Yeah, and I guess I'm not
17 sure who to address this to.

18 PARTICIPANT: I'll be here in person no
19 matter what.

20 CHAIR BALLINGER: You'll be here no matter
21 what. Okay. I mean, the idea of industry doesn't
22 have to be here unless they want to, of course. The
23 same thing goes for the staff.

24 It would be nice if there was a sort of
25 conduit that we would have if we had a question or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 some discussion that came up where we needed to get --
2 where a staff member's comment would be more than
3 would be appropriate. So that would be my request.
4 And so unless I -- well, maybe I should talk to
5 Theresa.

6 MS. CLARK: Yes, we plan to have our team
7 available tomorrow.

8 CHAIR BALLINGER: Okay. That's wonderful.

9 MS. CLARK: And I think most of them will be
10 here because they planned to be here.

11 CHAIR BALLINGER: Yeah.

12 MS. CLARK: And we'll take it as long as it
13 takes.

14 CHAIR BALLINGER: Wonderful. Okay. That
15 solves that problem.

16 MR. BURKHART: Yeah, this is Larry Burkhardt.
17 Just -- and I'll let Al Csontos weigh in from the ACRS
18 staff. We did have a discussion with Al Csontos who
19 has coordinated the industry and EPRI's presentations.

20 And Al, I'll let you speak. But the
21 discussion we had is that he would be available and he
22 would make sure he has the contacts available in case
23 they are needed. So Al, why don't I turn it over to
24 you.

25 MR. CSONTOS: Yes, Al Csontos, NEI. Yes, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I'll be here tomorrow. Frankie (phonetic) will be
2 here tomorrow. And we'll have some of the industry
3 here tomorrow to answer. And I will be able to then
4 have a conduit to go back to the team to ask any
5 questions or to get your response. So we'll be here
6 to support it.

7 VICE CHAIR HALNON: Thanks, Al. And one of
8 the things that I'm going ask tomorrow is if I come
9 into the control room the day after a limitation as an
10 operator. When am I going to see different? When am
11 I going to do differently? So you can -- over dinner
12 and whatever beer you have --

13 (Laughter.)

14 VICE CHAIR HALNON: -- discuss that and come
15 back with some juicy stuff. I was talking industry
16 speak.

17 CHAIR BALLINGER: Okay. So with that,
18 again, I'm sure I speak with the subcommittee that we
19 appreciate the effort that's been made and getting our
20 questions answered. And we'll pick this up tomorrow
21 morning at, I guess, 8:30. And so with that, we are
22 -- I think it's going to be recessed until tomorrow
23 morning.

24 (Whereupon, the above-entitled matter went
25 off the record at 5:20 p.m.)

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguard
Regulatory Rulemaking, Policies and Practices

Docket Number: (n/a)

Location: teleconference

Date: Friday, January 17, 2025

Work Order No.: NRC-0184

Pages 1-93

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 REGULATORY RULEMAKING, POLICIES AND PRACTICES

8 SUBCOMMITTEE

9 + + + + +

10 FRIDAY

11 JANUARY 17, 2025

12 + + + + +

13 The Subcommittee met via Videoconference, at
14 8:30 a.m. EST, Ronald Ballinger, Chairman, presiding.

15 SUBCOMMITTEE MEMBERS:

16 RONALD G. BALLINGER, Chairman

17 GREGORY H. HALNON, Vice Chairman

18 VICKI M. BIER, Member

19 VESNA B. DIMITRIJEVIC, Member

20 CRAIG D. HARRINGTON, Member

21 WALTER L. KIRCHNER, Member

22 ROBERT P. MARTIN, Member

23 SCOTT P. PALMTAG, Member

24 DAVID A. PETTI, Member

25 THOMAS E. ROBERTS, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 ACRS CONSULTANTS:

2 DENNIS BLEY

3 STEVEN SCHULTZ

4

5 DESIGNATED FEDERAL OFFICIAL:

6 WEIDONG WANG

7

8 ALSO PRESENT:

9 LARRY BURKHART, ACRS/TSB

10 THERESA CLARK, NRR/DSS

11 AL CSONTOS, NEI

12 ELIJAH DICKSON, NRR/DRA/ARCB

13 LISA GERKEN, Framatome

14 JOSEPH MESSINA, NRR/DSS/SFNB

15 SCOTT MOORE, ACRS

16 JOHN PARILLO, NRR/DRA/ARCB

17 DAVID RUDLAND, NRR/DNRL

18 BARIS SARIKAYA, Constellation

19 ROBERT TREGONING, RES/DE

20 SUNIL WEERAKKODY, NRR/DRA

21

22

23

24

25

P-R-O-C-E-E-D-I-N-G-S

(8:30 a.m.)

CHAIR BALLINGER: Okay. This is a resumption of the meeting the Regulatory Rulemaking, Policies and Practices Subcommittee of the ACRS. I'm Ron Ballinger still chair of this subcommittee meeting. Members present and I don't have the real list, but I think Walt Kirchner and Dave Petti are remotely connected. And I don't --

VICE CHAIR HALNON: Vicki is also.

CHAIR BALLINGER: Who?

VICE CHAIR HALNON: Vicki.

CHAIR BALLINGER: And Vicki is on. Members present in the room are Craig Harrington, Tom Roberts, myself, Greg Halnon, Bob Martin, and Scott Palmtag. And our consultant Steve Schultz is here, and I don't know -- Dennis Bley is also online. So I am sure I'll miss somebody, but please let me know. I must remind you that this committee is running in accordance to FACA rules. I can use an abbreviated intro statement and the like, so I don't need to go much further than that.

VICE CHAIR HALNON: Vesna just came on.

CHAIR BALLINGER: And what? Okay. Vesna Dimitrijevic is now on. So I think we're definitely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 -- almost everybody except for Scott -- except for
2 Matt Sunseri, who may join us as well. So yesterday,
3 we were going through the slide that's on the screen,
4 and we had gotten down to number 8 and then one of
5 our members disabused me of that fact and suggested
6 that we need to continue the discussion on the control
7 room dose before we go to the broader impacts. And so
8 we turned it over to Dave Petti to at least start the
9 discussion. So Dave, are you okay?

10 MEMBER PETTI: Yeah. So I just want to
11 say I heard -- I didn't hear sort of consensus. I
12 heard a number of folks who didn't like the use of the
13 risk metrics to scale the control room dose, and some
14 who just didn't like the higher value. But then I
15 heard others who thought it was okay and didn't seem
16 to have a problem with it. And given the fact that
17 they were asked by the commission to just conform the
18 rule, and there are other places where the rule is
19 just conformed. So I think it's still worth discussion
20 because I didn't sense anybody in consensus in the
21 room on what we're going to say here.

22 MEMBER MARTIN: This is Bob. I didn't say
23 anything yesterday because I basically agreed with
24 Walt had said and wasn't going add to the echo
25 chamber. But I thought we did have a little more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 consensus.

2 MEMBER ROBERTS: So when I left yesterday
3 I wasn't really clear what Walt was saying. And so I
4 wanted to maybe get back around to what Walt's
5 proposal is, which basically is an accepted 10 rem
6 proposal for some set of conditions and use a 25 rem
7 for the most severe accident that's included in the
8 design basis. Walt, is that a fair characterization?

9 MEMBER KIRCHNER: Sorry. I had multiple
10 screens open. Let me make -- yes, I'll come back to
11 what Tom was suggesting. But let me first start by
12 saying by analogy let's look at things that we have
13 considered reasonably that have been quote/unquote
14 risk informed in one manner or other. So a good
15 example of that is EPZ sizing. What we don't change
16 is the acceptable dose, we change the distance in the
17 case of the EPZ size. So we still hold to or
18 recommend that the agency hold to, you know, the PAG,
19 the EPA Protective Action Guidelines, and/or, you
20 know, traditional dose consequence metrics. So having
21 a sliding scale for the acceptable dose to me just
22 doesn't make any sense. I think it's a misapplication
23 of using risk metrics in this case. It would seem to
24 me that you would have a design basis accident kind of
25 acceptable dose. The current is 5 rem. I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there's good in the preamble, the proposed rule there
2 is a good write up on this particular issue, and they
3 suggest 10 and then up to 25 in the case of, as Tom
4 was saying, severe accidents. To me, that makes sense
5 based on the Fukushima experience and such. Once you
6 have a severe accident, I don't understand why you
7 would have a sliding scale. You would determine
8 what's acceptable for this one-time exposure in an
9 extreme, unusual case, and 25 rem seems to be a
10 reasonable target. And then you'd manage the
11 situation accordingly to not overexpose the staff.

12 MEMBER PETTI: But Walt --

13 MEMBER KIRCHNER: Having a sliding scale
14 is just a misapplication, in my mind, of risk metrics.

15 MEMBER PETTI: Walt, your argument is
16 based on the occupational things that happen. This is
17 a design criteria for control room acceptability. So
18 yeah.

19 MEMBER KIRCHNER: The granularity makes no
20 sense to me either, but that's a different matter.

21 MEMBER PETTI: Yeah, I have a little bit
22 --

23 MEMBER KIRCHNER: It's over application
24 of technical calculational results without any
25 consideration of the -- of who's being exposed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER PETTI: Yeah, I don't -- if you've
2 done those calculations you know there's enough
3 uncertainty in the, you know -- once you have the
4 source to just the calculation, right. I mean there's
5 a whole protocol with chi over Qs and all of that
6 stuff. I mean there's conservatism there, but you
7 could easily come up 10 rem versus 5 rem, just change
8 a couple things that wouldn't be considered, you know,
9 outrageous. So I do think that 25 -- what I like to
10 say is that what they're doing is aligning the control
11 room -- the control room habitability dose and the
12 control room design aligning the criteria to something
13 that's more realistic to the occupational side.
14 That's how I tend to think of it.

15 MEMBER KIRCHNER: No, that -- I agree with
16 you. But those no need to invoke the CDF -- sliding
17 CDF scale to do that.

18 CHAIR BALLINGER: Yes. This is Ron
19 Ballinger. Where I come from and where Tom comes
20 from, I think, we use 5N minus 18 and 25 rem in an
21 emergency one time -- one lifetime dose. So going
22 through 5 to 10, again, like Dave was saying, when you
23 do these calculations that's in the weeds. The
24 difference 5 and 10, I'm not going to, you know, fall
25 on my sword by thinking I'm going to get cancer for 5

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 versus 10. But the 25 rem lifetime, that's been around
2 for a very long time, and it's consistent with all
3 kinds of standards and the like. But -- and so I
4 don't -- even for control room design, why not just
5 keep it that, 10 rem, 25 rem in an emergency or
6 whatever you want to call it and forget the sliding
7 scale. It just seems like sort of arbitrary -- not
8 arbitrary -- but forced response or some kind of
9 thing. Maybe I'm using the wrong words. But I think
10 I'm agreeing with Walt. Just make it simple.

11 (Simultaneous speaking.)

12 MEMBER ROBERTS: I look at table 7 in the
13 reg guide it actually does pretty close to what Walt
14 suggested which is there's a whole sequence of either
15 AOOs or non -- maximum hypothetical DBAs of that
16 limits like 5 and 10 rem. But then there's that top
17 rung that's the MHA LOCA which is not exactly a severe
18 accident, but it's essentially a severe accident with
19 containment not recurring that's not determined to
20 function. Now are the 25 rem and the only 25 rem in
21 this table then -- and that would seem to be
22 consistent with Walt's proposal. That's what he
23 trying to get clarity. If that's, Walt, what you're
24 saying, I think that makes sense to me. Because it
25 says that just for this artifice, it's only use for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 design criteria for the control room to get a control
2 room that's reasonably tight for other scenarios that
3 aren't analyzed, then that seems to makes sense. That
4 way you still get a 10 or 5 rem criteria the scenarios
5 that are closer to being real.

6 CHAIR BALLINGER: But isn't the 25 rem
7 connected to reality?

8 MEMBER PETTI: It's aligned.

9 CHAIR BALLINGER: For design purposes we
10 can use 25 rem, but in the real world that a limit
11 that you can't exceed. Regardless of what the
12 accident is.

13 MEMBER ROBERTS: Right. It's the same
14 number for different reasons.

15 CHAIR BALLINGER: Right. But it's still,
16 you know, why --

17 MEMBER ROBERTS: It can't be the same
18 number. It's almost a convenience but it's the same
19 number. But in reality, the 25 rem for this somewhat
20 stylized scenario you may or may not get 25 rem with
21 a severe accident as you manage it with severe
22 accident guidelines, and it's almost fortuitous if you
23 do or do not. You would manage this severe accident
24 at 25 -- you would start with the control room that
25 was as tight as practical which increases the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 probability you could manage the 25 and not be taking
2 an operative --

3 MEMBER KIRCHNER: Part 20 rules are still
4 in effect.

5 MEMBER MARTIN: Exactly.

6 MEMBER KIRCHNER: So --

7 MEMBER MARTIN: I just think whether we're
8 over thinking this.

9 MEMBER KIRCHNER: Yeah. That's what I
10 mean.

11 MEMBER MARTIN: I mean, this was all, of
12 course, driven by the high-level topic you're
13 increased which meant longer cycles, you know, the
14 engagement with industry basically says, 5's not going
15 to work anymore. Is it a big deal to move to 10?
16 Sounds like a pretty simple change, whether it's 10 or
17 25. I think I agree with you guys, there is probably
18 not a big, big change here. But there is the
19 Fukushima where when the event happened -- of course,
20 it becomes a radiation protection issue not so much a
21 design issue where, of course, they upped the control
22 room criteria or whatever it would have been in that
23 case or a radiation protection to a 25 which I think
24 may still exceed it in that case. So it was an
25 immediate exception, so I just think you just go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 whether it's 10, 15, 20, 25, seems like everyone was
2 happy with 10. You know, that's the easy button
3 because it's, of course, maybe more conservative,
4 doesn't really change the methods, it doesn't change
5 a lot of things. I don't think anybody was
6 complaining about 10. It seems like a natural --

7 CHAIR BALLINGER: What we're discussing is
8 the sliding scale.

9 MEMBER MARTIN: Well, I know. That's why
10 I said I think we're over thinking that kind of
11 detail. Just make the small change and everybody's
12 happy.

13 CHAIR BALLINGER: Dave probably knows the
14 answer to this but in these calculations when you
15 calculate the 25, what's the uncertainty the on the
16 25?

17 MEMBER PETTI: Yeah. I mean --

18 MEMBER MARTIN: You incorporate that in
19 there.

20 MEMBER PETTI: All I'm saying is that I
21 think we're -- Tom went exactly where I was going.
22 That for a certain class of events the acceptance
23 criteria will be 10. Those are the quote less severe.
24 But for the MHA LOCA, it'll be 25 because you're
25 getting closer to, you know, severe accidents and it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 aligns better with -- at 20 occupational standards.
2 That's all I'd say. And then we could say that, yeah
3 we don't -- we think that the, you know, that the risk
4 application is a little forced bit. It doesn't need
5 it. I guess I don't care about that as much.

6 MEMBER DIMITRIJEVIC: Yeah. This is
7 Vesna. I mean, I completely -- my point is the same.
8 It's a little forced. We don't really have a direct
9 connection should that be called demonstrated maximum
10 hypothetical accident. And the one thing which we
11 don't even consider is the importance of operator
12 actions in certain scenarios. So since we can
13 ultimately make logical connection between then why
14 make this fine tuning into the four things? I mean,
15 having the two limits make much more sense.

16 CHAIR BALLINGER: I mean, just saying that
17 we're -- it adheres to occupational standards, end of
18 story.

19 VICE CHAIR HALNON: I just want to make
20 sure that we continue to keep separate occupational
21 standards and the reference value that's being given
22 to evaluate features of the plan based on an accident.
23 And that's -- it seems like we're continuing to jump
24 over, oh, operators shouldn't get 25 rem. That's not
25 what this is saying. This is saying you evaluate your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 control room as a feature of the plan against the
2 accident dose and if it's over this number then you
3 have to either change the accident or you have to
4 change a criteria like leakage or something else. But
5 it doesn't say that from now on we're going to involve
6 -- you already get 25 rem in the control room during
7 MHA. That's handled by the different regulation and
8 it's something separate. This is simply a reference
9 value. I mean, we could show as a control room
10 leakage instead of dose. We could have chosen
11 thickness of the wall or something to that effect
12 instead of dose, but instead it makes more sense
13 comprehensively to choose a dose number because that
14 encompasses all of these different things. So then,
15 if you start with that premise the 10 rem versus 25
16 rem, why not allow the site to say, if I have this
17 accident gives me 11 or 12 in the control room, I can
18 say that's acceptable because I have a very unlikely
19 event and its below 10 to the minus of whatever, we're
20 at CDF, LERF or some other value from this. So I'm
21 not saying that -- yeah, you could make a case that it
22 doesn't make any sense to say CDF versus dose, and you
23 could have a sliding scale. But what else would, from
24 evaluation of safety of the plan or the likeliness for
25 frequency of the accident.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER PETTI: So, Greg, if we could just
2 -- I mean, if we go back to that table we say the less
3 severe events have a 10 rem target, and the MHA LOCA
4 has a 25 rem target. That's somewhat in a sense risk
5 informing. Because you're creating it based on the
6 severity.

7 DR. SCHULTZ: This is Steve. Dave and
8 Greg, I agree with you the -- with the approach you're
9 describing. We talked a little bit about Fukushima
10 and if you think about how the site responded to the
11 event, the control room dose was high. Those that
12 received doses which approached and exceeded 25 rem
13 were in the control room. They weren't necessarily
14 operators in the control room. And, in fact, when --
15 if you look at emergency preparedness and planning
16 associated with U.S. plants, the control room is good
17 to be designed at the level for 25 rem for severe
18 accidents and below that for the other accidents. And
19 10 rem is a good target as is described in the graph
20 guide. So I think that approach is appropriate. For
21 a risk-informed approach, I think the overall approach
22 would be associated with identifying the likelihood of
23 the events and certainly the severe accident event of
24 MHA LOCA, as we've described here in the last few
25 days, has a very low -- going to be very low

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 probability. The other point is that there's one
2 point in draft guide that I think deserves some
3 attention and that is, there's a -- there's a comment
4 in the draft guide that says for new reactors the
5 technical support center should be set at the control
6 room dose, but then selects a limit for the technical
7 support center of 5 rem, which I think ought to be
8 moved to 10 rem. If you think about emergency
9 response, the decisions associated with who does what
10 outside the control room is really dictated by and
11 established by the technical support center. And it's
12 usually the technical support center that makes
13 decisions who might go out into the plant the way they
14 did at Fukushima. Who might go out into the plant and
15 receive doses above the standard occupational dose in
16 response to an emergency.

17 VICE CHAIR HALNON: Steve, doesn't the
18 technical support center get evacuated at a certain
19 dose and change its function over to the EOF which is
20 equivalent to the abilities in the E plants?

21 DR. SCHULTZ: It may. But I was talking
22 about the decision making that associated with those
23 plant employees that might be asked to volunteer to
24 receive --

25 (Simultaneous speaking.)

1 VICE CHAIR HALNON: That's the stage where
2 actual decisions are made by the emergency director
3 which follows wherever the habitability would be.

4 DR. SCHULTZ: Correct. Correct. We
5 talked a lot about the operators receiving 25 rem at
6 Fukushima and -- in terms of emergency response.
7 They're, in fact, not likely to be going out into the
8 plant to do things in the event of a severe accident.

9 VICE CHAIR HALNON: I agree that there
10 needs to be a synergy there that makes sense. And I
11 hadn't looked at it for the same point of how it all
12 fits together, but probably could make a case for it.

13 DR. SCHULTZ: The other comment that the
14 sliding scale that has been developed within the reg
15 guide is an interesting one. I just don't think its
16 application to control room dose -- sliding scale
17 control room dose makes the most sense. It does make
18 an argument that this would be the performance based
19 part of risk-informed and performance based. In other
20 words, a sliding scale based on risk-informed would
21 look at the likelihood of the event, including
22 performance based, is an attempt -- and I think in
23 other instances it ought to be used -- an attempt to
24 give credit to those sites that completely gone of PRA
25 and have good results as a result of the effort of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 actions taken due to the PRA.

2 VICE CHAIR HALNON: And I'm fine backing
3 you're statement, Dave, with making it simple if we
4 can show that that's simple for everybody, not
5 excluding someone like what Steve's saying, someone
6 who's done a lot more work may be could get more
7 margin overall. A better treatment by the rule if
8 they've done more work. I just do want to eliminate
9 that potential.

10 CHAIR BALLINGER: Well, we can -- as part
11 of our letter we can make -- we can outline what we're
12 saying. But it's really up to the pilot studies and
13 the workshops that'll go forward that'll eventually
14 sort this out. So I don't know that we should be
15 saying you shall do this as opposed to, consider the
16 following, and let that get sorted out as part of the
17 overall discussions of the rule.

18 VICE CHAIR HALNON: I think that we can
19 agree that it's a risk-informed approach. I mean,
20 that's pretty aligned. We're all agreed that those
21 suggestions that exist being and in keeping what we
22 say the simple method is a risk-informed approach. I
23 think we're saying that. There's an opportunity here
24 to use a risk-informed thought process and make it
25 real simple as opposed to putting in more detailed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 processes that's dependent on a potentially unrelated
2 or -- maybe not unrelated -- but loosely tied risk
3 metric. I wouldn't say that we wouldn't indict either
4 one but --

5 MEMBER MARTIN: And I want to -- this is
6 Bob, I want to defend the folks that do the analysis,
7 right. They have methods already and, you know, much
8 of a deviation from how they do thing is churn. Now,
9 this is not like changing LOCA methods or anything.
10 It's not quite in the same ballpark. But nonetheless,
11 I mean, there's public comment later, you know, on
12 what you want. But I just had the impression they
13 wanted simple, you know. And I don't think risk-
14 informed in some articulation like we have now or even
15 a lighter version of that is necessary. Drawing a
16 line in sand just continues to support what we've
17 already had, which of course is fine. But now that
18 we've moved to the changes with cycle lengths and what
19 have you, you need more, we just move the line and
20 they can continue to use the same methods, just with
21 a different criteria, slightly different criteria. If
22 that's good enough, we just can -- simple and move on.
23 It doesn't disrupt what analysts do. Serves its
24 purpose. So anyway, in defense of analysts.

25 CHAIR BALLINGER: I've got a hammer, I'm

1 going move on that nail.

2 MEMBER MARTIN: Exactly. Everything looks
3 like a nail.

4 DR. SCHULTZ: The analysis for control
5 room -- this is Steve. The analysis for the control
6 room dose is not a simple exercise.

7 MEMBER MARTIN: It's not LOCA.

8 DR. SCHULTZ: And with the appendices
9 changed in rev 2 of the guide, it makes it more of a
10 challenge for certain in the MHA LOCA. And when we
11 consider that what MHA LOCA could be classified as a
12 severe accident, I would agree that 25 rem makes sense
13 for that evaluation. And 10 rem for the other
14 evaluations for the control also makes sense based on
15 the arguments that are in the reg guide as well.

16 MEMBER ROBERTS: I have a quick question
17 for Elijah. Just following up on Steve's question of
18 the TSC. There's some discussion about the TSC
19 requirements and thereby the control room
20 requirements, are they the same. But there is one
21 sentence in the draft guide that says that the 5 rem
22 criterion applies. Is that a typo or is that an
23 intended difference?

24 MR. DICKSON: This is Elijah Dickson with
25 the staff. I think that's something we massed. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 it's a typo. Yeah.

2 DR. SCHULTZ: It refers to 10 CFR. But
3 there's really no value in 10 CFR associated with the
4 technical support side.

5 MEMBER KIRCHNER: Ron, this is Walt
6 Kirchner. Just a question for the staff. Elijah is
7 there. Elijah, is there -- as part of the rule, are
8 you going to change Appendix A Criterion 19?

9 MR. DICKSON: Yes. As part of the rule
10 GDC-19 would change to be consistent with 10 CFR
11 50.67. So the proposed rule language would change the
12 value from 5 rem to 10 rem, and then we an additional
13 paragraph that allows for this -- effectively this
14 sliding scale to go up to 25 rem based off of plan
15 specific risk information or, in this case, we put
16 into the guide was utilizing or leveraging the CDF
17 information from their PRAs.

18 MEMBER KIRCHNER: Thank you.

19 MR. DICKSON: In the presentation I gave
20 last month there is an example of that language. I
21 think it was on 17th. That was the first day I gave
22 it the presentation. But similar conforming language
23 to GDC-19.

24 MEMBER HARRINGTON: This is Craig.
25 Elijah, is there any sense that the sliding scale not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 just as an opportunity but maybe an incentive to the
2 plant?

3 MR. DICKSON: Yeah. So as we wrote it in
4 the federal register notice in the draft documents you
5 all received, we based the sliding scale from
6 commission policy and SECY-98-144 that asks us to
7 develop performance based and risk-informed rules that
8 do provide incentive for increased safety, right. So
9 the intent here with this sliding scale is to leverage
10 the PRA site-specific risk information or other
11 information, right, to allow for a higher value. So
12 if the facility itself is designed and has a low CDF
13 value, then we are considering that they don't need to
14 be held to the same standard as those facilities that
15 have a lower CDF value. So we're trying to provide
16 that incentive for plant designs. The thought is, for
17 instance, the AP1000, right. They have 1e to negative
18 7 type CDF value. Do we want to hold them to the same
19 standard for this MHA LOCA as some of these Gen 2
20 plants that we have at lower CDF. So we're trying to
21 provide some incentive with the rule language itself,
22 and then our proposal to provide that incentivization
23 is in the guide, is based off of this sliding scale.

24 MEMBER HARRINGTON: So if we don't have a
25 sliding scale, the incentive concept just goes away.

1 MR. DICKSON: Right. And we have a
2 thought process being drafted up now in an enclosure
3 to the SECY paper, and it's talking exactly about what
4 you all are talking about here. That where we looked
5 at three different options, the first option was just
6 update the rules at 10 rem. There's plenty of
7 information to support that. Option 3 was to update
8 it to 25 rem. There's plenty of information to
9 support that to as well. But as the staff we felt
10 that we could find something in the middle between 10
11 and 25 rem that could provide some incentive for
12 facilities to make some operational changes or some
13 design feature changes that might decrease their site-
14 specific risk and gain a little bit of incentive in
15 the control room design criteria itself. And that
16 makes sense if you have a facility that has a 1e to
17 negative 7 type CDF to allow them to have a higher
18 design criteria to add for additional operational
19 flexibility at the facility. That's the thought
20 process. We have it in a enclosure to the SECY paper.
21 When you guys see -- you don't have that one, I don't
22 think. But when you guys do see it, or when ACRS sees
23 it, I highly recommend taking a look at it and you
24 could see our thought process there. And Sunil wanted
25 to jump in.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. WEERAKKODY: I'm the senior advising
2 PRA in NRR. Am I allowed to say something on that?
3 So I worked with Elijah and my then-boss Mike
4 Franovich very closely with respect to whether or not
5 we should have a sliding scale. And Elijah gave a
6 great example with AP1000, but I want the committee to
7 benefit from some of the other thoughts as they apply
8 to the operating plants. We really wanted to do
9 something even for the operating plants. There are
10 plants out there who are developing a risk-informed
11 culture and based on that, when they do the math, the
12 capital budgeting gives them more of an incentive to
13 lower their risk. As a case and example with respect
14 to the FLEX strategies, there were some plants who
15 went out and bought two extra diesels, big size, and
16 that -- and they change their seals and that's a
17 significant reduction to their CDF. So I was
18 listening, and I know it brings this added complexity,
19 but I want to emphasize that the thought process was
20 we really want to get to a paradigm where the
21 regulator is continuously motivating our operating
22 plants also to enhance safety. So that was the
23 thought process. So hopefully that helps Elijah. I
24 was working with Elijah. We had some difficult
25 conversations among us talking about some of the exact

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 same things. You know, the added complexity. Why
2 can't we keep it simple, because we have plenty of
3 information to support a claim. So thank you for your
4 patience. I was out yesterday. I will answer any
5 questions if you have any.

6 CHAIR BALLINGER: Thank you. Weidong, can
7 we get that enclosure?

8 MR. WANG: It is part -- I think it's a
9 white paper.

10 CHAIR BALLINGER: Or whatever it is.
11 Whatever you're talking about.

12 MR. DICKSON: Yes. So, I mean, there is
13 a white paper on this as the basis for this sliding
14 scale. But the staff's decision-making process and
15 moving forward with the rule making, it's an enclosure
16 to a SECY paper that will be made available. It's not
17 available yet. You'll see it in the rule making
18 package.

19 CHAIR BALLINGER: Whatever gets discussed
20 at one of these meetings has to be -- we have to have
21 access to it.

22 MR. DICKSON: Right. Okay.

23 MEMBER PALMTAG: This is Scott Palmtag.
24 Elijah, I just want to have clarification. A sliding
25 scale it gets applied to the dose for all accidents.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Is it all accidents or just the LOCA?

2 MR. DICKSON: It's just MHA LOCA. The
3 maximum hypothetical accident, not all the other
4 accidents.

5 MEMBER PALMTAG: So what's the proposal
6 for all the other accidents? Keep those at 10?

7 MR. DICKSON: At 10 rem for all the other
8 accidents for the control room. And then for the EAB,
9 exclusionary boundary, and low population zones those
10 would stay the same.

11 MEMBER PALMTAG: Okay. And the sliding
12 scale is just for MHA LOCA?

13 MR. DICKSON: Just for MHA LOCA.

14 MEMBER PALMTAG: Okay. I did not
15 understand that at all so --

16 MR. DICKSON: Understood. okay.

17 DR. SCHULTZ: Elijah, you mentioned that
18 this is going to be described as a general topic in
19 terms of the overall approach, that is the sliding
20 scale. Here, the decision was made to apply it to
21 control room dose for the MHA. Are there areas of the
22 rule that is going to have something like this in
23 terms of a sliding scale for applications? Talked
24 about use of PRA in other applications. But did you
25 hear anything about if there was special things that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 might apply to a plant with a very low CDF or --

2 MR. DICKSON: This scale, to my knowledge
3 --this type of approach, to my knowledge, isn't being
4 applied to the other areas of the rule making. So if
5 you're referring to 50.46, no, it's not being applied
6 there. Joey?

7 MR. MESSINA: Correct. Correct.

8 DR. SCHULTZ: Okay.

9 MEMBER ROBERTS: Slightly different
10 question. Maybe you can help answer this question.
11 Direct Guide 1426 which I don't think applies for this
12 part of the rulemaking, but Direct Guide 1426 has I
13 think an interesting paragraph on risk acceptance
14 other than probable risk assessment and on screen, the
15 first couple of sentences in the paragraph it says,
16 even with a PRA that addresses all the relevant
17 initiators and operating modes, many proposed facility
18 changes may affect equipment that is not explicitly
19 modeled in the PRA, and it goes to the example of
20 containment leak detection systems. It seems to me
21 that a control room would also fall in this category.
22 That the command and control that you get from being
23 in the control room is somewhat intangible, and I
24 don't know how well that's modeled in PRAs in terms of
25 how decision making would be degraded if operators had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 to control it from someplace farther away. Is the
2 intent to apply that concept when evaluating control
3 room dose increases?

4 MR. WEERAKKODY: I'm not sure. I might be
5 answering the wrong question. There is -- you are
6 referring to DG-1426. I believe that's direct guide
7 the in support of the 4056A. I wouldn't mix the two
8 because really for the control room dose -- that's the
9 one that I worked with closely with Elijah -- we
10 already knew that there's a stylized accident that
11 they use to come up with the same criteria for the
12 control room. And then we said, okay, we want more to
13 get licensees who are safer to give more flexibility.
14 And we kind of talked about, you know, what is the
15 best criteria -- not the perfect criteria -- that can
16 have a correlation between MHA and LOCA and then we
17 can adapt it to CDF. You know, we could have taken
18 things like LERF. But I will not -- I mean that's,
19 1426 was written with a completely different mindset.
20 So I wouldn't venture to try to connect the two.

21 MEMBER ROBERTS: All right. It seemed to
22 be the same concepts applied. That the -- if you have
23 a control room that was leakier that was permitted by
24 the rule, and so, you know, an applicant were to
25 change the filter design or a tech spec that allows

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 for more leakage in the control room or the way they
2 manage it and those kinds of things, then that would
3 increase our risk in Level 2 PRA because maybe you
4 don't control the dose to the public as well because
5 you're not as effective in manning the control room.
6 And so it would seem like the evaluation of a design
7 change enabled by this rule would have very similar
8 logic as to their -- the thing I just read that you
9 want to understand what is the risk implication of
10 having let's say a leakier control room if you ran us
11 through an accident scenario that's well beyond what
12 is in the MHA LOCA.

13 MR. WEERAKKODY: I would 100 percent
14 agree. This is Sunil Weerakkody. I do 100 percent
15 agree that there is a correlation, but we are balance
16 the state to getting too much complexity down to the
17 degradation. So that's why I said you're right on.
18 You know, those exact same things apply here as well.

19 MEMBER ROBERTS: There was a sentence in
20 Rev 01 of the Reg Guide 1.183 that got deleted or
21 rewritten, I couldn't quite tell which, in Rev 2,
22 which would have the applicant, you know, evaluate the
23 implication of any change enabled by the AST on risk,
24 either through active management or a PRA. And so
25 it's a very, again, similar concept that's in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Direct Guide, but for some reason that got deleted or
2 revised in Rev 2 and I wasn't quite sure what the
3 intent of that was.

4 MR. DICKSON: Yeah. After -- this is
5 Elijah Dickson with the staff. After our discussions
6 last month, I went and took a closer look at that.
7 And we made a lot of improvements in regards to
8 defense in depth and safety margin discussions, and I
9 believe that's sentence was in the Defense in Depth
10 section. We brought in concepts from Reg Guide 1.174
11 to have seven or eight concepts that are really good
12 to think about in regards to defense in depth. And
13 then we made additional edits to that section, trying
14 to provide examples of what we would be thinking about
15 in a severe accident. So we talked about, like, the
16 IPEs and some other areas where you could be
17 considering severe accident mitigation. But it's --
18 you're right. It's not as direct as to go look at
19 severe accidents, make sure that these design changes
20 are not impacting things like EOP and SAMGs, I think
21 is what you're referring to. Now, what are the
22 follow-on effects to making design changes under
23 severe accident conditions. And that sentence, could
24 it be added back to it? I believe. But as well as,
25 you know, maintain some of -- giving some examples of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 what you should be thinking about in severe accidents.
2 So that was, I think, a good thought of Member
3 Roberts.

4 MEMBER ROBERTS: Yeah. And I think it's
5 there. It's just it was clearer in Rev 1. And I
6 think it's clearer in Reg Guide 1426.

7 MR. DICKSON: Yeah.

8 MEMBER ROBERTS: And so it might be, you
9 know, worth looking just to make sure you caught the
10 right guidance and what kinds of evaluation to expect.
11 It's not just a matter of making numbers, you have to
12 also look at, okay, those are all based on stylized
13 scenarios that aren't the scenarios that we think are
14 risk significant scenarios. So what is the role of
15 the control room in those scenarios which probably is
16 not modeled all that well in the PRA. I think you
17 agree with that.

18 MR. WEERAKKODY: Yes, sir. This is Sunil.
19 I believe I can -- the way I'm internalizing your
20 feedback is we have DG 1426 and then you have Reg
21 Guide 1.183. The way I'm thinking of that is, you
22 know, there should be some high-level consistency.
23 You know, it's the same rule. You have two different
24 Reg Guides, and thank you for that.

25 MEMBER ROBERTS: Yeah. And the other

1 point is to make sure that we don't lose the fact that
2 this -- these scenarios are stylized in Reg Guide
3 1.183, and at least it seems to me the real goal is to
4 support sort of active management and if there's some
5 control room degradation that's allowed by the
6 stylized scenario that would adversely affect the
7 accident mitigation, I think you weren't looking.

8 MR. WEERAKKODY: Definitely. Yes.

9 MEMBER ROBERTS: Okay. Thank you.

10 DR. SCHULTZ: Along those lines, Elijah,
11 when the -- I'm recalling back when the alternative
12 source term was first proposed and developed by the
13 NRC and the industry, the question associated with
14 control room unaffiliated in-leakage came up. It was
15 a -- I'll call it a requirement of those adopting AST
16 to do unfiltered in-leakage testing in the control
17 room. And you mentioned that had the other day that
18 is still being -- that is still the expectation is
19 still the -- and I don't expect that any plant would
20 take -- would make design changes as a result of these
21 changes associated with moving the dose limits up to
22 degrade the occupational protection that's provided to
23 control room operators.

24 MR. DICKSON: Yes, you're right. There is
25 a whole program in regards control habitability.

1 Every 7 years they do a tracer gas test. And that was
2 based off of operating experience from the late 80's
3 and early 90's were they found that the control rooms
4 were much more leakier in design and so that kicked
5 off a whole regulatory initiative to tighten these
6 control rooms back up, put in these programs. They
7 are controlled in the aspects that you mentioned and
8 on administrative controls. And the values that they
9 use in the consequence analyses are rather usually
10 several factors higher than what they're actually
11 testing at. And that's something that we assess.
12 When we receive an amendment, often we'll ask them,
13 you know, what is your testing data for the control
14 room. And we can see whether or not there's enough
15 defense in depth there. And then, of course, the
16 additional margin that may have to provide, you know,
17 in case they had a bad testing day. That's what that
18 margin is there for, to handle that from an
19 operational point of view.

20 DR. SCHULTA: Thanks for the additional
21 information. That helpful.

22 MR. DICKSON: John Parillo, my coworker,
23 has his hand up.

24 MR. PARILLO: This is John Parillo. I
25 work with Elijah and for the staff. I would just like

1 to point out to the committee on Table 7.1 which -- of
2 the Draft Guide listing the changes to the dose
3 criteria, the acceptance criteria, that one of the
4 concerns that we had was that by relaxing the control
5 room criteria, might -- as being discussed, might have
6 an unintended consequence of reducing the
7 effectiveness of the control room design's protective
8 safety system such as the filtration systems and so
9 on. And so what we did was, if you'll notice for the
10 accidents that have a source term which is based on
11 the coolant only and the assumption is that that
12 source term is not going to be affected dramatically
13 by the increased enrichment and higher burnups and so
14 on, that we maintain the lower acceptance criteria, 5
15 rem, for those accidents. So sometimes those
16 accidents do, you know, challenge control room so that
17 -- in other words, what I'm trying to say is we do not
18 expect that by virtue of relaxing the acceptance
19 criteria that it's going to result in a degradation of
20 the effectiveness of the control room because they
21 still will need that effectiveness to meet that lower
22 acceptance criteria for those accidents which are the
23 concurrent spike accidents for steam generator 2
24 rupture and main steam line break. So I just wanted
25 to point that out to the committee. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 DR. SCHULTS: This is Steve, John. Thanks
2 for the clarification.

3 MR. PARILLO: You're welcome.

4 MEMBER PETTI: So he based on what I'm
5 hearing, here's had the concern I have. I think we
6 all would agree that we support the staff trying to
7 incentivize plans to enhance safety. So when you
8 think of the thought process that Elijah said they
9 went through, I think we agree with the thought
10 process. In which case they're just using CDF as a
11 metric for better or worse to try to incentivize the
12 plants. So this is where I think it's a struggle
13 because I think otherwise I think we are kind of
14 aligned on, yeah, MHA LOCA is the only one that this
15 way applies to, 10 rem to the less severe events. So
16 that's, in essence, a form of risk informing because
17 the frequency of the events versus the dose, you know,
18 are aligned there. But how do we -- the idea that
19 it's a forced fit using CDF versus incentivizing the
20 plans to enhance safety, I'm having trouble figuring
21 out how we bring those two together.

22 VICE CHAIR HALNON: And, Dave, may be
23 very well what the letter needs to say. And we don't
24 have to couple up with a final answer today because
25 we've got a lot of work to go, a lot of workshops, and

1 other discussions. Any guys generally in favor of
2 what we're doing, maybe there's a better way of doing
3 it as they adjudicate it through a workshop type of
4 atmosphere. We certainly should hold this in our
5 letter as on open item the or some other whatever we
6 want to call it that we're going to reengage on to see
7 where the industry and NRC come to a meeting of the
8 minds on down the road. And it may be very well the
9 same thing to know we can express a little bit more.

10 MEMBER PETTI: Okay. I think -- I can --
11 I've been taking notes, so I guess, Ron, I will try to
12 write up something on this one. Because there is
13 going to be some homework when we're all done on each
14 of these areas and who's going to take the lead and
15 write something up for the letter.

16 CHAIR BALLINGER: Good plan.

17 MEMBER PETTI: I think if there's no more
18 discussion, we can move to the broader impacts.

19 CHAIR BALLINGER: Okay. So now we're on
20 number 8, and it's a kind of open discussion I suppose
21 as it always is. And look for input from members on
22 broader impact. I think we kind of alluded to these
23 and actually mentioned some of these in previous
24 discussion yesterday related to this, what I'd call
25 the tentacles that this rule has out into the rest of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the system. So that included, you know, power
2 upgrades which have been discussed, and then other
3 issues which I'm drawing a blank on, but I know there
4 were a couple.

5 MEMBER PETTI: Yeah. So I've got lists
6 here that -- I mean, this -- I was -- what happened is
7 that Tom had put together something that liked good
8 about, you know, how we're taking deterministic rules
9 and we're trying to risk inform them. And he was
10 focusing somewhat on severe accident risk. I had
11 written something about making sure the staff
12 continues to think about other parts of plant safety
13 because this is kind of like having heart surgery
14 making sure the rest of the system still works, right.
15 I think Bob had talked -- had some comments relative
16 to, you know, looking at the effects on EPZ and SAMG.
17 I then further raised issues on tech specs and aging
18 management based on what we heard on yesterday
19 morning. So my picture is a -- something in the
20 letter, you know, a comment that not that anything has
21 to necessarily change, but that the staff continue to
22 think about these things in the broader sense. And we
23 can list these items to show the commission, look,
24 this touches lots of different things. That's sort of
25 my sense of what would be a good conclusion of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 something to put in the letter.

2 CHAIR BALLINGER: Yeah. I mean I think
3 that we can make a list but stress that it's not
4 complete because we might leave something out. And
5 I'm also guessing that the staff has got their own
6 list somewhere. Hopefully they overlap. But, yeah.
7 Yeah.

8 VICE CHAIR HALNON: That kind of follows
9 my question about, you know, when I take this shift
10 the day after it's implemented, what am I going to see
11 different. The effect on the control room operator to
12 me is one of the more important -- I get all of the
13 analysis behind the scenes and stuff like that, but
14 it's not -- that doesn't do a lot for me to operate a
15 plant unless I can see increased operating margins, a
16 few more tech specs to have to comply with, and those
17 sort of things. And I wrote on the key analysis, a
18 lot of this is an analysis of design space, but it's
19 really where the rubber meets the road is how does it
20 affect the control room operator and as Steve was
21 saying, going beyond the control room to the TSC and
22 the EOFs and that's so the EP effects of it. I'll
23 make sure we stay focused on practicalities as well.

24 MEMBER PETTI: No, I agree. That's why
25 I sort of raised issue on, you know, amps and the tech

1 specs. I'd like -- I think it'd be good if like Bob
2 and Tom worked this one because they were the ones who
3 had good words and roll in these other items that
4 we've talked about for the last day and a half.

5 MEMBER MARTIN: This is Bob. Where I kind
6 of fall on these broader issues, you know, we can --
7 hopefully we don't get a certain level of complacency
8 regarding all the work that's done to, you know, risk
9 inform, you know, the accident analysis, the focus on
10 fuel, and project that I think we have the same
11 understanding beyond that of the containment and new
12 leases and stuff like that. I'm a little bit more
13 conservative in the sense that I still believe
14 deterministic design criteria be moved out, you know,
15 the final barriers or the final barrier for sure to
16 cover residual risk. It's probably not a popular
17 idea. But I'm fine with a certain segregation of how
18 we look at different problems as the design basis.
19 We've done a ton of work, you know, with LOCA. We
20 understand fuels quite a bit. We understand, you
21 know, how water works. The methods going beyond that
22 are just not as well characterized as we've done
23 there. And to say we have a different method or
24 different -- maybe the old method for how we approach
25 containments, EPZs, and that sort of thing, doses, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 have no problem making -- drawing a line and saying
2 these are different problems. We have, you know, a --
3 different inputs to that. So I don't know if I'm as
4 comfortable with blending -- harmonizing methods
5 across the different kind of physical defenses. A
6 quick sound bite there. So in some ways it's also
7 saying, let's just keep focus on what we know and the
8 immediate problems, immediate challenges, immediate
9 interests and what the industry is looking for with
10 longer cycles and, you know, keep us in that smaller
11 box. And if it looks a little messy because we have,
12 you know, these different boxes of how we approach
13 things, we live with it for the time being as we
14 continue to gather more information and support better
15 methods. I think as we get into mechanistic source
16 term solutions and see more of those, we'll get better
17 confidence about where we can go on these other
18 questions. But I don't know. I'm a little anxious
19 about doing too much.

20 MEMBER PETTI: Well, again, I'm not
21 arguing that we change anything. What we're saying is
22 that the staff should continue to think about the
23 impact of the rule in these other areas where there's
24 subtleties. Again, they may never see an LAR, but
25 better to be prepared, right, in advance to have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thought through these things. You know, what struck
2 me was I asked the question, and they say, yeah. We're
3 thinking about it all the time. And I'm like but you
4 didn't tell us, you know. I mean because those are --
5 when you write a rule -- this is why writing
6 regulation is not easy, right -- you've got to think
7 about the unanticipated or, gee, I didn't really mean
8 it that way. I mean, people read things differently
9 and interpret things differently which is why they've
10 got to have all these workshops. But the other thing
11 I worry about -- because, you know, we've sat here in
12 other venues -- is we tend of think of things in a
13 very integrated sense. Whereas, the way the staff is
14 organized, they've got, you know, expertise in each
15 specific area. Now, they are working together to
16 help, you know, assure sort of an integrated look.
17 But that's what our role is. And I just want -- it's
18 a more positive thing to say, keep thinking beyond
19 just, you know, the analytical stuff inside the core
20 about what this could be. That's all I wanted to put
21 in there.

22 MEMBER MARTIN: I certainly have no
23 disagreement with that. I think I'm saying the same
24 way, just another way. There's always going to be --
25 you know, as we make changes, there's going to be some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 tension because of the points that Dave raises. And
2 as those tensions, you know, become more evident, we
3 should inherently be looking at recognizing them and
4 looking at them and planning the next. I think the --
5 you know, one of the biggest things we worry about is
6 that, you know, lot of, you know, these what are
7 called projects, but obviously rule making is a big
8 deal, that there is a commitment until you kind of get
9 to a milestone and then all of a sudden things go
10 dormant. I mean, we kind of heard the story about,
11 you know, DG-1216 yesterday and it goes up to 2016 and
12 then goes dormant. And that just -- obviously our
13 body is going to go, well, give me the key point. And
14 recognizing the tensions that are there and doing the
15 investment, gathering of information which are more
16 with proposals for new policies or rules.

17 VICE CHAIR HALNON: So one other area
18 that -- well, there's probably several, but we heard
19 several times in the spirit of simplicity the control
20 room dose discussion, we heard several times that the
21 complexity and some of the processes to get into using
22 parts of the rule may be difficult, and in some cases
23 and add burden, add dose, add inspections, that sort
24 of thing. We should emphasize the need to root those
25 things out during workshops and try to work the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 way so that people say that would be an easier way to
2 do it. And it bounds -- maybe retain the complexity.
3 If you need to have margin, you can do a lot more work
4 instead of more money in the analysis but allow a more
5 simple bounding process. If you have a plain margin
6 and that would also serve the new actors coming in as
7 well in the safety margin than the ones we have now.
8 So I think that would be an important point to make.
9 This is sort of a letter to encourage the industry and
10 staff, not necessarily so much inform the
11 commissioners of where all the issues are. I'm sure
12 there's plenty of drop-ins and other information
13 coming your way saying that we acknowledge the same
14 areas -- like Bob says, areas of tension, and that
15 we're going to be watching those may give them some
16 comfort. But also, to make sure that we encourage
17 these issues to get through the process just to go
18 forward and then do it promptly because there's not a
19 lot of time to work through it.

20 CHAIR BALLINGER: Okay. Speaking of not
21 a lot of time, the rubber is about the hit the road
22 here, in that we have to produce a letter, and it has
23 to be produced by February the whatever. And so what
24 I would suggest is that we have a discussion now that
25 we can agree on not the exact wording, but conclusions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 and recommendations that we have to form the letter
2 around. We can get consensus or sort of consensus
3 around that, that'll help me an awful lot and it'll
4 probably also help everybody who have been assigned,
5 if we want to do that, various members to do various
6 things or address various areas, although we really to
7 let all members comment on anything that we want, of
8 course. I would also remind people that this -- and
9 Larry keeps reminding me the same darn thing -- this
10 is a draft rule. It's not -- unless it's really
11 something we think about, we shouldn't be sticking
12 stakes in the ground and hills to die on in the letter
13 because of what is going to happen going forward.
14 What we should be doing is making, as we always do,
15 constructive suggestions that would allow the staff
16 and the industry to deal with them in workshops and
17 maybe include some of our thoughts in their thinking.
18 Along those lines, the letter from NEI was dated
19 1/22/25. And so I would suggest that members read
20 that letter.

21 VICE CHAIR HALNON: Wait a minute.

22 CHAIR BALLINGER: No. January.

23 VICE CHAIR HALNON: Yeah. Of '24. You
24 said '25.

25 CHAIR BALLINGER: That's what I meant.

1 VICE CHAIR HALNON: Okay.

2 CHAIR BALLINGER: That's what I meant.

3 Oh, I thought there was one that was right
4 after the December subcommittee meeting because I was
5 told by NEI that we only got this rule a week ago.
6 Anyway, it's a good thing to read to provide a little
7 context, if you will, with respect to options -- all
8 the various options from the various stakeholders and
9 things like that. Not that it would -- you know, not
10 that it's something that needs to influence our
11 discussion, but it's a point of reference, if you
12 will. So all that being said, I am sure that Dave
13 will disabuse me of what I just said.

14 MEMBER PETTI: So yeah.

15 CHAIR BALLINGER: I would like to see if
16 we can have a discussion on the major conclusions and
17 recommendations that we would put in the letter. Now,
18 I see 1 through 8, maybe that's a sort of thinly
19 veiled attempt to do that.

20 MEMBER PETTI: Exactly.

21 CHAIR BALLINGER: Okay. So it's not so
22 thinly veiled.

23 MEMBER PETTI: No. No. But let me --
24 before we go there, the there's one thing that came
25 up, hit me listening to industry and we've never said

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 anything. You know, the staff decided, based on their
2 reg basis, to go with option two. But I heard a
3 number of comments from industry about Option 4,
4 Option 5. Do we want to say something about --

5 CHAIR BALLINGER: If you look at that NEI
6 letter, there's a lot of discussion of those things in
7 there. In fact, that's all that's discussed in there.

8 MEMBER MARTIN: This is the major topic of
9 the letter. That's right.

10 VICE CHAIR HALNON: And Theresa said in
11 her opening remarks that they were working on the ALS
12 review. I think that we talked about -- one of my
13 comments about the incremental -- I won't say that --
14 it's improvement that we're doing this. It's not the
15 boldest move we can make, but it's a move that
16 probably appropriate in this time and frame with the
17 amount of change. We should continue to work on the
18 next level of that improvement which, to me, is the
19 ALS option to eliminate the large, big bulk of
20 discussion, potentially. So I think that should save
21 it. I think we should hold that as that's the next
22 point and that it should be done promptly and continue
23 the process, not just for the existing fleet, but as
24 we go forward with the new SMRs and other light water
25 type reactors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. MESSINA: Joe Messina. Can I just
2 correct? The ALS does not remove the large break LOCA
3 completely. They still have to do the PCT and MLO
4 evaluation. Just dispositions FFRD.

5 VICE CHAIR HALNON: Yes.

6 MR. MESSINA: Okay. Just wanted to make
7 sure.

8 VICE CHAIR HALNON: Yeah. Thank you, Jim.

9 MEMBER PETTI: So okay. Yeah. I have no
10 problem with putting something in there about that.
11 Who would like to volunteer that one? Don't all jump
12 at once.

13 VICE CHAIR HALNON: Craig raised his hand.

14 MEMBER PETTI: Craig did. Great. Great
15 Craig. Thank you.

16 MEMBER HARRINGTON: That means we have to
17 consider whether I can though.

18 VICE CHAIR HALNON: Yeah, that's true.

19 CHAIR BALLINGER: Well, let's just go down
20 the line then. I mean, what is the conclusion and
21 recommendation in that area?

22 VICE CHAIR HALNON: I think it's a short
23 one.

24 CHAIR BALLINGER: Okay. Well, what is it?

25 VICE CHAIR HALNON: It is to accept this

1 incremental improvement and to continue to work on the
2 next level of the ALS to convince the -- the FFRD is
3 the big question mark in all this.

4 CHAIR BALLINGER: So that's an overall
5 conclusion regarding the entire rule.

6 MEMBER HARRINGTON: I think that the ALS
7 piece is parallel to the rule.

8 CHAIR BALLINGER: Well, that's what it
9 says in the NEI.

10 MEMBER HARRINGTON: ALS helps move forward
11 with the immediate problem in the schedule that the
12 industry is pursuing that was described to us
13 yesterday to allow them to move forward with increased
14 enrichment. It's not taking anything away from the
15 rule, the broader proposed rule. That should still go
16 forward because it does more and other things.

17 CHAIR BALLINGER: The ALS is not 1 through
18 8. It's separate.

19 MEMBER PETTI: All right. I think that's
20 a good way to end. It would be like our last one
21 because it would, you know, point to stuff sort of
22 outside, you know, what we were asked to look at.

23 VICE CHAIR HALNON: It removes a large
24 piece -- uncertainty is not the right word probably
25 because -- a large piece of the regulatory uncertainty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 going forward.

2 DR. SCHULTZ: It goes after the broader
3 impacts and broader opportunities that you might --
4 that should be.

5 CHAIR BALLINGER: Because I keep coming
6 back to the NEI letter. They talk about not just
7 Option 5, but Option 4. It's on BWRs, all kinds of
8 stuff. And then combinations of Option 4 and Option
9 5, ALS being Option 5, and the like. So there's a lot
10 of discussion and it's not just ALS.

11 DR. SCHULTZ: There's the opportunity and
12 there are effects on all of the points and all of the
13 designs. And some are getting more benefit than
14 others in the selection of 2 and 5. And 4 is
15 something that the BWRs also said they needed to
16 pursue.

17 CHAIR BALLINTER: Well, Craig?

18 MEMBER HARRINGTON: It seems to be that
19 Option 4 going to be pursued in these workshops
20 because that's going to be the focus of the BWRs. So
21 it sounds like it's similar to what we talked about
22 last night with the prioritization of the best
23 estimate LOCA methods. There's another prioritization
24 of does the rulemaking comport with alternative 4 and
25 the needs of the BWR. So it may be the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 conclusion, I'm thinking, that we'll eventually get to
2 on the prioritizing the LOCA description. It's just
3 a question of, you know, prioritizing the workshops
4 and focusing them on these items that are identified
5 as important. So I think ALS really solves part of
6 the problem, which is the PWRs. And maybe that's a
7 separate deal. I think we can note that we encourage
8 the continued rapid evaluation of the ALS system with
9 the need to be thorough.

10 MEMBER PALMTAG: Based on regulatory
11 uncertainty though, I'm kind of concerned that we're
12 moving forward with these rules and, oh, by the way,
13 we're also doing ALS. That may be coming down the
14 pipeline. Oh, by the way, we also -- maybe having an
15 Option 4 down the pipeline. It seems like --

16 (Simultaneous speaking.)

17 CHAIR BALLINGER: But the EPRI folks have
18 submitted and submitted -- I want to -- I think four,
19 three plus another one that we haven't seen of
20 shouldn't have seen -- topical reports related to ALA.

21 MS. CLARK: This is Theresa Clark from
22 staff. So yeah, I think as I've mentioned yesterday
23 and possibly other times, these are the records are
24 going on in parallel with the rule making. ALS is one
25 that's under current review. We're talking about how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 we might be able to approach alternative 4. One of
2 the key things that we're thinking about is ensuring
3 that we have a rule that is inclusive and enabling.
4 I'm not sure I'm aware of any content in the current
5 rule that would prevent these other alternatives from
6 being pursued. I just recall that they are
7 alternatives for dispositioning FFRD. Option 2, which
8 is in the rule, not only does FFRD, but enables a
9 large variety of other source of operational changes
10 like were referred to earlier in this meeting. So it
11 was definitely ambitious to put it in there but could
12 be very beneficial, not to say we can't think about
13 these other things that might provide a more narrow
14 benefit.

15 MEMBER PALMTAG: Yeah. I'm sorry. I
16 understand that, you know, all these different options
17 do different things, but there seems to be a lot of
18 regulatory uncertainty when they don't really know
19 what's going to be fine lance or fine lancers coming
20 down the road.

21 CHAIR BALLINGER: Now I'm getting fuzzy
22 because I see 1 through 8, I don't necessarily agree
23 with the order or the number. But anyway, what we've
24 been discussing now is separate from that in some
25 ways.

1 MEMBER PETTI: Correct.

2 CHAIR BALLINGER: And so, we need to be --
3 kind of re-center ourselves a little bit and decide
4 how we going to proceed.

5 VICE CHAIR HALNON: I think 1 and 2 didn't
6 get -- I didn't see any dissatisfaction with those.
7 I think those would come off the list.

8 MEMBER PETTI: Correct. That's exactly
9 what I was as going to say. We got the clarifications
10 we needed, I think.

11 CHAIR BALLING: If I were to rank them,
12 I would rank TBS size -- in terms of order of
13 discussion, TBS size, FFRD, and then subsumed in that
14 would be the clad testing that whole set of reg guides
15 and stuff related to that. And then, you know, I'm
16 confused a little bit or ambivalent about how to deal
17 with the combination of 6 and 7 now, 1.183 control
18 room dose based on what we had discussed this morning
19 already. So I'm assuming that somebody that's a heck
20 of a lot more knowledgeable than me will take a stab
21 at that.

22 MEMBER PETTI: Yes. I'm going to do that.

23 CHAIR BALLINGER: So Dave's going --
24 you've already supplied me with a few things, but not
25 nearly what we've been talking about so far.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER MARTIN: I can help you with that,
2 too Dave.

3 MEMBER ROBERTS: Yeah, I'll help you Dave
4 on that also.

5 MEMBER PETTI: I'm going to -- you know,
6 I had a specific concern that we went through on the,
7 you know, FFRD, DBA, LOCA, but they clarified that so
8 I don't -- I'm not going to -- I don't think we can
9 talk about it. It's really just going to focus on the
10 control room dose.

11 CHAIR BALLINGER: Okay. So control room
12 dose and I've got Dave, Tom, and Steve. Okay. Well,
13 I've accomplished one thing so far.

14 MEMBER PETTI: Let me do this. On TBS
15 size, I really liked some of the words that Craig
16 had put together. I think we want a positive comment
17 on the strong technical basis of TBS. It's even
18 stronger than it was, you know, when -- because it was
19 only based on expert elicitation, right, and that
20 seismic stuff that they did. Now they've got
21 probabilistic fracture mechanics. So I think
22 something, you know, a comment on that would be
23 worthwhile. I'm not sure where we come down on the
24 inspection stuff. We spent a lot of time talking
25 about it. I think we all better understand it. Is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there still an issue?

2 CHAIR BALLINGER: I am pretty sure
3 there's an -- that's one of the issues that our
4 industry participants suggested was an issue. When I
5 heard from Dave Rudland compared to what I heard from
6 the industry side, there's a disconnect somewhere, I
7 think. A disagreement.

8 MEMBER HARRINGTON: Where we landed
9 yesterday I think was, you know, better understanding
10 by industry of the staff's intent and a need to, one,
11 go back and think about that and, two, spend some time
12 in workshops and table talks --

13 CHAIR BALLINGER: Yeah. And this is --

14 MEMBER HARRING: -- figuring through it.
15 And --

16 CHAIR BALLINGER: -- the workshop tabletop
17 discussion part. Yeah. I'm -- there's nothing on
18 here that relate to see putting the actual conditions
19 in today's plants in context. The 1.145 -- boy, I
20 keep forgetting these things -- the last one we got
21 talks about leak rate detection and those kinds of
22 things and ALS puts a lot of emphasis on
23 administrative controls and leak rate detection and
24 things like that. And so -- and I keep harping on the
25 fact that a lot of these welds have been mitigated in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 one way or another and there may be others that
2 aren't. But some discussion to put the concurrent
3 state of the plants in perspective with respect to the
4 rule -- with respect to what's going to be required.
5 Because I suspect that if you go through those tables
6 and move, there's the short circuits through some of
7 those tables exist because a lot of the welds that
8 we've been talking about, or that are in this class,
9 have very low probability of rupture. In fact, I
10 don't want to use -- you know, he corrects me when I
11 use the word zero, but it was his own words. His own
12 words. But that is the -- remember this rule is going
13 to be part of the public. So we ought to be sure that
14 we don't -- that we put things in the right
15 perspective in that regard. And I don't know what
16 other people think. I don't know where that fits in
17 here either.

18 MEMBER PETTI: Well, I mean, I think it
19 has to be under TBS.

20 CHAIR BALLINTER: Yeah.

21 MEMBER PETTI: And so I'm thinking one
22 bullet that talks about the strength of the technical
23 basis and another that just talks about the need -- in
24 inspection space the need to, you know, better
25 characterize the actual state of the industry because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the industry was confused, right. I mean, I think the
2 staff has a certain idea of what the words mean, and
3 the industry had a different idea. And so maybe it's
4 --

5 VICE CHAIR HALNON: So Dave, I was going
6 to say it sounded to me like there was -- the language
7 in the rule was somewhat developed on the fact that
8 there was some gaps in the knowledge of, like, what
9 you said the present status of the industry is by the
10 staff. There was a couple times we just don't know
11 what we don't know. And I think that that's where the
12 workshop will come in. If those we don't knows were
13 itemized or if the industry could come with that
14 information and sort of the rule language could
15 reflect that knowledge now. So it helps what Ron is
16 basically, what kind of mitigation has been done and
17 what's left out there.

18 CHAIR BALLINGER: I think it's wrong -- it
19 would be wrong for us to give the impression that the
20 ASME Code is somehow wrong. Section XI is somehow
21 inadequate, unless that's what we really think. I
22 don't think so.

23 MEMBER HARRINGTON: I can help put words
24 to part of the letter that we're talking. Maybe not
25 so much on the ALS, but on the rules side I can.

1 MEMBER PETTI: Yeah. And if the answer is
2 that we need -- you know, that they need to work this
3 in a workshop because there's this gap -- knowledge
4 gaps by -- and that's a fine recommendation to have
5 them work together. I don't have a problem with that.

6 CHAIR BALLINGER: Okay. So I've got my --
7 I've got Craig and myself and anybody else that would
8 volunteer or be voluntold. Okay. So let's go --

9 MEMBER PETTI: FFRD.

10 CHAIR BALLINGER: FFRD. I've got to take
11 the lead on that. Unless, again, we want to voluntold
12 somebody.

13 MEMBER PETTI: I think what I have -- I
14 have a couple of things. I have I still think no
15 burst of preferable at least in the near term until
16 more is learned about FFRD. So there is a concern
17 that the -- we're concerned that the analysis could be
18 become intractable, which leads to there really needs
19 to be more focus on the best estimate really means.

20 CHAIR BALLINGER: I think we're in
21 violent agreement on that. Yeah.

22 MEMBER PETTI: So I was thinking Tom was
23 the one who brought up the whole best estimate
24 discussion that he could work with --

25 CHAIR BALLINGER: Yeah. And I put him on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the list for -- he needs to supply at least 50 pages.

2 And it's got to have cliff-edge effect and
3 watchdog timer at least on he each page.

4 MEMBER PETTI: On the clad testing, you've
5 already get written stuff from me, I think.

6 CHAIR BALLINGER: To me, that's part of
7 FFRD.

8 MEMBER PETTI: Right.

9 CHAIR BALLINGER: That's part of -- yeah.

10 MEMBER PETTI: I see multiple bullets in
11 the -- you know, we're going to have a header TBS,
12 header FFRD. And we can talk about the clad testing
13 as a separate item.

14 CHAIR BALLINGER: Yes. Because we wrote
15 a letter on that. Well, we wrote a letter on the real
16 and we wrote a letter on the old 50.46c where we
17 actually outlined it -- with related to the issue and
18 required testing and the like, we came down on that
19 and I don't think we need -- unless we know we need to
20 change our mind, we probably shouldn't be inconsistent
21 with the letter on 46c that we wrote which is
22 somewhere in the ether. So myself -- we're talking
23 about an FFRD and clad testing, myself, Tom, I'll put
24 Dave down. Who else wants to volunteer?

25 DR. SCHULTZ: I'll be in there too, Ron.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Okay so, Steve. Okay.
2 Some of these folks that are out in the ether. Walt,
3 come on.

4 MEMBER PETTI: He's kind of busy on
5 NuScale.

6 CHAIR BALLINGER: Yeah, okay.

7 MEMBER KIRCHNER: I have my hands full on
8 some other things.

9 CHAIR BALLINGER: Okay. I just wanted to
10 give you a chance.

11 MEMBER KIRCHNER: Thank you. No. I
12 certainly will try and assist where I can.

13 CHAIR BALLINGER: I have another letter to
14 do also.

15 MEMBER KIRCHNER: Yes.

16 CHAIR BALLINGER: Yeah. 3.78 letter which
17 is going to be simple but nonetheless it's still a
18 letter. Let's see. We got FFRD. We got clad
19 testing. Okay. We got the control room doses.

20 MEMBER PETTI: Right. We got that all
21 done.

22 CHAIR BALLINGER: You know, we may have
23 it.

24 MEMBER PETTI: Well, the broader impacts.
25 Who's going to lead that?

1 CHAIR BALLINGER: Oh, yeah. Yeah. But
2 I'm assuming that that was -- I got that as a higher
3 level.

4 VICE CHAIR HALNON: Yeah. I don't think
5 that we can --

6 CHAIR BALLINGER: That's, like, everybody
7 right?

8 VICE CHAIR HALNON: -- get detailed in
9 there. We need to give a couple of examples and what
10 you said earlier. Just continue the thought process.

11 MEMBER PETTI: Sure. I'm just saying can
12 someone draft a paragraph to put in the letter to help
13 Ron.

14 MEMBER MARTIN: Tom and I could work on
15 that.

16 MEMBER PETTI: Yeah. That was exactly
17 where I was going to go.

18 MEMBER MARTIN: Yeah.

19 CHAIR BALLINGER: So now these -- the way
20 we've got it scoped out here, that kind of helps deal
21 with the discussion that needs to see take place on
22 each one. And what I'm hearing -- what we -- what I'd
23 like to hear people's comments on are other discussion
24 topics. For example, a lot of these conclusions and
25 recommendations stress the ongoing process that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 going to happen of the workshops and things like that.
2 Somewhere in the discussion there has to be -- we have
3 to put something in there that unifies all of this and
4 stresses the fact that any of this is draft rule, and
5 they've got the workshops and, I don't know, pilot,
6 whatever happens, are going to take place and they'll
7 have a significant impact on the final rule. And
8 that's something we need to endorse. Maybe that's a
9 conclusion also, I don't know.

10 DR. SCHULTZ: But I think it shows up in
11 three or four different topics.

12 CHAIR BALLINGER: Oh, it does. It shows
13 up everywhere.

14 DR. SCHULTZ: It can wrap up to a
15 conclusion.

16 MEMBER PETTI: Yeah. Instead of calling
17 it broader impacts, I'd call it broader impacts and
18 opportunities. That's where you could, you know,
19 endorse this idea of the workshops as being a way to
20 resolve a lot of these.

21 CHAIR BALLINGER: Yeah. You know, the
22 paragraph begins with, as we have discussed several
23 times before. Yes?

24 MR. MOORE: Chair, this is Scott Moore,
25 acting executive director of resource. If the

1 subcommittee on committee's going to get into how the
2 staff approaches this, make sure you have a link to
3 safety about how it will impact safety either
4 positively or, if they don't do it, negatively.

5 CHAIR BALLINGER: Okay. Yeah. I mean, I
6 guess it was by default that to assume that you were
7 going to do that. But okay. So make sure link to
8 safety. Okay. Okay. Now, Vesna, you've had comments
9 from time to time related to control room dose and TRA
10 discussion and the like. Is there something that you
11 think we need to deal with, or you can provide input
12 on?

13 MEMBER DIMITRIJEVIC: Well, I can review
14 what is written about this control room dose and make
15 sure that you're not -- that those things are
16 captured, you know. We will be writing this letter
17 together, right? We can contribute there. I mean, I
18 don't think I can take lead on anything here.

19 MEMBER PETTI: I'll draft something, and
20 I'll put the other people on.

21 CHAIR BALLINGER: Yeah it would be very,
22 very, very, very nice if we didn't end up with letter
23 writing from scratch on a topic during the February
24 meeting. So that would be not nice to me.

25 MEMBER BIER: Yeah I will -- this is

1 Vicki. I will volunteer also to at least kibitz on
2 the control room dose issue. I'm not sure I
3 understand it well enough to have an opinion yet
4 myself, but I'm happy to look at it and weigh in if,
5 you know, things are headed in a good direction or
6 whatever.

7 MEMBER DIMITRIJEVIC: Well, also, my
8 thinking was also in the, you know, when it comes to
9 the inservice inspections, and so I'm very familiar
10 with the Section XI. For my side, I will also kibitz,
11 as Vicki will say, on that and see where it goes.

12 MEMBER BIER: Please copy me on that part
13 of it.

14 CHAIR BALLINGER: Please keep in mind that
15 this is a draft rule. So if we do what amounts to
16 getting into the weeds, we're just not going to be as
17 productive as we could be I think.

18 DR. SCHULTZ: PRA also showed up in the
19 charts that were shown yesterday.

20 CHAIR BALLINGER: Right. That's what
21 tripped me active.

22 DR. SCHULTZ: Yeah. So might be something
23 to examine more thoroughly.

24 CHAIR BALLINGER: Okay. Other comments
25 from members? Scott, you've been strangely silent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER PALMTAG: My concern was the
2 control room dose. I think we're in consensus on
3 that.

4 CHAIR BALLINGER: Okay. So we're good
5 there?

6 MEMBER PALMTAG: Yeah.

7 MEMBER PETTI: Ron, I lost track of who
8 were the people on the control room dose. I didn't
9 write it down.

10 CHAIR BALLINGER: You, Tom, and Steve.

11 MEMBER PETTI: Good. Okay.

12 CHAIR BALLINGER: And I think they'll be
13 some kibitzing from other people as well.

14 MEMBER PETTI: Right. Okay. Got it.

15 CHAIR BALLINGER: That's otherwise known
16 as letter writing.

17 MEMBER PETTI: Look, this is exactly how
18 we did Part 53. Some of the people who are -- who
19 were not involved. When we get these really odd rules
20 we kind of do a little divide and conquer and I think
21 it just helps us get to a letter better and faster so.

22 CHAIR BALLINGER: Well, speaking of better
23 and faster, my schedule is -- I would like to -- my
24 significant other is out of town Monday and Tuesday
25 this coming week. So that's going to be the time when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I'm going to start trying to at least hang things
2 together. I've got something written on the
3 introductory part and way down is help there too. And
4 so there's a little bit going on there. And then I
5 plan on coming in the week of full committee on the
6 Monday. Our full committee doesn't start until
7 Tuesday, and I don't think -- I don't know what the
8 schedule is on this letter. NuScale on Tuesday.

9 MR. BURKHART: This is Larry Burkhart.
10 NuScale and subcommittee meetings on Tuesday. The
11 full committee is on Wednesday.

12 CHAIR BALLINGER: So are we taking this
13 up right off the bat?

14 MR. BURKHART: No. I got 3.78.

15 CHAIR BALLINGER: Okay. That's the other
16 one.

17 MR. BURKHART: 10:30 on Wednesday is this
18 topic. One thing I would still need to do today at
19 some point when you're ready is take public comment
20 and discuss what's desired for that full committee by
21 presentation by the staff industry, et cetera so.

22 CHAIR BALLINGER: And we kind of had to
23 have our sort of ducks in a row here and then --
24 before we have that discussion.

25 MEMBER PETTI: So Ron, just one more thing

1 to realize in terms of time, if you guys got on email
2 we have to change our computers those of us of that
3 the old black ones in February. And that's the only
4 time. So I'm going to have to step out of the NuScale
5 meeting to go -- hopefully it won't take long to get
6 rid of the old computer and to get the new one.

7 CHAIR BALLINGER: But this is all public.
8 So we don't have -- well, we don't necessarily need
9 our NRC computer. So if they're in the process of
10 getting changed out or something like that, it could
11 not be.

12 MR. BURKHART: It's just an hour out of a
13 meeting.

14 MEMBER PETTI: It's just an hour out of
15 our meeting, but each of us has to do that and so it's
16 going to -- it's something that we have to be aware of
17 for next week. Ron, what is your availability the
18 last week of the month, the week before full
19 committee?

20 CHAIR BALLINGER: Now I got to figure out
21 dates. Thought I had only win week to do this. Where
22 am I missing something?

23 MEMBER PETTI: There's two weeks.

24 CHAIR BALLINGER: Two weeks. I can be
25 available at any time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER PETTI: Okay. I am tied up. I'm
2 actually back in Washington for the National Academy
3 nuclear workshop that I got roped into. So I don't
4 have any availability.

5 CHAIR BALLINGER: I can be available at
6 any time. In fact, I can -- I haven't been to Idaho
7 in a long time. I don't want to go to Idaho in a long
8 time. But schedule is completely open, and I can
9 adjust to do whatever. Except I have only one
10 engagement on February the 23rd -- on the 23rd of
11 February, but that's after full committee. So I'm
12 good.

13 MEMBER PETTI: I'm Tuesday through Friday
14 the week before our full committee I'm in D.C.,
15 online, and airplane.

16 CHAIR BALLINGER: Well, if we're not well
17 along by the week before full committee, we're in
18 Dutch.

19 MEMBER PETTI: Right. Okay.

20 CHAIR BALLINGER: Okay. So now you've
21 announced that I have no life but --

22 MEMBER DIMITRIJEVIC: Ron?

23 CHAIR BALLINGER: Yeah.

24 MEMBER DIMITRIJEVIC: Maybe you can have
25 these list with the people who are doing it in charge.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 You know, so we have some comments we can send to
2 them.

3 CHAIR BALLINGER: Yeah. I think, if I were
4 to get comments or write-ups or whatever it happens to
5 be, what I would think about doing is having Teams
6 meetings with these groups when appropriate. I don't
7 know if we can. My next question to Larry was, can I
8 do that?

9 MR. BURKHART: Restate the question,
10 please? I'm sorry.

11 CHAIR BALLINGER: Well, we've got these
12 groups on these areas and we're working on write-ups
13 and stuff. Can we have virtual meetings amongst these
14 groups? Not everybody. But just these groups they
15 have discussions.

16 MR. BURKHART: So we should discuss that.
17 I mean, to be clear, what you're doing now and what
18 you're doing in these other meetings that you talk
19 about preparatory work, right?

20 CHAIR BALLINGER: Right.

21 MR. BURKHART: Deliberation -- true
22 deliberation will happen during full committee meeting
23 in February. So there should not be substantive of
24 exchanges of ideas without that being --

25 CHAIR BALLINGER: In other words, no.

1 MR. BURKHART: You can exchange drafts of
2 what you've written up that will be discussed at the
3 full committee meeting and deliberated on in full
4 committee meeting. You should not have sustained
5 discussion between yourselves outside of a publicly
6 announced meeting unless it's proprietary.

7 VICE CHAIR HALNON: We're stepping real
8 close to the line that we shouldn't be close to.

9 MR. BURKHART: Yes. Exactly.

10 VICE CHAIR HALNON: Those kinds of
11 meetings would need to be subcommittee meetings.

12 CHAIR BALLINGER: All right.

13 MEMBER PETTI: That's why I tend to think
14 that it should be the lead member that we've assigned
15 should take the best cut. And I think they're allowed
16 to email that the others.

17 CHAIR BALLINGER: Okay. So, Dave, you're
18 the lead on Number 1 which is the control room dose.
19 The rest the committee is Tom and Steve. The TBS size
20 I've got Craig listed as Number 1, so by definition
21 you must be the lead. And then I'll be the lead on
22 both FFRD and the clad testing with Tom, Dave, and
23 Steve. Okay. So now the lead can get obviously input
24 from others and then produce a draft document, if you
25 will, and then we can circulate that. We're not over-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 stepping our lane there, right?

2 MR. MOORE: So I think -- this is Scott
3 Moore. I think that it's reasonable for the lead to
4 interact with the other people that are assigned on
5 that topic to develop something. As soon as sections
6 start going out to everybody, they cannot tender
7 discussion.

8 CHAIR BALLINGER: Yeah. What you just
9 told me then we could do it by -- if the lead can have
10 interactions with the other members, why can't we do
11 that virtually?

12 MR. MOORE: The few other members.

13 CHAIR BALLINGER: Yeah. Yeah.

14 MR. MOORE: That's something that can go
15 on that you don't want to have discussions. Basically
16 you don't want to trip into deliberation.

17 MEMBER PETTI: I think if you just do it
18 by email you're safer.

19 CHAIR BALLINGER: Safer. All right.
20 Okay.

21 MEMBER PETTI: And who's leading the
22 broader impact?

23 CHAIR BALLINGER: There is nobody
24 assigned for that yet. I thought that was more or
25 less -- well, no, no. I think Craig.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER HARRINGTON: Yeah. I'm going to --
2 I'll take the first cut, and Tom will write a lot more
3 detail I'm sure. Because mine is going to be really
4 focused on control room and impacts to the operator.
5 You're going to probably be more of a design space.
6 So that's --

7 MEMBER PETTI: It's good. That'll be
8 good.

9 MEMBER HARRINGTON: I'll write the first
10 paragraph, and I am sure Tom's going to add another
11 one to it.

12 MEMBER ROBERTS: I plan to focus on the
13 role of the PRA in the severe accident and evaluating
14 the impact of things allowed by design changes.

15 MEMBER HARRINGTON: I think it's going to
16 be a few sentences with a couple examples.

17 MEMBER ROBERTS: I agree.

18 MEMBER PETTI: Exactly.

19 MEMBER PALMTAG: What about these other
20 options in ALS? Where would that go?

21 CHAIR BALLINGER: Well, I'm guessing that
22 these options somewhere get discussed -- well, ALS is
23 primarily FFRD related, so that's where it would be
24 here.

25 MEMBER HARRINGTON: I would be inclined

1 for us to focus the letter on the rule and then have
2 another paragraph or two that talks about the other
3 options and how they fit into --

4 CHAIR BALLINGER: That -- yeah.

5 MEMBER HARRINGTON: -- the overall
6 landscape.

7 CHAIR BALLINGER: Dave suggested that --
8 the oh, by the way paragraph, which is the one that
9 we're talking about, would be after the broader
10 impacts, you know, as part of that general thing. Did
11 I get that right, Dave?

12 MEMBER PETTI: Yeah.

13 CHAIR BALLINGER: So that's where that
14 would go.

15 MEMBER HARRINGTON: Otherwise, I think the
16 letter gets really convoluted in, you know, what it's
17 talking about.

18 CHAIR BALLINGER: Oh sure. Yeah. Yeah.
19 So let's see. Who wants to -- well, it looks like I'm
20 the only one that read that NEI letter.

21 MEMBER PETTI: I've read it.

22 CHAIR BALLINGER: You read it? Yeah. So
23 what about you and I, Dave, do that? I'm happy to do
24 it also because, you know, I spent last evening going
25 through things. And I think I understand -- you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I listened to the presentations yesterday and that
2 prompted me to go after that letter and read it
3 thoroughly. And I think I understand better what I
4 already thought about Option 5 from the earlier
5 readings of the rule. So I can put together.

6 DR. SCHULTZ: I can work with you, Ron.
7 I think -- I know I have some NuScale stuff. I don't
8 want to make Walt nervous, but I can work with you on
9 that.

10 CHAIR BALLINGER: Okay. So -- I just use
11 word ALS but it's broader than that.

12 DR. SCHULTZ: Sure. But that's going to
13 work right into the workshops as well and industry
14 interaction.

15 CHAIR BALLINGER: Oh, yeah. I'm guessing
16 that the first workshop will be a discussion of that
17 letter, topics of the letter the way they interact.

18 MEMBER PALMTAG: One thing with these
19 other options, I'm kind of -- one hand I'm a little
20 bit concerned that we seem to be ignoring the BWRs,
21 but on the other hand, I don't really hear anything
22 that they need anything either.

23 CHAIR BALLINGER: Yeah. We had some of
24 these side discussions yesterday. They're already on
25 a 24-month cycle.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER PALMTAG: Right. So I don't know
2 if we should at least mention BWR. There's not really
3 a path forward for BWRs here, but I don't know.

4 CHAIR BALLINGER: An Option 4 presumably
5 is the path forward for BWRs, right.

6 MEMBER PALMTAG: Is that -- I don't know.
7 I haven't heard anything about that so --

8 CHAIR BALLINGER: There was some
9 discussion -- now its fuzzy -- yesterday.

10 MEMBER PALMTAG: NEI was pushing for it

11 CHAIR BALLINGER: Yes. Yes.

12 MEMBER PALMTAG: But I haven't heard any
13 progress on it or anything. The NEI's original
14 proposal was for modifying 5 and then they didn't they
15 there was time for 2.

16 DR. SCHULTZ: It seems to still be
17 somewhat conceptual in space.

18 MEMBER PALMTAG: Yeah. That's my
19 understanding too.

20 CHAIR BALLINGER: Again, we know -- we
21 think we know what the industry is favoring, but it's
22 our letter.

23 MEMBER PALMTAG: Right. I'm just -- I
24 would like -- I think we need to mention that this is
25 very BWR specific. I just don't know if needs to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 for BWRs or not.

2 CHAIR BALLINGER: Okay. That would
3 probably be in the introduction related to background
4 or whatever.

5 MEMBER PALMTAG: I'll let you -- we have
6 a comment.

7 MR. RUDLAND: This is Dave Rudland from
8 the staff. I'm still -- I am sure why the committee
9 keeps saying there's no path to BWRs. I don't --

10 MEMBER PALMTAG: What is the path I guess?

11 MR. RUDLAND: Well, again at least for the
12 TBS there's a path. There just is not -- they don't
13 have an LBB analysis so they still -- they all have to
14 do some kind of analyses to demonstrate that and
15 that's one of the paths in the flow chart that we
16 showed. So there is not no path. It just may not be
17 a path that they want to take. But there still is a
18 path.

19 CHAIR BALLINGER: The BWRs are not likely
20 to call you to satisfy leaving for a break. They're
21 going to call the chemistry people and they're going
22 make an argument.

23 MR. RUDLAND: There going to call EPRI or
24 somebody like that. But I don't think saying that
25 there's no path is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 DR. SCHULTZ: I was going to say --

2 MR. RUDLAND: I thought I heard --

3 MEMBER PALMTAG: That might be a little
4 strong. There's not a --

5 MR. RUDLAND: There's not an easy button.

6 MEMBER PALMTAG: -- easy straight forward
7 path.

8 MR. RUDLAND: Yeah. There's not the same
9 easy button as the PWRs have, but there's still a path
10 for them. That was a TBS applicability.

11 MEMBER HARRINGTON: Make I can take up
12 that theme at least in a little bit in the TBS
13 discussion for the letter. So at least point out that
14 there are differences. It's not no path, but it may
15 be a more challenging path.

16 CHAIR BALLINGER: But we did have a
17 discussion with the one of the industry folks -- I
18 think it's an industry.

19 MS. CLARK: Baris is on the line from the
20 BWROG.

21 MR. LI: This is Guangjun Li from GEH.
22 The other paths, so right now based on the rule --
23 based on what we read actually only the dispersal is
24 allowed above the TBS. Below the TBS there are no
25 perforations (phonetic) allowed. This list alone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 probably have a big problem with BWR. BWR, the 50
2 percent is a small break limit. Even for the large
3 break limit itself you could have a perforation as a
4 break below TBS. TBS, therefore -- determining TBS is
5 very hard for BWR. You have to deal with all of the
6 leak before break, all of this stuff. I mean, yeah,
7 you could say you have a way but that way probably too
8 hard for the licensee to overcome. Fifty percent, I
9 mean, if you don't allow the perforation below the
10 TBS, yes, without that, we have big problems.

11 MEMBER PALMTAG: I guess my question is
12 more big picture, is there something we're missing
13 that the BWRs really need or want or are you just
14 observing this?

15 MR. LI: I don't know, there is an
16 assumption basically in the NRC document saying FFRD
17 actually large break is always limiting because
18 pressure is down fast, and you have (indiscernible due
19 to accent). But there's other things, I mean, the
20 combination you have the chromium (phonetic)
21 temperature stuff. So actually (indiscernible due to
22 accent) could be, we found preliminary, yeah we have
23 those perforation. So that's something I think we
24 have this modified Option 4. So basically from the
25 consequences point of view, you consider the dose that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 is basically eventually you're clear for the
2 (indiscernible due to accent).

3 MEMBER PALMTAG: So what I'm hearing is
4 the BWRs want this Option 4?

5 MR. LI: Yes. Thank you.

6 MS. GERKEN: This is Lisa Gerken from
7 Framatome with both BWR and PWRs. So this -- I think
8 it comes back to how perhaps the Draft Guide is
9 written. Some of the conversation we had earlier
10 about just saying that the way to address fuel
11 dispersal is by saying no cladding rupture. If you
12 eliminate that then it opens up a lot more space to
13 say, if cladding rupture is your only way then
14 whatever plant you are, for whatever break size you
15 have, you have some path forward to be able to justify
16 what the effects of dispersal are, why dispersal is
17 not an issue. But I think it's coming back to the way
18 that 1434 is written right now, where it's only saying
19 that you can do something the besides cladding rupture
20 or above the design base if you're above the TBS. So
21 basically you can only have fuel dispersal for beyond
22 that basis. To come back to alternative 4,
23 alternative 4 doesn't specify DBA versus BDBA, it's
24 just saying there is a consequence, and plants must
25 deal with it in some manner. So I think removing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 limitation to cladding rupture is hugely helpful for
2 our BWR fleet and as well as Theresa had said earlier,
3 their flexibility in multiple strategies whether it be
4 alternative 4 if it's codified, whether it be ALS,
5 whether it be XY or Z. Strategy flexibility, I think,
6 is the key thing that we need from the NRC right now
7 for fuel dispersal or for whatever comes down two
8 years from now. There will be something else, and we
9 need to be acceptable to different strategies for how
10 plants operate.

11 MR. MESSINA: Joe Messina. Just wanted to
12 clarify. The guide is guidance. One way to meet the
13 regulation. And also, I'm not sure maybe I misspoke
14 or misimplied, but for breaks below the transition
15 break size, dispersal could happen if it could analyze
16 it under the high probability assumptions or find
17 another way to address it. It's just the guide only
18 really addresses dispersal above the transition break
19 size. And below the transition break size says the
20 main way is to show no burst of the rod is susceptible
21 to that part.

22 CHAIR BALLINGER: Thank you. You said
23 that two or three times yesterday so --

24 MR. MESSINA: Just -- clear.

25 MR. CSONTOS: So this is Al Csontos. I

1 don't want to reiterate. Baris Sarikaya is on and
2 he's the PWR, VIP -- I'm sorry, PWR owners group
3 representative to the group that we have here. And so
4 he can respond. I think the other thing I just want
5 to add in is the implementability, if that's a word,
6 you know, going forward, is that PWRs like they said
7 have an easier path. But it's not just an easy
8 button, it's like what can we get done understanding
9 the risk of LOCA. And so what is a risk-informed
10 approach to get to an appropriate answer on the
11 assurance and safety for BWR and you know, have
12 hopefully a similar timeframe as these, knowing that
13 leak before break will get through between now and
14 then. So and that's why we were saying Option 4 may
15 be another option for us to pursue. So I'll let
16 Baris, can you -- I saw your hand up.

17 MR. SARIKAYA: Yeah. Thanks, Al. And,
18 again, in the interest of not repeating everything
19 that's been done -- said, I do agree that BWRs -- the
20 path for BWRs currently is not as clear as the PWRs.
21 And that causes us concern for our submittals because
22 we do not know what type of additional challenges we
23 will see in that paths that we don't know how we get
24 there or the more difficult path. The other thing
25 that I want to mention is that we keep talking about

1 TBS below and above and Guangjun mentioned that. That
2 our half the BWR fleet is small or intermediate break
3 level. So just focusing on about TBS for one solution
4 that is not -- that does not sound technology-neutral.
5 And then the last thing I want to add is that we had
6 a really great discussion early in the morning about
7 the unintended consequences. One thing that I'd like
8 to bring the members' attention is that we need to
9 also think about what is the unintended consequence of
10 adding excess conservatism to regulation? Does that
11 have -- does that make us to do -- go change things in
12 the plant operation? Does that increase the dose to
13 the average workers? Are we trading the imaginary
14 dose with the real dose? I think when we have the
15 discussion about the unintended consequences, we're
16 going to need to think about the real life affect as
17 well. Thank you.

18 CHAIR BALLINGER: Okay.

19 MR. TREGONING: Maybe one more? This is
20 Rob.

21 VICE CHAIR HALNON: Yeah, one more, Rob.

22 MR. TREGONING: I just want to comment on
23 the BWR path through this. LBB is one way, but there
24 are other ways. There's an Option 3 analysis where
25 they just have to look at critical areas. So it would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 be a very simplified analysis. And we've never
2 granted an LBB for BWR. And while that's not part of
3 the rule, there may be other benefits that the BWR
4 community could glean from LBB. And so that's
5 something that could be outside the framework of this
6 rule, but it might be something that's worth pursuing.
7 So two things. There is an alternative path for BWRs
8 that does not require, that's an LBB evaluation.
9 However, if they do decide to do an LBB evaluation,
10 there may be other operational benefits that they may
11 gain from that evaluation. So that's all I want to
12 say.

13 CHAIR BALLINGER: Thank you. Okay. I
14 think we're pretty much exhausting our discussion. So
15 if that's the case, then I think we need to go out for
16 public comments. And --

17 MEMBER KIRCHNER: Ron, pardon me. We
18 don't need to go out for public comment. We did that
19 yesterday. These are committee deliberations, and we
20 don't take public comment on committee deliberations.

21 CHAIR BALLINGER: Okay. I was just
22 looking over at the control desk and people were
23 saying yes so. Okay. We don't need to do it, we
24 don't need to do it.

25 MR. MOORE: This is Scott Moore. I do

1 believe that it's in the agenda.

2 CHAIR BALLINGER: Well, that may be true.

3 MR. KIRCHNER: If there is a second
4 opportunity for public comment, then go ahead and do
5 it. But typically we don't do it on committee
6 deliberations.

7 CHAIR BALLINGER: Okay. There is a public
8 comment opportunity. It's later in the day today, but
9 I think we're not going to make it that far.

10 VICE CHAIR HALNON: Well, in charity this
11 is not a deliberation. That happens during full
12 committee meeting, and this is subcommittee
13 discussion, which I think may be different. I don't
14 know if there's a nuance there.

15 MR. KIRCHNER: Yeah. I misspoke. Yeah.
16 It's the subcommittee making a recommendation to the
17 full committee. But we typically don't take comments
18 on our recommendations. We have allowed adequate
19 input by even entertaining input today from the non-
20 members that are present. But go ahead. If you -- if
21 that checks the box, go ahead and take comments from
22 the public.

23 MEMBER HARRINGTON: Ron, before we do that
24 there's one other person to follow up on what Scott
25 was poking at earlier. In big view of our space, is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there -- right now, in PWR space there's somewhat
2 compelling timeline that that plants are working to to
3 try to move forward on increased enrichment issues.
4 Is there something similar to that in BWR space?

5 MR. LI: Yes. It's Guangjun Li from GEH.
6 Yes, there is several plants like we've had like
7 (indiscernible due to accent) and also Constellation
8 has an interest on this.

9 MEMBER HARRINGTON: And it's (audio
10 interference) or --

11 MR. LI: Well, we just want to extend the
12 (indiscernible due to accent).

13 MEMBER HARRINGTON: Okay.

14 MEMBER ROBERTS: So it's a burnup
15 increase?

16 MR. LI: Yes.

17 MEMBER ROBERTS: Thank you.

18 DR. SCHULTZ: We had some discussions at
19 various times about best estimate LOCA and what was
20 the definition of that for the work that's being done
21 associated with this, if any. Is that still a topic
22 that reaches? I mean, we never came to any conclusion
23 there. Just --

24 PARTICIPANT: Just caught up in either
25 FFRD or TBA.

1 CHAIR BALLINGER: Yeah. That's what I was
2 saying.

3 MEMBER PETTI: It is FFRD.

4 PARTICIPANT: Good.

5 CHAIR BALLINGER: Okay. Again, I think we
6 should go out for public comments. If there are
7 members of the public that would like to make a
8 comment, please state your name and your organization
9 if you choose and make your comment. I don't see
10 anybody but that's -- who knows.

11 MEMBER MARTIN: Do what you did yesterday
12 and just invite anybody without raising their hand.

13 CHAIR BALLINGER: Well, we had one person
14 that didn't raise his hand and then got us at the end.
15 But I think we're fine. So okay. No. We have --
16 hearing no public comments, unless there are
17 additional things that we need to discuss.

18 MR. BURKHART: So you need to talk about
19 what is the --

20 (Simultaneous speaking.)

21 CHAIR BALLINGER: Oh, yeah. Yeah. Yeah.
22 Okay. So now that we have this grouping that we have,
23 and we had discussions of each one of these things,
24 pretty extensive, where would we like to see the staff
25 being -- making a discussion? I mean, I'm going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 guess that control room dose and 1.183 is 1. The TBS
2 size we need to have some presentations related to
3 that, and FFRD the clad testing. Those are the areas
4 that we've identified. I don't think, you know,
5 broader impacts or ALS or anything like that needs to
6 be there. Unless I don't know what the rules are on
7 public participation by request to make presentations.

8 VICE CHAIR HALNON: I have a suggestion
9 and that is to, since this is subcommittee and full
10 committee theoretically has different -- you know, for
11 a broader audience even though we're all here, we can
12 take -- and this kind of speaks to the how does it all
13 fit together. Take each major section -- some of
14 these are on here, like, FFRD, control room dose, and
15 just do one- or two-bullet summary of what that is and
16 what it does and just walk through four or five slides
17 of the huge in a very broad overview of the rule.
18 That will spark discussions based on what we're
19 writing in the smaller groups. And that, again, will
20 help the full aspect of how it all fits together in
21 the bigger picture.

22 CHAIR BALLINGER: Just stick to the main
23 points.

24 VICE CHAIR HALNON: Yeah. Just --

25 CHAIR BALLINGER: How much time is there

1 on the agenda?

2 VICE CHAIR HALNON: Control room dose,
3 here's two bullets. FFRD, three bullets. You know,
4 just something very high level. If nothing else -- if
5 you're not going to be able to queue up every little
6 technical issue that has been discussed, but if you
7 can queue up the topic and any of the members who have
8 been thinking about it, writing words down,
9 considering transcripts and other things we've done,
10 if it's still burning in them, they'll don't bring it
11 up. They'll bring up a topic under it. And we can
12 talk about that specific topic as opposed to a very
13 broad discussion.

14 CHAIR BALLINGER: And you've heard all of
15 the discussions, so you pretty much know.

16 VICE CHAIR HALNON: Does that seem
17 reasonable? Does it resonate that you can do that in
18 maybe, you know, 45 minutes to an hour?

19 CHAIR BALLINGER: Is that what we have?

20 MR. BURKHART: Yeah. So on February full
21 committee agenda on March 5th, we have 10:30 to 1:00.
22 Essentially we have an hour and a half, 2 hours for
23 presentation.

24 CHAIR BALLINGER: We have until 5:00.

25 MR. BURKHART: We have the complete rest

1 of the day for committee deliberations on the subject.
2 So it's a lot of time in the full committee meeting,
3 so yes. So I think you're getting to what you want
4 from the staff. The question is in my mind, do you
5 want anything from the industry? There had been --
6 with that in mind, there had been a lot of
7 subcommittee meetings that are documenting all this
8 stuff. So I think that is a reason why you may not
9 need as much from the staff and the industry in the
10 full committee. That's up to the committee.

11 VICE CHAIR HALNON: If we're going to have
12 an industry folk, I'd have Al come up speaking for the
13 wider industry and here's, again, take their two or
14 three letters that they sent and just give me two --
15 one bullet on each of the main points and where we
16 want to see and what we want for, you know, not
17 platitude, but what we need to see more and more for.
18 If we're still in disagreement here, a workshop will
19 help. That will help us correlate where when we say
20 we're encouraging the workshops moving forward,
21 that'll help us correlate where those need to be. And
22 the prep work into those workshops is highly important
23 so that workshop is useful to the industry. Because
24 there's a lot of investment into these workshops.
25 It's not just a bunch of people getting together.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 There's typically just tremendous amount of work and
2 cost for these workshops. So we want to make sure
3 that we encourage them that we're not just asking to
4 check a box at the end of the workshop. So, Al, does
5 that seem reasonable that you could just come in for
6 maybe 15 or 20 minutes and just give us, not detailed
7 discussions, but here are the high points and where
8 the industry's head's at?

9 MR. CSONTOS: Sure. This is Al Csontos,
10 NEI. Yes, we can do that. We can probably give you
11 a prioritized list of the issues in terms of priority
12 to the industry. So probably through a workshop.

13 VICE CHAIR HALNON: That would be useful,
14 I think. Maybe 15 minutes?

15 MR. CSONTOS: Sure.

16 VICE CHAIR HALNON: Okay.

17 MR. BURKHART: Sure. And just so it's --
18 this is Larry Burkhart, you may provide written
19 comments the committee also. Please send that to me
20 and wait online. We will make sure they get recorded
21 as appropriate.

22 VICE CHAIR HALNON: So did she you say
23 there are 2 hours for presentations?

24 MR. BURKHART: Essentially, yes.

25 VICE CHAIR HALNON: Okay. So an hour and

1 15 minutes for industry. That will give us 45 minutes
2 of questions, which seems reasonable to me. Bob, did
3 you have something or Dennis?

4 MEMBER KIRCHNER: I was going to say,
5 yeah, that the staff does a high level overview of the
6 rule. And as Craig said, you know, the focus really
7 should be the rule. And our letters should focus
8 accordingly. I mean that's what the commission as our
9 audience and customer is going to be looking for.

10 VICE CHAIR HALNON: Seem reasonable, Ron?

11 CHAIR BALLINGER: Hmm?

12 VICE CHAIR HALNON: That seem reasonable?

13 CHAIR BALLINGER: Yeah.

14 VICE CHAIR HALNON: Okay. Dennis has his
15 hand up.

16 CHAIR BALLINGER: Dennis?

17 DR. BLEY: Yeah. Ron, hadn't come after
18 me. I have a couple -- a suggestion. There's only two
19 areas where I think I could really help. The one
20 you've not get pretty well covered which was in
21 control room dose. But the thing that kind of has
22 been nagging at me and I haven't thought it through
23 yet, I was thinking of polyester, they're talking
24 about forward fitting. If we apply this sliding scale
25 in the way it's suggested, I wonder where that leads

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 us in the future, if the staff and the commission have
2 thought about that. As far as the meeting -- full
3 committee meeting, staff floated this true best
4 estimate wording and if they want to, that might be a
5 good thing for them to expand on and be a little more
6 specific, if they can. That's the other area I
7 thought I could help with, if you would like. And
8 this has nothing to do with the letter, I don't think.
9 And I don't know what to do about it. But I was
10 really struck on what the last month by Elijah's
11 really great history and if somehow the committee
12 could urge the staff to get that embedded in some
13 permanent form. I just, that would be great. That's
14 all.

15 MEMBER KIRCHNER: Dennis, that's a good
16 point. That could perhaps be part of the knowledge
17 management series.

18 CHAIR BALLINGER: Okay. Other last
19 parting shots?

20 MEMBER KIRCHNER: Ron, I have one. For
21 the people working on control room dose, I really
22 commend you to -- first as Dennis pointed out, a
23 larger summary of his excellent from our December
24 presentation. It would help, I think, for to you read
25 -- this is going to sound boring -- but 50.34 as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 contents of applications and Title 1034, and the
2 footnotes there are important because they explain
3 what an MHA is. And then there are some interesting
4 footnote on the 25 rem question, as background. And
5 then go look at GDC-19. And the interesting thing I
6 would point out is that GDC-19 uses loss of coolant
7 accidents. And so there is an opportunity -- I'll go
8 back. I think Elijah pointed out that in the December
9 presentation there is -- they're suggesting a rewrite
10 for the GDC. But I just recommend that people working
11 on this read that first to see the context in the
12 background in the disconnect that's there between an
13 MHA and the LOCA, and the possibility that out there
14 to redefine that control room dose. End of comment.

15 CHAIR BALLINGER: Thanks. Not to give
16 Elijah a big head, but that rule preamble that
17 discussion of dose and the like is like a textbook.
18 It's great.

19 MR. DICKSON: Thank you.

20 CHAIR BALLINGER: Okay. I didn't see any
21 swelling.

22 MEMBER ROBERTS: Just to add to that,
23 Walt, the other piece of that puzzle that Elijah has
24 also done a great job putting together is probably
25 worth clarifying and memorializing somewhere is the

1 reason why the containment leakage assumption is
2 apparently inconsistent with the casualty progression.
3 The act the progression would have contained leakage
4 in general, but there is history dating back to 1968.
5 And then Elijah's found some references of pre-loss
6 claim, you know, how they got decoupled and then the
7 -- and the reason why the containment assumed to be
8 intact even though the accident scenario wouldn't
9 necessarily support that assumption. So it's
10 important to understand how it all fits together
11 because it is explains the role of why these
12 requirements at least made sense at the time and what
13 their current applications, you know, still means.

14 CHAIR BALLINGER: Okay. Again, if I keep
15 silent somebody else will -- we can rapidly
16 approaching faculty member -- faculty meeting issues.
17 Apart from Elijah, again, I said it yesterday, we need
18 to complement the staff in general on -- it's almost
19 intractable problem that they have to deal with in an
20 intractable amount of time. And so that's what we're
21 doing. So and like Theresa, would you like to make
22 any comments before we shut this down?

23 MS. CLARK: You just appreciate the
24 conversation. We look forward to continuing that.

25 VICE CHAIR HALNON: Yeah. And let's not

1 forget the commitment by the industry folks to be here
2 in person, but also obviously engage in a level of
3 detail that is necessary.

4 PARTICIPANT: Very helpful.

5 CHAIR BALLINGER: By the way, it's not
6 just this meeting. We've had several subcommittee
7 presentations by industry related analysts, and
8 Larry's alluded to the multiple subcommittees that
9 we've had. I don't know what the count is, but it's
10 large. Okay. That being said, unless and one more
11 last chance for comments from members. Hearing none
12 we're adjourned.

13 (Whereupon, the above-entitled matter went
14 off the record at 10:37 a.m.)
15
16
17
18
19
20
21
22
23
24
25

Proposed Rule: Increased Enrichment of Conventional and Accident Tolerant Fuel Designs for Light-Water Reactors

January 16-17, 2025

Opening Remarks

Theresa Clark
Director
Division of Safety Systems

Draft Regulatory Guide DG-1428

(Proposed Regulatory Guide RG 1.258, Rev. 0)

Plant-Specific Applicability of the Transition Break Size

Presented by:

David Rudland (NRR/DNRL),
Robert Tregoning (RES/DE), and
Se-Kwon Jung (NRR/DEX)

ACRS Regulatory Rulemaking, Policies and Practices Subcommittee
January 16, 2025

Background

- Technical Basis for Transition Break Size (TBS)
 - **NUREG-1829**: Used 10^{-5} /yr conservative LOCA frequency results as starting point
 - Selected based on operating experience, piping geometries, and to promote regulatory stability
 - **NUREG-1903**: Verified that risk associated with seismic-induced breaks > TBS is acceptable
- NUREG-1829
 - Generic evaluation intended to provide best estimate LOCA frequencies accounting for uncertainty and variability
 - Only broad differences among reactor types and vendors considered
- NUREG-1903
 - **Direct piping failure**: Subset of PWRs analyzed using available information
 - **Indirect piping failure**: Scoping study of main loop piping support failure which partially updated mid-1980s estimates for two PWRs
 - Both direct and indirect failures likely have a mean failure probability on the order of 10^{-6} /yr or less, but both analyses are strongly plant specific

Initial Motivation for Regulatory Guidance

- Plant-specific attributes can strongly influence LOCA frequencies so important to ensure TBS is applicable at each plant
- Commission Direction in SRM-SECY-07-0082 (ML072220595)
 - “The final rule should require licensees to justify that the generic results in the revised NUREG-1829, ‘Estimating Loss-of-Coolant Accident Frequencies Through the Elicitation Process,’ are applicable to their individual plants.”
 - “The staff should develop regulatory guidance that will provide a method for establishing this justification.”
- Staff has interpreted that this guidance extends to NUREG-1903
- Staff developed DG-1216, “Plant-Specific Applicability of Transition Break Size Specified in 10 CFR 50.46a” (ML100430356)

DG-1216 Scope and History

- Scope
 - Only applies to primary loop piping (PLP) systems and reactor coolant pressure boundary (RCPB) components whose failure could result in breaks greater than the TBS
 - Initial NUREG-1829 Applicability
 - Initial NUREG-1903 Applicability for direct piping failures
 - Effect of plant changes on NUREG-1829 and 1903 Applicability
- History
 - Initial public meeting discussing DG white paper (ML090350757) – February 20, 2009
 - Issued for public comment (75 FR 36698) - June 28, 2010
 - ACRS Subcommittee meeting on Regulatory Policies and Practices – September 22, 2010
 - Public meeting – September 30, 2010
 - ACRS Main Committee meeting – October 7, 2010
 - End of public comment period – November 25, 2010
 - Scheduled Commission Briefing – March 24, 2011
 - DG-1216 withdrawn (81 FR 88615) – December 8, 2016

DG-1216 ACRS Feedback

- ACRS Letter on draft final 10 CFR 50.46a rule (October 20, 2010): ML102850279
 - Provides acceptable methods and acceptance criteria for evaluating NUREG-1829 applicability
 - Provides an evaluation framework and acceptance criteria to demonstrate the NUREG-1903 applicability for direct piping failures
 - Should include assessment of NUREG-1903 applicability for indirect piping failures
 - Should explore methods to reduce required effort
- Staff adopted ACRS recommendation to add guidance pertaining to indirect piping failures
 - Modified the FRN in draft final rule to require this demonstration
 - Presented initial ideas for DG-1216 modifications - September 30, 2010 public meeting
 - Planned to evaluate acceptability of planned guidance as part of pilot study

DG-1216 Public Feedback

- NEI Comments (ML103160267)
 - Guidance too complex and proposed simple checklist
 - Concerned about expanding DG-1216 to account for seismically induced indirect piping failures
 - Place more reliance on existing programs (e.g., 50.59) to reduce plant change analysis
 - Leverage existing TBS margin to provide confidence that it applies to all plants
 - Conduct a pilot study of the process prior to issuance
- PWROG Comments (ML103140567)
 - 20 specific comments; several echoed the NEI comments
 - Current inspections and examinations provide adequate protection against a large LOCA
 - Recognized reduced complexity for plants completing license renewal but concerned about burden for other plants
 - Plants in low seismic zones can be eliminated from demonstrating NUREG-1903 applicability
 - Unclear requirements or acceptance criteria associated with several regulatory positions

DG-1216: Planned Next Steps

- Wait until Commission vote on SECY-10-0161 (draft final rule) before proceeding further
- Planned activities
 - Add method to address indirect seismic analysis
 - Conduct pilot plant study
 - Evaluate guidance
 - Estimate implementation costs
 - Develop evaluation template
 - Establish change process for determining impact of future plant modifications
 - Address public comments
 - Modify guidance
 - Present draft final guidance to ACRS
- However, as stated earlier, in 2012, the Commission approved the staff's request to discontinue rulemaking (SRM-SECY-10-0161) and DG-1216 was withdrawn in 2016

Increased Enrichment Rulemaking

- In 2021, staff requested to pursue rulemaking and develop a regulatory basis to amend requirements for the use of light water reactor fuel containing uranium enriched to greater than 5.0 weight percent uranium-235
- Commission approved via SRM-SECY-21-0109, but stated Fuel Fragmentation, Relocation, and Dispersal (FFRD) should be appropriately addressed
- Staff's regulatory basis included five options for FFRD, and based on industry feedback the staff chose Alternative 2 began development of a proposed rule to implement this alternative, 10 CFR 50.46a
- This effort was described in detail at the December 2024 ACRS subcommittee meeting
- To support this proposed rule, the staff developed DG-1428, "Plant-Specific Applicability of the Transition Break Size" (ML24341A159, ACRS version)

Related Proposed Rule Requirements¹ Supported by DG-1428

- Application: 50.46a(c)
 - Existing plants: demonstrate applicability of TBS
 - New plants
 - Demonstrate similarity of plant design to existing plants
 - Recommend and justify plant-specific TBS
 - Both existing and new plants
 - Demonstrate that TBS remains applicable after initially proposed plant changes
 - Demonstrate acceptable leak detection program [Section (d)]
 - **Optional:** Describe process for demonstrating TBS applicability for changes without prior NRC approval
- Programmatic: 50.46a(d)
 - Identify, monitor, and quantify primary pressure boundary leakage
 - Perform evaluation to demonstrate that the TBS remains applicable after planned facility changes
- Changes to facility: 50.46a(h)
 - Proposed changes enacted with or without prior NRC approval demonstrate continued applicability of TBS
- Reporting (every 24 months): 50.46a(j)
 - Document basis for determining that changes enacted without prior NRC approval do not invalidate the TBS

¹ 1/16/25 – 1/17/25 – Predecisional Information to Support – ACRS Public Meeting – Draft Federal Register Notice to Support Increased Enrichment of Conventional and Accident Tolerant Fuel Designs for Light-Water Reactors (ML25013A080)

Purpose of DG-1428

- Proposed 10 CFR 50.46a requires an evaluation to demonstrate plant-specific applicability of the TBS
- This draft guide provides one acceptable way to meet that regulation
- If applicability can not be demonstrated, the entity needs to determine a plant-specific TBS. This draft guide may also aid in the development of that TBS.

DG-1428 Overview

- Used DG-1216 as the starting point for development
- Leverages required inspections and license renewal lessons-learned to streamline and simplify guidance
- Considers DG-1216 comments
- Provides guidance to address indirect seismic failures
 - Address recommendation in 2010 ACRS letter on draft final 10 CFR 50.46a rule
 - Consistent with rulemaking requirements and leverages DG-1426² guidance
 - Separate evaluation for NUREG-1903 applicability not necessary
- Provides several options to demonstrate TBS applicability for maximum flexibility
 - Plan to work with stakeholders to identify most viable options and further refine before finalizing
 - Propose to pilot the guidance before finalizing

² DG-1426, “An Approach For A Risk Informed Evaluation Process Supporting Alternative Acceptance Criteria For Emergency Core Cooling Systems For Light Water Reactors,” - ACRS Version Rev 1 (ML25010A417)

DG-1428 Overview

NUREG-1829
applicability

Aging
Management

Adequate
Leak
Detection

Plant-Specific
Attributes

NUREG-1903
applicability

Limiting
Locations
Selection

Material
Properties

Applicability
Though ISI
Program

Surface Flaw
Analysis

Component
Stresses


Seismic Risk
of Indirect
Failures

Plant changes and
LOCA frequencies

Direct
Failures

Indirect
Failures

NUREG-1829 Applicability – General Approach



NUREG-1829 Applicability

Aging Management

- Option I:** Credit license renewal (LR) or subsequent license renewal (SLR) approval
- Option II:** If first LR submitted, adopt relevant aging management programs
- Option III:** Demonstrate that Part 54 requirements met for applicable PLP and RCPB components

Adequate Leak Detection

- Option I:** Demonstrate adherence to RG 1.45, “Guidance on Monitoring and Responding to Reactor Coolant System Leakage”
- Option II:** Demonstrate compliance with GDC 30 and 10 CFR 50.46a(d)(2) criteria

Plant-Specific Attributes

1. Ensure PLP attributes are acceptable
2. Conduct RCPB component evaluation (new plants only)
3. Develop acceptable risk-informed PLP inspection sample

Plant-Specific Attribute Analysis

PLP Attribute Evaluation

Option I: Credit existing or conduct new LBB evaluations

Option II: Conduct PFM evaluation

Option III: Identify unique attributes*

*materials; fabrication practices; loading sources, frequencies, and magnitudes; geometries and system configurations; material and component degradation; aging management

RCPB Component Evaluation (new plants only)

- Identify unique plant-specific attributes
- Assess impacts of differences on TBS applicability


Risk-Informed Inspection Sample

- 10% of similar metal piping circumferential welds (PWR) or IGSCC Category A welds (BWR) with diameters greater than the TBS. Ongoing inspection programs may be leveraged.
- Highest failure potential: combination of lowest toughness and susceptible materials and highest applied and residual stress loads

NUREG-1903 Applicability

- General Approach
- Limiting Locations Selection
- Applicability Demonstration Through ISI Program
- Component Stresses
- Material Properties
- Surface Flaw Analysis
- Seismically Induced Risk of Indirect PLP or RCPB Component Failures

NUREG-1903 Applicability: General Approach



Limiting Locations Selection

- All piping locations with inner diameter greater than TBS
- Represented by the combination of high component stresses and low material fracture toughness, accounting for aging effects over the licensing period
- Susceptibility to service-induced cracking should be considered
- Multiple limiting locations may be needed
- Strive to include all limiting locations in ISI program

Applicability Demonstration Through ISI Program

- For the limiting locations that are part of the plants ISI program, NUREG-1903 applicability is demonstrated through successful application of that program
- No additional analyses are needed if
 - No indications larger than the Section XI, IWB-3500, acceptance criteria are identified
 - No preexisting or new indications are present that are larger than IWB-3500 acceptance criteria

Applicability Demonstration Through ISI Program

- Additional analyses are needed if any identified indication exceeds IWB-3500
 - Follow IWB-3600 but include mean 10^{-6} /yr seismic stress using a structural factor of 1 or
 - Use an alternative approach to conduct a probabilistic analysis
- If limiting locations are not part of an ISI program, then analyses must be used to demonstrate applicability

Component Stresses

Option I: Use NUREG-1903 Results

- Critical piping location in LBB submittal are still applicable
- Normal and SSE stresses from LBB analyses still conservative
- 10^{-6} /yr seismic stresses still applicable

Option II: NUREG-1903 Scale-Factor Method

- Determine seismic hazard information
- Determine service level A & D stresses
- Calculate scale factor per NUREG-1903 to extrapolate SSE stresses to 10^{-6} /yr stresses

Option III: Direct Analysis

- Develop a hazard curve for the site
- Model the site-specific foundation properties for the 10^{-6} /yr seismic hazard.
- Construct a reactor building dynamic model
- Perform a soil, structure interaction analysis
- Address modeling and input uncertainties

Material Properties

- Use the properties in NUREG-1903 if conservative or representative of limiting locations materials
- Develop plant specific properties based on ASME code or experiments
- Appropriateness of properties can be demonstrated by
 - Accounting for any age-related degradation of the strength, toughness, and, if applicable, crack growth rate properties
 - Considering effects on these material properties caused by the elevated loading rates associated with a seismic event
 - Assessing the effects of uncertainty and variability in material properties

Surface Flaw Analysis

- Two options for conducting deterministic analysis


Option I: Bounding Analysis

- Directly utilizes NUREG-1903 results
- Two conditions required for use
 - NUREG-1903 material properties are bounding or representative
 - Component normal operating plus 10^{-6} /yr seismic stresses < 35 ksi
- If conditions met, then NUREG-1903 applicability is demonstrated

Option II: Plant-Specific Analysis

- Utilize plant-specific component stresses and material properties
 - Plasticity effects can be credited to reduce applied stresses above yield
- Calculate critical flaw depth for long surface flaw (i.e., 80% of circumference)
 - Corrected limit load analysis (i.e., Z-factor approach) or elastic plastic fracture mechanics can be used
- Demonstrate that critical flaw is appropriately deep (i.e., > 25% of wall thickness)


Option III: Plant-Specific Probabilistic Analysis



Seismically Induced Risk of Indirect Component Failures

- An acceptable analysis would include:
 - most up-to-date seismic hazard information
 - plant-specific component and support fragilities
 - impacts of age-related degradation
- Plant-specific seismic PRA that complies with RG 1.200 is acceptable
- Methods other than seismic PRAs may be acceptable
 - seismic margin assessment
- Risk-informed evaluation described in DG-1426 is applicable and provides additional guidance and acceptance criteria

Impact of Plant Changes: General Approach



Plant Changes and LOCA Frequencies

- Entities must demonstrate that proposed plant changes do not significantly increase LOCA frequencies such that TBS remains applicable
 - Both direct and indirect failures should be considered
 - Failures under normal loads, design basis and rare seismic loading (as in NUREG-1903) should be considered
 - Age related degradation should be considered
 - A risk-informed evaluation should be conducted to demonstrate plant changes do not significantly increase LOCA frequencies.
 - More guidance in DG-1426

Plant Changes and Direct Failure Frequencies

- Continued applicability to both NUREG-1829 and NUREG-1903 to be demonstrated

Option I: Effects on NUREG-1829 Variables

- Identify if change affects materials, environment, loading, degradation, geometry, maintenance or mitigation
- Identify if change may introduce new degradation
- Assess and describe performance monitoring program

Option II: Review Standard for Extended Power Uprates

- Use guidance for EPU
- Focus on RPV surveillance, PT limits, USE, PTS, LBB, piping materials and supports, chemical control, etc.
- Assess and describe performance monitoring

Plant Changes and Direct Failure Frequencies

- Evaluate effects on NUREG-1903 analyses
 - Verify changes do not impact the inspections at limiting locations
 - Determine if change increases degradation rates
 - Determine if surface flaw analyses remain applicable
 - Determine if the change increases stress at limiting location
 - Determine if the change may decrease strength or toughness, or increase crack growth rate of materials
 - Determine if surface flaw analyses still meet acceptance criterion

Plant Changes and Indirect Failure Frequencies

- Ensure that GDC-4 is met and that risk of indirect seismic failures remains acceptable
- Continued adherence to GDC-4
 - Dynamic effects (e.g., pipe whip and jet impingement) and missile protection
 - **Option I:** Prior analyses unaffected by plant changes or existing analyses remain sufficient (no additional evaluation needed)
 - **Option II**
 - Supplement existing evaluations to evaluate relevance and significance of proposed changes to demonstrate that they do not invalidate the TBS
 - Utilize existing guidance in NUREG-0800 (SRP) 3.6.2 (Dynamic Effects) and 3.5.1.1/3.5.1.2 (Missile protection)
- Indirect seismic failure risk
 - Demonstrate that associated risk due to plant change meets proposed rule change requirements
 - Utilize DG-1426 guidance for assessing risks

Appendices

- Appendix A: Detailed Information for Conducting Plant-Specific Analyses Using the NUREG-1903 Approach
 - Contains information pertaining to the direct piping failure analysis in NUREG-1903
 - Table A-1 lists the PWR plants evaluated in NUREG-1903
 - Table A-2 provides the information obtained from NUREG-1488³ to develop the seismic component stresses
 - Table A-3
 - Provides information submitted as part of LBB evaluations used in analysis
 - Provides intermediate and final analysis results
- Appendix B: Example Calculation for Hot Leg
 - **Critical location:** Girth weld of an SA312-TP304N seamless pipe to reactor pressure vessel nozzle
 - Provides step-by-step calculation of the deterministic, plant-specific surface flaw analysis using the NUREG-1903 scale factor approach (i.e., Option II on Slide 23)

³ NUREG 1488, “Revised Livermore Seismic Hazard Estimates for Sixty-Nine Nuclear Power Plant Sites East of the Rocky Mountains,” (ML20069B899)

DG-1428 Summary

- Evaluation required to demonstrate that breaks greater than TBS remain unlikely
 - **Direct failures:** primary coolant systems and components that could lead to breaks greater than TBS
 - **Indirect failures:** failures of other components that could lead to breaks greater than TBS
- DG-1428 provides guidance for conducting these evaluations
 - Uses DG-1216 as the starting point while streamlining and simplifying that guidance
 - Increases scope of DG-1216 to provide guidance on addressing indirect seismic failures
 - Comments received on DG-1216 considered during development
 - Leverages DG-1426 and other applicable long-standing guidance (e.g., SRP 3.6.3)
- DG-1428 provides several options for demonstrating TBS applicability
- Plan to work with stakeholders, ideally through a pilot study, to identify most viable options and further refine guidance before finalizing

Acronyms

ASME	American Society of Mechanical Engineers	PLP	Primary Loop Piping
BWR	Boiling Water Reactor	PRA	Probabilistic Risk Assessment
DG	Draft Guide	PWR	Pressurized Water Reactor
EPU	Extended Power Uprate	PWROG	PWR Owners Group
FFRD	Fuel, Fragmentation, Relocation and Dispersal	RCPB	Reactor Coolant Pressure Boundary
FRN	Federal Register Notice	SLR	Subsequent License Renewal
ISI	Inservice Inspection	SRP	Standard Review Plan
LBB	Leak before Break	TBS	Transition Break Size
LOCA	Loss of Coolant Accident		
LR	License Renewal		
NEI	Nuclear Energy Institute		
PFM	Probabilistic Fracture Mechanics		

Questions

Back-up Slides

10 CFR 50.46a: Related Application Requirements

- (c)(1)(i) requires existing plants to submit “(a) written evaluation demonstrating applicability of the TBS to the entity’s facility. The effects of the initial plant changes proposed in the application must be considered as part of this evaluation.”
- (c)(2) requires new-plant applicants to submit “... an analysis demonstrating why the proposed reactor design is similar to the designs of reactors licensed under this part before December 31, 2015, such that the provisions of this section may properly apply. The analysis must also include a recommendation for an appropriate TBS and a justification that the recommended TBS is consistent with the technical basis for this section. The effects of the initial plant changes proposed in the application must be considered as part of this evaluation.”
- (c)(1)(v)(C) requires, for making changes without prior NRC approval, “(a) description of the approach, methods, and decision-making process to be used to evaluate the continued applicability of the TBS with the acceptance criteria used in the evaluation...” from paragraphs (c)(1)(i) or (c)(2), as applicable
- (c)(1)(vii) requires “(a) written evaluation demonstrating how the leak detection program in place at the facility satisfies the criteria in paragraph (d)(2) of this section.”
- (c)(3) “The NRC may approve an application to use this section if...” above evaluations, change process program, or both are acceptable, as applicable.

10 CFR 50.46a: Related Implementation Requirements

- (d)(2) requires that “(t)he entity must have leak detection systems available at the facility and must implement actions during operation as necessary to identify, monitor, and quantify leakage to ensure that adverse safety consequences do not result from leaking primary pressure boundary components that are larger than the TBS”.
- (d)(4) requires that “(t)he entity must perform an evaluation to determine the effect of all planned facility changes and must not implement any facility change that would significantly increase LOCA frequencies or invalidate the evaluation demonstrating the applicability of the TBS performed pursuant to...” paragraphs (c)(1)(i) or (c)(2), as applicable.
- (h)(1)(iii) for changes without prior NRC approval requires that “(t)he change does not significantly increase LOCA frequencies or invalidate the evaluation demonstrating the applicability of the TBS to the applicant’s facility, performed pursuant to...” paragraphs (c)(1)(i) or (c)(2), as applicable.
- (h)(2)(v) for changes submit for NRC approval requires “... (i)information demonstrating that the proposed change will not significantly increase the LOCA frequencies or invalidate the evaluation demonstrating the applicability of the TBS to the entity’s facility, performed pursuant to...” paragraphs (c)(1)(i) or (c)(2), as applicable.
- (j)(3) Minimal changes: reporting. “No later than 24 months after NRC approval of the entity’s application and every 24 months thereafter, the entity must submit ... a short description of each change involving minimal changes in risk made under paragraph (h)(1) of this section in the preceding 24 months and a brief summary of the basis for the entity’s determination pursuant to paragraph (h)(1)(iii) of this section that the change does not invalidate the applicability evaluation made under paragraphs (c)(1)(i) or (c)(2), as applicable.

Sample Problem (Appendix B)

- Example Plant SSE: 0.2g PGA, with Mean Annual Frequency of Exceedance (MAFE) of $5.35\text{E-}5/\text{yr}$
- PGA corresponding to the $1\text{E-}6/\text{yr}$ MAFE: $0.876\text{g} \rightarrow (\text{SSE PGA})/(1\text{E-}6 \text{ PGA}) = 0.876\text{g}/0.2\text{g} = 4.38$
- Highest SSE stress location: Hot Leg (ID = 29", Thickness = 2.45"), TP304N wrought austenitic stainless steel joined by SMAW/SAW \rightarrow SSE stress = 12.96 ksi
- Normal plus $1\text{E-}6$ seismic stress adjusted for seismic scale factor and nonlinear correction, using typical material properties = 26.35 ksi < 35 ksi
- Elastic-Plastic Fracture Mechanics (EPFM)-corrected stress = 43.19 ksi
- Minimum critical surface flaw depth from limit load equations = 0.335 > 0.25 \rightarrow OK for TBS

Fuel Dispersal and 50.46a – Changes Since December Meeting

Follow-Up ACRS Subcommittee Meeting
January 2025

Joseph Messina
Nuclear Methods and Fuel Analysis
Office of Nuclear Reactor Regulation



Changes

- Removed 50.46a(c)(3)(v) requirement that any non-safety related equipment credited in the LOCA analysis above the TBS be listed in a plant's Technical Specification.
 - (c)(3)(v): "Non-safety equipment that is credited for demonstrating compliance with the ECCS acceptance criteria in paragraph (e) of this section is identified in the plant's Technical Specifications or appropriate conditions require that any future license applicant lists this equipment in the plant's Technical Specifications;"
 - Licensees should consider on a plant-specific basis whether any non-safety related equipment credited for LOCAs above the TBS should be placed in TS under Criterion 4 of 50.36(c)(2)(ii).
- LOCA definition in 50.46 and 50.46a restored to "breaks *in pipes* in the reactor coolant pressure boundary" rather than "breaks in the reactor coolant pressure boundary."



Discussion

Discussion

- 1) Criticality
- 2) Fissile Packaging
- 3) TBS sizes
- 4) FFRD
- 5) Clad testing
- 6) RG 1.183
- 7) Control Room dose
- 8) Broader impacts

IE Rulemaking: Industry Feedback

Al Csontos - NEI

Victoria Anderson - NEI

Jim Stavely - PSEG

Tara Matheny - Duke

Jonathan Chavers - Southern

Baris Sarikaya - Constellation/BWROG

Brian Mount - Dominion/PWROG

Kevin Barber - Westinghouse

Paul Clifford - Framatome



January 16, 2025

©2025 Nuclear Energy Institute



IE Rulemaking Key Messages

- LARs for uprates and/or advanced fuels are on the way
- IE rule and schedule are vital to industry strategic plans
- Draft IE Rule from the recent ACRS meetings has many appropriate improvements, but major concerns remain
- Industry feedback remains consistent with March '23 letter:
 - Combined/modernized rule with modified 50.46a/c (ML23107A230)
- ACRS should allow the draft IE rule for Commission review
- Workshops needed for industry engagement on concerns

ADVANCE Act alignment for modern, risk-informed, and efficient regulations

IE Rulemaking Key Messages

- Generally, beneficial impacts with the overall rule package:
 - Enables improved safety benefits associated with less generated waste
 - Allows increase enrichments to LEU+
 - Allows existing UF_6 packages to ship with up to 10 wt% U-235
 - Improved risk-informed control room dose design criteria
 - RG 1.183 revisions permit some units to move forward with strategic plans
 - ◆ More realistic modeling of potential release paths
 - ◆ NRC workshops yielded a more predictable, durable, and stable RG
 - Openness to LBLOCA as BDBA has potential for significant improvements
 - NUREG-2266 for up to 10 wt% U-235 and 80 GWd/MTU burnup
- Specific areas remain deterministic, prescriptive, and not risk-informed with additional burdens and high uncertainty to implementation

Enabling Advanced Fuel Technologies




- ATF/LEU+/HBU fuels are complementary to uprates and enabling in some cases
- Modern advanced fuel technologies can:
 - Increase potential for power uprates
 - Enable 24-month fuel cycles for PWRs
 - Less waste = improved safety/fuel efficiency
 - Improve plant resiliency and performance
 - Improve economics for fleet sustainment
- On track to meet industry's goal to deploy batch quantities in the mid-to-late 20s:
 - Applications for 24-month cycles submitted
 - Efficient NRC licensing for advanced fuels and uprates by 2027 with the IE rule needed

2024 NEI Future of Nuclear Power Survey



- Key takeaways:
 - **>70% of sites** have a level of interest/planning for one or more power uprates with a combined capacity **increase of 3 GWe**
 - **Nearly 50%** of sites have varying interest/plans for one or more of the enabling changes (ATF/ LEU+, Extended Fuel Cycles, and/or RI LOCA)
- <https://www.nei.org/resources/reports-briefs/the-future-of-nuclear-power-2024-survey>



Utility Perspectives on Implementation

- PSEG
- Duke
- Southern
- Constellation

LOCA Risk Significance

IMPACT OF LOCA ON OVERALL PLANT RISK

LOCAs not Significant Contributors to Overall Plant Risk

- Review of Industry Baseline Risk Index for Initiating Events (BRIIE) – NUREG/CR-6932 for Initiating Events leading to core damage (1988-2005):
 - VSLOCAs have CDFs on the order of $1\text{E-}10$ (BWRs) and $1\text{E-}09$ (PWRs) yr^{-1}
 - Small sample of plants confirm. MLOCAs slightly higher but on the order of $\text{E-}7$ to $\text{E-}8$ (PWR, BWRs) yr^{-1} for CDF
 - LERF values $\sim 2\text{-}3$ orders of magnitude smaller than CDF $\text{E-}9$ to $\text{E-}11$ yr^{-1} for LERF
 - Compared to mean CDFs of $1\text{E-}05$ and $1\text{E-}06$ yr^{-1}
 - OE Extended to 2020 in INL/EXT-21-63577
 - Plant risk and safety performance have continued to improve (utilities focusing on maintenance and improvements that positively impact risk, safety, and operability)
- Figures on right show plant risk reduced by a factor of 20 ([NEI-20-04-The-Nexus-Between-Safety and Operational Performance](#))





Figure A1 – Unit Capability Factor

Early Industry Draft IE Rule Feedback

AREAS FOR IMPROVEMENT

Implementation

- 2010 Draft 50.46a rule required substantial implementation burden as compared to the potential benefits utilities would obtain (see ML100260383 & ML10316027)
- Risk Informed Evaluation Process (RIEP): New rule does not appear to implement efficiencies and learnings associated with risk informed change programs that most of the fleet has implemented since 2010.
 - More stringent criteria for what requires NRC approval compared to what most of the fleet is approved to use today
 - Draft rule still stipulates the performance of low power shutdown (LPSD) risk assessments/PRAs (NEI 2023 Att. 1, Item 1) even though the industry addressed this after 2010
 - 50.46a (h) RIEP duplicates requirements for implementing risk informed change programs communicated in RG-1.200 and RG-1.174

Implementation

- Existing NRC-approved robust aging management program (submitted as a part of plant license renewals) protects against degradation of primary loop piping (PLP)
 - DG-1428 acknowledges the industry addressed seismic risk per NRC 10CFR50.54 order after Fukushima-Daiichi event but still requires plant specific seismic analyses. (NEI 2023 Att.1, Item 2)
 - DG-1428 imposes additional in-service inspection (ISI) requirements per 50.46 a(b)(3) even though the frequency of rupture is decreasing resulting from maturity increases in PFM

These increased inspections would result in unnecessary additional occupational dose to plant personnel and is not risk-informed.

- DG-1428 extension of credit for plants with approved LBB programs is minimal (NEI 2023 Att.1, Item 4)

Implementation

- Additional Implementation Considerations
 - New analyses for 50.46 compliance > TBS
 - New dose analyses for LOCA with FFRD
 - DG-1428 requires the performance of plant specific pipe and component stress evaluations in addition to increased inspection frequencies
 - Draft rule requires new Technical Specifications for non-safety equipment credited in > TBS ECCS compliance analysis (which is beyond design basis) and is inconsistent with Industry's treatment of FLEX equipment
 - Ongoing Activities
 - NRC supporting work to evaluate continued use of TID source term for EQ; The outcome of this could have significant impacts on implementation

Flexible and Durable

- Industry has concerns that draft 50.46a rule is too rigid and prescriptive
 - Draft rule does not allow alternative approaches
 - Codifying a prescriptive TBS definition may lead to future rulemaking and/or exemption requests
- NRC has communicated desire to allow alternative paths
- With minimal changes in rule language, a more flexible and durable rule capable of supporting advancements in risk-informed applications is achievable

Flexible and Durable

- Rule should be structured to allow alternative approaches to defining and implementing TBS
 - Regulation should allow a TBS demarcation which separates beyond design basis based on risk-insights
 - Current TBS definition (50.46a(a)(9)) and SOC bases should be moved to regulatory guidance (i.e., DG-1428)
 - Analytical requirements in 50.46a(e) need to be flexible enough to allow alternative approaches and where possible moved to regulatory guidance
- These changes enable near-term alternative approaches without the need for exemption requests
- EPRI ALS, true risk-informed metrics (Δ CDF), break frequency, etc.

Flexible and Incorporation of Alternative #4

- NRC staff's FFRD Alternative #4 would focus compliance with respect to dispersed fuel on more restrictive radiological consequence limits
 - Downstream consequences of dispersed fuel, including coolability, are removed from the design basis of ECCS performance
 - Plants must demonstrate compliance to “well within” 10 CFR 50.67 dose limits (i.e., 6.3 rem TEDE)
 - Must consider additional source term associated with dispersed fuel
 - Applies to all break sizes and reactor types
- DG-1425 includes guidance for demonstrating compliance with Alternative #4
- Draft § 50.46 rule does not include an alternative path to enable implementation of Alternative #4
 - Discrepancy needs to be resolved

Modernization

A modernized and risk-informed rule would efficiently enable the deployment of advanced fuel designs, including ATF, higher enrichment and higher burnup

- Industry Advancements
 - Since 2005, fleet has implemented approved risk-informed licensing applications and change processes
 - Lower probability of initiating event identified during reconfirmation of NUREG-1829/NUREG-1903, but Draft RGs require increased inspections

Implementation and inspections should capitalize on currently available information

Modernization

- Industry Standards

- Effect on risk due to changes at sites are assessed based on RG-1.174
- >TBS beyond design basis, but reporting requirements increased compared to current design basis LOCA
- Breakaway oxidation testing requirement does not recognize fuel vendor quality assurance, manufacturing control, and design change procedures

Requirements should account for current industry standards, not increase inspection & reporting requirements for beyond design basis events

- Cladding Embrittlement

- DG-1263, Rev. 1 does not account for NRC-approved cladding alloys that considered known embrittlement mechanisms

Licensed alloys that considered known embrittlement mechanisms should not require additional licensing actions

Regulatory Stability and Predictability

- Without justification, draft § 50.46 and § 50.46a extend the long-standing definition of LOCA beyond breaks in piping (original bases* shown below)

“The wording of the definition of a loss-of-coolant accident has been modified to conform to its long-accepted usage, limiting it to breaks in pipes.”

- Extending the definition of LOCA beyond its historical scope has significant consequences to both the existing fleet and future advanced LWRs
 - This change would invalidate the design basis of current fleet
 - The change to the existing § 50.46 definition is not included in the backfitting determination and would render the rule mandatory
- Definition should be restored to its “long-accepted usage” for 40 years

* Original bases in 39 FR 1002, January 4, 1974

Regulatory Stability and Predictability

- Because its a voluntary alternative, NRC's Backfit assessment states that licensees "would not be required to comply with the proposed amendments and would have the option to continue their current treatment of LOCAs"
- Industry agrees with NRC's earlier assessments that LOCA fuel dispersal at current BU limits and § 50.46c research findings are not safety significant
- NRC MD 8.4 states that if a "backfit has not been imposed for cases where a forward fit is being considered, it is unlikely that a change could be justified to be necessary to ensure adequate protection of public health and safety"
- Based on the above, industry expects that future LARs and vendor topical reports which comply with § 50.46 will not to be subjected to new requirements (i.e., continue current treatment of LOCAs)
- Forward-fitting via vendor topicals should not be allowed

Regulatory Stability and Predictability

- Relaxing assumptions generally provides analytical benefits, but interpretation of BDB LOCA requirements can greatly impact fuel dispersal conclusion

“... NRC expects that with true best-estimate modeling and realistic assumptions, the quantity of fuel calculated to be dispersed would be eliminated or greatly reduced.” (Draft FRN)

- BDBA analyses are used to fully understand the capability of the plant design, rather than establishing tech specs and operational limits based on fuel performance
- BDBA conclusions should not be obscured by artificial biasing
 - Analyses should consider as-expected conditions
 - Conservatism may be included as a matter of convenience, but is not required
- Characteristics of “true best-estimate” for BDB LOCA
 - Nominal operating values shall be applied (e.g., operational target, midpoint of a range)
 - Break considerations should reflect physical plant geometry (e.g., relative frequencies)
 - Mitigating systems are available and functional (e.g., non-safety, no single failure, offsite power, etc.)
 - Code models should be best-estimate and applied without bias

Summary

- IE rule with 50.46a/c would enable more realistic operational margins for advanced fuels and additional power uprates as incentivized in the IRA
- Alignment of the combined draft rule to Commission direction and intent of the ADVANCE Act for a modern, risk-informed, and efficient regulatory process
- Industry feedback remains consistent with recent NEI letters:
 - Combined/modernized rule with modified 50.46a/c – Mar '23 (ML23107A230)
 - IE Rulemaking Regulatory Basis industry comments – Jan '24 (ML24023A604)
- Development of a clear, efficient, and durable rule with draft regulatory guides needs full consideration of the holistic implementation pathway for licensees
- NRC workshops would enable an open and transparent dialogue on the Industry's implementation, efficiency, predictability, and durability concerns



Backup

“True Best Estimate”

- Assumed operating conditions at time of break reflect most likely state of the plant
 - Nominal values or midpoint of ranges without uncertainty
 - Nominal peaking factors and axial power condition
- Nominal or as-coded models without conservative uncertainties or biases
 - Realistic accident conditions consider all relevant systems
 - Breaks and distribution of sizes can account for physical plant geometry and expected frequencies of occurrence
 - No single failure or loss-of-offsite power
 - Non-safety systems can be credited

Conditions assumed for beyond design-basis accident analysis should not be tied to technical specification limitations

Optimized Risk-Informed Approach

- True risk-informed approach consistent with approved risk-informed programs already existing in plant's license bases
- TBS should be defined based on plant-specific risk profile (e.g. 10^{-7} CDF)
 - Above TBS, PRA models must continuously demonstrate that plant-specific risk remains below TBS threshold
 - ◆ Full LOCA break spectrum included in internal events scenarios
 - ◆ More detailed analytical demonstration not needed for insignificant risk
 - At or below TBS, traditional LOCA EMs used for compliance demonstration
- Future changes in plant configuration, operating conditions, and technical specifications assessed to confirm TBS and overall plant risk

Benefits of Optimized Risk-Informed Approach

- Modified Alternative 4
- Universally applicable to BWR and PWR fleet
- Building upon proven risk-informed regulatory process
- Demonstrated no fuel dispersal
 - Avoids complex, downstream consequence analyses
- Removes reporting requirements

Considerations/Clarifications for Modernized 50.46a Rule

Consideration/Clarification	Justification
LOCAs > transition break size (TBS) would be treated as beyond design basis with realistic assumptions. NRC approved thermal-hydraulics method may not be needed for large breaks.	<ul style="list-style-type: none"> > TBS = Beyond Design Basis is consistent with intent of 50.46a (SECY-10-0161) Considerations based on information in Reactor Accident Analysis Modernization Report: Item 2.4 (ML24220A292) <ul style="list-style-type: none"> Use of Chapter 19 methods could be acceptable (Section 2.4.1)? Demonstrate compliance with RG-1.200 acceptance criteria (including DiD), and NRC review and approval may not be required?
LOCAs < TBS (design basis) could take credit for RI single failure, some non-safety SSCs, and use alternate criteria to demonstrate high probability?	<ul style="list-style-type: none"> LOCAs are not significant contributors to plant risk and ECCS performance is not credited to satisfy dose acceptance criteria? Based on industry interpretation of RAAM Items 2,2, 2.3, 2.6
Selection of TBS could be based on risk criteria (CDF, LERF)?	<ul style="list-style-type: none"> Draft 50.46a rule used initiation event frequency which is not a true risk metric (omits consequences)?
Separate approval of some changes under 50.46a may not be required?	<ul style="list-style-type: none"> Utilities that have received approval for other RI programs would receive credit for QA of RI change programs? Evaluation of changes under RG-1.174 for RI programs and 50.59 are well vetted and established.
Site specific seismic risk demonstrations under NUREG-1903 would not be required?	<ul style="list-style-type: none"> Utilities have addressed plant specific seismic risk as a part of Post-Fukushima Task Force requirements/recommendations
Implementation of a modernized 50.46a would be voluntary?	<ul style="list-style-type: none"> Consistent with 2010 draft 50.46a rule

Implementation Burden

- 2010 Draft 50.46a rule required substantial implementation burden as compared to the potential benefits utilities would obtain (see ML100260383 & ML10316027)
- **Risk Informed Evaluation Process:** New rule does not appear to implement efficiencies and learnings associated with risk informed change programs that the majority of the fleet has implemented since 2010
 - Specifies use of Region III Δ CDF ($1.0 \text{ E-}07$) and Δ LERF ($1\text{E-}08$) criteria in RG-1.174 to determine if a change is acceptable
 - Requires any change processed under 50.46a to be approved by NRC if the change falls outside of Region III
 - Whereas other approved risk informed programs use a Region II criteria
 - ACRS in response to Issue 3 (ML070460275) recommended Region II criteria [Δ CDF ($1.0 \text{ E-}06$) and Δ LERF ($1\text{E-}07$)] for changes and that any changes that increase risk > Region II criteria should require staff review

Implementation Burden

- Justification for applicability of the transition break size (TBS) contained in DG-1428 requires more **reactor coolant piping weld** inspections (NUREG-1829) and plant specific seismic evaluations (NUREG-1903)
 - DG-1428 (Section B.2) acknowledges the industry addressed seismic risk per NRC 10CFR50.54 order after Fukushima-Daiichi event.
 - DG-1428 (B.1.3) imposes additional in-service inspection (ISI) requirements per 50.46 a(b)(3) even though presentations to ACRS on 12/17/24 demonstrate that the frequency of rupture is decreasing resulting from maturity increases in PFM. **These increased inspections would result in unnecessary additional dose to plant personnel.**

LOCA Category	Effective Break Size (inch)	Plant-Level LOCA Frequency (1/Year) – Statistical Mean Values			
		BWR - Piping		PWR - Piping	
		NUREG-1829	2024 Update	NUREG-1829	2024 Update
4	≥ 7	5.9E-06	2.4E-08	7.6E-07	6.0E-08
5	≥ 18	1.0E-06	4.3E-09	1.3E-07	2.6E-08
6	≥ 41	--	--	1.2E-08	4.0E-10

Implementation Burden

- Implementation of the draft rule would also require new analyses:
 - DG-1425 requires a new dose analysis “LOCA with FFRD” with an acceptance criteria 25% of MHA LOCA even though DG-1425 acknowledges MHA LOCA bounds LOCA with FFRD.
 - LOCA with FFRD is valid under Alternative 4
 - 50.46a rule requires a new “true best-estimate” LOCA analysis for breaks > TBS, still requires deterministic LOCA analysis **that must be maintained by the Licensee, in addition to the current LOCA analyses for breaks \leq TBS**
 - Draft rule still requires compliance to 50.46 design basis acceptance criteria for both analyses even though it is recognized > TBS is beyond design basis
 - DG-1428 requires the performance of plant specific pipe and component stress evaluations along with ISI inspection information that needs to be approved by the NRC to use a TBS
 - DG-1428 requires the performance of a plant specific seismic evaluation for pipe and components that could fail and impact pipe pressure boundary performance, while acknowledging plants have already addressed seismic risk
 - New TS (Never could find in what document the new TS is required)

Modernization

- The draft rule does not reflect the significant advancements in licensing actions, including risk-informed applications, since the draft § 50.46a rule was first developed in 2005
- Applicability of § 50.46 and DG-1263 should be expanded to include all approved cladding alloys
 - Demonstration of acceptable performance already justified
- Since 2005, fleet has implemented approved risk-informed licensing applications and change processes
 - Duplicative RIEP codified in draft § 50.46a unnecessary
 - Unjustified differences from approved risk-informed applications

Modernization



- Draft § 50.46 and § 50.46a maintain legacy reporting requirements
 - In 1974, computational limitations and uncertainties necessitated reporting to provide “book-keeping” and NRC confidence
 - Unrelated to plant safety
- Given the anticipated large margins to acceptance criteria, “At or Below TBS” reporting should only be required when predictions approach criteria.
- No reporting requirements should be required for “Above TBS” BDBAs
 - Best-estimate, realistic calculations are not deterministically bounding, therefore “book-keeping” is unnecessary
- Licensees required to take corrective actions to ensure compliance
 - This legacy reporting requirement should be removed

Summary of EPRI's Alternative Licensing Strategy to Address LOCA induced FFRD



Fred Smith
Sr. Technical Executive

ACRS Meeting of the Fuels Materials, & Structures Subcommittee
January 16, 2025

Alternative Licensing Strategy Purpose

Purpose:

Provide technical justification to exclude consideration of fuel fragmentation, relocation, and dispersal (FFRD) from the core cooling evaluation for a loss of coolant accident (LOCA) in a pressurized water reactor (PWR) to allow increasing the fuel burnup limit.

Problem Statement

FFRD involves multiple phenomena potentially induced in high burnup (HBU) fuel by large-break (LB) LOCAs. The usual approach of validating methodology against empirical data does not support desired schedule.

Proposed Approach

Based on precedents and on existing regulations and guidance define a methodology that shows that:

- 1) Burst of clad of high burnup fuel is not credible for LB-LOCAs
- 2) Smaller LOCAs do not cause clad burst

ALS Overview

- Submitted for Review April 26, 2024

- [1] *Loss-of-Coolant-Accident-Induced Fuel Fragmentation, Relocation, and Dispersal with Leak-Before-Break Credit – Alternative Licensing Strategy*. EPRI, Palo Alto, CA: 2024. 3002028673.
- [2] *Materials Reliability Program: xLPR Estimation of PWR Loss-of-Coolant Accident Frequencies (MRP-480)*. EPRI, Palo Alto, CA: 2024. 3002023895.
- [3] *LOCA Analysis of Fuel Fragmentation, Relocation, and Dispersal for Westinghouse 2-Loop, 3-Loop and 4-Loop Plants – Proprietary, Evaluation of Cladding Rupture in High Burnup Fuel Rods Susceptible to Fine Fragmentation*. EPRI, Palo Alto, CA: 2024. 3002028674.
- [4] *LOCA Analysis of Fuel Fragmentation, Relocation and Dispersal for Westinghouse 2-Loop, 3-Loop and 4-Loop Plants – Non-Proprietary, Evaluation of Cladding Rupture in High Burnup Fuel Rods Susceptible to Fine Fragmentation*. EPRI, Palo Alto, CA: 2024. 3002028675.
- [5] EPRI letter #FRP 2024-013, "Request for Exemption of NRC Review Fees for Electric Power Research Institute (EPRI) - Analysis of PWR LOCA Induced Fuel Fragmentation Relocation and Dispersal (FFRD) for Fuel Operating to Extended Burnup: Alternative Licensing Strategy," dated April 26, 2024.

- Accepted for review June 25, 2024

- Fee Waiver approved August 1, 2024

Review Schedule

EPRI Report	Fracture Mechanics	SB/IB LOCA	Integrated Report with credit for LBB
Audit Dates	March / April 2025	November 2024 / March 2025	May / June 2025
RAI Schedule	May 23, 2025	July 18, 2025	July 21, 2025
Draft Safety Evaluation	December 4, 2025	February 6, 2026	February 17, 2026
Product ID	3002023895	3002028674 3002028675	3002028673

Allowing 6 months for final approval of all Safety Evaluations – Topical Approval Expected August 2026

Increased Enrichment Rulemaking Schedule:

Rule to Commission September 30, 2026

Rule for Final Publication March 20, 2027

Overview of Analysis Framework

- Main coolant loop piping LOCA
 - Credit Leak-Before-Break (LBB)
 - Informed by Probabilistic Fracture Mechanics (xLPR) results
 - Extended timeframe for operator action to comply with unidentified leak rate technical specifications LCO
- Other smaller connected piping LOCAs
 - Deterministic LOCA analysis
 - Updated for increased burnup and FFRD effects
- Results demonstrate no burst for high burnup fuel
 - No fuel dispersal
- Applicable to PWRs

Realistic Sequence of Events for Main Coolant Piping

- Initial flaw evolves, over many years, into through wall crack
- Small leakage rate approaches T/S unidentified leakage rate (1 gpm)
 - xLPR results demonstrates LOCA will not occur for 19 months even if plant continues full power operation
- Detected by one or more of the follow indications
 - Inventory balance, Makeup flow rate, Containment sump level, Containment pressure, temperature, humidity, particulate activity,...
- Typical T/S requirements
 - Mode 3 (hot standby) in 8 hours
 - Mode 5 (cold shutdown) in 36 hours
- Coolant has insufficient energy to drive piping crack into LOCA configuration
- Decay heat is reduced once power production is ceased
 - 1 Week after shutdown to 0.30 % of full power
 - 1 Month after shutdown to 0.21 % of full power
 - Should a LOCA occur at these reduced decay heat levels, no FFRD consequences are expected

LBB Applications

- Addresses a specific LOCA related performance criteria
- Limited to individual piping systems that meet deterministic fracture mechanics criteria
 - Demonstrate that the probability of fluid system piping rupture is extremely low
- Approved on plant specific basis for individual piping configurations
- LBB already accepted for:
 - Fuel Fragmentation due to broken Baffle-Former Bolts
 - Exclude blowdown forces on control rod insertion
 - Thermal-Mechanical loads on fuel structures

LBB application to ECCS Policy

- Previously evaluated in Federal Register (Vol. 54, No. 83, May 2, 1989)
 - “Having considered all public comments received, the Commission has decided not to undertake any rulemaking to extend the applicability of LBB to ECCS or EQ at this time. In large part, any safety benefits associated with ECCS can presently be more readily obtained under the recent ECCS rule. The Commission will consider modifying its current ECCS and EQ regulations when adequate technical justification supports the feasibility and benefits of the proposed modifications.”*
- ALS Safety Benefits result from faster deployment of lower batch size designs
 - Reduces the number of Dry Cask Loading campaigns
 - Lower Occupational Dose,
 - Lower Site Boundary Dose
 - Reduced transportation accident risk and dose to public during transport
 - Support transition to 24-month fuel cycles
 - Reducing occupational dose and outage related risks
 - Eliminates staff and industry burden for the experimentation and model development and approval of fuel dispersal. This allow scarce highly specialized NRC staff to focus on more risk significant issues.
 - Smaller front end fuel cycle requirements reduces transportation risk
 - More economical fuel designs supports continued operation of nuclear plants, a carbon free energy source
- An open issue exist about the applicability of a beyond design bases event, created by alternative 2, to design base requirements such as GDC 4 as implemented in SRP 3.6.3 (LBB Evaluation Procedures). The LBB policy should be revised to remove this inconsistency.

LB-LOCA induced FFRD Precluded

- LB-LOCA induced FFRD has an extremely low likelihood of occurrence as supported by
 - NUREG-1829 expert elicitation
 - Confirmed by xLPR analysis probabilistic fracture mechanics analysis
 - LBB piping qualification process with deterministic fracture mechanics also supports the conclusion that the probability of piping rupture is extremely low
- Layers of Defense that support prevention of LB-LOCA
 - NSSS piping system design (e.g. material selection, geometry...)
 - NSSS piping system fabrication (Q/A, welding procedures, welder qualification, weld inspection...)
 - NSSS normal and abnormal operating procedures that limit piping loads
 - In-service Inspection
 - Leak Rate Detection
 - Many months for detection of small leak
 - Multiple independent methods of detection
 - Leak rate progression makes leakage more evident
 - Undetected leakage to the point of piping rupture is not plausible


A blue-tinted photograph of four people standing in a row. From left to right: a woman with curly hair and glasses wearing a white lab coat with 'EPRI' on the pocket; a man with glasses wearing a white lab coat with 'EPRI' on the pocket; a woman wearing a white hard hat and a dark polo shirt with 'EPRI' on the pocket; and a man with glasses and a beard wearing a light blue button-down shirt. The text 'Together...Shaping the Future of Energy®' is overlaid in white in the center.

Together...Shaping the Future of Energy®

Leak Detection


- Regulatory Guide 1.45, “Guidance on Monitoring and Responding to Reactor Coolant System Leakage”*
 - Unidentified leak rate > 0.05 gpm detection/quantification
 - Response time (excluding transport time) of no more than 1 hour for leak rate of 1 gpm
 - Leakage Monitoring Parameters
 - Inventory balance
 - Containment sump level or flow
 - Airborne particulate activity
 - Air cooler condensate flow
 - Airborne gaseous activity
 - Containment pressure, temperature, humidity
 - Acoustic emission
 - Video surveillance
 - Pump seal leakage
 - Makeup flow rate
 - Walkdowns

*Most PWRs were licensed to and still apply Revision 0



**Comments on Cladding Embrittlement
as discussed in the ACRS SC Meeting
on
December 17, 2024**

Ralph O. Meyer, USNRC (retired), and
Wolfgang Wiesenack, Halden Reactor Project (retired)
January 12, 2025



Original Concept for a LOCA Rule Late 1960s

If a fuel rod heats up in steam during a LOCA, the cladding will eventually become brittle. Brittle cladding will shatter or chunks of it will fall away allowing fuel pellets to get out. A core in such disarray is not a coolable geometry.

Therefore

**Do not permit cladding embrittlement
under LOCA conditions.**



Surprising First Test Results Oak Ridge 1971

The fuel rod cladding ballooned and burst at hot spots. Ballooning had not been expected. Embrittlement was localized.

*Final Report on the First Fuel Rod Failure
Transient Test of a Zircaloy-clad
Fuel Rod Cluster In Treat
(ORNL-4635, MARCH 1971)*

R. A. Lorenz, D. O. Hobson, and G. W. Parker



Modified Concept for the LOCA Rule 1973


- Apply embrittlement criteria where cladding is thinnest and embrittlement would occur first.
- Add a time limit because localized embrittlement would occur faster.
- Use oxidation as a surrogate for time.

The limits adopted were:

2200 °F Peak Cladding Temperature

17 % Maximum Cladding Oxidation

How fuel pellets or fragmented particles might escape was not considered. It was assumed that fuel would remain within the cladding if the cladding were not embrittled.



Tests on High Burnup Fuel Rods Halden 2006

In this LOCA test, the upper half of the rod became void of fuel. Fuel had filled the balloon, and some had fallen to the bottom of the test vessel.

Pellet fragments were often observed to be very small as the result of rapid expansion of fission gas that was trapped in voids in the pellet microstructure.

Summary of the Halden Reactor Project


LOCA Test Series IFA-650

(HPR-380, May 14, 2013)

Wolfgang Wiesenack


Tests on Medium Burnup Fuel Rods

Studsvik 2013



Approximate percentage of fuel loss during each test, color-coded by when fuel loss occurred.

*Post-Test Examination
Results from Integral,
High-Burnup, Fueled
LOCA Tests at Studsvik
Nuclear Laboratory
(NUREG-2160, August 2013)
Michelle E. Flanagan,
Peter Askeljung, and Anders Puranen*



Tests on Low Burnup Fuel Rods Karlsruhe 1983

Tests with previously irradiated rods resulted in fragmented fuel pellets in the rod sections with major deformation. Pellet fragments relocated outward and downward, filling the space in the fuel rod created by the balloon.


*LWR Fuel Rod Behavior in the
FR2 In-pile Tests Simulating the
Heatup Phase of a LOCA
(KfK 3346, March 1983)*

E. H. Karb, M. Prüßmann, L. Sepold,
P. Hofmann, and G. Schanz

Possible Impact of Higher Enrichment

When low-enrichment fuel rods are irradiated to high burnup, much of the burnup is accumulated through Pu fission in the outer part of the pellet, eventually creating an ultra high burnup rim containing a lot of fission gas. Rapid expansion of this gas is believed to be a driving force for fuel particle expulsion when cladding bursts during a LOCA.

In higher enrichment fuel with the same burnup, more fission gas will reside in the interior of the fuel pellet, induce microstructural changes, and possibly contribute to energetic fuel expulsion.



Fuel (83 MWd/kgU) subjected to LOCA

CONCLUSION

50.46(b)(1) and (2) should be Replaced and Appendix K should be Eliminated

- Ballooning and burst always occur before embrittlement.
- Burst openings are large enough for fuel to get through
- Fuel expulsion is possible at low burnup and inevitable at high burnup
- Higher enrichments may affect fuel dispersal
- Embrittlement criteria are harmful because they result in core designs and power levels that keep the temperature from getting too high on the limiting rod (a single rod calculation) when cores should be operated to minimize the number of rods that burst (a core-wide calculation).

POSTSCRIPT

- The staff knows how to draft language for this rule change (see letter to the Secretary of the Commission, August 25, 2024).
- The proposed rule does not prescribe the number of permissible rod bursts but rather requires the number to be specified and acceptable.
- The proposed rule resolves FFRD subject only to the performance of confirmatory research – analogous to the 1973 approach.
- This proposed correction to LOCA criteria is a result of earlier confirmatory research performed by NRC, either through direct funding, contribution to cooperative programs, or formal technical exchanges.