

# **Official Transcript of Proceedings**

## **NUCLEAR REGULATORY COMMISSION**

Title: ACRS NuScale Subcommittee Open Session

Location: teleconference

Date: Tuesday, February 4, 2025

Work Order No.: NRC-0195

Pages 1-137

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1716 14th Street, N.W.**  
**Washington, D.C. 20009**  
**(202) 234-4433**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 NuSCALE SUBCOMMITTEE

8 + + + + +

9 OPEN SESSION

10 + + + + +

11 TUESDAY

12 FEBRUARY 4, 2025

13 + + + + +

14 The Subcommittee met via video  
15 teleconference, at 8:30 a.m. EST, Walter L. Kirchner,  
16 Chair, presiding.

17  
18 SUBCOMMITTEE MEMBERS:

19 WALTER L. KIRCHNER, Chair

20 RONALD G. BALLINGER, Member

21 VICKI M. BIER, Member

22 VESNA B. DIMITRIJEVIC, Member

23 CRAIG D. HARRINGTON, Member

1 GREGORY H. HALNON, Member

2 ROBERT P. MARTIN, Member

3 SCOTT P. PALMTAG, Member

4 DAVID A. PETTI, Member

5 THOMAS E. ROBERTS, Member

6 MATTHEW W. SUNSERI, Member

7

8 ACRS CONSULTANTS:

9 DENNIS BLEY

10 STEPHEN SCHULTZ

11

12 DESIGNATED FEDERAL OFFICIAL:

13 MIKE SNODDERLY

14

15

16

17

18

19

20

21

22

23

24

25

## CONTENTS

<u>AGENDA</u>	<u>PAGE</u>
Opening Remarks . . . . .	4
Discussion of SDAA Sections 3.7, 3.8 and 3.9.2 .	8
Staff's Evaluation of SDAA Sections 3.7, 3.8 and	
3.9.2 . . . . .	8
Discussion of SDAA Chapter 5 . . . . .	46
Staff's Evaluation of SDAA Chapter 5 . . . . .	46
Opportunity for Public Comment . . . . .	137
Adjourn . . . . .	137

## P R O C E E D I N G S

8:30 a.m.

CHAIR KIRCHNER: Good morning. I'm Walt  
Kirchner, Chair of today's Subcommittee meeting.

ACRS members in attendance in person are  
Ron Ballinger, Vicki Bier, Greg Halnon, Craig  
Harrington, Bob Martin, Scott Palmtag -- Dave Petti  
will join us shortly -- and Thomas Roberts. ACRS  
members in attendance virtually via Teams are Vesna  
Dimitrijevic and Matt Sunseri.

We have one of our consultants  
participating in person, Steve Schultz, and one of our  
consultants participating virtually Via Teams. That's  
Dennis Bley. If I've missed anyone, either ACRS  
members or consultants, please speak up now.

Michael Snodderly of the ACRS staff is the  
Designated Federal Officer for this meeting. No  
member conflicts of interest were identified. We have  
a quorum as well for today's meeting.

During today's meeting, the Subcommittee  
will receive a briefing on the staff's evaluation of  
NuScale Power LLC's US460 Standard Design Approval  
Application, Sections 3.7, 3.8, and 3.9.2, and Chapter  
5, Reactor Coolant System and Connecting Systems,  
including the Committee's area of focus on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 potential for density wave oscillations occurring in  
2 the steam generators.

3 We previously reviewed the certified  
4 NuScale US600 design, as documented in our July 29,  
5 2020, letter reporting the safety aspects of the  
6 NuScale small modular reactor.

7 Like the staff, we are performing a delta  
8 review between the two designs, including the power  
9 uprate from 50 to 77 megawatts electric per module.  
10 We are reviewing these chapters as part of our  
11 statutory obligation under Title 10 of the Code of  
12 Federal Regulations, Part 52, Subpart E, Section 141,  
13 referral to the Advisory Committee on Reactor  
14 Safeguards, to report on those portions of the  
15 application which concern safety.

16 The ACRS was established by statute and is  
17 governed by the Federal Advisory Committee Act, or  
18 FACA. The NRC implements FACA in accordance with our  
19 regulations.

20 Per these regulations and the Committee's  
21 bylaws, the ACRS speaks only through its published  
22 letter reports. All member comments, therefore,  
23 should be regarded as only the individual opinion of  
24 that member and not a Committee position.

25 All relevant information related to ACRS

1 activities, such as letters, rules for meeting  
2 participation, and transcripts, are located on the NRC  
3 public website and can be readily found by typing  
4 About Us ACRS in the search field on the NRC's home  
5 page.

6 The ACRS, consistent with the agency's  
7 value of public transparency and regulation of nuclear  
8 facilities, provides opportunity for public input and  
9 comment during our proceedings. We have received no  
10 written statements or requests to make an oral  
11 statement from the public. However, we have also set  
12 aside time at the end of this meeting for any public  
13 comments.

14 Portions of this meeting may be closed to  
15 protect sensitive information, as required by FACA and  
16 the Government in the Sunshine Act. Attendance during  
17 the closed portion of the meeting will be limited to  
18 the NRC staff and its consultants, applicants, and  
19 those individuals and organizations who have entered  
20 into an appropriate confidentiality agreement. We  
21 will confirm that only eligible individuals are in the  
22 closed portion of the meeting.

23 The ACRS will gather information, analyze  
24 relevant issues and facts, and formulate proposed  
25 conclusions and recommendations, as appropriate, for



1 deliberation by the full Committee.

2 A transcript of the meeting is being kept  
3 and will be posted on our website.

4 When addressing the Subcommittee, the  
5 participants should first identify themselves and  
6 speak with sufficient clarity and volume, so that they  
7 may be readily heard. If you are not speaking, please  
8 mute your computer on Teams or by pressing \*6 if  
9 you're on your phone.

10 Please do not use the Teams chat feature  
11 to conduct sidebar discussions related to  
12 presentations, but, rather, limit use of the meeting  
13 chat function to report IT problems.

14 For everyone in the room, please put all  
15 your electronic devices in silent mode and mute your  
16 laptop microphone and speakers.

17 In addition, please keep sidebar  
18 discussions in the room to a minimum, since we have  
19 live ceiling microphones.

20 For the presenters, these table  
21 microphones are quite unidirectional. You'll need to  
22 speak directly into the front of the microphone,  
23 particularly so the court reporter can transcribe  
24 today's session.

25 Finally, if you have any feedback for the

1 ACRS about today's meeting, we encourage you to fill  
2 out our public meeting feedback form on the NRC's  
3 website.

4 And with that, we will now proceed with  
5 the meeting. I will turn to the NRC staff.

6 Please go ahead, M.J.

7 MR. JARDANEH: Good morning, Chair  
8 Kirchner, and good morning to the ACRS Subcommittee  
9 members, NuScale, the NRC staff, and members of the  
10 public.

11 My name is Mahmoud Jardaneh, or M.J. I  
12 serve as the Branch Chief for the New Reactor  
13 Licensing Branch, responsible for the licensing of the  
14 NuScale US460 design, in the Division of New and  
15 Renewed Licenses in NRR.

16 Okay. Today, the staff will be presenting  
17 their review of a group of the SDAA Chapters,  
18 including Sections 3.7, 3.8, and 3.9.2 of Chapter 3,  
19 Design of Structures, Systems, Components and  
20 Equipment, and Chapter 5, Reactor Coolant System and  
21 Connecting Systems.

22 Earlier this year, the staff presented to  
23 the Subcommittee on Chapters 2, portions of Chapter 3,  
24 Chapters 7, 8, 9, 10, 11, 12, 13, 14, 16, portions of  
25 Chapter 17 and Chapter 18. The staff also presented

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 on the LOCA, on the Loss of Coolant Accident  
2 Evaluation Model Topical Report associated with the  
3 application.

4 The staff is finalizing their review of  
5 the remaining SDAA chapters and Topical Reports, and  
6 we will inform the ACRS on the safety evaluations on  
7 the remaining chapters and Topical Reports that are  
8 available today to the ACRS.

9 At today's meeting, the staff will focus  
10 on the deltas from the Design Certification that the  
11 NRC has already approved and that the Subcommittee  
12 reviewed in the past.

13 Once again, thank you for the opportunity  
14 and we look forward to begin the session. Thank you.

15 CHAIR KIRCHNER: Thank you, M.J.

16 And with that, I think we'll turn to Tom  
17 Griffith of NuScale. Okay?

18 MR. GRIFFITH: Thank you.

19 Good morning, ACRS Members. Good morning,  
20 NRC counterparts and members of the public, as well as  
21 our NuScale counterparts out on the West Coast.

22 I am Thomas Griffith, licensing manager  
23 for the NuScale US460 Standard Design Approval  
24 Application. I've been with NuScale for, roughly,  
25 three years. I have a background as a former senior

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactor operator/I&C manager, and it's background in  
2 re-occurrence (audio interference) as well as safety  
3 analysis.

4 Today, we are very excited and look  
5 forward to the opportunity to present the remaining  
6 sections of Chapter 3, as well as Chapter 5, and then,  
7 in the closed session, we'll touch on additional  
8 portions of the density wave oscillation topic itself.

9 So, with that, I'd like to turn it back  
10 over to my counterparts here to start the  
11 presentation.

12 DR. KARAOGLU: Thank you.

13 Good morning. My name is Haydar Karaoglu.  
14 I'm a civil engineer with a PhD from Carnegie Mellon  
15 University. Over the past five years, I have been  
16 with NuScale specializing in seismic analysis and  
17 design of structures, as well as the seismic analysis  
18 of the NuScale power modules.

19 Today, we will delve into the differences  
20 between the Certified Design and the Standard Design  
21 Approval Application for Chapter 3, which covers  
22 design of structures, systems, components and  
23 equipment.

24 MR. GRIFFITH: This is Thomas Griffith.

25 We do appreciate the Department of

1 Energy's support for the NuScale US460 Standard Design  
2 Approval Application, appreciate their support and all  
3 the efforts that they made out to the system thus far.

4 DR. KARAOGLU: Thank you. Yes, thank you.

5 So, for Chapter 3, we will on Sections  
6 3.7, 3.8, and 3.9.2, Seismic Design, Design of  
7 Category I Structures, and Mechanical Systems and  
8 Components. Note that some sections, such as concrete  
9 containment, are excluded because they are not  
10 applicable to the US460 NuScale Power Plant design.

11 Next slide, please.

12 This slide here is the summary of key  
13 design features and updates.

14 The Standard Design Approval Application,  
15 SDAA, is a derivative of the certified design, design  
16 certification, DC.

17 SDAA structures reflect six modules, in  
18 support to the 12 modules in the certified design.  
19 And the difference necessitated updated structural  
20 analyses.

21 For the SDAA, the reactor building uses  
22 steel-plate composite walls, along with reinforced  
23 concrete members.

24 And the site layout reflects the updated  
25 building designs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           Seismic analyses for the SDAA are  
2 performed for a double-building model, which features  
3 the reactor building and the rad waste building and a  
4 separate surface-based control building model. The  
5 Certified Design, on the other hand, used a triple-  
6 building model and individual building models for the  
7 seismic analyses.

8           Finally, this presentation will focus on  
9 the high-level design and methodology changes, and  
10 important audit questions and requests for additional  
11 information, RAIs.

12           Next slide, please.

13           We begin with Section 3.7, which is  
14 seismic design. Section 3.7.1 addresses seismic  
15 design parameters.

16           For the percentage of critical damping,  
17 the Certified Design used separate fully cracked and  
18 fully uncracked models, and all the reinforced  
19 concrete members had the same damping ratio of 7  
20 percent for the design calculations.

21           The SDAA, on the other hand, employs  
22 hybrid models with both cracked and uncracked members.  
23 The damping in the structural members varies based on  
24 their cracking status, as well as the purpose of the  
25 calculation, whether for the in-structure response

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 spectra calculations or for design purposes.

2 More details of the damping values for  
3 essential critical damping are available in the  
4 Topical Report titled Building Design and Analysis  
5 Methodology for Safety-Related Structures.

6 Regarding the supporting medium, in the  
7 Certified Design, we had four generic soil profiles,  
8 representing rock, firm soil/soft rock, hard rock, and  
9 soft soil profiles, named as Soil-7, -8, -9, and -11  
10 respectively.

11 In the SDAA, the Soil-8 profile is removed  
12 and, based on the Safety Analysis, the soil-separation  
13 scenario with the Soil-7 is included in the design  
14 basis.

15 There were no audit questions or RAIs for  
16 this section.

17 Next slide, please.

18 Section 3.7.2 covers seismic system  
19 analysis.

20 In the Certified Design, soil-structure  
21 interaction, SSI, analyses were performed using the  
22 extended subtraction method with the software SASSI.

23 In the SDAA, the SSI analyses are  
24 performed using the soil library methodology, which is  
25 a robust approach equivalent to the direct methods of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 SASSI. In this method, the soil libraries are built  
2 using SASSI and the simulations are performed with  
3 ANSYS, leveraging fluid-structure interaction  
4 technology of the software.

5 As they are presented in this figure,  
6 using this methodology, it could model all different  
7 soil structures by soil, building, and fluid together  
8 and simulate the soil-structure interaction and fluid-  
9 structure interaction simultaneously.

10 More details of the methodology are  
11 available in the Topical Report entitled Improvements  
12 in Frequency Domain Soil-Structure-Fluid Interaction  
13 Analysis.

14 Another difference between the Certified  
15 Design and the SDAA is in the combination of the  
16 responses to three components of the ground motion.

17 In the Certified Design, the maximum  
18 responses were calculated using the square-root-of the  
19 sum-of the squares method.

20 In the SDAA, the responses from the three,  
21 statistically independent components of the ground  
22 motion are algebraically added.

23 Next slide, please.

24 SSI Numerical models using the seismic  
25 system analysis, you've seen this figure, the double-



1 building model, featuring the reactor building and the  
2 rad waste building, which are in dark gray here, and  
3 the engineered backfill surrounding them, in blue.

4 In the SDAA, the reactor pool is modeled  
5 with FLUID elements of ANSYS and using the fluid-  
6 structure interaction technology. And the six NuScale  
7 power modules, NPMs, are modeled in detail using  
8 advanced features of ANSYS.

9 In the Certified Design, the pool was  
10 modeled as distributed mass and the 12 NPMs were  
11 modeled as simplified beam models, made of mass,  
12 spring, and beam elements.

13 Thirty-three questions were resolved in  
14 audit for this section, resulting in updates in the  
15 Final Safety Analysis Report, FSAR. Updates cover  
16 modal analysis, double-building model dimensions, and  
17 pool sloshing.

18 There were no RAIs for this section.

19 Next slide, please.

20 Section 3.7.3 addresses seismic subsystem  
21 analysis.

22 The SDAA includes updates to major  
23 subsystems, including the bioshields, the reactor  
24 building crane, and the NPMs.

25 For the SDAA, we developed three different

1 NPM models.

2 A simplified NPM model, which is  
3 represented in the figure here, is used in the SSI  
4 analysis to calculate the seismic demand on the  
5 structural members.

6 A detailed NPM model is used in the SSI  
7 analyses to calculate the seismic response around the  
8 pool.

9 And another detailed NPM model, which was  
10 developed using superelement technology of ANSYS, was  
11 used in the nonlinear transient analysis of the NPMs.

12 A summary of the models and the  
13 methodology are available in Appendix 3A. Also more  
14 details are provided in the Topical Report titled  
15 US460 NuScale Power Module Seismic Analysis.

16 Next slide, please.

17 In the SDAA, the nonlinear NPM seismic  
18 analyses are performed using a comprehensive local  
19 model that includes the six NPMs, the pool, and the  
20 surrounding structural members.

21 The local model used in the SDAA is shown  
22 in this figure here.

23 In the Certified Design, the NPM seismic  
24 analyses were conducted using a local model which  
25 included only one NPM at a time, the pool, and a rigid

1 plane under the NPM.

2 No details of the methodologies are  
3 available in the Topical Reports listed in this slide.

4 For this section, four questions were  
5 resolved in the audit, resulting in additional  
6 bioshield details in the FSAR.

7 And there were no RAIs.

8 Next slide, please.

9 Section 3.7.4 covers seismic  
10 instrumentation.

11 In the SDAA, the locations and  
12 descriptions of the seismic instrumentations are  
13 updated due to the new layout of the buildings.

14 There were no audit questions or RAIs for  
15 this section.

16 Next slide, please.

17 CHAIR KIRCHNER: Haydar, may I ask a few  
18 questions?

19 DR. KARAOGLU: Sure.

20 CHAIR KIRCHNER: Oh, it went off. Let's  
21 try again.

22 First, what did you see as the result of  
23 your analyses with a different level in the reactor  
24 building pool versus loads on the modules? Did you  
25 see any noticeable difference because of lower water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 level? In other words, is there any impact in terms  
2 of seismic forces put on the individual modules?

3 DR. KARAOGLU: It's difficult to comment  
4 on that computing Certified Design and the Standard  
5 Design Approval Application because the models are  
6 different significantly --

7 CHAIR KIRCHNER: Right.

8 DR. KARAOGLU: -- as well as ours with 12  
9 modules and the other six. So, even if we saw  
10 differences, I think it's not really possible to point  
11 to the pool level individually to say that that is the  
12 source of the difference. But I am sure that the pool  
13 level had some impact on some results.

14 CHAIR KIRCHNER: So, overall, did you see  
15 higher stresses, seismic stresses, as a result, or  
16 lower? In other words, what was the net impact of the  
17 pool on the modules?

18 DR. KARAOGLU: I understand that. Yes,  
19 it's kind of difficult to -- just specifically  
20 focusing on the pool, of course, the fact that it was  
21 lower definitely reduces the hydrostatic forces that  
22 we used, that's for sure, on the structural members  
23 and on the NPMs as well.

24 CHAIR KIRCHNER: Right.

25 DR. KARAOGLU: However, in terms of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 dynamic aspect of it, as I said, there are multiple  
2 differences between the models. So, I don't think  
3 it's really possible to point to a certain difference  
4 and say that it's because of the pool.

5 CHAIR KIRCHNER: What about buoyancy? So,  
6 you have a module, essentially, a little ship inside  
7 the pool. What about forces, buoyancy forces, and  
8 such, stresses in the building?

9 DR. KARAOGLU: It's like for the --

10 CHAIR KIRCHNER: The building is holding  
11 more load with a lower level, right?

12 DR. KARAOGLU: That's true. Well, I mean,  
13 the pool, compared to the Certified Design, the pool  
14 volume is lower; hence, the mass is less --

15 CHAIR KIRCHNER: I see.

16 DR. KARAOGLU: -- than what we had before.  
17 But the building size is also different. It used to  
18 be much lower in one direction --

19 CHAIR KIRCHNER: Right.

20 DR. KARAOGLU: -- compared to what we have  
21 now.

22 But regarding the buoyancy, yes, because  
23 the pool level is lower, the buoyancy on the NPMs is  
24 reduced as well.

25 CHAIR KIRCHNER: It looks like the

1 compartments are tighter. Is there any sloshing  
2 impact that you see in a seismic event?

3 DR. KARAOGLU: We looked at sloshing and  
4 I don't remember the numbers right now exactly, but  
5 our conclusion was that the maximum sloshing that was  
6 to be calculated in accordance with the equations  
7 provided in the proposed standards, they were not  
8 significant.

9 CHAIR KIRCHNER: Then, could you just kind  
10 of summarize for us -- you went to much more  
11 sophisticated models; much more higher fidelity is  
12 maybe a better way to say it. Did you see any  
13 noticeable differences, for example, for forces? You  
14 did the square root of the sum of the squares, and  
15 then, the updated methodology. Now, you're going in  
16 actually three directions, adding -- how did you say  
17 it? -- geometric or algebraic --

18 DR. KARAOGLU: That was algebraic ground  
19 forces.

20 CHAIR KIRCHNER: Yes. Did you see any  
21 noticeable difference in the seismic impact on the  
22 modules?

23 DR. KARAOGLU: I would say that the  
24 differences, it's not really possible -- and again,  
25 I'm conflicted in myself, but it is really in the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 way, I think. The methodology may not be the only  
2 source of the differences that we are observing  
3 because the structural members are significantly  
4 different.

5 CHAIR KIRCHNER: Okay.

6 DR. KARAOGLU: But regarding the  
7 comparison of the two methods, like the algebraic  
8 addition of the times versus the SRSS method, you  
9 know, one approach is about -- this is, basically,  
10 captured in the new behavior, the average behavior.

11 CHAIR KIRCHNER: Right.

12 DR. KARAOGLU: And both the methods are  
13 acceptable, according to the Regulatory Guides and  
14 standards.

15 CHAIR KIRCHNER: Thank you.

16 MEMBER HALNON: Haydar, while we're off-  
17 script, this is Greg Halnon.

18 On a previous slide, one of the  
19 differences beyond methodology, I guess, was that you  
20 included six NPMs in the SDAA and you did the DC one  
21 at a time. Can you tell me what the impact of that  
22 decision is relative to, in a DC, theoretically, I  
23 guess, with the seismic analysis, each NPM stands on  
24 its own, is that correct, because you did model one at  
25 a time. How does that translate into the six NPMs?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Can still one module stand on its own from an analysis  
2 perspective?

3 DR. KARAOGLU: Yes. Well, you know, no  
4 model is perfect. So, they're all approximations.  
5 But we believe that in this approach that we followed  
6 in the SDAA, by putting all six NPMs together in this  
7 local model, you could capture the interaction between  
8 the NPMs much more accurately; also, thanks to using  
9 the fluid and soil-structure interaction.

10 But in the earlier methodology as well,  
11 it's also a valid approach. Most of these  
12 approximations are based on engineering judgment. So,  
13 for example, using a single NPM, you would expect,  
14 maybe because of the pool size getting larger, that a  
15 single bay becoming more dominant in capturing the  
16 enveloping demand on a single NPM.

17 And also, it's simple to say that, you  
18 know, in that model, the pool model was represented as  
19 less distributed mass. So, that's also an  
20 approximation.

21 So, I don't know if that answers the  
22 question, though.

23 MEMBER HALNON: Yes, well, I mean, when we  
24 get further into this presentation today, in the 3.9  
25 section that we talk about, we're going to talk about



1 prototype versus non-prototype plants with the Reg  
2 Guide 1.20.

3 And the first NPM is going to be a  
4 prototype. My question is, is this contrary -- not  
5 contrary -- but it is conflicting a little bit that  
6 they have to have one plant stand on its own, both  
7 from vibration and seismic, and everything else, in  
8 order to say that the rest of it is okay? So, you  
9 almost get a non-prototype.

10 I know we'll get to that in the future.  
11 But I was curious, in this DC, you did a single one,  
12 and then, you integrated the 12 together to show that  
13 all 12 would be fine. In the six NPMs, the SDAA, was  
14 that similar? You took all six; you modeled all six  
15 together, but you did still get the individual  
16 interactions on each module, adjacent modules, and  
17 that sort?

18 I'm trying to get a picture in my mind how  
19 that's going to work down the road. Maybe when we get  
20 to 3.9.2, we'll talk a little more about  
21 prototype/non-prototype and how those figure into  
22 that. I assume you'll assume be here, and if there's  
23 any questions, you can --

24 DR. KARAOGLU: Right. Again, yes, I  
25 believe that is something that I hope to discuss later

1 on.

2 But just a brief response to your comment  
3 here, by having all six modules in the same model, we  
4 are kind of trying to represent that seismic waves  
5 traveling into the pool, from the ground to the pool,  
6 and all the interactions between the NPMs and their  
7 structural members around it, we tried to capture it  
8 as accurately as possible using advanced technology or  
9 enhanced --

10 MEMBER HALNON: Okay. So, it's a step  
11 forward -- I mean, from the standpoint of the DC, Walt  
12 said you use much more sophisticated modules and  
13 you're able to integrate it better.

14 DR. KARAOGLU: Right, right.

15 MEMBER HALNON: Okay. Thanks. We'll talk  
16 more about the prototype, and this question in my head  
17 may go ahead at that point, but we'll talk later with  
18 the staff this morning.

19 Thanks.

20 DR. KARAOGLU: Okay. Continuing with  
21 Section 3.8, which is design of Seismic Category I  
22 structures.

23 Section 3.8.2 addresses steel containment.

24 The differences of the SDAA from the  
25 Certified Design include the following:

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1           An increase in design pressure and  
2           temperature for power uprate.

3           Material change from carbon steel with  
4           cladding to a combination of austenitic and  
5           martensitic stainless steels.

6           Pre-service and in-service inspections are  
7           changed from Class 1 to Class MC vessel with  
8           additional requirements in some areas.

9           Hydrogen detonation is removed from load  
10          combinations because of additional passive  
11          autocatalytic recombiners, the details of which are  
12          available in Chapters 6 and 15.

13          The majority of nozzles are changed from  
14          welded to integrally-forged.

15          Twelve audit questions were resolved.

16          And for this section, there were no RAIs.

17          Next slide, please.

18          Section 3.8.4 addresses other Seismic  
19          Category I structures.

20          In the SDAA:

21          The reactor building incorporates steel-  
22          plated composite walls which are designed according to  
23          AISC N690, 2018 version, using element- and panel-  
24          based approaches.

25          Reinforced concrete members are designed

1 according to ACI 349, 2013 version, using the section-  
2 cut demands at critical locations.

3 The forces are calculated from numerical  
4 models with different cracked states associated which  
5 are associated with different load combinations.

6 And all the simulations are performed  
7 using ANSYS with the use of SASSI for soil library  
8 calculations.

9 A summary of the technology and results  
10 are reflected in Appendix 3B, and more details of the  
11 methodology are available in the Topical Report titled  
12 Building Design and Analysis Methodology for Safety-  
13 Related Structures.

14 In the Certified Design, the major  
15 structural members were of reinforced concrete type,  
16 and they were designed according to ACI 349, 2006  
17 version, using an element-based approach. The  
18 simulations were performed using SASSI for the SSI  
19 analysis and SAP2000 for the other load combinations.

20 Fifteen questions were resolved in the  
21 audit, resulting in the updates in the FSAR. The  
22 updates cover: dynamic soil pressure, differential  
23 settlement analysis, definition of the supporting  
24 medium used for calculating the static load demands,  
25 and the design and analysis procedure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   There are no RAIs for this section.

2                   Next slide, please.

3                   Section 3.8.5 covers foundations.

4                   In addition to the analysis and design of  
5 foundations, this section also covers the stability  
6 analysis of the structures.

7                   In the SDAA, the nonlinear stability  
8 analysis is performed only for the Seismic Category I  
9 portion of the surface-based control building.

10                  Also, the peak-bearing pressure values are  
11 calculated using a methodology tailored to the  
12 capabilities of the software utilized, which was  
13 ANSYS.

14                  Twelve questions were resolved in the  
15 audit for this section.

16                  And there were no RAIs.

17                  Next slide, please.

18                  Okay. I will turn it over to Emily Larsen  
19 now.

20                  MS. LARSEN: Hi. I'm Emily Larsen, and I  
21 am a licensing engineer at NuScale. Previously, I was  
22 a system engineer at Braidwood Power Station, and  
23 then, I did design and analysis of hydraulic  
24 components. And I've been at NuScale about a year and  
25 a half.

1           Section 3.9.2 will finish out the  
2 presentations for 3.9. 3.9 was held from the rest of  
3 the presentations to allow time for the analyses for  
4 the DWO Safety Case to complete and allow TF-3 flow  
5 testing to complete and testing data to be analyzed.

6           Differences from the DC to the SDAA  
7 include:

8           Updating the comprehensive vibration  
9 assessment program, Regulatory Guide 1.20, to revision  
10 4.

11          Updating the requirements for the ASME  
12 Operations and Maintenance Code to the 2017 edition.

13          The comprehensive vibration assessment  
14 program startup instruction changed from strain gauges  
15 and accelerometers to dynamic pressure sensors.

16          COL Item 3.9-14, the DC density wave  
17 oscillation carve-out, was removed.

18          Reactor vessel internals and flow-induced  
19 vibration analyses were updated for US460 loads,  
20 design changes, updated flow rates, and operating  
21 conditions, as appropriate.

22          An analysis case of both reactor vent  
23 valves actuating was added to the NuScale Power Module  
24 Short-Term Analysis Technical Report.

25          Next slide, please.

1 All audit questions were resolved and  
2 resulted in:

3 Updating the language for the NPM  
4 prototype classifications to match the NuScale  
5 Comprehensive Vibration Assessment Program Analysis  
6 Topical Report.

7 Providing a summary of flow testing  
8 results for review for TF-3.

9 And providing analyses to show the  
10 structural integrity of the steam generator during  
11 DWO.

12 There was one RAI, and we provided the  
13 preliminary Service Level D fatigue results for the  
14 reactor vessel internals and the steam generator  
15 components.

16 And this resulted in no changes to the  
17 SDAA.

18 Next slide, please.

19 Section 3.9.2 also supports the analyses  
20 pillar of the Safety Case for DWO.

21 Audit questions resolved on this topic  
22 were resolved and there were no RAIs.

23 The DWO Service Level A transient, along  
24 with the NPM lifetime limit for time in DWO is in  
25 Section 3.9.1.

1                   And structural integrity of the steam  
2 generator during DWO supports Section 3.9.2.

3                   Next slide.

4                   And that ends the Chapter 3 presentations.

5                   MEMBER HALNON:   So, Emily, this is Greg  
6 Halnon.

7                   You probably heard prototype versus non-  
8 prototype, the question that we were asking.   Since  
9 the first module in operation will be the prototype,  
10 and every other module beyond that for Reg Guide 1.20  
11 is going to be a non-prototype, can you explain how  
12 that's going to work with six modules being developed  
13 at the same time?   And is it because of the huge  
14 amount of margin that you have that you're confident  
15 you can re-analyze any potential parameters that out  
16 of scope or out of range?

17                  MS. LARSEN:   So, the first module is a  
18 prototype.   All other modules are going to be  
19 instrumented, so that, as they are prototyping, they  
20 won't be prototyped until the first goes through its  
21 final CVAP inspection program.

22                  MEMBER HALNON:   The entry of models to  
23 prototype, until you get at least one that's  
24 identical, and the rest of them can follow along, as  
25 long as they're instrumented and everything is within



1 the bounds of the scope of the analysis, and they'll  
2 be non-prototype from here on out at that point. Is  
3 that the proposal, I guess?

4 MS. LARSEN: Yes. Unless there's some  
5 changes, and then, there may be a limited prototype.

6 MEMBER HALNON: Okay. Well, that makes  
7 sense.

8 And I had one other question for you. And  
9 I'm going to ask this question as a mechanical  
10 engineer and not civil engineer. So, the first word  
11 out of your mouth is going to be over my head.

12 The area's intensity, one of the  
13 measurements was outside of the 6-second range that  
14 you look for strong motion. There was very little  
15 justification why it was okay, but it seemed to be  
16 okay. Could you just give us a quick summary on why,  
17 when we're targeting, trying to get strong motion in  
18 that 5 to 75 percent range in the area's intensity,  
19 that this one is okay at 5.2? Are you familiar with  
20 what I'm talking about?

21 DR. KARAOGLU: Is this -- there's one  
22 that's less than 6 seconds --

23 MEMBER HALNON: Yes, the station is met in  
24 1999. That one was 5.265 seconds.

25 DR. KARAOGLU: Right. Yes, it's the

1        easement. Yes, well, there, the justification is that  
2        the strong ground motion of the area's intensity is a  
3        way of quantified the strong ground motion. And those  
4        are some guidelines about how to calculate it.

5                However, if you look at the time history  
6        plotted and see that strong ground motion, how much  
7        oscillation, and what is that oscillation range? You  
8        can see that, independent of the area's intensity, you  
9        actually can see the strong ground motion starts  
10       earlier. It's because of, if, for example, we were to  
11       take much longer data for the time series, than we  
12       would see that area's intensity already catching up  
13       with that 5 percent limit way earlier.

14               MEMBER HALNON:    Okay.

15               DR. KARAOGLU:    So, that's why, in addition  
16       to the area's intensity, it's important to visually  
17       justify if that range is good for the strong ground  
18       motion.

19               MEMBER HALNON:    Okay.    Good job.    I  
20       appreciate it.

21               DR. KARAOGLU:    Thank you.

22               DR. SCHULTZ:    Emily, with regard to the --  
23       this is Steve Schultz -- with regard to the vibration  
24       assessment    program    and    the    change    from    the  
25       instrumentation to the dynamic pressure sensors, can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       you describe the advantage that provides for this  
2       design?

3               MS. LARSEN:   It actually allows for the  
4       entire steam generator to be monitored at the same  
5       time, instead of just having a couple of tubes  
6       instrumented.

7               DR. SCHULTZ:    So, that's the main  
8       advantage?

9               MS. LARSEN:   Yes.

10              DR. SCHULTZ:   Thank you.

11              MEMBER HALNON:   So, Emily, this is Greg  
12       again.

13              Is that why you characterize this as  
14       extensive instrumentation as opposed to just --  
15       anytime I see a word like extensive, it makes me  
16       wonder, well, what was it before, not extensive?

17              (Laughter.)

18              MS. LARSEN:    I just want to add real  
19       quick, the dynamic pressure sensors also monitor the  
20       reactor vessel internals.   And extensive is a word  
21       used in Regulatory Guide 1.20 -- and, yes.

22              (Laughter.)

23              MEMBER HALNON:   Yes.   So, I guess I was  
24       wondering how you met the term extensive.   And I guess  
25       it's because you have this ability now to measure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 whole components and whole internals, what's going on.

2 Okay. Thanks.

3 DR. SCHULTZ: Steve Schultz again.

4 You described a large number of changes  
5 and advances in your seismic analysis for this design.  
6 And there are very few RAIs -- actually, no RAIs in  
7 the presentations that you made here were provided to  
8 the staff, but a lot of audit questions were answered.  
9 How does that relate to the changes that you've made?  
10 In other words, were you targeting that kind of  
11 performance as you made the changes? What do you  
12 credit for the resulting review by the staff? Very  
13 smooth, I would say, but, as you interacted with the  
14 staff, how would you describe that interaction?

15 DR. KARAOGLU: So, library methodology?

16 DR. SCHULTZ: Yes.

17 DR. KARAOGLU: Well, the methodology  
18 itself is actually, you know, it's relative, but it's,  
19 actually, rather straightforward. It's (audio  
20 inference) to the well-established direct methods of  
21 SASSI. The advantage is particularly in the  
22 computation. Initially, we paid a price for a  
23 demanding calculation for the soil library. However,  
24 later on, when we performed the harmonic analysis,  
25 they are smooth and quick. And also, we incorporated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 most features of ANSYS into the simulation.

2 So, because the underlying theory is  
3 straightforward, it's just a condensation of the  
4 impedance matrices. I believe that the evaluation of  
5 this and, also, in the Topical Report, we also showed  
6 how good it works through verification tests. So, I  
7 think that's why the procedure was smooth -- and to  
8 justify the use of this methodology, soil library  
9 methodology. Even though it's a significant  
10 difference, the advantages it brought were  
11 significant. However, the methodologies of the  
12 underlying theory is straightforward.

13 I don't know if that answers the question.

14 DR. SCHULTZ: That's very helpful.

15 With regard to the seismic forces and the  
16 database that was used to derive them, how would you  
17 characterize that with regard to, if you will -- I saw  
18 what you've chosen. How does that fare with regard to  
19 the seismic forces and systems that need to be  
20 evaluated, let's say, across the United States? Is it  
21 a bounding evaluation? I know, for COLs, the  
22 licensees are going to have to demonstrate that their  
23 site will either be enveloped or do additional  
24 calculations. Is your expectation that it will not be  
25 a problem for COLs, I'll just say, in the United

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 States, because we've got great experience associated  
2 with that?

3 DR. KARAOGLU: Right. Well, there are  
4 different aspects of it, of course, beginning with the  
5 design response spectra. So, our design response  
6 spectra, the Certified Design response spectra, it  
7 covered most of the sites in the U.S. And also, the  
8 rocky sites, because we had this high-frequency  
9 version of the response spectra as well. So, that's  
10 one aspect of it.

11 In regard to the response spectra, we are  
12 enveloping most sites in the U.S., but that's just one  
13 aspect. The other one, that soil-structure  
14 interaction is very much dependent on the soil profile  
15 itself. And by looking at very hard rock and very  
16 soft soil, we tried to address a wide range of soil  
17 properties. So, it's important to ensure that we see  
18 that they are calculated using the soil, local site  
19 properties, and make sure that their demands are  
20 enveloped with what we calculated.

21 However, you know, just making a general  
22 statement like that would be really difficult because  
23 there can be some special sites with very different  
24 profiles. For example, for most of the site, it might  
25 be enveloped by our soil profiles, but very close to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the surface there might be some layers with, like,  
2 much softer layers, and then, they might amplify  
3 certain frequencies. So, it's still necessary to make  
4 sure that things are enveloped, the demands are  
5 enveloped with what we calculated.

6 DR. SCHULTZ: It's necessary to validate  
7 that?

8 DR. KARAOGLU: Right.

9 DR. SCHULTZ: And even what you've just  
10 described as a fairly straightforward approach to  
11 doing the evaluation, is that fair to say, that it  
12 will not be difficult for a COL applicant to perform  
13 that evaluation?

14 DR. KARAOGLU: Yes. Speaking for the SSI  
15 analysis --

16 DR. SCHULTZ: Yes.

17 DR. KARAOGLU: -- the methodology we are  
18 following is, because it's equivalent to the direct  
19 method of SASSI, that shouldn't be difficult.

20 DR. SCHULTZ: Thank you.

21 MEMBER PALMTAG: This is Scott Palmtag.

22 I just had a question about the seismic  
23 analysis. In the NuScale design, there's a lot of  
24 things moving around compared to a standard reactor,  
25 where things are pretty much stationary.

1           You're going to have one, two, three,  
2           four, five, six modules. In addition, you're going to  
3           be moving modules around. They might be in the  
4           refueling bay. They might be under a crane. How does  
5           that go into the seismic analysis? Are those  
6           relatively small changes that you can bound? Or do  
7           you actually have to do a seismic analysis for all of  
8           these different configurations that can happen?

9           DR. KARAOGLU:       In the sensitivity  
10          analysis, we look into modularity. And our analysis  
11          shows that it's not a significant difference. It  
12          doesn't make a significant difference on the demand  
13          that will be within the structural members.

14          Also, it might be worth to point at the  
15          NPMs. A single NPM's mass is significantly small  
16          compared to the whole mass of the reactor building.  
17          So, you know, all these analyses, it doesn't really  
18          require a highly detailed model to be used to address  
19          wherever the NPM is located at.

20          MEMBER PALMTAG:    Okay. So, all the  
21          different configurations are relatively small compared  
22          to the ability to --

23          DR. KARAOGLU:    Yes.

24          MEMBER PALMTAG:    Thank you.

25          CHAIR KIRCHNER:    Haydar, I had another

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 question, just in terms of bracketing things.

2 So, with the steel-plate/concrete  
3 composite structure for the reactor building, you  
4 mentioned cracked/uncracked. Could you just give us  
5 an assessment? What's the impact if you have  
6 significant cracking in terms of the structural  
7 integrity, the seismic response of the building --

8 DR. KARAOGLU: Sure.

9 CHAIR KIRCHNER: -- cracked versus  
10 uncracked? Or what are you looking for when you do  
11 that analysis and what does that tell you?

12 DR. KARAOGLU: Sure. So, it's very good  
13 material for compression, but retention is weak. So,  
14 under seismic load, it cracks. Once it's cracked,  
15 what happens is that its thickness increases and,  
16 also, density increases. So, it's, basically,  
17 absorbing more of that seismic energy.

18 So, as a result of how widespread that  
19 cracking is, the behaviors of the structure change.

20 CHAIR KIRCHNER: Right.

21 DR. KARAOGLU: It gets, for example, lower  
22 frequencies.

23 CHAIR KIRCHNER: Right.

24 DR. KARAOGLU: Its natural frequency  
25 decreases.

1           So, by addressing the cracking using  
2           hybrid models, we tried to capture the dynamic  
3           characteristics of the building, the variation in the  
4           dynamic characteristics of the building under seismic  
5           conditions.

6           CHAIR KIRCHNER:   And if it were fully  
7           cracked, and hence, as you just described, do you see  
8           any amplification in the seismic loads for the module,  
9           transferred to the module or any of the equipment,  
10          including above?   Does the dynamics of the reactor  
11          building response materially impact any of the  
12          questions that would arise regarding the safety of the  
13          modules?

14          DR. KARAOGLU:    The only time we see a  
15          cracked scenario is in the SDAA.   So, I cannot really  
16          say much about it.   But I should state that --

17          CHAIR KIRCHNER:   How do you bound that  
18          then?   You know, what spectrum of cracking do you look  
19          at?

20          DR. KARAOGLU:    For the cracking, the way  
21          we decide on that is, you know, we calculate the --  
22          after SSI analysis, we look at the demands on the  
23          structural members and, you know, compare the stresses  
24          with the cracking stress, obviously, on the (audio  
25          interference) walls, and then, we assign change in the

1 material properties. Seeing how widespread it is in  
2 the model, we make it either cracked or uncracked.

3 Now, that definitely changes the forces --

4 CHAIR KIRCHNER: Right.

5 DR. KARAOGLU: -- being transferred. The  
6 load, you know, it changes. But how do we envelope  
7 that? Well, previously, by design, an uncracked model  
8 and a fully cracked model we'll use to kind of look at  
9 the two extremes, right?

10 CHAIR KIRCHNER: Extremes, right.

11 DR. KARAOGLU: But by looking at the  
12 hybrid model, we are actually kind of following each  
13 of the (audio interference). Because we actually  
14 start with an uncracked model and we perform this  
15 assignment, and seeing how widespread it is, we change  
16 the properties, and then, we run it again.

17 CHAIR KIRCHNER: Right.

18 DR. KARAOGLU: So, that way, we are kind  
19 of trying to follow the variation in dynamic cracking  
20 in the building. So, it's, either way, enveloping  
21 that variation.

22 I don't know if that answers the question.

23 CHAIR KIRCHNER: Well, I'm thinking  
24 through it. If you have a substantially cracked --  
25 I'm not sure how to phrase it. If you have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 significant amount of cracking in the steel-plate  
2 composite building, my sense is that, because it's  
3 steel-plate composite, you still retain the structural  
4 integrity, much more so than a reinforced concrete  
5 reactor building with a liner. In this case, we're  
6 presuming that the inner surfaces of the steel-plate  
7 composite is, indeed, also the pool liner. Or is  
8 there an additional liner?

9 DR. KARAOGLU: One of those, the composite  
10 is just the --

11 CHAIR KIRCHNER: It's just the inside  
12 surface? Right.

13 DR. KARAOGLU: Part of the surface, yes.  
14 Right.

15 Yes, but in regard to that, maybe I should  
16 point to AC 416 or 43, that it's basically, even under  
17 the cracked case, you know, we are modeling the whole  
18 structure as inelastic. So, even in that phase, you  
19 know, we are not assuming any significant damage to  
20 the building. You know, everything is intact. The  
21 reinforced concrete is also intact as well.

22 CHAIR KIRCHNER: So, to follow up on that  
23 earlier question by Scott, what about the building  
24 crane and having a module in transit, or something?  
25 Yes, in the overall picture, the mass of a module

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 isn't that much. But once you've picked it up, it's  
2 out of order, partially out of order, whatever you're  
3 doing with it, and it's on the crane, the crane  
4 support structure, is that impacted in any material  
5 way by significant cracking in the steel-plate  
6 composite structure? Or is the steel-plate composite  
7 structure sufficient without the concrete bearing --  
8 as you said, the concrete is creating compression.  
9 So, holding up the crane and everything. But is the  
10 steel-plate structure sufficient on its own to support  
11 those loads?

12 DR. KARAOGLU: Yes. Based on our  
13 calculations for the demand on the steel-plate  
14 composite walls, they are sufficient the way we  
15 designed them to resist those forces. But I should  
16 maybe point out that, compared to the seismic demand  
17 created by the seismic excitation, the reactor  
18 building crane and the impedance on the structural  
19 members, the effects are mostly local.

20 CHAIR KIRCHNER: Thank you.

21 MEMBER ROBERTS: Yes, Tom Roberts.

22 I'm looking for a little perspective on  
23 the removal of the detonation loads from the scope  
24 containment. I know that it's out of scope of this  
25 discussion. I'm sure we'll get into it with Chapters

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 6 and 15, the uncertainties and the ability of the  
2 PARs to remove hydrogen, some of the uncertainties in  
3 that methodology or that phenomenology.

4 So, by removing it from the analysis, do  
5 you have any sense of what the withstandability to  
6 hydrogen detonation remains? Is that degraded by some  
7 design change or is it just your (audio interference)?

8 DR. KARAOGLU: We'll need to give that to  
9 my colleagues on the call to answer that question. If  
10 this is something that we can take on at this point?

11 MR. GRIFFITH: Yes, Thomas Griffith,  
12 Licensing Manager.

13 So, we do expand the discussion in Chapter  
14 6 on that. I would say that our position is that the  
15 PAR provides sufficient protection against the events  
16 that are postulated there. And I think that our  
17 analysis shows the PAR is safety-related. It performs  
18 sufficiently as sufficient design margin.

19 As far as your question on loads, I would  
20 have to confer with the Chapter 6 LEs on that specific  
21 question. But I don't think it's -- you know, what we  
22 were able to demonstrate in the review, I think, is  
23 that the event is not going to happen. The PAR is  
24 well designed for that.

25 MEMBER ROBERTS: Okay. Thanks. We could

1 sort of come back to that in Chapters 6 or 15. And if  
2 we need to come back to the withstandability of the  
3 structures to deal with it, we can come back to then  
4 subsequently.

5 Thanks.

6 CHAIR KIRCHNER: Since you're showing  
7 acronyms, I'm presuming we're at the end of your  
8 presentations. Is that correct, Tom? I don't have  
9 the slides in front of me.

10 MR. GRIFFITH: That is correct.

11 CHAIR KIRCHNER: Okay. So, Members, any  
12 further questions of NuScale in these sections of  
13 Chapter 3? No?

14 Okay. Then, we'll just take a momentary  
15 pause here and change out and ask the staff to come  
16 forward.

17 Thank you. Thank you.

18 MR. SNODDERLY: Chair Kirchner, I  
19 appreciate the great interaction between you and the  
20 Applicant. Just so that you know, we're about a half-  
21 hour behind.

22 CHAIR KIRCHNER: Yes. Thank you very  
23 much.

24 DR. CHOWDHURY: Good morning.

25 This is Prosanta Chowdhury.

1 If I missed it, are we at a break right  
2 now?

3 MR. TESFAYE: Yes. This is Getachew  
4 Tesfaye.

5 Our lead project managers for Chapter 3  
6 and Chapter 5 are not able to join us in person. So,  
7 that they are leading the meeting virtually.

8 CHAIR KIRCHNER: Yes.

9 MR. TESFAYE: Thank you.

10 CHAIR KIRCHNER: Getachew, who's up first?

11 MR. TESFAYE: For Chapter 3, Prosanta.

12 CHAIR KIRCHNER: Are you first?

13 DR. CHOWDHURY: Yes.

14 MR. TESFAYE: Prosanta.

15 CHAIR KIRCHNER: Oh, Prosanta?

16 DR. CHOWDHURY: Yes.

17 CHAIR KIRCHNER: Okay.

18 DR. CHOWDHURY: Yes. Good morning.

19 CHAIR KIRCHNER: Okay, Prosanta, go ahead,  
20 go ahead, thank you.

21 DR. CHOWDHURY: Okay, good morning, thank  
22 you. Good morning, ACRS members, NuScale  
23 counterparts, NRC colleagues, and members of the  
24 public. My name is Prosanta Chowdhury. I am a senior  
25 project manager in the branch of New Reactor Licensing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 under Division of New and Renewed Licenses at the NRC.

2 I have been with the NRC for about 20  
3 years, 17 of which I have been a project manager. My  
4 background is I have a master's in nuclear engineering  
5 and also a master's in electrical engineering. I have  
6 previously worked for the State of Louisiana in the  
7 radiation protection field for 18 years.

8 So I am the project manager for Chapter 3,  
9 and I will present the slides, and at the appropriate  
10 times I will hand the microphone over to the  
11 presenters.

12 So with that, please let me know if you  
13 can see the slides. Okay.

14 CHAIR KIRCHNER: Yes, we have the slides  
15 up.

16 DR. CHOWDHURY: Thank you, thank you. So  
17 this is the presentation to the Advisory Committee on  
18 Reactor Safeguards Subcommittee. A staff review of  
19 NuScale's US460 standard design approval application  
20 final safety analysis report, Revision 1. And these  
21 are sections are Chapter 3, Sections 3.7, 3.8, and  
22 3.9.2.

23 This slide shows the technical reviewers  
24 that contributed to these sections of the FSAR review,  
25 Sunwoo Park, Scott Stovall, Ata Istar, Zuhan Xi,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Luisette Candelario-Quintana, Yuken Wong, and Stephen  
2 Hambric is the consultant. The lead project manager  
3 is Getachew Tesfaye, and I am Prosanta Chowdhury  
4 again.

5 An overview of these sections of staff  
6 review. So NuScale submitted Chapter 3 of Revision 1  
7 on October 31, 2023. NRC performed a regulatory audit  
8 as part of its review of Chapter 3 from March 2023 to  
9 June 2024. Questions raised during the audit are  
10 resolved within the audit. All RAI responses were  
11 acceptable.

12 So this is a blanket statement because we  
13 are not listing the number of RAIs in all these  
14 questions. They have been reflected in the  
15 appropriate sections of the safety evaluation, which  
16 was released to the public on January 30 this year.

17 Staff completed the review of these  
18 sections of Chapter 3 and issued an Advanced Safety  
19 Evaluation Report to support the ACRS meeting. Now,  
20 on January 4, staff submitted a draft Safety  
21 Evaluation to ACRS for a preliminary review, and there  
22 have been some changes, some updates.

23 Section 3.7 was updated regarding  
24 acceptability of strong motional time history being  
25 less than 6 seconds. Staff will elaborate that later

1 if that question comes up.

2 Section 3.8 was updated regarding demand  
3 over capacity ratio values for reactor building,  
4 calculated and assessed by both element-based and  
5 panel section-based approaches.

6 NuScale SDAA Chapter, FSAR Chapter 3,  
7 these sections have some subsections. As listed here  
8 3.7 has four subsections, 3.8 has five. And then  
9 3.9.2 we have several topics that will be covered  
10 later.

11 So with that, we start with Section 3.7.1,  
12 and I'd like to turn the microphone over to Dr. Sunwoo  
13 Park.

14 Sunwoo, please go ahead.

15 MR. PARK: Thank you, Prosanta.

16 Good morning, I am Sunwoo Park, data and  
17 risk analyst (phonetic) at the NRR Division of Risk  
18 Assessment. I have been with the agency for 17 years  
19 now, previously serving as a structural engineer in  
20 the NRR Division of Engineering.

21 Although my current role focuses on  
22 seismic PRA, I was requested to support the review of  
23 NuScale SDAA seismic design because I reviewed also  
24 the TGA seismic design when I was a structural  
25 engineer. It was part of the inter-organizational

1 collaboration efforts.

2 Yeah, before moving into the slide that I  
3 prepared, if I may briefly comment on the issue that  
4 was discussed concerning slow motion duration.  
5 Initially the staff did not explicitly evaluate that  
6 because staff thought the -- anticipated the impact  
7 would be minimal, but in the updated SER, staff  
8 reviewed it, and then they provided a steady variation  
9 in the SER, which was completed as unacceptable. The  
10 staff specifically reviewed the areas of intensity  
11 curve and noted that there was a quite steep slope on  
12 the curve and around 7 -- 5% and 75% time mark, which  
13 indicates quite strong shaking under that region, 5%  
14 and 75%.

15 So, effectively that indicates the slow  
16 motion invasion practically is graded at 6 second. So  
17 it is acceptable.

18 MEMBER HALNON: Something like that, maybe  
19 it's just the only thing I could find that was really  
20 out of the norm. You mentioned that you didn't have  
21 it in the -- I didn't see the revised SER you had, so  
22 I'll take a look at that.

23 The original SER you felt like, just from  
24 your experience, that that was minimal impact, so you  
25 just didn't mention it at all basically. Is that the

1 reason it wasn't in the original SERs from the minimal  
2 perspective?

3 MR. PARK: Yes, but you know, it was 5.3  
4 seconds at the range of 60 second, the threshold. And  
5 also because there are multiple time histories are  
6 considered by the time histories, which are all  
7 accounted for in developing design basis. So I  
8 thought that the impact would be minimum.

9 MEMBER HALNON: Okay, and you completely  
10 agree with the NuScale rationale behind that?

11 MR. PARK: Yes, I reviewed the, this case  
12 the assertion in the FSAR, and confirmed that is  
13 acceptable.

14 MEMBER HALNON: Okay, thank you for adding  
15 that, I appreciate it.

16 MR. PARK: In Section 3.7.1, seismic  
17 design parameters, there are significant differences  
18 between DCA and SDAA, including structural damping  
19 values using seismic measures. In DCA, the reinforced  
20 concrete was used for safety-related structures and  
21 applied a uniform 2% damping value for both cracked  
22 and uncracked reinforced concrete members to generate  
23 in-structure response spectra.

24 Then SDAA, the two different types of  
25 structural material are used, including reinforced

1 concrete and steel plate combined. And NuScale  
2 utilized the hybrid damping scheme to generate ISRS,  
3 including 7, 5, and 4 and 3 percent, depending on the  
4 cracking condition, whether cracked or uncracked, and  
5 also on the material type, whether reinforced concrete  
6 or steel composite.

7 In both cases, cracked and uncracked ISRS  
8 is the envelope enough to establish design basis. And  
9 the staff concluded that SDAA damping values are  
10 acceptable because they are consistent with the Reg  
11 Guide 1.6.1, the latest update in Revision 2,  
12 published in 2023, yeah. Just stop me if you have a  
13 question. Next slide please.

14 Another interest was in supporting media  
15 for seismic Category I structures. DCA, as mentioned  
16 earlier by NuScale, considered four different  
17 supporting media, including soft soil, firm soil/soft  
18 rock and rock and hard rock. By contrast, SDAA  
19 utilized just three supporting media: soft soil, rock,  
20 and hard rock.

21 In both cases, seismic response from each  
22 soil type enveloped to generate the design basis. And  
23 staff found the supporting media for SDAA are still  
24 acceptable because they reasonably represented a range  
25 of expected site soil conditions. Next slide, please.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           In Section 3.7.2 on seismic system  
2           analysis, significant differences include the  
3           different methodologies for seismic soil-structure-  
4           fluid interaction analysis. DCA employed a two-step  
5           methodology to address the SSFI effects involving  
6           separate soil structure fraction and fluid structure  
7           interaction analysis, which involved a certain level  
8           of basically simplifications and approximations.

9           Whereas in SDAA, the single integrated  
10          methodology was evaluated to evaluated the defense.  
11          And the -- that new methodology used for SDAA was --  
12          it is based on the topical report which was reviewed  
13          by the staff and approved in 2022. And, yeah, 2022.

14          And because the methodology was already  
15          approved in the topical reports. And also because  
16          staff verified that the analysis was performed in  
17          compliance with the applicable limitations and  
18          conditions specified in the topical report. The  
19          methodology is acceptable. Next slide, please.

20          The differences also included the  
21          different analysis models associated with design  
22          changes, which includes -- including six NPMs and  
23          updated NPM models, and the resized ultimate heat sink  
24          with a reduced water volume, water depth. And the  
25          relocated CRB and the new steel composite walls.

1           And also, DCA employed a Triple Building  
2           Model, which includes reactor building, control  
3           building and rad waste building for design basis  
4           seismic demand calculations. To whereas SDAA used a  
5           Double Building Model, including reactor building and  
6           rad waste building and also considering control  
7           building independently.

8           And the updated models were acceptable  
9           because they adhere to applicable industry standards  
10          and DSRS specific review standard acceptance criteria.  
11          Next slide, please.

12          The differences are also identified in  
13          different -- in the approaches to addressing the  
14          results of parameter sensitivity studies. Both DCA  
15          and SDAA conducted in-structure response spectra --  
16          spectrum sensitivity analysis to evaluate the  
17          parameter variations, including structure-soil  
18          separation, empty dry dock, and the modularity.

19          In those cases, in both DCA and SDAA, the  
20          soil-separation scenario resulted in a noticeable  
21          exceedance of the design-basis ISRS. And there are  
22          different approaches to the addressing this  
23          exceedance between DCA and SDAA.

24          DCA addressed the exceedance by including  
25          a COL Item, referring to COL applicant to make sure



1 that the site-specific ISRS soil-separation condition  
2 is bounded by DCA design basis ISRS.

3 Whereas in SDAA, the NuScale incorporated  
4 the soil-separation scenario into the design basis  
5 analysis cases, separate at the analysis cases, which  
6 is a preferred approach here from staff's point of  
7 view and it is acceptable -- yeah, it was acceptable.  
8 It is now, it makes the, one of the design basis case.  
9 Next slide, please.

10 In Section 3.7.3, on seismic soil system  
11 analysis, the differences were -- was identified in  
12 seismic analysis of a building is varied. Seismic  
13 Category I piping, conduits, and tunnels.

14 These data do not include varied piping or  
15 conduits. But at least have, it included tunnel  
16 connecting reactor building and control building. And  
17 the tunnel was analyzed as part of the control  
18 building.

19 In SDAA, there was -- there is a  
20 underground pipe long underground in first counted  
21 duct bank containing conduits that connect -- that  
22 connect to reactor building and to control building.  
23 And the staff, they confirmed that the analysis was  
24 conducted in accordance with applicable industry  
25 standards and DSRS acceptance criteria.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The Section 3.4 -- 3.7.4 on seismic  
2 instrumentation was that reviewed by my colleague  
3 Scott Stovall. And he identified no significant  
4 differences between DCA and SDAA. So we're going to  
5 skip that and move on to Section 3A, presented by Ata,  
6 unless there is any question on 3.7.

7           CHAIR KIRCHNER: Sunwoo, can I ask a  
8 question? Since you highlighted this underground duct  
9 to connect the control, main control room with the  
10 reactor buildings, what's your figure of merit for  
11 success?

12           The implication I'm reading here is just  
13 that it meets codes and standards, but did you analyze  
14 whether there was displacement? Or did you look at  
15 their analysis to see displacement? Was there another  
16 figure of merit in terms of survivability of cabling  
17 and so on as that's contained in that structure?

18           MR. PARK: The detailed calculations on  
19 the underground -- the conduit, was not provided in  
20 the FSAR, rather there was a qualitative description  
21 how the analysis and the design were connected and  
22 stated that NuScale followed the guidance provided in  
23 the ASTE (phonetic).

24           CHAIR KIRCHNER: So from the civil  
25 structural standpoint, it meets the applicable

1 standards and acceptance criteria?

2 MR. PARK: Yes.

3 CHAIR KIRCHNER: Okay. Thank you.

4 MR. ISTAR: Good morning. My name's Ata  
5 Istar, I'm a structural engineer at NRR, and I've been  
6 with the NRC over, well, almost 20 years. Prior to  
7 NRC I worked in, I started in the nuclear industry in  
8 1979 working at the firms Entergy and Constellation  
9 and NRC.

10 And I'll be covering Section 3.8. And as  
11 Haydar described earlier, we had 12 audit questions  
12 for Section 3.8.2, which is the steel containment, and  
13 15 audit questions 3.8.4 for other structural and  
14 Category I. So other-sized in Category I structures.

15 And each audit question had multiple  
16 requests under it. In Section 3.8.2, seismic  
17 containment, the design parameters are slightly  
18 different. And of course the material, as Haydar  
19 earlier mentioned. And what we realized in the,  
20 during the discussions, they also changed the,  
21 reconfigured the boundary conditions between the  
22 bottom of, head of the CNV and the RPV.

23 And in the DCA space, there was a pin  
24 connection, one single pin connection at the bottom  
25 heads connecting from OD of RPV to ID of CNV. With

1 shims and -- shims located at each phase.

2 And the new configuration has three logs  
3 on the OD of RPV and clevis screws on the inside  
4 diameter of CNV. So I think this is a better  
5 configuration than a pin connection concentrated at  
6 the bottom. So staff cited that's a better  
7 improvement supporting the reactor vessel and the  
8 containment connection.

9 CHAIR KIRCHNER: But the other design was  
10 hardly a pin. It was significant structure.

11 MR. ISTAR: It was insert, some kind of  
12 insert.

13 CHAIR KIRCHNER: Okay.

14 MR. ISTAR: So basically design parameter  
15 is slightly higher, as I listed in the presentation.  
16 But of course the steel containment was designed for  
17 those conditions, and we had no issue with that. Next  
18 slide, please, Prosanta.

19 The other seismic Category I structures,  
20 and we had -- I would think this, we have sections  
21 into this. There's a methodology, which was presented  
22 for the development of this approach, which is SC  
23 walls. And there was a topical report that was  
24 provided to us. We reviewed it in detail, accept it,  
25 and it was accepted by the ACRS as well.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So that was a major change from the  
2 reinforced concrete design to SC wall, applicational  
3 SC walls with combination of reinforced concrete  
4 substructures with it.

5           I think this is a big improvement compared  
6 to the DCA design from numerous aspects. One, it's  
7 faster constructability of the reactor building. And  
8 much better seismic capability, as well as its  
9 aircraft impact assessment. So those are important  
10 elements that improve this SDAA design using the SC.

11           Again, the one thing we found during the  
12 review, of course the NuScale did both -- I should  
13 credit that, element-based and panel-based sections,  
14 which is an important thing.

15           And panel-based, section-based, panel  
16 section-based approach is provided in the N690, in  
17 SEN690, which is one times the thickness of the sea  
18 wall at the edges, at the corners, and two times of  
19 the thickness of the SC walls in the middle sections,  
20 which is accepted by these both.

21           And as we were reviewing the demand over  
22 capacity ratios, certain very, very localized areas  
23 were higher than 1.0. And I'm not sure we should  
24 elaborate this at this point or maybe in the closed  
25 section.

1           It's up to you, sir. And just, or  
2 NuScale, whether we should discuss that and how we  
3 concluded those exceedances at three locations in the  
4 reactor building are acceptable. It's up to you, I  
5 can elaborate this. As a matter of fact, I brought  
6 this big picture here so I can locate those.

7           CHAIR KIRCHNER: Well, let's, if I may, go  
8 back to 2022, don't hold me to the date exactly, when  
9 we did review the steel plate composite topical report  
10 from NuScale, and you approved that. And we thought  
11 you should issue that.

12           One of the areas that we highlighted, and  
13 perhaps you could take up, if not here, in the open  
14 session and the closed session, is connections. And  
15 I think you're hinting at that. And I think one would  
16 ask about leak-tight integrity of the structure as you  
17 -- with fasteners and connectors and from the base mat  
18 to the side walls.

19           Can you address that either now or in the  
20 closed session?

21           MR. ISTAR: Based on the design, and I  
22 mean, we're looking at the structural integrity of  
23 the, all of the building.

24           CHAIR KIRCHNER: Right.

25           MR. ISTAR: Not the leak-tightness here.

1 The leak-tightness comes in the construction  
2 capability of this at the -- at the, you know, steel  
3 plate, SC plate, goes into the reinforced concrete.  
4 It's buried into it. And there, in the structure and  
5 the plate, bottom plate, there is another bottom plate  
6 on the foundation connecting to the vertical SC wall.

7 And that weld should provide, that joint  
8 weld should provide the leak-tightness at that  
9 location. And that is a critical weld for leak-  
10 tightness perspective. But we, in this section, 3.8.4  
11 section, we're looking the integrity of the structure.  
12 Leak-tightness is not the element that we will look  
13 at.

14 We'll assume that weld is appropriately  
15 done and provides structural integrity of the walls as  
16 well as the foundation.

17 CHAIR KIRCHNER: But in your review, then,  
18 you would look at the -- that weld, that series of  
19 welds, actually, that comprise the, in effect, the  
20 liner equivalent that was in the DC design where you  
21 had a reinforced concrete building with a liner. So  
22 at some point, where do you look at the integrity of  
23 that weld in terms of a massive leak from the reactor  
24 pool?

25 MR. ISTAR: I just got a question. That

1 particular weld does not provide any integrity of the  
2 overall structure. The weld that has --

3 CHAIR KIRCHNER: No, understood.

4 MR. ISTAR: Okay, that does not provide  
5 anything except the leak-tightness, right, at that  
6 location. And in the, I recall in the design  
7 certification, there is, you know, that's a reinforced  
8 concrete structure that it's a huge, I think five-foot  
9 thick walls with pilasters. And you know, it's a  
10 major -- the cost of that is huge compared to this  
11 one.

12 But that location is, I don't recall  
13 exactly how it's -- probably it's similar to the SDAA  
14 configuration. But the liner, the liner comes in and  
15 butts into the -- butts into the SC wall face steel.  
16 And it should, there is a weld there at the -- I think  
17 that's all I can tell.

18 And whether there -- you know, I think, as  
19 I understand from your question whether under any  
20 seismic event or something that weld has some --

21 CHAIR KIRCHNER: Say you had a major  
22 fracture --

23 MR. ISTAR: Fracture at that location.

24 CHAIR KIRCHNER: -- along the length of  
25 the weld.



1 MR. ISTAR: Well, if you're looking at the  
2 design over capacity ratios, and this is deeply  
3 embedded structure, deeply embedded structure, and we  
4 are -- if your design over the capacity ratios at that  
5 location is low. And remember, this is a linear  
6 elastic regime. It's, we don't have any plastic  
7 deformations at that location.

8 So as long as we are within the linear  
9 elastic area, we should not have any cracks at that  
10 location. It's below the -- I think it's over 80 foot  
11 below the ground level. And you are kind of confined  
12 into this space.

13 And they actually, which we'll hopefully  
14 discuss that later, design over capacity ratios which  
15 are over one, they are upper sections, in the upper  
16 sections. Not at that location. They all meet the --  
17 they are well below the --

18 CHAIR KIRCHNER: The N690 or?

19 MR. ISTAR: They're, I don't think there's  
20 going to be any fracture under any external load  
21 conditions.

22 CHAIR KIRCHNER: Good, that's what I  
23 wanted you to answer in the public session. Okay,  
24 thank you.

25 MR. ISTAR: And I think -- should we

1 discuss the design over -- demand over capacity ratio  
2 discussions?

3 CHAIR KIRCHNER: Can you just summarize?

4 MR. ISTAR: Yeah, I can summarize. There,  
5 you know, there are three locations. NuScale staff  
6 who are members, engineers, identified there -- demand  
7 over capacity ratios are larger than 1. Which is, the  
8 highest one is 1.05. That will be -- the other one is  
9 1.04. The other one is 1.02.

10 And we closely look at those locations.  
11 And I can maybe -- because it's hard to explain it.  
12 I pull up, this is the DCA design.

13 DR. CHOWDHURY: This is Prosanta, Ata. I  
14 apologize for interruption, but I assume it's okay,  
15 but please make sure that we are not bringing up any  
16 proprietary information in this section. Thank you.

17 MR. ISTAR: Thank you. This is a old  
18 design, but I just, the reason I'm pointing this out,  
19 the shear wall numbers are similar. So this wall is  
20 RX1, where the main entrance is. And as you can see,  
21 the structure's deeply embedded. And I think this is  
22 83 feet underground.

23 And the one that is the highest demand  
24 over capacity ratio is at this little location. And  
25 the second one is at this location on the opposite

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 side, not on this side. On the opposite side. And it  
2 was in the application, revised application, I should  
3 say, this was described as due to the geometric  
4 discontinuities, that was developed.

5 And in the finite element analysis, there  
6 are always glitches when you have geometric  
7 discontinuities. You have high peak stresses in areas  
8 that are not -- they're very cornered --

9 CHAIR KIRCHNER: Corners, fasteners, yeah.

10 MR. ISTAR: -- openings and that kind of  
11 thing. And please note that these, the results are  
12 based on the high seismic conditions that, you know,  
13 conservative loading combinations. And with the all  
14 soil types, that was all soil types. So these are the  
15 maximum worst conditions, you could see it.

16 You can see it, it's in the upper  
17 sections, in the higher elevations. And very, very  
18 concentrated area.

19 They're, you know, from a structural  
20 perspective, if you want to, you know, if they want to  
21 make those numbers lower, there are two things that  
22 can be done. As I told your earlier panel, this is  
23 the result for a panel section-based results.

24 CHAIR KIRCHNER: Right.

25 MR. ISTAR: And panel section-based

1 design, it can be merged with adjacent members, which  
2 will reduce the stresses. Or if that area, I don't  
3 believe it's critical to the overall structural  
4 behavior, the face plates could be enlarged and make  
5 that area reduced.

6 I don't think any of these things are  
7 necessary because these are developed due to the  
8 mathematical calculations in the finite development  
9 analysis. And these are very, very localized. And as  
10 you can see it, it doesn't affect the big overall  
11 structure. It's a very localized location.

12 So that's all -- I can elaborate this --

13 CHAIR KIRCHNER: In the closed session,  
14 thank you.

15 MR. ISTAR: -- more if you like. I think  
16 next section is 3.8.5 foundation. I would like to ask  
17 Zuhan contribute to this section.

18 Thank you.

19 MR. XI: Hi, my name is Zuhan Xi. I have  
20 been with the agency for 18 plus years. I am  
21 currently a geotechnical engineer --

22 CHAIR KIRCHNER: Pull that microphone  
23 closer to you.

24 MR. XI: Okay, I'm sorry.

25 CHAIR KIRCHNER: Yeah, just reintroduce

1       yourself so the court reporter gets it.

2               MR. XI: Yeah. I start over again. My  
3       name is Zuhan Xi. I'm with agency for 18-plus years.  
4       And I'm a geotechnical engineer. And previously I was  
5       a structural engineer. Prior to joining the NRC, I  
6       was a contractor at The Fairbank Highway Research  
7       Center. I was a research structural engineer.

8               I reviewed 3.8.5 and which is the  
9       foundation. Yeah, the big difference is, you know, I  
10      noticed for the embedment of the control room  
11      building, which is in the SDAA. The CRB is modeled as  
12      a surface-founded structure, conservatively, ignoring  
13      the five-feet embedment of the foundation of its  
14      stability analysis.

15              In the DCA, the CRB with an embedment  
16      that's of 55 feet is modeled is as embedded structure  
17      with the backfill. So that's the major, you know,  
18      difference between the SDAA and a DCA. So SDAA, SC  
19      conclusion is the same as DCA SC type conclusion.

20              CHAIR KIRCHNER: Just for the record,  
21      could you state what that conclusion is?

22              MR. XI: The conclusion is the safety  
23      integrity is with the limits.

24              CHAIR KIRCHNER: Thank you.

25              MR. WONG: My name is Yuken Wong, I'm a

1 senior mechanical engineer in the Mechanical  
2 Engineering and In-Service Testing Branch. I have  
3 been with the NRC for 18 years. And prior to that,  
4 I've worked for Westinghouse for 15 years.

5 The review of Section 3.9.2, dynamic  
6 testing and analysis, involves three main areas.  
7 First is the piping vibration and thermal expansion  
8 testing. Second is the comprehensive vibration  
9 assessment program, or CVAP, of the reactor vessel  
10 internals, which include steam generators.

11 The staff reviewed two technical reports  
12 relating to flow-induced vibration analysis and  
13 testing and inspection of reactor vessel internals.

14 Third area is the analysis of reactor  
15 vessel internals under ASME Service Level D  
16 conditions. Those are the earthquake events and loss  
17 of coolant accidents.

18 The staff reviewed two technical reports  
19 that provide the seismic loads and the short-term  
20 transient blowdowns. The staff also reviewed the  
21 stress and deflection analysis. Next slide, please.

22 For the DCA, there were deferred or  
23 unresolved issues. The qualification of steam  
24 generator components due to the DWO was a carve-out.  
25 The validation testing to demonstrate the steam

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 generators is not at risk to FIV. It was deferred to  
2 the COL applicant.

3 The Service Level D evaluations did not  
4 include the hard rock high frequency seismic loads.  
5 And those were deferred to the COL applicant. Next  
6 slide, please.

7 For the SDA CVAP, there were significant  
8 changes. Higher flow velocity lead to stronger FIV  
9 loads. NuScale introduced a temperature approach  
10 method in the later part of the SDAA review to limit  
11 operating conditions that, where COL may occur and  
12 produce the DWO loads.

13 The steam generator inlet flow restrictors  
14 were redesigned and no longer a risk to increased flow  
15 instability.

16 The steam-generated tube supports are  
17 changed to provide more surface area, more compact  
18 surface area and provide improved dimensional  
19 variability. The secondary flow piping branches are  
20 changed and improved, minimize the risk to acoustic  
21 resonance.

22 A qualification of steam generator due to  
23 the DW load is no longer a carve-out. NuScale  
24 performed the steam generator validation testing,  
25 which confirmed there's a minimum risk to FIV. Next

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 slide, please.

2 In the DCA and early part of the SDA  
3 reveals --

4 MEMBER PETTI: I'm sorry, go back to the  
5 previous slide.

6 MR. WONG: Okay.

7 MEMBER PETTI: Last bullet suggests  
8 there's not a big risk of flow-induced vibration. The  
9 previous slide basically said that it, they hadn't  
10 demonstrated that significant flow-induced vibration  
11 in the steam generator tubes. Those seem  
12 contradictory.

13 MR. WONG: That's correct. This slide  
14 refers to the SDA, what's current now for the SDA.  
15 And the previous slide was highlighting --

16 MEMBER PETTI: Oh, the DCA --

17 (Simultaneous speaking.)

18 MR. WONG: -- in the DCA.

19 In the DCA or early part of the SDA  
20 review, there were concerns that during high  
21 amplitude, reverse DWO flow to phase region in the  
22 steam generator tube may approach the inlet, leading  
23 to a cavitation and condensation-induced water hammer.

24 There was no limit on the number of DWO  
25 cycles during the life of plant, so significant



1 numbers of cycles were made cumulatively. Next slide,  
2 please.

3 For the review of the steam generator due  
4 to DWO loads, it's based on three-tiered approach.  
5 First, boiling boundaries are highly unlikely to  
6 approach the steam generator inlets, even during DWO.  
7 So cavitation and condensation-induced water hammer,  
8 highly likely would not occur.

9 The Chapter 5 review confirms that  
10 NuScale's analysis provides reasonable prediction of  
11 the boiling heights. The NRC Office of Research  
12 performed the independent analysis using the computer  
13 code TRACE. The results show condensation-induced  
14 water hammer is highly unlikely.

15 In the unlikely event this mechanisms  
16 occur, NuScale calculated the steam generator tube and  
17 inlet flow restrictor erosion due to cavitation and  
18 the tube stress due to liquid slack (phonetic) flow.  
19 Results show damage to the components is not like.

20 Finally, the steam generator program  
21 inspection would detect any unexpected wear for  
22 modules. One hundred percent of the tubes will be  
23 inspected during the first refueling outage, and after  
24 that, at least 72 effective full power months.

25 I'm going to turn over for the review of

1 the remaining of Section 3.9.2 to Dr. Hambric.

2 DR. HAMBRIC: Hi, everyone, I'm Dr. Steve  
3 Hambric. I've been a consultant for the NRC for about  
4 20 years now, going back to boiling water reactors  
5 steam fire failures. And I've worked in flow-induced  
6 vibration and noise for over 35 years, primarily for  
7 the U.S. Navy, but also U.S. industry, both in  
8 managements and simulations.

9 I will point out that we do have a bunch  
10 of backup slides if you guys want to dig deeper into  
11 the DWO stuff or anything I'm about to tell you here.  
12 We can do that in the closed session.

13 A lot of work on steam generators in the  
14 SDAA. So the next topic is making sure they were not  
15 subject to significant FIV due to vortex shedding and  
16 fluid-elastic instability. Those are mechanisms that  
17 can make these tubes shake around a lot and  
18 potentially fail over time.

19 NuScale had built, actually several years  
20 ago, a pretty nice scale model facilities, actually  
21 full scale, but it's not as -- it's not all the tubes,  
22 in Piacenza, Italy, at the SIET facility. And had not  
23 tested it at the end of the DCA.

24 But they did test it that past summer, and  
25 we actually went on site and looked at the facility,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 made sure it looked good to us. Had some preliminary  
2 flow results. They look good as well.

3 And the two big things we were after were,  
4 number one, is it a valid facility. And so they were  
5 able to prove to us by looking at vibration  
6 measurements that they had a nice, tightly fitting  
7 setup. All the tubes were really well connected to  
8 the support system.

9 That's important to us because if we had  
10 a sloppy connection, that would induce a bunch of  
11 damping that would essentially invalidate the entire  
12 test. You'd never be able to get a flow-induced  
13 vibration instability going if you had a loose, sloppy  
14 system. But they got a nice, tight system, looks  
15 good.

16 The other thing we were concerned about is  
17 when they built this, it was an old design with a  
18 support system. New design is a little bit different,  
19 it's better. Wanted to make sure that the support  
20 system wasn't going to somehow invalidate the test,  
21 and it will not. It's a good, tight facility, and  
22 we're quite happy with it.

23 The neat thing they were able to do in  
24 this facility that they couldn't do in the real actual  
25 NPM is they could crank up the power to 250% and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 higher, really get the flow moving. And did not see  
2 any evidence of anything untoward in any of their  
3 tubes. So we're very happy about that, no vortex  
4 shedding, no FEI.

5 We've got a bunch of detailed stuff we can  
6 show you in the closed session if you like, but it  
7 looks like nice, linear response all throughout. So  
8 we're quite confident that these steam generators  
9 should not experience significant vortex shedding or  
10 FEI in service.

11 MEMBER HALNON: So Steve, this is Greg,  
12 so all the clearances, everything for a leakage flow  
13 type, you looked at all those and they were, even  
14 though it had a lot fewer tubes, it was prototypical  
15 enough to be able to see the, what is it, like six or  
16 seven different flow-induced vibration type phenomena?

17 DR. HAMBRIC: Yeah, the only two we're  
18 worried about here are vortex shedding, which is  
19 individual tubes and the vortices behind them shaking  
20 the tube up and down and locking in, and fluid-elastic  
21 instability, where multiple tubes can kind of grab  
22 onto each other and start moving significantly.

23 There's no really concern about leakage  
24 flow instability in the vortex -- in the steam  
25 generator. We did evaluate that phenomenon in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 rest of the plant. In particular, there's a hose in  
2 the support place for the CRDS tubes to go through and  
3 the ICIGs to go through. So we looked at leakage flow  
4 there.

5 MEMBER HALNON: And the reason I ask --

6 DR. HAMBRIC: But not in the steam  
7 generator.

8 MEMBER HALNON: Okay, the reason I ask in  
9 the steam generator is because the flow issues will be  
10 on the outside of the tubes. And to inspect that, I  
11 haven't got a clear view in my head how that's going  
12 to be inspected after a certain amount of operation.  
13 And it's going to be done visually, I guess.

14 So that's kind of the reason I asked. The  
15 structures around the outside of the tubes and the  
16 clearances and whatnot that's holding in place,  
17 whether or not there would be any problems. So it's  
18 sounds like you've --

19 DR. HAMBRIC: If there were clearances, we  
20 would have seen that in the flow-induced vibration.  
21 There would have been kind of a lot of sloppiness in  
22 the vibrational elements we were seeing in the  
23 spectrum. We didn't see any of that.

24 MEMBER HALNON: Maybe a little sloppiness,  
25 not a lot of sloppiness. All right, just trying to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 put it in context.

2 DR. HAMBRIC: Yeah, we saw almost none.  
3 The damping was tidy. It looks like a nice, tight  
4 fit. When you turn the thing on and you've got the  
5 fluid in there and it's pushing everything together,  
6 everything's tight, so.

7 MEMBER HALNON: Good, thanks.

8 DR. HAMBRIC: Once again, we've got more  
9 details. They've put together a really nice report  
10 summarizing their results. And it just looks as good  
11 as we could have hoped it to be. Next.

12 One other TF-3 related test that they did  
13 for us is, if you remember when NuScale presenting,  
14 they did change pretty significantly the initial  
15 startup testing instrumentation. In the DCA, they  
16 were going to individually instrument several tubes  
17 with accelerometers, strain gauges to directly measure  
18 the vibration during startup.

19 And in the SDAA, they said no, we're going  
20 to switch to dynamic pressure sensors scattered  
21 throughout the plant. And a couple of good reasons  
22 for that.

23 As Emily pointed out, really able to hear  
24 anything. If it's an individual tube instrumented,  
25 you might not hear it if another tube is vibrating.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 But if you have the pressure sensors, you can pretty  
2 much hear anything crazy happening throughout the  
3 plant.

4 The other nice thing about it is you don't  
5 have wires and other stuff feeding through the flow  
6 and potentially causing some problems.  
7 Instrumentation is falling off. It's a much cleaner  
8 approach having the external for the -- or dynamic  
9 pressure sensors.

10 But the one thing they really didn't show  
11 us until recently was that those were going to be  
12 sensitive enough to hear if anything bad was happening  
13 inside the plant. That's all external stuff. I mean,  
14 it's close to the internal -- or the internal  
15 components, but not on the internal vibration  
16 components.

17 But the neat thing they did during the TF-  
18 3 testing is along with instrumenting tubes with  
19 actual accelerometers and strain gauges, they put  
20 those same pressure sensors in the TF-3 test facility  
21 and were able to show us that when a tube did start  
22 vibrating, not non-linearly, it was total linearly,  
23 they could actually hear that tube vibration in those  
24 pressure sensors.

25 And they could hear it quite clearly. And

1 that proved to us that their approach for the NPM is  
2 sound, that those pressure sensors ought to hear if  
3 anything crazy is happening inside the plant. So that  
4 gave us a lot of confidence, feel good about that.  
5 But that is not something we had in DCA but we have  
6 now. Okay, next, please.

7 Let's move on to the Service Level D  
8 stress analyses. And just a note, I did not perform  
9 the DCA review, David Ma (phonetic) did. But I worked  
10 closely with Yuken and David during that, so I have a  
11 pretty good feel for what they did.

12 There are a few differences between the  
13 DCA and the SDAA approach. It's obviously completed  
14 for building. We've talked about that already. The  
15 seismic loads for the Service Level D calcs, the SDAA  
16 did include both soft soil and hard rock.

17 Under DCA it was I think only soft soil or  
18 something intermediate. But it was one condition, but  
19 in the SDAA that they expand everything.

20 And the reason that's important is the  
21 hard rock shifts some of the peak loads up in  
22 frequency. And that ended up aligning with some of  
23 the low frequency resonances of the steam generator  
24 tubes itself, so that was something we looked pretty  
25 closely at.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1           They did make some other changes to the  
2 designs, not going to get into that here. But the one  
3 thing I want to highlight is that the modeling  
4 approach when you compare the DCA to SDAA, much, much  
5 improved. Much cleaner, simpler, more rigorous, more  
6 detailed. So it's a much simpler evaluation we were  
7 able to do.

8           Also their assessment of the overall  
9 stresses throughout the RVI, the steam generators.  
10 Comprehensive, quite thorough. We did not see any  
11 significant risk of damage to worry about.

12           It is preliminary, they will do an updated  
13 calculation before they actually build the thing. But  
14 we're pretty confident they've got a bounding  
15 evaluation and there shouldn't be anything to worry  
16 about.

17           Now, we've got some details we can get  
18 into if you like, but I'd like to skip the next couple  
19 of slides unless you want to ask some questions.

20           Oh, one final point. The transient loads  
21 are pretty significant here, like the blowdowns from  
22 inadvertent vent openings. It's pretty much the  
23 seismic that dominates everything by about an order of  
24 magnitude.

25           Okay, I think the next two are just kind

1 of backup, we can go ahead. Next one, please. Next  
2 one, please. Okay, so that's -- we are concluded.

3 DR. CHOWDHURY: So thank you, thank you,  
4 Steve. This is Prosanta Chowdhury again, Project  
5 Manager, NRC. So this is an overall conclusion slide.  
6 As staff already described some of the differences  
7 between the DCA and SDAA. The staff found that the  
8 Applicant provided sufficient information to support  
9 the staff's safety findings.

10 And the staff found that all applicable  
11 regulatory requirements were adequately addressed.  
12 And that concludes Chapter 3, Sections 3.7, 3.8, and  
13 3.9.2 formal presentations. Thank you.

14 CHAIR KIRCHNER: Thank you, Prosanta.

15 Members, any questions? We can also take  
16 up some of this in the closed session later.

17 Okay, with that, we're a little bit behind  
18 on the schedule, but we can catch up later. Let's  
19 take a break until 10:45 a.m. Eastern Time. And we'll  
20 pick up Chapter 5 and the NuScale presentation.

21 Thank you to all the presenters.

22 (Whereupon, the above-entitled matter went  
23 off the record at 10:28 a.m. and resumed at 10:45  
24 a.m.)

25 CHAIR KIRCHNER: Okay. We're back in

1 session, and we're going to turn to NuScale and  
2 Chapter 5. And Wendy, are you up first? Go ahead,  
3 please.

4 MS. REID: Hello. My name is Wendy Reid.  
5 I'm a licensing engineer with NuScale and have been  
6 for three years now. Previous to NuScale, I was an  
7 engineer with Electric Boat. I specialized in taking  
8 first of a kind technologies through qualification and  
9 installing them on the submarine for proof of concept  
10 trials.

11 I will be introducing Chapter 5 here and  
12 presenting Sections 5.1 and 5.2. And then I will turn  
13 it to Erin who has Sections 5.3 and 5.4. Chapter 5 is  
14 the reactor coolant system and connecting systems.

15 It's where we described the reactor  
16 coolant pressure boundary and its components over  
17 pressure protection, the reactor vessel and its  
18 properties, and our system components in the subsystem  
19 design, so DHRS and steam generators, the pressurizer.  
20 I would like to note that Section 5.3 is where we  
21 incorporate the Pressure and Temperature Limits  
22 Methodology Technical Report which does have an SER,  
23 although it's a technical report. And we are  
24 including it in our presentation today.

25 And where changes were made in Revision 2

1 of the FSAR, we have been noting that (audio  
2 interference) as with Chapter 3. Our presentation  
3 focuses on the differences from DCA. In the staff's  
4 review of Chapter 5 and the PT Limits methodology  
5 report, we had 59 questions -- audit questions in  
6 Chapter 5.

7 We had 20 additional questions against the  
8 technical report. And we had one RAI in Chapter 5.  
9 All of these were successfully resolved.

10 In Section 5.1 is our summary description.  
11 We have tables describing the normal operating  
12 parameters. And they do show changes in both the  
13 primary and the secondary operating pressure,  
14 operating temperature, and the flow rates.

15 These are all a result of the power  
16 uprate. Also, the design pressure is the same for  
17 primary and secondary, so both sides of the steam  
18 generator tubes. Both those design pressures changed  
19 from 2,100 psi to 2,200 psi.

20 And we made a classification change to the  
21 upper steam generator support based on feedback from  
22 the manufacturer. The requirements for that support  
23 remain consistent with ASME code. Finally, there was  
24 a change to the RCS volume.

25 MEMBER HALNON: Wendy, what's --

1 MS. REID: Sure.

2 MEMBER HALNON: This is Greg. What's the  
3 footnote there that you get --

4 MS. REID: Oh, the footnote?

5 MEMBER HALNON: You got it on every single  
6 one of them.

7 MS. REID: Sure. The footnote was where  
8 Revision 2 of the FSAR has a markup from Revision 1.

9 MEMBER HALNON: Okay. So those are all  
10 adds on the original one.

11 MS. REID: Yeah, the last two bullets are.  
12 The first two bullets are consistent with Revision 1  
13 of the FSAR.

14 MEMBER HALNON: Okay, thanks.

15 MS. REID: In Section 5.2, integrity of  
16 reactor coolant pressure boundary -- reactor coolant  
17 boundary. Section 5.2 is where we describe code  
18 compliance and it's where we adopt the 2017 additions  
19 of the boiler and pressure vessel in the operation  
20 maintenance codes. In 5.2, we also describe RCS  
21 leakage.

22 And there is a change to the requirement  
23 for sensitivity of detection in Chapter 5. But our  
24 containment evacuation system itself, that equipment,  
25 and its capabilities didn't change. And there was no

1 change to the limits and tech specs for leakage.

2 Chapter 5 describes the reactor coolant  
3 pressure boundary. So we also describe the change  
4 from three to two reactor vent valves there as was  
5 previously discussed in the LOCA presentation. The  
6 setpoints and the design of the reactor safety valves  
7 had a change.

8 The setpoints increased with the design  
9 pressure. We also staggered those setpoints.  
10 Previously, they both had the same pressure.

11 We increased the minimum design capacity  
12 per valve. And for the design of the valve itself, we  
13 moved from pilot operated to spring operated. In  
14 SDAA, we added -- yes.

15 MEMBER HARRINGTON: This is Craig  
16 Harrington. For the reactor safety valves, the spring  
17 operated safety valves, have the designs of those, I  
18 guess, benefitted from the testing that was done after  
19 TMI, spring operated safety valves? A lot of testing  
20 done.

21 Obviously, these were 30 years on,  
22 whatever. And the same valves aren't available, and  
23 these were going to be smaller than legacy plants.  
24 But has knowledge gained from that testing been --

25 MS. REID: I know we made the change to

1 spring operated because they had better OE. But Brian  
2 Kanen is the one who can provide better context on  
3 that. Brian, are you on the line?

4 MR. KANEN: Yeah, I am here. The primary  
5 reason for going to the spring operated is it  
6 simplified the design and made it also smaller. It  
7 was more complex than it needed to be with the pilot  
8 operated valve.

9 We are currently working with a couple  
10 suppliers. But we haven't gone into the details of  
11 all the matter, I guess, with the testing of OE. We  
12 haven't selected -- we haven't downselected this  
13 specific supplier yet. So I can't speak on that  
14 exactly.

15 MR. CARDILLO: This is Augi Cardillo from  
16 NuScale. We have considered that as part of the valve  
17 design. And as part of the test regime, that will  
18 happen post -- all the testing will get done in  
19 accordance with the OM code, et cetera, and the design  
20 of the valve itself as we go with the vendors. So we  
21 are looking at that and we'll include that in our  
22 testing regime for the -- like the industry continues  
23 already.

24 MEMBER HARRINGTON: Okay. Thank you.

25 MS. REID: All right, continuing. In

1 SDAA, we added the containment isolation test fixture.  
2 And we also introduced some augmented examinations  
3 above and beyond what ASME requires for the valve  
4 bodies and the welds on the four chemical and volume  
5 control system lines.

6 And then the low temperature  
7 overprotection -- overpressure protection setpoints  
8 changed due to the material change in the lower RPV.  
9 And then last for 5.2, Table 5.2.3 is where we show  
10 the materials for the reactor coolant pressure  
11 boundary components and support materials. That table  
12 does look substantially different from DCA.

13 But it is more of a change in how we  
14 report the information than actual design changes to  
15 the components themselves. The biggest design change  
16 is easily the lower RPV material change to austenitic  
17 which is discussed further in Section 5.3. But in how  
18 we report that information, we added permissible  
19 materials to that table when an alternate material was  
20 ASME approved and acceptable.

21 We included it in that table to add  
22 flexibility for the COL applicant. And then we had  
23 some changes for consistency in completeness and  
24 response to audit questions. And we also reconciled  
25 our naming conventions with internal design documents.



1 So the names of some components changed in that table.

2 MEMBER HARRINGTON: This is Craig. You  
3 speak to maybe this afternoon the decision to change  
4 the lower vessel material. What drove that?

5 MS. REID: In the next slide --

6 (Simultaneous speaking.)

7 MS. REID: -- we have a discussion about  
8 it, yeah.

9 MEMBER BIER: I have another question,  
10 Vicki Bier. This has come up in some past meetings  
11 also. So it's not unique to this presentation.

12 But when you talk about increasing  
13 flexibility for alternate materials, how does that fit  
14 with the goal of standardization? How big could the  
15 cost pressure or other performance pressure be to  
16 require alternate materials? And would there be any  
17 safety or analytic impact, or you think they're really  
18 all equivalent?

19 MS. REID: We see it primarily as avoiding  
20 a departure in the COL if it's already a licensed  
21 material and agreed to be acceptable by NuScale and  
22 the staff. Erin, do you want to add any context to  
23 that?

24 MS. WHITING: This is Erin Whiting from  
25 NuScale. I would say that in addition to that,

1 everything is ASME approved. So we're not introducing  
2 any novel materials in this application.

3 So yeah, it's just to make sure that  
4 people have options. We have supply chain concerns,  
5 things like that. So that was really that and  
6 anticipating it.

7 MEMBER BIER: All right. Thank you.

8 MS. REID: Yeah, the next slide is Erin.

9 MS. WHITING: Hi, I'm Erin Whiting. I've  
10 been a licensee engineer at NuScale for about two  
11 years now. Prior to that, I had 15 years of  
12 analytical experience at Westinghouse.

13 Section 5.3 is the reactor pressure  
14 vessel. To Craig's point, we're going to discuss the  
15 material change for the lower RPV. We moved from  
16 ferritic steel to FXM-19 austenitic stainless steel  
17 mostly because it was a better material for fluence  
18 concerns.

19 This plays out into the PT limits report.  
20 The methodology we used is different because we don't  
21 have the beltline fluence concerns. We did for the PT  
22 limits report expand the COL Item 5.3-1 in response to  
23 audit.

24 And we took exemptions for 50.60 for  
25 fracture toughness, including Appendices G and H and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 also 10 CFR 50.61, pressurized thermal shock. There's  
2 superior ductility for the use of austenitic stainless  
3 steel. And it is less susceptible to the effects of  
4 neutron and thermal embrittlement which was really  
5 what informed that decision. And we do not have a  
6 material surveillance program requirement for Appendix  
7 H.

8 MEMBER BALLINGER: This is Ron Ballinger.  
9 I've mentioned this quite a few times. FXM-19, by the  
10 way, will crack in high temperature water.  
11 Temperature is much lower.

12 But all the documents I read justifying  
13 use -- and it's a code case too -- don't mention that  
14 at all. So I'll say it again. You ought to be a  
15 little bit cautious to make sure that you're not  
16 running yourself into trouble, especially with a weld.

17 MS. WHITING: Thank you. Are there any  
18 other comments on -- did I address your question?  
19 Okay. We also removed a COL item concerning onsite  
20 cleaning of the RPV during construction because that's  
21 covered under NQA-1. It was redundant.

22 We removed the flow diverter, and we  
23 changed the seismic restraint fixture which was a  
24 feature which was already discussed in Chapter 3.  
25 Next slide, please. In Section 5.4 which is RC

1 component and subsystem design, they outline the  
2 performance requirements of the decay heat removal  
3 system. We changed the size less for its -- sorry,  
4 more for manufacturing concerns and less about the  
5 actual performance of the system.

6 We do credit DHRS and safety analysis for  
7 containment peak pressure response to a loss of  
8 coolant accident in SDAA which is a change from DCA.  
9 We do address this in Chapter 5 as a result of the  
10 audit. We added details on the emergency core cooling  
11 system venting to limit hydrogen accumulation in the  
12 reactor pressure vessel during containment isolation.

13 And the DHRS meets the intent of SECY 94-  
14 084 by achieving a passively cooled safe shutdown  
15 condition within 36 hours. We added off-nominal cases  
16 at staff request during the audit for worst case DHRS.  
17 And we added details about the actuation valve  
18 accumulator pressure.

19 We also expanded a description of the  
20 steam generator supports as Wendy mentioned earlier.  
21 And we added descriptions of flow paths between the  
22 riser and the downcomer as a result of the audit. We  
23 also changed the description of the steam generator to  
24 plugging criterion due to bracketing the two plug-in  
25 value and technical specifications.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MEMBER HALNON:   So Erin, before you get  
2                   into the DWO discussion, I was talking to my  
3                   colleagues. And one of the things that we take great  
4                   comfort in is there's a lot of margin in this overall  
5                   design. But when you see things, like, going from  
6                   three to two valves, higher pressures, and stuff like  
7                   that, I just wanted to get it on the record for you to  
8                   all say that all those things that you did actually  
9                   either maintained or improved that margin or at least  
10                  sufficient margin. Let's say the same margin. But  
11                  can you make that statement in public that all these  
12                  changes did not eat away any of the margin in any  
13                  significant manner?

14                 MS. WHITING:   There's several --

15                 MEMBER HALNON:   It's a broad question.

16                 MS. WHITING:   Yeah, I was going to say  
17                  it's a broad question and it's also -- it's hard to  
18                  say that we didn't sacrifice any margin when we made  
19                  changes to the design.

20                 MEMBER HALNON:   Sufficient margin.

21                 MS. WHITING:   Yes.

22                 MEMBER HALNON:   And we took comfort in  
23                  from the standpoint of the overall NuScale design is  
24                  -- got a high level of margin just kind of  
25                  generically.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MS. WHITING: Yes, and I think throughout  
2 the FSAR, we're meeting the requirements and maintain  
3 margin limits for safety.

4 MEMBER HALNON: I just don't want people  
5 to misunderstand going from three to two, changing  
6 system pressures, and other things. You're not  
7 tightening up on this to the point where you're just  
8 barely acceptable. It's still --

9 (Simultaneous speaking.)

10 MS. WHITING: No, we optimize things to  
11 maintain margin and also we're meeting all the ASME  
12 code requirements in Chapter 5 as well.

13 MEMBER HALNON: I just wanted to get that  
14 out. Appreciate it.

15 MS. WHITING: Any other questions?

16 MEMBER HARRINGTON: This is Craig  
17 Harrington again. Just a question on the heat  
18 exchange -- heat removal, heat exchanger system.  
19 There's level instrumentation to look for the  
20 noncondensable gas, water interface.

21 But what does the operator do if they see  
22 that here or there? Is there any intended operator  
23 action in response to that? Or they just note that  
24 that's where it is and move on? You've analyzed  
25 presumably a limiting amount of noncondensable gas.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 But just kind of what does the operator do with that  
2 information other than write it down?

3 MS. WHITING: There's a DHRS operability  
4 technical specification which would be where we  
5 maintain that.

6 MEMBER HARRINGTON: Do they have the  
7 ability, like, crack the valve open and flow water  
8 through our steam through to sweep out the gases?

9 MS. WHITING: I think Ben Bristol can  
10 address that.

11 MR. BRISTOL: Sure. This is Ben Bristol  
12 with NuScale. So there's a couple of options.  
13 Certainly we can down power and do some maneuvering  
14 that way in order to bleed that.

15 The other option at power conditions,  
16 there's a certain pressure drop across the steam  
17 generator. So operators can actually optimize the  
18 pressure drop in such a way that they can bleed the  
19 DHRS side by cracking the valve open and causing  
20 reverse flow and recover the level once the  
21 noncondensable is filled up. Bleed it out through the  
22 steam system.

23 MS. WHITING: Does that address your  
24 question?

25 CHAIR KIRCHNER: Dennis, go ahead.

1 DR. BLEY: Yeah, I want to address a  
2 question to Ron because I nosed around just a little  
3 bit. I don't know much about FXM-19. And I saw  
4 something about cracking in a chlorine-rich  
5 environment.

6 What kind of temperatures, Ron, are we  
7 talking about? And what kind of cracking? NuScale  
8 hasn't really responded to your statements here. I'm  
9 just curious if you can fill the committee in a little  
10 bit on that history and what the problems might be.

11 MEMBER BALLINGER: It's -- FXM-19, it's  
12 basically a better stainless steel than 304 or 360.  
13 It's cracked in some environments, and I have a paper  
14 which I sent them. But the temperature is way higher.

15 It's in PWR steam generator temperatures  
16 which is lower -- which is higher than the NuScale  
17 steam generator temperatures. And the rule of thumb  
18 is they're probably closer to, let's just say,  
19 military applications for PWRs. And so while you can  
20 crack it and it has -- there have been instances of  
21 cracking at PWR, U.S. PWR temperatures, the lower  
22 temperatures at NuScale operates at mitigates against  
23 having the same problem, although I think they need to  
24 be aware of it, especially when you do welding on this  
25 stuff where you get very high residual stresses.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 DR. BLEY: Okay. That helps me a little  
2 bit. Thank you.

3 MEMBER BALLINGER: It's also known as  
4 Nitronic, I think, 50, yeah. And that's been used by  
5 --

6 DR. BLEY: Yeah, I saw that.

7 MEMBER BALLINGER: That's been used  
8 forever.

9 MS. WHITING: Next slide. And finally in  
10 Section 5.4, we address of the pillars of the DWO  
11 safety case. Both the real time monitoring and  
12 physical inspections are addressed in Chapter 5. For  
13 the DCA, the impetus of DWO is, as this body probably  
14 knows, there was a carve out that asked us to evaluate  
15 secondary site instabilities and also ensure steam  
16 generator integrity that was meant to -- that the COL  
17 applicant has to address that for the US-600 design.

18 We removed that COL item for SDAA. And  
19 our initial intent was to use the inlet flow  
20 restrictor to say that DWO is precluded across all  
21 operation. As we moved through the SDAA and gathered  
22 more information about DWO, we decided that, well, we  
23 couldn't preclude DWO throughout operation.

24 And so we used real time monitoring which  
25 is an approach temperature that's discussed in Section

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 5.4. There's a figure and a description of what it  
2 is. The use of safety signals ensures that we know  
3 when we are likely to have DWO.

4 And then there's a lifetime limit as was  
5 discussed in Chapter 3. And we ensure that the steam  
6 generator integrity is insured throughout that  
7 lifetime limit. We also added extra inspections for  
8 the steam generator tubes and the inlet flow  
9 restrictors to ensure that we are aware of degradation  
10 occurring. And we added a loss coefficient range as  
11 part of the audit because of audit questions where it  
12 made it easier for the staff to review exactly what  
13 that particular performance the IFR would be doing.

14 CHAIR KIRCHNER: So Erin, because of the  
15 approach temperature concept that you're using to kind  
16 of (audio interference) most of the operating range to  
17 ensure that you don't get into these DWO situations,  
18 does that then get reflected in tech specs somehow?

19 MS. WHITING: Yes. The requirement for  
20 the cyclic and transient limits in Chapter 3 are in  
21 Tech Specs 543, I believe. And Tech Specs 544 has the  
22 steam generator program which is the inspection  
23 requirements --

24 (Simultaneous speaking.)

25 CHAIR KIRCHNER: Yeah, so those are kind

1 of -- how should I say it -- not something that you --  
2 that's something you monitor and inspect for after  
3 service. But during normal operation, is there a tech  
4 spec that requires that within a certain power  
5 operating profile that approach temperature has to be  
6 such and such?

7 MS. WHITING: Yes, there are regions that  
8 we'll discuss in the closed session. And actually in  
9 the FSAR, the Figure 5.4-16, I believe, has a region  
10 where DWO is precluded during operation and also a  
11 region where you could count time in DWO.

12 CHAIR KIRCHNER: Would the operator then  
13 have that figure or something equivalent, much like  
14 you have pressure, temperature limits and you operate  
15 within that band when you're operating a PWR like this  
16 design? Would there also be then some kind of tech  
17 spec operating limit somehow that the operator -- some  
18 reincarnation of that or --

19 MS. WHITING: There's no restriction on  
20 operating with DWO. We're just counting time in DWO  
21 in Chapter 3 and through those tech specs. And it's  
22 5.5.3 and 5.5.4. I misspoke. I apologize. So it's  
23 not like a pressure-temperature limit where you have  
24 to stay under the curve for operation. It's not an  
25 LCO.

1 CHAIR KIRCHNER: You wouldn't -- why would  
2 you not have an LCO for the operators that check that?  
3 You had sufficient -- I'll call it subcooling or  
4 temperature difference between the main average  
5 coolant temperature and in that water inlet  
6 temperature.

7 MS. WHITING: So the limit of time in DWO  
8 for the lifetime of the NPM is 2,840 days. So it's  
9 over six years. And we can show that the steam  
10 generator integrity is maintained over that period.

11 So there's, first of all, not a safety  
12 concern saying we can't operate there until we hit  
13 that limit. Then we would not be able to. Does that  
14 answer your question?

15 CHAIR KIRCHNER: Yes and no. I'm just  
16 thinking from an operator standpoint, yes, we can go  
17 through the cycle and have some confidence that we're  
18 not going to eat up our margin in terms of fatigue and  
19 vibration and wear and so on. But that's something  
20 you inspect for after, say, a refueling cycle or  
21 whatever. But as the operator, what guidance is out  
22 there to the operator to support this safety case?

23 MS. WHITING: The operator would be  
24 counting time in DWO against the tech specs limits for  
25 the cyclic and transient operations. So that's a

1 normal thing that operators do. So they'd be counting  
2 time in DWO to ensure that they're not hitting the  
3 2,840 days.

4 CHAIR KIRCHNER: How would they measure  
5 time in DWO while you're operating the plant? I get  
6 the shutdown you inspect and all the rest. And you've  
7 done analysis to show you're not eating up the margin  
8 in terms of structural integrity. But what does the  
9 operator do with this?

10 MS. WHITING: So they would evaluate the  
11 approach temperature. And if they're above the limit  
12 where they have to count time, they're fine. There's  
13 really no chance of DWO in that operating space. When  
14 they're below the curve, they would count time in DWO  
15 against the cyclic limits in Chapter 3.

16 CHAIR KIRCHNER: Okay. So they're  
17 counting time. But that suggests to me then there's  
18 a tech spec that somehow they're monitoring at  
19 temperature and --

20 (Simultaneous speaking.)

21 MEMBER HALNON: Yeah, this is Greg. The  
22 tech spec or if you will those limits could be not in  
23 days. But you have an operating curve that they'll  
24 probably be operating their plant to.

25 And they're in the region of concern. A

1       ticker will go off, probably automated to some extent  
2       I would imagine. And then when they get above it, the  
3       ticker stops. And at the end of the day, you say,  
4       okay, I added one day to the 200,000, whatever hours  
5       I can have. So my sense is it's an operating curve  
6       that applies towards a limit, whether it be in tech  
7       specs or a safety limit, whatever the case may be.

8               MS. WHITING: Yes, and so --

9               MEMBER BALLINGER: This is not unlike  
10       counting fatigue cycles in PWRs. And yeah, it's the  
11       same concept.

12              CHAIR KIRCHNER: No, I get that part. I'm  
13       just in my own sense of operating a plant and you have  
14       the peak heat curves you typically use. There would  
15       be some three dimensional plot that shows steam  
16       generator feedwater inlet temperature versus --

17              MS. WHITING: That's not one of the  
18       parameters. The approach temperature is the  
19       difference between RST hot and being steam  
20       temperature.

21              CHAIR KIRCHNER: Yeah, I'm sorry. I  
22       misspoke. So yeah, main steam exit. So anyway, in my  
23       mind for an operator, that's something that they would  
24       be monitoring.

25              MS. WHITING: Yes. I guess the cyclic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 limits in Tech Spec 5.5.3.

2 MR. BRISTOL: This is Ben Bristol. So a  
3 little context to how we anticipate this folding into  
4 the operational scheme. We will have control systems,  
5 and we'll get into in the closed section.

6 But we're planning to define the operating  
7 path of the steam generator a long way from where the  
8 limit is. As Erin kind of mentioned, we view the --  
9 the concern is mostly being a long term accumulated  
10 degradation type concern. Therefore, we don't  
11 necessarily want operators immediately responding to  
12 space where we're getting close or may dip into that  
13 region.

14 That's something that can be analyzed on  
15 the back end. So it's not something that is acutely  
16 important to safety and something that operators  
17 should be worried about. But we will devise control  
18 systems that maintain a level of margin and keep the  
19 steam generator controlled in the stable zone, the  
20 Region 2.

21 MS. WHITING: And we'll discuss this more  
22 in closed session --

23 (Simultaneous speaking.)

24 CHAIR KIRCHNER: Thank you.

25 MS. WHITING: And I believe that concludes

1 our open presentation. Are there any further  
2 questions?

3 CHAIR KIRCHNER: Members? Okay. Thank  
4 you very much, Wendy and Erin. And we'll just pause  
5 here a moment and ask the staff to come forward.

6 MR. DRUCKER: Hey, Mike Snodderly. Can  
7 you see the screen? I'm sharing my screen right now.

8 MR. SNODDERLY: Yes, we can see your  
9 screen. Can you make it presentation mode?

10 MR. DRUCKER: Yes.

11 MR. SNODDERLY: That's good thank you.  
12 Yes, better.

13 CHAIR KIRCHNER: Okay. Who's going to  
14 lead off for the staff?

15 MR. DRUCKER: I am. Good morning. My  
16 name is David Drucker. I'm a senior project manager  
17 in the new reactor licensing branch at NRR and the  
18 lead project manager for the Chapter 5 review.

19 This slide shows the main contributors for  
20 the review of Chapter 5. And names in shown in blue  
21 are today's presenters. The NRC staff completed the  
22 review of Chapter 5 and issued an advanced safety  
23 evaluation to support this ACRS subcommittee meeting.

24 There are no significant changes between  
25 the draft safety evaluation provided to ACRS on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 January 4th and the safety evaluation published on  
2 January 29th. There are four sections that constitute  
3 Chapter 5. And the remainder of this briefing will  
4 focus on the deltas between the design certification  
5 and the SDAA. Next up is Nick Hansing.

6 MR. HANSING: My name is Nicholas Hansing.  
7 I'm a mechanical engineer.

8 MR. DRUCKER: (Audio interference.)

9 MR. HANSING: Excellent, thank you. My  
10 name is Nicholas Hansing. I'm a mechanical engineer  
11 in the Mechanical Engineering and In Service Testing  
12 Branch. I've been with the NRC for over ten years.

13 Again, Section 5.2.1 which is compliance  
14 with the codes and standards rule and SME code cases.  
15 Significant differences between the DCA and the SDAA  
16 include the particular codes of record that are used  
17 as discussed in the NuScale presentation. They use  
18 the 2017 edition as opposed to the earlier editions  
19 that were for the DCA.

20 Additionally, the selection of ASME Code  
21 Cases that used are different in this application.  
22 However, they are all accepted for use in the  
23 appropriate NRC regulatory guides. The conclusions  
24 remain the same for the SDAA as compared to the DCA.

25 There are no matters to discuss for 5.2.2,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 5.2.4, or 5.2.5. So my next slide will be on 5.2.3.  
2 This is the reactor coolant pressure boundary  
3 materials.

4 As we heard earlier from NuScale, the  
5 materials have changed. They're outlined here. NRC  
6 has found them acceptable for the particular  
7 applications.

8 They're compatible and suitable for the  
9 intended use. And the conclusions remain the same  
10 between the DCA and the SDAA. That concludes the 5.2  
11 slides.

12 MEMBER PALMTAG: This is Scott Palmtag.  
13 So you mentioned the FXM-19 looks just fine for this  
14 application. And Ron says there may be issues with  
15 cracking. So how do you reconcile this?

16 MR. HANSING: I will note I am a  
17 mechanical engineer, not a materials engineer for  
18 this. So I'm going to turn to my colleague here.

19 MR. WIDREVITZ: We'll discuss that more in  
20 5.3 --

21 MEMBER PALMTAG: Okay.

22 MR. WIDREVITZ: -- which is next.

23 MEMBER HARRINGTON: This is Craig  
24 Harrington. One quick comment. In the version of the  
25 SER that I reviewed, it still speaks to the reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 safety valves as pilot operated. Does that mean  
2 updated to spring operated?

3 MR. TESFAYE: This is Getachew Tesfaye.  
4 Yes, those have been changed to spring valves. They  
5 put that in the final version and change it to spring  
6 operated.

7 MR. DRUCKER: Dan, are you ready? Next  
8 slide?

9 MR. WIDREVITZ: Take it forward to 5.3.  
10 All right. Section 5.3 is focused on materials,  
11 ensuring aspects of the reactor vessel itself. The  
12 significant differences between the DC and SDAA were  
13 principally the use of FXM-19 austenitic stainless  
14 steel for the lower reactor vessel. Also, there were  
15 several exemptions, 6 and 15. The slides are correct  
16 here from the ferritic steel requirements which are  
17 inapplicable to austenitic stainless steel through the  
18 material change.

19 These generally interact with requirements  
20 of 10 CFR 50.60, 10 CFR 50.61, and 10 CFR 50  
21 Appendices G and H which don't apply to austenitic  
22 stainless material. So we had to find a way of  
23 syncing that back up which the applicant did for their  
24 exemptions. Also, you'll notice that there's a fairly  
25 large COL item, 5.3-1 which is partially transcribed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 here on the slide.

2 That gets to a number of remaining details  
3 that would have to be verified at the COL stage versus  
4 the information that was available during the SDAA  
5 review. Next slide, please. So if we went two slides  
6 --

7 MEMBER BALLINGER: Can you go back a  
8 slide?

9 MR. WIDREVITZ: So the NuScale SDAA SE  
10 conclusion is different from the DCA generally because  
11 of the material change for the lower RPV.  
12 Consequently, there's a whole discussion of exemptions  
13 that do not exist in the design certification  
14 application. In addition, there are some differences  
15 in how pressure-temperature limits methodology was  
16 constructed and reviewed. Next slide, please. I'll  
17 take a significant pause.

18 MEMBER BALLINGER: This is Ron Ballinger  
19 again. I'm going to keep pounding this dead horse.  
20 2017 version of the ASME code, now I've got to  
21 remember whether that's true or not. If you go from  
22 2017 to 2019 version of the code, there are changes  
23 related to API 579 and 580, including it's called FM-  
24 1.

25 These numbers that require you to deal

1 with environmental effects which didn't -- which were  
2 required in past times. So I'm curious as to whether  
3 -- I don't see anything in there in the SE and  
4 everything that says other than the issues, the  
5 difference between stainless steel and ferritic steel  
6 with respect to embrittlement and those kinds of  
7 things. There's nothing in there where it said did  
8 you look at environmental effects and did you  
9 disposition those environmental effect possibilities  
10 and the reasons for doing that.

11 MR. WIDREVITZ: Well, I can't speak  
12 directly to that because that is the 2019 edition.  
13 That's talking off the top of my --

14 MEMBER BALLINGER: Well, we're talking  
15 about --

16 MR. WIDREVITZ: I'll try and answer you in  
17 a technical way which is moving to FXM-19 is totally  
18 unique because everyone else is using these  
19 traditional OLI ferritic steels, right? Clad with  
20 stainless, nobody is making a vessel in our commercial  
21 industry yet until NuScale does out of Nitronic 50.  
22 So what we did do is we tried to conduct a -- I'll  
23 call it thorough, you can debate that term. We try to  
24 conduct independent literature research. And also  
25 quite a bit of information was provided by the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 applicant as part of their support for the exemptions.

2 And so we were looking for things like how  
3 does it age, particularly the temperatures of  
4 interest, right? Now we know that austenitic  
5 stainless steel is obviously going to be better in  
6 corrosion properties. It's a lot more tough than  
7 ferritic materials that use vastly more fluence before  
8 you can measure any effects in terms of toughness,  
9 right? And we were looking to verify those through  
10 essentially literature review, and that's what we did.

11 MEMBER BALLINGER: Yeah, I mean, and  
12 that's perfect. All I'm saying -- that's perfect.  
13 All I'm saying is, is that there's not much mention in  
14 there of the potential for environmental effects which  
15 I just didn't see it.

16 MR. WIDREVITZ: Yeah, we don't --

17 MEMBER BALLINGER: So --

18 MR. WIDREVITZ: -- specifically address  
19 that, no.

20 MEMBER BALLINGER: Yeah, but that's not  
21 necessarily a good thing.

22 MR. WIDREVITZ: If the -- if our  
23 literature indicated aging considerations, you'd bet  
24 they'd be in there.

25 MEMBER BALLINGER: I'm sitting on my desk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 in my office here. Okay, thanks.

2 MR. WIDREVITZ: I can only speak to what  
3 we did and I don't have my time machine handy. So  
4 that brings us to the pressure-temperature limits  
5 methodology itself. There were a lot of significant  
6 differences mainly because of the change in material.

7 And I think from a -- I'm going to say the  
8 words that might get folks excited -- fracture  
9 mechanics standing, changing to austenitic stainless  
10 steel gives you a lot of advantages. And that sort of  
11 change where you're interested in looking in terms of  
12 pressure-temperature limits where you're limiting  
13 locations are change from what is traditionally  
14 ferritic materials are outlined where you're receiving  
15 a lot of fluence just near the fuel and lower reactor  
16 pressure vessel to some sort of geometric  
17 discontinuity where there's a stress riser in the rest  
18 of the power module. And so that was quite a big  
19 difference in pressure-temperatures.

20 It's in some sense more robust design  
21 which makes verification pressure-temperatures just  
22 move to a more sophisticated analysis question but not  
23 necessarily a riskier question. So with that, the  
24 SDAA design is never beltline limited in the lower  
25 reactor pressure vessel. That's very different from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 every other design that's operating in the fleet.

2 The pressure-temperature limit curves are  
3 limited by geometric discontinuities and locations  
4 where potentially no neutron embrittlement. The aging  
5 of those thermal and neutron is going to be  
6 inconsequential based on our review relative to what  
7 you'd expect from limiting locations in a traditional  
8 design. And of course, there's this enlarged COL item  
9 5.3-1 with a lot of details that need to be verified  
10 because the location of interest is very different and  
11 how it interacted with the information and the various  
12 things that were presented for our review.

13 So ultimately, the SDAA SE conclusion is  
14 different from the DCA, not because of anything  
15 necessarily more risky or safety considerations but  
16 just how the whole case and the details that need to  
17 be validated for the COL stage are different from what  
18 you'd expect from all of the other designs. And  
19 that's a bad thing. That concludes my slides for 5.3.  
20 I'll take a significant pause here.

21 MEMBER PALMTAG: Scott Palmtag. I didn't  
22 really hear an answer to that question. Is there a  
23 cracking issue?

24 MR. WIDREVITZ: Not that I'm aware of,  
25 though I would love to see that paper because I did



1 not find it.

2 MEMBER BALLINGER: So let it be written,  
3 so let it be done.

4 (Laughter.)

5 CHAIR KIRCHNER: Okay.

6 MR. WIDREVITZ: Next up is Greg Makar.

7 CHAIR KIRCHNER: Go ahead, Greg.

8 MR. MAKAR: My name is Greg Makar. I'm a  
9 materials engineer in the Division of New and Renewed  
10 Licenses and Corrosion and Steam Generator Branch.  
11 And I'd like to thank and acknowledge my coworker on  
12 this review, Leslie Terry, also in Corrosion and Steam  
13 Generator Branch, and also a reviewer for the thermal  
14 hydraulics area for the approach temperature limits,  
15 Tim Drzewiecki, who's in the senior reactor systems  
16 and engineer in the Division of Advanced Reactors and  
17 non-power production and utilization facilities.

18 The regulatory basis for our review  
19 focuses on the integrity and the inspection of the  
20 reactor coolant pressure boundary. Staff reviewed  
21 FSAR Section 5.4.1 in accordance with the design  
22 specific review standard, Section 58.21, to ensure the  
23 integrity of steam generator materials is maintained  
24 and that the steam generator materials meet the  
25 relevant regulatory requirement. We also reviewed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Sections 5.4.1 and 5.4.1.6 in accordance with the SRS  
2 Section 5.4.2.2 to ensure the steam generator is  
3 designed to permit periodic inspection and testing of  
4 the tubes and other critical areas and that it  
5 includes features to assess structural and leakage  
6 integrity of the tubes.

7 And we also reviewed the tech specs and  
8 bases as they relate to incorporating the steam  
9 generator program. This slide focuses on the  
10 differences from certified design that we consider  
11 most significant. I'll start with the inlet flow  
12 restrictors.

13 These are a different design in that they  
14 -- in the certified design, they were -- the flow was  
15 around the restrictor. Now it's through a central  
16 orifice. And there's now contact with the inside  
17 surface of the tube.

18 But the materials are 300 series  
19 austenitic stainless steel. They're compatible with  
20 the secondary coolant. Although the new design  
21 involves contact with the tube, there are design  
22 features designed to prevent it from coming loose and  
23 becoming a source of loose parts in the tubes or from  
24 damaging the inside of the tubes.

25 They will be inspected visually during

1 steam generator tube inspections or cavitation. And  
2 based on the IFR design, those materials approved by  
3 ASME code, compatible with the environment and  
4 features to prevent tube damage and the proposed  
5 periodic inspections, staff found this design  
6 acceptable with respect to tube integrity. Added to  
7 the steam generator program, combined license item  
8 5.4-1 is additional inspections in between the first  
9 -- the inspection of the first refueling outage which  
10 is 100 percent of the tubes.

11 And the next inspection that's required in  
12 the tech specs which is no tube can go beyond 72  
13 effective full-power months. There's an addition of  
14 at least 20 percent of the tubes being inspected at  
15 each refueling outage for the first module to undergo  
16 a refueling outage. This was introduced in the  
17 context of density wave oscillations, DWO.

18 But it's a good idea regardless of whether  
19 DWO is a concern. Without operating experience early  
20 in life, it's more difficult to assess the  
21 significance of tube degradation or the lack of tube  
22 degradation. And so these additional inspections will  
23 be valuable for understanding the form and rate of  
24 degradation that's needed for condition monitoring and  
25 the forward looking operational assessment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           And it's also -- I also want to mention  
2           these are primarily performance-based tech specs that  
3           are required to maintain tube integrity. So we really  
4           can't say going in when the second inspection will be.  
5           But it's -- because it's going to depend on the  
6           findings of the first inspection. But we know that  
7           there will be at least this minimum amount of  
8           inspection in the subsequent inspections to the first.  
9           And so we find these as an acceptable way to address  
10          the uncertainty early in life of the steam generators  
11          and to help ensure integrity is maintained.

12                 MEMBER HALNON:     Greg, this is Greg.  
13          Outside of the tubes, you mentioned visual. Is that  
14          the expectation is that there'll be a comprehensive  
15          visual inspection on the outside of the tubes  
16          supports?

17                 MR. MAKAR:     Well, I'm not sure any --  
18          their comprehensive visual inspection is very  
19          difficult in steam generators on the outside because  
20          of the proximity of the tubes to one another.  
21          Normally, there are lanes without tubes installed,  
22          these long vertical passes that they have in  
23          traditional steam generators. So there are -- you can  
24          put cameras in and look into this. The expectation is  
25          that they'll do that, tube sheets and where they can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 at supports. But I'm not sure there's a way to look  
2 -- I'm not sure it would be possible to look  
3 everywhere.

4 MEMBER HALNON: I guess -- so we're going  
5 to rely on eddy current through the tubes to tell us.  
6 If we are seeing any kind of flow issues between the  
7 outside of the tubes, you may not see those after only  
8 one cycle. So my question is, you think the 72 month  
9 -- it was 72 long months -- do you think that's going  
10 to be adequate to prevent any kind of failures if  
11 there is something starting to occur?

12 MR. MAKAR: I think not 72 months alone.  
13 I think that's the importance of this. Well, there's  
14 the first outage where 100 percent of the tubes.

15 And then the tech specs say you could go  
16 up to 72 effective full-power months until your next  
17 inspection provided that you have an operational  
18 assessment to support that. It's not automatic. Now  
19 with this first module having additional inspections  
20 at 36 months, 54 months, 72 months, then it gives you  
21 some more -- a better idea of what -- if there's  
22 nothing happening.

23 That's one of our concerns is that nothing  
24 happens in the first cycle. And then it looks like  
25 nothing is going to happen forever. And this helps to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 prevent that scenario. And I would say the COL item  
2 also has subsequent modules. The COL applicant will  
3 have to justify if they believe at that 20 percent  
4 doesn't apply to them.

5 MEMBER HALNON: We've heard earlier that  
6 the subsequent modules will be treated as prototypes  
7 until such time that the first modules proves it's an  
8 adequate prototype. I'm kind of paraphrasing. How's  
9 that going to work with this scheme?

10 MR. MAKAR: As far as I know, that  
11 prototype system does not affect this tech spec  
12 program.

13 MEMBER HALNON: It's only the CVAP, not  
14 the inspection portion. I'll have to think on that.  
15 Thanks.

16 MR. MAKAR: And one scenario for the  
17 outside of the tubes is sometimes you -- if there's --  
18 of course, we're looking for -- and a very common  
19 thing to see is where from support structures. But  
20 there's also where it could occur from a loose part or  
21 a foreign object. And sometimes those are protected  
22 from the inside with eddy current.

23 MEMBER HALNON: Yeah.

24 (Simultaneous speaking.)

25 MEMBER HALNON: -- that all bets are off.

1 You're going to find it --

2 (Simultaneous speaking.)

3 MR. MAKAR: And then you have a targeted  
4 area where you can try to get a camera in and see  
5 what's going on.

6 MEMBER HALNON: Okay, thanks.

7 DR. SCHULTZ: Greg, this is Steve Schultz.  
8 The inspection program is described in a number of  
9 different places now. And in one place, I thought I  
10 saw that there was a pre-operational inspection, a 100  
11 percent inspection, pre-operational so that when you  
12 perform that first 100 percent inspection after the  
13 first outage that you would know that something had  
14 changed, not that something was wrong because you've  
15 done it pre-operational.

16 MR. MAKAR: Yeah, or pre-service  
17 inspection --

18 DR. SCHULTZ: Pre-service.

19 MR. MAKAR: -- PSI. That's done after the  
20 tubes are installed and after hydrostatic pressure  
21 testing has been performed, either in the shop or in  
22 the field. So you get that look at any flaws in the  
23 tubes or imperfections in the tubes before they go on  
24 the surface.

25 DR. SCHULTZ: Then I thought I saw

1 something that suggested that if you're performing a  
2 20 percent inspection anywhere in the process and you  
3 find something, then your inspection program is  
4 advanced. In other words, you need to look in other  
5 areas right away. Is that true?

6 MEMBER BALLINGER: I think that's a  
7 Section 11 requirement, right?

8 MR. MAKAR: I don't know. The industry  
9 does have guidelines for how to expand the scope of  
10 the --

11 (Simultaneous speaking.)

12 DR. SCHULTZ: Okay.

13 MR. MAKAR: And the details of the 20  
14 percent, I'm sorry, I don't remember. But yes, there  
15 are in the steam generator program the industry  
16 framework. There are expansion guidelines. And  
17 that's the expectation here. And that's why I say we  
18 can't say for these steam generators any for sure when  
19 a second 100 percent inspection would occur because it  
20 depends on what they find in that first inspection.

21 DR. SCHULTZ: Okay. That's fair. I think  
22 we've got another presentation that's going to come  
23 back to this. Thank you.

24 MR. MAKAR: Okay. The next topic was  
25 changes in the technical specifications. There's one



1 that is a change in the structural integrity  
2 performance criterion. The structural integrity  
3 performance criterion include a safety factor on  
4 primary, secondary pressure differential for normal  
5 steady-state full-power operations which is the most  
6 limiting of the criteria for NuScale. This is -- for  
7 conventional steam generators, this is a factor of 3.0  
8 for burst because higher pressure is on the inside.

9 And that was also used for NuScale in the  
10 DCA, although they applied it to collapse or external  
11 pressure. But NuScale is -- the thickness of the  
12 tubes are determined by the ASME code case and 759-2.  
13 And that allows a stress reduction factor of 1.7 to  
14 2.0, so lower than 3 for externally pressurized  
15 cylinders.

16 That's not different. That code case was  
17 also used for the DCA. But they didn't make use of  
18 that provision for the lower safety factor. So  
19 they're doing that now, but they're not taking any  
20 exceptions.

21 That's the code case approved by the NRC  
22 without conditions. It's consistent with some other  
23 parts of the ASME code such as pressure vessel design.  
24 So the staff finds this acceptable based on being  
25 designed in accordance with the approved code case

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with no exceptions and because the other safety  
2 factors and structural integrity performance criterion  
3 were not changed.

4 MEMBER BALLINGER: I have sort of a  
5 technical question which it may have been addressed in  
6 the B&C. These are externally pressurized tubes. And  
7 there's this 40 percent through-wall requirement which  
8 is basically for original other internally pressurized  
9 tubes.

10 And it's for environmental degradation.  
11 Now the issue you're going to have is not that. It's  
12 wear. So if you have 40 percent through-wall wear,  
13 does that affect the collapse criteria? Is that  
14 safety factor in the ASME code that allows you to  
15 reduce the differential pressure on everything, if you  
16 had a 40 percent through-wall region now, wear region,  
17 would that affect the collapse criteria? Because it's  
18 really collapse, not rupture.

19 MR. MAKAR: Well, I'm glad you asked about  
20 that because the 40 percent plug-in criterion has not  
21 changed from the DCA.

22 MEMBER BALLINGER: Yeah, that's what I was  
23 thinking.

24 MR. MAKAR: And it's a bracketed value in  
25 the technical specification which means a COL

1 applicant has to either justify its use or justify  
2 something else. But what's different, and the reason  
3 I'm presenting it on the slide, is that the -- it's  
4 based on a new analysis. Now the 40 percent widely  
5 used in the industry is a value that's found to be  
6 bounding. And it is thinning around the tube from the  
7 outside. So that's limiting over --

8 (Simultaneous speaking.)

9 MEMBER BALLINGER: It's the volumetric  
10 criteria.

11 MR. MAKAR: Yes, yeah, yeah. And so they  
12 apply that same -- the same concepts that were used  
13 and the same approach that's used in the determination  
14 of the plugging criterion here when operating plants  
15 look at that because the thinning is coming from the  
16 -- still coming from the outside.

17 MEMBER BALLINGER: I'm just wondering  
18 about the collapse criteria.

19 MR. MAKAR: Well, and NuScale has  
20 performed an analysis, looking at those criteria,  
21 looking at the different loading conditions. And with  
22 thinning what they expect to be the most likely  
23 location of where in the dimensions they expect that  
24 wear to take. And then they performed an analysis --  
25 finite element analysis to calculate the collapsed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 pressure.

2 MEMBER BALLINGER: We're kind of using a  
3 set of rules that were designed for one configuration  
4 and applying it to a different configuration.

5 CHAIR KIRCHNER: Greg, isn't the wall  
6 thickness or wall thinning allowance different than  
7 the crack depth allowance?

8 MR. MAKAR: Cracks are normally not  
9 allowed to stay in service because of the difficulty  
10 sizing them and evaluating them. There are some  
11 exceptions. But in this case, NuScale did look at  
12 cracking.

13 It's hard for them to get -- they've  
14 looked at conditions where they could potentially get  
15 a tensile stress in the presence of different types of  
16 cracks and found that this thinning is still bounding.  
17 And cracks will be -- would be plugged on to (audio  
18 interference) for protection. And in looking at this  
19 plugging criterion, the staff, we reviewed NuScale's  
20 analysis.

21 We also performed some calculations of our  
22 own based on our relationship between yield stress and  
23 geometry from collapsed tests that were performed at  
24 Pacific Northwest Laboratories years ago. And we had  
25 -- during the DCA review, we had a finite element

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 analysis support to justify using that data, applying  
2 that data for a collapsed test on Alloy 600 to Alloy  
3 690. So our calculations indicate that they can  
4 maintain this factor of 2.0 when we looked at more  
5 wall thinning than in their analysis.

6 CHAIR KIRCHNER: And Greg, that also  
7 includes the higher operating approach?

8 MR. MAKAR: Yes, yes. So for those  
9 reasons, we found that 40 percent bracketed through-  
10 wall. Plugging criterion and a reasonable preliminary  
11 value is that COL applicant will have to justify that.  
12 Next slide, please. And so the next slides are on the  
13 density wave oscillations and our staff's evaluation  
14 of approach temperature limit.

15 The definition and use and the definition  
16 of approach temperature is here which is the  
17 difference between the reactor coolant system hot  
18 temperature and the exit temperature from the steam  
19 generators. And so the review focused on whether this  
20 approach temperature limit is a way to protect against  
21 the onset of -- the effects of the onset of DWO. Next  
22 slide, please. This is an organization chart to show  
23 how our review was organized.

24 See the main questionnaire is -- the goal  
25 of the evaluation, the finding we were seeking to make

1 is whether the approach temperature provides  
2 reasonable assurance or protection against the onset  
3 of DWO, not to -- not a finding on that DWO onset  
4 itself is accurate predicted. So a little different  
5 there. The next two slides have more information  
6 about three of these four topics.

7 You see that there are different elements  
8 identified for each topic. For the third one, static  
9 instability coupling, staff determined that no  
10 detailed review was necessary for that one. And then  
11 on the last slide, it summarizes the conclusions.  
12 Next slide, please.

13 This has two topics. They're not in  
14 order. I think that probably because they fit on the  
15 slide well in this configuration. But this first  
16 topic is whether there is margin between the  
17 approached temperature limit and calculations of DWO  
18 onset.

19 And there's a table added to in the SER  
20 that lists the five parameters and compares operating  
21 range to the analysis range. And this shows that  
22 there were different elements. This shows the  
23 elements that were applied to this review area, 1.1,  
24 the approach temperature.

25 And we'll get back to the second one, 1.2

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 on the next slide. But here, 1.4 address the  
2 uncertainties and whether the uncertainties in -- if  
3 we look at risk associated with DWO onset, are they  
4 reasonable? The uncertainty and the prediction of DWO  
5 onset, are they reasonable considering the risk  
6 associated with DWO? And there are these four  
7 elements that we looked at in our review. Next slide,  
8 please.

9 DR. BLEY: This is Dennis Bley.

10 MEMBER DIMITRIJEVIC: I have a question  
11 about risk associated with the DWO. This is Vesna  
12 Dimitrijevic. So my question is, did you -- what the  
13 sensitivity performed for these estimates? Well, when  
14 you risk is small, is this risk associated with DWO  
15 was evaluated to be small?

16 MR. MAKAR: When we speak of risk in this  
17 part of our -- in this safety evaluation section, I  
18 think it refers to the risk that was determined --  
19 associated with the failure of a tube which we're not  
20 presenting that here. But I think it's risk  
21 associated with tube failure.

22 MEMBER DIMITRIJEVIC: Well, so my question  
23 is related to this. This is just associated with a  
24 frequency of estimated steam generated tube failure.  
25 It's not associated with the number of the tubes which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       assume fail or the likelihood that those tubes can be  
2       in both steam generators.

3               MR. MAKAR: I don't think so. But I don't  
4       know. I'm sorry. I didn't -- I wasn't -- I didn't  
5       perform the review. So I think we can --

6               MR. TESFAYE: This is Getachew Tesfaye.  
7       So risk associated with the failure of steam generator  
8       is discussed in Chapter 19.

9               MEMBER DIMITRIJEVIC: And --

10              (Simultaneous speaking.)

11              MEMBER DIMITRIJEVIC: Yeah, finishing the  
12       Chapter 19 and then how they address in Chapter 19 is  
13       different than where we discussed the phenomena. So  
14       this is why I want to bring it here because in the  
15       Chapter 19, already DWO was considered, is shown to be  
16       unsensitive to frequency or steam generator tube  
17       failures, approximation. However, there is no  
18       analysis of the sensitivity to map out the tubes  
19       assume fail.

20              So in the risk analysis, it's assumed that  
21       only one tube is fail and it's only in the steam  
22       generator. So I was really -- my question was, was it  
23       considered that this DWO could affect this -- the DWO  
24       consideration will affect those assumptions. That was  
25       my question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. TESFAYE: This is Getachew again. I  
2 believe that will be addressed in Chapter 19. We just  
3 take advantage of the results in Chapter 19 to justify  
4 the DWO condition here. There's no specific risk to  
5 my knowledge. We can get back to you on that.

6 MEMBER DIMITRIJEVIC: I understand this,  
7 Getachew. I just want to say using this as one of the  
8 things which makes you feel more sure that this issue  
9 can be closed. But this is without looking and what  
10 assumptions were done.

11 So I mean, the Chapter 19 would not  
12 address the closure of DWO issues. Chapter 19 is  
13 separate thing. So I just thought it will make sense  
14 to bring it here. But it's all right. Chapter 19 is  
15 coming in two weeks. So we will look in it.

16 MR. SNODDERLY: Mr. Chairman, I think  
17 someone from -- Tom Griffith from NuScale would like  
18 to speak.

19 MR. GRIFFITH: This is Tom Griffith from  
20 NuScale. I think Sarah Bristol can add a little  
21 context here. I do think it's appropriate maybe to  
22 talk of 19. But I think now is a fine a time as any  
23 to talk a little bit about one of the audit responses  
24 that we have related to, I think, this question. So  
25 Sarah, can you step in?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MS. BRISTOL: Yes, this is Sarah Bristol,  
2 manager of PRA. Can you hear me?

3 MEMBER DIMITRIJEVIC: Yeah.

4 (Simultaneous speaking.)

5 MS. BRISTOL: All right. Hi, Vesna. Yes,  
6 we did get three audit questions related and  
7 supporting this DWO topic. Ultimately, as you know,  
8 we do look at the single tube failure in our PRA in  
9 Chapter 19.

10 But ultimately, we did do and look at  
11 additional failures or other potential considerations  
12 because of DWO. And so ultimately, we do a  
13 sensitivity in 19 where we increase the initiating  
14 event frequency. So therefore, if, for instance, DWO  
15 were to result in additional initiating events, we do  
16 look at that impact.

17 And again, that is in the sensitivity  
18 table in Chapter 19. But ultimately, looking through  
19 the various data and the history, NuScale knows no  
20 known failure mechanism that could lead to this. And  
21 there hasn't been those examples in the industry as  
22 described in SECY 93-87.

23 So we started there. However, we still  
24 did look at initiating event frequency and the  
25 potential for an increase there. In addition, we also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 do the various failures of system response.

2 And so we also look at all DHRS failing  
3 and the impact of what happens if we didn't have steam  
4 generators at all to respond. And also based on that,  
5 there still was nothing substantially different  
6 between a single tube failure and multiple tube  
7 failures. So we looked at it from initiating event  
8 frequency.

9 We looked at it from plant response. We  
10 looked at it from multiple tubes. We had about three  
11 audit questions with multiple questions asked that we  
12 worked with the staff to confirm that there was no  
13 safety or risk concern with respect to this potential  
14 phenomena.

15 MEMBER DIMITRIJEVIC: Thanks, Sarah.  
16 We're looking forward to check those when we reviewed  
17 the Chapter 19 and discussed it. I just thought since  
18 this was one of the -- on the previous slide, this was  
19 one of the elements which were supporting finding the  
20 (audio interference) to discuss here.

21 So because let's say in Chapter 19 you  
22 find there's some sensitivities where no kind of  
23 impact. I don't believe that will be the case. I  
24 mean, that will have to go back to reflect on the  
25 conclusion on this. So that's why I think even this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is a part of Chapter 19. The results of this belongs  
2 here as long as they're presented as one of the  
3 elements supporting finding. Okay. Thanks.

4 MS. BRISTOL: Understood. Thank you.

5 DR. BLEY: This is Dennis Bley. Just a  
6 follow-up on that one. If, in fact, what we're  
7 looking at is uncertainties in the prediction of DWO,  
8 if the problem is in some systematic error that's  
9 hidden in the uncertainties, then certainly you could  
10 get multiple tube failures. And I'm not sure why we  
11 think it'd be two or three or something like that. So  
12 I look forward to Chapter 19 too.

13 MR. MAKAR: Any suggestions for -- I  
14 wonder. Did I hear a suggestion that there should be  
15 more in Chapter 5, safety evaluation, about this  
16 topic?

17 MEMBER DIMITRIJEVIC: My suggestion was  
18 the reference to this one should be maybe provided in  
19 Chapter 5. But in that case, our review would not be  
20 completed until we complete the review of Chapter 19.  
21 The same thing happened with the LOCA thing when the  
22 sensitivity to DHRS was said it will be addressed in  
23 Chapter 19.

24 And a lot of those risk analysis refer to  
25 Chapter 19. But then there is no feedback connection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 back to the chapters where they have been initiated.  
2 So they sort of go as I say to Chapter 19 to die  
3 there. It's just like there should be some feedback  
4 in connection between those.

5 MR. MAKAR: Well, we've moved to the next  
6 slide. And this is on the -- whether the onset  
7 calculations find reasonable insight into the  
8 likelihood. And so that's made up of two main parts,  
9 adequacy of the modeling capabilities and assessment  
10 of the model against experimental data.

11 So there were a number of areas we looked  
12 at. You can see there are 15 elements that go into  
13 these two parts. Next slide, please. The first four  
14 bullets on this say that based on these four review  
15 areas and all those 23 elements that we reached a  
16 conclusion that the approach temperature limit  
17 provides reasonable assurance of adequate protection  
18 against DWO onset. But it goes on to say the finding  
19 does not extend to the general use of NRELAP5  
20 evaluation model for DWO calculations or for thermal  
21 hydraulic condition calculations during the DWO  
22 conditions.

23 MEMBER HALNON: This is Greg. What I take  
24 away from this is that this approach limit that  
25 they're measuring days against in concert with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 inspections you talked about earlier provides a real  
2 solid margin for us to present. Is that fair to say?

3 MR. MAKAR: That's fair to say, yes.

4 MEMBER HALNON: Because if you take any  
5 one in isolation, you can say it's okay to put them  
6 together. It's really solid.

7 MR. MAKAR: Okay. Well, next, Brian Nolan  
8 is going to present the staff review on the heat  
9 removal system.

10 MR. NOLAN: Thanks, Greg. My name is Ryan  
11 Nolan. I'm in the Nuclear Methods Systems Branch for  
12 new reactors. I've been doing new reactor licensing  
13 reviews for 15 years now. Prior to that, I was a  
14 systems engineer in the NSSS group licensee in the  
15 northeast.

16 I was one of the reviewers who performed  
17 the systems review for the decay heat removal system.  
18 While there are changes to the system, overall  
19 functionally, it has not changed. The purpose of the  
20 DHRS is to remove decay heat when the secondary side  
21 is not available.

22 So that all stays the same. Regarding the  
23 changes, it kind of falls into three different  
24 categories, actual physical design changes, some  
25 analytical approach changes, and, in addition,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 modeling changes. And so for the physical changes, I  
2 note them here.

3 There's things like increases in the  
4 number of tubes. They shorten the tubes. The  
5 condenser sits a little bit lower. And then the  
6 ultimate heat sink water level, the initial water  
7 level has decreased.

8 As far as changes to analytical approaches  
9 as the staff briefed the subcommittee last month when  
10 it presented the LOCA topical report, DHRS is now  
11 credited in the LOCA evaluation model. It is a  
12 safety-related system. It was a safety-related system  
13 in the DCA.

14 NuScale is just taking credit for that for  
15 the SDA. And then regarding modeling changes, this is  
16 a topic that will be covered in more detail next month  
17 when the staff presents the non-LOCA topical report.  
18 But there were some significant modeling changes with  
19 respect to DHRS.

20 I note a couple here such as additional  
21 heat structures, changes to pool nodalization.  
22 Overall, taking a more realistic look how the plant  
23 responds and how DHRS functions. So as far as the  
24 conclusions are concerned, they're very, very similar  
25 conclusions to the SDA with respect to the functional

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 requirements and meeting typical GDCs too for 34, for  
2 example.

3 We just -- because it's now credited in  
4 the LOCA EM, we also include some explanation on 50.46  
5 and GDC 35. And that's all I had to share on DHRS.  
6 I'll pause for some questions.

7 CHAIR KIRCHNER: Given the previous topic,  
8 have you thought through what would happen to the DHRS  
9 performance with a tube rupture or multiple tube  
10 ruptures?

11 MR. NOLAN: Yes, the staff did look at  
12 that. I was not the one to perform that review. So  
13 I can't speak to it in detail. But we certainly did  
14 ask questions, not just on tube ruptures themselves.

15 But if you do enter a DWO condition, does  
16 that impact DHRS? And we concluded it would not  
17 impact the DHRS overall and particularly some of the  
18 loss coefficients from the IFR. And ensuring that is  
19 captured in the FSAR was something that the staff did  
20 do as part of this review.

21 CHAIR KIRCHNER: So the DHRS performance  
22 is based on evaporating, essentially condensing. If  
23 you just pressurize the system from the primary side,  
24 then you would just have single phase heat transfer  
25 conditions which is nowhere near as good as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 condensation in the heat exchanger and then draining  
2 the fluid back, so --

3 MR. NOLAN: This is in reference a tub  
4 rupture scenario?

5 CHAIR KIRCHNER: Yes.

6 MR. NOLAN: If someone wants to correct me  
7 in the back, feel free to step up. But in those  
8 instances, you would just consider that train lost and  
9 not effective anymore.

10 MEMBER DIMITRIJEVIC: So if you have a  
11 tube rupture in both steam generators, you will  
12 consider total loss of decay heat removal.

13 MR. NOLAN: Right. I don't believe that's  
14 something that's considered within the design basis.  
15 So we're getting into, like, Chapter 15 area.

16 (Simultaneous speaking.)

17 MEMBER DIMITRIJEVIC: Well, I'm getting  
18 into Chapter 19.

19 CHAIR KIRCHNER: Yes, Vesna.

20 (Simultaneous speaking.)

21 CHAIR KIRCHNER: Thanks, Ryan.

22 MR. NOLAN: Yeah. Like, the main purpose  
23 of this is really establishing the design criteria the  
24 system has regarding response to the system, the  
25 various transients that will come in future

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 subcommittee meetings. And if there's no further  
2 questions, I'll pass it back to David to close out the  
3 presentation.

4 CHAIR KIRCHNER: Dave, do you want to make  
5 a summary statement or just let us read the view  
6 graph?

7 MR. TESFAYE: David, you're on mute.

8 MR. DRUCKER: Thanks. So overall for  
9 Chapter 5, the staff found that all applicable  
10 regulatory requirements were adequately addressed.  
11 And this concludes the Chapter 5 presentation.

12 CHAIR KIRCHNER: Thank you. Members, any  
13 pressing questions right now?

14 Okay. We've gone over schedule. I take  
15 responsibility for that. But -- oh, I didn't see you.

16 MS. WHITING: That's okay. Erin Whiting  
17 from NuScale. As it relates to FXM-19 and the lower  
18 RPD, we do have a technical report in SDA, TR130721,  
19 entitled Use of Austenitic Stainless Steel for NPM  
20 Lower Reactor Pressure Vessel, which assesses the  
21 impact of using FXM-19 and a location of welds within  
22 the RPD when subjected to radiation and thermal  
23 embrittlement.

24 And we have documented that concluded that  
25 FXM-19 is substantially safer than use of ferritic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 material. And there are no safety concerns when  
2 reviewing all of the applicable available  
3 documentation. Chapter 5 does require pre-service  
4 inspection and in-service inspection of each vessel  
5 and the welds on the vessel. And in addition, the  
6 lower RPD was analyzed for all applicable ASME code  
7 and environmental fatigue criteria. And we  
8 demonstrated that the design meets those criteria.

9 MR. DRUCKER: Thank you.

10 CHAIR KIRCHNER: Thank you, Erin. So at  
11 this point, we'll take the opportunity to ask for  
12 public comments. Anyone in the room or anyone on the  
13 line, just state your name, affiliation as  
14 appropriate, and make your comment.

15 Not hearing anyone trying to make a  
16 comment. Okay. Then at this point, we have completed  
17 our open session. And we are going to break for  
18 lunch. For those listening online, if you are  
19 authorized access, we will re-engage at 1:00 o'clock  
20 Eastern Time. And with that, we are recessed.

21 (Whereupon, the above-entitled matter went  
22 off the record at 12:09 p.m.)  
23  
24  
25

C E R T I F I C A T E

This is to certify that the foregoing transcript


In the matter of: ACRS NuScale Subcommittee Open  
Session

Before: NRC

Date: 02-04-25

Place: teleconference

was duly recorded and accurately transcribed under  
my direction; further, that said transcript is a  
true and accurate complete record of the  
proceedings.

  
-----  
Court Reporter

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1716 14TH ST., N.W., STE. 200

WASHINGTON, D.C. 20009-7831

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

January 29, 2025

Docket No. 052-050

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738

**SUBJECT:** NuScale Power, LLC Submittal of Presentation Material Entitled "ACRS Subcommittee Meeting (Open Session) Sections 3.7, 3.8, 3.9.2, and Chapter 5 (Including the Pressure and Temperature Limits Methodology Technical Report and the Density Wave Oscillation Safety Case)," PM-178795, Revision 0

The purpose of this submittal is to provide presentation materials for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Subcommittee Meeting on February 4th, 2025. The materials support NuScale's presentation of the subject sections, and technical report for the US460 Standard Design Approval Application.

The enclosure to this letter is the nonproprietary presentation entitled "Sections 3.7, 3.8, 3.9.2, and Chapter 5 (Including the Pressure and Temperature Limits Methodology Technical Report and the Density Wave Oscillation Safety Case)," PM-178795, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Jim Osborn at 541-360-0693 or at [josborn@nuscalepower.com](mailto:josborn@nuscalepower.com).

Sincerely,



Thomas Griffith  
Director, Regulatory Affairs  
NuScale Power, LLC

**Distribution:** Mahmoud Jardaneh, Chief New Reactor Licensing Branch, NRC  
Getachew Tesfaye, Senior Project Engineer, NRC  
Michael Snodderly, Senior Staff Engineer, Advisory Committee on Reactor Safeguards, NRC

Enclosure 1: ACRS Subcommittee Meeting (Open Session) Sections 3.7, 3.8, 3.9.2, and Chapter 5 (Including the Pressure and Temperature Limits Methodology Technical Report and the Density Wave Oscillation Safety Case), PM-178795, Revision 0, Nonproprietary

**Enclosure 1:**

ACRS Subcommittee Meeting (Open Session) Sections 3.7, 3.8, 3.9.2, and Chapter 5 (Including the Pressure and Temperature Limits Methodology Technical Report and the Density Wave Oscillation Safety Case), PM-178795, Revision 0, Nonproprietary



# ACRS Subcommittee Meeting

(Open Session)

February 4<sup>th</sup>, 2025

## Sections 3.7, 3.8, 3.9.2, and Chapter 5

(Including the Pressure and Temperature Limits Methodology Technical Report and the Density Wave Oscillation Safety Case)



# Acknowledgement and Disclaimer

This material is based upon work supported by the Department of Energy under Award Number DE-NE0008928.

This presentation was prepared as an account of work sponsored by an agency of the United States (U.S.) Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.



# Chapter 3

## Design of Structures, Systems, Components and Equipment

(Sections 3.7, 3.8, and 3.9.2)

February 4, 2025

Presenters:

Haydar Karaoglu and Emily Larsen

## Chapter 3 - Design of Structures, Systems, Components and Equipment

- Section 3.7 – Seismic Design
- Section 3.8 – Design of Category I Structures
- Section 3.9.2 – Mechanical Systems and Components - Dynamic Testing and Analysis of Systems, Components, and Equipment

Note: The presentation does not include Section 3.8.1, Concrete Containment, and Section 3.8.3, Concrete and Steel Internal Structures of Steel or Concrete Containments. The US460 NuScale Power Plant design does not use concrete containments or internal structures.

# Overview of Key Design Features and Updates

- The Standard Design Approval Application (SDAA) is a derivative of the certified design.
- SDAA structures reflect 6 modules (12 modules in the DC), which necessitated updated structural analyses.
- For the SDAA, the Reactor Building (RXB) uses steel-plate composite (SC) walls along with reinforced concrete (RC) members.
- The site layout in the SDAA reflects the updated building designs.
- Seismic analyses for the SDAA are performed for a double-building model, featuring the RXB and Radioactive Waste Building (RWB) and a separate surface-based Control Building (CRB) model, while the design certification (DC) used a triple-building model and individual building models.
- Presentation will focus on high level design and methodology changes and important audit questions and requests for additional information (RAIs).

## Section 3.7 – Seismic Design

### Section 3.7.1 – Seismic Design Parameters

- Percentage of Critical Damping
  - The DC used separate fully cracked and fully uncracked models, and the RC members had the same damping ratio of 7 percent.
  - The SDAA employs hybrid models with both cracked and uncracked members. The damping in the structural members varies based on their cracking status and whether the calculation is for developing in-structure response spectra (ISRS) or performing design calculations.  
*“Building Design and Analysis Methodology for Safety-Related Structures”, TR-0920-71621-P-A*
- Supporting Medium
  - The DC included four generic soil profiles, Soil-7 (Rock), Soil-8 (Firm Soil/Soft Rock), Soil-9 (Hard Rock), and Soil-11 (Soft Soil).
  - In the SDAA, Soil-8 is removed and the soil-separation scenario with the Soil-7 profile is introduced.
- No audit questions or RAIs for Section 3.7.1


## Section 3.7 – Seismic Design (Continued)

### Section 3.7.2 – Seismic System Analysis

- Seismic Analysis Method
  - In the DC, soil-structure interaction (SSI) analyses were performed using the extended subtraction method with SASSI.
  - In the SDAA, the SSI analyses are performed using the soil library methodology, a robust approach equivalent to the direct method. The soil libraries are built using SASSI and the simulations are performed with ANSYS.

*“Improvements in Frequency Domain Soil-Structure-Fluid Interaction Analysis”, TR-0118-58005-P-A*
- Three Components of Earthquake Motion
  - In the DC, the maximum responses were calculated using the square-root-of-the-sum-of-the-squares method.
  - In the SDAA, the SSI responses from the three, statistically independent-components of the ground motion *are algebraically added*.

TR-0118-58005-P-A, Figure 4-1:  
Idealized Soil, Structure, and Fluid Substructures



## Section 3.7 – Seismic Design (Continued)


### Section 3.7.2 – Seismic System Analysis (Continued)

- SSI Numerical Models
  - In the SDAA, the reactor pool is modeled with FLUID elements of ANSYS and using the fluid-structure interaction (FSI) technology. The 6 NuScale Power Modules (NPMs) are modeled in detail using advanced features of ANSYS.
  - In the DC, the pool was modeled as distributed mass. The 12 NPMs were modeled using mass, spring, and beam elements (simplified beam model).
- Audit Responses

33 questions resolved in audit, resulting in the following details and updates added to the Final Safety Analysis Report (FSAR)

  - modal analysis, double building model dimensions, and pool sloshing
- No RAIs for Section 3.7.2

Figure 3.7.2-2a: Isometric View of the Double Building (DB) Model






## Section 3.7 – Seismic Design (Continued)

### Section 3.7.3 – Seismic Subsystem Analysis

- The SDAA includes updates to major subsystems, including the bioshields, the reactor building crane, and the NPMs.
- Three different NPM models have been developed
  - Simplified NPM model is used in SSI analyses to calculate seismic responses on RC and SC structural members.
  - A detailed NPM model is used in SSI analyses to calculate the seismic response around the pool.
  - A detailed NPM model with the use of the superelement technology of ANSYS is used for the nonlinear transient analysis.

(content reflected in Appendix 3A)

*“US460 NuScale Power Module Seismic Analysis”, TR-121515-P*



Simplified NPM Model  
(TR-121515 Figure 3-1)



## Section 3.7 – Seismic Design (Continued)

### Section 3.7.3 – Seismic Subsystem Analysis (Continued)

- In the SDAA, the nonlinear NPM seismic analyses are conducted using a local model that includes the 6 NPMs, the pool, and the surrounding structural members.


*“US460 NuScale Power Module Seismic Analysis”, TR-121515-P*

- In the DC, the NPM seismic analyses were conducted using a local model that included only one NPM at a time, the pool, and a rigid plane under the NPM.

*“NuScale Power Module Seismic Analysis”, TR-0916-51502-P-A*

- Audit Responses  
4 questions resolved in audit, resulting in additional bioshield details in the FSAR
- No RAIs for Section 3.7.3

Figure 3.7.2-7: NPMs within UHS  
(Local Seismic Model)



## Section 3.7 – Seismic Design (Continued)

### Section 3.7.4 – Seismic Instrumentation

- In the SDAA, the locations and descriptions of the seismic instrumentations are updated due to the new layout of the buildings.
- No audit questions or RAIs for Section 3.7.4

## Section 3.8 – Design of SC-I Structures

### Section 3.8.2 – Steel Containment

- Differences from DC
  - Increase in design pressure and temperature for power uprate
  - Material change from carbon steel with cladding to combination of austenitic and martensitic stainless steels
  - Changed pre-service/in-service inspections from Class 1 to Class MC vessel with augmented requirements in some areas
  - Removed hydrogen detonation from load combinations because of added passive autocatalytic recombiners (Chapters 6 and 15)
  - Majority of nozzles changed from welded to integrally forged
- Audit Responses
  - 12 questions resolved in audit
- No RAIs for Section 3.8.2

## Section 3.8 – Design of SC-I Structures (Continued)

### Section 3.8.4 - Other SC-I Structures

- In the SDAA
  - The RXB incorporates SC walls designed according to AISC N690-18 using element- and panel-based approaches.
  - The RC members are designed according to ACI 349-13 using the section-cut forces at critical locations.
  - The forces are calculated from numerical models with different cracked states associated with different load combinations.
  - The simulations are performed using ANSYS with the use of SASSI for soil library calculations.  
(content is also reflected in Appendix 3B)  
*“Building Design and Analysis Methodology for Safety-Related Structures”, TR-0920-71621-P-A*
- In the DC, the major structural members were of RC type and designed according to ACI 349-06 using an element-based approach. The simulations were performed using SASSI and SAP2000.
- Audit Responses

15 questions resolved in audit, resulting in the following updates to the FSAR

  - dynamic soil pressure, differential settlement analysis, definition of the supporting medium used for calculating the static load demands, and the design and analysis procedure (Appendix 3B)
- No RAIs for Section 3.8.4

## Section 3.8 – Design of SC-I Structures (Continued)

### Section 3.8.5 - Foundations

- Differences from DC
  - In the SDAA, the nonlinear stability analysis is performed only for the SC-I portion of the surface-based CRB.
  - In the SDAA, the peak bearing pressure values are calculated using a methodology tailored to the capabilities of the software utilized, ANSYS.
- Audit Responses
  - 12 questions resolved in audit
- No RAIs for Section 3.8.5

## Section 3.9.2 – Dynamic Testing and Analysis of Systems, Components, and Equipment


- Differences from DC
  - Updated requirements from Regulatory Guide 1.20 Revision 3 to 1.20 Revision 4
  - Updated requirements from the American Society of Mechanical Engineers (ASME) Operations and Maintenance (OM) Code, 2012 Edition to ASME OM Code, 2017 Edition
  - Comprehensive vibration assessment program (CVAP) startup instrumentation changed from strain gauges and accelerometers to dynamic pressure sensors
  - Removed Combined Operating License (COL) Item 3.9-14 (DC density wave oscillation (DWO) carveout)
  - Reactor vessel internals (RVI) were evaluated for updated US460 loads
  - Revised flow-induced vibration (FIV) analyses with US460 design changes and updated flowrates and operating conditions
  - Added inlet flow restrictor (IFR) cavitation evaluations with consideration of DWO to CVAP analysis report
  - Added an analysis case of both reactor vent valves (RVVs) actuating to TR-121517-P, "NuScale Power Module Short-Term Transient Analysis"

## Section 3.9.2 – Dynamic Testing and Analysis of Systems, Components, and Equipment (Continued)

- Audit Responses
  - 35 audit questions resolved
    - Added reference to startup test abstracts from Section 14.2 to FSAR 3.9.2.1
    - Updated language of NPM prototype classification options to match TR-121353-P, “NuScale Comprehensive Vibration Assessment Program Analysis Technical Report”
    - Provided summary of TF-3 (steam generator fluid-induced vibration (SGFIV)) flow testing results for review
    - Provided tube sliding and wear evaluation caused by the DWO transient
    - Provided DWO fatigue usage for tube-to-tubesheet weld, tubes, and tubesheet in the feedwater plenum
- RAI Results
  - RAI 10111 (Question 3.9.2-1) - Confirmation that steam generator (SG) integrity is maintained during Service Level D events
    - Provided preliminary Service Level D fatigue results for RVI and SG components
    - Resulted in no changes to the SDAA

## Section 3.9.2 – Density Wave Oscillation

- 10 audit questions resolved
  - 1 in Section 3.9.1, 9 in Section 3.9.2
- No DWO RAIs in Chapter 3
- Analyses
  - Section 3.9.1
    - DWO Service Level A Transient
    - NPM lifetime limit for time in DWO
  - Section 3.9.2
    - Structural integrity of steam generator during DWO





# Acronyms

ASME	American Society of Mechanical Engineers	NPM	NuScale Power Module
COL	Combined Operating License	NRC	Nuclear Regulatory Commission
CRB	Control Building	OM	Operations and Maintenance
CVAP	Comprehensive Vibration Assessment Program	RAI	Request for Additional Information
DB	Double Building	RC	Reinforced Concrete
DC	Design Certification	RVI	Reactor Vessel Internals
DWO	Density Wave Oscillation	RVV	Reactor Vent Valve
FIV	Flow-Induced Vibration	RWB	Radioactive Waste Building
FSI	Fluid-Structure Interaction	RXB	Reactor Building
IFR	Inlet Flow Restrictor	SC	Steel-Plate Composite
ISRS	In-Service Response Spectra	SG	Steam Generator
ITP	Initial Test Program	SGFIV	Steam Generator Fluid-Induced Vibration
		SSI	Soil-Structure Interaction
		SDAA	Standard Design Approval Application



# Chapter 5

## Reactor Coolant System and Connecting Systems

February 4, 2025

Presenters:

Wendy Reid and Erin Whiting

## Chapter 5 – Reactor Coolant System and Connecting Systems

- Section 5.1, Summary Description
- Section 5.2, Integrity of Reactor Coolant Boundary
- Section 5.3, Reactor Vessel
  - Pressure and Temperature Limits Methodology Technical Report (TR-130877-P, Revision 1)
- Section 5.4, Reactor Coolant System Component and Subsystem Design

<sup>1</sup> Denotes changes made in revision 2 of the Standard Design Approval Application (SDAA) Final Safety Analysis Report (FSAR)

# Chapter 5 and Pressure and Temperature Limits Technical Report Review

- Audit Questions
  - 59 questions in Chapter 5
  - 20 questions on Pressure and Temperature Limits Methodology Technical Report (PTLR)
- Request for Additional Information (RAI)
  - 1 RAI in Chapter 5
  - No RAIs on PTLR

## Section 5.1 - Summary Description

- Change in primary and secondary operating pressures, temperatures, and flow rates as a result of the power uprate
- Design pressure is the same for primary (inside the reactor vessel) and secondary (inside the steam generator tubes). Both design pressures changed from 2100 psi to 2200 psi
- Classification change for upper steam generator (SG) support for manufacturing concerns, requirements are consistent with American Society of Mechanical Engineers (ASME) code. <sup>1</sup>
- Reactor coolant system (RCS) volume change <sup>1</sup>

## Section 5.2 - Integrity of Reactor Coolant Boundary

- Adopted 2017 ASME Boiler and Pressure Vessel and Operation and Maintenance Codes
- Change to leakage detection sensitivity requirement
  - No change to the equipment or system capabilities
  - No change to Technical Specifications for RCS leakage
- Change from three to two reactor vent valves
- The set points and design of the reactor safety valves (RSVs) changed
  - Setpoints increased with the design pressure increase and staggered
  - Minimum design capacity per valve increased<sup>1</sup>
  - Design change from pilot operated to spring operated RSVs
- Added the containment isolation test fixture (CITF) <sup>1</sup>
- Augmented preservice examination for the Class 1 containment isolation valves (CIVs) and CITF on each of the four chemical and volume control system lines <sup>1</sup>
- Augmented examinations applied to welds between containment vessel (CNV) and CIVs to support Branch Technical Position 3-4 requirements as discussed in Section 3.6 <sup>1</sup>
- Low temperature overpressure protection setpoints changed due to material change for lower reactor pressure vessel (RPV)

## Section 5.2 - Integrity of Reactor Coolant Boundary (Continued)

Changes to Table 5.2-3 reporting materials for reactor coolant pressure boundary components and support materials

- Lower RPV change discussed in Section 5.3
- Added additional permissible materials to increase manufacturing flexibility for the combined license applicant
- Changes for consistency and completeness in response to audit questions
- Reconciled naming conventions with internal design documents

## Section 5.3 - Reactor Pressure Vessel

- Material change for the lower RPV to FXM-19 austenitic stainless steel
  - Change reflected in the PTLR methodology Technical Report
    - Upper RPV limiting ferritic component susceptible to fluence effects <sup>1</sup>
  - Expansion to Combined Operating License (COL) Item 5.3-1 for PTLR <sup>1</sup>
  - Exemptions for 10 CFR 50.60 fracture toughness (Appendices G and H) for and 10 CFR 50.61 pressurized thermal shock
  - Use of austenitic stainless steel in lower RPV
    - Superior ductility compared to ferritic materials
    - Less susceptible to the effects of neutron and thermal embrittlement than ferritic materials
    - Regulatory beltline concerns not an issue
    - No Appendix H material surveillance program required
- Removal of COL Item concerning onsite cleaning of the RPV during construction
- Removal of the flow diverter <sup>1</sup>
- Change to seismic restraint feature between lower CNV and lower RPV <sup>1</sup>




## Section 5.4 - Reactor Coolant System Component and Subsystem Design

- Decay heat removal system (DHRS)
  - System size change
  - Credited in safety analysis; required for containment peak pressure response to a loss-of-coolant accident (LOCA) (added to Chapter 5)<sup>1</sup>
  - Details on emergency core cooling system (ECCS) venting to limit hydrogen accumulation in the RPV during containment isolation <sup>1</sup>
  - Design meets the intent of SECY 94-084 by achieving passively cooled, safe shutdown conditions within 36 hours <sup>1</sup>
    - DHRS performance cases achieve a passively cooled, safe shutdown condition within 36 hours.
    - Added off-nominal cases, including the worst case DHRS case (single train, high inventory), which provides sufficient cooling to below 450 degrees Fahrenheit RCS average temperature in 36 hours.
  - Actuation valve accumulator pressure details added <sup>1</sup>
- Expanded description of SG supports <sup>1</sup>
- Added description of flow paths between the riser and downcomer <sup>1</sup>
- SG tube plugging criterion description changed due to bracketed value in Technical Specifications <sup>1</sup>

## Section 5.4 - Reactor Coolant System Component and Subsystem Design (Continued)

- Design Certification (DC) approach
  - Ensure density wave oscillation (DWO) preclusion with inlet flow restrictor (IFR) sizing
  - DWO onset evaluation subject to future analysis
  - SG integrity to be determined during operation with DWO
  - COL Item 3.9-14 (DC DWO carveout)
- DWO Safety Case <sup>1</sup>
  - Three pillars provide defense-in-depth safety case
  - Real-Time Monitoring
    - Approach temperature description and figure
    - Link to Section 13.5.2 procedure development
  - Physical Inspections
    - Augmented examination requirements for SG tubes and IFRs
  - Added IFR loss coefficient range



# Acronyms

ASME	American Society of Mechanical Engineers	RSV	Reactor Safety Valve
CITF	Containment Isolation Test Fixture	SG	Steam Generator
CIV	Containment Isolation Valve	SDAA	Standard Design Approval Application
CNV	Containment Vessel		
COL	Combined Operating License		
DC	Design Certification		
DHRS	Decay Heat Removal System		
DWO	Density Wave Oscillation		
ECCS	Emergency Core Cooling System		
FSAR	Final Safety Analysis Report		
IFR	Inlet Flow Restrictor		
LOCA	Loss-of-Coolant Accident		
NRC	Nuclear Regulatory Commission		
PTLR	Pressure-Temperature Limits Report		
RAI	Request for Additional Information		
RCS	Reactor Coolant System		
RPV	Reactor Pressure Vessel		

# **Presentation to the Advisory Committee on Reactor Safeguards Subcommittee**

## **Staff Review of NuScale's US460 Standard Design Approval Application Final Safety Analysis Report, Revision 1**

Chapter 3, Sections 3.7, 3.8, 3.9.2

February 4, 2025  
(Open Session)

# NuScale SDAA FSAR Chapter 3 Review

## (Sections 3.7, 3.8, 3.9.2)

### Contributors

#### ❖ **Technical Reviewers**

Sunwoo Park (NRR/DRA/APLC)

Scott Stovall (RES/DE/SGSEB)

Ata Istar (NRR/DEX/ESEB)

Zuhan Xi (NRR/DEX/ESEB)

Luisette Candelario-Quintana (NRR/DEX/ESEB)

Yuken Wong (NRR/DEX/EMIB)

Stephen Hambric (Consultant)

#### ❖ **Project Managers**

Prosanta Chowdhury, PM (NRR/DNRL/NRLB)

Getachew Tesfaye, Lead PM (NRR/DNRL/NRLB)

# NuScale SDAA FSAR Chapter 3 Review

## (Sections 3.7, 3.8, 3.9.2)

### Overview

- ❖ NuScale submitted Chapter 3, “Design of Structures, Systems, Components and Equipment,” Revision 1, of the NuScale SDAA FSAR on October 31, 2023.
- ❖ NRC performed a regulatory audit as part of its review of Chapter 3, from March 2023 to June 2024.
- ❖ Questions raised during the audit were resolved within the audit. All RAI responses were acceptable.
- ❖ Staff completed the review of Chapter 3 (Sections 3.7, 3.8, 3.9.2) and issued an advanced safety evaluation to support the ACRS meeting.
- ❖ Since providing draft SE to ACRS on 1/4/2025, **Section 3.7** was updated regarding acceptability of strong-motion time history being less than 6 seconds; **Section 3.8** was updated regarding demand over capacity ratio (DCR) values for Reactor Building (RXB) calculated and assessed by both element-based and panel section-based approaches.

# NuScale SDAA FSAR Chapter 3 Review

## ❖ 3.7 – Seismic Design

- ☐ Section 3.7.1 – Seismic Design Parameters
- ☐ Section 3.7.2 – Seismic System Analysis
- ☐ Section 3.7.3 – Seismic Subsystem Analysis
- ☐ Section 3.7.4 – Seismic Instrumentation

## ❖ 3.8 – Design of Category I Structures

- ☐ Section 3.8.1 – Concrete Containment (N/A)
- ☐ Section 3.8.2 – Steel Containment
- ☐ Section 3.8.3 – Concrete and Steel Internal Structures of Steel or Concrete Containments (N/A)
- ☐ Section 3.8.4 – Other Seismic Category-I Structures
- ☐ Section 3.8.5 – Foundations

## ❖ Section 3.9.2 – Dynamic Testing and Analysis of Systems, Structures, and Components

## Section 3.7.1 – Seismic Design Parameters

### Significant Differences Between NuScale DCA and SDAA:

#### 1. Structural Damping Values Used in Seismic Analysis:

- ❖ DCA used reinforced concrete (RC) for safety-related structures and applied a uniform 4% damping for both cracked and uncracked RC members to generate in-structure response spectra (ISRS).
- ❖ SDAA used RC and steel-plate composite (SC) for safety-related structures, utilizing a hybrid damping scheme to generate ISRS; 7% and 5% for cracked RC and SC, and 4% and 3% for uncracked RC and SC, respectively.
- ❖ In both cases, cracked and uncracked ISRS are enveloped to establish design-basis ISRS.
- ❖ Staff finds the SDAA damping values (percent of critical damping) for both cracked and uncracked RC and SC cases acceptable, as they align with the guidance in RG 1.61, "Damping Values for Seismic Design of Nuclear Power Plants."



## Section 3.7.1 – Seismic Design Parameters

Significant Differences Between NuScale DCA and SDAA:

### 2. Supporting Media for Seismic Category I Structures:

- ❖ DCA considered four supporting media types: soft soil, firm soil/soft rock, rock, and hard rock.
- ❖ SDAA, by contrast, utilized three supporting media types: soft soil, rock, and hard rock.
- ❖ In both cases, seismic responses for each soil type were enveloped to generate the design-basis seismic demand.
- ❖ Staff finds the SDAA supporting media for Seismic Category I structures acceptable, as they adequately represent the range of expected site soil conditions.

## Section 3.7.2 – Seismic System Analysis

### Significant Differences Between NuScale DCA and SDAA:

1. Different Methodologies for Seismic Soil-Structure-Fluid Interaction (SSFI) Analysis:
  - ❖ DCA employed a two-step methodology to address SSFI effects, involving separate soil-structure interaction and fluid-structure interaction analyses, which included simplifications and approximations.
  - ❖ SDAA adopted a single, integrated methodology to evaluate SSFI effects under design-basis ground motion.
  - ❖ SDAA methodology is based on Topical Report (TR-0118-58005), “Improvements in Frequency Domain Soil-Structure-Fluid Interaction Analysis,” which was approved in 2022.
  - ❖ Staff verified that seismic SSFI analysis for US460 standard design was performed in compliance with the applicable limitations and conditions specified in the approved topical report.

## Section 3.7.2 – Seismic System Analysis

### Significant Differences Between NuScale DCA and SDAA:

#### 2. Different Analysis Models Due to Design Changes:

- ❖ SDAA incorporates significant design changes from DCA, including six NPMs, updated NPM models, resized UHS, relocated CRB, and new SC walls.
- ❖ DCA employed a Triple Building Model (including RXB, CRB, and RWB) for design-basis seismic demand calculations, whereas SDAA used a Double Building Model (including RXB and RWB) with an independently modeled CRB.
- ❖ Staff determined that updated models used in seismic system analysis for US460 standard design are acceptable, as they adhere to applicable industry standards and DSRS acceptance criteria.

---

## Section 3.7.2 – Seismic System Analysis

### Significant Differences Between NuScale DCA and SDAA:

3. Different Approaches to Addressing the Results of Parameter Sensitivity Studies:
  - ❖ Both DCA and SDAA conducted in-structure response spectrum (ISRS) sensitivity studies to evaluate parameter variations, including structure-soil separation, empty dry dock, and modularity.
  - ❖ In both cases, the soil-separation scenario resulted in a noticeable exceedance of the design-basis ISRS.
  - ❖ DCA addressed this exceedance by including a COL Item, requiring that site-specific ISRS in soil-separation conditions be demonstrated to remain bounded by the DCA design-basis ISRS.
  - ❖ SDAA addressed the exceedance differently, incorporating the soil-separation scenario into the design-basis ISRS analysis cases. The staff found this approach acceptable, as it directly integrates soil-separation effects into the design basis.

## Section 3.7.3 – Seismic Subsystem Analysis

Significant differences between NuScale DCA and SDAA:

❖ Seismic Analysis of Buried Seismic Category I Piping, Conduits, and Tunnels:

- ☐ DCA did not include buried piping or conduits, and the tunnel connecting RXB and CRB was analyzed as part of CRB.
- ☐ SDAA, however, included an underground reinforced-concrete duct bank containing conduits that connect RXB and CRB.
- ☐ Staff determined the seismic analysis of SDAA buried Seismic Category I structures and systems is acceptable, as it was conducted in accordance with applicable industry standards and DSRS acceptance criteria.

## Section 3.8 - Design of Category I Structures

(Control Building (CRB) and Reactor Building (RXB))

### ❖ Section 3.8.1 - Concrete Containment: N/A

### ❖ Section 3.8.2 - Steel Containment

- ❑ Significant differences between NuScale DCA FSAR and SDAA FSAR include:
  - Reconfigured boundary condition between the bottom heads of CNV and RPV.
  - Design parameter
    - » /operating parameters: (50 psig/1,200 psig/600 °F vs. 60 psig/1,050 psig/550 °F)\*
- \*(external design pressure/internal design pressure/design temperature)*
- ❑ SDAA SE conclusion is the same as DCA SE conclusion.

## Section 3.8.4 - Other Seismic Category I Structures

- ❖ Significant differences between NuScale DCA FSAR and SDAA FSAR include:
  - ❑ Methodology for the evaluation of seismic Category I and II structures (RXB and CRB) is per the requirements provided in TR-0920-71621-P- A, Rev. 1, "Building Design and Analysis Methodology for Safety-Related Structures."
- ❖ SDAA SE conclusion is the same as DCA SE conclusion.

## Section 3.8.5 - Foundations

- ❖ Significant differences between NuScale DCA FSAR and SDAA FSAR include:
  - ❑ The embedment of CRB:
    - » In the SDAA, the CRB is modeled as a surface-founded structure, conservatively ignoring the 5-ft embedment of the foundation for its stability analysis.
    - » In the DCA, the CRB with an embedment depth of 55 feet is modeled as an embedded structure with backfill surround it for its stability analysis.
- ❖ SDAA SE conclusion is the same as DCA SE conclusion.



## Section 3.9.2 - Dynamic Testing and Analysis of Systems

- ❖ Piping Vibration, Thermal Expansion, and Dynamic Effects
- ❖ Comprehensive Vibration Assessment Program (CVAP) of Reactor Vessel Internals (RVI) and Steam Generators (SG)
  - ❑ Dynamic Response Analysis under Operational Flow Transients and Steady State Conditions
    - TR-121353, Revision 2, “NuScale Comprehensive Vibration Assessment Program Analysis Technical Report”
  - ❑ Flow-Induced Vibration (FIV) Validation Testing and Inspection
    - TR-121354, Revision 1, “NuScale Comprehensive Vibration Assessment Program Measurement and Inspection Plan Technical Report”
- ❖ Dynamic System Analysis of the RVI and SG under ASME Service Level D Conditions
  - ❑ Seismic Loading Analysis
    - TR-121515, Revision 1, “US460 NuScale Power Module Seismic Analysis”
  - ❑ Short-Term Transient Loading Analysis
    - TR-121517, Revision 1, “NuScale Power Module Short-Term Transient Analysis”
  - ❑ Stress and Deflection Evaluations
    - RAI 10111, Question 3.9.2-1 (Resolved)

## Section 3.9.2 – DCA Deferred or Unresolved

### ❖ CVAP-Steam Generator Qualification

- ☐ Qualification of SG components due to DWO-induced dynamic loads carveout in the DCA
- ☐ SG validation testing deferred to COL applicant
  - Elimination of significant SG tube FIV not demonstrated

### ❖ Service Level D evaluations

- ☐ Did not include hard rock (there is a COL item for site-specific seismic analysis)

## Section 3.9.2 – CVAP - Dynamic Response Analysis

- ❖ Significant differences between NuScale DCA and SDAA FSARs:
  - ❑ Higher flow speeds (25% more power) → stronger FIV loads
  - ❑ Reduced DWO-induced dynamic loads and impacts on SG
  - ❑ SG inlet flow restrictors (IFRs) redesigned – no longer at risk for FIV
  - ❑ SG tube support system redesigned
  - ❑ Secondary flow piping and valve systems redesigned to minimize FIV risk
- ❖ SDAA SE conclusion is complete, unlike DCA SE conclusion
  - ❑ Qualification of SG due to DWO-induced dynamic loads is no longer a “carveout”
  - ❑ TF-3 SG validation testing shows minimal risk of significant FIV

## Section 3.9.2 – CVAP – DWO-Induced Loads

### ❖ DCA (and early SDAA) concerns:

- ❑ During reverse DWO flow the boiling boundaries in SG tubes might approach the SG inlets leading to:
  - Cavitation erosion
  - Condensation-induced water hammer (CIWH)
- ❑ Significant number of DWO cycles initially allowed over plant life

## Section 3.9.2 – CVAP – DWO-Induced Loads

### ❖ Three-tiered SDAA safety finding:

- ❑ Boiling boundaries are highly unlikely to approach SG inlets; cavitation and CIWH are therefore highly unlikely
  - Chapter 5 finding confirms NuScale's analysis methods are acceptable for simulating boiling boundary heights
  - NRC Office of Research independent analysis confirms CIWH is highly unlikely
- ❑ In the unlikely event cavitation or CIWH occurs, NuScale estimates low tube and IFR wear
  - Reduced number of allowable cycles, small loads
- ❑ Finally, the SG inspection program is sufficient to capture any unexpectedly high wear (Section 5.4.1)
  - Full inspection during first refueling outage
  - Afterwards, full inspections over 72 effective full power month intervals

## Section 3.9.2 – CVAP – TF-3 SG Validation Testing

- ❖ On-site staff audit of facility and flow testing at SIET in Piacenza, Italy in October 2024
  - ☐ Facility is a reasonable representation of a partial NPM SG
    - Tightly fitting SG tubes and supports, no need to account for SG support system design differences
  - ☐ Test data are sufficient to evaluate risk of significant FIV
- ❖ Tested over a comprehensive range of flow rates up to 250% of equivalent NPM 100% power
  - ☐ No evidence of Vortex Shedding (VS) or Fluid-Elastic Instability (FEI)

## Section 3.9.2 – CVAP – FIV Validation Testing and Inspections

- ❖ Significant differences between NuScale DCA and SDAA FSARs include:
  - ❑ Replaced internal vibration sensors with dynamic pressure sensors for initial startup testing
- ❖ SDAA SE conclusion
  - ❑ SG TF-3 testing demonstrated that dynamic pressure sensors should “hear” unexpectedly high RVI or SG vibration during initial startup testing

## Section 3.9.2 – Dynamic System Analysis of the RVI and SG under Service Level D Conditions

- ❖ Significant differences between NuScale DCA FSAR and SDAA FSAR:
  - ❑ Different building, fewer NPMs (6 vs 12)
  - ❑ Seismic loads include soft soil and hard rock ground conditions
    - Hard rock events include significant higher frequency loads which align with SG modes of vibration
  - ❑ Upper and lower riser interface redesigned
  - ❑ RVI hanger plate interface redesigned
  - ❑ Different (but improved) modeling approaches
- ❖ SDAA SE conclusion is more comprehensive, unlike DCA SE conclusion
  - ❑ Thorough assessment of RVI and SG stresses and deflections show minimal risk of damage



## Section 3.9.2 – Dynamic System Analysis of the RVI and SG under Service Level D Conditions

### ❖ Seismic loads:

- ☐ Simpler, more comprehensive and accurate modeling approach than in DCA
- ☐ Bound all soil types and NPM locations

### ❖ Transient loads:

- ☐ Short blow-down events
- ☐ Loads order of magnitude lower than seismic

## Section 3.9.2 – Dynamic System Analysis of the RVI and SG under Service Level D Conditions

### ❖ RVI stress analyses:

- ☐ Bounding response spectrum method for overall structure
  - Confirmed to be reasonably bounding by comparing to single transient analysis
- ☐ Bounding engineering calculations for joints and simple structures
  - Highly conservative

### ❖ SG stress analyses:

- ☐ Full transient analyses for bounding soft soil and hard rock load cases – comprehensive and accurate

### ❖ All stresses within allowable limits

# NuScale SDAA FSAR Chapter 3 Review

(Sections 3.7, 3.8, 3.9.2)

## Conclusion

- ❖ While there are some differences between the DCA and the SDAA, the staff found that the applicant provided sufficient information to support the staff's safety finding.
- ❖ The staff found that all applicable regulatory requirements were adequately addressed.

# **Presentation to the Advisory Committee on Reactor Safeguards Subcommittee**

## **Staff Review of NuScale's US460 Standard Design Approval Application Final Safety Analysis Report, Revision 1**

### **Chapter 5**

### **“Reactor Coolant System and Connecting Systems”**

February 4, 2025  
(Open Session)

# NuScale SDAA FSAR Chapter 5 Review

## Contributors

### ❖ Technical Reviewers

Nick Hansing, Section 5.2 (NRR/DEX/EMIB)  
Gordan Curran, Section 5.2 (NRR/DSS/SCPB)  
Eric Reichelt, Section 5.2 (NRR/DNRL/NPHP)  
John Budzynski, Section 5.2 (NRR/DSS/SNRB)  
Dan Widrevitz, Section 5.3 and PTLR (NRR/DNRL/NVIB)  
Greg Makar, Section 5.4 (NRR/DNRL/NCSG)  
Leslie Terry, Section 5.4 (NRR/DNRL/NCSG)  
Ryan Nolan, Section 5.4 (NRR/DSS/SNRB)  
Tim Drzewiecki (DWO) (NRR/DANU/UTB1)

### ❖ Project Managers

Getachew Tesfaye, Lead PM (NRR/DNRL/NRLB)  
David Drucker, PM (NRR/DNRL/NRLB)

# NuScale SDAA FSAR Chapter 5 Review

## Overview

- ❖ NuScale submitted Chapter 5, “Reactor Coolant System and Connecting Systems,” Revision 1, of the NuScale SDAA FSAR on October 31, 2023
- ❖ Responses to Audit questions and RAIs were acceptable
- ❖ NRC staff completed the review of Chapter 5 and issued an advanced safety evaluation to support the ACRS Subcommittee meeting
- ❖ No significant changes between draft SE provided to ACRS on 1/4/25 and SE submitted on 1/29/25

---

# NuScale SDAA FSAR Chapter 5 Review

## Sections

- ❖ Section 5.1 – Summary Description
- ❖ Section 5.2 – Integrity of Reactor Coolant Boundary
- ❖ Section 5.3 – Reactor Vessel
- ❖ Section 5.4 – Reactor Coolant System Component and Subsystem Design

---

# NuScale SDAA FSAR Chapter 5 Review

## Section 5.2.1 Compliance with Codes and Cases

- ❖ Significant differences between NuScale DCA FSAR and NuScale SDAA FSAR include:
  - ❑ ASME Codes of Record (2017, vice 2013 BPV/ 2012 OM)
  - ❑ Use of ASME Code Cases used (while different, all approved in RGs)
- ❖ SDAA SE conclusion same as DCA SE conclusion



# NuScale SDAA FSAR Chapter 5 Review

## Section 5.2.3 Reactor Coolant Pressure Boundary Materials

- ❖ Significant differences between NuScale DCA FSAR and NuScale SDAA FSAR:
  - ❑ Lower RPV section flange shell RPV bottom head was SA—508 Grade 3, Class 1 for the DC vs. Lower Vessel (Lower Head, Shell and Flange) is SA-965 FXM-19 for the SDAA. This material is acceptable for ASME Code Class 1 applications
  - ❑ Welding material is SFA-5.4 Type E209, E240/SFA-5.9 Type ER 209,ER240 and is compatible to SA-965 FXM-19
  - ❑ FXM-19 and Type 2XX weld filler metal specify 0.04 maximum carbon and a Ferrite Number in the range of 5FN to 16FN which meets ASME Code
  - ❑ TR-130721 Use of Austenitic Stainless Steel for NPM Lower Reactor Pressure Vessel concludes the US460 SDAA design meets the requirements of GDC 14, GDC 15, GDC 31 and GDC 32
  - ❑ Section 5.3 covers additional technical information in more detail
- ❖ SDAA SE conclusion same as DCA SE conclusion

# NuScale SDAA FSAR Chapter 5 Review

## Section 5.3 Reactor Vessel

- ❖ Significant differences between NuScale DC FSAR and NuScale SDAA FSAR include:
  - ❑ Use of austenitic stainless steel for the lower NPM
  - ❑ Exemptions 6 and 7 from ferritic steel requirements inapplicable to austenitic stainless steel lower NPM
    - » Requirements of 10 CFR 50.60; 10 CFR 50.61, and 10 CFR 50 Appendices G (fracture toughness requirements) and H (reactor vessel surveillance program), do not apply to the lower NPM
  - ❑ At the COL stage, the final as-built design transients, and material properties of the reactor pressure vessel will be evaluated to confirm that they are bounded by those used in the PTL methodology (SDAA COL Item 5.3-1)

# NuScale SDAA FSAR Chapter 5 Review

## Section 5.3 Reactor Vessel (contd.)

- ❖ NuScale SDAA SE conclusion is different from NuScale DCA SE conclusion because the SDAA design includes austenitic stainless steel lower NPM instead of ferritic steel lower NPM in the DCA
  - ❑ Consequently, the SDAA SE includes granting exemptions from some ferritic requirements for the lower NPM
  - ❑ In addition, pressure-temperature limits methodology approval differs (next slide)

# NuScale SDAA FSAR Chapter 5 Review

## Pressure Temperature Limits Methodology Report

- ❖ Significant differences between NuScale DCA FSAR and NuScale SDAA FSAR include:
  - ❑ SDAA design is never beltline limited in the lower NPM
  - ❑ Pressure-Temperature curves are primarily limited by geometric discontinuities in locations with essentially no neutron embrittlement
  - ❑ At the COL stage, the final as-built design transients, and material properties of the reactor pressure vessel will be evaluated to confirm that they are bounded by those used in the PTL methodology (SDAA COL Item 5.3-1)
- ❖ SDAA SE conclusion is not the same as DCA SE conclusion because of changes to the design and expanded COL Item 5.3-1

# NuScale SDAA FSAR Chapter 5 Review

## Section 5.4.1 Steam Generators

- ❖ Significant differences between NuScale DCA FSAR and NuScale SDAA FSAR
  - ❑ Inlet flow restrictor (IFR) design
    - New center-flow orifice design
    - IFRs expanded against the tube inside surface, not attached to a plate outside the tubes
    - Removed for SG inspection and maintenance activities, including IFR inspection
  - ❑ SG Program COL Item 5.4-1 includes additional inspections for first module to undergo a refueling outage
    - 20 percent of the tubes will be inspected during each refueling outage over the 72 effective full-power months after the first refueling outage (100 percent inspection)
  - ❑ SG Program technical specifications
    - Structural integrity performance criterion (SIPC) for steady-state full-power operation is based on ASME Code for external pressurization ( $2x\Delta P$ ) rather than burst ( $3x\Delta P$ )
    - Tube plugging criterion not changed from [40%] through-wall, but new analysis based on new support design and SIPC

# NuScale SDAA FSAR Chapter 5 Review

## Section 5.4.1 Steam Generators (Continued)

### *Approach Temperature Limit for Density Wave Oscillation (DWO) Instability*


- ❖ FSAR Section 5.4.1.3 describes the approach temperature
  - $\Delta T_{approach} = T_{RCS,hot} - T_{SG,exit}$
- ❖ Adequacy of approach temperature limit demonstrated through NRELAP5 calculations
  - Approach temperature limit demonstrates margin to DWO onset with respect to NRELAP5 predicted DWO onset

# NuScale SDAA FSAR Chapter 5 Review

## Section 5.4.1 Steam Generators (Continued)

### *Approach Temperature Limit Review Framework*

- ❖ NRC staff evaluated 23 elements to support finding



# NuScale SDAA FSAR Chapter 5 Review

## Approach Temperature Limit Review Framework (continued)

5.4.1.4.2.1.1	<b>The approach temperature limit provides margin to DWO with respect to DWO onset calculations</b>
	Approach temperature limit is always reached before DWO onset is predicted to occur
	Calculations cover an adequate range of operating conditions for the NPM steam generators
	Calculations use suitably conservative input
5.4.1.4.2.1.4	<b>Uncertainties in the prediction of DWO onset are reasonable considering the risk associated with DWO</b>
	Consistent with defense-in-depth philosophy
	Maintains sufficient safety margins
	Risk is small and consistent with the intent of the Commission's Safety Goal Policy Statement
	Performance measurement strategies



# NuScale SDAA FSAR Chapter 5 Review

## Approach Temperature Limit Review Framework (continued)

5.4.1.4.2.1.2 DWO onset calculations provide reasonable insight into the likelihood of DWO		
	5.4.1.4.2.1.2.1	The evaluation model contains the adequate modeling capabilities
		4 elements
	5.4.1.4.2.1.2.2	The evaluation model has been adequately assessed against experimental data
		<u>The experimental data used for assessment is appropriate</u>
		7 elements
		<u>The evaluation model has demonstrated the ability to predict DWO over the analysis envelope</u>
		4 elements

# NuScale SDAA FSAR Chapter 5 Review

## Conclusions - Approach Temperature Limit Review

- ❖ Approach temperature limit provides reasonable assurance of adequate protection against DWO onset for the SG design
  - ❑ Approach temperature limit provides margin to DWO with respect to DWO onset calculations (see SER Section 5.4.1.4.2.1.1)
  - ❑ DWO onset calculations provide reasonable insight into the likelihood of DWO (see SER Section 5.4.1.4.2.1.2)
  - ❑ Static instability coupling is precluded (see SER Section 5.4.1.4.2.1.3)
  - ❑ Uncertainties in the prediction of DWO onset are reasonable considering the risk associated with DWO (see SER Section 5.4.1.4.2.1.4)
- ❖ The staff approval of the approach temperature limit does not approve the general use of the NRELAP5 evaluation model for use in DWO calculations
  - ❑ Limitation includes the prediction of DWO onset or the prediction of thermal-hydraulic behavior during DWO
  - ❑ The staff is unable to determine the adequacy of the evaluation model due to gaps in model assessment (see SER Section 5.4.1.4.2.1.2)

# NuScale SDAA FSAR Chapter 5 Review

## Section 5.4.3 Decay Heat Removal System

- ❖ Notable changes between NuScale DCA FSAR and NuScale SDAA FSAR include:
  - ☐ increase in number of condenser tubes, average shorter tube length, lower condenser elevation, lower UHS water level
  - ☐ credited in the revised LOCA evaluation model
  - ☐ new NRELAP5 basemodel changes related to DHRS such as additional heat structures and changes to pool nodalizations
- ❖ SDAA SE conclusion similar to DCA SE conclusion except with inclusion of LOCA-related requirement

---

# NuScale SDAA FSAR Chapter 5 Review

## Conclusions

- ❖ While there are some differences between the DCA and the SDAA, the staff found that the applicant provided sufficient information to support the staff's safety finding
- ❖ The staff found that all applicable regulatory requirements were adequately addressed

<b>Meeting Title</b>	<b>Open Session NuScale Subcommittee on Staff's Evaluation of NuScale Standard Design Approval Section 3.7, 3.8 and 3.9.2 and Chapter 5, including DWO</b>
----------------------	--

**Attendee**

Michael Snodderly	ACRS (DFO)
Getachew Tesfaye	NRR
Matt Sunseri	ACRS
Shandeth Walton	ACRS
Ron Ballinger	ACRS
Larry Burkhart	ACRS
Thomas Dashiell	ACRS
Andrea Torres	ACRS
David Yeager	
Courtney Goodwill	
Jim Osborn	NuScale
Court Reporter	
Larry Loomis Jr	NuScale
Brian Kanen	NuScale
Sarah Bristol	NuScale
Kevin Drost	NuScale
Rim Nayal	NuScale
Nicholas Mowers	
Eric Matthews	NuScale
R Snuggerud	NuScale
Taylor Zindren	
Wendy Reid	NuScale
Omer Erbay	NuScale
Daniel Diefendorf	NuScale
Cindy Williams	NuScale
Tammy Skov	ACRS
Mahmoud -MJ- Jardaneh	NRR
Melissa Bates	
Meghan McCloskey	NuScale
Pei-Yuan Cheng	NRR
David Drucker	
Elisa Fairbanks	NuScale
Prosanta Chowdhury	NRR
Gordon Curran	NuScale
Timothy Polich	RoPower
Thomas Scarbrough	NRR
Hannah Rooks	
Robert Martin	ACRS
Rachel Dern	NuScale
Vesna Dimitrijevic	ACRS
Stephanie Garland	ACRS
Janet Riner	ACRS
Dennis Bley	ACRS

Jason Thompson	
Matthew Martineau	NuScale
Allyson Callaway	NuScale
Alissa Neuhausen	NRR
Stacy Joseph	NRR
Hank Pratte	NuScale
Steven Bloom	NRR
Andrea Mota	NuScale
Marissa Bailey	ACRS
Ramon Gascot Lozada	
JJ Utberg	NuScale
Gurjendra Bedi	
김철민(CE0271)	
Eric Baker	NuScale
Jared Nadel	
Stephanie Roche Rivera	
Rim Nayal	NuScale
Omid Tabatabai	
Taylor Coddington	NuScale
Karl Gross	NuScale
Derek Widmayer	ACRS
Caty Nolan	COMM
Chulmin Kim	
Peter Shaw	NuScale
Thomas Hayden	NRR
Gary Becker	NuScale
Carolyn Fairbanks	
Tom Griffith	NuScale
Emily Larsen	NuScale
Kevin Lynn	NuScale
Erin Whiting	NuScale
Hayder Karaoglu	NuScale
Kevin Spencer	NuScale
Brian Wolf	NuScale
Ben Bristol	NuScale
Ata Istar	NRR
Yuken Wong	NRR
Stephen Hambric	Hambric Acoustics, LLC
Si Hwan Park	NRR
Sean Piela	NRR
Gregory Makar	NRR
Leslie Terry	NRR
Sunwoo Park	NRR
Peter Yarsky	RES
Zuhan Xi	NRR
Josh Miller	NRR
Rebecca Patton	NRR
Dong Zheng	NRR
Antonio Barrett	NRR

Paul Klein	NRR
Andrew Johnson	NRR
Steven Bloom	NRR
Nicholas Hansing	NRR
Alissa Neuhausen	NRR
Stewart Bailey	NRR
Dan Widrevitz	NRR