

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Nu-Scale Design Centered Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, February 18, 2025

Work Order No.: NRC-0226

Pages 1-203

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 NUSCALE DESIGN-CENTERED SUBCOMMITTEE

8 + + + + +

9 TUESDAY

10 FEBRUARY 18, 2025

11 + + + + +

12 The Subcommittee met via Teleconference,
13 at 8:30 a.m. EST, Walter L. Kirchner, Chair,
14 presiding.

15 COMMITTEE MEMBERS:

16 WALTER L. KIRCHNER, Chair

17 RONALD G. BALLINGER, Member

18 VESNA B. DIMITRIJEVIC, Member

19 CRAIG A. HARRINGTON, Member

20 GREGORY H. HALNON, Member

21 ROBERT P. MARTIN, Member

22 SCOTT P. PALMTAG, Member

23 THOMAS E. ROBERTS, Member

24 MATTHEW W. SUNSERI, Member

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 ACRS CONSULTANTS:

2 DENNIS BLEY

3 STEPHEN SCHULTZ

4

5 DESIGNATED FEDERAL OFFICIAL:

6 MICHAEL SNODDERLY

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

C-O-N-T-E-N-T-S

Opening Remarks	4
Discussion of NuScale SDAA Chapter 6	10
Staff's Evaluation of NuScale SDAA Chapter 6 . .	53
Discussion of NuScale SDAA Section 17.4 and Chapter 19	102
Staff Evaluation of NuScale SDAA Section 17.4 and Chapter 19	150
Public Comment	201
Adjourn	

P-R-O-C-E-E-D-I-N-G-S

8:31 a.m.

CHAIR KIRCHNER: Okay. Good morning. The meeting will now come to order. This is a meeting of the NuScale Design-Centered Review Subcommittee of the Advisory Committee on Reactor Safeguards.

I'm Walt Kirchner, Chairman of today's subcommittee meeting. ACRS members in attendance are Ron Ballinger, Craig Harrington, Robert Martin, and Thomas Roberts. ACRS members in attendance virtually via Teams are Vesna Dimitrijevic, Greg Halnon, Scott Palmtag, Matt Sunseri, and myself.

We have one of our consultants participating virtually via Teams, Dennis Bley. If I've missing anyone, either members or consultants, please speak up now. Michael --

DR. SCHULTZ: Walt --

CHAIR KIRCHNER: -- Snodderly -- yes.

DR. SCHULTZ: Walt, Steve Schultz is here.

CHAIR KIRCHNER: Oh, thank you. Our consultant, Steve Schultz, is also with us. Thank you, Steve. Michael Snodderly of the ACRS staff is the Designated Federal Officer for this meeting.

No member conflicts of interest were identified for today's meeting. And I know we have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 quorum as well. During today's meeting, the
2 subcommittee will receive a briefing on the staff's
3 evaluation of NuScale Power, LLC's US460 standard
4 design approval application, Chapter 6, engineer
5 safety features, Section 17.4 of Chapter 17,
6 reliability assurance program, and Chapter 19,
7 probabilistic risk assessment and severe accident
8 evaluation.

9 We previously reviewed the certified
10 NuScale US600 design as documented in our July 29,
11 2020 letter report on the safety aspects of the
12 NuScale small modular reactor. Like the staff, we are
13 performing a delta review between the two designs,
14 including a power uprate from 50 to 77 megawatts
15 electric per module. We are reviewing these chapters
16 as part of our statutory obligation under Title 10 of
17 the Code of Federal Regulations, Part 52, Subpart E,
18 Section 14.1, referral to the Advisory Committee on
19 Reactor Safeguards to report on those portions of the
20 application which concern safety.

21 The ACRS was established by statute and is
22 governed by the Federal Advisory Committee Act or
23 FACA. The NRC implements FACA in accordance with our
24 regulations. Per these regulations and the
25 committee's bylaws, the ACRS speaks only through its

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 published letter reports.

2 All member comments should be regarded as
3 only the individual opinion of that member, not a
4 committee position. All relevant information related
5 to the ACRS activity such as letters, rules for
6 meeting participation, and transcripts are located on
7 the NRC public website and can be readily found by
8 typing About Us ACRS in the search field on the NRC's
9 home page. The ACRS, consistent with the agency's
10 value of public transparency and regulation of nuclear
11 facilities, provides opportunity for public input and
12 comment during our proceedings.

13 We have received no written statements or
14 requests to make an oral statement from the public.
15 However, we have set aside time at the end of the
16 meeting for any public comment should there be any.
17 Portions of this meeting may be closed to protect
18 sensitive information as required by FACA and the
19 government in the Sunshine Act.

20 Attendance during the closed portion of
21 the meeting will be limited to NRC staff and its
22 consultants, applicants, and those individuals and
23 organizations who have entered into an appropriate
24 confidentiality agreement. We will confirm that only
25 eligible individuals are in the closed portion of the

1 meeting. The ACRS will gather information, analyze
2 relevant issues and facts, and formulate proposed
3 conclusions and recommendations as appropriate for
4 deliberation by the full committee.

5 A transcript of the meeting is being kept
6 and will be posted on our website. When addressing
7 the subcommittee, the participants should first
8 identify themselves and speak with sufficient clarity
9 and volume so that they may be readily heard. If
10 you're not speaking, please mute your computer on
11 Teams or by pressing *6 if you are on your phone.

12 Please do not use the Teams chat feature
13 to conduct sidebar discussions related to the
14 presentations. Rather limit use of the meeting chat
15 function to report IT problems. For everyone in the
16 room, please put all your electronic devices in silent
17 mode and mute your laptop microphone and speakers.

18 In addition, please keep sidebar
19 discussions in the room to a minimum since the ceiling
20 microphones are live. For the presenters, your table
21 microphones are unidirectional and you'll need to
22 speak into the front of the microphone to be heard.
23 Finally, if you have any feedback for the ACRS about
24 today's meeting, we encourage you to fill out the
25 public meeting feedback form on the NRC's website.

1 And with that, we'll now proceed with the
2 meeting. And I think, Mike, it's best for me to turn
3 to Bob Martin and let him run the meeting from there.
4 He'll be able to better coordinate than myself. So
5 with that, Bob, I think our next step is to turn to
6 the NRC project management team for NuScale.

7 MEMBER MARTIN: That's right. I think
8 it's MJ.

9 MR. Jardaneh: Yes, thank you. Good
10 morning, Chair. And good morning to ACRS subcommittee
11 members, NuScale participants, NRC staff, and members
12 of the public.

13 My name is Mahmoud Jardaneh. I serve as
14 the branch chief, the new reactor licensing branch
15 responsible for licensing of the NuScale US460 design
16 in addition new and renewed licenses at NRR. Thank
17 you for the opportunity today, for the staff and their
18 review of select NuScale US460 standard design
19 approval application or SDAA chapters and topical
20 reports.

21 As you are aware, the staff is reviewing
22 is reviewing all chapters of the SDAA concurrently
23 with standard completion dates based on the complexity
24 of the chapter and the extent of the changes from the
25 certified NuScale US600 design. Today, the staff will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 be presenting their review. That's six SDAA chapters,
2 including Section -- including Chapter 6, engineered
3 safety features, the remaining section of Chapter 17,
4 quality assurance and reliability assurance, and
5 Chapter 19, probabilistic risk assessment and severe
6 accident analysis.

7 Previously, the staff presented to this
8 subcommittee on Chapters 2, 3, 5, 7, 8, 9, 10, 11, 12,
9 13, 14, 16, portions of Chapter 17, and Chapter 18.
10 The staff also presented on the loss of coolant
11 accident evaluation model topical report, one of the
12 three topical reports associated with this
13 application. The staff is finalizing the review of
14 the remaining SDAA chapters of topical reports, and we
15 will inform the ACRS from the safety evaluation of the
16 remaining chapters where topical reports are available
17 to the ACRS.

18 Today's meeting, the staff will focus on
19 the delta from the design certification that the NRC
20 has and the subcommittee reviewed in the test. Once
21 again, thank you for the opportunity. And we look
22 forward to a good discussion today.

23 MEMBER MARTIN: Thanks, MJ. I assume
24 we'll move to NuScale. Tom?

25 MR. GRIFFITH: Good morning, ACRS

1 subcommittee members, NRC staff, NuScale staff on the
2 line, and the public. This is Thomas Griffith,
3 Licensing Manager for NuScale's US460 Standard Design
4 Approval Application. We are looking forward to the
5 opportunity today to present Chapter 6, 17.4, and
6 Chapter 19. I look forward to the discussion that
7 we're going to have today. And with that, I will turn
8 over to Tyler Beck to start the presentation on
9 Chapter 6.

10 MR. BECK: Hello. My name is Tyler Beck.
11 I'm a licensing engineer with NuScale, and I'm the
12 licensing engineer for Chapter 6 amongst some other
13 chapters.

14 Part of my time at NuScale, I was a
15 reactor systems engineer at the -- with NRC staff.
16 And part of my time with NRC, I got my bachelors of
17 science in nuclear engineering from University of
18 Tennessee. Next slide. We'd like to acknowledge that
19 this work, we have DOE support from. Next slide.

20 This is an overview of Chapter 6, and it
21 lists this section that we covered today. I'd like to
22 note that this is the design of engineered safety
23 features as discussed in the FSAR. Chapter 6 includes
24 a breadth of components and systems.

25 This presentation is not specific to the

1 accident sequences or evaluations such as Chapter 15
2 or the PRA which will be discussed later today. As
3 previously noted, there will be -- this presentation
4 will be a delta review from the US600 design
5 certification application to the US460 standard design
6 approval application. Next slide. Section 6.1 is
7 engineered safety feature materials.

8 And for noteworthy changes from the design
9 certification application, the containment vessel
10 upper portions of the vessel materials have changed.
11 So previously in the DCA, it was SA-508, low-alloy
12 steel, and the SDA design proportions are F6NM
13 martensitic stainless steel. Along with that change
14 in the SR Section 6.1, we're added a new table for
15 dissimilar metal welds.

16 It describes dissimilar metal welds. And
17 we've implemented additional welding controls such as
18 post weld heat treatment controls and in regard to the
19 staff audit and NRR review base. Next slide.
20 Mentioned the material change is the significant
21 change here.

22 And here we have a couple of figures from
23 the application. On the right, you can see the
24 containment system as a whole. On the left, you can
25 see the lower containment vessel and you can see where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the material change is from FXM-19 to F6NM.

2 And along these lines, I believe there was
3 an outstanding question from the last meeting on FXM-
4 19. And there was a mention of a paper. And we just
5 wanted to clarify that we had reviewed the paper.

6 And I believe we determined it wasn't
7 applicable in certain respects to our design. And we
8 have a couple of subject matter experts on the phone.
9 And I think, Steve, you wanted to say something in
10 this regard.

11 MR. WOLBERT: Sure. Yeah, good morning.
12 This is Steven Wolbert, the manufacturing engineer
13 with NuScale. Yeah, we did review the paper and I
14 have seen this paper before among others.

15 Some of the conclusions drawn from the
16 paper, I guess, start off the boundary conditions of
17 the paper studied. This paper primarily looked at
18 case hardening via nitride treatment on XM-19. I
19 guess just a noteworthy comment there is we don't
20 employ any case hardening on XM-19.

21 It's kind of a more severe condition
22 tested there. And then additionally, the paper also
23 studied XM-19 tubing with 25 to 35 percent cold work
24 and case hardening. But of these conditions are much
25 more extreme than what NuScale permits. And then in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 addition, the study concluded that the XM-19, even in
2 those extreme conditions, actually outperformed the
3 control specimens of a standard F-304 material. So
4 we're confident that we've covered most of the
5 concerns raised by the paper, the conditions raised by
6 the paper and welcome any other questions in this
7 regard.

8 MEMBER MARTIN: This is Bob Martin. And
9 we'd like to have some questions. Regarding -- and so
10 XM-19 is relatively recent addition to the code case.
11 Is that correct? I'll look over to Ron.

12 MEMBER BALLINGER: You said with respect
13 to --

14 (Simultaneous speaking.)

15 MEMBER BALLINGER: It's been around
16 forever.

17 MEMBER MARTIN: Well, the material itself
18 --

19 MEMBER BALLINGER: Yeah.

20 MEMBER MARTIN: -- right? So I was just
21 going to ask the question. So say, 50 years from now
22 you have this containment sitting in water.
23 Obviously, you have to have the standard inspections
24 and what have you.

25 But you find that there's a problem. Is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 this a containment that can be replaced? So if you
2 wanted to go, say, 100 years. Or what would happen at
3 that juncture ran into a problem and everything else
4 is working just fine?

5 MR. WOLBERT: Yeah, this is Steve Wolbert
6 again. Prior to NuScale, my career was component
7 repair and replacement with another company where we
8 do steam generator replacements, head replacements,
9 those types of things. Obviously, an effort like that
10 would be pretty extensive.

11 The first option if you ran into some kind
12 of problem would be to a field repair. And so we have
13 looked into that type of methods that one would
14 employ. Really a lot of that starts to fall into the
15 Section 11 -- ASME Code, Section 11, rules and
16 requirements.

17 So we do have NuScale members on those
18 committees in ASME that are looking into those options
19 and additionally with our supplier partners. Now this
20 is something that would really be on the plant owner
21 to control but is something that we understand the
22 question and welcome it and want to have those
23 dialogues with our customers as well. So we do have
24 some options that we're looking into, including some
25 additional -- we've done extensive weld testing with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 our suppliers. And we do believe there are some
2 relevant field repair methods that would be
3 applicable.

4 MEMBER MARTIN: Right. Appreciate that.
5 Obviously, it's just kind of a sidebar kind of
6 question. But certainly the uniqueness of the design
7 gives you certain opportunities that maybe other
8 plants don't have and put some resilience into your
9 design where another alternative would not necessarily
10 have that. So I appreciate that answer. Go ahead,
11 continue.

12 MR. BECK: Next slide, please. Section
13 6.2 is containment systems. For the significant
14 changes from the DCA, the last slide, we mentioned the
15 material changes for the containment vessel. There
16 are a number of containment vessel penetrations from
17 the DCA to the SDA.

18 The design ratings have been increased.
19 So the design pressure ratings have been increased
20 1,200 psi. Design pressure rating has been increased
21 to 600 degrees Fahrenheit.

22 And then otherwise for containment vessel
23 penetrations, the CVCS injection and discharge line
24 penetrations include venturis that are integral to the
25 penetration. And that's to mitigate potential breaks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that occur outside of the containment vessel. On the
2 topic of combustible gas control, we have differing
3 strategy in the SDA.

4 So in this design, we include a safety-
5 related passive autocatalytic recombiner or PAR. And
6 that maintains an inert containment atmosphere. With
7 that change, it removes potential combustion loads
8 because flammability precluded in an inert environment
9 is maintained. And it also coincides with the
10 exemption we have for combustible gas monitoring
11 requirements. And so there are no combustible gas
12 monitoring provisions strictly in the containment
13 vessel.

14 MEMBER ROBERTS: Tyler, this Tom Roberts.
15 The removal of combustion loads will maintain an inert
16 environment, reading through the staff's SE, they seem
17 to indicate that you have maintained the combustion
18 load. And there's an RAI where you discuss that you
19 did the analysis to show that you could still
20 withstand a combustion load if it were to occur. So
21 I'm a little confused as to what's the intent of that.
22 Is the intent to -- or I would say, what is the
23 intent?

24 MR. BECK: I think you're referencing
25 Chapter 19, adiabatic, isochoric, complete combustion

1 analysis.

2 MEMBER ROBERTS: It's the Chapter 19 RAI
3 that has a change in Chapter 6 in it. And the staff's
4 Chapter 6 safety evaluation basically talked about
5 that. It says part of the basis for accepting the
6 pressure table of the PAR is you still have the
7 analysis that you can withstand the combustion load
8 even if the PAR is there to inert the environment.
9 You've still got the analysis and if you had the
10 detonation, it would still be covered. I was trying
11 to understand what would that bullet mean.

12 MR. MULLIN: Yeah, this is Etienne Mullin
13 from NuScale PRA. That analysis was part of several
14 analyses that we prepared and shared with the staff to
15 demonstrate that we don't need the PAR for the success
16 criteria of the PRA. We don't need the PAR to prevent
17 a core damage event.

18 We don't need the PAR to prevent a large
19 release event or core damage event. And so we
20 prepared several analyses to demonstrate that the PAR
21 wasn't necessary. And for that reason, it's not
22 included in our containment event trees.

23 MEMBER ROBERTS: So I'm confused what this
24 bullet means. It seems like you've done the analysis
25 with a convection mode in support of the PRA. Is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a nondesign analysis so it's got less QA? I'm just
2 trying to understand what the distinction is.

3 MR. MULLIN: I think that's a fair
4 characterization. The combustion analysis that was
5 performed is for a beyond design basis event prepared
6 with different analysis assumptions.

7 MR. BECK: And I believe if you include
8 detonation loads, for example, those are included in
9 the individual design specifications for the
10 components. And that is not specifically included in
11 the US460 standard design because we do preclude those
12 loads.

13 MEMBER ROBERTS: Yeah, okay. It seemed to
14 me the most important point is that the containment
15 itself is essentially -- I think it's uprated, right,
16 from the US600 containment. So there's no reason to
17 believe that you've got more vulnerability to
18 detonation. Plus you have -- you might call it
19 defense in depth multiplier, though you have a much
20 lower likelihood of having a combustion event. Is
21 that a fair characterization?

22 MR. BECK: Yeah, I would say that's a fair
23 characterization except I wouldn't say much more lower
24 likelihood with the PAR that the loads are precluded
25 and detonation is precluded entirely.

1 MEMBER ROBERTS: Okay, thank you.

2 MEMBER MARTIN: I wanted to get a
3 clarification on your last bullet regarding exemption
4 from monitoring requirements. You obviously are going
5 to -- I mean, it's an essential vacuum, right? You
6 will be monitoring pressure which would be basically
7 zero all the time, correct?

8 What do you mean specifically by that?
9 Because you have to have some safety-related
10 monitoring because it might -- and if you had air in
11 there, again, that's a source term of the combustion
12 event. That would factor back into, say, a design
13 basis analysis because air would affect, say,
14 condensation rates and such like that. I want to give
15 you an opportunity to clarify what you mean by
16 monitoring requirements.

17 MR. BECK: There are not specific
18 provisions within containment to monitor hydrogen gas
19 and oxygen gas concentrations.

20 MEMBER MARTIN: But at least pressure?

21 MR. BECK: Yes.

22 MEMBER MARTIN: So if pressure was
23 elevated from at least the target, you would otherwise
24 expect that more than likely you had some kind of air
25 ingress. And then you could act on that. So it's not

1 like you have no monitoring.

2 MR. BECK: Yes.

3 MEMBER HARRINGTON: This is Craig
4 Harrington. The PAR, do you have to do anything in
5 the outage? Just continue happily combining oxygen
6 with any hydrogen it finds? Or what happens?

7 MR. BECK: The PAR is included in tech
8 specs. And there are inspection and testing
9 requirements to test some sample of the catalytic
10 plates to make sure they're recombining the right
11 amount of hydrogen and oxygen.

12 MEMBER HARRINGTON: Okay. That continues
13 -- when you open the system up to atmosphere, it just
14 keeps doing the same thing?

15 MR. BECK: Yes.

16 MEMBER HARRINGTON: Okay. And a couple
17 things unrelated probably to the delta between the 600
18 and this design, I wasn't around for that. There was
19 wording in the FSAR chapter that says it will be
20 fueled in a partially flooded condition. NPM is moved
21 loosely from the reactor building frame to the
22 refueling area without loss of reactor coolant
23 inventory and refueled in a partially flooded
24 condition, precluding operation with reduced
25 inventory. What does that mean?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BECK: That was in Chapter 6.

2 MEMBER HARRINGTON: Yes, Section
3 6.2.1.1.2.

4 MR. BECK: I'm not sure on the intent of
5 the statement originally.

6 MR. MULLIN: Yeah, I'm not familiar with
7 the statement you're referring to. But the NPM is
8 filled with water before being moved. It's not filled
9 to the top. It's partially filled up to approximately
10 the pressurizer baffle plate is being referred to.

11 MEMBER HARRINGTON: I mean, it seemed to
12 be after. You pick it up. You move it over. You
13 separate the flanges, lift the top off.

14 MR. MULLIN: The core is certainly
15 submerged by the depth.

16 MEMBER HARRINGTON: I mean, it seemed
17 obvious. I just didn't make any sense of the words.
18 And there's also discussion of four instruments that
19 measure and monitor containment water level. This is
20 during operation during an accident phase. They're at
21 the reactor pressure boundary interface, four
22 independent channels of CNV water level
23 instrumentation. What kind of instruments do you use?

24 MR. BECK: Do we have anyone from I&C on
25 the call to discuss the containment vessel water level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 instrumentation?

2 MR. MEYER: Yes, Rob Meyer, NuScale, I&C.
3 What would you like explained?

4 MEMBER HARRINGTON: What kind of
5 instrumentation are you using?

6 MR. MEYER: Oh, it's a thermal dispersion
7 sensor.

8 MEMBER HARRINGTON: Okay, okay. So you
9 just get elevation readings at discrete points? Okay.

10 MR. MEYER: That's correct.

11 MEMBER HARRINGTON: Okay.

12 MEMBER PALMTAG: This is Scott Palmtag.
13 Oh, sorry. I'm sorry, Craig. Go ahead.

14 MEMBER HARRINGTON: I'm done, Scott.

15 MEMBER PALMTAG: Okay. This is Scott
16 Palmtag. Slightly off topic, but kind of since we're
17 talking about the containment and instrumentation, I
18 have some questions about the valves that are used
19 inside. I think it's RVV and RPV. Can you explain
20 that?

21 MR. BECK: You're asking about the
22 containment isolation valves?

23 MEMBER PALMTAG: No, the -- sorry. It's
24 later in the slides.

25 MR. BECK: Oh, you're talking about the

1 ECCS valves?

2 MEMBER PALMTAG: Yes.

3 MR. BECK: There will be a slide --

4 MEMBER PALMTAG: Those are inside the --

5 MR. BECK: Yes, those will be discussed in
6 a few slides.

7 MEMBER PALMTAG: Okay. Thank you.

8 MR. BECK: Next slide.

9 CHAIR KIRCHNER: This is Walt Kirchner.
10 Going back to Craig's question about the PARs. So
11 when you do a refueling operation, the containment
12 isn't entirely flooded. You keep the PAR -- the PAR
13 location is high in the containment and it is not
14 immersed in water?

15 MR. BECK: That's correct.

16 CHAIR KIRCHNER: Okay. And then Craig,
17 what I remember from the DCA was that they were
18 considering for the level measurements a radar kind of
19 based system rather than this -- I think they call it
20 a dispersion type sensor now. So that was a
21 significant change in the SDA design to my knowledge.

22 MEMBER HARRINGTON: Thanks, Walt.

23 MR. BECK: Next slide. Continuing on
24 containment changes for containment isolation. A
25 significant change from the DCA is the addition of a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 containment isolation test fixture valve. It's
2 between the CNV nozzle safe-end and the containment
3 isolation valve body.

4 This is an enhancement to improve the
5 ability to perform Appendix J testing whereas the DC
6 design included first of a kind testing features that
7 are integrated into the CIV body. The containment
8 isolation valves are welded directly to that CITF.
9 And the CITF is welded directly to the nozzle safe-
10 end.

11 And you can see that depicted on a picture
12 in the right side where CITF is. There also was a
13 change in the closure time of CIVs which was changed
14 from 7 seconds to 10 seconds now in the SDA.

15 MEMBER HARRINGTON: So this is Craig
16 Harrington again. On the CCW line isolation states
17 that two CIVs instead of just the one that would be
18 required for GDC 56, the particular issue that drove
19 the decision to go conservative?

20 MR. BECK: I'm not sure of that. If
21 anyone is on the call that's aware of the RCCW CIVs.
22 However, I do believe that kind of standard CIVs
23 across the penetrations where we can. And so that
24 might be the reason why.

25 MR. LASSITER: Tyler, this is Dan

1 Lassiter, NuScale, design engineering. The impetus to
2 have the dual isolation values on the closed lines is
3 so that we don't have to design the piping and
4 components of that line to -- as a containment
5 boundary particular ASME Class 2. So we design the
6 piping and components inside containment with lower
7 pressure boundary integrity requirements and just
8 rely, excuse me, on the containment isolation valves
9 themselves.

10 MEMBER HARRINGTON: Just standard design
11 tradeoffs. Okay. And just one thing that I noticed,
12 it just seemed like a big of an inconsistency between
13 -- this is in Section 6.2.4.2.2, component design.
14 And it talked about the SSCIVs.

15 The tech says it allows for maintenance
16 repair and replacement. Those same words aren't there
17 for the PSCIVs. I'm just curious if that was just an
18 oversight, just an inconsistency in words, or if there
19 was some other issue.

20 MR. BECK: I would imagine that is just an
21 oversight, an inconsistency.

22 MEMBER HARRINGTON: Okay, thanks.

23 MR. BECK: Next slide. The last slide for
24 Section 6.2. For the containment response analysis,
25 it was previously presented as part of the

1 methodologies previously presented as part of the LOCA
2 evaluation model topical report. So the discussion
3 today is just really going to talk about the
4 implementation.

5 For initial conditions, those have been
6 changed from the DCA to align with the new design. An
7 example of that would be ultimate heat sink pool level
8 exchanged. However, it's not really that.

9 There is a similar amount of stored energy
10 compared to the US600. Because of our operating
11 containment design, there is significantly more design
12 margin, particularly with pressure. And you can see
13 on the right side peak cases.

14 And so the primary events peak pressure is
15 similar between the two designs. But because of the
16 operating containment vessel design rating, there's
17 more margin. And you can see that peak temperature is
18 also comparable.

19 MEMBER MARTIN: Question, this is Bob. So
20 what drove the increase in design in pressure?
21 Anything -- 10 percent is, I guess, template guidance.
22 And before, I guess you were kind of just not quite 10
23 percent there.

24 But you definitely are. And then you were
25 10 percent even with respect to the old design

1 pressure. Now you've gone to 1,200. What drove that
2 change?

3 MR. BECK: More margin was the goal
4 certainly. And we're over 20 percent now. So a
5 little above the SRP guidance of 10 percent, and I
6 think that was a significant part of the decision.

7 MEMBER MARTIN: Okay. What margin? The
8 cost take a little bit more. But you decided that the
9 safety margin was more valuable to you than, say, the
10 cost of the vessel itself. Another thing that's
11 obvious here is your secondary event peak pressure
12 where all the other ones kind of look more or less
13 what you'd expect. That one is doubled. So that has
14 implied that the event has changed or the design.
15 What drove that?

16 MR. BECK: And we'll get to the --

17 MEMBER MARTIN: To the extent that you can
18 talk about it.

19 MR. BECK: And we'll get to the ECCS
20 changes in the next slide, I think, maybe. But it's
21 the removal of the IABs. And so you've have a main
22 steam line break and a coincident ECCS actuation. And
23 so whereas in the DCA design, the valves had the IABs.
24 And so now you have that valve actuation with the main
25 steam line break and thus form --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: How to get it twice.

2 MR. BECK: And then the last bullet points
3 on this slide, so there's previous COL item in the DCA
4 for containment leakage rate testing. That COL item
5 has been removed simply because those requirements are
6 already specified the requirement, that's already
7 required and specified. So that was removed.

8 And we've also removed a COL item that
9 related to containment vessel volume. And that is
10 because there is now an ITAAC that confirms that
11 parameter. And for Section 6.2, there's extensive
12 audit. And we had 17 audit items and 4 RAIs resolved
13 in this section. Next slide.

14 Section 6.3 is the emergency core cooling
15 system. For ECCS changes versus the ECCS valve
16 changes, and several changes here related to safety
17 analysis optimization, some of which you have already
18 or you have already heard about. So there are two
19 vent valves from three in the DCA.

20 And that change is made coincident with
21 the ultimate heat sink pool level change. The vent
22 values do not include inadvertent actuation block
23 valves. And so now the vent valves open upon ECCS
24 actuation.

25 The IABs are still on the recirculation

1 valves. However, the threshold and release pressures
2 are lower than the SDA design. And there are integral
3 venturis to the reactor recirculation valves and
4 reactor vent valves that limit flow during high
5 differential pressure conditions.

6 And that entry change is made to decouple
7 the function -- the flow limiting function of the
8 valve internals. And now the venturi performs that
9 function. For other ECCS changes, there previously
10 was one trip solenoid valve per ECCS main valve in the
11 DCA design.

12 And now in the SDA, there are two in
13 series trip solenoid valves per ECCS main valve. And
14 then the last bullet on the screen is related to
15 actuation signals. So there was -- the DCA, there was
16 a high CNV level and low RCS pressure ECCS actuation
17 signals.

18 And those have been removed. And instead,
19 now there is a low and low-low RPV riser level
20 actuation signal. Additionally, there are now high-
21 high RCS pressure and high-high RCS Tave ECCS
22 actuation setpoints or beyond design basis events.

23 MEMBER HARRINGTON: This is Craig again.
24 Knowing in the review, the ACRS review of the US600
25 design, there were -- I guess there was ongoing

1 testing of these valves at the time. I guess it's
2 completed now.

3 But one of the concerns was just the
4 complexity of the valve system and making sure that it
5 would be reliable in adding another trip solenoid
6 valve maybe helps with inadvertent actuation. But
7 makes it more complex again. Has that all been
8 thought through? I'm sure it has been thought
9 through.

10 MR. BECK: For our Chapter 15 analysis of
11 that we do to the periodicity of failures and that
12 sort of thing. And that is included in our design and
13 safety analysis.

14 MEMBER HARRINGTON: So return to that --

15 MR. LASSITER: This is Dan Lassiter,
16 NuScale, design engineering. Just to comment briefly
17 on the test programs, there was a test program
18 executed specifically for the purpose of DCA review.
19 And that use representative of components and
20 demonstrated that the valve performed all safety
21 functions with the representative arrangement of parts
22 as you said as a valve system.

23 Between DCA and SDA, we've also executed
24 a fully prototypic valve test program, NTS,
25 Huntsville. I think it changed names now again. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that covered really the whole scope of what we intend
2 to qualify the valve for.

3 There will be some additional testing in
4 the future or qualification testing to meet all ASME
5 QME-1 qualification requirements. But the valve
6 performed all its safety functions up to full
7 pressure/temperature conditions. So we have high
8 confidence in the ability of the ECCS valve to perform
9 its safety function.

10 MEMBER HARRINGTON: Okay. Thanks. I
11 appreciate that.

12 MEMBER ROBERTS: This is Tom Roberts. I
13 had two questions on inadvertent actuation of these
14 ECCS valves. One is there was a 2019 SECY document
15 that talked about the potential IAB valve to not swing
16 shut during the accident.

17 And as I understood from that SECY was
18 inadvertent actuation of a valve during the event.
19 With your change now, two of the valves -- the vent
20 valves don't have IABs at all. Is the concern
21 identified in that document still in effect?

22 Because that seemed like a reliant with
23 the IABs to prevent basically anything if they don't
24 exist in those valves. So there's a whole debate
25 about single failure criteria and how they would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 apply. And is any of that discussion relevant? Or is
2 it all covered, I imagine, with the design change and
3 the IABs?

4 MR. BECK: Do we have the analysis from
5 hydraulics group?

6 MR. CUMMINGS: I can address that. So
7 this is Kris Cummings, NuScale. I've been with
8 NuScale for about 5 years, 25 years of experience in
9 the industry working on fuel safety analysis and spent
10 fuel issues.

11 So in particular, we still have the IAB on
12 the RRV. So that's still applicable. And that SECY
13 was germane to whether that component was essentially
14 single failure criterion needed to apply to that.

15 So the Commission decided that was not the
16 case. So we still apply that aspect of it to the
17 safety analysis. But we don't apply single failure.
18 So it's basically determined that it's very similar to
19 a check valve. So from that perspective of the SECY-
20 19-0036, that part still applies.

21 MEMBER ROBERTS: But what's the scenario
22 that currently exists with the new design where you
23 would need to take account for that exception? Is
24 there a scenario where it matters?

25 MR. CUMMINGS: Yeah, I think I'd have to

1 ask Meghan to chime in on the safety analysis side of
2 that or Devon, if you're on.

3 MS. McCLOSKEY: This is Meghan McCloskey
4 from NuScale safety analysis. The IAB single failure
5 itself has a -- during the scope of events that we
6 analyze in Chapter 15, the IAB single failure has
7 relatively little impact on our progression now with
8 the exception of what scope of initiating events we
9 need to consider. In the DCA design, we evaluated the
10 inadvertent opening of one ECCS valve, either one vent
11 valve or one recirculation valve as the inadvertent --
12 as the initiating event.

13 And then we apply the deterministic
14 Chapter 15 criteria of single failures and loss of
15 power scenarios. And so what the IAB SECY meant to us
16 in the DCA space was that it was not necessary to
17 evaluate the simultaneous opening of two valves
18 because one was the initiating event. We assumed a
19 loss of DC power supply, again, a very deterministic
20 assumption.

21 And then an IAB single failure, we only
22 needed to cover the single event and the loss of power
23 supply. In the SDA design, we evaluate the scope of
24 events that are appropriate for this ECCS valve
25 system. So we cover inadvertent opening of a single

1 value.

2 We also address an inadvertent ECCS
3 actuation signal that results in two vent valves
4 opening simultaneously. And we cover those scenarios
5 with and without power available. So one of our
6 limiting cases is evaluating an inadvertent recirc
7 valve opening event with loss of DC power. And that
8 results in three valves opening simultaneously. The
9 IAB SECY continues to apply in that it's not necessary
10 to evaluate all four valves opening simultaneously in
11 that scenario.

12 MEMBER ROBERTS: Okay. Thank you. I
13 think I understand. Would it make a difference?
14 Three valves seems like you've got most of the system
15 already in actuation. Is there a benefit to having
16 the fourth valve assumed to not open?

17 MS. McCLOSKEY: There's still a bit of a
18 benefit in terms of how much of a flow in -- a core
19 flow in reduction. It has an MCH-4 margin that we're
20 evaluating.

21 MEMBER ROBERTS: Yeah, okay. Thank you.
22 That's helpful. The other question is related. It
23 has to do with the inadvertent opening of a reactor
24 vent valve.

25 We had a discussion last month in a closed

1 session about how your safety analysis doesn't assume
2 a complete loss of all the DC power coincident with an
3 unrelated event. And the reasoning was the closed
4 head. But I think the fact that you have that
5 assumption is certainly not closed.

6 That was just specific to the loss of DC
7 power which would cause two RVVs to open spuriously.
8 But that's not the only way you get a spurious opening
9 of an RVV, right? You have other ways you could do
10 it. Is spurious opening of one RVV a problem or is it
11 just two that's a problem in the analysis?

12 MS. McCLOSKEY: Spurious opening of one
13 vent valve is part of the design basis initiating
14 event scope. And we take the -- we evaluate the loss
15 of DC power coincident with the initiating event. And
16 as we -- I think as we discussed in the last meeting
17 or a couple before that, in the Chapter 15 design
18 basis space, we don't stack initiating events on top
19 of each other, so to speak.

20 And so we take the valve opening as an
21 initiating event or we evaluate an inadvertent ECCS
22 actuation. But we -- it's not necessary to assume
23 that happens randomly in the middle of some other
24 event like a reactivity insertion event or a cool down
25 event. That's beyond the scope of the design basis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 event.

2 MEMBER ROBERTS: Right, I understood that.
3 That was specific to the loss of DC power. I'm
4 thinking about other ways to get an actuation of a
5 reactor vent valve which would potentially be a single
6 failure. You would need to assume it in conjunction
7 with this unrelated reactor condition event.

8 One scenario that comes to mind is if
9 you've got the two trip valves, right, for each RVV.
10 But I think in a failure in one trip valve as was
11 discussed in the Chapter 16 review, there's no
12 requirement in tech specs to limit operation. So if
13 you had one trip valve that was open, you could still
14 continue to operate the plant which now you'd be
15 portable to a single failure of the other trip valve
16 causing inadvertent actuation of that RVV. Is that a
17 scenario that would be of concern?

18 And if it would be a concern, is it
19 something you would need to consider as a single
20 failure? Or is that wrapped up in the 2019 SECY, very
21 unlikely single failure basis? That's something I
22 didn't see discussed is other ways to get a single RVV
23 to trip spuriously. And that's one that occurred to
24 me. There may be others. I don't know.

25 MS. McCLOSKEY: Right, right, sure. But

1 that would be a random failure that's not impacted by
2 the initiating event or the event progression. And so
3 when we consider the single failures, we're
4 considering for the active system components, it's
5 failure to -- it's really related to failure to
6 actuate upon demand.

7 The electrical system components can have
8 latent failures. And that's why the module protection
9 systems are designed to accommodate that with the
10 logic. But in the case of a solenoid for the ECCS
11 valve, if the ECCS valves are not being demanded by
12 the initiating event, it would have to be a random
13 failure that occurs. And that's outside the design
14 basis event progression as well.

15 MEMBER ROBERTS: I would've thought that
16 a single failure criteria would have you assume that
17 there's an unrelated failure occurring in the
18 protection system, either active or passive. The
19 passive failure exception for 10 CFR 50 is only for
20 fluent systems or mechanical systems, not for
21 electrical systems. So it would seem like you would
22 need to include that as a potential single failure.

23 I guess I'm wondering why you wouldn't.
24 Now it's the combination of the solenoid being pre-
25 failed and this single failure of the control system

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 is very unlikely. I see you can probably make a
2 similar argument about likelihood.

3 I don't know if you were making that
4 argument or the argument you're making is that this is
5 not a valid unrelated signal failure you assume occurs
6 coincident with the casualty of the event. I'm just
7 trying to understand which it is. And the general
8 question, I suppose, is, is there a requirement to
9 look at the vulnerability to inadvertent trip of the
10 ECCS valves given this linkage to unrelated transient
11 events?

12 MR. GRIFFITH: So this is Thomas Griffith,
13 licensing at NuScale. So let's make sure I understand
14 what you're saying clearly is that for the RVVs, you
15 have two solenoids that need to de-energize in order
16 to cause an actuation. And when I hear the concern is
17 if one of the solenoids is out of service and is in
18 the open position meaning that you are one solenoid
19 away from potentially having an inadvertent operation
20 of a relief valve. Is that the setup scenario?

21 MEMBER ROBERTS: Yes.

22 MR. GRIFFITH: Okay. So I would expect
23 that an operating plant evaluates and takes control of
24 that situation using the correct batch in process as
25 well as maintenance role. And the online risk program

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 would have to evaluate the time that it's acceptable
2 to stay in that position. And in my view, this is no
3 different than if a half scram was to come in on a
4 plant or a half actuation of a safety system. So
5 obviously, there's some period of time that would be
6 required for an operating plant to evaluate the
7 condition, assess risk, and take appropriate
8 corrective actions commensurate with the safety
9 significance.

10 MEMBER ROBERTS: Yeah, I think the
11 distinction -- you can tell me if I'm wrong. A half
12 scram is in the safe direction. So you're closer to
13 losing continuity of power which is obviously
14 something the plant wants to avoid because you want to
15 keep running.

16 But for inadvertent actuation of the ECCS
17 valve, there's a potential safety implication that if
18 you have this unrelated reactivity initiated event and
19 you were single failure would be the actuation of the
20 other solenoid. Then that would now compound the
21 event to the extent that you would see your CHF
22 limits. Now you discussed last month that's also --
23 there's margin in your CHF analysis. Then there's
24 other arguments you can make. I was trying to
25 understand just what the line was in terms of how you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 parse single failure and the unrelated event.

2 MR. GRIFFITH: I think Chapter 15 already
3 analyzes the RRVs spuriously opening with a concurrent
4 loss of DC power. In the event that the solenoid that
5 was out of service was on the RRV, you have the IAB
6 that still exists. And given that the RVVs don't have
7 the IAB and you assume a loss of DC power, that event
8 is analyzed in the design basis.

9 MEMBER ROBERTS: Yeah, the event I'm
10 asking about is the unrelated reactivity addition. So
11 that one, the discussion we had last month is you, I
12 think justifiably, are assuming that you don't lose
13 your reliable DC power system coincident with that
14 event because that's a redundant system and there's
15 reasons why it's reasonable to not assume loss. So
16 I'm asking about other ways to inadvertently operate
17 the RVV during this unrelated reactivity initiated
18 event and whether you thought through what the
19 requirement is to reasonably prevent them and whether
20 that's a constraint that ought to be covered in
21 Chapter 6.

22 MR. GRIFFITH: I think our discussion is
23 that a loss of DC power de-energizes the solenoids and
24 results in the RVV's opening. Whether or not an RVV
25 solenoid is out of service or not, the failure that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 being discussed there is a loss of DC power. So the
2 total number of solenoids, if one is already in the
3 fail safe position, there's less solenoids to have to
4 move to the safe position. The safe position for ECCS
5 is in the open position.

6 MEMBER ROBERTS: Right. But there's more
7 scenarios once you got a solenoid out of service that
8 causes inadvertent actuation of the RVV.

9 (Simultaneous speaking.)

10 MEMBER ROBERTS: Lots of things beyond
11 loss of DC power that can cause the other solenoid to
12 trip and then the RVV to open.

13 MR. GRIFFITH: So I think I agree with you
14 that the likelihood of an event that results in that
15 RVV to open because there's only one of two solenoids
16 in service is an accurate statement because there's
17 only one solenoid remaining. However, I would argue
18 that is appropriately managed under the online risk
19 program by the licensee.

20 MEMBER ROBERTS: Right. Probably the
21 continuity of operation perspective.

22 MR. GRIFFITH: Correct.

23 MEMBER ROBERTS: Not from the -- you now
24 have either an assumed or a stated assumption in the
25 safety analysis that an event valve not opened

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 coincident with a reactivity addition event. There is
2 a distinction there, I think.

3 MR. GRIFFITH: Yeah, and I think that what
4 Chapter 15 specifies specifically is that the IORV
5 event needs to be less -- the inadvertent actuation of
6 ECCS needs to have a frequency of less than once per
7 module lifetime. And so you would have to evaluate an
8 operability evaluation whether or not you're in
9 conformance of your licensing basis and for how long
10 that service could take place. But that is not --
11 that would be a more complex evaluation based upon
12 whatever failure occurred.

13 MEMBER ROBERTS: Yeah, okay. I think I'll
14 ask the staff for their view when they come up.
15 Again, I don't know that I'm concerned about the
16 combined likelihood of these because I think they're
17 extremely low. I was trying to, again, understand
18 what your threshold was for what single failures you
19 would still assume in your safety analysis for these
20 things like the reactivity initiated events where the
21 loss of DC power I think we've discussed at length and
22 it's reasonable.

23 The system is very reliable and it's
24 redundant. And it's nonsafety which is almost a term
25 as opposed to a real distinction for the reliability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of that system. But for these other scenarios that
2 cause inadvertent actuation, I'm not sure that same
3 argument applies. And that's what I'm trying to
4 understand.

5 MR. GRIFFITH: Yeah, so I think I'd like
6 to point out that failure of ECCS to actuate properly
7 contributes significantly to the overall CDF of the
8 plant. And I think that that'll be discussed as part
9 of Chapter 19 is that over -- and Jim, you can correct
10 me here. But roughly 90 percent of the core damage
11 events is due to the ECCS not actuating properly. And
12 I think, Kevin, I think you -- Kevin Lynn, if you're
13 on the line, you had something you want to join in
14 here?

15 MR. LYNN: Yeah, this is Kevin Lynn of
16 licensing. I'd just like to add I think one of the
17 things is when it comes to our design to keep in mind
18 is that actuation of ECCS is a safe -- is the safe
19 position. So it's similar to Tom's analogy with
20 putting the reactor at an operating plant, putting it
21 in half trip.

22 So you're essentially putting ECCS in a
23 half trip situation here in your postulating scenario
24 where on solenoid valve is out of service. So you're
25 halfway to ECCS actuation. And in our plant, ECCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 actuation puts us in a safe state.

2 So there's not a concern about going to a
3 safe state. The issue is as you've raised it is about
4 how do you interpret that in terms of the Chapter 15
5 assumptions. So NuScale's position is when we talk
6 about single failures to apply, if you look at the
7 history of the discussion, it's always applied in
8 terms of applying the single failures to things that
9 mitigate the event.

10 So for example, at an operating plant, if
11 you need diesel to start to mitigate that event while
12 you single fail one of the diesels because that hurts
13 you. In our case if we're talking about a reactivity
14 insertion event, you don't need ECCS to actuate. So
15 applying a single failure to ECCS doesn't make sense.

16 ECCS is a separate system not being relied
17 upon for that particular event. So what we're doing
18 is we're saying we're not going to take a single
19 failure that initiates a different event during an
20 unrelated event when there's no reason to assume so.
21 So I think that's the key is when you apply the single
22 failure, you don't apply it to unrelated systems. You
23 apply it to mitigated systems. And for these events,
24 like a reactivity assertion event, ECCS is not a
25 mitigated system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER ROBERTS: Okay. Yeah, I understand
2 the argument. I'm kind of puzzled about the active
3 versus passive failure aspect of it. But I'll think
4 about that. So thank you.

5 MEMBER HARRINGTON: One other question on
6 the IAB. Clear the block at 450 psid differential
7 pressure. And at that point, I don't remember there
8 being a discussion on this. But it seems like
9 obviously you would then be flowing water out the RRV
10 instead of flowing back in. Is that a problem or why
11 pick 450 and not some lower differential?

12 MR. BECK: I think there are manufacturing
13 of procurement reasons for the thresholds picked for
14 the valve. But we do analyze the 450 psid. And that
15 released pressure on the recirculation valves.

16 MEMBER HARRINGTON: From an event
17 progression standpoint, losing the water out the RRV
18 at that stage doesn't --

19 MR. BECK: In the DCA, I would say that
20 the release pressure was 900. So it is reduced in
21 this design by a significant amount.

22 MEMBER HARRINGTON: Okay, okay.

23 MR. BECK: Next slide. For the ECCS
24 changes, there is now an ECCS supplemental boron or
25 ESB feature. That includes boron hoppers, condensate

1 channels, dissolvers, and mixing tubes. And there's
2 a schematic FSAR on the right side.

3 You can see the hoppers, dissolvers, and
4 mixing tubes. And on the next slide, there's another
5 picture that's a little bit more detailed of the FSAR.
6 It shows more detail to the ESB system. I'll show
7 that in a second.

8 But for the last two points for Section
9 6.3, there's also an added 8-hour ECCS actuation timer
10 following reactor trip in the SDA design. That timer
11 did not exist in the DCA design. And there was a
12 significant audit during the test review. There's 14
13 audit items and 5 RAIs.

14 MEMBER HARRINGTON: It's Craig again. I
15 think toward the end of the chapter found discussions
16 somewhere about some event that might occur during
17 operation caused condensation and impacts on the
18 dissolver, the contents of the dissolver, the boron
19 oxide. I guess those kinds of events during operation
20 really force you into a situation of having to get
21 back into the module, reassess the status of the
22 pellets and the dissolver, clean all that up before
23 you can go back into operation. Okay?

24 MR. BECK: Yeah, that's correct. If the
25 pellets are wetted, we'll have to probably replace the

1 pellets and certainly evaluate the pellets.

2 CHAIR KIRCHNER: So Tyler, this is Walt
3 Kirchner. Following up on Craig, so the hoppers in a
4 refueling operation wouldn't be immersed.

5 MR. BECK: That's correct.

6 CHAIR KIRCHNER: Yeah. But they would be
7 in a moisture environment. So the water level
8 basically in the revised design for the SDAA, where
9 would the water level be under normal operations in
10 the reactor building, about the hopper level, below
11 it? I think it would be below, right?

12 MR. BECK: Yes. And I don't remember off
13 the top of my head what specific elevation the hopper
14 is at.

15 CHAIR KIRCHNER: Just a couple of
16 questions then.

17 MR. BECK: But it is below.

18 CHAIR KIRCHNER: Yeah. So that hopper is
19 going to see there's quite a temperature differential
20 inside the containment vessel above the water level
21 line and below. Have you looked at the environmental
22 qualification of the hopper? It's probably going to
23 see pretty -- well, it's going to be likely seeing,
24 pardon me, something close to the steam temperature
25 because it's in a vacuum during normal operation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So it's probably seeing something like
2 that. So is there any concern that this whole mass in
3 the hopper would solidify in some way that it wouldn't
4 dissolve once you -- on demand when you had the actual
5 scenario of a steam environment that you're relying on
6 to essentially release that boron into your dissolver
7 and then further down? Have you looked at the
8 environmental qualification of the system?

9 MR. BECK: Yes. But first I'll say so the
10 hopper is loaded during refueling. And it's above the
11 pool level. And so that's -- you load it with the
12 pellets initially. And then once you're starting up
13 and you drained out a containment vessel, the pellets
14 are released and they actually fall into the dissolver
15 baskets. And so that's where the pellets are during
16 operation, the dissolver baskets. For --

17 CHAIR KIRCHNER: Okay.

18 MR. BECK: -- the question on temperature
19 and the conditions, yes, the pellets and ESB are
20 included in the environmental qualification program.
21 They are qualified for that environment.

22 CHAIR KIRCHNER: Thank you.

23 MR. BECK: Next slide. And this is tough
24 to see on the slide format. But this is from the FSAR
25 Figure 6.3-5. And it just shows a bit more detail of

1 the ESB feature.

2 And so on the left, you can see the
3 dissolver, the dissolver baskets. And on the right,
4 you can see the system as a whole. So that includes
5 the hoppers and then the pellets falling into the
6 dissolvers.

7 You can see the associated main and
8 auxiliary condensate panels. They allow condensation
9 while the pellets do dissolve accordingly and then the
10 lower containment mixing tubes. That was the last
11 slide for Section 6.3.

12 This is Section 6.4, control room
13 habitability. For changes for the DCA, relatively
14 minor changes. The first is that there's a ten-minute
15 delay that is added. So when you have loss of battery
16 chargers, CRHS actuates.

17 However, now in the SDA design, there's a
18 ten-minute delay. That just allows the operators time
19 to try and figure out what's going on. There was also
20 previously toxic gas detection that's included
21 directly in the scope of the design.

22 Now it's in the scope of COL Item 6.4-1.
23 There was a COL item that required testing and
24 inspection requirements for CRHS to be specified.
25 That was removed simply because those testing and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 inspection requirements are already specified
2 elsewhere throughout the FSAR.

3 And then on the note of toxic gas
4 detection, during the audit and RAI days, there was a
5 clarification. And we revised one of our initial test
6 program tests and that COL item. It clarified the
7 scope of toxic gas detection and control room
8 habitability. Next slide.

9 Section 6.5 is fission product removal and
10 control systems. And it is essentially unchanged from
11 the DCA. Next slide. Section 6.6 is the last section
12 we'll discuss today.

13 And it says inservice inspection and
14 testing of Class 2 and 3 components. There aren't any
15 significant changes from DCA. So the design still
16 satisfies the relevant 50.55a requirements and allows
17 for the optional Reg Guide 1.147 code cases.

18 We did remove a COL items that required
19 specifying -- I think it's related to inservice
20 testing for Class 2 and 3 components. And that's
21 because inservice testing program is described in
22 Section 3.9.6. And that's it for Chapter 6.

23 MEMBER MARTIN: Okay. Members, any other
24 questions before we transfer to the staff?

25 MEMBER HARRINGTON: Just one other quick

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 question. This is Craig. And I don't know if you
2 want to respond now or in closed session. But the
3 conditioning of the studs, reactor vessel studs,
4 containment studs is nontrivial activity. And this
5 design has to be done remotely. Describe a little bit
6 about how that's going to occur.

7 MR. BECK: Do we have -- I don't know that
8 we have for fueling handling on the call right now or
9 anyone in the group can address it. If not, we may
10 want to defer this question in closed session.

11 MEMBER HARRINGTON: Okay.

12 MR. CUMMINGS: I mean, I'll just say --
13 Kris Cummings again, NuScale. Yeah, you're right at
14 a high level. We do have some details to that. But
15 that's not a level of scope that we include in the SDA
16 because it's not a safety-related activity, right?

17 I mean, you do fuel handling and things
18 like that and that sort of stuff is covered in the
19 SDA. We certainly have considered that. But that's
20 just not content that's included in the SDA.

21 MEMBER HARRINGTON: Okay.

22 MEMBER PALMTAG: Yeah, this is Scott
23 Palmtag again. Can you go back to slide 10? I do
24 have some questions about the reactor recirculation
25 valves. I just have some -- can you just first -- and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you may want to defer this until the closed session.
2 But can you tell me how far the reactor recirculation
3 valve is above the core?

4 MR. BECK: I'm not sure on the specific
5 change, but it's on top of the reactor pressure
6 vessel. Oh, you said the recirc valve. Sorry.

7 MEMBER PALMTAG: Yeah.

8 MR. BECK: We probably would have to get
9 that in the closed session.

10 MEMBER PALMTAG: Okay. And I assume these
11 are electrically actuated solenoids?

12 MR. BECK: Yes.

13 MEMBER PALMTAG: And how do you run the
14 instrumentation? Where does that go? I mean, is that
15 in a pipe --

16 MR. BECK: The solenoids --

17 MEMBER PALMTAG: -- that runs up the side?

18 MR. BECK: The solenoids are actually
19 technically outside of the containment vessel. And
20 there's hydraulic lines between the main valves, so,
21 for example, the vent valves and those solenoid
22 valves. And so there's no associated electronics in
23 the containment vessel.

24 MEMBER PALMTAG: Okay. That makes more
25 sense. It doesn't show up on the diagram. So all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 solenoids --

2 MR. BECK: There's a --

3 MEMBER PALMTAG: -- are outside of the
4 containment vessel?

5 MR. BECK: Yeah, and there's a figure in
6 6.3 that shows a schematic of the trip to reset valve
7 assembly, I think. And that assembly is a containment
8 penetration. So the valves are located technically
9 outside of the vessel.

10 MEMBER PALMTAG: Okay. Thank you.

11 MEMBER MARTIN: All right. Any other
12 questions, members online? Not hearing any, let's
13 make a quick switch. I mean, just we're going to
14 pause here for a second and then move right into with
15 the staff's presentation. Thank you.

16 (Pause.)

17 MR. SNODDERLY: Bob?

18 MEMBER MARTIN: Yes.

19 MR. SNODDERLY: Just for the interested
20 members of the audience and participants, even though
21 it looks like on the schedule we're following the plan
22 on time, we need to keep in mind right now we do not
23 have the presentation from either the staff or
24 NuScale, who will be there to answer questions. It's
25 okay to take more time in open session, but we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 covering some material we're covering. You have the
2 power to stop for a break. I think that's the only
3 way.

4 (Pause.)

5 MEMBER MARTIN: Okay. Everyone is seated.
6 Who's going to kick us off?

7 MR. TESFAYE: Yes, thank you. Good
8 morning. Let me just get the slides.

9 (Pause.)

10 MR. TESFAYE: Okay. Good morning. Again,
11 my name is Getachew Tesfaye. I'm the lead project --
12 oh, can you hear me now? Good morning. My name is
13 Getachew Tesfaye. I'm the lead project manager for
14 the NuScale U.S. standard design approval, US460.

15 I work for the Chapter 6 PM. We start our
16 presentation with Chapter 6. A quick overview, as
17 we've been saying for a while, NuScale submitted
18 Chapter 6, engineered safety feature, Revision 0 of
19 the SDAA FSAR on December 31st, 2022 and Revision 1 on
20 October 31, 2023. And the safety evaluation is based
21 on Revision 1.

22 NRC developed audit of Chapter 6 was
23 performed from March of 2023 through August of 2023,
24 generating 46 audit issues. Questions raised during
25 the audit were resolved within the audit. Six RAIs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 were issued and the response were all acceptable. And
2 the response are also documented.

3 Staff completed Chapter 6 review and
4 issued an advanced safety evaluation to support
5 today's ACRS subcommittee meeting. The first draft
6 sent to you was on January 18 and then the final draft
7 -- not the final but the final draft was submitted
8 last week officially in a memo. Several NRR staff
9 participated in reviews.

10 And today we're going to concentrate on
11 those chapters or sections that have a significant
12 change from the DCA. There are seven sections. 6.7
13 doesn't apply for NuScale's PWR section. But the rest
14 of them are in our safety evaluation.

15 The report and most of the change that
16 we're going to be discussing here today will be in
17 6.1, 6.2, and 6.3. With that, I'll pass the mic over
18 to Robert Davis, Bob Davis who's online to present
19 significant changes, 6.1.1, engineered safety feature
20 materials. Bob, are you ready?

21 MR. DAVIS: Yes, I'm here. Can you hear
22 me?

23 MR. TESFAYE: Yes.

24 MR. DAVIS: Okay. So the biggest
25 difference in 6.1.1 is the change of the containment

1 vessel to -- or the use of code case N774 which allows
2 the use of F6NM, martensitic stainless steel for the
3 containment vessel. And this is allowed via code case
4 N774 which is listed in Reg Guide 1.84 Revision 39 as
5 permitted for use without conditions. And this
6 applies to the upper containment vessel and a portion
7 of the lower containment vessel below the upper/lower
8 vessel flange. Next slide.

9 Okay. So this material is very different
10 from typical materials that we use in PWRs. The
11 applicant has considered the effective welding
12 procedures, one, the martensite start temperature, the
13 martensite finish temperature. Like I said, this is
14 very different from typical materials that we deal
15 with.

16 The applicant will not follow recommended
17 preheat temperatures listed in the nonmandatory
18 Appendix D of Section 3. And the applicant is
19 employing an extensive testing program to determine
20 the appropriate pre-temperature to prevent hydrogen
21 cracking while at the same time promoting martensite
22 formation during welding. Next slide, please. Okay.
23 So welding F6NM requires special considerations in
24 addition to ASME code requirements.

25 And welding processes that employ flux may

1 require post weld heat treatment times greater than
2 those specified in ASME code due to the pickup of
3 oxygen from flux welding processes which may require
4 post weld heat treat times greater than those
5 specified in the code. So typically, when welding
6 procedures are developed for standard vessel
7 materials, they're post weld heat treated for a very,
8 very long time because to account for repairs and
9 things like that. And so you're worried about the
10 length of the post weld heat treatment whereas in this
11 case for -- and so the standard times listed in the
12 code are more than adequate to get the appropriate
13 toughness.

14 You're worried about post weld heat
15 treating something too long to where you can decrease
16 the tensile properties below what's required by code.
17 However, with this material, using flux welding --
18 flux processes, we're worried that if you qualify a
19 welding procedure for, say, 20 hours and then you weld
20 something that the code requires, say, a 3-hour post
21 weld heat treatment that the impact properties may not
22 be adequate if you post weld heat treat it for 3 or 4
23 hours. You may need much longer times.

24 So the applicant has addressed this by --
25 has addressed this in their application. I guess part

1 of the presentation that we'll give later on today as
2 to how they do that. Next slide, please. ASME code
3 specifies that post weld heat treat temperatures for
4 F6NM is 1050 to 1150.

5 However, the lower critical temperature of
6 a 410 nickel-moly type weld filler metals which is
7 what the applicant uses and F6NM-based materials can
8 be as low as 1150. So if you have variances in your
9 post weld heat treatment which it's impossible to get
10 the exact temperature, you could actually if you were
11 post weld heat treating at the higher end of what's
12 required by code, you could actually be going into --
13 going beyond the lower critical temperature which, of
14 course, would cause the formation of martensite and
15 not the tempering of martensite. However, the
16 applicant has agreed to modify the application to
17 state that their temperature will be 1075 plus or
18 minus 25 degrees.

19 And of course, this provides a margin to
20 ensure that they do not reach the AC-1 temperature.
21 And so the staff has determined that the additional
22 control considerations placed on the fabrication of
23 the F6NM are adequate. And our ultimately conclusion
24 for the 6.1.1 did not change from the last design.
25 And I think that's my last slide unless there's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 another one.

2 MR. TESFAYE: If there are no questions
3 for Bob, we'll go to Syed.

4 MR. HAIDER: Thank you. Good morning. My
5 name is Syed Haider. I'm from NRR Division of Safety
6 Systems, Nuclear Systems Performance Branch. Today,
7 I present a high-level summary of the design changes
8 in NuScale SDAA FSAR Sections 6.2.1 and 6.2.2, and
9 they are mainly related to evaluating the NPM-20
10 containment design application for the NuScale SDAA
11 for the peak contaminant pressure and temperature
12 during a design basis event involving mass energy
13 release from the reactor pressure vessel into the
14 containment during a primary or secondary systems pipe
15 break or an anticipated operational occurrence, or
16 AOO.

17 This slide has the most significant design
18 changes on the NPM-160, for the DCA NPM-20 of the SDAA
19 FSAR Section 6.2.1 on containment functional design
20 and Section 6.2.2 on containment heat removal systems.

21 The staff review established the
22 consistency and conservatism of the modified design
23 parameters with the SDAA Technical Specifications and
24 also verified that all design changes are properly
25 implemented in the Applicant's engineering applied

1 model for the containment response analysis through
2 various initial and voluntary action.

3 And now I'll go over some of the major
4 design changes NuScale made in the SDAA with respect
5 to the containment thermal hydraulics. In the NPM-20
6 module for the LTAA, the reactor thermal power has
7 been increased by about 56 percent compared to that of
8 NPM-160. And the containment upper vessel material
9 has been changed from SA-508 to SA-336, while the
10 lower containment vessel material is still the same as
11 SA-965. This reduces the thermal conductivity of the
12 upper part of the containment by about 35 percent,
13 while wall thicknesses have somewhat changed.

14 The initial reactor pool water temperature
15 has been lowered from 65 feet for NPM-160 to 32 feet
16 in the NPM-20 Tech Specs. The staff found the change
17 to be conservative, as it would reduce the heat
18 transfer from the containment to the reactor pool, and
19 thereby, leading to a higher peak containment pressure
20 and temperature.

21 It's worth mentioning that containment
22 analysis credits only the pool water inventory
23 available in a single day around the NPM for the
24 ultimate heat sink for the analysis, but not the
25 entire pool. And this is conservative.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 The initial reactor pool temperature has
2 been increased from 110 degrees Fahrenheit that was
3 used in the DCA analysis to 140 degrees Fahrenheit in
4 the SDAA analysis, even though the Tech Spec values
5 for the pool temperature is increased to 120 degrees
6 Fahrenheit, which is conservative as 150 degrees
7 Fahrenheit would further suppress the containment heat
8 removal to the pool.

9 The 140 degrees Fahrenheit initial pool
10 temperature leads to around 150 degrees Fahrenheit
11 initial containment wall, such as temperature below
12 the pool level under normal operation, the steady-
13 state operation. However, the initial containment
14 water temperature above the pool has been
15 significantly increased from 240 degrees Fahrenheit
16 from the DCA to 500 degrees Fahrenheit in the SDAA,
17 based on the results of a 3D FEM analysis for NPM-20.

18 The containment analyses also assume the
19 outer surface of containment head and the wall above
20 the pool level as adiabatic, which the staff found to
21 be conservative.

22 The number of RRVs, or reactor regulation
23 valves, located on the top of the reactor pressure
24 vessel has been reduced from three to two in the NPM-
25 20. In NPM-160, the inadvertent actuation blocks, or

1 IABs, were used on RRVs, as well as RVVs, while in the
2 NPM-20 design, IABs are used only with RRVs and open
3 in the IAB design criteria based on the differential
4 release pressure. As RVVs do not have IABs anymore,
5 they can openly indicate the loss of AC and DC power.
6 In the SDAA, IAB release pressure has also been
7 reduced from 950 psid nominal to 450 psid nominal.
8 That will typically delay the activation of IAB.

9 Now, NPM-20 design uses venturi nozzles on
10 all the RVV and RRV lines, while the NPM-160 design
11 does not have any venturi nozzles; it, rather, had
12 orifices. In the NPM-160 containment safety analysis,
13 DHRS heat exchanger operation was not credited to the
14 containment design basis, even during mitigation, but
15 in NPM-20 it is credited. Even though there are two
16 single failure-proof safety-related DHRS cranes, the
17 staff has mandated a 50 percent NRELAP5 fouling factor
18 penalty to both sides of the DHRS heat exchanger tubes
19 in the DHRS model for peak containment pressure and
20 temperature calculations, as an indication and
21 condition for using the NPM-20 containment response
22 analysis methodology. The limitation and condition is
23 documented in the LOCA Topical Report SER.

24 And all the containment internal design
25 pressure for the NPM-20 has increased from 1050 psia

1 to 1200 psia, and the containment design pressure has
2 increased from 550 psia to 600 psia. These increases
3 have had even higher containment design modules for
4 the SDAA.

5 Next slide, please. This slide summarizes
6 some additional important changes from the DCA to the
7 SDAA applicable to Section 6.2.1 and 6.2.2 that are
8 worth underscoring.

9 First off, the containment response
10 analysis methodology, or CRAM, for the DCA was
11 documented in a standalone Technical Report that was
12 incorporated by reference in the DCA. However, the
13 CRAM methodology, as modified for the SDAA containment
14 design for NPM-20 is now included in the LOCA Topical
15 Report that has been presented to the ACRS
16 Subcommittee meeting on January 15 as being acceptable
17 to the staff.

18 Another significant change is the
19 inclusion of a one-time containment free volume ITAAC
20 in the SDAA to verify that the as-built containment
21 free volume bounds the minimum value of 6,000 cubic
22 feet used in the Chapter 6 containment design basis
23 analysis and its validation to the ITAAC did provide
24 an overall indication that the containment has been
25 built as designed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Containment free volume is a key important
2 parameter to be verified by the ITAAC because it needs
3 the various key parameters introduced and underscored
4 in several 14.3 SRP sections.

5 With NPM-20 being a standard design
6 module, and free volume being a best feature not
7 subject to significant changes from module to module,
8 the staff found it acceptable that this ITAAC will be
9 performed for the first module ever built and not for
10 subsequent adopters of the SDAA. And the specified
11 design control process will, rather, be used to
12 maintain the containment free volume in accordance
13 with the design.

14 It is worth emphasizing here that,
15 unchanged from the DCA, the SDAA also includes a
16 separate, but related ITAAC to verify the passive heat
17 sink parameters for the as-built NPM-20 containment
18 vessel structure that includes the containment walls
19 and linings by evaluating the heat sink materials of
20 this area, thicknesses, and properties that have been
21 relied upon in the containment safety analysis. So
22 these two ITAACs are closely related.

23 As previously mentioned, the DHRS is not
24 credited to the containment design basis event
25 mitigation for the SDAA. While it was not credited to

1 the DCA containment DBEs, now with a 56 percent higher
2 decay heat for NPM-20, and, apparently, insufficient
3 reactor coolant pool normalization around DHRS and
4 containment, the staff looked closely into the reactor
5 coolant pool heatup and thermal stratification due to
6 their potential for DHRS and containment heat removal
7 performance degradation and the resulting impact on
8 the containment LOCA response.

9 MEMBER MARTIN: Syed, for some of us that
10 haven't been on the Committee so long, could you give
11 a little bit of the backstory on why maybe the DHRS
12 was not credited previously. It's a passive system,
13 right?

14 MR. HAIDER: It's a passive system, yes.

15 MEMBER MARTIN: Right. In the DCA, was
16 that the way NuScale came in, basically, not
17 crediting? Because they didn't need to --

18 MR. HAIDER: Yes.

19 MEMBER MARTIN: -- or that was their
20 position? It was kind of a defense-in-depth-type
21 system, and now, of course, with their passive system,
22 there's no reason not to? Can you fill in the
23 backstory?

24 MR. HAIDER: Yes, that's a fair and
25 correct characterization. I mean, the simple truth is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that they did not need crediting DHRS.

2 MEMBER MARTIN: Okay.

3 MR. HAIDER: Even the limiting containment
4 design basis accidents, either in the small-break LOCA
5 --

6 MEMBER MARTIN: Right, right, right.

7 MR. HAIDER: -- large-break LOCA regime.
8 But now, being an eastern margin, and also the core,
9 the entire spectrum from large-break LOCA to small-
10 break LOCA, they had to credit.

11 MEMBER MARTIN: Okay. Thank you.

12 MR. HAIDER: And in the same vein, the
13 staff also deep dived into the sensitivity of the
14 containment response break size and ECCS actuation, as
15 with the uncertainty in modeling natural convection
16 heat transfer.

17 NuScale provided additional LOCA spectrum
18 analysis results -- coming to your point -- results
19 going down from 100 percent large-break LOCA to 2
20 percent small-break LOCA regime for the discharge
21 line, as well as high point vent line breaks to cover
22 both the liquid -- break LOCA and also the reference
23 break LOCA.

24 The submitted results showed that the peak
25 containment pressure and temperature are not very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 sensitive to the DHRS performance degradation caused
2 by the pool heatup. RAI-10359, the response also
3 provided justifications for modeling the pool heatup
4 around the containment, thermal stratification, and
5 natural conduction heat transfer modeling. Now, there
6 is no open item outstanding in the Chapter 6 FSAR
7 Sections 6.2.1 and 6.2.2.

8 Now, the table at the bottom of this slide
9 captures the changes in the limiting containment
10 pressure and temperature design basis event from the
11 DCA to the SDAA, as well as the corresponding results.

12 In the DCA, an inadvertent RRV opening was
13 the containment pressure design basis event that had
14 led to a peak calculated containment pressure of 994
15 psia that had about a 5-percent margin with respect to
16 the containment design basis pressure of 1050 psia for
17 the SDAA.

18 While in the SDAA an RCS design line break
19 LOCA is different in the pressure design basis event
20 that led to a peak calculated containment pressure of
21 957 psia. That has about a 32 percent margin with
22 respect to the modified containment design pressure of
23 1200 psia.

24 The same RCS discharge line break LOCA
25 also happens to be the containment temperature design

1 basis event for the SDAA that led to a maximum
2 containment temperature of 533 degrees Fahrenheit,
3 which is 67 degrees Fahrenheit lower than the
4 containment design temperature of 600 degrees
5 Fahrenheit for the SDAA.

6 Previously, an RCS injection line break
7 LOCA was the containment temperature design basis
8 event for the DCA that led to a maximum containment
9 temperature of 526 degrees Fahrenheit, which was 44
10 degrees Fahrenheit lower than the containment design
11 temperature of 550 degrees Fahrenheit for the SDAA.

12 Anyway, in summary, both the peak
13 calculated pressure and temperature have not changed
14 much from the DCA in the SDAA, but significant
15 increases in the containment design pressure and
16 design temperature have led to higher containment
17 pressure and temperature margins.

18 Next slide, please. So I have entered
19 this slide to show the comparison between the staff
20 confirmatory analysis and also the Applicant's
21 analysis. So basically this slide is showing that the
22 staff's -- that the Applicant's analysis is
23 conservative.

24 MEMBER MARTIN: I've got to jump on this
25 one.

1 MR. HAIDER: Sure.

2 MEMBER MARTIN: The phenomena that we're
3 looking at here is pretty straightforward, right? You
4 have two bottles, concentric. Nothing opens up. You
5 know, a pathway opens up between the two and you're
6 moving energy from one to the other.

7 I would not expect a 100 degree psi
8 difference in the plot you're showing here on the
9 left. Have you investigated that? I mean, are you
10 using a best-estimate-type approach? Or what are the
11 differences that result in that 100 degree -- 100 psi,
12 I'm sorry?

13 MR. HAIDER: Yes, you are right. I mean,
14 we deeply investigated this. This is -- the green
15 curve, the 20-year for our confirmatory analysis, and
16 the blue curve is from MELCOR, while the green curve
17 is from NRELAP, and, yes, there's about 100 psi
18 difference. And we spent a lot of time reconciling
19 the geometry and going over the differences and made
20 sure that there is no sensitivity that we could
21 conduct, and we did not conduct, to identify exactly
22 where the differences were coming from.

23 And that's why we've also have done a case
24 confirmatory analysis. As you see, the peak
25 containment pressure here, on the left, is about 957

1 psia, while MELCOR is predicting about 812. And we
2 conducted the same exercise using TRACE, aligning the
3 conservatism, the models, the initial conditions, the
4 boundary conditions, everything in TRACE, and the
5 TRACE was around 870 psia.

6 MEMBER MARTIN: So we're in the middle?

7 MR. HAIDER: Yes, so TRACE was somewhere
8 in the middle. So from these results, we can conclude
9 clearly that the Applicant's analysis is very
10 conservative. And we have gone through evaluating all
11 the phenomenologies like the effect of non-condensable
12 on condensation heat transfer and the decay heat, and
13 also the critical flow models. But we were not able
14 to pinpoint where exactly the differences are coming
15 from.

16 But the TRACE was also about 50 pounds
17 below where the Applicant is. So considering that we
18 were getting the evaluation of the results, the
19 validation of the conservatism of the Applicant with
20 our two different independent models, and also,
21 considering the time, we did as much investigation as
22 we could.

23 MEMBER MARTIN: I guess my expectation
24 would be, since MELCOR, you know, has been more of a
25 severe accident containment code, going back to at

1 least the containment models, going back to the
2 CONTAIN code once upon a time, maybe it's the heat
3 transfer package related to containment heat transfer
4 is maybe a little more sophisticated or more accurate.
5 Whereas, codes like RELAP5-3D was not developed with
6 that in mind, and not knowing what's actually in
7 TRACE, although I know there's some similarity, a lot
8 of similarities between TRACE and RELAP5, it's likely
9 that the containment heat removal heat transfer
10 package, whether it's condensation or whatever, is
11 maybe just not as vetted.

12 But what I think that this doesn't say is
13 that, more than likely, I think I would have more
14 confidence in the MELCOR prediction of containment
15 response, given its history and validation. And then
16 you're certainly confirming significant margin,
17 whether NuScale has quantified it or not, but it gives
18 us a lot of confidence.

19 MR. HAIDER: But I would like to also add
20 one more piece of information that I believe is
21 relevant in this context. In the DCA, the peak
22 containment pressure was predicted by RELAP at about
23 994. And we literally used a very similar containment
24 volume model using MELCOR in the DCA stage. And it
25 predicted around 986.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER MARTIN: Oh, so you were much
2 closer?

3 MR. HAIDER: So we were very close. And
4 the same model was modified in RELAP5 for SDAA, using
5 the modified initial conditions, and literally, they
6 are using the same condensation model, the same models
7 for critical flow and the same model for decay heat.
8 But, yes, the pressure came out far below. But TRACE
9 is also --

10 MEMBER MARTIN: In the ballpark?

11 MR. HAIDER: It is in the ballpark.

12 MEMBER MARTIN: That's interesting to me,
13 and maybe the more significant thing is just the level
14 of the reactor pool, a larger condensation area. I
15 don't know. That's interesting that they would be so
16 different.

17 But, anyway, I won't belabor that one.
18 Thank you.

19 MR. TESFAYE: So now, I think you can
20 (audio interference) forward. So this slide
21 essentially summarizes the SER conclusions for all
22 subsections of Sections 6.2.1 and 6.2.2. The staff
23 concludes that the containment safety analyses have
24 appeared to be moderate.

25 All relevant physical phenomena in the

1 NPM-20 containment response, that includes
2 condensation heat transfer, the degrading impact of
3 non-condensable gas on condensing heat transfer, decay
4 heat, choked flow, DHRS and ECCS sensitivities, and
5 containment taking more of the area of the pool.

6 The staff review of NuScale's SDAA FSAR
7 Chapter 6 has shown that the NuScale containment
8 design incorporates sufficient conservatism in the
9 NPM-20 containment model through initial and bounding
10 conditions and appropriate constitutive models.

11 The staff also concludes that the SDAA
12 FSAR has provided sufficient description of the
13 spectrum of primary and secondary design basis events
14 and acceptable results for the limiting mass energy
15 released into the containment and the resulting
16 containment pressure and temperature responses.

17 In summary, the NuScale containment design
18 for the SDAA meets all regulatory requirements and
19 acceptable criteria for the containment safety design.
20 This concludes my presentation. Thanks for the time
21 for presenting the staff's review. I would like to
22 know if the Committee would have any other questions
23 about the staff's review of SDAA Sections 6.2.1 and
24 6.2.2.

25 MEMBER MARTIN: Anyone in the room or

1 online?

2 I'm not hearing any. Thank you.

3 MR. TESFAYE: Anne-Marie?

4 MS. GRADY: Good morning.

5 MEMBER MARTIN: You might want to come a
6 little closer to the microphone. You're kind of soft-
7 spoken. Pull the microphone closer to you, please.

8 MS. GRADY: I've never been accused of
9 that before.

10 One more time. Good morning. My name is
11 Anne-Marie Grady, and I'm a severe accident analyst,
12 and also I reviewed the design of combustible gas
13 control, actually both for DCA and SDAA. And there
14 are some changes in combustible gas control which are
15 summarized on the slide in front of you.

16 The first one is the applicable
17 regulation. The DCA applied 10 CFR 50.44(c), which is
18 for new reactors. The SDAA decided that the
19 appropriate applicability was 10 CFR 50.44(d), which
20 is for reactors of new design that hadn't been
21 envisioned when the combustible gas control regulation
22 was issued.

23 (C) is a much more prescriptive
24 regulation. SDAA, by its very nature, is less so.
25 The guidance that's applicable for DCA is SRP 625,

1 which is combustible gas control, and 19.0, which is
2 severe accident. The guidance that's applicable for
3 the SDAA, however, is a little bit different. It's
4 Reg Guide 1.7, combustible gas control, and again, SRP
5 19.0.

6 The combustible gas control design is
7 based on combustion analysis, so the -- I'm sorry.
8 The DCA design was based on combustion analysis. Now,
9 NuScale analyzed combustion in containment. They
10 analyzed the transition to detonation, DDT. They also
11 analyzed detonation and they proved that the
12 containment integrity was protected via the analysis.
13 There was no PAR in that design.

14 The SDAA, however, has changed their
15 approach to showing that the containment would retain
16 its integrity. And they show that by adding a PAR to
17 the design and showing that it maintains that the
18 containment atmosphere is always inert. In some
19 instances, it's natural inert. For example, during
20 normal operation, it's almost a complete vacuum.

21 There are no combustible conditions in the
22 containment then, but there are other design basis
23 accidents to consider. There are severe accidents to
24 consider and there's also long-term radiolysis.
25 Various stages could be considered in evaluating the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 combustible gas control. So now, we have a PAR, a
2 single one, safety-related.

3 Okay. The safety category is --

4 MEMBER ROBERTS: Hey, Anne-Marie, yes, Tom
5 Roberts. May I ask a question now?

6 The safety evaluation addressed at least
7 took partial credit for the fact that it continued to
8 do the combustible analysis. And we heard from the
9 Applicant that they did that as part of the PRA, and
10 that that may not have been to the same level of
11 quality as a design analysis.

12 Can you comment on the role of the safety
13 analysis of the combustible gas, please?

14 MS. GRADY: Well, first of all, I could
15 say that the statement that's in the SER, in 6.25, was
16 in the section that was talking about PDC-41. That
17 sentence, while it's correct, is appropriately
18 addressed in Chapter 19 for the severe accident, and
19 it doesn't support the discussion on the PDC-41.

20 And I heard NuScale's description of why
21 they did that combustible analysis and it was for
22 severe accident analysis and the PRA.

23 MEMBER ROBERTS: In looking at the graph,
24 I see there's a section called Structural Analysis
25 Containment Integrity. And it goes on to talk about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the analysis that they did with the bounding hydrogen
2 and oxygen mix, similar to the NPM-160.

3 MS. GRADY: Are you talking about 19.2428?

4 MEMBER ROBERTS: It's hard to find the
5 section number here.

6 MS. GRADY: In Chapter 19.

7 MEMBER ROBERTS: Yes. The top of page 101
8 in Chapter 6. It says during the regulatory audit,
9 the staff reviewed the NuScale evaluation and agreed
10 with the conclusions, which is about the structural
11 capability of the containment, assuming a combustion
12 event. And it says the staff agrees with this and
13 concludes that the NPM design meets the required
14 criteria in Reg Guide 1.7, Section C.(5).

15 That paragraph kind of confused me because
16 the argument seemed to be that the PAR maintained the
17 environment inert, but it seemed like the staff
18 acceptable was at least partially based on the
19 containment calculation, assuming the combustion
20 happened.

21 MS. GRADY: The AICC analysis was done of
22 Chapter 19 for severe accident to show that it was
23 not, that combustion was not going to threaten the
24 containment integrity. It doesn't belong in Chapter
25 6, SER. It was in there inadvertently with PDC-41,

1 and the sentence, since you have read it, has been
2 taken out of Chapter 6.25. It's still appropriate in
3 Chapter 19.2.

4 MEMBER ROBERTS: Okay. Thank you. So
5 what I just read will be removed from the draft?

6 MS. GRADY: That sentence that you -- yes,
7 absolutely.

8 MEMBER ROBERTS: Okay. Thank you.

9 MS. GRADY: You're welcome.

10 MEMBER MARTIN: Anne-Marie, just a
11 question. It's been a while since I've analyzed, done
12 analysis related to PARs. You used the word safety-
13 related PARs. I would say, 15 years ago, that wasn't
14 a thing, right? Well, at least in my experience. Is
15 there something different about design of PARs today
16 that distinguishes them as safety-related versus a
17 non-safety-related PAR?

18 MS. GRADY: I can't speak about PAR
19 manufacturers marketing a product. What I can say is,
20 when NuScale agreed that it would be a safety-related
21 PAR, they also agreed that there would be significant
22 more testing in the design specification and it would
23 be a specific design specification; that they would
24 have more inspection. It would be an ITAAC and there
25 would be a Tech Spec on the PAR. So it really gave us

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a much fuller confidence in how it was going to be
2 designed; how it was going to be analyzed, and how it
3 was going to be installed and operated.

4 MEMBER MARTIN: Oh.

5 MS. GRADY: So that's almost a --

6 MEMBER MARTIN: So it might be the same
7 product, but they might have been available when I
8 last looked at them. But it's the testing and the
9 monitoring Tech Spec; it's all the other layers that
10 control --

11 MS. GRADY: It's the design specification
12 --

13 MEMBER MARTIN: Okay.

14 MS. GRADY: -- does meet the conditions
15 that we were concerned about, yes.

16 MEMBER MARTIN: Okay.

17 MS. GRADY: It probably is
18 indistinguishable from off-the-shelf --

19 MEMBER MARTIN: Right, right. Okay.
20 Thanks.

21 MS. GRADY: As we just said, the safety
22 category, there was no PAR in the DCA and there is now
23 a single safety-related PAR in the SDAA.

24 There is now an ITAAC in the SDAA;
25 whereas, there wasn't one in the DCA. Actually, there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 are three ITAACs. There was one that verifies the
2 physical arrangement and the installation. There is
3 one that specifies the analysis and the testing, and
4 the test of the recombination rate of the PAR, because
5 there is a minimum recombination rate. And there's an
6 ITAAC on the fact that the PAR would be part of the
7 cube.

8 MEMBER MARTIN: Okay.

9 MS. GRADY: There were no Tech Specs
10 because there was a PAR in the DCA, but there is a
11 Tech Spec on PAR operability now. And that really
12 involves that the PAR would be inspected during every
13 refueling, and physically inspected. The PAR would be
14 tested in general and in a sampling process to make
15 sure that the recombination rates are still being
16 maintained from refueling to refueling. And the PAR
17 will be reinstalled if it has to be moved, and I don't
18 believe it has to be moved, but if it does, back in
19 the same location that it was always intended to be.
20 So there are Tech Specs and there are ITAACs.

21 MEMBER HARRINGTON: So this is Craig
22 Harrington. I'm confused. In 6.25.1 of the FSAR
23 version that I looked at, it says, the design includes
24 a passive autocatalytic recombiner PAR that is non-
25 safety-related, Seismic Class II, of the new

1 requirements.

2 MS. GRADY: That's Rev 1. Our Rev 2 would
3 say that it's safety-related.

4 MEMBER HARRINGTON: Okay. Okay.

5 MS. GRADY: Yes, it absolutely is safety-
6 related and that has been a change.

7 MEMBER HARRINGTON: Okay. All right.
8 Thanks. That clears the confusion.

9 MS. GRADY: A combustible --

10 MEMBER DIMITRIJEVIC: Sorry, this is
11 Vesna, Vesna Dimitrijevic. But the PAR is supported
12 with the augmented DC system, right?

13 MS. GRADY: I'm sorry?

14 MEMBER DIMITRIJEVIC: Which is not safety-
15 related, right?

16 MS. GRADY: I'm sorry, Vesna, the PAR is
17 safety-related. So what was the first part of your
18 statement again?

19 MEMBER DIMITRIJEVIC: Okay. My question
20 is, does it -- it requires DC, an EDAS system, right,
21 for operation?

22 MS. GRADY: No, no, no. No, Vesna, it's
23 passive.

24 MEMBER DIMITRIJEVIC: Oh, okay.

25 MS. GRADY: It's essentially an open

1 chimney with some catalytic plates at the bottom, and
2 the combustible gases come up past the plates,
3 recombine, and express steam out the top. It doesn't
4 require any electrical signal or any electrical supply
5 or any other supporting systems. It's passive.

6 MEMBER DIMITRIJEVIC: All right. I
7 thought it requires a signal?

8 MS. GRADY: No.

9 MEMBER DIMITRIJEVIC: I mean, that's my
10 misunderstanding. All right. Okay.

11 MR. BECK: This is Tyler Beck with
12 NuScale.

13 I'll just clarify that Anne-Marie is
14 correct; it is a fully passive component. It's a
15 passive catalyst that serves for the recombination
16 reaction of hydrogen and oxygen.

17 MEMBER MARTIN: I think one thing that's
18 maybe unique -- again, because NuScale's containment
19 design or whole design is unique -- is that that PAR
20 is going to be exposed to rather high temperatures.
21 And, of course, in an earlier slide, or your slide,
22 but earlier in the presentation here, it noted
23 boundary conditions, assumed analyses, and one of them
24 being a containment surface above the water level is
25 like 500 degree F. That would be significantly higher

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 than, say, what PARs have probably been considered in
2 the past, right? Because in large containments the
3 environment is typically that it would be below 120.

4 So there would be some unique EQ-type work
5 that would need to be done in this particular case.
6 So that, I guess, would go to the extra work NuScale
7 would be otherwise expected to do in their testing.
8 And has that work happened or is it ongoing? Whether
9 they're working with a manufacturer or fabricator, or
10 whatever we call them today, to move in that
11 direction; to have that all complete, say, by the time
12 we get approval? Or is that just ITAAC?

13 MS. GRADY: The design specification would
14 indicate the conditions in the containment the PAR
15 would see under all the different conditions. I can't
16 speak specifically to a temperature, but I know
17 NuScale has the intent of having in the design
18 specification a maximum temperature.

19 But even more interesting, as far as I'm
20 concerned, with respect to the PAR, is the fact that
21 it's inside containment. It's inside a very small
22 containment. It's relatively close to the reactor
23 vessel, and it's going to see high neutron irradiation
24 during normal operation, and that's something that the
25 PARs off the shelf today don't necessarily -- don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 provide.

2 MEMBER MARTIN: Well, certainly --

3 MS. GRADY: They're not exposed to such
4 conditions. But that is in the NuScale design
5 specification.

6 MEMBER MARTIN: Right. But will the
7 testing and all that be resolved before, say,
8 approval? That would be just pushed to an ITAAC? Is
9 that the intent of NuScale?

10 MS. GRADY: I think NuScale would have to
11 answer that.

12 MEMBER MARTIN: Yes.

13 MR. BECK: Tyler Beck with NuScale again.
14 So one thing is we've specified environmental
15 qualification as a requirement for the PAR, and
16 there's an associated ITAAC with that. And so that
17 would -- it would need to be qualified prior to
18 completing ITAAC and the 52.103g finding.

19 MEMBER MARTIN: Okay. Has that been
20 initiated, or is that just kind of --

21 MR. BECK: I can't speak right now for the
22 engineering procurement process on that.

23 MEMBER MARTIN: All right. Thank you.

24 MS. GRADY: All right. There was a
25 Technical Report which is, basically, a combustion and

1 containment report for the DCA. There is no such
2 report comparable to combustion for the SDAA.
3 However, there's a limiting -- sorry. There are
4 several calculations, several analyses on different
5 aspects of design basis accidents, severe accidents,
6 long-term radiolysis, that are in the electronic
7 reading room and they have been proprietary, but they
8 are there. And they have been reviewed by us, meaning
9 me and others.

10 There is an exemption request also. There
11 was in the DCA and it really resulted in -- it was for
12 hydrogen and oxygen monitoring in the containment
13 during an accident to be able to inform the operators
14 of whether or not a severe accident had taken place
15 and how it was progressing. How much hydrogen had
16 been generated in the containment would be a
17 measurement of how much core damage would be there.
18 And there was a requirement, there is a requirement to
19 have that kind of monitoring.

20 In the DCA, NuScale came up with a, more
21 or less, uncertain means of post-accident monitoring
22 of hydrogen and oxygen. It was a conceptual design,
23 and that's all I can say about that.

24 Now, in the SDAA, the exemption request
25 wants to have no hydrogen and oxygen monitoring in the

1 containment post-accident. What they want to rely on,
2 instead, is, first of all, they have a PAR. The PAR
3 can take and operate and can recombine and prevent
4 combustible mixture from occurring, whether it's the
5 DBA, whether it's the severe accident, whether it's
6 long-term, days and weeks down the road, and from
7 long-term radiolysis. So the PAR is maintaining the
8 containment indirect under all the different
9 circumstances it's likely to see. So the PAR is doing
10 that.

11 In addition to that, the operators will be
12 able to rely on radiation monitors under the
13 bioshield, and also exothermocouples to give them some
14 indications of the severity of the accident in
15 containment. So the exemption request is to have no
16 monitoring of hydrogen and oxygen in this design, and
17 we've recommended that.

18 Next slide, please. Okay. The
19 acceptability of applying 50.44(d) as the applicable
20 regulation for combustible gas control in the SDAA, we
21 reviewed that also, because that was a change in the
22 application.

23 The CNV is not inert. However, the CNV is
24 not inert in the presence of hydrogen of -- less than
25 4 percent oxygen in the presence of hydrogen during a

1 design basis accident in the first 24 hours of a non-
2 core-damaged AOO. So in other words, when there is a
3 specific design basis accident in the containment, the
4 CNV is not inert.

5 And CFR 50.44(c) applies mainly to severe
6 accidents. 10 CFR 50.44(d)(2) applies to the safety
7 impacts of combustible gases during design basis and
8 significant beyond-design-basis accidents. And for
9 those reasons, we believe 50.44(d) is applicable and
10 we agreed with the change.

11 Do you have any other questions? All
12 right.

13 Combustible gas control conclusion.
14 During a core-damaged DBA, the PAR is credited to
15 maintain an inert containment. Post-accident, post-
16 severe-accident, the CNV remains inert without
17 crediting the PAR. During long-term radiolysis, PAR
18 is credited to maintain an inert CNV.

19 In the exemption request, the post-
20 accident monitoring of hydrogen and oxygen are not
21 required to assess core damage. The assessment is
22 going to be accomplished, as I've just said, by the
23 core reg's thermocouples and the radiation monitors
24 beneath the bioshield.

25 As far as combustible gas control is

1 concerned, are there any other questions?

2 MEMBER HARRINGTON: Well, this is Craig.
3 I guess that non-LOCA event where in the short term
4 maybe you're not quite inert, it kind of feels like a
5 technicality there why that might be okay, but is it
6 just happening too fast at that point for the PAR to
7 keep up or?

8 MS. GRADY: Initially, during normal
9 operation, there's a vacuum. If you have that non-
10 core-damaged DBA LOCA, in other words, when the ECCS
11 timer opens the relief valve. There is almost
12 immediately, because of the materials that are
13 released from the RCS, almost immediately a
14 combustible mixture in the containment. You haven't
15 had core damage, but you have hydrogen and oxygen that
16 will support combustion. NuScale's analysis shows
17 that and they show that they need to address that as
18 a design basis accident, and our confirmatory calcs
19 confirm that as well.

20 A PAR is needed for that very specific,
21 but non-core-damaged LOCA; whereas, if you had a core-
22 damaged LOCA, there would be so much more hydrogen
23 going in there, it would suppress the oxygen and there
24 wouldn't be -- it's almost better from that aspect,
25 anyway.

1 So the DBA requires a PAR. That's the
2 non-core-damaged DBA. However, if you didn't have
3 that, we can talk about that separately, and these
4 three bullets have separate analyses that NuScale has
5 done and that we have confirmed in ours.

6 In the severe accident, because there now
7 has been core damage, in fact, significant core
8 damage, now you have sufficient hydrogen certainly,
9 but you also have oxygen, but you don't have enough to
10 ever exceed 4 percent oxygen, because there's so much
11 hydrogen in there. So the hydrogen is almost keeping
12 the containment indirect after a severe accident.

13 Long-term radiolysis, there's no more
14 hydrogen generated from the core damage. However, the
15 PAR is credited because there's long-term radiolysis
16 taking place. NuScale has done a calculation and
17 looked at what happens long term. And around 37 days,
18 there could be a combustible mixture again, but the
19 PAR is in there. It's always in there. It's always
20 -- I can't say operational; that's odd -- but it will
21 do its job.

22 So that's why there are separate bullets
23 here.

24 MEMBER HARRINGTON: So on the previous
25 slide, the top bullet that says it's not inert, that's

1 not credited PAR?

2 MS. GRADY: If you don't credit the --
3 yes. I'm sorry.

4 MEMBER HARRINGTON: Okay. Okay.

5 MS. GRADY: Yes, absolutely.

6 MEMBER HARRINGTON: All right. Fine.

7 MS. GRADY: That's one of the reasons the
8 PAR is in there.

9 MEMBER HARRINGTON: Yes. Thank you.

10 MEMBER MARTIN: Anne-Marie, you made a
11 point about the advantage of this small containment;
12 it's the proximity of the PAR to the vessel, and that,
13 of course, would probably improve its performance or
14 at least your uncertainties related to performance,
15 because everything is really tight in there.

16 One possible failure mode, not knowing
17 anything else, is that that proximity -- is there a
18 possibility that there's a jet impingement scenario
19 where, okay, the opening of the RVVs in some way
20 directs the coolant towards the PAR? And that has --
21 okay, you're nodding your head. So they have
22 obviously thought about it and maybe mitigated that
23 possibility?

24 MS. GRADY: Yes, there are two points to
25 make about that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 There's an ASME AG Code that requires
2 that, if you comply with that Code -- and NuScale
3 intends to comply with the Code -- that you would have
4 to take into account the jet impingement loads on the
5 PAR as part of the qualification of the PAR. That's
6 No. 1.

7 And No. 2, they have that condition, jet
8 impingement, as one of the conditions in their design
9 spec.

10 MEMBER MARTIN: Okay. I mean, one
11 solution would be just to kind of direct the flow away
12 from the PAR. Do they --

13 MS. GRADY: I don't know about alternate
14 solutions. I just know they're going to address it,
15 so that the PAR is designed for that.

16 MEMBER MARTIN: Okay. Is that considered
17 an ITAAC?

18 MR. BECK: Yes, so the environmental
19 qualification is a piece of that. It is that
20 associated ITAAC.

21 But we have looked at it for the closest
22 possible position of the PAR on the vessel to the vent
23 valves and RSVs. The jet loads are not significant.

24 MEMBER MARTIN: All right. Thank you. I
25 assume there's no more questions in the room. Is

1 there anyone online, any member or consultant online
2 with a followup question before we move on?

3 I'm not hearing any. Move on.

4 MR. WIDREVITZ: Hello. This is Dan
5 Widrevitz. I can quickly address Section 6.2.7 for
6 actual prevention of the containment vessel.

7 Here we have a significant difference
8 between the NuScale DCA and the NuScale SDAA FSAR,
9 which is primarily that they're using F6NM to replace
10 SA-508, Grade 3, Class 2, from previous designs, with
11 the upper CNV and a portion of the lower CNV below the
12 upper lower vessel flange.

13 This is, of course, interesting because,
14 when you have heard the word Martensite, and you think
15 of the word pressure toughness, they don't usually go
16 together, but this is a pretty tough Martensite.

17 The staff verified that the material
18 change would not result impacts to the fracture
19 toughness management for the CNV, particularly if you
20 have to meet ASME Code fracture toughness
21 requirements, which you are quite capable of doing
22 with this material. And therefore, the staff
23 conclusion did not change from the DCA.

24 Any questions?

25 MEMBER BALLINGER: The proper word is

1 tempered Martensite.

2 MR. WIDREVITZ: Yes.

3 MEMBER MARTIN: I guess if there are no
4 questions, go on to the next slide.

5 MR. NOLAN: This is Ryan Nolan, like the
6 baseball player, but backwards.

7 I'm in the Nuclear Methods and Systems for
8 New Reactors Branch, and I was one of the reviewers
9 for Section 6.3. NuScale covered most of these
10 changes, so I'll go through fairly quickly.

11 So one significant change is that they
12 added the supplemental boron feature. If you recall
13 the DCA, they did have an exemption to GDC-27. So one
14 condition of the system, they are now complying with
15 GDC-27.

16 The staff's evaluation to that particular
17 criterion is performed as part of Chapter 4, which I
18 believe you'll see in April.

19 There is an Extended Passive Cooling
20 Topical Report which provides the methodology for this
21 system. And so I believe that will be presented next
22 month, and then the evaluation of the system is
23 performed as part of Chapter 15. Again, it will be
24 presented in April.

25 One thing the staff did ensure was that

1 this system is tested as part of the initial test
2 program or ITAAC. This is a new system. And so we
3 did verify that a first-of-a-kind test does exist to
4 test the system in an integrated fashion to verify
5 that they're getting the dissolution rates in the
6 mixing as expected in the analysis.

7 Another change was the removal of the IAD
8 on the vent valves, as well as the reduction of number
9 of vent valves from three down to two.

10 In order to sort of compensate for this,
11 as well as other design changes, NuScale had added
12 flow-restricting venturis into the RVVs and the RRVs.
13 This raised an interesting question as to whether the
14 design could mitigate a break at the flange versus
15 just an inadvertent opening of a valve, which was the
16 main focus of the DCA and the staff's review of that
17 particular design. This particular question will be
18 addressed as part of Chapter 15 and was the subject of
19 a high-impact technical issue, and we'll certainly
20 discuss that in more detail in April.

21 They did change the ECCS actuation
22 signals. In the DCA, it was containment parameter-
23 based, and for the SDAA, they went to more direct
24 measurement of a mixture level. This was discussed
25 briefly when the staff presented the LOCA Topical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Report.

2 And then lastly, they did add an eight-
3 hour ECCS timer, which will actuate ECCS eight hours
4 after an automatic or manual reactor trip. This does
5 two things. One is it ensures that the ESB is
6 utilized when needed to maintain subcriticality, and
7 as well, vent any combustible gases due to radiolysis.

8 And so Anne-Marie had already presented on
9 the analysis we looked at. But, basically, when we
10 looked at the long-term radiolysis development, we
11 ensured that NuScale's calculations showed that any
12 combustible mixture within the RCS does not occur
13 within the eight-hour timeframe. And so you hit the
14 eight-hour timer. Everything vents into containment.

15 We also did our own confirmatory
16 calculation and we had results in the same ballpark or
17 magnitude as NuScale.

18 MEMBER ROBERTS: Hey, Ryan, I want to ask
19 you about the single failure assessment of inadvertent
20 actuation of the RVV during an unrelated event. There
21 is some discussion in the SE about the loss of EDAS,
22 the DC power system, which we have talked about in
23 previous meetings.

24 But we talked earlier this morning about
25 the single failure criterion for cases other than loss

1 of EDAS that would lead to an inadvertent actuation of
2 an RVV during an unrelated event.

3 The purpose of the single failure
4 criterion from NuScale is that you wouldn't have to
5 assume that. I'm just wondering what your view is.
6 Is that something that you would not assume because
7 it's not directly part of the protected action in
8 response to the reactivity addition event? Or is
9 there concern that it is a single failure that would
10 cause something that impedes the ability to show
11 protection for that event?

12 MR. NOLAN: Yes, so when it comes to
13 interpreting the single failure criteria, a lot of our
14 guidance lives in policy space. And so one of the
15 best sources of information is SECY-77-0439. That was
16 the agency's first attempt at distinguishing various
17 single failures.

18 And so if you look at that SECY paper, you
19 know, we sort of break it out into mechanical and
20 electrical components. So in this case, in 6.3, we're
21 focused on the valves as a mechanical component. It's
22 an active component, right? It requires movement to
23 perform its function. And so it's a single active --
24 or it's an active component, subject to the single
25 failure criterion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And so when we look at how we apply single
2 failures to mechanical systems, we typically look at
3 it at two times, either at event initiation, you know,
4 is it subject to single failure, as well as on-demand.
5 And so I think if we're talking about two unrelated
6 events, if the valve inadvertently opens at time zero,
7 well, you've terminated the event and you have an IO
8 or EE analysis, or in Chapter 15, you have the results
9 for that.

10 If you're looking at having to use the
11 reactivity insertion scenario, ECCS isn't demanded at
12 any time during that until after the reactor is
13 tripped and the event is terminated. And so we don't
14 necessarily see a single failure consideration for
15 that particular scenario that wasn't already addressed
16 in our Chapter 15.

17 MEMBER ROBERTS: But the loss of EDAS was
18 considered? And then that was thrown out because of
19 the redundancy in the EDAS system. But that was
20 considered? Even though you could make the same
21 argument for loss of EDAS, there's nothing -- you
22 know, loss of EDAS is a safe action for the reactivity
23 addition event, because it causes the scram
24 independent of the rest of the system. And yet, there
25 was still the consideration.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. NOLAN: Yes, and --

2 MEMBER ROBERTS: So, I mean, it's kind of
3 an interesting question on the single failure
4 criterion that really hadn't occurred to me until the
5 point from NuScale this morning, that you would
6 actually parse the single failures that you would
7 consider based on whether or not they're part of the
8 system that you, in effect, actuate, as opposed to
9 they are systems, and if they were to cause -- if the
10 single failure were to cause an actuation, they would
11 take away the ability of the system to protect the
12 reactor.

13 It seems like they're the same thing. In
14 my mind, they would get the same concern, which is, if
15 there's some likelihood of a single failure in
16 systems, and if they either prevent or protect the
17 system from actuating at all, or if they cause the
18 plant conditions to change, such as the protective
19 system can't protect, it seems like in either case you
20 would need to consider that single failure scenario.
21 But I'm just wondering if you've got any thoughts on
22 that.

23 MR. NOLAN: Yes, and I think we're going
24 to -- it's probably unsatisfying to say, but a lot of
25 this discussion will probably occur during Chapter 15,

1 15.0. The staff is still working to finalize the
2 engineering evaluation and controls associated with
3 the EDAS. And so we'll have all of our documentation
4 prepared for April for that.

5 But when we're talking about EDAS and the
6 HITI that was raised, it was more of a classification
7 issue the staff had. It wasn't really a single
8 failure issue. Because when we look at how you apply
9 single failures, we apply single failures to safety-
10 related systems, right? The safety-related systems
11 are those systems that are mitigating Chapter 15
12 events.

13 MR. BARRETT: Right. This is Antonio of
14 the staff. Yes, so those two trip valves are in
15 series. They're both safety-related.

16 MEMBER ROBERTS: Speak up.

17 MR. BARRETT: Yes, my name is Antonio
18 Barrett of the NRC staff.

19 So, yes, those two valves are in series.
20 They've both safety-related. So if one was to fail,
21 you would still have the other one. So that's how we
22 are thinking about that and it has all the protections
23 --

24 MEMBER ROBERTS: Right, and I agree with
25 that. But the question came up during the Tech Spec

1 discussion that there's no plant restrictions if one
2 of those were to fail, and then be open for,
3 presumably, as long as the plant would be willing to
4 live with (audio interference) away from ECCS --

5 (Simultaneous speaking.)

6 MR. BARRETT: Sure. Correct.

7 MEMBER ROBERTS: Which I agree. We heard
8 this morning there are some concerns there. You need
9 to have a low probability of an actuation. So the
10 plant would be acting on that --

11 MR. BARRETT: Yes.

12 MEMBER ROBERTS: -- but the Tech Spec
13 would not preclude that, which would then put you in
14 the single failure space, I would think, because
15 that's now -- a lot of it is allowable.

16 MR. BARRETT: You're 100 percent correct.
17 We will probably address that later on when we get to
18 the Chapter 15 section. But you're 100 percent
19 correct.

20 But, generally, if you have two safety-
21 related pieces of equipment and one of them fails,
22 that's your single failure. You have those other
23 considerations which are 100 percent accurate. So
24 we'll be talking about that. Okay?

25 MEMBER ROBERTS: Great. Yes, I'm willing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to have all the questions in Chapter 15. So thank you
2 very much.

3 MR. NOLAN: Yes. Yes, there's certainly
4 a symbiotic relationship between the Chapter 15 safety
5 analysis and the Technical Specifications, right?

6 We would, typically, perform the Chapter
7 15 analysis. We would use the operability
8 requirements to determine what systems are there,
9 right, that they have operability requirements to
10 mitigate in the system. So those two definitely play
11 a large role together.

12 MEMBER MARTIN: Okay. That's your last
13 slide, correct?

14 MR. NOLAN: This is the last slide. If
15 there are no questions, I'll turn it back to Getachew.

16 MR. TESFAYE: Yes, that concludes --
17 excuse me. This is Getachew Tesfaye again. That
18 concludes the Chapter 6 presentation.

19 MEMBER MARTIN: Okay. Any last questions
20 related to Chapter 6 in the room or online?

21 I'm not hearing any. I think it's time
22 for a break. So I'll say maybe a 20-minute break?

23 MR. SNODDERLY: To 11:15?

24 MEMBER MARTIN: 11:15? I don't think
25 we're going to get through that part of the open

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 before lunch. It would be appropriate. But that's
2 okay.

3 MR. SNODDERLY: Yes, as I said, I'm not --

4 MEMBER MARTIN: We can continue after
5 lunch with some open, and then --

6 MR. SNODDERLY: That's right.

7 MEMBER MARTIN: Okay. Then that's what
8 we'll do. So we will recess until 11:15.

9 (Whereupon, the above-entitled matter went
10 off the record at 10:54 a.m. and resumed at 11:15
11 a.m.)

12 CHAIR KIRCHNER: We're back with now
13 NuScale, who has more to discuss, I guess with just
14 one slide, on Section 17.4, and then the bulk of it
15 will relate to Chapter 19. So, Sarah, you're nodding
16 the most, so who's going to lead us off?

17 MS. BRISTOL: Ultimately Pete Shaw will be
18 the presenter and he will be the presenter, and he'll
19 be online, so --

20 CHAIR KIRCHNER: Okay.

21 MS. BRISTOL: -- he'll start on 17.4.
22 Pete?

23 MR. SHAW: Hi, good morning. My name is
24 Peter Shaw. I just want to double-check that my mic's
25 coming through?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER MARTIN: It is.

2 MR. SHAW: Okay. So once again, my name
3 is Peter Shaw. I'm a NuScale licensing engineer.
4 I've been in the industry for over 15 years now. And
5 prior to my tenure at NuScale here I worked for 10
6 years at the Vogtle 3 and 4 construction project.

7 I'm going to be starting this next run of
8 presentations with, as said, the slide for Section
9 17.4.

10 Next slide, please? So 17.4 is the
11 Reliability Assurance Program. As in the DCA, the
12 Design Reliability Assurance Program reviews and
13 approves safety and risk classification for the
14 NuScale SSC. For the US460 the evaluations were
15 completed.

16 The D-RAP panel expert insights resulted
17 to changes in some methodology for the panel insights,
18 but without design changes. These include the steam
19 generator tubes as safety-related, not risk-
20 significant components, as well as the control rod
21 drive mechanisms, safety-related, not risk-
22 significant.

23 There were 10 audit items that were
24 resolved. These resulted in updates to Section 8.2
25 and the Figure 17.4-1 to clarify the SSC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 classification process. And there was a single RAI.
2 This was a clarification -- this resulted in a
3 clarification for the section that the process does
4 not assume a risk significance based on safety-related
5 classification. And it also resulted in
6 clarifications in FSAR 17.4.3.2 and the role of the
7 backup diesel generators in Table 19.1-56.

8 Another note of a Revision 2 change that
9 -- from Revision 1 to Revision 2 is the top support
10 structure for the containment vessel was added as a
11 risk-significant component given that it is the
12 connection between the containment and the crane, both
13 of which are risk-significant components. And also
14 the secondary side for the CVCS valves and the
15 pressurizer spray valve were removed as risk-
16 significant components.

17 MEMBER MARTIN: Peter, this is Bob Martin.
18 Earlier there was a number of questions related to
19 what would be the safety-related PAR. Did you
20 explicitly address that in the D-RAP?

21 MR. SHAW: Yes, the D-RAP process reviewed
22 the classification of the PAR as it was presented to
23 them by the responsible system engineers. And in
24 review of the PAR, as stated before, given the
25 significance between both design-basis and beyond-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 design-basis it is classified as a safety-related non-
2 risk-significant component.

3 MEMBER MARTIN: Okay. That's was what I
4 was looking for. Thanks.

5 MR. SHAW: Yes. Okay. Without further
6 questions, I will turn it over to Jim Schneider.

7 MR. SCHNEIDER: Thank you, Pete.

8 Next slide, please?

9 Good morning. My name is Jim Schneider
10 and along with Peter I'll be presenting Chapter 19,
11 the application. I've been with NuScale licensing for
12 three years, and prior to that I spent 20 years in
13 operations at Braidwood Station where I was licensed
14 as both a reactor operator and (Audio interference.)

15 Next slide, please? So Chapter 19 covers
16 the PRA and severe accident evaluation. You see the
17 different sections there up on the slide. During the
18 two years of the staff's review in Chapter 19 there
19 were 156 audit issues resolved in the audit including
20 84 document requests. The majority of those audit
21 issues and document requests were in 19.1, 19.2
22 related to the PRA. There were many discussions on
23 crosscutting issues in Chapter 19. I think it made
24 for a risk-informed review of the application. And
25 then after the audit phase we have 15 RAI questions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 resolved in Chapter 19.

2 I just want to note in the Chapter 19
3 presentation if you see an asterisk, that represents
4 information that was added to Rev. 2 of the SDAA. So
5 the committee hasn't had an opportunity to see that
6 yet, but we wanted to point that out. It might be a
7 change what you've read.

8 Next slide?

9 MEMBER MARTIN: I'm just curious, 84
10 documents is an awful lot of documents.

11 MR. SCHNEIDER: It is.

12 MEMBER MARTIN: Are these calculations?
13 Are these --

14 MR. SCHNEIDER: There were a lot of
15 reports, PRA notebooks. There were calculations. I'm
16 not sure how else to --

17 MS. BRISTOL: We'll say the underlying
18 technical basis of --

19 MR. SCHNEIDER: Yes.

20 MEMBER MARTIN: Okay.

21 MS. BRISTOL: Yes, like all of the various
22 notebooks.

23 MEMBER MARTIN: Thanks.

24 MR. SCHNEIDER: Okay. I'm going to start
25 with 19.1, the PRA. And I wanted to start with just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 an overview of the PRA, why we have one in our
2 application and just to give some context for when we
3 talk about NuScale's PRA numbers.

4 So we have a PRA In the application
5 because it's required by regulation. And as the
6 design progresses from the time it's just an idea on
7 paper to when it's built and producing power for
8 customers there is a PRA required at each phase of a
9 plant's development. And that is a living PRA. It
10 evolves with the plant design. And so the PRA in the
11 US460 SDAA has evolved as the design has evolved from
12 the US600 DCA. And then in the SDAA we do have COL
13 items that ensure that an applicant will have the
14 proper PRA in each of those phases as it moves towards
15 construction and operation.

16 At this phase of the design, the design
17 phase, the purposes of the PRA in general include to
18 evaluate the overall safety of the plant design and
19 provide insights into that -- the design for
20 improvements of the design. And as a reminder, the
21 Commission's safety goals for all nuclear plants are
22 a core damage frequency of less than 1.0E-4 each
23 reactor year and a large release frequency of less
24 than 1.0E-6 each reactor year, which leads into the
25 next slide, please?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 DR. SCHULTZ: Jim, before you go to the
2 next slide, this is Steve Schultz --

3 MR. SCHNEIDER: Yes?

4 DR. SCHULTZ: -- just a comment or a
5 question associated with the general overview you've
6 just provided. As you've indicated each licensee is
7 going to have the requirement to have a PRA and will
8 be using it throughout operation. Are you expecting
9 that each licensee is going to develop their own PRA?
10 Is there going to be a common approach taken by
11 NuScale licensees associated with PRA? What do you
12 envision?

13 MR. SCHNEIDER: Each licensee will be
14 responsible for their own PRA. I'm not sure if
15 there's any -- no, right now, I mean, we don't have
16 any plans we can share with -- I think you're talking
17 about sort of the owner's group, I think.

18 DR. SCHULTZ: Yes, I am.

19 MR. SCHNEIDER: As far as I know unless
20 anyone wants to chime in, that's not in the works for
21 now. I think we're too early in the development.

22 DR. SCHULTZ: It seems like it would be
23 both prudent and also extremely efficient and useful
24 given the new design and the potential applications to
25 many licensees, but just perhaps a comment for now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Thank you.

2 MR. SCHNEIDER: Okay. Thank you.

3 MEMBER HARRINGTON: And this is Craig to
4 follow up with that. I assume the PRA would equally
5 apply to all six modules in the facility?

6 MR. SCHNEIDER: From what I understand --
7 and, Sarah, you may know more -- each module will have
8 its own PRA. Is that correct?

9 MS. BRISTOL: This is Sarah Bristol,
10 manager of the PRA Team. NuScale potentially has
11 services opportunities currently for the SDAA. We've
12 got a single module PRA. And so it is pretty -- it's
13 equivalent to Module 1 or Module 2. It's indifferent
14 of module, but it a single module PRA. And then we'll
15 also take into account multi-module effects. And so
16 we also do expand that into -- and as you'll see on
17 the next slide just insights from multi-module
18 potential, but it truly is single module PRA.

19 MEMBER HARRINGTON: And then the site
20 operator would just have to either have separate PRAs
21 for each module or somehow manage any differences that
22 might develop during (Audio interference.)

23 MS. BRISTOL: Yes, that is true. They
24 would have to take that -- but as of now all of the
25 modules are the same, consistent, and so there's no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 need for modifications at this point (Audio
2 interference.) Yes, thank you.

3 MR. SCHNEIDER: Okay. Next slide, please?

4 CHAIR KIRCHNER: (Audio interference.)
5 address that previous slide. Since one of the
6 purposes is to identify potential design improvements,
7 can you -- you've actually -- from your DCA
8 application you've been working on your PRA for this
9 plant for quite some time. Can you point to any
10 specific areas where the PRA insights led to specific
11 design improvements from the DCA submittal to the SDAA
12 submittal?

13 MR. SCHNEIDER: One improvement that was
14 informed by the PRA was in the ECCS design. We added
15 venturis at the containment isolation valves to limit
16 the inventory loss in the case of a failure of the
17 containment isolation valves to (Audio interference.)

18 CHAIR KIRCHNER: Okay. Thank you.

19 MR. SCHNEIDER: Okay. Next slide, please?
20 So here is a comparison of the results of the PRA from
21 the US600 and the US460, and you'll see that core
22 damage frequency and the large release frequency for
23 the different hazards. We aren't going to go over all
24 the differences in the numbers. They all changed as
25 you can see and that's a reflection of both the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 overall design changes as well as some changes in
2 outside inputs. There are some changes in the generic
3 data, which is an input to the PRA. But it's all
4 reflective of a living PRA. One thing that hasn't
5 changed --

6 MEMBER DIMITRIJEVIC: This is Vesna. So
7 I have a question about this because this was one of
8 my questions. These changes shows little -- the core
9 damage frequency getting little worse. And I assume
10 that this is because of ECCS changes, because ECCS
11 performance has a little degradation because removal
12 of the valve or adding the SOVs.

13 But the thing is which is really shocking
14 to me is this improvement in large release frequency
15 where the previously condition of failure -- of
16 containment failure probability was in order or 0.1,
17 which is requested in -- or expected the safety goal.
18 And it suddenly improve 1,000, like three order or two
19 order of magnitude. So that's a really big change in
20 the results.

21 So, okay. Here's my question: So I
22 assume that all the design changes are reflected in
23 the PRA. And you said also there was some change in
24 generic data and some outside inputs. So what would
25 the other changes than design changes reflected in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 differences between 460 and 600?

2 PARTICIPANT: (Audio interference.)

3 MR. SCHNEIDER: Okay. Go on.

4 MEMBER MARTIN: Your question mostly
5 focused on the large release frequency, Vesna?

6 MEMBER DIMITRIJEVIC: No, my question --
7 first I want to understand before we start discussing
8 because I see that we will come to discuss all of
9 those. So I just pointed out that there's a huge
10 difference in the large release frequencies. And I
11 mean, that could be from -- due to these venturis in
12 the flow restrictions in containment isolation valves.
13 I don't know why it is, but that's a really big
14 difference. And it's really -- I expect to see that
15 through discussion.

16 My question at this moment before we go to
17 the specific discussion, are those differences mostly
18 because of all design changes or there was some other,
19 because you said there was a difference in the outside
20 inputs or in the data? Or will these changes in the
21 data or other inputs impact changes we see here in the
22 results? What about the changes, the design changes
23 consider when this PRA was made specific for 460?

24 MR. SCHNEIDER: I can't speak on which
25 were larger influences in the actual numbers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Sarah, do you have an idea (Audio
2 interference.)

3 MS. BRISTOL: Etienne.

4 MR. MULLIN: This is Etienne Mullin, PRA
5 with NuScale. The change in our results is a
6 combination of changes to the design, changes to the
7 generic data, the input to our models. I think on the
8 upcoming slides we'll talk a bit about why the core
9 damage frequency is changed and then we'll focus quite
10 a bit on the large release frequency changes.

11 MEMBER MARTIN: Those insights that you
12 gain impact in the approved US600 PRA? These are
13 always living documents, but did you get insights?
14 Say as time goes on you always get more information on
15 changes in that sense. Is there kind of a go-back as
16 you learn more about this design, even though of
17 course it is different, that plays back into the
18 US600? And is that being updated?

19 MR. SCHNEIDER: I can't speak to updates
20 that we may or may not be making to the US600 design,
21 but we have evidently learned a lot through the years
22 of maintaining our PRA and applied some of those
23 lessons to the design of the US460 design.

24 MEMBER MARTIN: Okay. I believe Walt had
25 his hand up.

1 CHAIR KIRCHNER: Yes, I wanted to add onto
2 Vesna's line of questioning. So I look at this chart
3 and I see -- let's just start with internal events.
4 You've got a CDF for the DCA of 3 times 10 to the
5 minus 10th. You put a conditional release on the
6 containment, which is 0.1. And you get a large
7 release frequency of 2.3E-11th. So one order of
8 magnitude difference between the two. Then you go
9 over to the new SDAA design. You've got a higher CDF
10 and on the order of three, four order of magnitude
11 difference in the large release frequency.

12 The venturis obviously help you on things
13 like CDF, but they don't isolate containment. So I
14 don't see the marked improvement in the containment
15 design, notwithstanding all the higher pressure rating
16 and such that would give you from an engineering
17 design standpoint four order of magnitude difference.

18 So could you elaborate? That is an
19 enormous spread in PRA space. Take the absolute
20 numbers off and talk about orders of magnitude. That
21 is really significant.

22 MR. SCHNEIDER: Yes, well, we're going to
23 address that in a couple of slides, but just at a
24 quick high level it's a consequence of some changes we
25 made to the ECCS actuation criteria, the removal of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the IABs, the addition of the venturis. All of these
2 design changes have allowed us to mitigate breaks
3 outside of containment with a failure of isolation
4 without requiring the operator action to add coolant.
5 And that's primarily responsible for the dramatic
6 reduction in the large release frequency.

7 CHAIR KIRCHNER: Well, the ECCS changes;
8 I get that, mainly impact your CDF. I don't see how
9 they impact the containment integrity.

10 MR. SCHNEIDER: That's correct. The
11 ability to mitigate these un-isolated breaks outside
12 of containment is due to the ability to actuate ECCS
13 early and depressurize the system to atmospheric
14 pressure such that we are no longer losing coolant and
15 you can keep the core covered without having to add
16 water.

17 CHAIR KIRCHNER: But your CDF has gone up.

18 MR. SCHNEIDER: That's right, but I think
19 that's largely unrelated to the reduction in large
20 release frequency.

21 MEMBER DIMITRIJEVIC: Well, basically your
22 reduction in large release frequency comes from the
23 definition of large, right? By introducing -- by
24 depressurizing and restricting releases you -- what
25 you define as large release has significantly reduced.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Is that what's happening? And we will see this when
2 we start discussing specifically the LOCAs outside
3 containment of your steam generator tube ruptures and
4 things like that which become totally insignificant
5 contributors to the large release.

6 MR. SCHNEIDER: The reduction in large
7 release frequency is not -- has nothing to do with our
8 definition of what a large release is. It reflects
9 the fact that events that previously were core damage
10 and large release are no longer a core damage event
11 and therefore are not a large release event.

12 MEMBER DIMITRIJEVIC: I see. All right.
13 Okay. My original question was that -- what I was
14 concerned is that by the changing data also this
15 contributes to the significance, because you said
16 there was some change in the data. So I just want to
17 make sure that we will understand what are changes due
18 to design changes and what are changes due to the
19 different inputs.

20 Okay. Well, once discuss we will go to
21 the specific right changes and discuss them as we go,
22 right?

23 MR. SCHNEIDER: Yes, we can do that.

24 MEMBER HARRINGTON: And this is Craig
25 Harrington real quick. I assume that the changes in

1 high winds categories were all input data?

2 MR. SCHNEIDER: The last thing I wanted to
3 say about this slide was the one thing that hasn't
4 changed from the DCA is that these CDFs and LRFs are
5 still many orders of magnitude below the Commission's
6 goals. So we still have a very safe plant to offer.

7 Okay. Next slide, Wendy? So I think
8 we --

9 MEMBER DIMITRIJEVIC: Well, that's true
10 what you said, but that could reflect the degree of
11 uncertainty. We don't have a concern about that you
12 safety goals or not. The questions is the -- with
13 determining significant agreement and with determining
14 uncertainty. And this is what changes also. That's
15 why. We are not going to drill you on the -- we
16 understand that this is a safe plant. It's just the
17 question what degree of uncertainties we see in these
18 results and where the PRA provides input how -- why
19 the goals are (Audio interference.)

20 MEMBER MARTIN: Thank you, Vesna. As I've
21 listened to Vesna's question and looking at your slide
22 here, the conditional containment failure probability,
23 of course you say less than 0.1, which is -- I guess
24 comes from the SECY, I don't know, 8387 or whatever.
25 Was there much change between US600 and US460, more or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 less the same magnitude?

2 MS. BRISTOL: This is Sarah Bristol. The
3 magnitude could be calculated with the LRF over CDF.
4 And so it is different. It is orders of magnitude
5 different, yes.

6 MEMBER MARTIN: Okay.

7 MS. BRISTOL: Ultimately as you know
8 that's less than safety goal.

9 MEMBER MARTIN: Yes.

10 MS. BRISTOL: Yes.

11 MR. SCHNEIDER: We pretty much already
12 discussed the contents of this slide about how
13 internal event CDF increased due to in part ECCS
14 changes. And internal events large release frequency
15 decreased. And that's primarily also due to changes
16 to ECCS. But as Etienne said, for a large release
17 those changes are to allow breaks outside of
18 containment to be mitigated without the need for
19 inventory makeup.

20 MEMBER DIMITRIJEVIC: So basically ECCS
21 become less reliable with the current changes, right?
22 Because the level of the vessel is reduced and this --
23 actually this -- the trip valves now dominate this,
24 right, because fail of tube will fail the system. So
25 ECCS become less reliable. That change is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 understandable.

2 Now that's what causes the changes in CDF
3 and also in the contribution from the external events
4 like the winds and tornadoes, right? And I assume
5 that these -- right now we're going to discuss these
6 breaks outside of containment for LRF.

7 MS. BRISTOL: That is correct.

8 MR. SCHNEIDER: And sorry, I think I would
9 clarify, the ECCS valves are not less reliable, but we
10 anticipate more actuations which provides an
11 opportunity for an incomplete actuation which is a
12 contributor to the core damage frequency. So more
13 frequent ECCS actuations result in more frequent
14 incomplete ECCS actuations which results in more
15 frequent core damage frequency.

16 MS. BRISTOL: To clarify also, the
17 developed reliability as you mentioned, Vesna, is less
18 reliable. And so that's one thing that you're seeing
19 here that isn't an apples-to-apples comparison in the
20 cut sets from DCA to SDAA.

21 MEMBER DIMITRIJEVIC: Right.

22 MS. BRISTOL: And so the main valves'
23 reliability reduce -- or increases an order of
24 magnitude. And that's significant. That can be seen
25 in the cut sets. And so while the NuScale design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 hasn't changed, we believe the valves will be
2 reliable.

3 The generic data has changed for what
4 we're using in the PRA for both the main valves as
5 well as those trip valves. So that reliability
6 decreased as well in that generic data that we're
7 using.

8 And as you mentioned, Vesna, there are two
9 trip valves now also in the common cause of those.
10 And so a lot of the potential failures that we
11 consider in the PRA are shown in the increase in CDF.
12 And that's why you see that increase in CDF in all the
13 external events. ECCS can mitigate all those that
14 increased as the ECCS reliability data and the generic
15 data.

16 And so again, there are a lot of ECCS
17 changes that are mitigating these breaks outside
18 containment and that's where you see that -- the
19 increase in the -- or decrease in the LRF frequency,
20 but the CDF is increased because of the ECCS generic
21 data reliability pretty significantly.

22 MEMBER DIMITRIJEVIC: But because of the
23 -- yes, SOV failure rates for three valves dominates
24 now the ECCS. That's correct.

25 Okay. And now we will see on this

1 frequency. This is also interesting. All right.
2 Okay.

3 MR. SCHNEIDER: Okay. So this slide we're
4 going to talk about the mitigation of those un-
5 isolated breaks outside of containment. So early ECCS
6 actuation limits inventory loss through the break by
7 reducing the systems to atmospheric pressure.

8 And the relevant ECCS design changes,
9 which we've discussed all of these in the earlier
10 session. The removal of the IABs on reactor vent
11 valves, the addition of a low reactor pressure vessel
12 riser level, ECCS actuation signal, and then those
13 venturi flow restrictors on the CVCS lines.

14 That limits the break flow before you get
15 pressure released to atmospheric pressure.

16 During the review we added an uncertainty
17 to our table of uncertainties in the application
18 addressing the likelihood of weld failures between the
19 containment vessel and the containment isolation
20 valves. So it's a very unlikely weld failure and
21 there are means for a plant to identify a possible
22 weld leak before it gets to the weld break stage. And
23 so those factors combined we get an event that we
24 don't specifically analyze, but we wanted -- we
25 included it as an uncertainty (Audio interference.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER DIMITRIJEVIC: Okay. So basically
2 you don't consider isolated breaks, right, because of
3 the low likely of failure? So that's all right. How
4 about -- okay. So what you're said previously is that
5 the early actuation and reduction in the pressure
6 actually you -- the loss of the coolant outside of
7 containment doesn't require any makeup in the -- and
8 then that's a main difference between the previous --
9 between 600 and 460?

10 MR. SCHNEIDER: That's correct.

11 MEMBER DIMITRIJEVIC: All right. So now
12 I see what you mean. So the core damage frequency
13 never occurred because you didn't really -- you didn't
14 need any makeup for those losses?

15 MR. SCHNEIDER: Correct.

16 MEMBER DIMITRIJEVIC: And you guys done
17 success criteria? And that's not a shock?

18 MR. SCHNEIDER: Yes. Yes, that's correct.
19 Yes.

20 MEMBER DIMITRIJEVIC: I see. And same
21 thing for steam generator tube ruptures?

22 MR. MULLIN: This is Etienne again. The
23 question is have we preformed simulations -- success
24 criteria simulations for steam generator tube
25 ruptures. And the answer is yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER DIMITRIJEVIC: All right. And was
2 there anything else significant that would -- did you
3 need the DHRS for the initial pressure reduction or
4 the -- I'm just trying to think that this is a big
5 difference basically. You don't really have LOCAs
6 outside of containment anymore. You don't have
7 containment bypass events which dominated previous
8 LRF, yes.

9 MR. MULLIN: So the -- I -- maybe call it
10 a system success criteria for this event is unique to
11 have success without adding coolant to the NPM. We
12 need all of the ECCS valves to open, not just one vent
13 valve and one recirc valve. And we also need DHRS to
14 (Audio interference.) So we need our passive systems
15 to work effectively to be able to show success without
16 adding coolant.

17 MEMBER DIMITRIJEVIC: And what happen if
18 that fails?

19 MR. MULLIN: What happens if that fails
20 is --

21 MEMBER DIMITRIJEVIC: What happen if you
22 fail like for example -- I'm just -- I'm sorry. I'm
23 just opening your event trees. So what happen if you
24 fail the -- you need the operator to bypass -- okay,
25 here is un-isolated. Okay. So you need to open all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 four DHRS. You have to open all four ECCS valves,
2 right? And --

3 MR. MULLIN: That's right.

4 MEMBER DIMITRIJEVIC: -- then if you don't
5 open those all four, then you go for makeup, right?

6 MR. MULLIN: Yes, but the operator is
7 going to --

8 MEMBER DIMITRIJEVIC: You need to open at
9 least two and then makeup. Is that the true
10 statement?

11 MR. MULLIN: (No audible response.)

12 MEMBER DIMITRIJEVIC: Okay. All right.
13 Sorry. Sorry. Sorry I interrupted you. So if you
14 don't open four, then your success criteria open two
15 and other makeup, right?

16 MR. MULLIN: That's correct.

17 MEMBER DIMITRIJEVIC: I see. And does
18 that sequence lead to the large release?

19 MR. MULLIN: If operators fail to add
20 coolant, that's correct.

21 MEMBER DIMITRIJEVIC: So if you fail to
22 open all four ECCS valves, those sequences will lead
23 to the large release frequency?

24 MR. MULLIN: Yes, but again operators
25 would have to also fail to add coolant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER DIMITRIJEVIC: All right. Thanks.
2 You can continue. I just have to think about that.
3 I have to check in the LRF cut set will I see this.
4 Okay. All right. Continue.

5 MR. SCHNEIDER: Next slide, please?

6 MEMBER ROBERTS: Yes, this is Tom Roberts.
7 Just wondering, if you're reducing the system's
8 atmospheric pressure is there a potential for air
9 leakage back into containment?

10 MR. SCHNEIDER: Yes, we would expect that.

11 MEMBER ROBERTS: Then that would seem to
12 be a lot more oxygen than the assumption of just
13 radiological decomposition that -- if you start
14 sucking in air, it seems like you then are more
15 relying on the power or some other means to maintain
16 the inert environment? That right? I thought since
17 there's no concern on certain reactions on hydrogen
18 combustion. It sounds like if you start sucking air
19 back into containment, then you would have to provide
20 more on the PAR.

21 MR. SCHNEIDER: So this is not a severe
22 accident. Haven't experienced core damage.

23 MEMBER ROBERTS: Okay. So there's no
24 scenario like this where you reduce system pressure
25 where you do get core damage?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. SCHNEIDER: So in events with core
2 damage and a failure of the containment boundary we
3 already consider that a large release. So let's say
4 all four ECCS valves did not open, operators failed to
5 add coolant, core damage occurs with an open CVCS
6 line. And there will be a period of time where you're
7 generating hydrogen and maybe your system pressure
8 will actually increase above atmospheric, but you
9 could get to a case where come back down to atmosphere
10 you're pulling air in. The assessment on
11 combustibility within the containment is largely
12 irrelevant. We've already had a large release (Audio
13 interference.)

14 MEMBER ROBERTS: Okay. So the compounding
15 effect of the hydrogen issues and consider the
16 analysis because you're already -- basically you have
17 your release?

18 MR. SCHNEIDER: Yes, we don't evaluate it
19 beyond the point of it being a large release.
20

21 MEMBER ROBERTS: Okay. Thanks.

22 MEMBER MARTIN: And this is Bob. You all
23 run like NRELAP5 analyses of these scenarios? I would
24 not expect a whole lot of air typically to blow down.
25 And there's a brief period where you might draw from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the atmosphere, but it's hot and it's going to boil.
2 Then you're going to push that out. I would expect
3 that you've done analysis on what you've see.

4 MR. SCHNEIDER: So, yes, I might be going
5 a little bit out on a limb, but if you were to have an
6 open penetration to the environment, you would
7 depressurize to below atmospheric pressure. I don't
8 know the figure right -- but several psi, certainly
9 many psi below atmospheric pressure. And so that
10 delta between what you would depressurize to and
11 atmosphere that's how much air you're going to be
12 holding.

13 MEMBER MARTIN: Right. Then once that
14 little -- it's really a brief period of time where you
15 drop below and then you will -- because these things
16 are at the top, right, this basically events at this
17 point?

18 MR. SCHNEIDER: Yes.

19 MEMBER MARTIN: So it should be a
20 relatively small amount of oxygen that (Audio
21 interference.) You're still going to be -- you're
22 still hot, you know, boiling, and it's going to
23 continue post-critical flow to release steam.

24 MR. SCHNEIDER: Yes.

25 MEMBER MARTIN: So you would not expect

1 that. My question was really that the analysis was
2 NRELAP5, right? Or something.

3 MR. SCHNEIDER: I primarily use NRELAP5
4 for these success criteria analyses to demonstrate
5 that core damage doesn't occur. We also use MELCOR
6 for following severe accidents, core melts scenarios.
7 But there's some overlap where it will benchmark the
8 codes.

9 MEMBER MARTIN: Okay. Thanks.

10 MR. SCHNEIDER: So our next topic is
11 regarding how NuScale determines --

12 MEMBER MARTIN: (Audio interference.) your
13 microphone, please.

14 MR. SCHNEIDER: Thank you. So our next
15 topic is how NuScale determines component candidates
16 for risk-significance. We use both an absolute
17 criterion and a sliding scale to determine the
18 components. And the sliding scale is a change from
19 the DCA.

20 So the sliding scale applies only to an
21 importance factor. There is no change to the absolute
22 conditional core damage frequency and conditional
23 large release frequency thresholds. And you can see
24 that in the top two rows of the table there, which is
25 from the application. That's for a component and then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 system. And those criteria are unchanged from the
2 DCA.

3 Now what's new. The next four rows, which
4 is that sliding scale for this importance factor. And
5 the reason that NuScale did that is to identify
6 components that have -- that actually contribute to
7 absolute risk in the PRA. And so, the sliding scale
8 was chosen in a way that tries to equalize the
9 absolute risk. As the core damage or large release
10 frequency gets lower it tries to identify components
11 that contribute the same absolute risk to that hazard
12 with some allowance for -- from uncertainties in it.

13 MEMBER DIMITRIJEVIC: I have a lot of
14 comments, yes. I don't want to go to this discussion
15 on absolute relativity because I happen to disagree of
16 this discussion, but that's another one. That's a
17 philosophical question.

18 What is relevant for my discussion on
19 this, if you look -- like let's say look in the large
20 release frequencies. And your conditional LRF is 3
21 minus 7. That's mean that the -- and you know, and
22 I'm much more interested in this measure than Fussell-
23 Vesely. Fussell-Vesely reflects basically -- if
24 you're going to make these component, which you
25 evaluating perfect, how much you will improve CDF?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 When it comes to D-RAP -- went through a lot of thing
2 -- much more is interesting what will happen if this
3 component is like to fail? In that case your
4 conditional LRF, or what will be risk achievement?
5 What is the condition of core damage frequency, and
6 much more interesting, risk measure?

7 And what you are saying here in this table
8 -- we just saw that your LRF is in the order of the E-
9 13. So you're saying if the component fails and LRF
10 is now 3 minus 7 -- if is -- your LRF is now less than
11 3 minus 7. So let's say is $2.0E-7$. It's changed from
12 minus 13 to 3 minus 7. That component is not
13 important. That doesn't make any sense because this
14 is a huge increase in LRF. And how can you say that
15 that component would not be important?

16 You see what I'm saying, that when looks
17 at risk achievement vault, if you're allowed in your
18 conditional LRF given this component failure to be --
19 as long as it's less than 3 minus 7, that component is
20 not important? But your actual LRF is -- I don't
21 know, I mean, is dependent of the events. But let's
22 say the total LRF is $10.E-11$. You allowed four order
23 of magnitude to increase in LRF if this component is
24 fail and this component is still not considered risk-
25 important. There has to be some breaks there. Who

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 can say that component which was 1,000 time increase
2 my large release is to important? That's a question.
3 I would like to hear your thinking on it.

4 MS. BRISTOL: Thank you, Vesna. This is
5 Sarah Bristol. I understand the question. And I
6 think what we're looking at here, as you know, are
7 potential risk -- significance criteria for
8 consideration for candidates, just one part of the
9 consideration, and they are thresholds that we
10 proposed and reviewed in the topical.

11 And I guess I would say ultimately they're
12 well below the safety goals for one. And so just
13 because of that large delta it doesn't necessarily
14 indicate a less-safe design or a less-safe system or
15 component. And so we can -- is E-7 important? But as
16 you mentioned, we're looking at overall frequencies
17 and large release frequencies in this case in the
18 order of E-13.

19 Based on the analysis we did our numbers
20 for the system importance didn't really get up that
21 high and so it might be a no-never-mind here, but
22 ultimately these thresholds are well below the safety
23 goals. And so I guess I would just stop there. And
24 I understand that delta, how that could seem,
25 quote/unquote, significant, but ultimately the overall

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 safety of the plant is still confirmed by the design
2 and the risk insights.

3 MEMBER DIMITRIJEVIC: And as I promised,
4 we are not questioning safety of the plant. Even we
5 can question if you liked all of these components not
6 to be in tech specs. And it can be definitely out
7 operation and things like that and combine all of
8 those which are classify as not risk-significant. But
9 one of the question is you're coming here as a plant
10 which is much safer as currently operated plant. And
11 t h a t ' s p r o b a b l y t r u e .

12 I just want to say though your risk-
13 significance determination, it does not really show
14 that. I mean, you have to -- this is where using --
15 actually you are using absolute risk measure, not your
16 relative increase. You're just using what current
17 plants are using and saying, okay, well, we are still
18 much better than that. That doesn't mean when you
19 combine all of those systems that you are going to
20 declare to be not risk-significant that we don't know
21 really what the risk profile is.

22 Also the other thing is here when you go
23 -- like say for example, for D-RAP -- and I did not
24 discuss that in 17.4 -- if you're going to -- if
25 you're just going to give them these risk measures,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there is nothing that which is going to be risk-
2 important. You have a very low risk profile. And
3 then you're using Fussell-Vesely's. It's no wonder
4 that -- other than the main stuff. You're not going
5 to find anything else that will be risk-important.

6 Maybe some additional inputs have to be
7 provide so that those components which have a very
8 high -- if they're left to run to failure, have a very
9 high impact on risk should be identify. That's my
10 point. Because that's basically showing that your
11 defense-in-depth is significantly reduced.

12 So my point is we are just -- and I know
13 that you have this TR approve as a part of your 600
14 application. And we are ready to -- we would like
15 also to discuss these things with the staff. The
16 thing is here is that some additional break should be
17 put in so that defense-in-depth is not significantly
18 reduce and that this profile is -- this profile
19 remains low. So, okay. I just made this point.

20 I do know that you can -- you're not going
21 to change things and things like that. But when comes
22 to the D-RAP and things like that maybe some
23 additional inputs should be identify. And maybe you
24 should provide this high conditional core damage
25 frequency and large release frequency as inputs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. BRISTOL: Thank you, Vesna. Yes, we
2 are a member of the D-RAP panel and we are able to
3 take our insights and the actual calculations. So
4 while maybe these thresholds seem high, they are what
5 they are. But the PRA individual is able to go to the
6 D-RAP panel and share those insights, share those
7 deltas, the actual values. And the panel can then
8 determine from that. So it's not necessarily just
9 limited to these thresholds itself. The PRA
10 individual does bring those values and those insights
11 to the panel for discussion. The panel can even
12 decide to make things -- classify them as risk-
13 significant even if they don't meet this criteria.

14 So again, I wouldn't say we're limited to
15 this table, but the panel itself can make their
16 decisions with this consideration -- with these
17 considerations and these inputs.

18 MEMBER DIMITRIJEVIC: Okay. Good.
19 Thanks. This is good to hear because one of the
20 examples -- you're relying on this very passive
21 systems which there is not much operating experience
22 and you are also going to evaluate this passive
23 cooling criteria. But then all the backup systems to
24 the makeup are coming as a known risk-significant. So
25 it's just like the operator action or things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 necessary. So this is one of my concerns.

2 MR. SCHNEIDER: And I'll just add on,
3 Sarah, to what you said about the panel. In his
4 discussion of 17.4 Peter Shaw mentioned that we may be
5 made the top structure risk-significant. And that was
6 based on the judgment of the expert panel, not because
7 of input from the PRA.

8 Okay. I believe that ends --

9 CHAIR KIRCHNER: Well, since you threw
10 that out, I can't pass up -- this is Walt Kirchner.
11 Well, first of all, I share Vesna's concerns because
12 from the DCA we had -- when you did the D-RAP the CVCS
13 system was not considered important, yet that was the
14 only means really, that and the containment drain and
15 fill system for actually restoring any lost coolant.
16 So that makes one, pardon my saying it like this,
17 scratch my head and say is this a mathematical
18 exercise or is this an engineering exercise?

19 And so I share Vesna's concern that this
20 may be consistent with the Reg Guides and the PRA
21 standards, but from an engineering standpoint it begs
22 the question about defense-in-depth.

23 As far as the upper structures, of course
24 they would be important in seismic analysis because if
25 those pipes aren't properly supported like the CVCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 inlet and outlet lines, then the possibility of those
2 being fractured during a seismic event become much
3 higher. So it's just good engineering to make that
4 logical conclusion even if the PRA hadn't specifically
5 gone to that level of engineering detail and analysis.
6 So I meant that more as an observation, not as a
7 question.

8 MR. SCHNEIDER: Okay. Thank you. I
9 believe that ends our presentation on 19.1.

10 So next slide, please? We'll move onto
11 19.2, which is severe accident evaluation. There's
12 one change to 19.2 that we wanted to present to the
13 Committee and there's a new COL --

14 MEMBER DIMITRIJEVIC: Excuse me. Excuse
15 me. Can we just go back? I don't want to leave 19.1
16 before discussing steam generator tube rupture with
17 the NuScale because the steam generator tubes were
18 evaluated as not risk-significant. And in our
19 discussion with -- about the DW, that was -- one of
20 the argument was the steam generator tube rupture was
21 found not to be risk-significant from the PRA.

22 So what we saw previously in the 600 is
23 that the steam generator contributed 1 percent to the
24 LRF. It was much higher in that time. And now
25 contribute less than -- I don't think 0.1 percent to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the LRF, which is much lower. That's mean actually
2 steam generator tube rupture contribution to the LRF
3 was totally eliminated. It's down to 10 to minus 14
4 or something less than that, or 10 to minus 15.

5 So how that happen? What's the
6 difference? What is the difference in design that
7 contribute to the steam generator tube rupture is not
8 important? That's one of my questions. I wasn't
9 sure, should I ask that when staff discuss it or with
10 you. But I would like to hear NuScale argument on
11 that.

12 And the second thing is when the
13 sensitivity runs around for the multiple steam
14 generator tube ruptures and the tube ruptures in the
15 two different steam generators, they both show as not
16 risk-significant. So can we just have a discussion on
17 it?

18 MR. SCHNEIDER: Yes, certainly.

19 Etienne, do you want to address those
20 issues?

21 MR. MULLIN: So to your first question,
22 steam generators can contribute -- steam generator
23 tube failures can contribute to a large release or can
24 I guess result in a large release in the same way that
25 a CVCS injection line break outside of containment can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 lead to a large release. You need failure of
2 isolation. And there's the ability to reach
3 atmospheric pressure without coolant addition. So
4 from going from US600 to US460 the same design changes
5 that have reduced the large release frequency across
6 the board also apply to steam generator tube breaks.

7 As for the relative contribution of steam
8 generator tube breaks to the large release frequency
9 compared to -- injection lines breaks rather
10 contributes to a large release frequency, I can't
11 speak to that directly at this moment.

12 As for I think your second question, we
13 perform sensitivities on steam generator tube breaks
14 specifically looking at multiple tubes failing instead
15 of just one tube. And we demonstrated that that has
16 no meaningful impact on the event progression. You'll
17 just reach a low RPV level faster. And the normal
18 progression is you'll isolate the line sooner.

19 We also looked at steam generator tubes
20 failing in both trains of steam generators
21 simultaneously, or both steam generators I should say.
22 And the impact of that has is both trains of DHRS
23 become inoperable in effect, or ineffective. And we
24 had sensitivities already for the PRA where we assumed
25 that DHRS always fails and could be demonstrated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 through those sensitivities that the DHRS is not risk-
2 significant. So, yes, I think that's how I'd answer
3 your questions.

4 MEMBER DIMITRIJEVIC: Well, when I look at
5 the steam generator response, the three, I don't see
6 any -- if an insulated steam generator tube rupture,
7 just require ECCS actuation. And it's not the makeup
8 to the CVS makeup. I guess you don't really -- CVS is
9 variable here. You're not considering the flood --
10 containment flood system. But the thing is, so what
11 is the difference? Why was the large release much
12 higher in the -- I don't see any -- there is no
13 equalizing here pressure, the -- all four valves
14 opening, things like that. What is the difference
15 between the steam generator tube rupture in the 600
16 and here?

17 MR. SCHNEIDER: And so, again, it's
18 similar to the impact on injection line breaks with
19 the US460 design. If ECCS actuates successfully, it
20 will reach atmospheric pressure and the core will
21 remain submerged without requiring coolant addition.
22 So, that dramatically reduces the contribution to
23 large release frequency.

24 Steam generator tube breaks generally are
25 less challenging than the injection line break case.

1 So as in the case of the injection line break, to
2 reach atmospheric pressure with the core covered
3 without having to add coolant, you need all of the
4 ECCS valves to open. You need DHRS to work.

5 But for the similar scenario with this
6 unisolated steam generator tube break, you actually
7 only need one train of ECCS to succeed, I believe, or
8 one vent valve and one recirc valve.

9 And you don't need any DHRS. And that's
10 simply because it's a less challenging event with a
11 smaller flow area, more pressure drop along the steam
12 generator tube path. And I believe that the minimum
13 elevation of the break is higher than the opening of
14 the injection line.

15 So, for all of these reasons, steam
16 generator tube breaks are less challenging than other
17 unisolated breaks, outside of containment.

18 MEMBER DIMITRIJEVIC: Okay, well, so let
19 me just ask you. So, here there was no new design
20 change to contribute to that, it's just that you have
21 different success criteria?

22 That's the first question. The second
23 question is, would then multiple tubes make
24 difference? I mean, obviously, we are just discussing
25 the size of the LOCA here. But the thing is that if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 it is less challenging because there's a smaller LOCA
2 size, then I mean, then multiple tube ruptures will
3 make a difference, and you said that that doesn't
4 matter.

5 I mean, so -- and okay, so I don't want to
6 mix multiple questions. Let's just start with the
7 first. Here, it's totally the same assumptions as was
8 in the 600. It's a totally same sequence. And in the
9 600 it was assumed to lead to the large release and
10 here, assume not to lead to large release so that you
11 just have different success criteria.

12 MR. SCHNEIDER: No, the event progression
13 is different because of changes to the ECCS scheme,
14 that is a removal of the IABs, the use of the low RPV
15 level signal.

16 Those are changes we implemented for US460
17 in order to mitigate containment bypassing breaks.

18 MEMBER DIMITRIJEVIC: Okay, I get that.
19 So it's just earlier ECCS actuation made the
20 difference. That's what you're saying?

21 MR. SCHNEIDER: That's right.

22 MEMBER DIMITRIJEVIC: So, earlier ECCS
23 actuation actually prevents the --

24 MR. SCHNEIDER: It prevents core damage
25 for the event.

1 MEMBER DIMITRIJEVIC: But always, it
2 always prevent the core damage and so now I'm just
3 like, I mean didn't ECCS actuation always prevent the
4 core damage?

5 I mean, I just like I cannot see what is
6 different.

7 MR. SCHNEIDER: What's different is we no
8 longer require containment isolation to be successful.
9 And I'm talking about the difference between US600 and
10 US460.

11 MEMBER DIMITRIJEVIC: All right, I have to
12 think about that.

13 All right, thanks.

14 MS. BRISTOL: And also to add on to that
15 Vesna, if you looked at the event tree for tube
16 failures from DCA, we needed inventory addition for
17 success.

18 And so, here again with that earlier ECCS
19 actuation similar to breaks outside containment, you
20 don't need that addition, inventory addition.

21 And so, for tube failures in the DCA
22 design, we had taken credit for RCS injection, as well
23 as containment flooding.

24 MEMBER DIMITRIJEVIC: Okay, all right.
25 That's interesting. I mean, that's really -- okay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 thank you.

2 MR. SCHNEIDER: In 19.2, we added a COL
3 item related to survivability in our design. There
4 are several components that will have a severe
5 accident dose that is actually larger than the EQ
6 dose, environmental qualification dose.

7 So, to ensure that a licensee captures
8 that in the design specs for that equipment, we have
9 a COL item for them to identify those components.

10 And, that is a change to rev 2, so you
11 won't see that.

12 MEMBER HARRINGTON: But wouldn't those,
13 this is Craig. Wouldn't those components be part of
14 the MPM supplied by NuScale?

15 MR. SCHNEIDER: I don't know. I'm not
16 familiar with the supply chain.

17 MEMBER HARRINGTON: Yes, but it seems --
18 (Simultaneous speaking.)

19 MR. SCHNEIDER: So, yes --

20 MEMBER HARRINGTON: -- that you would have
21 something for an applicant to fill out, that's going
22 to be a part that's physically in the module when it
23 arrives on their site.

24 MR. SCHNEIDER: It's just I guess an extra
25 insurance that the dose requirements are, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 CHAIR KIRCHNER: Why, yes, just to add,
2 this is Walt Kirchner, to add on to Craig's comment.
3 This goes somewhat related to our discussion in
4 earlier meetings about what really a standard design
5 means.

6 If they're not captured by the licensee,
7 then that's a major equipment modification, i.e., if
8 the severe accident dose is greater than the
9 environmental qualification dose.

10 So, this seems to pose a rather difficult
11 set of requirements on a COL applicant to, I hate to
12 use the word backfit the design, to meet the severe
13 accident dose requirements.

14 MR. SCHNEIDER: It's not a backfit. They
15 will, I mean they're going to address it up front.
16 And, that information is already in the application in
17 Section 19.2, those components are identified.

18 CHAIR KIRCHNER: So why would you not
19 design for this requirement in the SDAA, and not wait
20 for the COL?

21 MR. SCHNEIDER: It's a standard design.
22 We don't have, I mean on a lot of components we don't
23 have just the -- I don't want to say this wrong.

24 They are designed for this requirement.

25 CHAIR KIRCHNER: Well, that's the logical

1 answer I would like to hear. So why is it a COL item?

2 MR. SCHNEIDER: There was a concern that,
3 I think that the requirements could get overlooked
4 because they are in chapter 19. I think that was the
5 concern that was brought to NuScale.

6 It's unusual for components to have a
7 severe accident dose greater than the EQ dose. And
8 so, there was a concern that an applicant might just
9 go off of the EQ specs in chapter 56, but --

10 MEMBER MARTIN: Well, you have, this is
11 Bob. You've done the severe accident evaluations.
12 You made assumptions based on your design of where
13 everything is.

14 I don't think there could be too much that
15 a specific plant could do to change, change a design
16 and where things are located, right?

17 You don't expect a big difference, but
18 you're saying that this is a way to elevate the
19 importance? Kind of to --

20 MR. SCHNEIDER: Yes.

21 MEMBER MARTIN: -- just not let this slip
22 through the cracks?

23 MR. SCHNEIDER: Correct. I think that's
24 --

25 (Simultaneous speaking.)

1 MEMBER MARTIN: It shouldn't be necessary.

2 MR. SCHNEIDER: Correct.

3 MEMBER MARTIN: But this kind of shines
4 the light on it.

5 MR. SCHNEIDER: Yes. All the information
6 was there before the COL item was added.

7 MEMBER HARRINGTON: But it almost feels
8 like different chapters aren't talking to each other.
9 Find this over here in chapter 19. You go write it
10 down in the other chapter that has the EQ
11 requirements, then you don't need the COL item.

12 MEMBER MARTIN: Sometimes when you're
13 trying to be extra careful, it just raises more
14 questions, so. I'm sympathetic, I've been on your
15 side of the table.

16 Any more questions on Section 19.2?

17 MR. SCHNEIDER: Let's move on to 19.3.

18 19.3 is Regulatory Treatment of Non-Safety
19 Systems. There was no change from the DCA in terms of
20 methodology or the results, and no SSC were identified
21 as needing regulatory treatment for non-safety
22 systems.

23 Next slide, please.

24 19.4 is Strategies and Guidance to Address
25 Mitigation of Beyond Design Basis Events. And, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the SDAA, the applicant has the responsibility of
2 addressing that issue.

3 And, we expect the applicant to use
4 NuScale's topical report for that, which has been
5 presented to the NCRS.

6 And, that concludes my presentation in
7 chapter 19. I will pass it off to Peter Shaw, to
8 present 19.5.

9 MR. SHAW: Hello, this is Peter Shaw
10 again. As Jim said, I will be presenting a couple of
11 slides here on the aircraft impact assessment for the
12 delta between the SDA, and the DCA.

13 Most significant obviously, is the 6-
14 module design versus the 12-module. So, the building
15 footprint changed.

16 The other significant change would have
17 been the fuel plate composite walls, along with the
18 reinforced concrete members. That was also a change
19 between the two.

20 There are some additional differences
21 between the SDA and the DCA. No other buildings are
22 credited as intervening structures.

23 The DCA credited the rad waste building.
24 FSAR Section 19.5.1 updates how the assessment was
25 performed.

1 This includes models for concrete and
2 steel, as discussed before. That was part of the fuel
3 composite design change.

4 19.5.4.1 had some updates for the physical
5 damage. These include key design features.

6 The reactor building equipment fissile
7 work door design changed. This also includes an SC
8 construction, and these were included as key design
9 features.

10 And then last was the emergency core
11 cooling system was identified as a key design feature,
12 as well.

13 Next slide, please.

14 So, for the review, there were 12 audit
15 questions. Four were resolved with no changes to the
16 SDA; eight were transitioned to RAIs.

17 And for the RAIs, some additional changes
18 were included in the FSAR. These were clarifications
19 on the basis of the steel composite wall efficacy.

20 Some details were clarified for key
21 structural features. The reactor building equipment
22 door was discussed with some equivalents for SC walls.

23 And then, some other key design features
24 were added in accordance with the NEI 07-13 guidance.

25 And, there were some changes that will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 upcoming from the SDA revision 1 to revision 2.
2 There's also supporting updates in Figures 1.2, but
3 the overall conclusions remain the same.

4 It is still consistent with the NEI 07-13
5 Revision 8 Guidance without exception. And, it meets
6 10 CFR 50.150(a) with containment, core cooling
7 capability, and spent fuel integrity.

8 And, this is largely owed to the fact that
9 our safety related features and the 51.50 components
10 are consolidated to the modules themselves.

11 So, so long as the bays inside of the
12 reactor building are intact, then we are also assured
13 that those three requirements are also met.

14 MEMBER MARTIN: I believe that's your last
15 slide, correct?

16 MR. SHAW: Yes.

17 MEMBER MARTIN: Any further questions,
18 whether in the room or online? Members and
19 consultants.

20 Not hearing any, it's 12:31 and that was
21 according to our schedule, we're going to have a lunch
22 break.

23 So, but we're not done with the open
24 session. We will come back. We will recess for an
25 hour for lunch, and then we'll hear from the staff on

1 our return at 1:30.

2 So, recess, come back at 1:30.

3 (Whereupon, the above-entitled matter went
4 off the record at 12:32 p.m. and resumed at 1:30 p.m.)

5 MEMBER MARTIN: Okay, it is 1:30. This is
6 NuScale subcommittee. We've been discussing chapter
7 6, chapter 17, or Section 17.4 and chapter 19 this
8 morning.

9 We're reconvening with the staff's review
10 of Section 17.4 and chapter 19.

11 Who will get us started?

12 MR. CHOWDHURY: Yes, yes, good afternoon.
13 Alina, would you please go back to the previous slide?
14 Thank you.

15 So, good afternoon. My name is Prosanta
16 Chowdhury. I am a senior project manager at the NRC's
17 Office of Nuclear Reactor Regulation, Division of New
18 and Renewed Licenses.

19 I have been with the NRC for very close to
20 20 years now, and 17 of which I have been a project
21 manager.

22 Staff will present to the ACR subcommittee
23 their review of NuScale SDAA FSAR, Revision 1, Chapter
24 17, Quality Assurance and Reliability Assurance.
25 Specifically, Section 17.4, Reliability Assurance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Program.

2 I would like to mention here also that it
3 is not only the revision 1 itself that came in October
4 of 2023, but subsequently, the docketed responses to
5 audit questions, and docketed response to request for
6 additional information.

7 So, all other sections of chapter 17 were
8 presented to the ACRS subcommittee on March 19, 2024.

9 Next slide, please.

10 So, this is an overview slide. NuScale
11 submitted chapter 17, revision 0 on December 28, 2022,
12 and then revision 1 on October 31, 2023.

13 The NRC staff performed a regulatory audit
14 as part of its review of chapter 17, Section 17.4, in
15 this case from March 2023 to June 2024.

16 Questions raised in the audit were
17 resolved within the audit, one RAI was issued and the
18 response was acceptable.

19 NuScale already showed that RAI and what
20 -- its impact on certain section of the FSAR.

21 Staff completed the review of this section
22 and issued an advanced safety evaluation report, to
23 support the ACRS subcommittee meeting today.

24 But there are no significant changes
25 between the draft SE that the staff provided to ACRS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 on 18 of January, and the one we recently provided 12
2 of February 2025.

3 Next slide, please.

4 The contributors to this section,
5 technical reviewers are Alissa Neuhausen, Steven
6 Alferink, and Keith Tetter.

7 Again, I am the project manager and
8 Getachew Tesfaye is the lead project manager.

9 Next slide, please.

10 So, this slide and the next slide, there
11 are two slides the NRC staff Steven Alferink will
12 present. And, I'll turn it over to Steve.

13 Steve, take it away, please. Thank you.

14 MR. ALFERINK: Thank you, Prosanta.

15 As Prosanta said, my name is Steven
16 Alferink. I'm a reliability and risk analyst in the
17 Division of Risk Assessment.

18 I was one of the reviewers and I'll be
19 presenting the staff's review of FSAR Section 17.4.

20 During our review, the staff focused on
21 four areas where there were significant changes from
22 the DCA to the SDAA.

23 The first two related to changes in the
24 plant design, and the last two related to changes in
25 D-RAP classification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 The first was related to the augmented DC
2 power system EDAS, which holds the reactor vent and
3 valves closed, and maintains the reactor coolant
4 pressure boundary during normal operations.

5 EDAS contributes to defense in depth in
6 the design because the reactor vent valves do not
7 include an inadvertent actuation block valve that was
8 present with DCA, as we discussed earlier.

9 The second was related to the safety
10 related-PAR, which maintains a containment atmosphere
11 inert during design basis and significant beyond
12 design basis events.

13 The third was related to the safety
14 related steam generator system, or SGS.

15 And, the fourth is related to the safety
16 related components to the control rod drive system, or
17 CRDS, which were not identified as risk-significant in
18 the SDAA, but were identified as risk-significant in
19 the DCA.

20 Next slide, please.

21 Based on its review, the staff made the
22 following findings. For EDAS, the staff finds that
23 the augmented design requirements are comparable with
24 the design requirements for D-RAP SSCs.

25 For the PAR, the staff finds that the

1 safety classification of the PAR is acceptable.

2 For SGS and the CRDS, the staff finds that
3 the SGS and applicable CRDS components are safety
4 related, and subject to the requirements of the
5 quality assurance program description, QAPD.

6 So in summary, the staff finds that the
7 design and quality requirements for EDAS, the PAR,
8 SGS, and the safety related components meet the intent
9 -- sorry, safety related components, CRDS -- meet the
10 intent of the Commission policy stated in item E of
11 SECY-95-132.

12 And, that the design and quality
13 requirements resulting from the classification of SSCs
14 is consistent with the guidance in SRP section 17.4.

15 So that is the end of the staff's
16 presentation on Section 17.4.

17 MEMBER MARTIN: Okay, if there are no
18 questions, I assume next it's chapter 19, correct?

19 MR. ALFERINK: Yes.

20 MEMBER MARTIN: Okay.

21 PARTICIPANT: Speak up, please.

22 MEMBER MARTIN: No, you're still coming
23 through pretty quiet.

24 MS. SCHILLER: I would like to thank the
25 ACRS subcommittee, NuScale Power, and the general

1 public for staff's opportunity to present the
2 significant changes from the DCA and SDAA for chapter
3 19 for probabilistic risk assessment and severe
4 accident evaluation.

5 NuScale submitted chapter 19 version zero
6 SDA safety evaluation analysis report in December
7 2022, and revision 1, October 2023.

8 From March 2023 through August 2023, the
9 NRC conducted a regulatory audit on chapter 19, which
10 generated 117 issues.

11 Issues raised during the audit, were
12 resolved within the audit.

13 Six requests for additional information
14 were issued, and all of those were accepted in this
15 document.

16 The staff completed chapter 19 review and
17 issued an advanced safety evaluation to support
18 today's ACRS subcommittee meeting.

19 Since providing the draft safety
20 evaluation to ACRS in January, on Table 19.1-4 was
21 updated to include two COL items which were
22 inadvertently missed from the draft.

23 The contributors were Alissa Neuhausen,
24 Marie Pohida, Sunwoo Park, Keith Tetter, Michael Swim,
25 Anne-Marie Grady, Steven Alferink, George Wang, Thinh

1 Dinh, and Ryan Nolan.

2 I'm the chapter team lead here and
3 Getachew Tesfaye is the SDAA lead here.

4 Today's presenters are Marie Pohida, Anne-
5 Marie Grady, Mike Swim, and George Wang.

6 The slide lists the five sections and now
7 I'm turning over to the first presenter, Marie Pohida.

8 MS. POHIDA: Thank you very much and good
9 afternoon. I'm a senior reliability and risk analyst
10 in the Division of Risk Assessment.

11 Okay, I'd like to start on slide 28.
12 Thank you very much.

13 All right, what we have here on this slide
14 is a list of the significant changes to the risk
15 profile between the DCA and the SDA. And, that's
16 based on design changes.

17 First, the core damage frequency. The CDF
18 increased due to more frequent actuations of ECCS
19 valves.

20 The dominant contributors to CDF include
21 high winds, module drop, external floods, internal
22 events, and internal fires, which is a complete
23 difference from the DCA where module drop comprised
24 over 90 percent of the core damage risk.

25 So, the risk profile changed quite a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 little bit.

2 Regarding the large release frequency, the
3 LRF, large release frequency decreased to earlier
4 actuation of ECCS valves.

5 And, the contribution to LRF from breaks
6 outside of containment decreased. And I'll be
7 discussing that in a future slide.

8 In this design, there's the addition of
9 the digital reactor building crane control system.
10 And, that minimizes operator error.

11 Particularly, operator errors of
12 commission. And that will also be discussed in a
13 future slide.

14 MEMBER HARRINGTON: This is Craig. Can
15 you speak to why high winds are a contributor?

16 MS. POHIDA: Yes.

17 In the DCA, the risk profile was dominated
18 by module drop. And, those failures were driven by
19 failures of limit switches and operator errors of
20 commission, okay.

21 With the addition of this digital control
22 system, that portion of risk decreased. And, what
23 increased were other initiating events like high
24 winds, external floods, internal events.

25 And for example, high winds if you were to

1 have a sustained loss of power, of offsite power, and
2 if you would not, if the diesel generators failed to
3 actuate, then that would require an ECCS actuation.

4 So, this is going to be a theme that
5 common cause failure of the ECCS to actuate is like 90
6 percent of the core damage frequency.

7 Does that help your question?

8 MEMBER HARRINGTON: So, the high wind
9 issue is more about power lines and things like that,
10 than it is any other impact of high winds?

11 Everything's inside a concrete building so
12 it seems like high wind would not be a big issue. But
13 if it's tied to offsite power, I can see that.

14 MS. POHIDA: There is a 24 ECCS timer that
15 actuate if offsite power is not restored within 24
16 hours.

17 Okay, so for example, if you were to have
18 a loss of offsite power, you would have a loss of, you
19 were to have a high wind event, okay?

20 There's two backup diesels. If they're
21 not able to provide power, successful actuation of
22 DHRS will not prevent the ECCS 24-hour timer from
23 actuating, and requiring an ECCS demand.

24 Does that help?

25 MEMBER HARRINGTON: Yes, I think so.

1 MS. POHIDA: Okay.

2 Anyway, please don't hesitate to ask me
3 any questions.

4 All right, I believe I was done with that
5 slide, so if I may, I'll continue to slide 29, but
6 thank you.

7 All right, so this is a list of the focus
8 areas for our PRA, severe accident review. And, I
9 will discuss the specific impacts in future slides.

10 I want to discuss the impact of change
11 ECCS actuation set points, the PRA modeling of the
12 EDAS system, CVCS line breaks outside of containment.

13 Unisolable CVCS line breaks outside of
14 containment. And, I'm talking about weld failures at
15 the containment isolation valves.

16 My colleague Mike Swim is going to be
17 discussing density wave oscillation impacts on steam
18 generator tube rupture failure.

19 I'll be continuing with discussion of the
20 reactor building crane digital control system, be
21 talking about the top support structure, and that
22 connection to the nuclear power module.

23 And where that's relevant, that's relevant
24 to the drop of a module that's being moved for
25 refueling, if it were to be dropped and impact an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 operating module.

2 And, my colleague Anne-Marie will be
3 discussing the addition of the PAR.

4 And I'll stop here if there's any
5 questions?

6 Go to slide 30.

7 Okay, the impact of the ECCS actuation
8 changes on CDF and LRF. About 90 percent of the core
9 damage scenarios involved incomplete ECCS actuation.

10 Also, the ECCS design was changed.
11 There's now actuation signals on the low RCS level
12 that's at the top of the riser, and at the low load
13 RCS level that's mid-riser, that result in earlier
14 ECCS actuation.

15 There's also an 8-hour ECCS timer that was
16 added. And, operators may bypass the timer after
17 checking for shutdown margin and hydrogen
18 concentration.

19 This operator action was not found to be
20 risk significant. This operator action to check for
21 shutdown margin and hydrogen concentration is
22 performed after every reactor trip with successful
23 decay heat removal system actuation.

24 And the human error probabilities in the
25 FSAR reflect this.

1 There I'll stop and see if anybody has
2 questions.

3 MEMBER ROBERTS: Yes, a real quick one.
4 This is Tom Roberts.

5 MS. POHIDA: Thank you.

6 MEMBER ROBERTS: Can you clarify what
7 incomplete ECCS actuation is?

8 MS. POHIDA: Let's say the ECCS is
9 demanded and the RVV valves open, and the RRV valves
10 do not open.

11 MEMBER ROBERTS: Okay, thanks. So it's
12 not unnecessary ECCS actuation?

13 MS. POHIDA: No.

14 MEMBER MARTIN: So what is it about the
15 partial actuation that makes things worse than a
16 complete actuation?

17 MS. POHIDA: There's many scenarios that
18 demand ECCS actuation. It's high winds -- it's
19 external events like high winds. External events like
20 external flooding, and it's internal events.

21 It's LOCAs within the containment. It's
22 LOCAs that are unisolable outside the containment.

23 MEMBER ROBERTS: Okay, I see. So these
24 are cases where ECCS is intended to operate --

25 (Simultaneous speaking.)

1 MS. POHIDA: Absolutely.

2 MEMBER ROBERTS: -- but fails. Okay,
3 thank you.

4 MEMBER MARTIN: Marie, a particular
5 example you gave, that's got to be the domino one,
6 right?

7 Of all the incomplete ECCS actuations, a
8 scenario where you basically lose inventory but you
9 can't get it back in, correct?

10 Or is there another example you can
11 mention that is equally --

12 MS. POHIDA: Not on the tip of my tongue.
13 As I understand the question is what's most likely --

14 (Simultaneous speaking.)

15 MEMBER MARTIN: The answer you gave,
16 that's the, that to me was the obvious one. I just
17 wondered if there's anything else in there, in the
18 PRA, that would come close to being as significant as
19 that particular scenario that you used as an example.

20 MS. POHIDA: Depending on the scenario,
21 and I have to be careful here so I don't stumble.

22 For many scenarios, the lifting of one
23 reactor vent valve, and the opening at the appropriate
24 time of one reactor recirculation valve, is
25 sufficient.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But there's scenarios, right now we're in
2 beyond design basis.

3 MEMBER MARTIN: Sure.

4 MS. POHIDA: So, there's going to be
5 scenarios that, that is not sufficient to preclude
6 pumped injection.

7 But you're asking me what the most likely
8 one is and I would defer to my lifelines in the --

9 MEMBER MARTIN: Well, I guess what I was
10 asking is that one is just most obvious.

11 MS. POHIDA: Yes.

12 MEMBER MARTIN: Right? And I'm trying to
13 think what could be kind of second on that list that
14 might be close.

15 MS. POHIDA: Yes.

16 MEMBER MARTIN: As far as maybe not
17 likelihood, but certainly, maybe likelihood. It just
18 seems hard to damage the core without that one
19 particular scenario that you mentioned.

20 Because it's all about keeping inventory,
21 and the only mechanism I would see you couldn't keep
22 inventory is if you couldn't otherwise get water back
23 in.

24 I mean, you can get more and more
25 incredible, less likely, come up with scenarios, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 as far as the one that's most likely, that would seem
2 to be the one that's obvious.

3 I just can't think of another one that
4 would, that would really rise very high on the list --

5 MS. POHIDA: Yes.

6 MEMBER MARTIN: -- than the example you
7 gave.

8 MS. POHIDA: May I take that back and
9 think about that?

10 MEMBER MARTIN: All right.

11 MS. POHIDA: And go look at the numbers.

12 MS. NEUHAUSEN: Can I add one more? And
13 that's just if both (Audio interference.) fail and the
14 -- both (Audio interference.) open and (Audio
15 interference.) stay closed?

16 MEMBER MARTIN: That's the example she
17 gave, right?

18 MS. NEUHAUSEN: It's either the two on the
19 top or the two on the bottom. The difference would be
20 liquids base or vapors base.

21 MEMBER MARTIN: Right, right, but if the
22 ones at the bottom open up, yeah, you would lose
23 inventory. But it would fill up, and you could, you
24 know, more or less maintain probably some circulation
25 in that scenario. But anyway. And maybe if you only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 had one of those. All right.

2 MS. NEUHAUSEN: Thank you.

3 MEMBER MARTIN: These are fun things to
4 ask.

5 MS. POHIDA: They're fun things to think
6 about. My next slide, I'll continue to -- on the next
7 slide on EDAS modeling. In this SDA design, it's
8 different than the DCA. The ECCS reactor vent valves
9 are held closed by EDAS, okay.

10 So failure of any two of the four channels
11 of EDAS, and I'm talking about the module-specific
12 EDAS as opposed to EDAS-C, which is shared among
13 modules, would cause a reactor trip in ECCS actuation.
14 So the PRA group looked into the PRA modeling of EDAS,
15 and particularly how it was modeled in the PRA and the
16 failure data. So we spent a significant amount of
17 time doing that.

18 I'm going to go back to the second bullet.
19 EDAS was not identified as risk-significant from, you
20 know, PRA importance measures. It is a single
21 failure-proof system. And there is physical
22 separation between the divisions. And I'm talking
23 about Division 1, which is Channel A and C, and
24 Division 2, which is B and D.

25 But as I mentioned earlier, failure of two

1 channels of the module-specific, that's EDAS-MS,
2 results in reactor-trip and ECCS actuation.

3 We did note, when we were reviewing the
4 fall trees, that common cause failure of the EDAS
5 electrical busses are -- the common cause failure was
6 not modeled in separate compartments. Common cause
7 failure was modeled between one division or the other
8 division, but not among, you know, both -- not among
9 both divisions that are physically separated.

10 And it's also important to note that the
11 data for EDAS common cause failures modeled in the PRA
12 is derived from operating plant data, and where DC
13 power is safety-related.

14 So, the FSAR states, and this is in
15 Section 8.3 of the FSAR, it states that the EDAS will
16 be included in the owner's controlled requirements
17 manual. And that's a COL item under Chapter 16,
18 that's a COL action item, and the maintenance role.

19 And so specifically, you know, it states
20 in FSAR Section 8.3, excuse me, that the goal is to
21 ensure during operation that common cause failure does
22 remain as the dominant failure mode, and that the
23 reliability of EDAS is equivalent to a Class 20
24 system.

25 EDAS did not meet the RTNSS criterion. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 did not meet the RTNSS criterion for being a
2 significant contributor to CDF and LRF. And also in
3 8.3, it also stipulates that EDAS will be included in
4 the maintenance role. So with here, I'll just stop
5 and see if anybody has any questions.

6 MEMBER ROBERTS: Maybe I missed the
7 conclusion, but the conclusion is that, do you agree
8 that it's not risk-invident, is that the conclusion?

9 MS. POHIDA: Alissa, may I defer that to
10 you?

11 MS. NEUHAUSEN: Yeah, the EDAS includes
12 augmented volume requirements that are similar to
13 those for (Audio interference.) program.

14 MEMBER ROBERTS: Thank you. I was trying
15 to -- you'd agree what this slide. I think what this
16 slide means is that you agree with the licensee, or
17 the applicant, rather, that the EDAS as designed and
18 as they plan to manage it is equivalent essentially to
19 what you already modeled -- what you already modeled
20 under the PRA.

21 It was a common cause failure from safety-
22 related electrical system, that type of thing. You
23 were in agreement that that's reasonable?

24 MS. NEUHAUSEN: Yeah, we agree that the
25 modeling is consistent with the design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: Okay, thank you.

2 MS. POHIDA: I'm going to go to slide 32.
3 These are CVCS line breaks outside of containment. So
4 as NuScale mentioned and as was mentioned this
5 morning, there are flow-restricting venturis in the
6 injection and discharge lines, so that, you know,
7 controls the inventory loss and aids to reduce the
8 large release frequency from CVCS line breaks outside
9 of containment.

10 If at least one train of decay heat
11 removal system is available and all the ECCS valves
12 are open, that means the two reactor vent valves and
13 the two reactor recirculation valves are open, the PRA
14 success criteria is met. And that pumped injection is
15 via the non-safety-related cavity flood and drain
16 system, and CVCS is not needed to prevent core damage.

17 And that's -- that is a risk-significant
18 design enhancement from the DCA where unisolated
19 breaks outside of containment, which were not
20 isolated. And you know, failure of pumped injection,
21 you know, comprised a majority of the large release
22 frequency. So this was a significant design
23 enhancement.

24 MEMBER DIMITRIJEVIC: Hi, is this is
25 Vesna. Well, I had forgotten to ask that while the

1 NuScale was presenting. When they decided their
2 importance measures, were those importance measures
3 based on the total CDF over LRF, or they are a base
4 for every, you know, hazard separately shutdown?

5 So if something was important in internal
6 events, it's considered important? Or just it has to
7 be important in the total CDF and LRF? Are importance
8 measures means -- everything which is important, for
9 example, for external flaps is considered important.

10 MS. POHIDA: Okay.

11 MEMBER DIMITRIJEVIC: You know what I
12 mean? There is importance measures for every CDF and
13 LRF, and we have a different CDF and LRFs, and we
14 never discussed total CDF and total LRF. So I assume
15 the importance measures are based on the -- you know,
16 on the 123s 810-plus LRFs of 20 different factors.

17 MS. POHIDA: Okay, I'm kind of at a loss
18 on how to answer this question. Are you talking about
19 the difference of importance about CVCS line breaks
20 that weren't isolated, you know, outside of
21 containment? Are you talking about the difference in
22 importance between the DCA and the SDA?

23 MEMBER DIMITRIJEVIC: Well, I'm sort of
24 like -- why I'm asking this question because I
25 suddenly I got curious in importance. And I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 actually very curious in importance of DHRS. Because
2 of so many times it comes up in discussion. So if we
3 have importance measures which are connected with
4 large release frequency for internal events, obviously
5 the DHRS would be important because it prevents.

6 If it's not available, it will not prevent
7 the loss of inventory. So that's what I want --
8 that's what I was trying to bring up. So I was sort
9 of curious, like was that for -- is it LRF for
10 internal events one source of importance measure?
11 That's my question, and then I will bring this DHRS
12 discussion, so.

13 MS. POHIDA: Okay, well, you know, please
14 forgive my slowness. So the concern is about the
15 importance of DHRS --

16 MEMBER DIMITRIJEVIC: Right.

17 MS. POHIDA: -- as a system in the SDA.

18 MEMBER DIMITRIJEVIC: Yes, as a system in
19 SDA. Yes.

20 MS. POHIDA: Okay. Well, and not just for
21 this scenario but for -- in the PRA as a whole.

22 MEMBER DIMITRIJEVIC: Well, that's why I'm
23 asking you, are importance measures based -- and what
24 are the important measures based on? Is there
25 importance measures which are related to large release

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for internal events where that was part of the CVCS
2 line breaks outside of containment used to dominate in
3 DCA?

4 MS. POHIDA: Yes, they did.

5 MEMBER DIMITRIJEVIC: So now if we don't
6 have a DHRS, they will still dominate. I mean, I
7 assume, because I would not see any other difference,
8 you know, because DHRS was important to credit this
9 ability to prevent lost inventory.

10 So that's why I'm asking, are importance
11 measure only measure to what is the total LRF for all
12 the events and, you know, hazards and shutdown and
13 blah, blah, blah? Or the importance measures are the
14 ten different categories?

15 MS. POHIDA: Okay, for this design,
16 regarding the importance of DHRS, it is safety-related
17 in this design.

18 MS. NEUHAUSEN: This is Alissa Neuhausen
19 again. So, Vesna, if I understand the question
20 correctly, I think the absolute risk metrics are based
21 on the aggregated hazard, and the Fussell-Vesely are
22 based on individual hazards.

23 MEMBER DIMITRIJEVIC: So what was the
24 first thing you said, Fussell-Vesely were based on the
25 individual, and what is the CDF based on, the risk-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 achievement or your conditional, what is that based
2 on?

3 MS. NEUHAUSEN: On the aggregated hazard.

4 MEMBER DIMITRIJEVIC: On what?

5 MS. NEUHAUSEN: On all of the hazards, and
6 I believe NuScale is also got --

7 MS. BRISTOL: Thanks, Alissa. This is
8 Sarah. So we, for that Fussell-Vesely and the risk-
9 informed criteria we provided earlier, we look at that
10 for every hazard. And we'll go internal events and
11 all of the external hazards, low power shutdown. And
12 we'll look at those criteria for each hazard for that
13 power (Audio interference.)

14 MEMBER DIMITRIJEVIC: Okay, all right. So
15 starting now, we understand what I'm getting in. This
16 is based on Fussell-Vesely even, because this -- this
17 type of events used to dominate all large release,
18 right? It was only thanks to --

19 MS. BRISTOL: Correct.

20 MEMBER DIMITRIJEVIC: -- this DHRS process
21 of opening all the valves that you were able to
22 eliminate that, right?

23 MS. BRISTOL: Correct, but as you know,
24 that's one portion of events that make up core damage.
25 And so we look at that as --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER DIMITRIJEVIC: I'm talking large
2 release here, just large release. All right, so.

3 MS. BRISTOL: Understood. But ECCS is
4 going to mitigate that event and prevent a core damage
5 before DHRS would need to be important to mitigate a
6 large release. You wouldn't get there if ECCS is
7 successful, even with --

8 MEMBER DIMITRIJEVIC: And I understand
9 this all. I'm just talking is about what will happen
10 is the current LRF will change to the value of
11 previous LRF if you don't have a DHRS. Is that a true
12 statement? Your currently LRF frequency would be the
13 same as it was in that DCA.

14 MS. BRISTOL: I understand what you're
15 saying and I believe it would increase. I can't say
16 to what value it would increase to, but that does make
17 sense that it would increase if DHRS --

18 (Simultaneous speaking.)

19 MEMBER DIMITRIJEVIC: Yes. So therefore
20 it would increase to the, you know, whatever value was
21 the -- we said it was like from that 13 to the -11 or
22 something. So this is what I was sort of trying to
23 say. Wouldn't that really indicate the importance of
24 DHRS?

25 But that's all right, I mean, I'm -- you

1 know, I don't really know your numbers, so I mean, it
2 just looks to me that if you without DHRS would go to
3 much higher LRF, that would be -- yeah, but not have
4 you just looking in Fussell-Vesely and you know, CBDP
5 will be all right. Okay.

6 MS. POHIDA: Vesna?

7 MEMBER DIMITRIJEVIC: So that will
8 definitely -- yeah.

9 MS. POHIDA: I would just like to add that
10 the internal events portion of the PRA has multiple
11 scenarios in it. I mean, this is just one of them.
12 This is CVCS line breaks outside of containment. We
13 have LOCAs, you know, inside containment.

14 MEMBER DIMITRIJEVIC: Yeah, I understand
15 but -- yes, but this particular event dominated your
16 LRF in the huge project, right? It was almost all
17 your LRF come from those -- the CVCS breaks outside
18 containment.

19 MS. POHIDA: In the DCA.

20 MEMBER DIMITRIJEVIC: In that DCA, yes.
21 That's why I'm sort of concerned. That's what I
22 thought. I mean, I can go and look in percentage, but
23 that -- that was -- I remember that this dominated all
24 LRF and then I was wondering. All right, okay, well
25 let's continue with the discussion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. POHIDA: Thank you. I'll go to slide
2 33. Okay, now we're talking about, in this slide,
3 unisolable CVCS breaks outside of containment. And so
4 what the PRA staff evaluated, we looked at the
5 likelihood of weld failures at the junction between
6 the containment vessel and the CVCS containment
7 isolation valves. We looked at the likelihood of
8 these weld failures because they're not modeled in the
9 PRA.

10 But it's important to note that the plant
11 behavior and the consequences of an unisolable CVCS
12 LOCA outside of containment are modeled. And how that
13 is modeled is you're modeling a CVCS break downstream
14 of the containment isolation valves with failure of
15 containment isolation valves.

16 So the weld failure was not numerically
17 included, but the plant behavior and the consequences
18 of this break are modeled in the PRA. So this weld
19 failure, weld failure frequency, there's uncertainty
20 on this weld failure frequency. It's identified as a
21 key source of level two uncertainty in the upcoming
22 revision of the FSAR, Revision 2.

23 And the impact of this weld failure
24 frequency is minimized by leak detection and operator
25 response. And as two examples, it would be Tech Spec

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 345 on RCS operational leakage, and temperature
2 monitoring under the bioshield.

3 And with that, I'll just break here and
4 see if anybody has any questions.

5 MEMBER DIMITRIJEVIC: The interesting --
6 how was the frequency of isolable CVS the LOCA
7 calculated? What was the used, the weld number, pipe
8 lengths, or?

9 MS. POHIDA: I beg your pardon, for the
10 weld failure frequency?

11 MEMBER DIMITRIJEVIC: Well, how -- okay,
12 my question is how was isolable CVCS break, you know,
13 outside of containment calculated? How was that
14 frequency calculated?

15 MS. POHIDA: I may have to take that back
16 and get back to you, how was it calculated.

17 MEMBER DIMITRIJEVIC: My question was it
18 based on the weld estimate, weld number? So was it
19 based on pipe length, or what was it based on?

20 MS. POHIDA: You know, I'm going to have
21 to take that question. I don't recall a change in
22 modeling of the CVCS break frequency outside
23 containment between DCA and SDA. But since Sarah's
24 here, I defer.

25 MS. BRISTOL: There was no change.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. POHIDA: I beg your pardon?

2 MS. BRISTOL: There was no change between
3 DCA --

4 MS. POHIDA: I didn't think there was.

5 MS. BRISTOL: -- and SDAA. And so, well
6 for these line breaks, we calculate, we measure the
7 length of pipe between the various distances that are
8 designated. So pipe breaks inside containment would
9 go up to the containment isolation valve, and so
10 that's a distance.

11 And so the isolable IE frequency is then
12 calculated from the pipe length inside containment of
13 those lines designated up to the CIV.

14 Does that help, Vesna?

15 MEMBER DIMITRIJEVIC: Well, no, I was
16 wondering, did you use the weld number of the
17 pipeline? Because you can use either based on EPRI
18 done on flat frequency. So I mean, the thing is like
19 I was wondering did you have a data on this weld
20 failure frequency? If you worked with weld frequency.

21 MS. BRISTOL: Generic data, yup. And so
22 we used the pipe failure for large and small breaks
23 for the length, and then we used just the generic HOV
24 CIV and reliability data.

25 MEMBER DIMITRIJEVIC: All right, so you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 did not use weld frequency. That was, I was just
2 curious about that. Okay.

3 MS. POHIDA: May I continue?

4 MEMBER DIMITRIJEVIC: Sure, thanks.

5 MS. POHIDA: And with that, I'm going to
6 turn it over to Mike, who's going to speak on DWO.
7 But thank you.

8 MR. SWIM: Yeah, thanks, Marie. And good
9 afternoon, everyone, my name's Mike Swim, I'm a
10 Reliability and Risk Analyst. Been with the agency
11 about one year. I was out in industry for 13 years
12 before that as a licensed SRO and diesel generator
13 engineer.

14 And for my role in this review, I was
15 assigned a disposition with DWO for Chapter 19, and
16 Chapter 19 specifically. So the PRA did not
17 explicitly model DWO impacts to the steam generator to
18 failure-initiating event frequency. It considers
19 things like high cycle fatigue, fretting wear from
20 normal operating conditions.

21 And so why was this okay from a Chapter 19
22 perspective? And what I came down to between
23 interactions with the staff was there's no -- even if
24 it were to be modeled, there were no significant
25 impacts to the results or insights of the PRA. And so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I'll go through in a little more detail here how that
2 works.

3 So how can DWO impact the normal event
4 progression for a steam generator tube failure? And
5 some of the things that we considered as a staff was
6 the increase in the steam generator tube failure
7 initiating event frequency. And also potentially
8 worst case consequences and what are required in the
9 Chapter 15 analysis of the single tube failure.

10 So looking at it from a perspective of
11 maybe multiple steam generator tube failures. And as
12 a result of maybe the loss of -- or a failure of steam
13 generator tubes and both steam generators, which would
14 result in a loss of both trains of the decay heat
15 removal system.

16 I do want to note, you know, these are
17 things that we looked at to make a safety evaluation
18 from a Chapter 19 perspective. So you know, some of
19 the steam generator tube failures, or multiple steam
20 generator tube failure, for instance or this appearing
21 in both steam generators.

22 I'm not making a declaration that this is
23 likely to occur from DWO conditions. This is just
24 something that we looked at to bound the potential
25 risk of this condition in the operating plan.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So for the event progression for multiple
2 steam generator tube failures, including in both the
3 steam generators, there's -- based on interactions
4 with NuScale, there's no discernable difference, with
5 a couple of exceptions. The expected response would
6 happen faster, so you'd reach various actuation
7 setpoints quicker due to a larger break size.

8 And of course what I've already mentioned
9 with the, if this were to occur on both steam
10 generators, both trains of the decay heat removal
11 system would be lost simultaneously in both steam
12 generators.

13 So there is some sensitivity analysis
14 performed by NuScale. One that's referenced in their
15 table 19.1-22 was they increased the initiating event
16 frequency by more than a order of magnitude, with no
17 change in CDF or LRF, and a sensitivity to a loss --
18 study of a loss of both trains of decay removal
19 system, which resulted. And still not identifying the
20 decay heat removal system as a candidate for risk
21 significance.

22 So a combination of those in and of itself
23 was enough for us to find out that NuScale PRA was
24 still technically adequate and consistent with the
25 Chapter 19 standard review plan, even without further

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 explicit consideration of DWO as it impacts on the
2 initiating event frequency.

3 We did do some further analysis in house,
4 just to build a stronger comfort level with this
5 stance. So we did some informal validation. The NRC
6 has a SAPHIRE SPAR model for the NuScale design, and
7 so we did some further worst-case hypotheticals
8 manipulating the SPAR model internally.

9 Looked at things like assumed an
10 initiating event frequency of times 100. No
11 significant changes to CDF and LRF. And developed a
12 new, a venturi, even to include common cause failure
13 of the steam generator tube failures as a result of
14 DWO. But no significant changes to CDF and LRF.

15 That's all I have for slide 34. Are there
16 any questions?

17 MEMBER DIMITRIJEVIC: Did you do this
18 simultaneously? Did you increase frequency the number
19 of the tubes and put them in both steam generators?
20 I mean, was that trial performed? Did you assume
21 multiple tubes of the both -- I mean, you know,
22 distributed between two steam generators and you know,
23 and then see what is totally impacted. Then look how
24 sensitive it is to the frequency.

25 MR. SWIM: Vesna, just to make sure I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 understand your question, you're asking with respect
2 to internally with our SPAR model, or what the direct
3 question asked of the, of NuScale?

4 MEMBER DIMITRIJEVIC: Yeah. I mean,
5 sensitivity is the -- I don't know could you do that
6 on the SPAR model because you had to run success
7 criteria, you know, to see what was the --. If you
8 have a larger sized LOCA and do you need DHRS to, you
9 know, to prevent inventory loss. I mean, things like
10 that. So you couldn't run that.

11 So I was sort of wondering if they run
12 multiple tubes of the different steam generators and
13 then see how sensitive to the frequency. Because I
14 have to put that this frequency is, you know, based on
15 expert opinion and is much lower than what we see in
16 the current industry, so. So that's what I was sort
17 of wondering was that combination of those factors,
18 what is the sensitivity run by NuScale.

19 MR. SWIM: So, that, I'd say that
20 consideration was embedded in our question to NuScale
21 for consideration. I don't have specifics on how
22 large a break they did do or analyzed. I will say
23 with respect to the system response and how the event
24 would progress, at a certain point, the things like
25 the secondary system isolation and ECCS do actuate on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 RCS-level-type setpoints.

2 So you would be reaching those setpoints
3 faster. Does that answer your question, Vesna?

4 MEMBER DIMITRIJEVIC: No, I mean, I'm
5 aware of this. I'm just really, you know, my question
6 was that, you know, the -- you know, preventing
7 inventory loss, I mean. So that's what my question
8 was, similar to the, you know, charging outside of the
9 containment when, you know. We have a situation where
10 you need DHRS and opening all ECCS valves.

11 I mean, I was wondering, and we have a
12 similar situation with steam generator tube ruptures
13 where the DHRS may not be available. So that was my
14 concerns.

15 MR. SWIM: Okay. Was there anything
16 additionally you'd like from me? I guess I didn't
17 hear another question in there. Was there --

18 MEMBER DIMITRIJEVIC: No, that's okay, I
19 mean, I already discussed that with the NuScale. I
20 mean, I don't have really have my answer, but you
21 know, I will look more into that.

22 MR. SWIM: Thank you, Vesna. Was there
23 any other questions? All right, well, I'll --

24 MEMBER DIMITRIJEVIC: What I wanted to
25 say, it's difficult for me to see, and I'm not really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 concerned the thought of risk, as I said many times.
2 I'm just concerned about what the PRA identify as
3 important for the other consideration. And for me to
4 see the steam generator tubes are not important, it's
5 difficult thing to, you know, to fathom. So I just,
6 that's why I'm sort of questioning. And then you
7 know.

8 The assumption is that this is much better
9 frequency, that we're only going to have a single
10 failure, that blah blah blah. So you know, I'm not
11 too comfortable with it.

12 MR. SWIM: And I understand your
13 perspective. I think that was part of why we dug a
14 little deeper with the SAPHIRE SPAR model. I mean, my
15 time with the operating plants, you know, E-3 was one
16 of the procedures you really didn't want to get into.
17 I didn't look forward to getting into because of the
18 all the time-critical operator actions, cooldown to
19 pressurization.

20 But one thing with the NuScale design that
21 is unique to operating plants is there's no relief
22 valves between the containment isolation and the
23 containment boundary itself. So any kind of -- once
24 you get into that steam generator tube failure
25 scenario, their response becomes a lot simpler.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER DIMITRIJEVIC: Right, but we are
2 just discussing unisolated steam generator tube.

3 MR. SWIM: With that, I'll pass the
4 presentation back to Marie.

5 MS. POHIDA: Thank you very much. Okay,
6 if I may, I'd like to go to slide 35. And thank you,
7 Anne Marie.

8 I'd like to go back to the presentation on
9 slide 35 on the reactor building crane digital control
10 system. So with the SDA there was the addition on the
11 reactor building crane digital control system, which
12 significantly decreases the contribution of operator
13 errors of commission. And I'm thinking of in the past
14 DCA design, examples are would be overspeed,
15 overtravel, overload.

16 This control system was designed to
17 prevent such errors. In fact, the reliability of this
18 reactor building crane control system is such that now
19 the dominant contributors to module drop are actually
20 redundant load path failures like, you know,
21 catastrophic gearbox failure and wire rope failures.
22 The contribution of the operator to module drop in
23 this SDA design is very, very small.

24 This digital control system is classified
25 as non-safety-related. However, it is risk-

1 significant. And the programmable logic controller is
2 validated and verified under software integrity level
3 3. There's more information about this control system
4 in FSAR Section 9.1.5.5.

5 And you know, to add some more
6 information, this single programmable logic
7 controller, it controls operation, it controls
8 monitoring. And their software interlocks to prevent,
9 you know, collisions with other SSCs and to prevent
10 the operator from operating the crane outside its
11 equipment design capabilities.

12 And I'll go to slide --

13 MEMBER ROBERTS: And Marie, just out of
14 curiosity, does level 3 define how you model the
15 failure rate to say a software error? Or if not, what
16 do you use to estimate the software failure rate?

17 MS. POHIDA: I'm going to have to get back
18 to you on that. What we did is when we reviewed the
19 PRA, we worked with expertise from the I&C branch
20 regarding making sure we understand, you know, how
21 this programmable logic controller's going to work and
22 what requirements were on that. And I'd like to take
23 that back and get back to you. It's a probability.

24 MEMBER ROBERTS: Okay, thank you.

25 MS. POHIDA: Thank you for your question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Excuse me, just jotting down some notes.

2 Okay, slide 36. All right, top support
3 structure, excuse me, the connection to the nuclear
4 power module. Okay, in the NuScale design, you have
5 a lower block assembly and that's at the bottom of the
6 main hoist. And that connects with the lifting logs
7 to the top support structure that sits on top of the
8 nuclear power module.

9 So once again, this is in context of a
10 postulated module drop on top of an operating module.
11 If a dropped module strikes an operating module, you
12 know, piping including the pressurizer spray piping,
13 the DHRS piping at the front of nuclear power module
14 have the potential to be impacted.

15 The three -- excuse me, not the three.
16 The safety-related CVCS containment isolation valves
17 are located under the top support structure. They
18 protect these -- the CIVs from impacts from a
19 postulated module drop. And this top supports
20 structure is classified as non-safety related and it
21 is risk-significant in FSAR table 17.4-1.

22 So, if there's a postulated module drop
23 that impacts an operating module, the expectation is
24 the containment isolation valves were closed. But
25 since -- but both trains of DHRS could be unavailable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 They could be impacted by the drop.

2 If that occurs and one reactor safety
3 valve successfully cycles open and closes, the RCS
4 will be pressurized and then ECCS will be demanded.
5 And even if the RSVs, the reactor safety valves, fail
6 to open, the ECCS functioning remains a success path
7 to keep -- to prevent core damage.

8 MEMBER DIMITRIJEVIC: But that scenario is
9 not analyzing PRA. There is no -- yeah, go ahead.

10 MS. POHIDA: Thank you, thank you, Vesna.
11 Yes, multi-module events, they are analyzed in the
12 FSAR. Multi-module internal events are quantified.
13 Multi-module external events are qualitatively
14 evaluated.

15 So this is, you know, postulated drop of
16 a module being moved for refueling on top of an
17 operating is qualitatively evaluated.

18 MEMBER DIMITRIJEVIC: All right. I mean,
19 I'm just -- no, I saw this qualitative evaluation. I
20 was just wondering how much. Because this is now
21 operating modules. So you know, you analyze this as
22 a shutdown risk, but this would be operating risk, you
23 know, so. All right.

24 MS. POHIDA: Thank you. Okay, may I turn
25 it over to Anne-Marie for a discussion on PAR. Thank

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you.

2 MS. GRADY: Final discussion. The PAR was
3 added, as we discussed earlier. Yes, thank you.

4 A single, safety-related PAR was added to
5 the design. It's not modeled in the PRA. Equipment
6 survivability dose for the PAR post-severe accident,
7 the two functions must be maintained at a containment
8 integrity in post-accident monitoring.

9 The PAR has been added to Table 19.2-8 for
10 equipment survivability list. A new COL item, which
11 was discussed this morning, shows that the applicant
12 will identify from the list of equipment on the
13 equipment survivability list the components in the
14 severe accident doses for cases which the severe
15 accident dose is greater than an EQ, as described in
16 COL item 19.2-4. Next slide, please.

17 Conclusion. The staff reviewed the US460
18 design-specific PRA. Oh, sorry, this is not my slide.

19 MS. POHIDA: That's okay.

20 MS. GRADY: Okay, and other PRA-related
21 information in FSAR 19.1, in accordance with SRP 19.0,
22 DC COL ISG-28 for applicable modes and hazards. The
23 applicant addressed the full scope of the internal and
24 external initiating events for both full power and low
25 power shutdown conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 The applicant developed quantitative risk
2 insights from multi-module internal events and
3 qualitative risks insights for multi-module shutdown
4 and external events. The PRA is of sufficient
5 technical adequacy to support the SDA. The staff's
6 review concludes that the Commission's CDF and LRF
7 goals have been met with margin.

8 Any questions on that? Next slide,
9 please.

10 Okay, I think they're out of order. Still
11 talking about the PAR and combustible gas control in
12 containment. Because it's also described, part of the
13 design is described in Chapter 19. Certainly
14 equipment survivability, but also an evaluation of why
15 the PAR isn't a PRA.

16 So, to refresh our memory from this
17 morning, hydrogen combustion in the CNV. The DCA
18 addressed a potential combustion event in the CNV
19 analytically and demonstrated the CNV design pressure
20 was not exceeded. The SDA, in contrast, had at a PAR,
21 which precludes combustion events from occurring
22 during DBAs and SAs.

23 A containment performance with no
24 combustion, but the SDAA table at 19.2-1, core damage
25 simulations for severe accident evaluation, identifies

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 a spectrum of severe accidents that could challenge
2 containment integrity.

3 The subsequent tables, 19.2-2 through 7,
4 document the CNV design pressures, include those that
5 generated hydrogen, the presence of hydrogen in the
6 containments, are not exceeded. That's the
7 demonstration, frankly that, well, that containment
8 integrity is maintained.

9 The conclusion. The applicant addressed
10 severe accidents consistent with Commission policy.
11 The SDAA design of containment performance meets the
12 containment structural integrity criteria of Reg Guide
13 1.7 and the containment leak tight criteria of SECY-
14 93087. Next slide, please.

15 MS. POHIDA: Thank you, Anne-Marie.

16 I'd like to go over our Chapter 19 review
17 as it relates to RTNSS, that's the regulatory
18 treatment of non-safety systems. We had one RAI on
19 this topic, and it had to do with the backup diesel
20 generators, that they're not scoped into RTNSS.

21 We concluded that the backup diesel
22 generators do not prevent the occurrence of an
23 initiating event. Specifically, that would initiate
24 the actuation of a passive system. They're not needed
25 for long-term post-accident capabilities. They're not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 needed to support defense-in-depth systems.

2 And all the components of the backup power
3 supply system, including the backup diesel generator
4 and closures, are seismic category 3. And the backup
5 diesel generator enclosure is rated for wind speeds in
6 excess of the weather-related events included in the
7 loop initiating event in the PRA.

8 So with that, I'll proceed to slide 41.
9 So regarding RTNSS, the staff has reviewed the NuScale
10 460 evaluation of RTNSS in accordance with SRP 19.3.
11 NuScale did not find any SSCs in the scope of RTNSS.
12 And the staff, we concluded that we didn't find any
13 SSCs that met the criterion for requiring additional
14 regulatory treatment. But thank you.

15 And with that, I will turn it over to our
16 discussion on aircraft impact analysis.

17 MR. WANG: Good afternoon, my name is
18 George Wang. I'm a Structural Engineer in the
19 Structural Stability Technical Engineering Branch.
20 I'm from the Office of the NRR.

21 I'm a technical reviewer for FSAR Chapter
22 1925 (Audio interference.) adequacy of the design
23 features and functional capabilities identified at
24 this (Audio interference.) for withstanding impacts.

25 So next I want to talk about two safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 changes between DCA and SDA from a structural
2 perspective. First, secondary change as SDAA use at
3 the steel-plate composite walls.

4 So because it's a unique design, so
5 NuScale performed design-specific aircraft impact
6 assessment both global and local assessments,
7 experimental data to benchmark the methodology and
8 results. NuScale followed NEI 07-13, Revision 8,
9 without exceptions.

10 Due to a unique design of the SC wall, so
11 NuScale identified some additional key design
12 features. Base strength, then a SC wall to reinforce
13 concrete slab connections, local detailing with tie
14 rods in SC walls to wall connection. Also the
15 structural steel beam seat connections. So that's key
16 design feature identified for SC walls.

17 And second significant change is for ECA
18 (Audio interference.) with buildings at the main
19 structures through limited potential structural
20 changes for west side within the reactor buildings.
21 But SDAA had not prepped the (Audio interference.)

22 That means that the west end of the
23 reactor building is sufficient aircraft strike. So
24 that's two major difference at the (Audio
25 interference.) from DCA to SDAA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And this concludes my presentation.
2 Thanks for your time.

3 MEMBER MARTIN: Okay, I guess your last
4 slide here is kind of back material, correct.
5 Something coded in a review approach. If there's no
6 other comment --

7 MR. SWIM: We can go ahead and have it
8 written out. I believe the intent was to get it
9 written.

10 MS. NEUHAUSEN: Yeah, we were -- this is
11 Alissa Neuhausen. We were asked to cover it. In, you
12 know, in the DCA review I think we covered a lot of
13 our review process up front. And so this is a newer
14 tool that we've (Audio interference.) SDA we were
15 asked to just bring.

16 MEMBER MARTIN: Feel free.

17 MR. SWIM: This is Mike Swim again. And
18 we just wanted to highlight that for the NuScale,
19 staff emphasized the use of the integrated risk-
20 informed decisionmaking to bring all the technical
21 disciplines and decisionmakers together. This slide,
22 as we already mentioned, is a visual representation of
23 that communication tool that was used to support the
24 integrated review approach.

25 Staff would evaluate all five principles

1 of risk-informed decisionmaking, as found in Reg.
2 Guide 1174 across the disciplines, and used color-
3 coding to quickly indicate status towards meeting each
4 principle.

5 Now, this was an effective way to get
6 everyone on the same and to gain alignment and
7 communicate what the applicant still needed to
8 provide. And part of why I'm also bringing this us is
9 this framework is referenced from time to time as you
10 may see as a part of the review, the SER, including
11 explicitly in Chapter 5 of the SER for (Audio
12 interference.)

13 That's all. Should be it for everything.

14 MEMBER MARTIN: Appreciate that. Are
15 there any questions from the members here in the room
16 or online?

17 MEMBER DIMITRIJEVIC: Yeah, I have one
18 question about uncertainty analysis. So you reviewed
19 uncertainty analysis and noticed there was a couple
20 comments in the SER about that. So did you find
21 uncertainty analysis satisfactory or not important?
22 I mean, what was the conclusion on uncertainty
23 analysis associated with the SDA?

24 MS. POHIDA: Vesna, I think I need a
25 clarification. As I understand the question is were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 we -- was the multi-module assessment technically
2 acceptable.

3 MEMBER DIMITRIJEVIC: No, uncertainty. I
4 don't know if my microphone maybe not working
5 perfectly. Uncertainty analysis, it's nothing to do
6 with multi-module. I mean, uncertainty analysis --

7 MS. POHIDA: Oh, I'm sorry.

8 MEMBER DIMITRIJEVIC: -- is done for the
9 multi-modules too. So you guys review uncertainty
10 analysis I know because I saw the couple questions you
11 also issue on the uncertainty distribution.

12 What was your conclusion on the review of
13 the summary of results with uncertainty, the, you
14 know, levels identified? Did you find this
15 acceptable, or in this moment you think it's
16 irrelevant because the safety goals are met with this
17 margin?

18 Okay, my question is did you find the
19 uncertainty analysis adequate in the SDA?

20 MS. POHIDA: I'll take a stab at this. We
21 reviewed the sensitivity studies, the various
22 sensitivity studies that were documented in the FSAR,
23 and I believe it's Table 19.1-22. You know, I'm
24 saying from my review of the passive safety system
25 reliability analysis, you know, I spent a significant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 amount of time looking at data inputs to RELAP and
2 uncertainty distributions.

3 So for, based on my review, yes, I found
4 -- I found the sensitivity studies that were done and
5 with respect to uncertainties, I found that
6 technically acceptable.

7 Does that answer your question?

8 MEMBER DIMITRIJEVIC: Well, I was
9 wondering about that. I mean, I had the, you know, on
10 the sensitivity studies, there was sort of like a, you
11 know, the very, how would I say? It's, they're not
12 really finely defined. Like because they've saying
13 they set all the common cause fire to 95%, then
14 increases in 100.

15 Well, surprise, surprise, what does it
16 mean, MDCCF? I mean, you know, like you know, we can
17 just concentrate on ECCS failure. Then when you talk
18 about the, you know, positive heat transfer, I mean,
19 I don't know how does it reflect in the RELAP.

20 But here there is a number assumed that
21 even if you have a successful actuation of ECCS, that
22 mean, you know, positive heat transfer to reactor pool
23 is estimated to be 1 in -7, and that's something which
24 needs to be confirmed in the future, the test.

25 Well, you know, this is a very, you know,

1 the -- what we're saying, that this is a passive
2 plant. There is a lot of things which we are not
3 familiar with. And this are the things which have to
4 come with the bigger uncertainty. But this plant,
5 uncertainty analysis shows incredibly uncertainty.

6 And also it's not really clear where those
7 uncertainties, you know, where -- I'm not sure is this
8 passive heat transfer failure at all involved because
9 it's small compared to the, you know, valves opening
10 or something. But the uncertainty associated that is
11 probably high, and so is the valves operation.

12 This is not reflected in sensitivity if I
13 don't say this ECCS value 95 percentile and then we
14 see increases higher than 100. What does it mean? I
15 mean, you know, or HEP, same thing, sector 95.

16 So my question is did you guys have a
17 discussion about that, then what was the -- when you
18 saw the narrow range of the distributions for all
19 those things, were you concerned about that? Have you
20 been concerned that mean value in point estimates are
21 the same? And the state of knowledge that wasn't
22 reflected in these things when the lot of things are
23 common valve failures.

24 So I mean, I was just, you know, wondering
25 about did you guys have a discussion about this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. POHIDA: Alissa, I defer to you. I
2 can speak specifically about the passive safety system
3 reliability analysis, if that would be helpful. But
4 as to overall discussions, I'm going to defer to
5 Alissa.

6 MR. VASAVADA: This is Shilp Vasavada from
7 the NRC staff. So if I understand the concern
8 correctly, you're saying that there's not enough data,
9 there's uncertainty.

10 One thing that we did look at in the
11 review is the list of key assumptions that includes
12 uncertainty are appropriate and capture as you can say
13 a kind of state of knowledge, items that need to be
14 revisited and confirmed during a COL and also later on
15 during operation.

16 That was when we are dealing with the, we
17 can call it the uncertainty variables that you were
18 talking about, if that helps.

19 MEMBER DIMITRIJEVIC: That will help if
20 it's identified somewhere, you know. It's really I
21 have a -- I mean, this is -- this is a SDAA PRA, and
22 it's probably best we will ever see because they have
23 already done DCA and this PRA has a lot of details and
24 you know, as a PRA, it's a great PRA.

25 Now, the question is best PRA is great as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a PRA. Does this PRA realistically identify important
2 thing. That's what I am not 100% sure. Does this PRA
3 realistically show uncertainties, that I'm not 100%
4 sure. This is the question, you know, I ask myself
5 when I look in there.

6 Is this good PRA? Yes, it's an excellent
7 PRA. But is a PRA good if it doesn't identify well,
8 you know, the important contributions. And does -- is
9 it reflecting on the uncertainties associated with
10 this new design with the passive features and things
11 like that.

12 And I question its importance for some
13 things, but for the uncertainty analysis I totally
14 question that, that that's uncertainty present here
15 it's totally unrealistic, so. You know, if you say
16 the passive failure, the passive cooling, you know,
17 it's one E minus seven what is uncertainty
18 distribution on this.

19 So I like what you said. Maybe these
20 things should be identified in the COL, but that
21 should be somewhere identified as something which will
22 be look in the more details.

23 That's my speech then, so. And I like
24 your presentation very much. It was very helpful,
25 thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. POHIDA: Thank you, Vesna. I
2 appreciate your question. There are tables in the
3 FSAR of key sources of uncertainty. You know, we
4 recognize that this is a paper plant with unique
5 design features and there's uncertainty.

6 But those -- but in the FSAR there are
7 listed key sources of -- key sources of uncertainty
8 that, you know, if someone were to come in with a
9 risk-informed application, those would need to be
10 reviewed and evaluated. But thank you.

11 MEMBER DIMITRIJEVIC: Okay.

12 MEMBER MARTIN: Are there any further
13 questions? From members in the call? Not hearing any,
14 it's time to go to public comment. Oh, feel free.
15 Introduce yourself.

16 MR. OSBORN: Yeah, my name's Jim Osborn,
17 NuScale Licensing. I just want to be very clear that,
18 because this could be taken out of context, out of
19 abundance of caution here, that this slide is a
20 example, is not necessarily a particular reflection on
21 NuScale design or NuScale PRA.

22 So I just wanted that on the record, that
23 that's an example slide and not necessarily --

24 MEMBER MARTIN: It's a lot of red.

25 Okay, I think at this time we'll move to

1 public comment. So if you're a member of the public
2 and wish to express yourself, please maybe raise your
3 hand using the MS Teams hand. And we'll identify you
4 and at that time we'll ask you to identify yourself
5 and your affiliation and your comment.

6 All right, going once, going twice? All
7 right, not hearing any public comment, I think we can
8 move to adjourn the open session. I'm looking for a
9 nod. Okay. Okay, all right.

10 So this concludes the open session on
11 Chapter 6, Section 17.4 and Chapter 19. There is a
12 closed session scheduled. We don't have any
13 presentations for that. So I don't know if, will we
14 actually enter closed session?

15 MR. SNODDERLY: So we can have a
16 discussion right now. I mean, I think the question is
17 --

18 MEMBER MARTIN: Is it -

19 (Simultaneous speaking.)

20 MR. SNODDERLY: Yeah.

21 MEMBER MARTIN: Okay.

22 MR. SNODDERLY: How about this --

23 MR. TESFAYE: This is Getachew Tesfaye
24 again. I have additional information in Section 19.5
25 in the closed session.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER MARTIN: So you're basically saying
2 yes. So we will have this closed session. So then
3 for the time being, I'm going to adjourn this open
4 session, and then we will clean everything up and
5 check out who can and cannot be in the room. And then
6 we'll reconvene, it will be in about ten minutes.
7 Let's just --

8 MR. SNODDERLY: I think we can do it in --
9 it's up to you, Bob. Do you want to break for 15 or
10 10? I can be ready in 10.

11 MEMBER MARTIN: Okay, let's do it, let's do
12 it, well, 10's basically 3:00 o'clock. So let's
13 reconvene at 3:00 o'clock, so we'll split the
14 difference and reconvene with the closed session.

15 But this otherwise adjourns the public
16 session.

17 (Whereupon, the above-entitled matter went
18 off the record at 2:48 p.m.)
19
20
21
22
23
24
25

February 12, 2025

Docket No. 052-050

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Material Entitled "ACRS Subcommittee Meeting (Open Session) Chapter 6, Section 17.4 and Chapter 19," PM-179462, Revision 0

The purpose of this submittal is to provide presentation materials for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Subcommittee Meeting on February 18th, 2025. The materials support NuScale's presentation of the subject chapters and section for the US460 Standard Design Approval Application.

The enclosure to this letter is the nonproprietary presentation entitled "ACRS Subcommittee Meeting (Open Session) Chapter 6, Section 17.4 and Chapter 19," PM-179462, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Jim Osborn at 541-360-0693 or at josborn@nuscallepower.com.

Sincerely,



Thomas Griffith
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Mahmoud Jardaneh, Chief New Reactor Licensing Branch, NRC
Getachew Tesfaye, Senior Project Manager, NRC
Michael Snodderly, Senior Staff Engineer, Advisory Committee on
Reactor Safeguards, NRC
Prosanta Chowdhury, Senior Project Manager, NRC

Enclosure 1: ACRS Subcommittee Meeting (Open Session) Chapter 6, Section 17.4 and Chapter 19, PM-179462, Revision 0, Nonproprietary

Enclosure 1:

ACRS Subcommittee Meeting (Open Session) Chapter 6, Section 17.4 and Chapter 19,
PM-179462, Revision 0, Nonproprietary



ACRS Subcommittee Meeting

(Open Session)

February 18, 2025

Chapter 6

Engineered Safety Features

Presenter: Tyler Beck

Acknowledgement and Disclaimer

This material is based upon work supported by the Department of Energy under Award Number DE-NE0008928.

This presentation was prepared as an account of work sponsored by an agency of the United States (U.S.) Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

Chapter 6 Overview

- Section 6.1, Engineered Safety Feature Materials
- Section 6.2, Containment Systems
- Section 6.3, Emergency Core Cooling System
- Section 6.4, Control Room Habitability
- Section 6.5, Fission Product Removal and Control Systems
- Section 6.6, Inservice Inspection and Testing of Class 2 and 3 Systems and Components
- Note: The Chapter 6 presentation covers design of engineered safety features as discussed in FSAR Chapter 6
 - The presentation does not cover specifics of accident sequences or evaluations (Ch. 15), Probabilistic Risk Assessment (Ch. 19), etc.
 - The presentation focuses on differences from the US600 DCA to the US460 SDAA

Section 6.1, Engineered Safety Feature Materials

- Containment vessel (CNV) material changes:
 - US600: CNV composed of FXM-19 (austenitic stainless steel) and SA-508 (low-alloy steel)
 - US460: CNV composed of FXM-19 and F6NM (martensitic stainless steel)
 - Addition of new Table 6.1-1, Dissimilar Metal Welds
 - Addition of weld metals due to CNV materials changes
 - Provisions for welding dissimilar metals
- Implemented additional welding controls in response to NRC staff audits (e.g., post weld heat treatment)

Containment Vessel





Figure: Lower Containment Vessel




FSAR Figure 6.2-1: Containment System

Section 6.2, Containment Systems

- Containment system (CNTS) changes:
 - Containment vessel:
 - Material changes (discussed in Section 6.1)
 - Number of CNV penetrations changed from 42 penetrations to 45 penetrations
 - Design pressure rating changed from 1050 psia to 1200 psia
 - Design temperature rating changed from 550°F to 600°F
 - CVCS injection and discharge line include venturis integral to the CNV penetration
 - Mitigates line breaks outside the CNV
 - Combustible gas control:
 - Addition of safety-related passive autocatalytic recombiner (PAR) to maintain inert containment atmosphere
 - Removal of combustion loads as a result of maintaining an inert environment
 - Removal of combustible gas monitoring and an exemption from monitoring requirements

Section 6.2, Containment Systems (cont.)

- CNTS changes:
 - Containment isolation:
 - Addition of containment isolation test fixture (CITF) valve between the CNV nozzle and the containment isolation valve (CIV)
 - Improves ability to perform Appendix J testing
 - DCA design included first of a kind leak testing features integrated into the CIV assembly
 - CIVs are welded directly to CITF, which are welded directly to the CNV nozzle safe-end
 - CIV closure time changed from 7 to 10 seconds



FSAR Figure 6.2-4: Primary System
Containment Isolation Valves Dual
Vale, Single Body Design

Section 6.2, Containment Systems (cont.)

- CNTS changes:
 - Containment response analysis:
 - Initial conditions align with US460 standard design
 - Similar stored energy to US600
 - US460 includes more design margin
 - Methodology included in the LOCA topical report
 - Removal of COL item related to containment leakage rate testing program
 - Addition of ITAAC verifying CNV free volume (and removal of previous COL item)
- 17 audit items and 4 RAIs resolved


	US600 DCA	US460 SDAA
Primary Events Peak Pressure (psia)	994 (IORV)	937 (DL break)
Primary Events Peak Temperature (°F)	526 (IL break)	533 (DL break)
Secondary Events Peak Pressure (psia)	449 (MSLB)	900 (MSLB)
Secondary Events Peak Temperature (°F)	433 (MSLB)	530 (MSLB)

Section 6.3, Emergency Core Cooling System

- ECCS changes:
 - ECCS valves:
 - Changes related to safety analysis optimization:
 - ECCS includes two reactor vent valves (RVVs) from three in the DCA (change coincident with UHS pool level change)
 - RVVs do not include inadvertent actuation block (IAB) valve: RVVs open upon ECCS actuation
 - RRV IABs modified to 900 psid threshold (block) pressure and 450 psid release pressure
 - Addition of integral venturi to RRVs/RVVs to limit flow during high differential pressure conditions
 - Decouples flow limiting function of valve internals
 - Other operational enhancements:
 - Two in-series trip solenoid valves per RRV/RVV from a single trip solenoid valve per RRV/RVV in the DCA
 - ECCS actuation:
 - Removal of high CNV level and low RCS pressure ECCS actuation signals
 - Addition of low and low-low RPV riser level actuation signal
 - Addition of high-high RCS pressure and high-high RCS T_{ave} ECCS actuation setpoints for BDBEs



Section 6.3, Emergency Core Cooling System (cont.)

- ECCS changes:
 - ECCS includes an ECCS supplemental boron (ESB) feature:
 - Boron hoppers, condensate channels, dissolvers, mixing tubes
 - Addition of 8-hour ECCS actuation timer following reactor trip
- 14 audit items and 5 RAIs resolved



FSAR Figure 6.3-2: Emergency Core Cooling System Operation

ECCS Supplemental Boron



Detail from FSAR Figure 6.3-5: ECCS
Emergency Supplemental Boron Feature Details

Section 6.4, Control Room Habitability

- CRHS changes:
 - Ten minute delay added to actuation due to a loss of power to battery chargers
 - Toxic gas detection is within the scope of COL Item 6.4-1
- Removed previous COL Item 6.4-5 that required testing and inspection requirements be specified for CRHS
- Audit and RAI Results
 - One audit item concerning test method for test 16.02.03 (FSAR Table 14.2-16) and COL Item 6.4-1, resolved successfully

Section 6.5, Fission Product Removal and Control Systems

- Unchanged from DCA

Section 6.6, Inservice Inspection and Testing of Class 2 and 3 Components

- No significant changes from DCA
 - Inservice Inspection of Class 2 and 3 components satisfies relevant 50.55a requirements and allows optional RG 1.147 code cases
- Removed previous COL Item 6.6-1
 - Inservice testing program is described in Section 3.9.6



ACRS Subcommittee Meeting

(Open Session)

February 18, 2025

Section 17.4

Reliability Assurance Program

Presenter: Peter Shaw

Section 17.4: Reliability Assurance Program

- As in the DCA, the Design Reliability Assurance Program (D-RAP) reviews and approves safety and risk classification
- NuScale re-evaluated the structures, systems, and components (SSC) classifications for the US460 standard plant design
- D-RAP expert panel insights resulted in changes to methodology for panel insights, without design changes
 - Steam generator tubes are safety-related, not risk-significant
 - Control rod drive mechanisms are safety-related, not risk-significant
- Audit Results
 - 10 items resolved in audit and resulted in updates to FSAR Section 8.2 and Figure 17.4-1 to clarify the SSC classification process and corresponding section references.
- RAI Results
 - RAI 10199, Question 17.4-11 Resolved
 - Clarified the process does not assume risk significance based on safety-related classification
 - Resulted in clarifications to the default classification in FSAR Section 17.4.3.2 and role of backup diesel generators in Table 19.1-56 (Revision 2)



ACRS Subcommittee Meeting

(Open Session)

February 18, 2025

Chapter 19

Probabilistic Risk Assessment and Severe Accident Evaluation

Presenters: Jim Schneider and Peter Shaw

Chapter 19 Probabilistic Risk Assessment and Severe Accident Evaluation

- 19.1 Probabilistic Risk Assessment
- 19.2 Severe Accident Evaluation
- 19.3 Regulatory Treatment of Nonsafety Systems
- 19.4 Strategies and Guidance to Address Mitigation of Beyond-Design-Basis Events
- 19.5 Adequacy of Design Features and Functional Capabilities Identified and Described for Withstanding Aircraft Impacts

Application review summary:

- 156 audit issues resolved in the audit, including 84 document requests
- 15 RAI questions resolved

Note: an asterisk (*) indicates information that was added to Revision 2 of the SDAA

Section 19.1: Probabilistic Risk Assessment

General Overview

- 10 CFR 52.137(a)(25) requires a standard design applicant to develop a design-specific PRA.
- When a site is chosen and a plant built, a licensee will develop and maintain a plant-specific PRA for the life of the plant (that is, each plant shall have a *living* PRA).
 - The SDAA includes COL items that ensure the applicant has a PRA in the combined license, construction, and operational phases.
- The purposes of the PRA at the design phase include:
 - evaluate the overall safety of the plant design
 - provide insights for potential design improvements
- The safety goals of the Commission are a core damage frequency (CDF) of less than **1.0E-4** each reactor year, and a large release frequency (LRF) of less than **1.0E-6** each reactor year.

Comparison of PRA Results (mean values)

US600 DCA

Full Power		
Hazard	CDF (per mcyр)	LRF (per mcyр)
Internal Events	3.0E-10	2.3E-11
Internal Fires	9.7E-10	4.3E-11
Internal Floods	6.1E-11	<1E-15
External Floods	8.7E-10	7.9E-14
High Winds (Tornado)	9.9E-11	<1E-15
High Winds (Hurricane)	7.2E-10	6.4E-14
Seismic (SMA)	0.88g	
Low Power and Shutdown		
Hazard	CDF (/mcyр)	LRF (/mcyр)
Internal Events	4.9E-13	2.0E-14
Module Drop	8.8E-08	N/A
Multi-Module		
Hazard	Conditional Probability of Core Damage	Conditional Probability of Large Release
Multi-Module	0.13	0.01
Composite CCFP < 0.1		

US460 SDAA

Full Power		
Hazard	CDF (per mcyr)	LRF (per mcyr)
Internal Events	6.0E-09	6.6E-13
Internal Fires	4.6E-09	1.3E-11
Internal Floods	1.6E-10	3.4E-14
External Floods	9.5E-09	1.4E-12*
High Winds (Tornado)	2.6E-09	1.6E-13
High Winds (Hurricane)	1.9E-08	1.3E-12
Seismic (SMA)	0.92g	
Low Power and Shutdown		
Hazard	CDF (/mcyr)	LRF (/mcyr)
Internal Events	4.0E-11	3.5E-12
Module Drop	1.8E-08	N/A
Multi-Module		
Hazard	Conditional Probability of Core Damage	Conditional Probability of Large Release
Multi-Module	0.21	0.03
Composite CCFP < 0.1		

mcyr = module critical year
 CCFP = conditional containment failure probability
 SMA = seismic margin assessment

Section 19.1: Probabilistic Risk Assessment

Overview of PRA Results

- Internal events CDF increased, in part because of changes to ECCS, such as reducing the number of RVVs from three to two, the addition of an 8-hour actuation timer, and the addition of redundant trip valves on RRVs and RVVs.
 - from 3.0E-10 per module critical year (mcy) to 6.0E-09 per mcy
- Internal events LRF decreased, primarily because of changes to ECCS that allow breaks outside of containment with failed containment isolation to be mitigated *without the need for operator action or inventory makeup*.
 - from 2.3E-11 per mcy to 6.6E-13 per mcy

Section 19.1: Probabilistic Risk Assessment

Mitigation of unisolated breaks outside of containment

- Early ECCS actuation can limit coolant loss from the break by reducing system to atmospheric pressure.
 - core stays covered and core damage is avoided without requiring addition of coolant to the module
- Relevant design changes:
 - removal of inadvertent actuation blocks on the reactor vent valves
 - addition of low reactor pressure vessel riser level ECCS actuation signal
 - addition of venturi flow restrictors to CVCS injection and discharge lines to limit maximum break flow
- NuScale added an uncertainty to Table 19.1-28 addressing the low likelihood of weld failures between the CNV and the CIVs for CVCS*.
 - The low likelihood of this weld failure, combined with leak identification and response requirements, minimize the impact of this event on the LRF.

Section 19.1: Probabilistic Risk Assessment

Criteria for Risk Significance

- For determining component candidates for risk significance, NuScale uses both an absolute criterion and a sliding scale.
- The sliding scale only applies to relative FV threshold; there is no change to the absolute conditional core damage frequency (CCDF) and conditional large release frequency (CLRf) thresholds.
- At lower CDF and LRF, a higher Fussell-Vesely (FV) value is tolerated due to the low absolute risk.
- The criteria are listed in FSAR Table 19.1-19, Criteria for Risk Significance:

Parameter	Core Damage Criteria for Risk Significance ¹	Large Release Criteria for Risk Significance ¹
Component	CCDF $\geq 3\text{E-}06$	CLRf $\geq 3\text{E-}07$
System	CCDF $\geq 1\text{E-}05$	CLRf $\geq 1\text{E-}06$
Component ²	Total FV = 0.005 if CDF > $1\text{E-}07$	Total FV = 0.005 if LRF > $1\text{E-}08$
Component	Total FV = 0.2 if ($1\text{E-}07 \geq \text{CDF} > 1\text{E-}08$)	Total FV = 0.2 if ($1\text{E-}08 \geq \text{LRF} > 1\text{E-}09$)
Component	Total FV = 0.5 if ($1\text{E-}08 \geq \text{CDF} > 1\text{E-}09$)	Total FV = 0.5 if ($1\text{E-}09 \geq \text{LRF} > 1\text{E-}10$)
Component	Total FV = 0.9 if ($1\text{E-}09 \geq \text{CDF} \geq 1\text{E-}10$)	Total FV = 0.9 if ($1\text{E-}10 \geq \text{LRF} \geq 1\text{E-}11$)

Notes:

1. Risk values are provided in units of per mcy.

2. Risk values are based on Condition 4 of the SER, which requires CDF to be approximately $1\text{E-}07$ /year or less, along with the CCFP goal of 0.1.

Section 19.2: Severe Accident Evaluation

- New COL Item 19.2-4 related to survivability*:
 - “An applicant that references the NuScale Power Plant US460 standard design will identify from Table 19.2-8 (*Equipment Survivability List*) the components and their severe accident doses for cases where the severe accident dose is greater than the environmental qualification dose.”
 - This COL item ensures that severe accident dose requirements are captured by the licensee in equipment specifications.

Section 19.3: Regulatory Treatment of Nonsafety Systems

- No change in methodology or results from the DCA: no SSC satisfy the criteria for Regulatory Treatment of Nonsafety Systems.

Section 19.4: Strategies and Guidance to Address Mitigation of Beyond-Design-Basis Events

- An applicant that references the NuScale Power Plant US460 standard design has the responsibility of addressing mitigation of beyond-design basis events in accordance with 10 CFR 50.155.
- NuScale has presented its topical report on the NuScale Power Plant Design Capability to Mitigate Beyond-Design-Basis Events to the ACRS.

Section 19.5: Adequacy of Design Features and Functional Capabilities Identified and Described for Withstanding Aircraft Impacts

- High-level SDAA design changes reflected in the Aircraft Impact Analysis (AIA):
 - The SDAA Reactor Building (RXB) reflects 6 modules (12 modules in the DCA) with updated building and site layout configuration.
 - In the SDAA the RXB uses steel-plate composite (SC) walls along with reinforced concrete (RC) members.
- Additional AIA differences in the SDAA:
 - No other buildings are credited as intervening structures in the analysis (DCA credited the Radioactive Waste Building)
 - FSAR Section 19.5.1 updates how the assessment was performed, including models for concrete and steel
 - FSAR Section 19.5.4.1 Physical Damage updates reflect key design changes with the updated analysis for SC construction and site layout
 - Reactor Building equipment door design changed (with the SC construction) and details updated for the key design feature including reinforcement and connection details
 - Emergency core cooling system (ECCS) identified as a key design feature to ensure adequate core cooling

Section 19.5: Adequacy of Design Features and Functional Capabilities Identified and Described for Withstanding Aircraft Impacts

- Audit Responses
 - 12 audit questions, 4 resolved with no changes to the SDAA, 8 transitioned to RAI
- RAI Results
 - 8 RAIs: Resulted in additional design details additions in FSAR Section 19.5 to support the RAI responses
 - Clarification on the basis of steel composite wall efficacy for resisting aircraft impact
 - Clarified details of certain structural features credited as key design features for aircraft impact analysis
 - Reactor building equipment door details were discussed for equivalence to SC walls
 - Key design features added to the SDAA consistent with NEI 07-13 guidance
- SDAA Revision 2 updates to include AIA key design feature updates in FSAR Section 19.5 with supporting Figure 1.2 updates, conclusions remain the same:
 - Consistency with NEI 07-13 Revision 8
 - Meets 10 CFR 50.150(a) with containment intact, core cooling capability, and spent fuel pool integrity

Acronyms

ACRS	Advisory Committee on Reactor Safeguards	ISI	inservice inspection
AIA	Aircraft Impact Analysis	IST	Inservice Testing
BDBE	beyond-design-basis event	ITAAC	Inspections, Tests, Analyses, and Acceptance Criteria
CCDF	conditional core damage frequency	LOCA	loss-of-coolant accident
CCFP	conditional containment failure probability	LRF	large release frequency
CDF	core damage frequency	mcyr	module critical year
CFR	Code of Federal Regulations	MSLB	main steam line break
CITF	containment isolation test fixture	NEI	Nuclear Energy Institute
CIV	containment isolation valve	NRC	Nuclear Regulatory Commission
CLRF	conditional large release frequency	PAR	passive autocatalytic recombiner
CNTS	containment system	PRA	Probabilistic Risk Assessment
CNV	containment vessel	PZR	pressurizer
COL	combined license	RAI	Request for Additional Information
CRHS	control room habitability system	RC	reinforced concrete
CVCS	chemical and volume control system	RCS	reactor coolant system
DCA	Design Certification Application	RG	Regulatory Guide
DL	discharge line	RRV	reactor recirculation valve
D-RAP	Design Reliability Assurance Program	RVV	reactor vent valve
ECCS	emergency core cooling system	RXB	Reactor Building
ESB	ECCS supplemental boron	SC	steel-plate composite
ESF	engineered safety feature	SDAA	Standard Design Approval Application
FSAR	Final Safety Analysis Report	SER	Safety Evaluation Report
FV	Fussell-Vesely	SG	steam generator
IAB	inadvertent actuation block	SMA	seismic margin assessment
IL	injection line	SSC	structures, systems, and components
IORV	inadvertent operation of a relief valve		

**Presentation to the Advisory Committee on
Reactor Safeguards Subcommittee**

**Staff Review of NuScale's US460 Standard Design
Approval Application (SDAA)**

Final Safety Analysis Report (FSAR), Revision 1

Chapters 6 and 19, and Section 17.4

**February 18th, 2025
(Open Session)**

Presentation to the ACRS Subcommittee Staff Review of NuScale SDAA FSAR, Revision 1

Chapter 6, “Engineered Safety Features”

**February 18th, 2025
(Open Session)**

NuScale SDAA FSAR Chapter 6 Review

Overview

- ❖ NuScale submitted Chapter 6, “Engineered Safety Features” Revision 0 of the SDAA FSAR on December 31, 2022, and Revision 1 on October 31, 2023
- ❖ NRC regulatory audit of Chapter 6 was performed from March 2023 to August 2023, generating 46 audit issues
- ❖ Questions raised during the audit were resolved within the audit. Six RAIs were issued, and the responses were acceptable
- ❖ Staff completed Chapter 6 review and issued an advanced safety evaluation to support today’s ACRS Subcommittee meeting
- ❖ No significant changes between draft SE provided to ACRS on 1/18/25 and SE submitted on 2/12/25

NuScale SDAA FSAR Chapter 6 Review

Contributors

❖ Technical Reviewers

- ☐ Robert Davis, NRR/DNRL/NPHP
- ☐ Matthew Yoder, NRR/DNRL/NCSG
- ☐ Syed Haider, NRR/DSS/SNSB
- ☐ Dan Widrevitz, NRR/DNRL/NVIB
- ☐ Brian Lee, NRR/DSS/SCPB
- ☐ Anne-Marie Grady, NRR/DRA/APLC
- ☐ Ryan Nolan, NRR/DSS/SNRB
- ☐ Sean Piela, NRR/DSS/SNRB
- ☐ Shanlai Lu, NRR/DSS/SNRB
- ☐ David Nold, NRR/DSS/SCPB
- ☐ Stephen Cumblidge, NRR/DNRL/NPHP
- ☐ Hanry Wagage, NRR/DSS/SCPB

❖ Project Manager

- Getachew Tesfaye, NRR/DNRL/NRLB

NuScale SDAA FSAR Chapter 6 Review

Sections

- ❖ Section 6.1 – Engineered Safety Feature Materials
- ❖ Section 6.2 – Containment Systems
- ❖ Section 6.3 – Emergency Core Cooling System
- ❖ Section 6.4 – Control Room Habitability
- ❖ Section 6.5 – Fission Product Removal and Control Systems
- ❖ Section 6.6 – Inservice Inspection and Testing of Class 2 and 3 Systems and Components
- ❖ Section 6.7 – Main Steamline Isolation Valve Leakage Control System (BWR)

NuScale SDAA FSAR Chapter 6 Review

Section 6.1.1 Engineered Safety Features Materials

❖ Significant differences between NuScale DCA FSAR and NuScale SDAA FSAR include:

- ❑ The use of ASME Code Case N-774, “Use of 13Cr-4Ni (Alloy UNS S41500) Grade F6NM Forgings Weighing in Excess of 10,000 lb (4540 kg) and Otherwise Conforming to the Requirements of SA-336/SA-336M for Class 1, 2, 3 Construction Section III, Division 1.”
 - Code Case N-774 is listed in Regulatory Guide 1.84, Rev. 39, “Design, Fabrication, and Material Code Case Acceptability, ASME Section III, Division 1,” as permitted for use without conditions.
 - F6NM replaces SA-508, Grade 3, Class 2 from the previous design for the upper CNV and a portion of the lower CNV below the upper/lower vessel flange.

NuScale SDAA FSAR Chapter 6 Review

Section 6.1.1 Engineered Safety Features Materials

❖ Welding/fabrication when using F6NM requires special considerations in addition to ASME Code requirements:

- ☐ The applicant has considered the effect of welding procedures on the Martensite start (M_s) and Martensite finish (M_f) temperatures
- ☐ Applicant will not follow recommended preheat temperature listed in Section III, non-mandatory Appendix D regarding weld preheat temperatures
- ☐ The applicant is employing an extensive testing program to determine the appropriate preheat temperature to prevent hydrogen cracking while at the same time promote martensite formation.

NuScale SDAA FSAR Chapter 6 Review

Section 6.1.1 Engineered Safety Features Materials

- ❖ Welding/fabrication when using F6NM requires special considerations in addition to ASME Code requirements (cont):
 - ❑ Welding processes that employ flux may require post weld heat treatment (PWHT) times than those specified in ASME Code.
 - Oxygen pickup from flux welding processes may require PWHT times greater than those specified in ASME Code to ensure adequate impact toughness.

NuScale SDAA FSAR Chapter 6 Review

Section 6.1.1 Engineered Safety Features Materials

❖ Welding/fabrication when using F6NM requires special considerations in addition to ASME Code requirements (cont):

- ☐ ASME Code specifies that the PWHT temperature range, for F6NM welds, is 1050°F to 1150°F. The lower critical (Ac1) temperature for 410NiMo type weld metals and F6NM base material can be as low as 1150°F or slightly lower.
- ☐ SDAA Section 6.1.1.1 will be modified to state, “Post weld heat treatment of SA-336 Gr F6NM for the CNV and supports shall be 1075°F +/- 25°F.”
 - Provides adequate margin to ensure that PWHT temperature does not exceed Ac1.
- ☐ Staff determined that additional controls/considerations placed on the fabrication of F6NM are adequate.
- ☐ Staff conclusion did not change from the DCA

NuScale SDAA FSAR Chapter 6.2.1/6.2.2 Review

Major Design Changes from DCA to SDAA

	NPM-160 for US600 (DCA)	NPM-20 for US460 (SDAA)
Rated thermal power	160 MWt	250 MWt
CNV upper vessel material	SA-508	SA-336 (F6NM)
Reactor pool level	65 ft	52 ft
Initial Reactor pool temperature	110 °F	140 °F (TS=120 °F)
Initial CNV wall temperature above pool level	240 °F	500 °F
Number of RVVs	3	2
IABs used on	RRVs & RVVs	RRVs
IAB release pressure range	900-1000 psid	400-500 psid
Venturis used on	None	RRVs & RVVs
DHRS operation for the DBE mitigation	Not credited	Credited
CNV design pressure	1050 psia	1200 psia
CNV design temperature	550 °F	600 °F

NuScale SDAA FSAR Chapter 6.2.1/6.2.2 Review

Additional Significant Changes from DCA to SDAA



- ❖ Containment Response Analysis Methodology (CRAM) TeR was IBRed in the DCA. Modified CRAM for the SDAA CNV design for NPM-20 is a part of the LOCA EM TR-0516-49422.
- ❖ A CNV free volume ITAAC included in SDAA to ensure that the as-built CNV free volume bounds the minimum value of 6000 ft³ used in the CNV safety analyses.
- ❖ DHRS credited to SDAA CNV DBEs: Reactor cooling pool heat-up and thermal stratification effects on DHRS and CNV heat removal performance degradation
 - ☐ Sensitivity of the CNV LOCA T/H response to break size & ECCS actuation
 - ☐ Justification for the natural convection heat transfer modeling
 - ☐ NuScale provided necessary analyses and justification through RAI 10359 response
- ❖ Containment P/T limiting design basis events have changed

	DCA	SDAA
Peak CNV Pressure DBE	Inadvertant RRV opening	RCS discharge line break LOCA
Peak CNV Pressure	994 psia	937 psia
CNV Pressure Margin	~5% (vs. $p_{\text{design}} = \text{1050 psia}$)	~22% (vs. $p_{\text{design}} = \text{1200 psia}$)
Peak CNV Temperature DBE	RCS injection line break LOCA	RCS discharge line break LOCA
Peak CNV Wall Temperature	526 °F	533 °F
CNV Temperature Margin	24 °F (vs. $T_{\text{design}} = \text{550 °F}$)	67 °F (vs. $T_{\text{design}} = \text{600 °F}$)

NuScale SDAA FSAR Chapter 6.2.1/6.2.2 Review

Staff Confirmatory Analysis Results for the SDAA NPM-20 CNV

- ❖ Staff (MELCOR) & Applicant's (NRELAP5) Results for the Combined P/T Limiting DBA Case
 - ❑ LOCA caused by RCS (CVCS) discharge line break from the downcomer (limiting CRAM DBE) (DL) – A primary system's M&E release event



❖ NRELAP5 Results:

- ❑ Peak containment pressure predicted is 937 psia (<1200 psia limit)
- ❑ Maximum containment wall temperature predicted is 533 °F (< 600 °F limit)

NuScale SDAA FSAR Chapter 6.2.1/6.2.2 Review

Conclusions

- ❖ The containment safety analyses appropriately modeled the relevant phenomena in the NPM-20 CNV response including condensation heat transfer, non-condensable gas effect, decay heat, choked flow, DHRS/ECCS impact, and CNV heat removal to the reactor pool.
- ❖ NuScale CNV design incorporates sufficient conservatism in the NPM-20 CNV model ICs/BCs for the US460 design.
- ❖ NuScale SDAA FSAR Chapter 6 provides sufficient and acceptable information for analyzing the M&E release into the CNV for the spectrum of primary and secondary design basis events, and determining the limiting CNV pressure and temperature response.
- ❖ NuScale CNV design meets all regulatory requirements and acceptance criteria for the containment safety design.

NuScale SDAA FSAR Chapter 6.2.5 Review

Significant Changes from DCA to SDAA

Change	DCA	SDAA
Applicable Regulation	10 CFR 50.44(c)	10 CFR 50.44(d)
Guidance	SRP 6.2.5, 19.0	RG 1.7, SRP 19.0
Combustible Gas Control	CNV combustion analysis	PAR maintains inert CNV
Safety category	No PAR	Safety-related PAR
ITAAC	none	Physical arrangement and installation; analysis and test of recombination rate; part of EQ
Tech Specs	none	LCO 3.6.4 on PAR operability
CGC technical report	TR-0716-50424, rev 1	Several - prop, ECI
Exemption Request #2	Uncertain means of post-accident monitoring of H ₂ , O ₂	No post-accident H ₂ , O ₂ monitoring

NuScale SDAA FSAR Chapter 6.2.5 Review

Acceptability of 50.44(d) as Applicable Regulation for CGC in SDAA

- ❖ The CNV is not inert ($<4\%$ O_2 in presence of H_2) during a design basis accident (DBA) in the first 24 hours of a non-core damage AOO.
- ❖ 10 CFR 50.44(c) applies mainly to severe accidents
- ❖ 10 CFR 50.44(d)(2) applies to the “the safety impacts of combustible gases during design basis and significant beyond design basis accidents...”

NuScale SDAA FSAR Chapter 6.2.5 Review

Conclusion

- ❖ Combustible Gas Control conclusion:
 - ☐ During non-core damage DBA LOCA, PAR is credited to maintain an inert CNV
 - ☐ Post severe accident, CNV remains inert without crediting PAR
 - ☐ During long term radiolysis, PAR is credited to maintain an inert CNV
- ❖ Exemption request #2
 - ☐ Post accident monitoring of H₂ and O₂ not required to assess core damage. Assessment to be accomplished by core exit thermocouples and radiation monitors beneath the bioshield.

NuScale SDAA FSAR Chapter 6 Review

Section 6.2.7 Fracture Prevention Containment Vessel

❖ Significant differences between NuScale DCA FSAR and NuScale SDAA FSAR include:

- ☐ F6NM replaces SA-508, Grade 3, Class 2 from the previous design for the upper CNV and a portion of the lower CNV below the upper/lower vessel flange.
- ☐ Staff verified that material change would not result in significant impacts on fracture toughness management of CNV.
- ☐ Staff conclusion did not change from DCD.

NuScale SDAA FSAR Chapter 6 Review

Section 6.3 Emergency Core Cooling System (ECCS)

Significant differences between NuScale DCA FSAR and NuScale SDAA FSAR include:

- ❖ Addition of passive Emergency Supplemental Boron (ESB) feature.
 - ☐ Chapter 14 includes first of a kind test
 - ☐ Extended Passive Cooling topical report and SDAA 15.0.5 contain boron transport methodology and analysis
- ❖ Removal of Inadvertent Actuation Block Valves (IABs) on Reactor Vent Valves (RVVs) – IABs retained for Reactor Recirculation Valves (RRVs).
- ❖ Inclusion of flow restricting venturis in RVVs and RRVs.
 - ☐ Exclusion of flange breaks from LOCA break spectrum evaluated in SER 15.6.5
- ❖ ECCS actuation signals changed to RPV riser level.
 - ☐ Chapter 15 review confirms modeling of the riser level sensor
- ❖ 8 hour timer actuates ECCS valves after an automatic or manual trip
 - ☐ Recirculates boron from ESB into core to maintain subcriticality
 - ☐ Vents accumulated combustible gas from radiolysis

Presentation to the ACRS Subcommittee Staff Review of NuScale SDAA FSAR, Revision 1

Chapter 17, “Quality Assurance and Reliability Assurance,” Section 17.4, “Reliability Assurance Program”

**February 18, 2025
(Open Session)**

NuScale SDAA FSAR Section 17.4 Review

Overview

- ❖ NuScale submitted Chapter 17, “Quality Assurance and Reliability Assurance,” Revision 0 of the NuScale SDAA FSAR on December 28, 2022, and Revision 1 on October 31, 2023.
- ❖ NRC performed a regulatory audit as part of its review of Chapter 17, Section 17.4, from March 2023 to June 2024.
- ❖ Questions raised during the audit were resolved within the audit. One RAI was issued, and the response was acceptable.
- ❖ Staff completed the review of Chapter 17, Section 17.4 and issued an advanced safety evaluation to support the ACRS Subcommittee meeting.
- ❖ No significant changes between draft SE provided to ACRS on 1/18/25 and SE provided on 2/12/25

NuScale SDAA FSAR Section 17.4 Review

Contributors

❖ Technical Reviewers

- ❑ Alissa Neuhausen, NRR/DRA/APLC
- ❑ Steven Alferink, NRR/DRA/APLC
- ❑ Keith Tetter, NRR/DRA/APLC

❖ Project Managers

- ❑ Prosanta Chowdhury, PM, NRR/DNRL/NRLB
- ❑ Getachew Tesfaye, Lead PM, NRR/DNRL/NRLB

NuScale SDAA FSAR Section 17.4 Review

Significant Changes from DCA to SDAA

- ❖ EDAS provides power to maintain ECCS valves closed during normal operation and contributes to defense in depth in the design.
 - ☐ Reactor vent valves do not include an inadvertent actuation block valve.
- ❖ Safety-related PAR added to maintain the containment atmosphere inert during design-basis events and significant beyond-design-basis events.
- ❖ Safety-related steam generator system and safety-related components in the control rod drive system are not identified as risk-significant in FSAR Table 17.4-1
 - ☐ These SSCs perform the same system functions in the US600 design and were identified as risk significant in the DCA.

NuScale SDAA FSAR Section 17.4 Review

Conclusion

- ❖ Augmented design requirements for EDAS are comparable with the design requirements for D-RAP SSCs.
- ❖ SER Section 6.2.5 concludes that the safety classification of the PAR is acceptable.
- ❖ The SGS and CRDS components are safety-related and subject to the requirements of the QAPD TR described in FSAR Section 17.5.
- ❖ The staff finds that the design and quality requirements...
 - ☐ for EDAS, the PAR, SGS, and the safety-related CRDS components meet the intent of the Commission policy stated in item E of SECY-95-132.
 - ☐ resulting from the classification of SSCs is consistent with the intent of guidance in SRP Section 17.4.

Presentation to the ACRS Subcommittee Staff Review of NuScale SDAA FSAR, Revision 1

Chapter 19, “Probabilistic Risk Assessment and Severe Accident Evaluation”

**February 18, 2025
(Open Session)**

NuScale SDAA FSAR Chapter 19 Review

Overview

- ❖ NuScale submitted Chapter 19, “Probabilistic Risk Assessment and Severe Accident Evaluation,” Revision 0 of the NuScale SDAA FSAR on December 31, 2022, and Revision 1 on October 31, 2023
- ❖ NRC regulatory audit of Chapter 19 was performed from March 2023 to August 2023, generating 173 audit issues
- ❖ Issues raised during the audit were resolved within the audit. 6 RAIs (15 Questions) were issued, and the responses were acceptable
- ❖ Staff completed Chapter 19 review and issued an advanced safety evaluation to support today's ACRS Subcommittee meeting
- ❖ Since providing draft SE to ACRS on 1/18/25, Table 19.1-4 was updated to include COL Item Nos. 19.1-7 and 19.1-8, which were inadvertently missed from the draft SE

NuScale SDAA FSAR Chapter 19 Review

Contributors

❖ Technical Reviewers

- Alissa Neuhausen, Branch Chief, NRR/DRA/APLC
- Marie Pohida, NRR/DRA/APLC
- Sunwoo Park, NRR/DRA/APLC
- Keith Tetter, NRR/DRA/APLC
- Michael Swim, NRR/DRA/APLC
- Anne-Marie Grady, NRR/DRA/APLC
- Steven Alferink, NRR/DRA/APLC
- George Wang, NRR/DEX/ESEB
- Thinh Dinh, NRR/DRA/APLB
- Ryan Nolan, NRR/DSS/SNRB

❖ Project Managers

- Alina Schiller, PM, NRR/DNRL/NRLB
- Getachew Tesfaye, Lead PM, NRR/DNRL/NRLB

NuScale SDAA FSAR Chapter 19 Review

Sections

- ❖ 19.1 Probabilistic Risk Assessment
- ❖ 19.2 Severe Accident Evaluation
- ❖ 19.3 Regulatory Treatment of Nonsafety Systems
- ❖ 19.4 Strategies and Guidance to Address Mitigation of Beyond-Design-Basis Events
- ❖ 19.5 Adequacy of Design Features and Functional Capabilities Identified and Described for Withstanding Aircraft Impacts

NuScale SDAA FSAR Chapter 19 Review

Significant Changes to Risk Profile Between DCA and SDAA

- ❖ Core Damage Frequency (CDF)
 - ☐ CDF increased due to more frequent actuation of ECCS valves.
 - ☐ Dominant contributors to CDF include high winds, module drop, external floods, internal events, and internal fires.
- ❖ Large Release Frequency (LRF)
 - ☐ LRF decreased due to earlier actuations of ECCS valves.
 - ☐ Contribution to LRF from breaks outside containment decreased.
 - ☐ Addition of digital reactor building crane control system minimizes operator error.

NuScale SDAA FSAR Chapter 19 Review

Focus Areas for PRA and SA Review

- ❖ Impact of changed ECCS actuation setpoints
- ❖ Augmented DC power system (EDAS) modeling
- ❖ CVCS line breaks outside containment
- ❖ Unisolable CVCS breaks outside containment
- ❖ Density wave oscillation (DWO) impact on Steam Generator Tube Failure (SGTF)
- ❖ Addition of reactor building crane (RBC) digital control system
- ❖ Top Support Structure (TSS) connection to RBC
- ❖ Addition of passive autocatalytic recombiner (PAR)

NuScale SDAA FSAR Chapter 19 Review

Impact of ECCS Actuation Changes on CDF and LRF

- ❖ Approximately 90 percent of core damage scenarios involve incomplete ECCS actuation.
- ❖ Low RCS level (top of the riser) and Low Low RCS level (mid-riser) result in earlier ECCS actuation.
- ❖ 8-hour ECCS timer added; Operator action to bypass timer after checking shutdown margin and hydrogen concentration found not to be a significant human action.

NuScale SDAA FSAR Chapter 19 Review

EDAS Modeling in PRA

ECCS reactor vent valves held closed by EDAS

- ❖ Not identified as risk significant from PRA importance measures.
- ❖ Single failure proof system.
- ❖ Physical separation between divisions.
- ❖ Failure of two channels of module-specific EDAS results in reactor trip and ECCS actuation.
 - ☐ CCFs not modeled between electrical buses in separate compartments
 - ☐ Data for EDAS CCF modeled in PRA is derived from operating plant data where DC power is safety-related
- ❖ FSAR states that EDAS will be included in the Owner Controlled Requirements Manual (OCRM) and the Maintenance Rule.

NuScale SDAA FSAR Chapter 19 Review

CVCS line breaks outside containment

- ❖ Flow restricting venturis in injection and discharge lines control inventory loss and reduce LRF from CVCS line breaks outside of containment.
- ❖ If at least one train of the DHRS is available and all ECCS valves are open, PRA success criteria are met.
 - ❑ Pumped injection via CFDS and CVCS is not needed for scenarios where all ECCS valves open in contrast to the DCA.

NuScale SDAA FSAR Chapter 19 Review

Unisolable CVCS breaks outside containment

- ❖ The likelihood of weld failures at the junction between the containment vessel and the CVCS containment isolation valves are not modeled in the PRA.
- ❖ The plant behavior and consequences of an unisolable CVCS LOCA outside of containment are modeled through the CVCS break downstream of containment isolation with failure of containment isolation.
- ❖ The low weld failure frequency is identified as a key source of Level 2 uncertainty.
- ❖ The impact on LRF is minimized by leak detection and operator response.

NuScale SDAA FSAR Chapter 19 Review

DWO Impact on SGTF Initiating Event and PRA Results

- ❖ PRA did not explicitly model impact of DWO on SGTF.
- ❖ Staff considered worst-case hypothetical impacts of DWO on PRA results.
 - ❑ Multiple SGTF
 - ❑ Loss of both trains of DHRS
- ❖ NuScale sensitivity analyses demonstrate that the PRA results and insights are insensitive to the SGTF initiating event frequency and a loss of both trains of DHRS.

NuScale SDAA FSAR Chapter 19 Review

RBC Control System Reduces Module Drop Contribution

- ❖ The RBC digital control system significantly decreases the contribution of operator errors of commission.
- ❖ Dominant contributors to module drop are redundant load path failures (i.e., catastrophic gear box and wire rope failures)
- ❖ The RBC digital control system is classified as non-safety related, risk significant, and SIL3.

NuScale SDAA FSAR Chapter 19 Review

TSS Connection to Module Crane

- ❖ If a dropped module strikes an operating module, piping, including pressurizer spray piping and DHRS piping, at the front of the NPM has the potential to be impacted.
- ❖ The safety-related CVCS CIVs location under the TSS protects these CIVs from postulated dropped NPM impacts.
 - ❑ The TSS is classified as non-safety related and risk significant in FSAR Table 17.4-1.
- ❖ If the CIVs close but both trains of DHRS are unavailable, if one RSV successfully cycles open and closed, as needed, the RCS depressurizes, and the ECCS is demanded.
- ❖ If the RSVs fail to open, ECCS functioning remains a success path.

NuScale SDAA FSAR Chapter 19 Review

Addition of PAR

- ❖ A single safety-related passive autocatalytic recombiner (PAR) was added to the design.
- ❖ The PAR is not modeled in the PRA.
- ❖ Equipment survivability dose for PAR:
 - ☐ Post severe accident, the two functions that must be maintained are containment integrity and post-accident monitoring.
 - ☐ The PAR has been added to Table 19.2-8, “Equipment Survivability List.”
 - ☐ A new COL Item 19.2-4 states that the COL applicant will identify from Table 19.2-8, “Equipment Survivability List,” the components and their severe accident doses for cases in which the severe accident dose is greater than the EQ dose, as described in COL Item 19.2-4

NuScale SDAA FSAR Chapter 19 Review

Conclusion

- ❖ Staff reviewed the NuScale US460 design-specific PRA and other PRA-related information in FSAR Section 19.1, in accordance with:
 - ❑ SRP Section 19.0.
 - ❑ DC/COL-ISG-028 for applicable modes and hazards
- ❖ The applicant addressed the full scope of internal and external initiating events for both full power and LPSD conditions.
- ❖ The applicant developed quantitative risk insights for multi-module internal events and qualitative risk insights for multi-module shutdown and external events.
- ❖ The PRA is of sufficient technical adequacy to support the SDA.
- ❖ The staff's review concludes that the Commission's CDF and LRF goals have been met with margin.

NuScale SDAA FSAR Chapter 19 Review

Conclusion

H₂ Combustion in the CNV

- ❖ The DCA addressed a potential combustion event in the CNV analytically and demonstrated that the CNV design pressure was not exceeded.
- ❖ SDAA added a PAR which precludes combustion events from occurring during DBAs and SAs.

Containment Performance (no combustion)

- ❖ SDAA Table 19.2-1, "Core Damage Simulations for SA Evaluation", identifies the spectrum of severe accidents that may challenge CNV integrity.
- ❖ SDAA Tables 19.2-2 – 19.2-7 document that CNV design pressures, including H₂ generated, are not exceeded.

Conclusion

The applicant addressed severe accidents consistent with Commission policy.

SDAA design for containment performance meets:

- ❖ the containment structural integrity criteria of RG 1.7, rev 3, "Control of Combustible Gas Concentrations in Containment."
- ❖ the containment leak tight criteria of SECY-93-087.

NuScale SDAA FSAR Chapter 19 Review

BDG Evaluation for RTNSS

- ❖ BDGs not scoped into RTNSS
 - 1) Do not prevent the occurrence of an initiating event
 - 2) Not needed for long-term, post-accident plant capabilities
 - 3) Not needed to support defense-in-depth systems
- ❖ All components of the backup power supply system, including the BDG enclosures, are seismic Category III.
- ❖ The BDG enclosure is rated for wind speeds in excess of the weather-related events considered in the LOOP initiating event.

Criterion C: SSC functions relied to meet the Commission goals for $CDF < 1 \times 10^{-4}/\text{yr}$ and $LRF < 1 \times 10^{-6} / \text{yr}$ and SSCs needed to maintain initiating event frequencies at the comprehensive baseline PRA levels (SECY-94-084)

NuScale SDAA FSAR Chapter 19 Review

Conclusion

- ❖ Staff has reviewed the NuScale US460 evaluation of RTNSS SSCs in FSAR Section 19.3, in accordance with:
 - ❑ SRP Section 19.3.
- ❖ NuScale did not identify any SSCs in the scope of RTNSS.
- ❖ Staff finds that no SSCs meet the criteria for requiring additional regulatory treatment.

NuScale SDAA FSAR Chapter 19 Review

Aircraft Impact Analysis

Adequacy of Design Features and Functional Capabilities Identified and Described for Withstanding Aircraft Impacts: Structural

- ❖ Steel-Plate Composite Walls (only applicable to SDAA)
 - ☐ Both global and local assessment use experimental data to benchmark the methodology and results
 - ☐ Followed NEI 07-13, Revision 8 with no exceptions
- ❖ Additional key design features (only applicable to SDAA)
 - ☐ Strengthen SC wall to RC slab connections
 - ☐ Local detailing with tie rods in SC wall-to-wall connection
 - ☐ Structural steel beam seat connections along RX-B and RX-D
- ❖ Credit RWB as Intervening Structure to limit potential strike locations to the west end of the RXB (only applicable to DCA)

Integrated Review Approach – Communication Tool

TOPIC – 5 Principles of Risk Informed Decisionmaking	
Principle 1: Meets current regulations or exemption requested	<ul style="list-style-type: none">Yellow indicates applicant/licensee has provided some information on the topic. Staff still needs information, but there's a clear path forward.
Principle 2: Consistent with the defense-in-depth philosophy	<ul style="list-style-type: none">Green indicates that all reviewers agree that applicant/licensee has provided sufficient information.E.g., backup systems that are available to mitigate the event
Principle 3: Maintains sufficient safety margins	<ul style="list-style-type: none">Red indicates that there is broad agreement that applicant/licensee did not provide information to make a regulatory finding. There is no clear path forward.
Principle 4: Increase in risk is small and consistent with the intent of the Commission's Safety Goal Policy Statement	<ul style="list-style-type: none">Integrated review team is established among technical review branches and risk analysts to align on a decision considering all 5 principles of RIDM.
Principle 5: Performance measurement strategies available for monitoring	

Acronyms

BDG	Backup Diesel Generator	LOOP	Loss of Offsite Power
CCF	Common Cause Failure	LRF	Large Release Frequency
CDF	Core Damage Frequency	NPM	Nuclear Power Module
CFDS	Containment Flood and Drain System	OCRM	Owner Controlled Requirements Manual
CIV	Containment Isolation Valve	PAR	Passive Autocatalytic Recombiner
COL	Combined License	PRA	Probabilistic Risk Assessment
CVCS	Chemical and Volume Control System	RBC	Reactor Building Crane
DCA	Design Certification Application	RCS	Reactor Coolant System
DHRS	Decay Heat Removal System	RSV	Reactor Safety Valve
DWO	Density Wave Oscillations	RTNSS	Regulatory Treatment for Non-Safety-Systems
ECCS	Emergency Core Cooling System	SBO	Station Blackout
EDAS	Augmented DC Power System	SDAA	Standard Design Approval Application
EQ	Equipment Qualification	SGTF	Steam Generator Tube Failure
FSAR	Final Safety Analysis Report	SRP	Standard Review Plan
LOCA	Loss of Coolant Accident	TSS	Top Support Structure

Meeting Title**Open Session NuScale Subcommittee on
Staff's Evaluation of NuScale SDAA
Chapters 6 and 19 and Section 17.4****Attendee**

Michael Snodderly	ACRS (DFO)
Getachew Tesfaye	NRR
Shandeth Walton	ACRS
Larry Burkhart	ACRS
Thomas Dashiell	ACRS
Wendy Reid	NuScale
Matt Sunseri	ACRS
Augi Cardillo	NuScale
Brian Kanen	NuScale
James Cordes	Court Reporter
David Nold	NRR
Milton Valentin	NRR
Robert Martin	ACRS
River Rohrman	NRR
Meghan McCloskey	NuScale
Steven Bloom	NRR
Ron Ballinger	ACRS
Steven Wolbert	NuScale
Kris Nerczuk	NuScale
Brandon Haley	NuScale
Cindy Williams	NuScale
Amanda Bode	NuScale
Alina Schiller	NRR
Stephen Schultz	ACRS
Erin Whiting	NuScale
Scott Palmtag	ACRS
Kevin Lynn	NuScale
Rob Meyer	NuScale
Elisa Fairbanks	NuScale
PJ Evans	NuScale
Joe Remic	NuScale
Taylor Coddington	NuScale
Melissa Bates	
Dennis Bley	ACRS
Carlen Donahue	NuScale
Walt Kirchner	ACRS
Ryan Miller	NuScale
Chulmin Kim	
Ellery Coffman	
Colin Sexton	
Gregory Halnon	ACRS
Sunwoo Park	NRR
Vesna B Dimitrijevic	ACRS

Etienne Mullin	NuScale
Tim Polich	
Sangeet Gupta	NuScale
Marissa Bailey	ACRS
Brian Lee	NRR
Peter Shaw	NuScale
Casey Emler	NRR
Eric Baker	NuScale
Dan Lassiter	NuScale
Reem Nayal	NuScale
Caty Nolan	Comm
Rose Charoensombud	NuScale
Larry Hu	NuScale
Bradley Drake	NuScale
Alissa Neuhausen	NRR
Freeda Ahmed	NuScale
Ben Bristol	NuScale
Stacey Rosenberg	NRR
Thinh Dinh	NRR
Tammy Skov	ACRS
p vock	
Matthew Mitchell	NRR
Gene Eckholt	NuScale
Stacy Joseph	NRR
Edwin Lyman	UCS
Sandra Walker	ACRS
Stephanie Garland	ACRS
Sarah Turmero	NuScale
Angelo Stubbs	NRR
Mahmoud -MJ- Jardaneh	NRR