

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 NuScale Design Centered Review
 Open Session

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, March 4, 2025

Work Order No.: NRC-0240

Pages 1-102

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 NUSCALE DESIGN-CENTERED REVIEW SUBCOMMITTEE

8 (OPEN)

9 + + + + +

10 TUESDAY

11 MARCH 4, 2025

12 + + + + +

13 The Subcommittee met via Video
14 Teleconference, at 9:30 a.m. EST, Walter L. Kirchner,
15 Chair, presiding.
16

17 SUBCOMMITTEE MEMBERS:

18 WALTER L. KIRCHNER, Chair

19 GREGORY H. HALNON, Vice Chair

20 DAVID A. PETTI, Member-at-Large

21 RONALD G. BALLINGER

22 VICKI M. BIER

23 VESNA B. DIMITRIJEVIC

24 CRAIG D. HARRINGTON

25 ROBERT P. MARTIN

1 SCOTT P. PALMTAG
2 THOMAS E. ROBERTS
3 MATTHEW W. SUNSERI

4
5 ACRS CONSULTANT:

6 DENNIS BLEY
7 STEVE SHULTZ

8
9 DESIGNATED FEDERAL OFFICIAL:

10 MICHAEL SNODDERLY

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

AGENDA

I	Opening remarks	4
II	Discussion of NuScale Non-Loss-of-Coolant-Accident Analysis Methodology Topical Report	9
III	Staff's Evaluation of NuScale Non-Loss-of-Coolant-Accident Analysis Methodology Topical Report	36
IV	Discussion of NuScale Extended Passive Cooling and Reactivity Control Methodology Topical Report	55
V	Staff's Evaluation of NuScale Extended Passive Cooling and Reactivity Control Methodology Topical Report	82
VI	Opportunity for Public Comment	102
	Adjourn	

P-R-O-C-E-E-D-I-N-G-S

9:30 a.m.

CHAIR KIRCHNER: Okay, the meeting will now come to order. Good morning. This is the meeting of the NuScale Design Centered Review Subcommittee of the Advisory Committee on Reactor Safeguards. I'm Walt Kirchner, Chairman of today's subcommittee meeting.

ACRS members in attendance in person are Ron Ballinger, Vicki Bier, Craig Harrington, Robert Martin, David Petti, Scott Palmtag and Thomas Roberts.

ACRS members in attendance virtually via Teams are Vesna Dimitrijevic, Greg Halnon and Matt Sunseri. We also have two of our consultants participating virtually via Teams, Dennis Bley and Steve Shultz. If I missed anyone, either ACRS members or consultants, please speak up now.

Michael Snodderly of the ACRS staff is the Designated Federal Officer for this meeting. No member of conflicts of interest were identified and I note that we have a quorum.

During today's meeting, the subcommittee will receive a briefing on the staff's evaluation of NuScale Topical Report TR051649416: Proprietary Non-Loss-of-Coolant Accident Analysis Methodology and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 TR124587: Extended Passive Cooling and Reactivity
2 Control Methodology.

3 We previously reviewed the certified
4 NuScale US600 design as documented in our July 29,
5 2020 letter report on the safety aspects of the
6 NuScale small modular reactor. Like the staff, we are
7 performing a delta review between the two designs
8 including a power uprate from 50 to 77 megawatts
9 electric per module. We are reviewing these chapters
10 and TRs as part of our statutory obligation under
11 Title 10 of the Code of Federal Regulations, Part 52,
12 Subpart E, Section 141, Referrals to the Advisory
13 Committee on Reactor Safeguards.

14 We report on those portions of the
15 application which concern safety. The ACRS was
16 established by statute and is governed by the Federal
17 Advisory Committee Act or FACA. The NRC implements
18 FACA in accordance with its regulations. Per these
19 regulations and the Committee's bylaws, the ACRS
20 speaks only through its published letter report. All
21 member comments therefore should be regarded as only
22 the individual opinion of that member not a Committee
23 position.

24 All relevant information related to ACRS
25 activities, such as letters, rules for meeting

1 participation and transcripts, are located on the NRC
2 public website and can easily be found by typing
3 "About us ACRS" in the search field on NRC's home
4 page.

5 The ACRS, consistent with the agency's
6 value of public transparency and regulation of nuclear
7 facilities, provides opportunity for public input and
8 comment during our proceedings. We have received no
9 written statements or requests to make an oral
10 statement from the public, but we have set aside time
11 at the end of the meeting for such public comments.

12 Portions of the meeting may be closed to
13 protect sensitive information as required by FACA and
14 the Government in the Sunshine Act. Attendance during
15 the closed portion of the meeting will be limited to
16 the NRC staff and its consultants. Applicants and
17 those individuals in organizations who have entered
18 into an appropriate confidentiality agreement, we will
19 confirm that only eligible individuals are in the
20 closed portion of the meeting later this afternoon.

21 The ACRS will gather information, analyze
22 relevant issues and facts and formally propose
23 conclusions and recommendation as appropriate for
24 deliberation by the full Committee. A transcript of
25 the meeting is being kept and will be posted on our

1 website. When addressing the Subcommittee, the
2 participants should first identify themselves and
3 speak with sufficient clarity and volume so that they
4 may be readily heard. If you are not speaking, please
5 mute your computer on Teams or by pressing *6 if
6 you're on your phone.

7 Please do not use the Teams chat feature
8 to conduct sidebar discussions related to
9 presentations, rather limit the use of the meeting
10 chat function to report IT problems.

11 For everyone in the room, please put your
12 electronic devices in silent mode and mute your laptop
13 microphone and speakers. In addition, please keep
14 sidebar discussions in the room to a minimum because
15 our ceiling microphones are live.

16 For presenters, your table microphones are
17 unidirectional and you'll need to speak into the
18 microphone to be heard. Finally, if you have any
19 feedback for the ACRS about today's meeting, we
20 encourage you to fill out the public meeting feedback
21 form on the NRC's website. With that, we will now
22 proceed with the meeting and I will turn first to the
23 NRC staff and to M.J. for opening comments.

24 MR. JARDANEH: Thank you. Good morning,
25 Chair Kirchner and good morning to the ACRS

1 Subcommittee Members, NuScale participants, NRC staff
2 and members of the public.

3 My name is Mahmoud M.J. Jardaneh and I
4 serve as the Branch Chief of the New Reactor Licensing
5 Branch, responsible for the licensing of the NuScale
6 US460 design and the Division of New and Renewed
7 Licenses in NRR. Thank you for the opportunity today
8 for the staff to present their review of the select
9 NuScale US460 Standard Design Approval or SDA,
10 chapters and topical reports.

11 As you are aware, the staff is reviewing
12 all chapters of the SDA concurrently with staggered
13 completion dates based on the complexity of the
14 chapter and the extent of change from the certified
15 NuScale US600 design. Today, the staff will be
16 presenting on their review of the seventh group of the
17 SDA chapter and topical reports, including on the Non-
18 Loss-of-Coolant Analysis Methodology Topical Report
19 and the Extended Asset Cooling and Reactivity Control
20 Methodology Topical Report.

21 Previously, the staff presented to the
22 Subcommittee on 16 of the 19 SDA chapters and one of
23 three SDA Topical Reports. The staff is finalizing
24 their review of the remaining three SDA chapters and
25 we will soon share their safety evaluations with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 ACRS.

2 At today's meeting, the staff will focus
3 on the deltas from the design certifications that the
4 NRC approved and the Committee reviewed in the past.
5 The staff will also discuss two remaining open items,
6 one in each of the topical reports to be presented
7 today.

8 Once again, thank you for the opportunity
9 and we look forward to a good discussion. Thank you.

10 CHAIR KIRCHNER: Thank you, M.J. Now, we
11 will turn to NuScale. I believe, Kevin, are you going
12 to kick it off for NuScale?

13 MR. LYNN: Sure, I can do that. Thank
14 you. Good morning, members of the ACRS, NRC staff and
15 thank you for having us here. We appreciate the
16 opportunity.

17 My name is Kevin Lynn. I'm a licensing
18 engineer at NuScale and I've been with NuScale for
19 over three years. Prior to my time at NuScale, I was
20 working in the Nuclear Navy. I also worked in Part 52
21 New Design, New Reactor Design with a different design
22 center and also spent time in an operating plant
23 reactor and also on license renewal for operating
24 plants. I'll allow my colleagues here to introduce
25 themselves as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. BRISTOL: Good morning, this is Ben
2 Bristol. I'm the manager of the system thermal
3 hydraulics team at NuScale. I've been with NuScale
4 for 13 years now.

5 MS. MCCLOSKEY: Good morning, my name is
6 Meghan McCloskey. I'm a safety analysis engineer with
7 NuScale and I've been with them for about the past 10
8 years and prior to that, I was with Westinghouse,
9 always focused on safety analysis methodology
10 development and application for design basis events.

11 CHAIR KIRCHNER: Thank you all for being
12 here in person. Go ahead.

13 MR. LYNN: Next slide, please. Before we
14 begin, we'd like to acknowledge that our work at
15 NuScale has been supported by the Department of Energy
16 and so we appreciate their support, but also
17 acknowledge that the views expressed during these
18 presentations are not necessarily those of the DOE.
19 Next slide, please.

20 During the open session for non-LOCA
21 topical report, we will start by talking about the
22 history of the non-LOCA topical report, talk about the
23 non-LOCA evaluation model, what the purpose is and the
24 acceptance criteria that's used to analyze. We'll
25 talk about the relevant power uprate and the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 and operating changes that have the potential to
2 affect the non-LOCA topical report and finish with a
3 summary of the evaluation model applicability
4 assessment and any changes that we've made since the
5 prior revision. Next slide, please.

6 As was alluded by the ACRS, the non-LOCA
7 topical report was previously reviewed by the staff
8 and the ACRS. It was approved by the NRC in 2020 and
9 that approved revision, which was revision three, was
10 used to support safety analyses performed for the
11 US600 design, which utilized the NPM-160 module. That
12 was submitted as part of the review of that.

13 That revision contains certain limitations
14 and conditions which restricted its use to the NMP-160
15 design, so when we began the work on our next design,
16 we realized that we would need to make some
17 modifications to that and so therefore, revision four
18 was submitted in January 2023 and it was submitted at
19 the same time as we submitted our FSAR for the US460
20 design, which utilizes the NMP-20 module.

21 Since the time of the submittal in January
22 2023, we have made some updates and changes to the
23 topical report in response to NRC questions and back
24 and forth with the NRC staff. Revision five will be
25 submitted at some point, which will incorporate all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 those updates, but it has not been submitted at this
2 time. The hope would be that then revision five would
3 become the Dash A approved version for future use. As
4 indicated by the ACRS, due to the nature of the delta
5 review, our focus of the discussion today is on the
6 changes since the NRC's prior approval in revision
7 three. Next slide.

8 This slide provides an overview of the
9 non-LOCA topical report and methodology and how it
10 fits in with other methodology that we utilize as part
11 of the safety analysis. On the left, we start with
12 certain input parameters related to the plant design,
13 core design, fuel design and the SSC design and those
14 all provide input to the NRELAP5 code, which is our
15 system thermal-hydraulic code. NRELAP5 is then used
16 to generate primary and secondary pressures that are
17 used to assess acceptance criteria and it's also used
18 to determine the exit of the safety analysis via
19 confirmation that we have a safe, stabilized
20 condition. All of that in that first box is the
21 subject of the non-LOCA topical report.

22 The NRELAP5 output is also used to provide
23 input to the VIPRE-01 code, which is used for our
24 subchannel analysis to determine acceptance criteria
25 for fuel. That's the subject of separate topical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reports for the subchannel which have both been
2 previously approved by the NRC. Lastly, there is the
3 potential that NRELAP5 is used to provide input to the
4 dose analysis in the form of mass and energy released
5 and that analysis is done separate from this, but is
6 also the subject of an approved top-four port.

7 DR. MARTIN: Question?

8 MR. LYNN: Yeah.

9 DR. MARTIN: It's Member Martin. The
10 NRELAP5 we, of course, have had other meetings and
11 talked about NRELAP5 or the specific application non-
12 LOCA. Are there any different packages that are used
13 and so we set that up a little bit more. Some
14 applicants will use the same code but then they are in
15 the process of personalizing it. They'll have an
16 input that says this is for this specific application
17 and then for others, what it does it just creates a
18 different flow through the architecture of the code.
19 For instance, one applicant does both Ps and Bs and
20 they'll have a P or a B in one of the cards up front
21 and it will use a different constituent package.

22 Do you have anything like that in your
23 code?

24 MS. MCCLOSKEY: No.

25 DR. MARTIN: Okay.

1 MS. MCCLOSKEY: No, we just have the
2 normal, you know, the user options for things like
3 choke flow and --

4 DR. MARTIN: Sure, sure, nothing that
5 you've added specifically that changes the course of
6 events as a consequence of say a different view of the
7 events that you're studying.

8 MS. MCCLOSKEY: No. Nothing like that
9 that fundamentally changes the models or the
10 structures.

11 DR. MARTIN: Right. We've also talked
12 about in the previous meetings that you have changed
13 a version or you've upgraded your version, your 1.7,
14 I believe it's still an open item and I'm sure you're
15 rapidly trying to close, but could you just to the
16 extent that's reasonable in an open meeting like this,
17 just kind of talk about from your perspective what
18 remains to be done to close out any questions related
19 to NRELAP5. Maybe it's just administrative at this
20 point, but --

21 MR. LYNN: So, the only open item at this
22 point is related to a question related to the
23 particular base model that's in use. We have the
24 version, I think we're pretty squared away on the
25 NRELAP version we're using, but as part of that, we

1 have a base model that's used essentially as a
2 starting point for all the event-specific analyses and
3 we made some updates to that base model. The staff is
4 still reviewing those updates as a delta compared to
5 the previous base model that we used prior to that
6 point. There's been some questions about that but
7 we're rapidly reaching convergence on that.

8 DR. MARTIN: Oh, so prior to that point
9 are you referring to five years ago or six years ago?

10 MR. LYNN: No, so actually when we
11 submitted in January 2023, we were using a specific
12 version of the NRELAP code 1.6 and the specific
13 version of the base model and since that time, during
14 the course of the review, we made changes both the
15 NRELAP version and to the base model.

16 DR. MARTIN: Okay.

17 MR. LYNN: And so the staff started their
18 review and reviewed the delta essentially from the
19 version we submitted in January 2023 prior to what
20 they approved before and now they are reviewing the
21 delta between what we submitted in January 2023 to the
22 changes that we made during the course of the review.

23 DR. MARTIN: Okay. Are you saying maybe
24 more focus is on really the model and not so much the
25 code?

1 MR. LYNN: Correct.

2 (Simultaneous speaking.)

3 DR. MARTIN: Right, so --

4 MR. LYNN: And at this point --

5 DR. MARTIN: Nodalization and some code?

6 MS. MCCLOSKEY: It's not nodalization,
7 it's more on factors of how we've modeled things, like
8 the feedwater pump response, during non-LOCA events.
9 We've modeled that more realistically now.

10 DR. MARTIN: Okay. Okay.

11 MR. LYNN: Yeah, there was an initial
12 condition focused --

13 (Simultaneous speaking.)

14 DR. MARTIN: It's state of the art.

15 MR. LYNN: Some changes to the DHRS, our
16 decay heat removal system, modeling to make it a
17 little bit more realistic. Previously, we'd neglected
18 some portions of the system conservatively. We added
19 those to be more realistic and that was the change
20 then that the staff wanted to --

21 (Simultaneous speaking.)

22 DR. MARTIN: When you say realistic, are
23 you implying that -- and maybe I'm reading too much
24 into it, maybe from testing?

25 MR. LYNN: No, so just component wise.

1 For example, the DHRS is --

2 COURT REPORTER: Excuse me, sorry to
3 interrupt. I'd just like to remind folks to state
4 their name before speaking. I'm having a bit of
5 difficulty determining who is speaking since there is
6 no video feed and everyone is in one room.

7 MR. LYNN: Okay, this is Kevin Lynn. You
8 threw me off. The DHRS receives steam from the steam
9 system and that piping to the DHRS, is a heat
10 exchanger essentially, that piping that carries steam
11 runs and goes through the heart of the refueling coil
12 or the UHS and so there's some condensation that
13 happens as that piping goes through the water before
14 it gets to the heat exchanger.

15 So, on one hand you could conservatively
16 ignore that, but it is actual heat transfer that's
17 occurring, so we've modeled some of those features.

18 DR. MARTIN: Okay.

19 CHAIR KIRCHNER: Maybe you've talked about
20 it before. You're taking credit now and before you
21 hadn't.

22 MR. LYNN: Okay.

23 DR. MARTIN: I remember that conversation
24 previously. All right, thanks. That's all.

25 MR. LYNN: So, to finish this slide just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 to point out that this general picture here and this
2 general scope is consistent with what we had when we
3 were here for prior approval of revision three. Next
4 slide, please.

5 So, now I'll talk about the power uprate
6 and the design changes from the NMP-160 to the NMP-20.
7 The biggest change was an uprate from 160 megawatts
8 hence the name to 250 megawatts thermal, which is our
9 current design, approximately 70-some megawatts
10 electric which was referenced by the ACRS in the
11 opening.

12 For the most part in terms of non-LOCA,
13 the module SSC design is essentially maintained.
14 There were some changes to the operating conditions,
15 so the normal primary pressure, normal operating
16 pressure increased from 1,850 to 2,000 PSI and along
17 with that, we increased the design pressure of the
18 primary side from 2,100 to 2,200 and the secondary
19 side has the same design pressure.

20 With the increase in power, we have a
21 larger delta T across the core because we're natural
22 circulation, but we use a constant T(avg) control and
23 that T(avg) was changed slightly from approximately
24 545 to 540. There was also a reduction in secondary
25 side feedwater temperature and a reduction in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 minimum temperature for criticality during startup.

2 There were some optimizations made to our
3 module protection system for the US460 design. Some
4 of the set points were adjusted to match the changes
5 that we made to the operating conditions. For
6 example, when we increased the pressure, we had to
7 increase the pressure for the trip rated to pressure.

8 There was also a new trip added on high
9 T(avg) and that was added specifically to terminate
10 some of our slower reactivity transients earlier, like
11 a rod withdrawal happening from maybe 75 percent power
12 wasn't hitting the high temperature and high power set
13 points, but the high T(avg) could reach that earlier
14 and cause a trip.

15 Finally, we added some additional DHRS
16 actuations and an isolation of the pressurizer line on
17 low pressurizer pressure. The one thing you won't see
18 on here is some of the discussion of the changes to
19 the ECCS. Those are more pertinent to the LOCA
20 discussion which was held previously, so we're not
21 covering those because they don't come into play in
22 non-LOCA.

23 There was also a change to add an ECCS
24 supplemental boron system. That's not relevant per se
25 to the non-LOCA but it will come up later today when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 we talk about the XPC topical report. Next slide,
2 please.

3 MR. ROBERTS: This is Tom Roberts. Just
4 out of curiosity, why did you pick high T(avg) instead
5 of high T(hot)?

6 MR. LYNN: This is Kevin. We had an
7 existing high T(hot) trip and in this particular case
8 for these particular transients, they weren't reaching
9 the high T(hot) trip as fast as we would like to
10 mitigate them, so in this particular case, they reach
11 high T(avg) sooner than they reach high T(hot), but
12 the high T(hot) is still active.

13 MR. ROBERTS: Okay, thank you.

14 MR. LYNN: Next slide, please. This slide
15 shows a comparison of the US460 to the US600. On the
16 left is the US600 which is our certified design and on
17 the right is US460. This kind of demonstrates the
18 changes that we made to some of the operating
19 conditions. For example, the red line at the top of
20 the box is moved upward because we have that higher
21 operating design pressure and the blue line, which is
22 the normal operating pressure, is moved up as well.

23 You can see the box that we would like to
24 operate in, in which case our safety analysis starts
25 from, is the box with the dotted black lines with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 T(avg) green right in the middle. The size of that
2 box is essentially unchanged between the two designs.
3 Next slide.

4 CHAIR KIRCHNER: Kevin, since you showed
5 it, could I just ask would you just explain you now
6 have a lower acceptable temperature for going
7 critical, what's the design basis behind that?

8 MR. LYNN: So, that's to allow startup
9 sooner essentially. To reach a startup condition, we
10 have to heat up the plant. So, we have a module heat
11 up system which adds heat, non-nuclear heat, into the
12 system and in the previous design it was a 420, so you
13 had to do quite a bit of heat up of non-nuclear heat
14 and this change allows us to essentially go critical
15 earlier and heat up the rest of the way with nuclear
16 heat.

17 CHAIR KIRCHNER: Thank you.

18 MR. LYNN: It was essentially an
19 improvement in terms of start up of plant. Next
20 slide.

21 We'll talk about the analytical
22 assumptions used in the non-LOCA analysis. The
23 general approach from the previous revision is
24 maintained. In terms of the scope of the event, we
25 analyzed the design basis events from an event

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 initiation until a safe, stable condition is reached.
2 There's kind of two ways that we can reach a safe,
3 stable condition. One is reactor trip and DHRS
4 operation. We have trends that show the temperature
5 is decreasing and pressure is decreasing, so we're on
6 a safe trajectory.

7 The other is potentially there are some
8 events where a reactor trip doesn't occur, a minor
9 decrease in feedwater temperature, a minor decrease in
10 feedwater flow we can essentially reach a new steady
11 state condition. So, that's the end of the event in
12 terms of the scope of the event progression.
13 Obviously, in terms of plant operation, the operators
14 would at some point need to restore themselves back to
15 where they want to be operating, but in terms of
16 operator action, there are no operator actions
17 credited during 72 hours after initiate event occurs
18 to achieve the safety functions.

19 We do look at different loss of power
20 scenarios, power available, loss of AC power, loss of
21 DC power to see what's more limiting for a particular
22 set of events.

23 We do have non-safety related control
24 systems and those do factor into the non-LOCA
25 analysis, specifically if we have a case where the

1 normal operation of that control system would tend to
2 make the plant transient less severe, then we neglect
3 or ignore that operation. On the other hand, if we
4 have a normal operating control system that would tend
5 to make the plant more severe, we do then assume that
6 that occurs. So, for an example, in the case of a
7 heat up event or a pressurization event, where
8 pressure is increasing, the normal response of the
9 pressure control system would be to actuate or to turn
10 on spray or increase spray to turn that event around.
11 So, if we credit spray, then it makes the event less
12 limiting, so in those particular cases, we neglect
13 spray which allows the pressurization to continue and
14 eventually reach a trip set point.

15 DR. MARTIN: This is Member Martin. To
16 this question of the role of non-safety systems, when
17 you consider with non-LOCA in particular maybe several
18 figures of merit to look at. Some are going to
19 respond conservatively and some will be non-
20 conservative. It really requires a thorough look at
21 these things and not just say attention on maybe the
22 figure of merit with maybe the least amount of margin,
23 right? Because, you know, maybe that one is
24 unaffected or benefits from the role of the non-safety
25 control system, but maybe something else affects the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 other metrics. Now, obviously you've been working on
2 this for a really long time and I can only imagine how
3 much analysis you've done.

4 Can you talk a little bit about your
5 approach and this investigation? Is it just kind of
6 brute force, where you kind of evaluated, of course,
7 we kind of know the events, you're more or less a
8 NUREG-0800 you have your own DHRS and all that. But
9 is there a separate kelp file where you just attack
10 this question head-on and identified the events, maybe
11 even a higher level document that, you know, say like
12 a hazards analysis type thing, but one that identifies
13 maybe scenarios from a qualitative standpoint and then
14 those unfortunately seem to matter the most and we go
15 out and determine -- anyway, I'm obviously putting
16 words in your mouth to some extent. Can you briefly
17 go over that about your approach to this sort of thing
18 and how is captured in your QA system or your document
19 control system?

20 MR. LYNN: This is Kevin. One thing that
21 we do is we do, as you mentioned, we do have
22 experience now using this as this is our second
23 design. So, for the experience we had from the US600,
24 we've leveraged that in terms of generally knowing
25 what transients go where and what types of cases that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 you need to look at, but certainly as part of the
2 design changes that we made, we looked at wanting to
3 confirm that those behaviors were still true and also
4 see if there were any differences. But for any
5 particular initiating event, we identify first what
6 are the figures of merit for that event, which are
7 most susceptible to that event. For a heat up event,
8 we're not really concerned as much about the fuel
9 response, it's more the pressurization response.

10 For a cool down event, we're both
11 concerned with the fuel response and also potentially
12 the pressurization. In those cases, where there's
13 more than one acceptance criteria that may be
14 relevant, we're looking at different cases within that
15 analysis to potentially maximize or minimize that
16 particular acceptance criteria. One set of conditions
17 may be worse for the RCS pressure, but a different set
18 of conditions may be worse for minimum critical heat
19 flux, for example. So, within a particular event
20 analysis, there's probably on the order of 50
21 individual cases, NRELAP cases, that are run to
22 identify different sensitivities to those things.
23 Even that's potentially in the final documentation of
24 that analysis. In most cases, there is a preliminary
25 analysis that's done that looks at a wider range and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 then identifies that hey, this particular set isn't
2 really that important. We can focus in and go to a
3 finer granularity on a particular area of this
4 analysis domain to try and find that limited case.

5 DR. MARTIN: Generally speaking, between
6 the US600 and 460, see any real differences coming out
7 of the design, you know, relatively few design
8 changes? Did you see the trends more or less
9 consistent between the two designs? Any surprises?

10 MR. LYNN: For the most part, things were
11 consistent and I think in our early days, we had some
12 slides in our pre-application meeting comparing the
13 transient progression to show that they were quite
14 similar. One thing that does come to mind is that in
15 terms of the CHF performance, there was a particular
16 nuance of the previous design just the operating
17 domain that we were in that it was sensitive in one
18 direction of biased pressure.

19 So, I believe a high bias pressure was
20 potentially more limiting for CHF which was a little
21 bit counterintuitive. When we changed our design
22 pressure and increased it, it's one of the changes we
23 made, that particular sensitivity disappeared. As
24 part of that, we've changed our biases to look at both
25 high and low pressure to find which one is more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 limiting. That was one change that we did identify
2 and the staff asked a question about that and so we
3 made some changes to the top recorded response.

4 DR. MARTIN: Thank you.

5 MR. LYNN: Next slide, please.

6 MR. ROBERTS: Yeah, Kevin.

7 MR. LYNN: Yes?

8 MR. ROBERTS: Stop there for a minute,
9 this is Tom Roberts. That last line, the credit for
10 non-safety valves. Where it says related valves
11 failed to trip. Can you explain that a little bit
12 more? It seems like that essentially says single
13 pairs don't happen because there's a back up valve
14 that predominantly actuates.

15 MR. LYNN: Yes, so for the main steam
16 isolation valves, there's two valves the safety-
17 related valve and the non-safety-related valve. In
18 the event of a single failure of either valve, there's
19 no consequence because the other valve is there to
20 provide that protection. The only noteworthy thing
21 here is instead of two safety-related valves, you have
22 a non-safety and a safety. As part of the review, we
23 did have some questions about that and to demonstrate
24 that it was acceptable to have the second valve be a
25 non-safety-related valve. In terms of their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 performance, the steam isolation valves are the same.
2 They have the same isolation time and everything. On
3 the feedwater side, the back up, the non-safety-
4 related valve, has a slightly slower closing time. In
5 our analyses where we take a single failure, there is
6 a delta there a little bit of additional flow that can
7 happen in that time delta between the two valves, but
8 we do factor that into our analysis.

9 MR. ROBERTS: So, what makes a back up
10 valve non-safety? What compromises are made in the
11 quality or something else to not call them safety-
12 related? It sounds like we should just say they're
13 essentially the same valves.

14 MR. LYNN: They are essentially the same
15 valves. It's really just a QA designation of the
16 additional pedigree. I don't know if you have
17 anything to add, Meghan.

18 MS. MCCLOSKEY: The regulating valves are
19 going to be different than the isolation valves, but
20 they also have augmented quality requirements applied
21 to them.

22 MR. LYNN: And the non-safety-related
23 valves are also identified in tech specs and
24 controlled under tech specs and part of the in service
25 testing program, etc., so it's really just a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 designation.

2 MR. ROBERTS: Okay, yes, thanks. I guess
3 there was an analogy to the EDAS discussion we've had
4 a couple of meetings ago.

5 So, that kind of leads to my next
6 question, with is the single-failure assumptions.
7 That's not on this slide but it is in the topical
8 report.

9 And, there is a specific statement in the
10 topical report that a inadvertent trip of the ECCS
11 valves is not considered a single-failure.

12 We talked about that in a previous
13 meeting, and I'm just wondering if you've got any more
14 to add on that.

15 Because it seems like if you've got, say,
16 one of those trip valves out of service, and that's
17 allowed by tech specs that you be down to a single
18 trip valve.

19 And so a single-failure in the module
20 protective system, would that presumably trip the
21 remaining trip valve and cause the inadvertent
22 actuation.

23 And, it would seem like that would be a
24 passive electrical failure that you need to consider,
25 which is a, like a trip that's not required or not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 desired.

2 It seems to me that's a kind of definite
3 between pass and failure in an electrical system.

4 And so, I was wondering why you would not
5 include that as a single-failure, or why that would
6 not be rolled up in the single-failure exception that
7 you got previously on the IAB valves. It just seems
8 to me like the same thing.

9 MR. LYNN: So, one thing to point out here
10 is in particular for this topical report, it's a non-
11 LOCA topical report methodology.

12 And in our methodology, if we open an ECCS
13 valve, it's no longer a non-LOCA event. So, we don't
14 analyze events with valve openings, with ECCS valve
15 openings, using this methodology.

16 So from that perspective, the non-LOCA
17 topical report doesn't address valve opening.

18 But we have heard the concern though and
19 the question before, and we are prepared to discuss
20 that more in detail in the chapter 15 discussion at
21 the next meeting on April 1.

22 MR. ROBERTS: Okay, thank you.

23 MR. LYNN: So in terms of the non-LOCA
24 evaluation model, the focus is on the design changes
25 since our prior approval.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 In this particular case, those design
2 changes don't have a substantial impact on our event
3 progressions, or the important phenomena.

4 From a high/low perspective, primary
5 pressure is still protected by lifting of the RSVs if
6 necessary, during an event.

7 Secondary pressure is protected in two
8 ways. One, the design pressure is equal to the
9 primary pressure, which is unique for our design.

10 And also, the secondary pressure during an
11 event is limited to the saturation pressure at the
12 maximum T-hot at the primary side.

13 For minimum critical heat flux, we are
14 limited typically under a high-power or high-
15 temperature condition that might occur during an event
16 like a reactivity insertion event, like a rod
17 withdrawal.

18 As discussed earlier, we do employ NRELAP
19 version 1.7 now. Previously, we had used version 1.4
20 and as I mentioned at the start of the review, we used
21 version 1.6 but we're now currently on version 1.7.

22 We did perform a PIRT previously in the
23 previous revision, in revision 3. And, that PIRT was
24 based on the NPM-160 design.

25 We did a review and applicability

1 assessment, and determined that that PIRT remains
2 applicable, and there are no new phenomena that needed
3 to be added or addressed in this revision.

4 One significant change that we did make is
5 that we performed additional testing for the NRELAP,
6 the validation to specifically on the DHRS
7 performance.

8 And so, that new testing was added to the
9 assessment basis as part of the overall validation of
10 the code.

11 In terms of individual events specific
12 analyses methodology, one of the changes we made is to
13 add a little bit more detail on when we need to do
14 additional sensitivity calculations, with an emphasis
15 on the fact that if margin is low for a particular
16 event, more sensitivity is needed.

17 If you have a lot of margin, you don't
18 need as much sensitivity cases.

19 DR. MARTIN: Member Martin. Just to ask
20 a question about the PIRT.

21 What do you do confirm your PIRT? I would
22 imagine do a lot of sensitivity studies particularly,
23 or I mean how formal is that process when you made
24 your initial PIRT over 10 years ago, correct?

25 And then, subsequent to that do a bunch of

1 sensitivity studies or what? And then for this
2 design, did you just kind of repeat it all?

3 MS. MCCLOSKEY: For this design, we, so
4 for the, in terms of confirming the PIRT, originally
5 we focused on understanding where the high ranked
6 phenomena had been addressed.

7 Because the original PIRT that was done
8 was fairly comprehensive in nature, when we focused on
9 the system thermal hydraulic response.

10 So a number of our phenomena are actually
11 addressed in sub-channel analysis work.

12 So, recognizing where our methodologies
13 landed at the time for the DCA, was the first part of
14 that.

15 And then, building on the understanding of
16 the design response I'd say in terms of what was
17 important, was a factor in how we originally assessed
18 the PIRT.

19 And, we continued that process with the
20 upgraded design and did an applicability assessment
21 that compared the, compared the transient progressions
22 and what was driving our margins to acceptance
23 criteria between the designs, and how that related to
24 the PIRT phenomenon.

25 I think it, our PIRTs, our PIRT was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 initially very detailed I'd say, in terms of the
2 components and the phenomena.

3 And with the body of work that we've done
4 thus far, especially a non-LOCA space, our margins
5 really come down to fairly simple design limits, which
6 Kevin covered at the beginning of this slide.

7 DR. MARTIN: That sounds consistent with
8 my own experience. Generally, the PIRT committee will
9 find many more things they consider important, like --
10 subjectivity to it.

11 And then, when you get into it, you
12 realize yes, there's really a much smaller set but as
13 the consequence of having your PIRT team, your kind of
14 laden with their conclusions.

15 And, that you end up treating maybe things
16 that are not as important as, say, the first guess.

17 So, would you say then that's kind of
18 consistent with what you saw over the last decade?

19 MS. MCCLOSKEY: I think that's reasonably
20 consistent.

21 And the other thing that we've noticed is
22 that the original PIRT work that was done, tended to
23 define out like very, very specific phenomena that
24 particularly when it came to the steam generator and
25 the DHRS heat transfer, it's been more, it's been more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reasonable for us to treat those things as steam
2 generator heat transfer DHRS heat transfer versus
3 condensation inside.

4 And then, the convention or boiling on the
5 outside of the tubes and the DHRS kind of takes a look
6 at that system a little more holistically.

7 DR. MARTIN: Okay, thank you.

8 MR. LYNN: Again, in terms of methodology
9 changes for event specific analyses, in general we
10 expanded the scope of our analyses to vary parameters,
11 rather than bias in one direction.

12 I gave an example earlier related to
13 initial pressurizing pressure. So, that's one
14 particular example.

15 And then, the last three bullets there is
16 we've made some changes to allow options for certain
17 analyses.

18 So, for the radiological analyses,
19 previously we used direct output from the NRELAP
20 analysis as input for those.

21 But we've also added an option for a
22 potential to determine using alternate means to
23 terminate bounding input, so that we don't have to
24 directly translate and wait for that output from
25 NRELAP to use as input.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Similarly, for the control rod drop
2 analysis, we have the potential now, we've identified
3 a method where you can bound that analysis so that you
4 don't have to perform event-specific analysis.
5 Instead, you can bound it by the single rod
6 withdrawal.

7 And then finally for the born dilution
8 event, we have made some changes to allow for the
9 level increase that occurs during that born dilution
10 event, to be used to result in termination of the
11 event, and confirmation of shut down margin.

12 Overall, in terms of the open session our
13 conclusion is that the evaluation model for non-LOCA
14 remains adequate to evaluate an NPM design.

15 Next slide.

16 And, that concludes our open session
17 presentation.

18 CHAIR KIRCHNER: Thank you, Kevin.

19 Members, any questions at this point? I
20 assume you're all waiting for the closed session.

21 Okay, Mike. Do we go next to NRC staff or?

22 MR. SNODDERLY: Yes, please.

23 We had a break scheduled on 10:45, and I
24 think we should stick to that, or around that time.
25 But yes, let's let the staff get started.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 CHAIR KIRCHNER: Okay. All right, thank
2 you. So, for those listening in, just a brief pause
3 and we'll have the NRC staff present their evaluation.

4 MR. HAYDEN: Thanks. My name is Tommy
5 Hayden. I'm a project manager in the New Reactor
6 Licensing branch, in the Division of New and Renewed
7 Licenses, in the Office of NRR.

8 I am the PM for the topical report for
9 non-loss of coolant accident analysis methodology.

10 Contributors to the staff's review of this
11 topical report are Zhian Lee, Antonio Barrett, Adam
12 Rau, Peter Lien, Ryan Nolan, Sean Piela, Carl
13 Thurston, Dong Zheng, Joshua Miller, Rosie Sugrue,
14 Upendra Rohagti, Andrew Dyzel, and Marvin Smith.

15 As you'll see, those are from the Methods
16 branch in the Division of Safety Systems, or
17 contractors and consultants to that.

18 My apologies to my colleagues if I've
19 pronounced those horribly. I've done my best.

20 Here's one I can do. Tommy Hayden again.
21 I'm the project manager for this, and then Getachew
22 Tesfaye, is the lead for NuScale.

23 As an overview, NuScale submitted the non-
24 loss of coolant accident evaluation model topical
25 report, rev. 4, on January 5, 2023.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 The topical report was formally accepted
2 for review on July 31, 2023.

3 The NRC conducted an audit of the topical
4 report from March 2023 to August 31, 2024. Within
5 that audit, 49 audit issues were resolved.

6 And for those not resolved, seven RAIs
7 were generated. One RAI remains open. Kevin and
8 Member Martin discussed that a little bit, and I'll
9 have a slide here shortly.

10 There are two significant differences
11 between the draft SER submitted to ACRS on February 4,
12 2025, and the draft SER published on February 26,
13 2025, to support this meeting.

14 The open item as discussed previously,
15 relates to RAI non-LOCA.LTR 50. In that issue, staff
16 is working to understand changes made to the base
17 model.

18 Those modeling changes revolve around DHRS
19 models, and modeling of core flow distribution.

20 As Kevin alluded to the path forward here,
21 we are converging on an understanding and resolution
22 to this issue.

23 We continue to discuss the modeling
24 changes and have high confidence the issue will be
25 resolved shortly, with minimal impact to the SECI

1 evaluation.

2 As noted, the two significant, there were
3 two significant differences from the safety evaluation
4 that we submitted to ACRS early in February, and the
5 SER we submitted just this past week.

6 Those differences are as follows. In
7 section 3537, NIST-2 steam generator decay heat
8 removal system integral effects test.

9 The staff expanded their assessment of the
10 NIST-2 DHRS scalability. And that came as a result of
11 a closure of an open item, RAI non-LOCA LTR 3-9 18,
12 19, 20, 21, and 69.

13 And section 3-9, quality assurance, and
14 section 4-0, limitations and conditions. Again, as a
15 result of the closure of an open item, the removal of
16 the limitation in condition number 10.

17 And then the modification to relay a
18 finding in the 3-9 section of reasonable assurance
19 related to implementation of QA controls, consistent
20 with Reg Guide 1.203 for the non-LOCA --

21 I'll now pass it to Zhian for changes from
22 the LTR rev. 3 to rev. 4.

23 MR. LI: Thank you, Tommy, for the
24 introduction.

25 My name is Zhian Li and it's little bit

1 hard to pronounce, Zhian, but yes.

2 Good morning, Mr. Chairman, good morning
3 ECRS members, and good morning colleagues. I'm glad
4 to have this opportunity to present to the committee
5 about our review about the non-LOCA topical report.

6 I'm the team lead. I have a whole bunch
7 of a team -- their education and their support the
8 completion of this review, and I really appreciate you
9 -- see here.

10 The review, we focused on five areas.
11 Number one, the design change of the reactors from
12 NPM-162 to NPM-20.

13 The second, we reviewed the phenomena for
14 the identification and the ranking table. And then,
15 seeing quite a bit work on that.

16 So we try to find to whether there are any
17 design change, or the impact, the PIRT table again.

18 And the then third one is there change in
19 the methodology, the evaluation methodology for non-
20 LOCA events.

21 As the NuScale has spoke on that -- go
22 ahead, do you have a question or no?

23 DR. MARTIN: Well, yes, I do.

24 MR. LI: Yes, go ahead.

25 DR. MARTIN: Hide my little green light

1 here.

2 Now you were careful with your words, I
3 think. You said you spent a lot of time looking at
4 the PIRT.

5 Now, I'll ask you kind of the same
6 question that I asked Meghan. Did you do a
7 sensitivity studies or were your, that attention on
8 PIRT more qualitative?

9 MR. LI: Well, we did not do sensitivity
10 study. We basically looked through, well not a lot of
11 -- really, yes, take that word back.

12 And we look at detail, put it this way.
13 And that's our first task basically during the review
14 is first to look at yes, what the design change, what
15 the impact, if there are any to the PIRT team.

16 And then, the team spent time on that and
17 we get details, and we try to see whether compare with
18 the previous revision and to the design change, to see
19 if there are any impact.

20 DR. MARTIN: And, maybe just to follow up
21 with the PIRT. I can tell from the gray hair you've
22 done this for a while.

23 MR. LI: Thank you.

24 DR. MARTIN: And, so you've seen other
25 applications and not every, going way back but not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 looking at just reply PIRTs, but PIRTs for non-LOCA
2 have been around for at least as long as PIRTs for the
3 most part.

4 Compared to typical PWRs, does, do those
5 PIRTs more or less cover 80-90 percent of everything
6 that you otherwise see with the NuScale?

7 What stands out uniquely with NuScale?
8 Now, I would say the role of the DSRS, which of course
9 is getting a lot of attention. Yes, that's an obvious
10 one.

11 Anything else, and then natural
12 circulation.

13 MR. LI: Based on our understanding of the
14 design, I think the fundamental difference that, so is
15 not, there's in the primary loop, you don't have a
16 pump to drive.

17 DR. MARTIN: Right.

18 MR. LI: Yes, and that the, really the
19 phenomena for the natural circulation, which was also
20 relates to the power density could drive the flow in
21 slightly different way.

22 It's not well-controlled. In the PWR, you
23 have a pump and you know what is a certain --

24 (Simultaneous speaking.)

25 DR. MARTIN: -- are low.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. LI: Right, yes, you know exactly what
2 your pump needs, but this one you don't. I think
3 that's more the fundamental difference we see.

4 DR. MARTIN: Thanks.

5 MR. LI: And, that's just to mention that
6 the second, the third part of was you look at the
7 change in the method of evaluation, which the NuScale
8 already discussed that.

9 They have a new methodology for bounding
10 to calculate the bounding radioactive material release
11 if you have a leak in the primary system, more like a
12 CVCS.

13 But broadly, this is beyond the non-LOCA
14 before that's covered in other topical report for the
15 small LOCA, the small break, or small leak that it
16 would, able to use a bounding source.

17 Just a estimate how much I can leak and
18 then, what the timing of the leak. And then, they say
19 okay, I was use the bounding number and then -- into
20 the radiological consequence application.

21 CHAIR KIRCHNER: To that point about
22 bounding assumptions, LOCA and even for NuScale LOCA,
23 you have something like Appendix K.

24 And non-LOCA, there's certainly more
25 latitude. But historically, they've been

1 deterministic-type approaches.

2 Pretty well understood about what
3 uncertainties end up being addressed in a bounding
4 sense.

5 Clear in looking at the evolution of
6 NuScale, that the DHRS has been a particular
7 component, a particular contribution to core cooling
8 that in the earlier version, it was a much more
9 obviously conservative type assumption. They have
10 moved more towards realistic. It's obviously getting
11 plenty of attention.

12 Has there been anything else kind of like
13 that, that has gotten unique attention with how
14 they're addressing uncertainties that you probed?

15 MR. LI: Actually, not really in this
16 particular --

17 (Simultaneous speaking.)

18 CHAIR KIRCHNER: Application.

19 MR. LI: -- case -- application. Because
20 NuScale did not provide a specific method or
21 evaluation for the bounding calculation methodology.
22 So, that's one of the limitation, the condition.

23 Instead, it says the applicant was
24 responding or use, referring to this topical
25 methodology in this topical report with having to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 their analysis to determine what's bounding. And
2 then, what would be the certainty.

3 CHAIR KIRCHNER: Or something like just
4 the uncertainty of a natural circulation itself. You
5 could maybe bound it with low resistance or something.

6 Did they do anything particular to address
7 uncertainties with the natural circulation phenomenon?

8 MR. LI: Not in this methodology. You
9 could be wrong, correct. I don't think they really --

10 (Simultaneous speaking.)

11 CHAIR KIRCHNER: Relying mostly on test
12 data to support what their --

13 MR. LI: Yes, basically mostly on their
14 design they say what are the lines, the size of a
15 line. For example, if you have a CVCS line break or
16 something.

17 But just not, and there was a time you
18 would identify there's a leak, and then their
19 potential was time you --

20 I think that's the idea how they're trying
21 to determine, rather than go to a detailed NRELAP5
22 calculation is okay.

23 With just the estimated total, potential
24 total release, and the maximum time.

25 CHAIR KIRCHNER: Relying a lot more on

1 realistic type behaviors, and with some expectation to
2 have margin, reasonable margin.

3 MR. LI: Right.

4 CHAIR KIRCHNER: Maybe not so quantified
5 as a, say --

6 (Simultaneous speaking.)

7 MR. LI: And deterministic --

8 (Simultaneous speaking.)

9 CHAIR KIRCHNER: -- criteria.

10 MR. LI: Yes.

11 CHAIR KIRCHNER: But, okay.

12 MR. BARRETT: This is Antonio Barrett, of
13 the NRC staff. Yes, so like one thing you were asking
14 about the natural circulation.

15 In their model, they actually --- this is
16 stuff that they already did before. It's not new for
17 this, for what they did now.

18 But they biased the loss as higher now so
19 natural circulation.

20 CHAIR KIRCHNER: Okay.

21 That's why -- threw that out there, yes
22 All right, thanks.

23 MR. LI: So we'll move on.

24 The next one actually we're looking into
25 the code updates, and the NuScale during the review,

1 and also in the application they have a 1., I think
2 1.4.

3 And then, they move from 1.4 to a new
4 version, 1.7. And then, this is a change during the
5 review. And, we look into the -- the version.

6 The other one is the change associated
7 with the code bench marking, or we validation. This
8 is all tied to the new tests, and the test result.

9 Certainly, this one will get into that in
10 the also the update, the CHF correlation for screening
11 the cases sub-channel now.

12 What NuScale does is they use NRELAP5 to
13 run bunch of cases, identify those steps potential
14 challenge to the system, I think the NCHFR, the
15 minimal critical graphs.

16 And then, so they identify this case and
17 then throwing into a sub-channel analysis the use of
18 viper code to get a more detailed result, more
19 accurate result.

20 And, in the previous version, they have a
21 look-up table. I will try to pronounce it. They call
22 it the -- Correlation. It's the look-up table.

23 And then, they add two more. One is the
24 Correlation. The other one is, yes, well, yes,
25 there's another one. And there are two analytic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 I think this with the new correlation will
2 give them more accurate screening and for the next
3 step average.

4 So, and also NuScale updates theirs in
5 response to revision 3, they try to revise some of the
6 limitation, the conditions you see.

7 And, the staff review that limitation
8 condition and with respect the new design. And then,
9 come up with some of the change limitation and
10 condition.

11 And we will get into that during the
12 closing session, the closed section, which I have a
13 much more detailed discussion why we have this
14 limitation condition.

15 But next one.

16 So, we already talk about the revision
17 1.7, the base model change. And, this two tests and
18 the test result, and which we'll get into the review
19 the scaling.

20 Whenever you have to code bench marking on
21 validation, you have to test what you have to address
22 the similarity, scalability, and any distortion.

23 I think that would be discussed more
24 detail in the --

25 Yes, some of the events may get into

1 extended, long-time pulling. That would be Howard's
2 in the next topical report, which Antonio and company
3 would present.

4 Next slide, please.

5 Here, the limitation and conditions. The
6 number 1, 7, 9 are the new ones. And, the rest are
7 the, from the previous revision of the topical report.

8 We revised some of the limitation and
9 condition but not major change. But the previous
10 limitation and condition as you clearly see, the first
11 one is really relates to the NPM-20 design, which some
12 unique design features and then you have to address.

13 And, number 9 is talk about the
14 radiological, using the bounding methodology for
15 radiological analysis.

16 And, number 7 is really about the code
17 version as you all know. The code version is critical
18 for any change. You change the code, try to address
19 certain phenomena, and then so that's our limitation
20 condition.

21 I think that's conclude my presentation.

22 CHAIR KIRCHNER: Yes, thank you, Zhian.

23 So, in conclusion, while there are some
24 differences between the current and previous revision,
25 the staff found the applicant provided sufficient

1 information to support the staff's safety finding.

2 The staff found that an applicant that
3 references this topical report with the limitations
4 and conditions, will meet relevant regulatory
5 requirements pending review and approval of that
6 application.

7 Questions? Members?

8 CHAIR KIRCHNER: I have one, Tommy, and
9 Zhian.

10 MR. LI: Yes.

11 MS. PATTON: And, that is why are you
12 limiting it to NPM-20? Why wouldn't it not work for
13 the certified design as well?

14 MR. BARRETT: I can --

15 MR. LI: Antonio, I can speak too and you
16 can supplement. Becky, go ahead.

17 MS. PATTON: Yes, this is Becky Patton,
18 I'm the supervisor from Reactive Systems.

19 Yes, so the staff looked at that early on
20 and the way I think that it was requested, it wasn't
21 just backward looking to the NPM-160, but it was also
22 forward looking to other module designs that would
23 have certain features.

24 And, when we approve a topical report
25 methodology, we don't do the forward looking like if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 other applicants, other technologies, BWRs and PWRs
2 when they come in.

3 You have to look at the sort of the
4 technology I want to say family, but that specific
5 design like for BWRs. You'd have BWR 3s, 4s, 5s,
6 right?

7 And, you come in with the topical report
8 and you say I want to cover these types of designs,
9 but we don't do a forward looking because that would
10 require the staff to look at all kinds of other things
11 that you can do with that design.

12 So, we looked at that early on and the
13 forward looking thing was sort of off the table, as
14 something that the staff could entertain.

15 The backward looking was really a
16 practicality of it for the 160, that that would have
17 required all of the RAI responses, all of the
18 considerations and everything to have also considered
19 the 160.

20 And so, there were some early on
21 engagements at the management level to, the decision
22 was made to take that off the table as well.

23 It doesn't mean that they couldn't come in
24 at some future time for an applicability. There's
25 certainly that allowance within the limitation and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 conditions. But it was mostly a practical
2 determination.

3 CHAIR KIRCHNER: Yes, I wasn't thinking of
4 forward looking, I was just thinking backward to the
5 DCA, and overall I think the methodologies enhanced
6 and obviously using an improved and updated version of
7 NRELAP.

8 So, my thinking was well, it would work as
9 well for the former design at this point. But I think
10 this is a trend in all your TRs on methodologies, to
11 kind of restrict it to the application at hand.

12 But it just strikes me that they made some
13 significant improvements in their modeling capability,
14 and that it would be a if they wanted to revisit the
15 previous design that was considered for the DCA, the
16 methodology would be applicable, as well.

17 So, I guess this is just at this juncture,
18 standard practice to somewhat limit the TRs to the
19 actual application at hand, and --

20 MS. PATTON: Yes, I wouldn't say that. I
21 wouldn't say it's -- standard.

22 MR. LI: Definitely it's not.

23 MS. PATTON: Oh, I'm sorry.

24 CHAIR KIRCHNER: Yes, go ahead, Becky.

25 MS. PATTON: Yes, Becky Patton again.

1 Yes, I wouldn't say it's necessarily
2 standard practice. Like I said, it was a practicality
3 of getting through this review on a predictable
4 timeframe. And not having to do a backward look as
5 well.

6 Like I said, the condition and limit is
7 written in such a way that you can do a fairly
8 straightforward applicability-type review in the
9 future.

10 If the backwards look to the 160's
11 designer also for any forward look for a future
12 design, that's also written in there.

13 So, I wouldn't say that it's our process
14 going forward. We certainly do topical report reviews
15 for the obsolete too, that are sort of stand alone
16 where you're looking at multiple technologies.

17 This was really a practicality --
18 (Simultaneous speaking.)

19 CHAIR KIRCHNER: Okay.

20 MS. PATTON: -- of this review. That's
21 the effect the decision that was made.

22 CHAIR KIRCHNER: All right, thank you.

23 Questions?

24 So, at this point, is this a good juncture
25 to take a quick break?

1 MR. SNODDERLY: Perfect, you're right on
2 time.

3 CHAIR KIRCHNER: Okay.

4 MR. SNODDERLY: It's 10:40 and we had a
5 break scheduled for 10:45 so -- with you.

6 CHAIR KIRCHNER: Let's go to 10:55. We'll
7 reconvene at 10:55 Eastern Time and we'll take up an
8 extended, I have a feeling, TR.

9 Thank you.

10 (Whereupon, the above-entitled matter went
11 off the record at 10:38 a.m. and resumed at 10:55
12 a.m.)

13 CHAIR KIRCHNER: Okay, we are back in
14 session and we are going to turn back to NuScale, and
15 we are taking up now the Extended Passive Cooling
16 Topical Report, and I will turn to Ben Bristol.

17 MR. BRISTOL: Good morning. This is Ben
18 Bristol. I'm the manager of the System Thermal
19 Hydraulics Group. We'll go through quick
20 introductions and then Tom is going to kick us off.

21 MR. CASE: Good morning. My name is Tom
22 Case. I'm a licensed engineer with NuScale. I've
23 been with NuScale for about two years and in the
24 nuclear industry for about 14 years, and I'm a
25 licensed professional engineer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CODDINGTON: Taylor Coddington, Safety
2 Analysis. I've been with NuScale about seven years.

3 CHAIR KIRCHNER: Just speak up a little
4 more, Taylor.

5 MR. CODDINGTON: Taylor Coddington. I've
6 been with NuScale about seven years in safety
7 analysis.

8 CHAIR KIRCHNER: Thank you.

9 MR. CASE: So, this is the open portion of
10 NuScale's presentation of the Extended Passive Cooling
11 and Reactivity Control Methodology Topical Report.
12 Next slide?

13 This portion will cover the evaluation
14 model scope, regulations, and acceptance criteria, the
15 NPM design features related to the methodology,
16 phenomena identification and ranking table or PIRT
17 evolution, and the evaluation model structure,
18 validation basis, and adequacy assessment and
19 conclusions. Next slide?

20 This is a new topical report that was
21 developed to support the 250 MWt NPM design and SDAA
22 submittal, but is applicable to NPMs that meet the
23 design requirements and conditions specified in the
24 topical report.

25 The scope of the methodology covers

1 analysis of long-term cooling and reactivity control
2 following the short-term response to required design
3 basis LOCA and non-LOCA events.

4 The regulations applicable to the topical
5 report include 10 CFR 50.46(b)(4) and (5), and NuScale
6 principal design criterion 35 for long-term ECCS
7 cooling and maintaining a coolable geometry, NuScale
8 PDC 34 for extended DHRS cooling, and GDC 26 and 27
9 for reactivity control.

10 The methodology also supports an exemption
11 to GDC 33 for a safety-related system to provide
12 makeup in response to reactor coolant leakage. Next
13 slide?

14 So, the applicable regulatory requirements
15 translate into three safety objectives, decay and
16 residual heat removal, reactivity control, and
17 maintaining coolable geometry. The methodology uses
18 the following acceptance criteria corresponded to
19 those safety objectives.

20 The acceptance criteria are collapsed
21 liquid level remains above the top of the core, the
22 reactor core remains subcritical, and boron
23 concentration remains below precipitation limits, and
24 these acceptance criteria need to be met for 72 hours
25 after event initiation and the subcriticality analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 assumes the highest worth control rod remains
2 withdrawn from the core. Next slide?

3 DR. PALMTAG: I just have a question on
4 the k effective equals one, plus one. For normal
5 shutdown margin calculations, you usually see
6 something like shutdown margin with one percent, so it
7 might be a 0.99 factor plus uncertainties. Can you
8 tell me why it's one here?

9 MR. CASE: Yeah, so for the long-term
10 cooling analysis and reactivity control, we're looking
11 at post-event initiation subcriticality as an
12 acceptance criteria, and so that's different than
13 shutdown margin as defined by tech specs, which would
14 basically establish initial conditions or ensure
15 initial conditions are maintained during normal
16 operation.

17 And so, the shutdown margin calculation
18 controlled by tech spec is different than what the
19 long-term cooling analysis is analyzing, and so the k
20 effective less than one is an appropriate acceptance
21 criteria for the long-term reactivity control given
22 the assumptions and conservatisms that are applied to
23 the methodology, and those conservatisms will be
24 discussed in the closed session.

25 DR. PALMTAG: Okay, so there's no margin

1 per se on the shutdown. You're assuming all of the
2 conservatism is built into the modeling, I guess?

3 MR. CASE: Correct, and that shutdown
4 margin calculation in tech specs does include a margin
5 prior to event initiation, whereas the acceptance
6 criteria we're looking at here during the long-term
7 cooling is just k effective less than one. Next
8 slide? And I'll turn it over to Ben Bristol for
9 design features.

10 MR. BRISTOL: Good morning. This is Ben.
11 So, we wanted to take a minute to just kind of talk
12 through some of the passive cooling features. These
13 have been described to the ACRS previously in other
14 presentations, but specifically with respect to the
15 long-term cooling conditions. So, just as a quick
16 orientation, after a LOCA event or some event where
17 ECCS is required, the function is all about
18 depressurizing the systems.

19 So, what happens is we have water
20 redistribution from the RCS into containment, a level
21 is established in containment, and the vent valves and
22 the condensation on the containment wall is used to
23 depressurize the system.

24 Once pressure equilibrium occurs, then
25 recirculation is passively provided based on a level

1 head difference between the liquid inside the
2 containment compared to the liquid level inside the
3 RPV.

4 Under these conditions, the HRS is also
5 active. However, mostly the steam generator tubes are
6 uncovered. So, inside the RCS, condensation is
7 occurring on the tube, the outer tube walls in
8 addition to the condensation that's occurring in
9 containment itself.

10 So, the distribution of the reactor
11 coolants is really established based on the pressure
12 drop, the vapor pressure drop, the pressure drop
13 across the vent valves. We've described previously
14 some optimization and the differences between the NPM-
15 160 design and the NPM-20 design.

16 That included a key feature change, which
17 is the reduction of one of the vent valves, so three
18 vent valves to two vent valves. It's this long-term
19 cooling analysis and behavior that demonstrates the
20 appropriateness of that sizing change and it's really
21 driven by the containment wall heat transfer rates,
22 which we will present on the next slide if you go to
23 that, Wendy?

24 In the XPC LTR, we consider a variety of
25 different exceptions criteria. One of those looks at

1 biases and conservatisms that maximize the containment
2 heat removal, and another analysis looks at conditions
3 where we minimize the containment heat removal in
4 order to demonstrate that depressurization functions
5 still occur.

6 Specifically, we look at sensitivities on
7 pool temperature, one of the main drivers, and what we
8 wanted to point out in this slide is the difference
9 between these two figures, so the equilibrium level
10 under the minimum pressure or maximum heat removal
11 conditions.

12 The equilibrium level is about five feet
13 of margin above the top active fuel, so that's the
14 liquid level inside the RPV compared to the top of the
15 core. In contrast, the figure on the right shows
16 under the maximum temperature conditions and minimum
17 heat removal conditions the overall system pressure
18 remains higher.

19 The vent valve capacity is not tested as
20 severely and that results in a much higher equilibrium
21 level. So, we reach an equilibrium state of about ten
22 feet or about twice the margin under those conditions.

23 CHAIR KIRCHNER: Ben, could you go back to
24 your previous picture? Just I wanted to ask you to
25 address the change. One of the changes is your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 ultimate heat sink pool level.

2 I don't know if that previous picture, one
3 slide back, if that's to scale, but I don't think
4 that's the level that we're going to see actually in
5 the NPM-20 design. I think your level is
6 significantly lower on the containment vessel.

7 MR. BRISTOL: Yeah, that's correct. This
8 is a non-scale --

9 CHAIR KIRCHNER: Schematic.

10 MR. BRISTOL: -- schematic.

11 CHAIR KIRCHNER: Yeah.

12 MR. BRISTOL: The equilibrium level and
13 the DHRs aren't quite scaled here either, but roughly
14 the pool level is around in the pressurizer band I
15 guess I would say.

16 CHAIR KIRCHNER: Several feet above the
17 DHRS heat exchanger.

18 MR. BRISTOL: That's correct.

19 CHAIR KIRCHNER: And that's reflected now
20 going forward to what you were presenting in the
21 maximum temperature conditions because that pool level
22 would have an impact on where you wind up in the long-
23 term.

24 MR. BRISTOL: Yeah, that's correct. So,
25 if you can consider the condensate, the containment

1 condensing surface area, it's directly proportional to
2 the pool level. The space above the pool has very
3 little heat transfer rate.

4 It heats up essentially to the steam
5 temperature and it does very little heat transfer
6 work, so reducing the pool level allows us to optimize
7 the thermal hydraulic response under the maximum
8 cooling conditions. Thanks, Wendy.

9 Okay, so switching gears here a little
10 bit, one of the other topics that we spent a fair
11 amount of review time with in the DCA or NPM-160
12 design was under the conditions where we were
13 condensing either on the containment wall or on the
14 steam generator walls, tube walls inside the RCS.

15 The characteristics of boron transport,
16 generally, boron is left behind when the water boils,
17 and therefore, the condensed water is of a deborated
18 state or a zero boron state, pure water in that
19 regard. So, the core can create a little bit of a
20 distilling effect, and the areas where condensate
21 accumulates are therefore diluted relative to the
22 average.

23 So, one of the concerns was downcomer
24 dilution, whether it be from the recirculation from
25 containment or direct contribution of condensate from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 the steam generator tube walls. In order to mitigate
2 that more thoroughly in this design, we've included
3 some passive features.

4 They're simply flow paths, liquid flow
5 paths in the figure here. We have the four sets of
6 holes in the upper riser. Those are there under
7 conditions where we have extended DHR. DHRS cooling
8 can shrink the RCS, and that results in the level
9 dropping out of the pressurizer and up to and
10 including uncovering the riser.

11 Under these conditions, the four sets of
12 holes allow for continued circulation of the RCS loop
13 to ensure that any condensing that's occurring in the
14 steam generator tubes is overcome by the natural
15 circulation flow paths in order to keep a relatively
16 uniform concentration in the RCS.

17 Similarly, under ECCS conditions where the
18 upper four sets of holes uncover, you have another set
19 of holes in the lower riser, and these provide the
20 same effect of allowing transport of more highly
21 borated RCS liquid in the core and upper riser region
22 to mix with the condensate that's recirculating,
23 whether it be from the recirc valves in the
24 containment or from the steam generator tube
25 condensation itself. I'll pause for any questions on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 this. We're going to switch gears again on the next
2 slide. Thanks, Wendy.

3 Okay, the last design feature that I have
4 to present here is the supplemental boron components
5 that we've added as part of ECCS. So, there's two
6 sets of components here on the diagram. We have --
7 the way this system works is we've got a dissolver
8 basket or container where we have boric oxide pellets,
9 and those are maintained in containment throughout the
10 core cycle.

11 In the event of the need for an ECCS, this
12 system passively works to collect condensate, the
13 condensate that's collecting on the containment wall,
14 redirect it through the basket and create liquid boric
15 acid that mixes with the liquid in the containment,
16 which then is recirculated through the recirc valves
17 into the RCS to provide the additional reactivity
18 control and hold down to support the long-term cooling
19 acceptance criteria that Tom described.

20 So, the features primarily associated with
21 the dissolver basket are those in the upper portion of
22 containment. In addition to that, we have what we
23 call the mixing tubes in containment, and what that
24 does is it redirects pure condensate, so deborated
25 water, from the condensing walls down to the bottom of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 containment.

2 What this allows for is any borated
3 accumulation that occurs in the lower containment
4 region to eventually be transported back upward
5 through the combination of convective effects, as well
6 as simple mass turnover that's provided by the tubes
7 that deposit the lower borated water to the bottom of
8 containment, the lower mixing tubes. If there's on
9 questions on that, we'll --

10 DR. PETTI: Ben?

11 MR. BRISTOL: Yeah?

12 DR. PETTI: This is Dave. Just during
13 normal operation, what's the atmosphere in
14 containment? It's evacuated, right?

15 MR. BRISTOL: Yes, it's evacuated normally
16 around one PSIA.

17 DR. PETTI: I'm just wondering what
18 happens to the lower boron oxide just sitting there,
19 you know, for a long time, whether there's any
20 potential degradation. The passive pressure of water
21 vapor would be pretty low, I guess, in PSI, okay.

22 MR. BRISTOL: Yeah, generally, the RPV is
23 quite high under the conditions, so there's some
24 radiative heat transfer that's occurring. Depending
25 on where the components are located, they can be quite

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 hot under normal operating conditions.

2 Most things attached to the containment
3 wall tend to stay closer to the pool temperature, but
4 there is a heat balance there between the heat loss
5 through the conductive effects and the heat addition
6 through the radiative heat transfer.

7 DR. PETTI: You check, at least on the
8 first part, every so often.

9 MR. BRISTOL: Yeah, the qualification of
10 the boron pellets is part of the program.

11 DR. PETTI: Okay.

12 DR. BALLINGER: Yeah, this is Ron
13 Ballinger. What's the packing fraction in there? In
14 other words, you've got, I'm assuming, spherical
15 pellets of some kind.

16 So, you dump them in here, and if the
17 packing fraction is above a certain number, you don't
18 have a continuous flow path through the bed, but if
19 it's low enough, you do have a flow path, a continuous
20 flow path, excuse me, through the bed, and that would
21 avoid this issue that we're sort of dreaming up, I
22 guess, of reconsolidation of these pellets to make a
23 solid mass as opposed to so that fluid can't get
24 through.

25 PARTICIPANT: That is something that is

1 addressed in the XPC LTR itself. There's correlations
2 that we found for pellets being dropped, and what
3 configuration they form, and the path factor that they
4 would result in, and demonstrating the environmental
5 qualification of the pellets is something that is
6 being considered.

7 MR. BRISTOL: Yeah, and specifically, I
8 think we've got some more details in the closed
9 session.

10 DR. BALLINGER: Okay.

11 MR. BRISTOL: We can get into that and
12 some of the testing that we did as part of that.

13 CHAIR KIRCHNER: Ben, what happens during
14 the refueling operation? You don't -- you know, you
15 keep -- that upper part of the containment remains
16 dry, so to speak, or I think --

17 MR. BRISTOL: Yes.

18 CHAIR KIRCHNER: -- or it floods and you
19 replace them.

20 MR. BRISTOL: Yeah, so where those are
21 located is below the level of the pool. Obviously, we
22 needed the condensing surface area above over where
23 the basket, the dissolver basket is located, so that
24 was one of the challenges in trying to figure out the
25 design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So, if part of refueling floods the
2 reactor module up to the pool level before it's
3 unbolted, so the bed will get flooded, it will
4 dissolve from there, and then as part of operations,
5 the upper module goes for inspections in the dry dock,
6 comes back, returns flooded as part of the restart
7 operations, then containment flood and drains are used
8 to drain containment --

9 CHAIR KIRCHNER: Right.

10 MR. BRISTOL: -- at which point there's an
11 operation where the pellets are installed and
12 confirmed to be relocated back in the basket, and from
13 that point on, then the containment atmospheric
14 conditions are controlled such that the boron doesn't
15 dissolve from there until ECCS operations is required
16 for some transient.

17 DR. PALMTAG: Scott Palmtag. Just to
18 confirm though, the way you've installed the dry
19 pellets, they're not flooded.

20 MR. BRISTOL: That's correct.

21 DR. PALMTAG: They remain dry --

22 MR. BRISTOL: Yeah.

23 DR. PALMTAG: -- until the next refueling.

24 MR. BRISTOL: That's correct. Okay,
25 Wendy, next slide?

1 MS. McCLOSKEY: Okay, this is Meghan and
2 I'll pick up here to talk about, first about the PIRT
3 evolution for this topical report. NuScale had
4 previously developed PIRTs for extended ECCS cooling
5 or extended DHRS cooling for the NPM-160 design, but
6 we took that work and reassessed it holistically
7 because we now had different acceptance criteria as
8 well as design changes to consider.

9 So, we started right back at the beginning
10 in considering what phases and figures of merit were
11 relevant for the phenomenon and that's what's shown on
12 the table at the bottom here for the NPM-160 design on
13 the left and then the updated, the 250 megawatt design
14 that's part of the SDAA on the right. For LOCA, phase
15 two is the same. That's really no different here.

16 For non-LOCA and extended DHRS operation,
17 with the previous design, we had a couple different
18 extended DHRS phases depending on whether the riser
19 level was above the top of the riser or whether the
20 DHRS cooling had shrunk it to below the top of the
21 riser and you had intermittent or perhaps interrupted
22 natural circulation there.

23 With the upper riser flow paths that Ben
24 pointed out with the four different levels there that
25 are sized to maintain liquid flow over top of the

1 steam generator during extended DHRS operation, we're
2 really more focused now on phase three and stable
3 natural circulation.

4 And then with respect to figures of merit,
5 the NPM-160 design, we established different design
6 criteria, particularly in the US PDC 27, where I'm
7 going to get this mixed up with 26, in that 27, the
8 long-term subcriticality was demonstrated with other
9 cold conditions with all rods in, and with the worst
10 rod stuck out condition, we evaluated that low power
11 recriticality and demonstrated that the fuel cladding
12 remained intact by demonstrating margin to the correct
13 heat flux ratios, low pressure, low power
14 recriticality conditions.

15 So, now with the design criteria to remain
16 subcritical considering worst rod stuck out, our decay
17 heat source long-term is, or our core heat source
18 long-term is decay heat levels, and under that
19 condition, demonstrating core cooling is met by
20 demonstrating that our collapsed liquid level remains
21 above the top of the core and we maintain a coolable
22 geometry, and then subcriticality remains a figure of
23 merit as well as an acceptance criteria here.

24 So, that really shifted how we were
25 looking at the PIRT and some things became differently

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 important as we went through that process. Next
2 slide?

3 In terms of the structure, we've got a
4 couple of key pieces. We're continuing to use NRELAP5
5 as the thermal hydraulic engine that's driving the
6 methodology, and we used the results from the code
7 calculations to demonstrate that the collapsed liquid
8 level is maintained above the top of the fuel and to
9 evaluate the containment response.

10 That's basically the same as the scope
11 that we had performed for the DCA and essentially the
12 same methodology there, and then NRELAP5 also provides
13 the thermal hydraulic input boundary conditions for
14 the transport analysis.

15 We used SIMULATE5 for the core reactivity
16 analyses, and that determines the critical boron
17 concentrations as well as the initial starting boron
18 concentrations because we're evaluating a range of
19 operating cycle exposures and operating histories,
20 different shutdown times, and evaluating conditions
21 for a range of thermal hydraulic conditions that could
22 potentially occur during long-term cooling.

23 And then the boron transport calculations
24 really bring all of the pieces together. We have this
25 currently implemented in MATLAB scripts, but it could

1 be done in other applicable computational tools.

2 So, the topical report provides the
3 methodology requirements for the transport analysis,
4 and this is where we map the NRELAP5 thermal hydraulic
5 conditions in the context of the different boron
6 transport regions that we're evaluating and the boron
7 loss terms or addition terms from the ESB, and we
8 compare those concentrations to the critical boron
9 concentrations calculated by SIMULATE5 for those
10 thermal hydraulic conditions in order to demonstrate
11 subcriticality.

12 And the boron transport analysis for
13 precipitation is similar except that we are treating
14 the loss terms differently because it's the opposite
15 directions of conservatism and we're comparing against
16 solubility limits rather than critical boron
17 concentrations.

18 DR. PETTI: Meghan, just a question on the
19 precipitation. We know the solubility of boric acid,
20 but sometimes in some systems, radiation fields can
21 cause boric precipitation and then, you know, you're
22 a chemical beaker, so it's important to make sure
23 there's good margin. Is there always, you know, good
24 margin relative to --

25 MS. McCLOSKEY: Yes, yeah, we don't need

1 a lot of additional boron to maintain subcriticality,
2 and so that's 25 to 30 kilograms, I think, per
3 dissolver inside of containment. So, our source term
4 for boron addition is much smaller than what we
5 typically see in like operating PWRs.

6 DR. PETTI: Okay.

7 MS. McCLOSKEY: And so, our concentrations
8 remain commensurately lower.

9 DR. PETTI: Okay, great.

10 DR. MARTIN: This is Member Martin.
11 RELAP, the way it models reactivity is not at all
12 like, say, any other reactor physics code, right. You
13 just wouldn't give it a boron concentration and expect
14 it to reflect reality. It's really about the delta,
15 and I expect that you're using a point kinetics model
16 on --

17 MS. McCLOSKEY: We're not using RELAP's
18 reactivity models at all in the long-term cooling.

19 DR. MARTIN: Right, okay, so you're not
20 even doing like a delta reactivity --

21 MS. McCLOSKEY: No, we're --

22 DR. MARTIN: You track boron.

23 MS. McCLOSKEY: No, we're not tracking --
24 we're tracking boron through the MATLAB script.

25 DR. MARTIN: So, you don't model boron in

1 NRELAP5?

2 MS. McCLOSKEY: Correct.

3 DR. MARTIN: Okay, so this is all outside?

4 MS. McCLOSKEY: Yes.

5 DR. MARTIN: All right, I need to think
6 harder about that.

7 (Laughter.)

8 DR. MARTIN: All right, thanks.

9 MS. McCLOSKEY: All right, next slide?
10 So, in terms of the validation basis for the method,
11 our NRELAP5 validation basis is probably pretty
12 familiar to folks at this point. We are continuing to
13 build on the basis established for the LOCA and the
14 non-LOCA EMs, and then we have additional specific
15 long-term cooling testing that was performed at the
16 NIST-2 facility.

17 Taylor briefly mentioned the boron
18 dissolution testing that was done. That was separate
19 effects testing that we performed to assess the
20 methods for slow-biased or fast-biased dissolution in
21 the dissolver baskets against that test data and
22 confirmed that our methods would bound the measured
23 data in whichever direction is conservative for a
24 particular transient evolution.

25 SIMULATE5 has an extensive validation

1 basis and use cases developed for a wide range of
2 other applications, and what we've done particular to
3 this evaluation model is develop a nuclear reliability
4 factor or NRF specifically considering the extended
5 passive cooling conditions, and that is included in
6 the critical boron concentration to account for
7 uncertainties associated with the reactivity balance
8 there.

9 And then in terms of the boron transport
10 methods and the adequacy basis, a lot of this relies
11 on the thermal hydraulic input, and it also relies on
12 ensuring that we have conservative treatment of the
13 phenomena that are specific to the boron transport of
14 how that boron is being transported within the module.
15 Next slide?

16 Overall, in the adequacy assessment from
17 the bottom-up perspective, we focused on correlations
18 that are in NRELAP5 and the correlations that we used
19 in the boron dissolution analysis, and we identified
20 some limitations of those correlations there. The
21 top-down assessment also considered what was the
22 numerical features within NRELAP5 and its fundamental
23 governing equations and how it assessed against the
24 NIST-2 tests.

25 So, we identified some limitations in the

1 models and correlations, particularly as related to
2 NRELAP5 under these types of conditions, and we have
3 identified conservative treatments within the
4 evaluation model in order to address those limitations
5 or we have implemented alternate approaches to confirm
6 that what we're getting from the method is
7 conservative.

8 And so, we have evaluated the limitations
9 under these types of low pressure conditions
10 predominantly where the code really wasn't originally
11 developed to operate, and we've ensured that we have
12 conservative treatment required by the evaluation
13 model to address those.

14 So, overall, our conclusion is that for an
15 NPM with design features that are specified in the
16 topical report, the methodology provides a
17 conservative method to demonstrate adequate core
18 cooling and decay heat removal, that the module
19 remains subcritical following design basis events, and
20 that coolable geometry is maintained. Any questions?

21 CHAIR KIRCHNER: Members? I have a lot of
22 questions, but I think probably I'll hold most of them
23 for the closed session, but just for the public
24 session, it seems to me that in a simple way on this
25 boron issue, you could look at your system and say

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 that, with the assumptions you used, the most were the
2 rod bank stuck out, what the --

3 And it's probably more a beginning of
4 cycle problem than end of cycle problem. What's the
5 critical boron concentration to be sufficiently below
6 k effective of one? As a figure of merit, is that
7 possible to do? Do you use that in your thinking to
8 kind of do an overall assessment?

9 You've looked at the boron redistribution
10 and such, and then you look at the effect of your
11 riser holes and so on, and look at how the boron is
12 transported, but you then have a goal, if you will, as
13 the function of burnup for where you are in the cycle.
14 This is how much we can't let the concentration of
15 boron get below this amount. I'm trying to remember
16 what your steady state normal start of the cycle PPM
17 is. It's about 1,000 or something, something in that
18 order without getting into --

19 MR. CODDINGTON: Yeah, 1,000 is about
20 right for --

21 CHAIR KIRCHNER: Yeah.

22 MR. CODDINGTON: -- equilibrium end of
23 cycle.

24 CHAIR KIRCHNER: So, if you're in the
25 beginning of cycle and you go through these transients

1 and either the extended cool down or the ECCS
2 functions, and you're looking at a figure of merit
3 target for what you don't want the boron concentration
4 to go below X. Is that how you look at your mass
5 balance, so to speak, of how effective your boron
6 dispensers are for the ECCS system and so on? Is that
7 basically your approach?

8 MR. CODDINGTON: Yeah, yeah, so, you know,
9 depending on what the initial exposure is, you have a
10 different initial boron concentration, and then we do
11 track the boron as it moves throughout the system and
12 compare it back to critical boron concentration that
13 is specifically tied to not only a cycle exposure, but
14 also a specific operating history.

15 CHAIR KIRCHNER: Right.

16 MR. CODDINGTON: So, yeah, that, the
17 critical boron concentration floats with time, with
18 the specific transient being evaluated, with the time
19 since reactor scram, so it's a large number of
20 simulated cases effectively.

21 CHAIR KIRCHNER: And then to deal with
22 uncertainty, because you have no way really to measure
23 local boron concentrations in this system, how do you
24 -- what's the conservatism that you build in to have
25 confidence that, you know, plus or minus 25 PPM or

1 what, you know, what kind of design targets do you
2 have for the functionality of the riser pools doing
3 their job as well as the, in the case of ECCS, the
4 boron dispensers functioning?

5 MR. CODDINGTON: Yeah, so we do have a
6 fair number of conservatisms in the method. You know,
7 we don't assume that. We do assume the rod is stuck
8 out and it's worth a lot. There are others that
9 go into the analysis methodology, and then we
10 do develop a specific XPC that gets applied at the
11 critical boron concentration, and I don't know exactly
12 how public those numbers are, so I'd probably prefer
13 to save them for closed session.

14 CHAIR KIRCHNER: Okay, well, I can pursue
15 this in the closed session, but I just wanted to get
16 a sense in the open session how you, you know, you
17 have identified some rather, I don't want to call them
18 gross because that's the wrong word, but some overall
19 figures of merit, like collapsed liquid level
20 obviously is an obvious one.

21 But the tracking of what the different
22 boron concentrations are in the system is a much more
23 complicated problem and I'm just looking for, you
24 know, what's your designer's figure of merit on boron

25 **NEAL R. GROSS**

1 concentration or do you just condense that with the
2 changes you've made in the design? You've kind of
3 overwhelmed the problem and you will not have a
4 significant inventory of unborated water anywhere in
5 the system?

6 MS. McCLOSKEY: We won't have a
7 significant inventory of unborated water near the
8 core, which is where we care about it being unborated.
9 I think the other thing is when we're considering a
10 normal operating history, it's only as we get towards
11 the end of the cycle conditions.

12 You know, if your plant has been operating
13 along at these load conditions for a cycle, it's
14 getting towards the end of cycle conditions where the
15 worth of the highest worth control rod remaining stuck
16 out can be offset by the amount of reactivity feedback
17 that comes along with up to 72 hours of very effective
18 passive cooling conditions and the assumption that the
19 operators aren't doing anything at all to resolve the
20 system, to resolve the issue.

21 You know, the plant is always going to be
22 initially shutdown, and then it's the later cooling
23 from the ECCS and the slow burnout of xenon worth that
24 rides the critical boron concentration back up, and
25 you can see some of those effects in some of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 closed session work.

2 CHAIR KIRCHNER: Okay, so you also have
3 included the xenon?

4 MS. McCLOSKEY: Yes, and we --

5 MR. CASE: Particularly the downcomer
6 resolution is something that we look at more
7 specifically, and the method doesn't require us to
8 stay above the critical concentration, but it's a part
9 of the consideration.

10 I think it is important that, and this
11 will be evident in the curves, that the end state of
12 the transient is very safe in terms of margin
13 perspective to the critical concentration, so there's
14 really an inflection point.

15 Meghan was kind of describing the dynamics
16 of the transport behavior and then the xenon and the
17 temperature effects, right? So, all of those create
18 a bit of a pinch point that we look at
19 deterministically, right, to apply margin, but overall
20 in the context of where the transient ends up, it's in
21 a good spot.

22 The dilution of the containment was not
23 something that we set out to resolve. I think that's
24 a consideration. In the event that we have modules
25 under those conditions, there's certain procedures,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 and we still have some of that language in the SRs as
2 to the consideration of that during recovery efforts.

3 MR. CODDINGTON: And I guess I would just
4 add that in this sizing of the ESB, some of our
5 transients that we do evaluate don't result in a
6 diluted downcomer. There's a flow path that is
7 maintained from the core and riser to the downcomer --

8 CHAIR KIRCHNER: Right.

9 MR. CODDINGTON: -- if you assume an
10 injection uprate, for instance. Some of the sizing of
11 the ESB and how much boron it needs to hold, you know,
12 the minimum value there is effectively enough to make
13 sure that it would remain shut down even for that type
14 of event where you don't actually concentrate boron in
15 the core very much.

16 CHAIR KIRCHNER: Okay, well, we can pursue
17 it further in the closed session, okay. Members? And
18 that concludes your presentation, Ben, yes?

19 MR. BRISTOL: Yes.

20 CHAIR KIRCHNER: Okay, so for those
21 listening in, we're going to pause for a moment and
22 change out to NRC staff.

23 MR. DRUCKER: Well, I just want to do a
24 slide check here. Are you guys seeing the full
25 slides?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR KIRCHNER: Not yet. We're seeing --
2 can you go to the slide show?

3 MR. SNODDERLY: Patrick, give us some
4 time. We won't start until we can see the slides, all
5 of us can see the slides, but thank you for asking.
6 Any other comments, Patrick, or things we can do to
7 help with the transcript?

8 (Pause.)

9 MR. SNODDERLY: Okay, thank you for the
10 feedback.

11 MR. TESFAYE: This is Tesfaye. David, can
12 you hear me?

13 MR. DRUCKER: Yes, I can hear you. We got
14 you.

15 Am I okay to start?

16 CHAIR KIRCHNER: Yes, please, but
17 introduce yourself.

18 MR. DRUCKER: Good day. My name is David
19 Drucker and I'm a Senior Project Manager in the New
20 Reactor Licensing Branch in NRR and the Lead Project
21 Manager for the XPC topical report review.

22 This slide shows the contributors to the
23 review of the XPC topical report, and I will present
24 a few introductory slides, and Antonio Barrett, the
25 lead reviewer, will present the remainder of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 slides.

2 During the staff's review of the topical
3 report, 25 audit issues were identified and resolved,
4 and eight RAIs were issued. The second to last bullet
5 on this slide says two RAIs remain open. However,
6 since these slides were submitted to ACRS last week,
7 one of the RAIs was closed, so there's only one open
8 RAI.

9 The significant changes between the draft
10 safety evaluation provided to ACRS on February 4 and
11 the safety evaluation published on February 26 will be
12 discussed in slide 16.

13 As I mentioned earlier, only one RAI
14 remains open. RAI XPC-6 was recently closed. NRC
15 staff is reviewing a revised response to RAI XPC-21
16 that was submitted by NuScale on February 27.

17 A significant change between the draft
18 safety evaluation provided to ACRS on February 4 and
19 the safety evaluation published on February 26 is the
20 addition of limitation and condition number 10 and
21 number 11, which will be discussed in more detail
22 later in this briefing. Next, Antonio Barrett will
23 discuss the staff's review of this topical report in
24 detail.

25 MR. BARRETT: Thank you, David. My name

1 is Antonio Barrett of the NRC staff. I work in the
2 new reactor, excuse me, the Nuclear Methods Systems
3 and New Reactors Branch, excuse me. Anyway, so let's
4 -- all right, we're on the first slide.

5 So, relevant changes from the DCA to the
6 SDAA, in the DCA, they had a long-term tooling and
7 technical report and SR evaluations, and now for the
8 SDAA, we have a new XPC topical report methodology and
9 new design features.

10 With respect to the criticality
11 evaluations, there were some for the DCA. There were
12 some conditions and events where you could return to
13 power, and now with the new SDAA and using at least
14 the new methodology and the design features now can
15 return to power. Go to the next slide?

16 Additionally, some of the additional
17 changes are increasing the riser holes which were
18 there to help promote mixing. For the DCA, the RVVs
19 contained in IAB, which would prevent a blowdown on
20 the ECCS signal, now for the SDAA, the RVVs do not
21 contain these IABs, so when you get a valid ECCS
22 signal it won't blowdown. Some of the boron addition
23 that we're going to talk about eventually.

24 And for the long-term cooling
25 enhancements, there is the new ECCS supplemental boron

1 system, so the combination of the riser holes, this
2 containment boron addition, the containment mixing
3 tubes, they all contribute to the boron transport and
4 redistribution around the system during DHRS and ECCS
5 cooling. Next slide?

6 And this is just a figure kind of
7 depicting some of the stuff that we already described
8 and I think you've already seen a lot of this stuff
9 already talked about during the NuScale slides. Over
10 here, you see the RVVs that no longer contain the
11 IABs, the containment mixing tubes which promote
12 mixing towards the bottom of the CNV, the riser holes,
13 the upper and lower riser holes which promote mixing
14 between the downcomer and the riser core section, as
15 well as the boron addition source. Next slide?

16 So, for some of the review highlights,
17 we're going to cover those on the next two slides.
18 So, the XPC topical report is an extension of the
19 short-term LOCA and non-LOCA topical reports. It was
20 built off of those particular evaluation models and
21 the staff reviewed it as such, and the staff used the
22 guidance in Reg Guide 1.203 to perform this review.

23 And the staff performed their own
24 independent PIRT, Phenomenon Identification and
25 Ranking Table, evaluation, and compared it to

1 NuScale's that they had performed.

2 The staff also reviewed the computational
3 tools used. NRELAP5 was used for the thermal
4 hydraulic response only. SIMULATE was used for their
5 neutronics calculations, and then a MATLAB script was
6 used to input all of the calculational framework for
7 their transport methodology, and that's how they
8 transport boron throughout the system.

9 The staff reviewed the NRELAP5 test
10 assessment basis. This included reinterval effects
11 tests, a long-term cooling test, and LOCA ECCS tests,
12 and then a non-LOCA test which was mainly a DHRS test
13 at the NIST-2 facility, and the staff reviewed the
14 validation and the associated uncertainties as shown
15 through those test comparisons between the NRELAP
16 predicted predictions versus the test data.

17 So, and the staff also reviewed the
18 construction and development of the long-term cooling
19 thermo-hydraulic model, and that model was based off
20 of the short-term LOCA base model, and then with some
21 adjustments to make it into the long-term cooling
22 model, some things to make it run a little bit
23 smoother, and the validation basis for that comparison
24 that staff review was about.

25 In the XPC topical report, there's a lower

1 riser hole flow assessment that's required to ensure
2 that you get adequate lower, that you're actually
3 calculating adequate lower riser hole modeling, and
4 the staff reported an evaluation of that as well.

5 And the staff also reviewed particular
6 events that were considered for collapsed liquid
7 level, heat removal capability, and the boron
8 transport for subcriticality and precipitation.

9 DR. MARTIN: This is Member Martin. We'll
10 talk about this more in the closed session. The
11 MATLAB model is obviously something a bit different
12 than NRELAP5 and SIMULATE5 because, you know, a lot of
13 history with those other codes. Once you just kind of
14 describe your approach to reviewing that, it's going
15 to require maybe a little bit more intention than the
16 other two.

17 MR. BARRETT: Yeah, as far as the review,
18 the staff requested disks that contained the RELAP
19 models, as well as the MATLAB scripts that were used,
20 so we got those in-house and we exercised them in
21 detail from the various sensitivity studies.

22 DR. MARTIN: So, it wasn't just a
23 qualitative review?

24 MR. BARRETT: Correct.

25 DR. MARTIN: There was some quantitative,

1 okay.

2 MR. BARRETT: So, we can actually check to
3 see that they actually implemented what they were.

4 DR. MARTIN: Okay, appreciate that.

5 MR. BARRETT: Can we go to the next slide?
6 We kind of discussed it already a little bit. We
7 reviewed the boron transport subcriticality
8 methodology concentrating on the thermal hydraulic
9 conditions as well as the mixing model assumptions for
10 assuming.

11 We also did the critical boron equation,
12 and it's going to operate less than the critical boron
13 concentration which obviously tells you your margin to
14 recriticality.

15 And similarly, we provided the same sort
16 of review for the boron transport and precipitation
17 methodology analysis, which is very similar to the
18 transport subcriticality methodology except for
19 getting the boron basically in one particular area.

20 MR. BLEY: Excuse me, this is Dennis Bley.
21 Could you speak a little slower? Coming over Teams,
22 it's blurring a little and it's hard to understand.

23 CHAIR KIRCHNER: Just pull it closer to
24 you.

25 MR. BARRETT: Okay, does that sound a

1 little bit better?

2 MR. BLEY: It does.

3 MR. BARRETT: Okay, so the boron transport
4 precipitation methodology was reviewed similarly to
5 how the boron transport subcriticality methodology was
6 reviewed, and some of the similar comments I made
7 earlier to Member Martin, except for the boron
8 precipitation methodology was geared towards
9 collecting all of the boron in one particular
10 location, and so you can compare it back to the
11 solubility limit for precipitation. Can we go to the
12 next slide?

13 So, Dave mentioned earlier that there were
14 some differences in the safety evaluation between what
15 you saw before and what you were just presented with,
16 one of which was the updated nuclear reliability
17 factor review portion, which is we just got the
18 response.

19 As Dave stated, we were still under
20 review, and then there were two limitations and
21 conditions added. One was requiring enough boron to
22 account for the integral down powers and pre-transient
23 operational histories to include xenon impacts as well
24 as low decay heats.

25 And in addition, there is another

1 limitation and condition that was added, and this one
2 was with respect to boron precipitation, and this was
3 to require that the zero power maximum operational
4 limit for boron concentration will be used as the
5 initial condition in the RPV to help account for some
6 uncertainties. Go to the next slide, Dave?

7 So, for the limitations and conditions,
8 for limitation and condition one, changes to the
9 short-term LOCA or non-LOCA topical reports will
10 require changes to the XPC topical report, so that
11 would have to be looked at.

12 For limitation and condition number two,
13 it's applicable only to the US460 and NPM-20 based off
14 of how the review was performed and how the PIRT was
15 performed.

16 Number three, you have to maintain
17 insignificant non-condensable gas in containment for
18 evaluate the amount of non-condensable gases in
19 containment in your subcriticality methodology.

20 Number five, the methodology was limited
21 to 72 hours and does not include post-event recovery
22 actions. Limitation and condition number six, the RVV
23 compressible flow qualification is going to have to be
24 a part of the ASME QME-1 qualification in the
25 application.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Limitation and condition number seven,
2 there must be an initial test program, first module
3 only, for dissolution testing so that you can account
4 for the different boron dissolution rates,
5 condensation rates, et cetera.

6 CHAIR KIRCHNER: Antonio, if I could
7 interrupt there just in the open session, what's your
8 expectation? How will they measure in that initial
9 test program the boron dissolution to your
10 satisfaction?

11 MR. BARRETT: Yeah, so --

12 CHAIR KIRCHNER: What are you looking for,
13 for metrics?

14 MR. BARRETT: Yeah, so it's going to be
15 consistent with the evaluation model. So, they make
16 certain assumptions or predictions about what happens
17 with condensation and condensation flow rates, and
18 they have the different mechanical designs set up to
19 get the condensate, have it go certain places.

20 So, I would imagine like a steam test over
21 varying conditions that would then validate how much
22 you collect, where it collects, how it's able to
23 dissolve a certain amount of boron, does it or does it
24 not, versus what was assumed in the analysis and then
25 overall, the mixing portion in terms of the vault

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 water container.

2 CHAIR KIRCHNER: You're seeing these as
3 nuclear driven tests, by which I mean you have nuclear
4 heating tested?

5 MR. BARRETT: I do not. I think it's --
6 as long as you get the steam, I think that would be
7 the most important part of the test.

8 CHAIR KIRCHNER: Okay, so they already
9 would use an auxiliary boiler kind of setup to bring
10 the module up to some temperature where they can
11 safely pull rods, but okay, how are you going to
12 measure this?

13 MR. BARRETT: Yeah, so it should be just,
14 in my opinion, my view, it would be just a dissolution
15 rate. So, if your collection is setup appropriately,
16 you would collect the amount of condensate per
17 whatever steam rate that you have, and then it would
18 dissolve the boron at a certain rate. And if you're
19 assuming, for example, in the analysis, that you're
20 not getting that dissolution rate, then there would be
21 a mismatch there.

22 CHAIR KIRCHNER: But the easy part is the
23 dissolution of the actual boron, I shouldn't use the
24 word pellets, whatever their geometric form is in the
25 basket. That's the easy part. Where does the boron

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 go? Is that what you're looking for?

2 MR. BARRETT: No, so the easy part is
3 definitely, I guess, a main portion of it. The second
4 part would be you have your mixing tubes, and whether
5 or not --

6 CHAIR KIRCHNER: Right.

7 MR. BARRETT: -- you're actually getting
8 that sort of mixing. So, what we would think you
9 would do is something similar to like a gradient,
10 concentration gradient. Does it actually -- are you
11 getting that sort of mixing flow through the tubes
12 that you expected?

13 CHAIR KIRCHNER: So, they would have to
14 design a probe that would be in the downcomer region
15 and/or the containment downcomer region to --

16 MR. BARRETT: That would be one way. I
17 think that you could do some sampling at different
18 elevations potentially over time, but I think there's
19 a lot of different ways that you can do it, but I
20 don't see it as being overly complex.

21 CHAIR KIRCHNER: So, let me take it one
22 step further. Would this eventually show up as an
23 ITAC then in a COL application?

24 MR. BARRETT: Yeah, so right now, I think
25 we asked this question as part of the SDAA design and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 now it's part of their initial test program.

2 CHAIR KIRCHNER: Okay.

3 DR. PALMTAG: This is Scott Palmtag. Just
4 to follow up on that, I'm kind of curious, how would
5 they get steam into the containment vessel? Is that
6 something you imagine doing offline at some facility
7 or doing it actually when they build the first,
8 install the first module?

9 MR. BARRETT: Yeah, I imagine it's when
10 they actually install the first module, but yeah, like
11 I think Dr. Kirchner was saying, like you could either
12 use the ox boiler if it was able to give you the steam
13 levels that you want. I think probably maybe you
14 might be a little bit more interested in the lower
15 steam levels, but as long as you can get the steam in
16 there somehow, I think that would be good enough.

17 DR. PALMTAG: How would you do that? I'm
18 just trying to figure out the piping. I mean, I don't
19 know all of the piping, but you have your reactor
20 pressure vessel. You'd have to open those valves to
21 let the steam into the containment or in the --

22 MR. BARRETT: No, I don't think you
23 actually -- I think that's one way you could do it,
24 but a different way would be you can just put the
25 steam directly in. We're not talking about nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 heating.

2 We don't even necessarily need you to
3 simulate an ECCS blow valve per se. You don't
4 necessarily have to, but if you're going to have a way
5 to just put the steam in, I think that that would be
6 one, and so it doesn't have to be overly --

7 DR. PALMTAG: Just when you have -- we're
8 not talking a special test facility. We're actually
9 talking about the real containment vessel.

10 MR. BARRETT: Yes.

11 DR. PALMTAG: Is there -- maybe this is
12 something I can ask NuScale, but is there available
13 piping that they could dump the steam into the
14 containment vessel?

15 CHAIR KIRCHNER: They have a containment
16 fill and drain system, so my sense would be that would
17 be used. Go ahead.

18 MR. NOLAN: This is Ryan Nolan from the
19 staff. And so, the staff wasn't too focused on how
20 you get the steam into containment, but our
21 understanding is right now that there's a module heat-
22 up system that they would use to bring the RCS up to
23 pressure and temperature, right.

24 And so, you would use that system and then
25 you could open the vent valves, which would then

1 create steam inside the containment, or they could
2 scope out a temporary system. We weren't really
3 overly concerned with how you get steam into
4 containment, but as of right now, I believe that's the
5 structure that was proposed with the initial testing.

6 DR. PALMTAG: Yeah, I understand it's easy
7 to define this, but I'm curious when the NuScale
8 people come back up, I'm kind of curious how they're
9 actually doing this because if you're -- I mean,
10 you're limited by your piping that's in there.

11 MR. NOLAN: Right, so as of right now,
12 this is part of the initial test program, so Chapter
13 14 does include Revision 2 of the FSAR will include a
14 test that describes how to perform this.

15 MR. BARRETT: So, limitation and condition
16 eight is approved for the NRELAP5 Version 1.7 in
17 conjunction with Basemodel Rev. 5 with allowable, you
18 know, change processes, allowable change processes.

19 Limitation and condition nine, you've got
20 to have a separate approval required for single
21 failures, electric power assumptions, and operator
22 actions, which would be a part of the downstream
23 application. Dave, can you go to the next slide?

24 And the last two, as we discussed earlier,
25 a limitation and condition to account for integral

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 down powers and xenon low decay heat for
2 subcriticality analyses, and limitation and condition
3 number 11, where you have zero power maximum
4 operational limit, no xenon, at the beginning of cycle
5 where initial conditions warrant more precipitation
6 analyses.

7 DR. PALMTAG: This is Scott Palmtag again.
8 So, I have some questions about ten and 11. So, in a
9 lot of calculations, your core calculation where you
10 have to do your cycle limits, you have to show that
11 you have shutdown capability for all kinds of other
12 limits. Is this meant to be more of a bounding
13 analysis that you're going to set some limit for the,
14 I guess, minimum boron concentration that's going to
15 handle all cycles or is it something that's going to
16 have to be shown on a cycle by cycle basis?

17 MR. BARRETT: Yeah, so I think we can get
18 into it a little bit more in the closed session, but
19 I think there will be -- what we envision is there's
20 something that's done -- well, I think it's already --
21 in response to XPC-6, NuScale already put in like a
22 curve, if you will, that will then be placed into the
23 cooler that will probably generally cover most cycles,
24 but can be updated if you wanted to get more margin
25 like, you know, that considers like your power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 ascension rate and things of that nature.

2 DR. PALMTAG: I'm just a little concerned
3 about having some bounding analysis because everything
4 has been done on an equilibrium core, right, so as you
5 know, cycle one is going to be completely different
6 and you never quite get to the equilibrium core.
7 There might be fuel changes and everything that goes
8 along the way.

9 I'm not sure that there's been enough
10 analysis. The equilibrium core analysis can really
11 cover cores. I would think this would have to be
12 something that would have to be shown for each core
13 design.

14 MR. BARRETT: Yeah, so currently, it's in
15 the cooler right now, so I assume that it will be done
16 for every core design, but that's a part of their tech
17 spec that they currently presented to us. We can show
18 it maybe later, but, so.

19 DR. PALMTAG: Yeah, and you probably will
20 not be able to answer this, but you have an
21 operational minimum boron concentration is the way I
22 understand this. Won't this -- maybe it's a small
23 amount, but won't this significantly affect core
24 operations and cycle length?

25 MR. BARRETT: No, this is just so that you

1 can do your precipitation analysis with additional
2 boron. That's it. So, this is not an actual -- if
3 you're talking about 11, there is not an actual limit
4 on operation or anything of that nature.

5 We're just saying when you're at zero
6 power, no xenon, boron concentration, you're at a very
7 high boron concentration, you have to deborate to kind
8 of go through your cycle, right? So, we're just
9 saying if you use it as your initial condition just
10 when you do the analysis to add some conservatism, and
11 this is how they already currently do the analysis,
12 then you must have this additional boron to account
13 for uncertainties.

14 DR. PALMTAG: I guess I'm not really --
15 I'm not sure I understand that. So, as you deplete
16 your cycle, at the end of the cycle, you're going to
17 be at zero boron, and then, but that won't be sort of
18 sufficient? There's going to have to be an additional
19 boron concentration above that zero boron?

20 MR. BARRETT: No, so I think maybe I, when
21 I was talking about ten and the limits and whatnot,
22 that's kind of a different thing. So, going down to
23 L&C number 11, only when you perform your boron
24 precipitation analyses, which means that the more
25 boron you have, the worse off you are, the worse, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 know, the closer you are to your solubility limit.

2 DR. PALMTAG: Okay.

3 MR. BARRETT: So, forgetting about
4 everything else and just putting some boron --

5 DR. PALMTAG: Okay, this is specifically
6 precipitation?

7 MR. BARRETT: Correct, yeah.

8 DR. PALMTAG: All right, thank you.

9 MR. CODDINGTON: This is Taylor
10 Coddington. So, it's effectively, for the boron
11 precipitation analysis, use a conservative method is
12 effectively finished or the limitation is trying to be
13 established.

14 DR. PALMTAG: Right, I misunderstood. I
15 didn't realize it was for precipitation. I thought
16 there would be a minimum boron limit in the core for
17 criticality purposes, but we can get into that in the
18 closed session.

19 MR. BARRETT: All right, Dave, can you go
20 to the next slide? I think that's the end. So, the
21 staff believes the applicant has provided sufficient
22 information to support this safety finding.

23 The staff found what the applicant
24 represents in this topical report satisfies the
25 limitations and conditions and will meet relevant

1 regulatory requirements pending review and approval of
2 the application. Thank you very much for your time.
3 If there's any more questions, I'll take those.

4 CHAIR KIRCHNER: Members, questions or
5 you're just saving everything for this afternoon?
6 Okay, all right, with that then, if there are no
7 further questions, let me take this opportunity to see
8 if we have any comments from the public either here in
9 our room or online. Just if you're online, unmute
10 your microphone, state your name and affiliation as
11 appropriate, and make your comment.

12 In the room here, I think we have all
13 staff and applicant with us, so I am not hearing
14 anyone wishing to make a public comment. We're going
15 to adjourn, not adjourn, but we're going to close the
16 open session and we will return at 1:00 Eastern Time
17 for the closed sessions, and those of you who are
18 authorized will have the Teams link to join us. So,
19 we are recessed until 1:00.

20 (Whereupon, the above-entitled matter went
21 off the record at 12:03 p.m.)
22
23
24
25

February 26, 2025

Docket No. 052-050

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Material Entitled "ACRS Subcommittee Meeting (Open Session) Non-Loss-of-Coolant Accident Topical Report and Extended Passive Cooling and Reactivity Control Methodology Topical Report," PM-179845, Revision 0

The purpose of this submittal is to provide presentation materials for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Subcommittee Meeting on March 4th, 2025. The materials support NuScale's presentation of the subject topical reports for the US460 Standard Design Approval Application.

The enclosure to this letter is the nonproprietary presentation entitled "ACRS Subcommittee Meeting (Open Session) Non-Loss-of-Coolant Accident Topical Report and Extended Passive Cooling and Reactivity Control Methodology Topical Report," PM-179845, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Amanda Bode at 541-452-7971 or at abode@nuscalepower.com.

Sincerely,



Mark W. Shaver
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Mahmoud Jardaneh, Chief New Reactor Licensing Branch, NRC
Getachew Tesfaye, Senior Project Manager, NRC
Michael Snodderly, Senior Staff Engineer, Advisory Committee on Reactor Safeguards, NRC
Thomas Hayden, Project Manager, NRC
David Drucker, Senior Project Manager, NRC

Enclosure 1: ACRS Subcommittee Meeting (Open Session) Non-Loss-of-Coolant Accident
Topical Report and Extended Passive Cooling and Reactivity Control
Methodology Topical Report," PM-179845, Revision 0, Nonproprietary

Enclosure 1:

ACRS Subcommittee Meeting (Open Session) Non-Loss-of-Coolant Accident Topical Report
and Extended Passive Cooling and Reactivity Control Methodology Topical Report,"
PM-179845, Revision 0, Nonproprietary



ACRS Subcommittee Meeting

(Open Session)

March 4, 2025

Non-Loss-of-Coolant
Accident Topical Report and
Extended Passive Cooling
and Reactivity Control
Methodology Topical Report



ACRS Subcommittee Meeting

(Open Session)

March 4, 2025

Non-Loss-of-Coolant Accident Topical Report

Presenters: Kevin Lynn, Meghan McCloskey, Ben Bristol

Acknowledgement and Disclaimer

This material is based upon work supported by the Department of Energy under Award Number DE-NE0008928.

This presentation was prepared as an account of work sponsored by an agency of the United States (U.S.) Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.


Agenda

- Non-loss-of-coolant accident (non-LOCA) topical report history
- Non-LOCA evaluation model (EM) analysis purpose, transient class, acceptance criteria
- Relevant power uprate design and operating changes
- Summary of EM applicability assessment and updates

Non-LOCA Topical Report History

- Non-LOCA topical report Revision 3 was approved by NRC in 2020
- Approved Revision 3 was used in Final Safety Analysis Report (FSAR) analyses for US600 (with NPM-160) design that has been certified
- Approved Revision 3 contained limitations and conditions (L&Cs) restricting use to NPM-160 design
- Revision 4 was submitted in January 2023 along with FSAR for US460 (with NPM-20)
- Updates to Revision 4 have been made since January 2023 in response to NRC questions
- Revision 5 will incorporate these updates, but has not been submitted at this time
- Focus of discussion today is changes since prior NRC approval of Revision 3


Non-LOCA EM: Analysis Purpose, Transient Class, Acceptance Criteria



→ Scope consistent with the NRC-approved Revision 3


Power Uprate and Design Changes Summary NPM-160 to NPM-20

- Power uprate from 160 MWt to 250 MWt
- Module SSC design essentially maintained
- Operating conditions
 - Increased primary pressure from 1850 psia to 2000 psia
 - Primary and secondary side design pressures increased from 2100 psia to 2200 psia
 - Use T_{avg} control instead of T_{hot} control (T_{avg} changed from ~545°F to 540°F)
 - Decreased secondary side feedwater temperature at 100% power from 300°F to 250°F
 - Reduced minimum temperature for criticality from 420°F to 345°F
- Module protection system (MPS) actuations optimized for US460 design
 - Adjusted to accommodate modified operating conditions
 - Added reactor trip on high T_{avg} to terminate slower reactivity transients earlier (e.g., reactivity transient initiated from lower power)
 - Additional decay heat removal system (DHRS) actuations – for any containment vessel (CNV) isolation signal during power operation
 - Pressurizer line isolation on low pressurizer pressure




Pressure/Temperature Operation and Limit Changes

US600 (Certified Design)



US460 (Design currently under review)



Analytical Assumptions for Non-LOCA Analysis

Approach from NRC-approved Revision 3 methodology maintained:

Scope of event progression	Safety analyses of design-basis events are performed from event initiation until a safe, stabilized condition is reached
Operator action	No operator actions required to achieve safety functions for 72 hours after an initiating event occurs
Loss of power	Evaluate whether power available, loss of alternating current (AC) power, or loss of AC and direct current (DC) power is more limiting
Nonsafety-related module or plant control systems	<ul style="list-style-type: none">• Operation of nonsafety-related control system that leads to a less severe plant response is not credited• Operation of nonsafety-related control system that leads to a more severe plant response is assumed
Nonsafety-related SSC credited	<ul style="list-style-type: none">• Nonsafety-related secondary main steam isolation valves (MSIVs) and feedwater (FW) regulating valves serve as backup for safety-related valve single failure• Nonsafety-related check valves in FW piping serve as backup for safety-related check valve failure

Non-LOCA EM Updates

- Design changes have no substantial change in non-LOCA event progressions or important phenomena
 - Reactor pressure vessel (RPV) pressure protected by reactor safety valve (RSV) lift
 - Secondary pressure protected by design pressure equal to RPV design pressure, physically limited to saturation pressure at maximum primary hot side temperature
 - Minimum critical heat flux ratio (MCHFR) limited under high power, high temperature conditions (e.g., reactivity insertion events)
- Non-LOCA phenomena identification and ranking table (PIRT) from NPM-160 remains applicable
- Current EM employs NRELAP5 v1.7 (NRC-approved Revision 3 used NRELAP5 v1.4)
- NRELAP5 assessment basis expanded with NIST-2 steam generator (SG)-DHRS tests
- Methodology changes for event-specific analyses
 - Provided additional detail on when more extensive sensitivity calculations performed
 - Dependent on margin to acceptance criteria – more sensitivity studies needed where margin is smaller
 - Generally expanded scope to vary parameters rather than bias in only one direction
 - Option for radiological analyses to use bounding input rather than transient-specific input
 - Option to demonstrate control rod drop analyses bounded by single rod withdrawal or steady-state conditions
 - Option to use increase in level during boron dilution events to determine shutdown margin at event termination
- Conclusion: EM remains adequate to evaluate an NPM design

Questions?

Acronyms

AC	Alternating current
CNV	Containment vessel
DC	Direct current
DHRS	Decay heat removal system
EM	Evaluation model
FSAR	Final safety analysis report
FW	Feedwater
L&C	Limitation and condition
LOCA	Loss-of-coolant accident
MCHFR	Minimum critical heat flux ratio
MPS	Module protection system
MSIV	Main steam isolation valve
NIST	NuScale Integral System Test Facility
Non-LOCA	Non-loss-of-coolant accident
NPM	NuScale Power Module
PIRT	Phenomena identification and ranking table
RPV	Reactor pressure vessel
RSV	Reactor safety valve
SG	Steam generator
SSC	Structures, systems, and components
T_{avg}	Average temperature
T_{hot}	Hot temperature



ACRS Subcommittee Meeting

(Open Session)

March 4, 2025


Extended Passive Cooling and Reactivity Control Methodology Topical Report

Presenters: Thomas Case, Meghan McCloskey, Ben Bristol

Agenda

- Evaluation model (EM) scope, regulations, acceptance criteria
- NuScale Power Module (NPM) design features
- Phenomena identification and ranking table (PIRT) evolution
- EM structure
- EM validation basis
- EM adequacy assessment and conclusions

NPM Extended Passive Cooling and Reactivity Control Scope




- New topical report to support 250 MWt NPM design and US460 submittal
- Regulations:
 - 10 CFR 50.46(b)(4) and (5)
 - Principal design criterion (PDC) 35 – emergency core cooling
 - PDC 34 – residual heat removal
 - General design criterion (GDC) 26, GDC 27 – reactivity control and subcriticality, normal operation or following anticipated operation occurrences (AOOs) or accidents
 - Supports application exemptions to GDC 33 for system with safety function to provide makeup in response to reactor coolant pressure boundary leakage

Extended Passive Cooling (XPC) Figures of Merit

Safety Objective	Acceptance Criteria
Provide decay and residual heat removal	Collapsed liquid level remains above top of core
Reactivity control	Core remains subcritical
Maintain coolable geometry	Boron concentration remains below precipitation limits
Key assumptions/requirements: <ul style="list-style-type: none">- Demonstrate subcriticality ($k_{eff}<1$) with highest worth control rod withdrawn from core- Demonstrate acceptance criteria met for at least 72 hours	

NPM Design – Long-term ECCS Collapsed Level


- After emergency core cooling system (ECCS) actuation, decay and residual heat generate vapor and energy transferred to reactor pool ultimate heat sink:
 - ECCS recirculation and condensation on containment wall, heat transfer through vessel wall
 - Steam generator (SG)-decay heat removal system (DHRS) operation with condensation on outside of SG tubes
- During ECCS long-term cooling, reactor coolant distributes between reactor pressure vessel (RPV) and containment vessel (CNV)
- Distribution of reactor coolant depends on
 - ECCS venting capacity and demand
 - Containment heat transfer capacity



NPM Design – Long-term ECCS Collapsed Level


Minimum Level Conditions

High CNV wall heat transfer




Maximum Temperature Conditions

Low CNV wall heat transfer





NPM Design Features – Boron Transport Method Applicability

- ECCS actuation designed for core cooling and reactivity control
- Upper riser flow paths between riser and downcomer
 - Sustain liquid flow over the SG for decay heat removal after riser uncover
 - Maintain boron transport during DHRs operation
- Lower riser flow paths between riser and downcomer
 - Maintain boron transport during ECCS operation



NPM Design Features – Boron Transport Method Applicability (continued)

- ECCS supplemental boron (ESB) feature
 - Passive design feature to maintain subcriticality during design basis extended passive cooling
 - Boron oxide (B_2O_3) pellets in dissolver basket(s)
 - Mixing tube(s) in containment
 - Condensate collection channels to dissolver basket(s) and mixing tube(s)



PIRT Evolution for XPC

- Previously developed PIRTs for NPM-160 long-term ECCS or DHRS cooling were re-assessed holistically, expanded as needed due to
 - ESB design changes
 - Requirement to maintain subcriticality

Design Certification Application (DCA) NPM-160 Design		Standard Design Approval Application (SDAA) CORE250B/NPM-20 Design	
Phase	Figure of Merit (FOM)	Phase	FOM
Loss-of-coolant accident (LOCA) long-term cooling (LTC) Phase 2 Period beginning after reactor recirculation valve (RRV) flow direction reverses and flows from CNV to RPV	Critical heat flux ratio (CHFR); Collapsed liquid level (CLL); Subcriticality	ECCS Phase 2 Period beginning after RRV flow direction reverses and flows from CNV to RPV	CLL; Subcriticality; Coolable geometry
Non-LOCA Phase 3 Stable natural circulation	CHFR; Mixture level (phase 3, 4); Subcriticality	DHRS Phase 3 Stable natural circulation	
Non-LOCA Phase 4 Intermittent natural circulation		n/a	n/a
Non-LOCA Phase 5 Interrupted natural circulation		n/a	n/a

EM Structure

- NRELAP5 thermal-hydraulic analysis
 - Evaluate collapsed liquid level above top of fuel and containment response
 - Minimum level conditions
 - Maximum temperature conditions
 - Provide boundary conditions for boron transport
- SIMULATE5 core reactivity analysis
 - Provide critical boron concentrations
 - Evaluate range of operating cycle exposures, operating histories, thermal-hydraulic conditions
- Boron transport analysis
 - Implemented in MATLAB scripts or other appropriate computational script
 - Map NRELAP5 conditions to critical boron concentration from SIMULATE5 to demonstrate subcriticality
 - Evaluate maximum concentration to demonstrate margin to precipitation concentrations

EM Validation Basis

- NRELAP5 validation
 - Builds on validation basis for LOCA and non-LOCA EMs
 - Additional validation against NIST-2 LTC and LOCA tests
- Boron dissolution validation
 - Separate effects tests performed
 - Methods for slow or fast-biased dissolution assessed against test data
- SIMULATE5
 - Extensive validation basis developed for other applications
 - Nuclear reliability factor (NRF) for XPC conditions evaluated and included in critical boron concentration
- Boron transport
 - Relies on thermal-hydraulic input
 - Conservative treatment of phenomena specific to boron transport

EM Adequacy Assessment and Conclusions

- Adequacy assessment evaluated from bottom-up and top-down perspectives
 - Models and correlations in NRELAP5 or phenomena treatment in boron transport considered
 - Top-down assessments considered NIST-2 integral tests and overall approach/conservatism in the EM
- Adequacy assessment discusses limitations in the models and correlations
- EM requires conservative or bounding approaches to address limitations in models and correlations

Conclusion:

- EM provides conservative method to demonstrate that an NPM, with specified design features, provides adequate core cooling and decay heat removal, remains subcritical following design basis events, and maintains coolable geometry.

Questions?

Acronyms

AOO	Anticipated operational occurrence	RCS	Reactor coolant system
CHFR	Critical heat flux ratio	RPV	Reactor pressure vessel
CLL	Collapsed liquid level	RRV	Reactor recirculation valve
CNV	Containment vessel	RVV	Reactor vent valve
DCA	Design certification application	SDAA	Standard design approval application
DHRS	Decay heat removal system	SG	Steam generator
ECCS	Emergency core cooling system	XPC	Extended passive cooling
EM	Evaluation model		
ESB	ECCS supplemental boron		
FOM	Figure of merit		
GDC	General design criterion/criteria		
LOCA	Loss-of-coolant accident		
LTC	Long-term cooling		
NIST	NuScale Integral System Test Facility		
Non-LOCA	Non-loss-of-coolant accident		
NPM	NuScale Power Module		
NRF	Nuclear reliability factor		
PDC	Principal design criterion/criteria		
PIRT	Phenomena identification and ranking table		

Presentation to the ACRS Subcommittee Staff Review of NuScale Licensing Topical Reports

TR-0516-49416, Rev. 4, Non-LOCA Analysis Methodology
TR-124587, Rev. 0, XPC Methodology

**March 4, 2025
(Open Session)**

Presentation to the ACRS Subcommittee of the Staff's Review of NuScale Non-Loss-of-Coolant Accident Analysis Methodology, TR-0516-49416, Rev 4.

**March 4, 2025
(Open Session)**

NuScale Non-LOCA LTR Review

Contributors

- **Technical Reviewers**

- *Zhian Li, NRR/DSS/SNRB
- Antonio Barrett, NRR/DSS/SNRB
- Adam Rau, NRR/DSS/SNRB
- Peter Lien, NRR/DSS/SNRB
- Ryan Nolan, NRR/DSS/SNRB
- Sean Piela, NRR/DSS/SNRB
- Carl Thurston, NRR/DSS/SNRB
- Dong Zheng, NRR/DSS/SNRB
- Joshua Miller, NRR/DSS/SNRB
- Rosie Sugrue, NRR/DSS/SNRB

* Non-LOCA LTR review lead

- Upendra Rohatgi, RES consultant
- Andrew Dyszel, SNRB contractor
- Marvin Smith, SNRB contractor

- **Project Managers**

- Thomas Hayden, NRR/DNRL/NRLB
- Getachew Tesfaye, Lead, NRR/DNRL/NRLB

NuScale Non-LOCA LTR Review

Overview

- NuScale submitted the Non-Loss-of-Coolant Accident (Non-LOCA) Evaluation Model Topical Report (TR-0516-49416-P), Rev. 4 on January 5, 2023. The topical report was formally accepted for review on July 31, 2023.
- NRC conducted an audit of the topical report from March 2023 to August 31, 2024.
- 49 audit issues were resolved in the audit
- For items not resolved during the audit, 7 RAIs were generated
- 1 RAI remains Open
- There are 2 significant differences between the draft SER submitted to ACRS on February 4, 2025, and the draft SER published on February 26, 2025

NuScale Non-LOCA LTR Review

Open Item(s)

- 1 Open Item remaining
- RAI Non-LOCA.LTR – 50
 - Issue description:
 - Staff is working to understand changes made to NRELAP5 (v1.7) and the NPM basemodel:
 - Modeling changes to DHRS models
 - Modeling of core flow distribution
 - Path forward:
 - NRC and NuScale continue to discuss these modeling changes and have high confidence the issue will be resolved shortly, with minimal impact to the SE

NuScale Non-LOCA LTR Review

Significant differences between previously submitted SER

- 2 significant differences
 - Section 3.5.3.7, “NIST-2 Steam Generator – Decay Heat Removal System (DHRS) Integral Effects Test”
 - Expanded explanation of NIST-2 DHRS scalability
 - Due to closure of Open item RAI NonLOCA.LTR-3,9,18,19,20,21,69
 - Section 3.9, “Quality Assurance” and Section 4.0, “Limitations and Conditions”
 - Removed Limitation and Condition No. 10
 - Inserted finding of reasonable assurance related to the implementation of Quality Assurance controls consistent with RG 1.203 for the Non-LOCA EM

NuScale Non-LOCA LTR Review

Changes from LTR Rev. 3 (NPM-160) to LTR Rev. 4 (NPM-20)

- Considered design changes from NPM-160 to NPM-20
- Applicability of Phenomenon Identification and Ranking to NPM-20
- Use of bounding assumptions for primary coolant release in the radiological analysis instead of calculating primary side mass release
- Updated critical heat flux (CHF) screening for subchannel analyses
- Updated initial conditions and biasing scheme for each Non-LOCA event

NuScale Non-LOCA LTR Review

Changes from LTR Rev. 3 (NPM-160) to LTR Rev. 4 (NPM-20)

- NRELAP5 revised to version 1.7
- NRELAP5 basemodel updated for NPM-20, some system models updated
- Updated DHRS information with new tests (used in Non-LOCA, LOCA, XPC LTRs)
- NIST-2 tests for validation of NRELAP5 for DHRS performance
- Test results and code predictions of oscillation
- Reviewed scaling and distortion
- Long-term progression of non-LOCA events is covered in the XPC LTR

NuScale Non-LOCA LTR Review

Limitations and Conditions

- 1) Applicable to NPM-20 only
- 2) Changes to LOCA LTR may require changes to Non-LOCA LTR
- 3) Types of analyses approved for Non-LOCA EM
- 4) DHRS heat transfer uncertainty
- 5) Credit for Non-Safety MSIVs
- 6) Separate approval required for single failures, electric power assumptions and operator actions
- 7) Approved for NRELAP5v1.7 in conjunction with NPM-20 basemodel Rev. 5
- 8) Separate approval required for analytical limits and actuation delays; Applicant must assess for changes to event-specific bias directions
- 9) Separate approval required for inputs to radiological consequence analysis not derived from transient analyses

NuScale Non-LOCA LTR Review

Conclusions

- While there are some differences between the current and previous revision, the staff found that the applicant provided sufficient information to support the staff's safety finding.
- The staff found that an applicant that references this topical report with the limitations and conditions will meet relevant regulatory requirements pending review and approval of the application.

NuScale Non-LOCA LTR Review

Questions?

Presentation to the ACRS Subcommittee of the Staff's Review of NuScale's Extended Passive Cooling and Reactivity Control Methodology (XPC) Topical Report, TR-124587, Revision 0

**March 4, 2025
(Open Session)**

NuScale XPC LTR Review

Contributors

- **Technical Reviewers**

- *Antonio Barrett, NRR/DSS/SNRB
- Dr Rosie Sugrue, NRR/DSS/SNRB
- Dr John Lehning, NRR/DSS/SNRB
- Dr Adam Rau, NRR/DSS/SNRB
- Dr Peter Lien, NRR/DSS/SNRB
- Carl Thurston, NRR/DSS/SNRB
- Dr Len Ward, SNRB contractor
- Marvin Smith, SNRB contractor

* XPC LTR review lead

- Chis Boyd, RES/DSA
- Jason Thompson, RES/DSA/CRAB II
- Justin Coury, RES/DSA/CRAB II
- Dr Andrew Bielen, RES/DSA/FSCB

- **Project Managers**

- David Drucker, PM, NRR/DNRL/NRLB
- Getachew Tesfaye, Lead PM, NRR/DNRL/NRLB

NuScale XPC LTR Review

Overview

- NuScale submitted the Extended Passive Cooling and Reactivity Control Methodology (XPC) Topical Report, TR-124587, Revision 0 on January 5, 2023. The topical report was formally accepted for review on July 31, 2023.
- NRC conducted an audit of the topical report from March 2023 to August 31, 2024.
- 25 audit issues were resolved in the audit
- For items not resolved during the audit, 8 RAls were generated
- 2 RAls remain open
- Significant differences between the draft SER submitted to ACRS on February 4, 2025, and the draft SER published on February 26, 2025, are discussed in Slide 16

NuScale XPC LTR Review

Open Items

- 2 Open Items remaining
- RAI XPC.LTR – 6
 - Issue description:
 - Staff is working to resolve issues with subcriticality considering downpowers and low decay heat
- RAI XPC.LTR – 21
 - Issue description:
 - Staff is working to resolve issues related to the incorporation of Nuclear Reliability Factors
- Path forward:
 - NRC and NuScale continue to discuss both of these issues and have high confidence they will be resolved shortly, with minimal impact to the SE

NuScale XPC LTR Review

Significant differences between previously submitted SER

- Significant difference
 - Sections 4.8.4, “Critical Boron Concentration Evaluation” and 4.8.7, “Boron Precipitation Methodology Assessment,” explain why Limitation and Condition No. 10 and No. 11 respectively were added
 - Section 5, “Limitations and Conditions”
 - Limitation and Condition No. 10 added to require an applicant to provide technical specification controls to ensure adequate boron concentration is maintained
 - Limitation and Condition No. 11 added to require an applicant use a specific initial boron concentration

NuScale XPC LTR Review

Relevant Changes from NPM-160 (DCA) to NPM-20 (SDAA)

- Long Term Cooling and Reactivity Control
 - DCA LTC Technical Report and FSAR Evaluations
 - SDAA New XPC Topical Report Methodology and new design features
- Criticality Evaluations
 - DCA has return to power under some conditions with evaluations
 - SDAA precludes return to power with use of XPC methodology and design features


NuScale XPC LTR Review

Relevant Changes from NPM-160 (DCA) to NPM-20 (SDAA)

- Revised Reactor Design
 - Increased number of riser holes to promote mixing between the downcomer and riser to help address potential for recriticality
 - Revised Reactor Vent Valve design
 - NPM-160 RVV with IAB
 - NPM-20 RVV without IAB
 - Long Term Cooling enhancements
 - New ECCS Supplemental Boron System (ESB)
 - Riser holes, containment boron addition and containment mixing tubes contribute to boron redistribution and transport during DHRS and ECCS cooling

NuScale XPC LTR Review

Relevant Design Changes from NPM-160 to NPM-20



NuScale XPC LTR Review

Review Highlights

- XPC TR reviewed as an extension of the LOCA and non-LOCA TRs
- Independent Phenomenon Identification and Ranking Table evaluation
- Reviewed computational tools used - NRELAP5, SIMULATE5 and MATLAB
- Reviewed NRELAP5 Test Assessment Basis
 - NIST-2 LTC, LOCA ECCS, Non-LOCA Tests
 - Reviewed validation and uncertainties
- Reviewed NRELAP5 LTC model used for thermal-hydraulic response
 - Reviewed LTC NRELAP5 model validation vs LOCA base model
- Review and evaluation of lower riser hole flow assessment
- Review of evaluated events for collapsed liquid level, DHRS and ECCS heat removal capabilities and boron transport

NuScale XPC LTR Review

Review Highlights

- Review of boron transport subcriticality methodology
 - Thermal hydraulic conditions
 - Boron transport and mixing model assumptions
 - Critical boron concentration and Nuclear Reliability Factors
- Review of boron transport precipitation methodology
 - Thermal hydraulic conditions
 - Boron transport and mixing model assumptions

NuScale XPC LTR Review

Safety Evaluation Report Differences

- Updated Nuclear Reliability Factor review portion
- Add limitation/condition for requiring enough boron to account for integral down powers and xenon impacts for subcriticality analysis applications
- Add limitation/condition to require the zero power maximum operational limit boron concentration (no xenon) at the beginning of cycle is used as an initial condition for precipitation analysis applications

NuScale XPC LTR Review

Limitations and Conditions

- 1) Changes to LOCA or Non-LOCA LTR may require changes to XPC LTR
- 2) Applicable US460/NPM-20 only
- 3) Maintain insignificant non-condensable gas in containment
- 4) Consider the density difference between the borated and unborated liquid
- 5) Methodology limited to 72 hours
- 6) RVV compressible flow qualification
- 7) Initial test program (first module only) for dissolution testing
- 8) Approved for NRELAP5v1.7 in conjunction w/NPM-20 Basemodel Rev. 5
- 9) Separate approval required for single failures, electric power assumptions and operator actions

NuScale XPC LTR Review

Limitations and Conditions

- 10) Account for integral down powers and xenon for subcriticality
- 11) Zero power maximum operational limit boron concentration (no xenon) at the beginning of cycle is used as an initial condition for precipitation

NuScale XPC LTR Review

Conclusion

- The staff found that the applicant provided sufficient information to support the staff's safety finding.
- The staff found that an applicant that references this topical report, and satisfies the limitations and conditions, will meet relevant regulatory requirements pending review and approval of the application.

NuScale XPC LTR Review

Questions?

Meeting Title**Open Session NuScale Subcommittee on
Staff's Evaluation of NuScale Non LOCA and
Extended Passive Cooling Topical Reports****Attendee**

Michael Snodderly	ACRS DFO
Stephen Schultz	ACRS
Larry Burkhart	ACRS
Thomas Dashiell	ACRS
Andrea Torres	ACRS
Patrick King	Court Reporter
Christina Antonescu	ACRS
Tammy Skov	ACRS
Shandeth Walton	ACRS
Sandra Walker	ACRS
Erin Whiting	NuScale
Karl Gross	NuScale
Ron Ballinger	ACRS
Kyle Hoover	NuScale
Amanda Bode	NuScale
Kenny Anderson	NuScale
Wendy Reid	NuScale
Derek Widmayer	ACRS
Nathanael Hudson	RES
Matt Sunseri	ACRS
Dennis Bley	ACRS
Hossein Nourbakhsh	ACRS
Getachew Tesfaye	NRR
Greg Halnon	ACRS
Sarah Turmero	NuScale
Lucas Kyriazidis	RES
Stewart Bailey	NRR
Mahmoud -MJ- Jardaneh	NRR
Gene Eckholt	NuScale
Freeda Ahmed	NuScale
Allyson Callaway	NuScale
David Drucker	NRR
Brian Wolf	NuScale
Adam Rau	NRR
Jason Thompson	RES
Gary Becker	NuScale
Tyler Beck	NuScale
Timothy Polich	RoPower
Ben Bristol	NuScale
Stacy Joseph	NRR
River Rohrman	NRR
Stephanie Garland	ACRS
Vesna Dimitrijevic	ACRS

Peter Lien	NRR
Thomas Hayden	NRR
Adam Brigantic	NuScale
Christopher Boyd	RES
Ken Rooks	NuScale
Rick Rosenstein	NuScale
Dan Lassiter	NuScale
Taha Abdelnaeem	Framatome
Hiroaki Sonoyama	
Marvin Smith	
Eric Baker	NuScale
Andrew Deszel	Numark
Kevin Lynn	NuScale
Thomas Case	NuScale
Ben Bristol	NuScale
Taylor Coddington	NuScale
Thomas Griffith	NuScale
Meghan McCloskey	NuScale
Rebecca Patton	NRC
Antonio Barrett	NRC
Len Ward	Consultant
Kris Cummings	NuScale
Zhian Li	NRR
Adam Rau	NRR
Warren Erling	NRR
Sean Piela	NRR
Rosemary Sugrue	NRR
Andrew Bielen	RES
Justin Coury	RES
Carl Thurston	NRR
Joshua Miller	NRR
Dong Zheng	NRR