

Hoc, HOO X

From: Hover, Margie <mhover@curtisswright.com>
Sent: Tuesday, May 6, 2025 1:51 PM
To: Hoc, HOO X
Cc: Hover, Margie
Subject: [External_Sender] Curtiss-Wright Transmittal DT2522669 (PO# N/A): Response required
Attachments: Rosemount Final Letter 05-06-2025-s.pdf

Workflow Notification


Dear Customer,

Please confirm receipt of attached documentation by replying Yes to this email.

Responding Yes not only confirms your receipt, but also initiates an update of our Submittal/Tracking Transmittal Database.

Thank you.

NOTICE: The documents listed in the DT below will be delivered via attachments to this email.

 Nuclear Division 4600 East Tech Drive, Cincinnati, OH 45245 T: 513.528.7900 F: 513.528.4537	DOCUMENT TRANSMITTAL Number DT2522669	Contract N/A Customer/Vendor Purchase Order Number N/A		
Originated By Hover, Margie	Originated Date 5/6/2025	Project Interim 10CFR Part 21 Report QDC's - Final Letter		
Name	Company	Email		
Headquarters Operation Officer	U.S. Nuclear Regulatory Commission	hoo.hoc@nrc.gov		
Document Number	Rev	Document Type	Qty	For...
Interim 10 CFR Part 21 Report QDC's - Final Letter	N/A	Other	1	Final Record
Remarks				

Contact Information for Originator of Part-21 Notification Final LetterKYLE QUINN Curtiss-Wright Nuclear DivisionDirector of Quality18001 Sheldon Road, Middleburg Heights, OH 44130T +1 216-898-8015 M 216-644-0827kquinn@curtisswright.comU.S. Nuclear Regulatory CommissionATTN NRC Document Control DeskWashington, DC 20555-0001Phone (301) 816- 5100Fax (301) 816-5151	ACKNOWLEDGMENT: Please confirm receipt of the referenced documentation by replying "YES" to the email you received. The referenced documentation will default to a status of UNCONTROLLED if your "YES" reply is not received within 30 days.
Document Control Use Only	
Transmitted By Hover, Margie	Transmitted Date 5/6/2025

020-07-91 Rev. 6

~~This e-mail and any files transmitted with it are proprietary and intended solely for the use of the individual or entity to whom they are addressed. If you have reason to believe that you have received this e-mail in error, please notify the sender and destroy this e-mail and any attached files. Please note that any views or opinions presented in this e-mail are solely those of the author and do not necessarily represent those of the Curtiss-Wright Corporation or any of its subsidiaries. Documents attached hereto may contain technology subject to government export regulations. Recipient is solely responsible for ensuring that any re-export, transfer or disclosure of this information is in accordance with applicable government export regulations. The recipient should check this e-mail and any attachments for the presence of viruses. Curtiss-Wright Corporation and its subsidiaries accept no liability for any damage caused by any virus transmitted by this e-mail.~~

~~For information about how we process personal data and monitor communications, please visit <https://www.curtisswright.com/privacy-notice/default.aspx>~~



Nuclear Division
18001 Sheldon Rd.
Middleburg Heights, OH 44130

Date: May 6, 2025

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

**SUBJECT: FINAL 10CFR21 REPORT REGARDING CUSTOMER CONCERN WITH PARTS
SUPPLIED BY CURTISS WRIGHT MIDDLEBURG HEIGHTS, OHIO**

**Reference: Letter dated March 7, 2025, Subject: Interim 10CFR21 Report Regarding
Customer Concern with Parts Supplied by Curtiss Wright Middleburg Heights, Ohio.**

This letter serves as the final report in accordance with 10CFR21.21 pertaining to a potential issue with parts produced from Curtiss Wright Middleburg Heights supplied to Rosemount. As identified in the Referenced letter, Curtiss Wright was notified by Rosemount on January 7, 2025, that Rosemount had identified five (5) Generation 3 QDCs with continuity issues on at least one pin.

In the referenced interim 10 CFR Part 21 Report dated March 7, 2025, Curtiss-Wright Middleburg Heights had requested an additional 60 days in determining if there is a Part 21 defect that will need to be issued.

Evaluation of reportability in accordance with 10 CFR Part 21 has been completed. All QDC's from this order were shipped to Rosemount only and Rosemount has not supplied to any other customer. Extent of condition and results of the evaluation have concluded that the deviation does not constitute a reportable defect.

The P/N 23066-162 (drawing B-N-23066-162) configuration in question is unique to Generation 3 QDCs provided to Rosemount for attachment to transmitters. There have been no other reported instances of continuity related issues with the Gen 3 QDCs, and this occurrence is isolated to the Gen 3 QDCs provided to Rosemount on this specific order. All questionable Gen 3 QDCs have been scrapped by Rosemount and not provided to any utility.

Records of the Evaluation will be maintained in accordance with 10 CFR 21.51.

Authorized By: *Kyle Quinn*
Kyle Quinn, Quality Director