

Chris Allen

From: Silko, Tom <TSilko@Northstar.com>
Sent: Monday, June 9, 2025 4:19 PM
To: Chris Allen
Subject: [External_Sender] RE: Technical Specification Language Question

The proposed language for Technical Specification C.2 would be appropriate since it would apply to both the VBWR and EVESR containment buildings. The proposed change to Technical Specification C.2 is acceptable.

Thomas B. Silko
Licensing Manager
Vermont Yankee Nuclear Power Station
Vallecitos Nuclear Center
TSilko@northstar.com
(802) 258-8666 (Work / Cell)

From: Chris Allen <William.Allen@nrc.gov>
Sent: Wednesday, June 4, 2025 10:53 PM
To: Silko, Tom <TSilko@Northstar.com>
Subject: Technical Specification Language Question

Caution: This is an external email and may be malicious. Please take care when clicking links or opening attachments.

For Technical Specification C.2 you proposed to replace “*A ventilation particulate monitor shall be operable whenever the containment building is ventilated.*” with “Particulate air monitoring shall be performed in the ventilation pathway whenever the facility containment building is ventilated.” The staff determined that your justification for this change was reasonable and is willing to approve the change. However, since you want to revise Technical Specification A.1 to identify a containment building for both the VBWR and the EVESR reactors, the staff suggests that your proposed Technical Specification C.2 language be slightly modified to read as follows: “Particulate air monitoring shall be performed in the ventilation pathway whenever a facility containment building is ventilated.”

Please let me know at your convenience if this change to the Technical Specification C.2 language is acceptable.

Thanks, Chris

Let us cross the river and rest in the shade of the trees.

Thomas Jonathan Jackson

Confidentiality Note: This e-mail, and any attachment to it, contains privileged and confidential information intended only for the use of the individual(s) or entity named on the e-mail. If the reader of this e-mail is not the intended recipient, or the employee or agent responsible for delivering it to the intended recipient, you are hereby notified that reading it is strictly prohibited. If you have received this e-mail in error, please immediately return it to the sender and delete it from your system. Thank you.