

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

April 16, 1976

Honorable Marcus A. Rowden
Acting Chairman
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: STATUS OF GENERIC ITEMS RELATING TO LIGHT-WATER REACTORS:
REPORT NO. 4

Dear Mr. Rowden:

The Advisory Committee on Reactor Safeguards reported on the "Status of Generic Items Relating to Light-Water Reactors" in its letters of December 18, 1972, February 13, 1974, and March 12, 1975. This is the fourth such report. Since the Committee limits its definitions of generic items to those cited specifically in its letters pertaining to projects and related matters, the attached listing is not all-inclusive; the Nuclear Regulatory Commission Staff list has additional generic items.

Group I of the attachment is a reiteration of the generic items considered resolved at the time the Committee issued its first report. Group IA includes those items resolved between December 1972 and February 1974; Group IB includes those items resolved between February 1974 and March 1975; Group IC includes those items resolved since March 1975. Following each resolved item is a brief statement of the specific action that resulted in the resolution. Group II lists those items included in the original report for which resolution on a generic basis is still pending. Groups IIA and IIB include generic items that were added in the second and third reports; Group IIC includes those added in the present report. The ACRS and the NRC Staff will continue to consider the safety significance of Group II, IIA, IIB and IIC items on a case-by-case basis until generic resolution is reached. Formal actions such as issuance of Regulations or Regulatory Guides are anticipated for many of the Group II, IIA, IIB and IIC items.

April 16, 1976

The NRC Staff considers several of the items on the attached unresolved lists to be "resolved", based on specific positions taken by them; however, these "resolutions" do not meet the ACRS criteria for adequate documentation and for Committee approval so they are considered to be pending until formally discussed and accepted by the ACRS. Items in the above category are:

- (1) II-2 "Effective Operation of Containment Sprays in a LOCA";
- (2) II-4 "Instruments to Detect Fuel Failures";
- (3) II-6 "Common Mode Failures";
- (4) II-9 "The Advisability of Seismic Scram";
- (5) IIA-1 "Pressure in Containment Following LOCA";
- (6) IIA-2 "Control Rod Drop Accidents (BWR)";
- (7) IIA-5 "Rupture of High Pressure Lines Outside Containment";
- (8) IIA-8 "Isolation of Low Pressure from High Pressure Systems";
- (9) IIB-3 "Behavior of BWR Mark III Containments."

Owing to questions raised concerning the scope and intent of various generic issues, the Committee has incorporated into the attachments a brief description for all items unresolved now or at the time of the third report.

"Resolved" as used in the Generic Items reports refers to the following: In some cases an item has been resolved in an administrative sense, recognizing that technical evaluation and satisfactory implementation are yet to be completed. Anticipated Transients Without Scram represents an example of this category. In other instances, the resolution has been accomplished in a narrow or specific sense, recognizing that further steps


Honorable Marcus A. Rowden

-3-

April 16, 1976

are desirable as practical or that different aspects of the problem require further investigation. Examples are the possibility of improved methods of location of leaks in the primary system, and of improved methods or augmented scope to inservice inspection of reactor pressure vessels.

Sincerely yours,

A handwritten signature in cursive script that reads "Dade W. Moeller".

Dade W. Moeller
Chairman

Attachments:

- 1) Group I
- 2) Group IA
- 3) Group IB
- 4) Group IC
- 5) Group II
- 6) Group IIA
- 7) Group IIB
- 8) Group IIC

GENERIC ITEMS

Group I - Resolved Generic Items

1. Net Positive Suction Head for ECCS Pumps: Covered by Regulatory Guide 1.1.
2. Emergency Power: Covered by Regulatory Guides 1.6, 1.9, and 1.32 and portions of IEEE-308 (1971).
3. Hydrogen Control After a Loss-of-Coolant Accident (LOCA): ACRS concurred in proposed Staff position, covered by NRC Standard Review Plan for Nuclear Power Plants.
4. Instrument Lines Penetrating Containment: Covered by Regulatory Guide 1.11 and Supplement.
5. Strong Motion Seismic Instrumentation: Covered by Regulatory Guide 1.12.
6. Fuel Storage Pool Design Bases: Covered by Regulatory Guide 1.13.
7. Protection of Primary System and Engineered Safety Features Against Pump Flywheel Missiles: Covered by Regulatory Guide 1.14.
8. Protection Against Industrial Sabotage: Covered by Regulatory Guide 1.17.
9. Vibration Monitoring of Reactor Internals and Primary System: Covered by Regulatory Guide 1.20.
10. Inservice Inspection of Reactor Coolant Pressure Boundary: Covered by ASME Boiler and Pressure Vessel (BPV) Code, Section XI and Regulatory Guide 1.65.
11. Quality Assurance During Design, Construction and Operation: Covered by 10 CFR 50, Appendix B; ASME BPV Code, Section III; ANSI N-45.2-1971, Regulatory Guides 1.28, 1.33, 1.64, 1.70.6 and Proposed Standard ANS-3.2.
12. Inspection of BWR Steam Lines Beyond Isolation Valves: Covered by ASME BPV Code, Section XI.
13. Independent Check of Primary System Stress Analysis: Covered by ASME BPV Code, Section III.
14. Operational Stability of Jet Pumps: Test and operating experience at Dresden 2 and 3 and other jet pump BWRs have satisfied the ACRS concerns.

Group I Continued

15. Pressure Vessel Surveillance of Fluence and NDT Shift: Covered by 10 CFR 50, Appendix A and Appendix H; and ASTM Standard E-185.
16. Nil Ductility Properties of Pressure Vessel Materials: Covered by 10 CFR 50, Appendix A and Appendix G; ASME BPV Code, Section III; ACRS Pressure Vessel Report.
17. Operation of Reactor With Less Than All Loops In Service: Covered by ACRS-Regulatory Staff position that manual resetting of several set points on the control room instruments under specific conditions and procedures is acceptable in taking one primary loop out of service. This position is based on the expectation that this mode of operation will be infrequent.
18. Criteria for Preoperational Testing: Covered by Regulatory Guide 1.68.
19. Diesel Fuel Capacity: Covered by ACRS-Regulatory Staff position requiring 7 days fuel.
20. Capability of Biological Shield Withstanding Double-Ended Pipe Break at Safe Ends: Covered by ACRS-Regulatory Staff position cited in several letters that such a failure should have no unacceptable consequences.
21. Operating One Plant While Other(s) is/are Under Construction: Specific requirements have been established by ACRS-Regulatory Staff. Position will be prepared.
22. Seismic Design of Steam Lines: Covered by Regulatory Guide 1.29.
23. Quality Group Classifications for Pressure Retaining Components: Covered by Regulatory Guide 1.26.
24. Ultimate Heat Sink: Covered by Regulatory Guide 1.27.
25. Instrumentation to Detect Stresses in Containment Walls: Covered by Regulatory Guide 1.18.

Group IA - Generic Items Resolved Since December 18, 1972

1. Use of Furnace Sensitized Stainless Steel: Covered by Regulatory Guide 1.44.
2. Primary System Detection and Location of Leaks: Covered by Regulatory Guide 1.45.
3. Protection Against Pipe Whip: Covered by Regulatory Guide 1.46.
4. Anticipated Transients Without Scram: Covered by Regulatory Position Document, "Technical Report on Anticipated Transients Without Scram for Water-Cooled Power Reactors," WASH-1270, September 1973.
5. ECCS Capability of Current and Older Plants: Covered by Rulemaking as a general policy decision, although acceptable detailed implementation remains to be developed. Docket RM-50-1, "Acceptance Criteria for Emergency Core Cooling Systems for Light-Water-Cooled-Nuclear Power Reactors," December 28, 1973.

Group IB - Generic Items Resolved Since February 13, 1974

1. Positive Moderator Coefficient: PWRs presently have or expect to have zero or negative coefficients. Where some Technical Specifications allow a slightly positive coefficient, the accident and stability analyses take this into account. Burnable poison provisions have been designed into PWRs to reduce otherwise excessive positive coefficients to allowable values.
2. Fixed Incore Detectors on High Power PWRs: Fixed incore detectors are not required for PWRs since reviews of potential power distribution anomalies have not revealed a clear need for continuous incore monitoring.
3. Performance of Critical Components (pumps, cables, etc.) in post-LOCA Environment: Qualification requirements of critical components are now covered by Regulatory Guides 1.40, 1.63, 1.73 and 1.89 and IEEE Standards 382-1972, 383-1974, 317-1972, 323-1974.
4. Vacuum Relief Valves Controlling Bypass Paths on BWR Pressure Suppression Containments: On designs prior to GE Mark III containment, resolution lies in surveillance and testing of vacuum relief valves. For Mark III containments, an additional requirement is that the design be capable of accommodating a bypass equivalent to one square foot for a given flow condition.
5. Emergency Power for Two or More Reactors at the Same Site: Resolved by issue of Regulatory Guide 1.81.
6. Effluents from Light-Water-Cooled-Nuclear Power Reactors: Resolved by issue of Appendix I to 10 CFR 50.
7. Control Rod Ejection Accident: Resolved for PWRs by Regulatory Guide 1.77.

Group IC - Generic Items Resolved Since March 12, 1975

1. Main Steam Isolation Valve Leakage of BWR's: Covered by Regulatory Guide 1.96.
2. Fuel Densification: Covered by 10 CFR 50 Appendix K plus case-by-case review of vendor fuel models.
3. Rod Sequence Control Systems: Covered by NRC Staff Review and Approval of NEDO-10527 and Presentation to ACRS.
4. Seismic Category I Requirements for Auxiliary Systems: Covered by Regulatory Guides 1.26 and 1.29.

IC-1 - MAIN STEAM ISOLATION VALVE LEAKAGE OF BWRs

The BWR main steam isolation valve (MSIV) leakage problem relates to a loss of coolant accident condition where radioactivity levels are postulated to exist in the coolant. The anticipated leakage levels in this class of valve may result in excessive releases of activity to the environment. Possible solutions include another valve in series to decrease leakage to acceptable levels, sealing mechanisms such as water seals to trap and retain radioactivity, or another type of MSIV capable of meeting the low levels of leakage. This issue has been resolved through issuance of Regulatory Guide 1.96.

IC-2 - FUEL DENSIFICATION

Fuel Densification is a facet of Behavior of Reactor Fuel Under Abnormal Conditions (II-7) and ECCS Capability of Current and Older Plants (IA-5). The densification of fuel changes fuel-cladding gaps, contained sensible heat, and fuel temperatures, leading to unpredictable fuel behavior throughout life. Newer fuel has been modified in several ways to minimize densification, particularly with regard to increasing initial densities of fuel pellets. Existing results indicate that these changes have eliminated densification as a problem. This issue is considered resolved on the joint bases of conformance to Appendix K of 10 CFR 50 and case-by-case reviews of vendor fuel models.

IC-3 - ROD SEQUENCE CONTROL SYSTEMS

Rod sequence control systems or rod pattern control systems are designed to prevent a control rod pattern to exist where a control rod accident could result in peak fuel enthalpies in excess of 280 calories/gram for the entire range of plant operations and core exposure. The problem is one of inadequate experience or analytic evaluation to confirm the design conservatism. Topical reports have been submitted and NRC reviews are complete, so the issue is considered resolved.

IC-4 - SEISMIC CATEGORY I REQUIREMENTS FOR AUXILIARY SYSTEMS

Various auxiliary systems provide continuous or intermittent functions insofar as control of radioactivity, safe plant operation including startup and shutdown, or essential safety actions under accident conditions. These systems are designed to various codes and standards and may or may not be seismic Category I. These auxiliary systems have been evaluated on the basis of such factors as potential release of retained radioactivity, disruption of operation, and failure to provide vital safety functions to determine what components, if any, need to be designed and constructed to meet seismic category requirements. These factors have been incorporated into Regulatory Guides 1.26 and 1.29.

Group II - Resolution Pending

1. Turbine Missiles: Turbine failures for past 16 years have been evaluated and a statistical probability analysis has been completed. An ACRS letter (April 18, 1973) discusses the problems.*
2. Effective Operation of Containment Sprays in a LOCA: Extensive documentation in topical reports. Review and evaluation are required.
3. Possible Failure of Pressure Vessel Post-LOCA By Thermal Shock: Regulatory Guide 1.2 covers current information. Ultimate position as to significance of thermal shock requires input of fracture mechanics data on irradiated steels from the Heavy Section Steel Technology Program.
4. Instruments to Detect Fuel Failures: Instrumentation exists to detect fuel failures. Continuing work is required..
5. Monitoring for Excessive Vibration or Loose Parts Inside the Pressure Vessel: State-of-the-Art results appear promising. More work may be required prior to decision as to installation of equipment.
6. Common Mode Failures: Requirements for diverse components should be established.
7. Behavior of Reactor Fuel Under Abnormal Conditions: This includes: flow blockage; partial melting of fuel assemblies as it affects reactor safety; and transient effects on fuel integrity. The PBF program will address some of these items.
8. BWR Recirculation Pump Overspeed During LOCA: Decision required by ACRS-Regulatory Staff.
9. The Advisability of Seismic Scram: Further studies required to establish need.
10. Emergency Core Cooling System Capability for Future Plants: Partially resolved by amendments to 10 CFR 50 [50.34(a)(4), 50.34(b)(4), 50.46, and Appendix K]. LOCA evaluation model complete. ACRS feels new cooling approaches should be explored.
11. Instrumentation to Follow the Course of an Accident: A Regulatory Guide to be issued should resolve the issue.

*Regulatory Guide is in preparation.

II-1 - TURBINE MISSILES

Turbine failures for the past 16 years have been evaluated and a statistical probability analysis has been completed. An ACRS letter (April 18, 1973) discusses the problem.

Three issues require answers to resolve the turbine missile problem:

(1) The first relates to the appropriate failure probability value; based on historical failures the probability is about ⁻⁴10 . Industry predicts a much lower failure probability based on improvements in materials and design. To date the ACRS has accepted the more conservative value; (2) The second issue is strongly dependent on turbine orientation with respect to critical safety structures. Strike probabilities from high angle missiles are acceptably low for single units and may be acceptable for multi-unit plants, depending on plant layout; however, lower angle missiles with non-optimum (tangential) turbine orientation have unacceptably high strike probabilities; (3) The third issue is one of penetration and damage of structures housed in the containment. The limited experimental data pertaining to penetration of large irregularly shaped missiles are not sufficient to determine structural response to impingement of turbine disc segments. Most missile penetration formulas are not relevant to this case. Some experiments with irregular missiles might resolve this issue, particularly for older plants with non-optimum turbine orientations.

II-2 - EFFECTIVE OPERATION OF CONTAINMENT SPRAYS IN A LOCA

Review and evaluation are required of the variety of experiments which have been conducted on the effectiveness of various containment sprays on the removal and retention of airborne radioactive materials anticipated to be present within containment following a LOCA. Such review should consider adequacy or definition of the physical and chemical forms of the anticipated airborne radionuclides, and quality or evaluative tests of the removal efficiencies of various sprays under the conditions of temperature, pressure, and radiation doses expected to exist under LOCA conditions. A desirable extension might be benefit/risk analyses of the use of sprays containing chemicals (such as NaOH) which have the potential for damaging equipment within containment. Studies using other spray additives, such as hydrazine, have been conducted. If compounds, such as this, have distinct advantages, action should be taken to encourage their use.

II-3 - POSSIBLE FAILURE OF PRESSURE VESSEL POST-LOCA BY THERMAL SHOCK

Earlier nuclear reactor pressure vessels subjected to fluences of $1-4 \times 10^{19}$ nvt, which are anticipated in the last 20 years of a 40-year life, may suffer severe radiation damage denoted by pronounced shift in impact transition temperature at the inner surface. There will be a damage gradient which decreases sharply, so that the properties halfway through the wall are essentially those of the as-fabricated material. If a LOCA occurs near end-of-life, the injection of cold water on the region of degraded properties may initiate and propagate a crack because of high local stresses near the surface. Analytic procedures indicate the stresses drop rapidly with distance through the wall so the flaw should not propagate beyond some limiting point. The lack of experimental evidence and the relative width of the error band in the analytic results are such that some experiments are required to validate the analytic model. These are planned under the HSST program.

II-4 - INSTRUMENTS TO DETECT FUEL FAILURES

In the event of local fuel overheating that leads to clad failure and to melting of sections of one or more irradiated fuel elements, relatively large amounts of fission products could be rapidly released to the reactor coolant. Although the course of events subsequent to such fuel melting may not have serious safety significance, there has, as yet, been no experimental research program to investigate such situations and there is little applicable reactor experience. Also, the subsequent course of events may depend, in part, on the initiating cause of fuel overheating. Early warning and timely response may avert an incident becoming an accident.

Instrumentation related to such diagnostic purposes is being used on most power reactors. A study to define the appropriate minimum requirements and judicious responses to various signals is needed.

II-5 - MONITORING FOR EXCESSIVE VIBRATION OR LOOSE PARTS INSIDE THE PRESSURE VESSEL

Loose parts monitoring can provide early warning of potential mechanical problems or failures within the pressure vessel and throughout the primary coolant circuit. Reactor vendors have developed monitoring systems; however, general requirements remain to be established.

II-6 - NON-RANDOM MULTIPLE FAILURES (FORMERLY "COMMON MODE FAILURE")

The term "common mode failures" has, in many instances come to mean multiple failures of identical components exposed to identical or nearly identical conditions or environments, and the use of diversity in components has been proposed or required to avoid such failures. The concern of the ACRS is better expressed by the term "non-random multiple failures", which is intended to include not only the type of "common mode failure" discussed above but other types of multiple failures for which the consequences and probabilities cannot be predicted by application of the single-failure criterion. Examples include the use of the same sensors or components for both control and protection systems (a resolved matter); sequential multiple failures due to a "domino effect", and simultaneous multiple failures due to a single fault. Since designs usually do not knowingly incorporate features susceptible to such failures, techniques and criteria need to be developed to detect and avoid them in all systems important to safety.

II-7 - BEHAVIOR OF REACTOR FUEL UNDER ABNORMAL CONDITIONS

The Behavior of Reactor Fuel under Abnormal Conditions is still considered unresolved due to the limited experimental data available. Partial melting of fuel assemblies due to flow blockage might lead to autocatalytic effects leading to more extensive fuel failure, pressure pulses, etc. Similar behavior might occur in the case of reactivity transients. The ACRS encourages analytic modeling but believes appropriate experimental data are necessary. It is anticipated that tests in the Power Burst Facility (PBF) should supply much of the required data.

II-8 - BWR PUMP OVERSPEED DURING A LOCA

It is possible for a BWR recirculation pump to overspeed if a large break occurs at the appropriate position in specific piping. Conservative estimates indicate substantial overspeed and possible failure of components with the generation of missiles. The problem is being approached analytically and experimentally with scaled pumps. The reliability of such protective measures as the use of decouplers between pump and motor is under study.

II-9 - THE ADVISABILITY OF SEISMIC SCRAM

The ACRS has recommended that studies be made of techniques for seismic scram and of the potential safety advantages and potential disadvantages of prompt reactor scram in the event of strong seismic motion, say more than one-half the safe shutdown earthquake. Various suitable techniques have been identified and exist, but thus far only limited studies have been reported on the pros and cons of seismic scram. The principal potential advantage identified arises from the greatly improved coolability of a core in the unlikely event of a seismically induced LOCA, should scram precede the LOCA by several seconds. A principal reason given in opposition to seismic scram relates to a stated interest in keeping power stations on the line to provide power offsite should a severe earthquake occur.

II-10 - ECCS CAPABILITY FOR FUTURE PLANTS

The ACRS has placed considerable emphasis on ECCS safety R&D so that the extent of the conservatism in the ECCS licensing requirements could be made more precise. With more experimental data a realistic and quantitative appraisal of ECCS systems would lead to valid judgments on the changes in licensing which could be put on a firm basis.

Parallel approaches that seek to improve the reliability of ECCS systems, to improve the monitoring of low power peaking, and to improve those fuel assembly designs which lower peaking factors are encouraged. Further, changes in plant design which improve the reflooding of the reactor core should be sought and evaluated.

R&D efforts on analysis of core blowdown and reflood should be increased and combined with the results of the standard problems and the associated experiments. Improved analytical methods would provide a basis for optimized ECCS.

II-11 - INSTRUMENTS TO FOLLOW THE COURSE OF AN ACCIDENT

Instrumentation for determining the nature and the course of potentially serious accidents, on a time scale that will permit appropriate emergency action, should be provided at power plants and appropriate calibration methods and calculated bases for interpreting instrument responses should be available. The diversity of the installed instrumentation should be adequate to assure that assessments can be made of accidents and appropriate action taken if they follow the predicted course. In addition, the range of the instrumentation should be adequate to cover various potential radioactivity releases, particularly the upper range limits so as to fully encompass the spectra of all possible accidents.

Group IIA - Resolution Pending - Items Since December 18, 1972

1. Pressure in Containment Following LOCA: Further criteria and methods are needed to better evaluate local dynamic pressures in a LOCA to establish more definitive design margins.
2. Control Rod Drop Accident (BWRs): Calculations indicate that the reactivity response differs from earlier values. New analyses are required, including three-dimensional effects.
3. Ice Condenser Containments: Additional analyses are required to establish response during a LOCA, and to establish design margins.
4. Rupture of High Pressure Lines Outside Containment: The possibility exists that failure of a high pressure line such as a steam pipe can prevent operation of critical safety components.
5. PWR Pump Overspeed During a LOCA: Problem arises in similar manner to that of BWRs (Item 8 Group II).
6. Isolation of Low Pressure From High Pressure Systems: Assurance required that low pressure systems cannot inadvertently be interconnected with a high pressure system leading to failure. There are potential interaction problems between Class 1 and Class 2 or Class 3 pressure connections.
7. Steam Generator Tube Leakage: Partially resolved by issue of Regulatory Guide 1.83 which addresses the concern from a preventative point of view.
8. ACRS/NRC Periodic 10-Year Review of all Power Reactors: A more effective, continuous alternative approach to periodic reviews is being proposed. Pending ACRS review, this item is still considered unresolved.

IIA-1 - PRESSURE IN CONTAINMENTS FOLLOWING LOCA

A potential problem is the overpressurization of subcompartments following a LOCA. A suitably conservative analytic pressure model should be developed to determine that adequate safety margins exist with regard to subcompartment loads.

IIA-2 - CONTROL ROD DROP ACCIDENT (BWRs)

Some uncertainties have arisen in previous calculations of this postulated accident, including the choice of negative reactivity insertion rate due to scram and the potential differences between a two dimensional and a three dimensional calculation. Particularly for the latter point, more precise theoretical comparisons may be required to resolve the matter although probabilistic considerations may be relevant.

IIA-3 - ICE CONDENSER CONTAINMENTS

The ice condenser containments have substantially smaller volume on the assumption that the ice will condense the steam during a LOCA, thus preventing system overpressurization. The rate of condensation is critical in the initial stages of the blowdown and is influenced by interaction of vapor with the ice. If the current analyses prove that the condensation model is suitably conservative, the problem may be resolved.

IIA-4 - RUPTURE OF HIGH PRESSURE LINES OUTSIDE CONTAINMENT

The functional or structural integrity of components required for safe shutdown and the maintenance of cold shutdown may be endangered by a failure of high pressure piping at certain locations outside of containment. Specific design and single failure criteria need to be developed to resolve this problem.

IIA-5 - PWR PUMP OVERSPEED DURING A LOCA

It is possible for a PWR primary coolant pump to overspeed if a large break occurs at the appropriate position in specific piping. Conservative estimates indicate substantial overspeed and possible failure of components such as flywheels with the generation of missiles. The problem is being approached analytically and experimentally with scaled pumps. The reliability of such protective measures as electrical braking of the pump motor is under study.

IIA-6 - ISOLATION OF LOW PRESSURE FROM HIGH PRESSURE SYSTEMS

Assurance is required that low pressure systems cannot inadvertently be interconnected with a high pressure system leading to a failure of the low pressure systems due to overpressurization. Both Class 2 systems required for ECCS and Class 3 systems used for many auxiliary coolant systems provide vital functions during normal and accident conditions. Any conditions leading to interconnection could trigger a LOCA. It is recognized that these systems must be interconnected because of the functions they meet. Therefore, particular attention is required in valve reliability and reliability of valve actuating circuits to assure that these valves will not open while the primary system is at pressure.

IIA-7 - STEAM GENERATOR TUBE LEAKAGE

Normally the steam generator is not a critical component during a LOCA-ECCS. However, a special case exists where the steam generator tubes have been degraded due to corrosion, wastage, etc. If the shock loads imposed by the LOCA cause a critical number of tubes to fail, say by a double-ended (guillotine) break the inflow from the secondary side can cause choking of flow during ECCS, preventing adequate cooling of the core. The critical number of tubes is relatively small. A position such as one specifying a statistically significant level of nondestructive examination (NDE) might resolve this issue. The purpose of NDE would be to confirm that damage is not excessive on the assumption that damaged tubes may fail catastrophically.

IIA-8 - PERIODIC (10-YEAR) REVIEW OF ALL POWER REACTORS

In its report of June 14, 1966, the ACRS recommended that periodic comprehensive reviews be conducted of operating licensed power reactors by the NRC Staff. These reviews would be preceded by a comprehensive report by the operator which evaluated the past experience and the safety of future operation of the plant.

The NRC Staff has maintained a continuing review of the safety of operating plants. In particular, as generic matters of potential safety significance arise, the appropriate operating reactors are asked to assess the relevance of the matter to each particular reactor. This is a necessary but different aspect of the continuing surveillance and review of the safety of operating reactors than was envisaged by the ACRS in its recommendation of June 1966.

The Committee continues to believe both approaches are desirable and awaits the development of a program of periodic comprehensive reviews.

Group IIB - Resolution Pending - Items Added Since February 13, 1974

1. Hybrid Reactor Protection System: Systems should be qualified for reliability, particularly through in situ tests and under various environmental conditions, prior to use in reactor system.
2. Qualification of new fuel geometries: The 16x16, 17x17 FWR and 8x8 BWR fuels should undergo testing to meet Item 2 in Group IC and Item 7 in Group II.
3. Behavior of BWR Mark III Containments: Various aspects, including vent clearing, vent coolant interaction, pool swell, pool stratification, pressure loads and flow bypass should be resolved. This is an extension of Item 1 in Group IIA.
4. Stress Corrosion Cracking in BWR Piping: Several failures have occurred in operating BWRs. The ACRS letter of February 8, 1975, discusses possible actions that should lead to generic resolution and extensive programs are underway by industry, ERDA, and NRC.

IIB-1 - HYBRID REACTOR PROTECTION SYSTEMS

The proposed systems would contain some types of components and subsystems not previously used for reactor protection. It is necessary that the required system reliability, both during normal operation and under postulated abnormal conditions, be established through an appropriate combination of tests and analyses.

IIB-2 - QUALIFICATION OF NEW FUEL GEOMETRIES

New fuels proposed for both BWRs and PWRs include the 8x8 (BWR) and 16x16 and 17x17 PWR fuels. The Committee recognizes that these fuels are intended to operate at power densities lower than earlier fuel designs. However, testing programs are considered necessary to establish their densification behavior (IC-2) as well as their behavior under abnormal conditions (II-7). Appropriate experimental programs should be developed dealing with flow blockage, behavior of fuel after partial melting and fuel response under transient conditions. It is anticipated that the solution of this item will include a synthesis of PBF data, experiments on earlier fuel types, behavior of fuel in commercial reactors, and confirmatory experiments on these fuel designs.

IIB-3 - BEHAVIOR OF BWR MARK III CONTAINMENT

The BWR Mark III Containment differs in many respects from the Mark I and II designs. Various aspects such as vent clearing, vent/coolant interaction, pool swell, pool stratification, pressure loads, and flow bypass must be evaluated and approved; ongoing experimental tests should develop much of the necessary data to confirm the conservatism in design.

IIB-4 - STRESS CORROSION CRACKING IN BWR PIPING

Several failures have occurred in operating BWRs. An ACRS letter of February 8, 1975, discusses possible actions that should lead to generic resolution, and extensive programs are underway by Industry, ERDA and NRC.

The austenitic stainless steels are commonly used as piping material in many of the smaller BWR lines. A combination of weld sensitization, residual stresses, superposed loads, and oxygen equal to or greater than 0.2 ppm in the BWR coolant can lead to cracking, initiating on the inner surface and propagating through the wall. In most cases there will be a leak well before pipe failure so there is adequate warning; however, one can postulate a LOCA caused by a guillotine break with minimal prior warning. Current efforts are to minimize stress corrosion by using other materials.

Group IIC - Resolution Pending - Items Added Since March 12, 1975

1. Locking Out of ECCS Power Operated Valves: The Committee suggests that further attention be given to procedures involving locking out electrical sources to specific motor-operated valves required in the engineered safety functions of ECCS.
2. Fire Protection: The Committee recommends review of design features intended to prevent the occurrence of damaging fires and to minimize the consequences to safety-related equipment should a fire occur.
3. Design Features to Control Sabotage: Attention should be given to aspects of design that could improve plant security.
4. Decontamination and Decommissioning of Reactors: Specific plans should be developed, including definitive codes and standards covering plant decommissioning. Also experience should be gained in reactor decontamination so that such information is available when needed.
5. Vessel Support Structures: Questions that have arisen concerning the loads on pressure vessel support structures due to certain postulated loss-of-coolant accidents should be resolved.
6. Water Hammer: Several cases of water slugging or water hammer have occurred in both PWRs and BWRs. Corrective measures should be taken to minimize such events.
7. Maintenance and Inspection of Plants: Provisions should be included in the design of future plants which anticipate the maintenance, inspection and operational needs of the plant throughout its service life.
8. Behavior of BWR Mark I Containments: Various aspects relevant to the BWR Mark I Containment should be resolved. Included are such items as relief valve restraint, control of local dynamic loads in the torus, vent clearing and establishment of torus water temperature limits during a LOCA. This is an extension of Item 1 in Group IIA.

IIC-1 - LOCKING OUT OF ECCS POWER-OPERATED VALVES

The physical locking out of electrical sources to specific motor-operated valves required in the engineered safety functions of ECCS has been required, based on the assumption that a spurious electrical signal at an inopportune time could activate the valves to the adverse position; e.g., closed rather than open, or opened rather than closed. While such an event has a finite probability another probability exists that the valves might be adversely positioned due to operator error.

The ACRS believes the matter should be studied using a systems approach, and considering such items as (1) the evaluation of the probability of a spurious signal; (2) time required to reactivate the valve operator; (3) status of signal lights when the circuit breaker is open; (4) can the valve be locked out in an improper position due to a faulty indicator; (5) are there other designs improving reliability without lock-out; (6) what are the advantages and disadvantages of corrective action by an alert operator in case of incorrect positioning vis-a-vis a system with power locked out.

IIC-2 - FIRE PROTECTION

The incidence of fires having the potential of damage to safety-related equipment has been sufficiently large to warrant concern. Measures should be taken to review design features intended to prevent the occurrences of damaging fires and to minimize the consequences to safety-related equipment should a fire occur. Where feasible, modifications should be made in older plants in addition to incorporating such changes into plants now being designed. Particular attention should be devoted to regions where vital systems are in near juxtaposition since an event such as a fire could affect redundant and diverse engineered safety functions.

IIC-3 - DESIGN FEATURES TO CONTROL SABOTAGE

Considerable attention has been devoted to control of industrial sabotage of nuclear power plants, particularly with regard to control of unauthorized access, and potential modes of sabotage by individuals or groups external to the operating organization. The ACRS believes that deliberate attention should be given to aspects of design that could improve plant security. With the emphasis being placed on standardized plant designs, it becomes especially important to introduce design measures that could protect against industrial sabotage, or mitigate the consequences thereof.

IIC-4 - DECONTAMINATION AND DECOMMISSIONING OF REACTORS

The Committee believes that well developed plans, confirmed by appropriate experiments where necessary, should be available to cover such events as the decontamination of primary reactor systems and the decommissioning of reactors. At this time the information on full scale decontamination is quite limited, particularly for BWRs. Examples of potential problems include such items as handling of decontamination solutions, potential hideout of radioactive products, enhanced corrosion and crud formation following decontamination, and the possible incompatibility of the different alloys in the pressure boundary to the decontamination solutions.

Experience is limited with regard to decommissioning operations including rules for dismantling and for mothballing. Definitive plans and standards should be developed covering such items as adequacy of action, problems in restitution of site, mutual responsibility of State and Federal Government, etc.

IIC-5 - VESSEL SUPPORT STRUCTURES

A possible consequence of the instantaneous double-ended pipe break postulated to occur in certain large pipes of PWRs is the asymmetric loading of the reactor pressure vessel support structures. The magnitude and effects of such loads on the pressure vessel should be determined to establish if such loads adversely affect the predicted course of a LOCA. If analysis indicates that the results are unacceptable, appropriate corrective action should be taken. A potential effect is pressure vessel movement due to blowdown jet forces at the location of the rupture, transient differential pressures in the annular region between the vessel and the shield, and transient differential pressures across the core barrel within the reactor vessel.

IIC-6 - WATER HAMMER

Several instances of water slugging or water hammer have occurred in both BWRs and PWRs due to causes such as the trapping of water between two valves. This slug of water is accelerated by steam or water once the valves are opened. The stored energy is sufficient to damage piping, bend or break pipe restraints, and damage support structures. Water hammer may occur due to flow instabilities in steam generators in conjunction with water flowing into the feedwater inlets, resulting in comparable damage.

Corrective measures should be taken to minimize such occurrences after completion of analytic and experimental studies directed to an understanding of the causes.

IIC-7 - MAINTENANCE AND INSPECTION OF PLANTS

Experience with older plants has verified that appropriate modifications in piping layout, with respect of walls and structures, type of insulation used, and weld joint design, to cite some obvious items, lead to improved maintenance, more reliable inservice inspections, and a better meeting of the operational needs of the plant throughout its service life, including decontamination and eventual decommissioning. An additional benefit is the reduction in personnel exposures in plants making them more amenable to maintenance and inspection. Appropriate changes should be considered in future designs to meet these criteria.

IIC-8 - BEHAVIOR OF BWR MARK I CONTAINMENTS

Recent tests on the BWR Mark I Containment design revealed phenomena not anticipated on the basis of earlier tests where pressure loads were imposed by insertion of air. Specific problems somewhat comparable to those under review for the Mark III Containment, include relief valve discharge pipe restraints in the torus, local dynamic loads on the torus, vent clearing, and influence of torus temperature on the LOCA.

Ongoing experiments are expected to develop the necessary data to confirm the adequacy of the existing design or to permit necessary modifications.