

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
UNITED STATES ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

February 12, 1974

L. Manning Muntzing
Director of Regulation

EMERGENCY PLANNING FOR THE SALEM-HOPE CREEK NUCLEAR GENERATING STATIONS

During a recent Subcommittee visit to the Salem Nuclear Generating Station and the proposed site for the Hope Creek Station, Committee members noted that egress from the site did not appear to be adequate for an orderly and speedy evacuation of construction forces for the Hope Creek Station in the event it is required after the nuclear units at the Salem Station have begun operating.

The Committee recommends that the emergency plans for the Salem Nuclear Station be examined to assure that construction workers on the Salem and Hope Creek sites can be quickly and safely evacuated, by alternate paths if necessary, in the event it is required after Salem Station Unit 1 is in operation.

/s/ W. R. Stratton

W. R. Stratton
Chairman

cc: P. Bender, SECY
J. F. O'Leary, DL
A. Giambusso, DL