

**ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
UNITED STATES ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545**

July 12, 1971

H. L. Price, Director of Regulation

ACRS COMMENTS ON SAN ONOFRE NUCLEAR POWER STATION UNITS 2 AND 3

Based on the available evidence the ACRS believes the acceleration (g) value of 0.5 proposed by the applicant for San Onofre Units 2 and 3 is not sufficiently conservative.

/s/ R. F. Fraley

R. F. Fraley
Executive Secretary

cc: ACRS Members