

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
UNITED STATES ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

July 13, 1971

H. L. Price, Director of Regulation

ACRS COMMENTS ON NEWBOLD ISLAND NUCLEAR GENERATING STATION

Based on discussion during the 135th ACRS meeting the Committee has reached the following conclusions with respect to the Newbold Island Station:

- 1) The changes in the ECCS proposed for this project meet Committee comments in its report of September 10, 1969, as they apply to emergency core cooling.
- 2) It is desirable to obtain as much flow as can be obtained from the HPCI system without making major system changes such as increasing the pump-turbine size.
- 3) The proposed containment design is considered acceptable.

Original Signed by
R. F. Fraley

R. F. Fraley
Executive Secretary