



Materials Inspection Report

1. Licensee/Location Inspected:

System One Holdings, LLC
201 Sixth Avenue
Pittsburgh, PA 15222
Location Inspected: Job site in Covert, MI

Report Number(s) 2025-001

2. NRC/Regional Office

Region III
U. S. Nuclear Regulatory Commission
2056 Westings Avenue, Suite 400
Naperville, IL 60563-2657

3. Docket Number(s)

150-00037

4. License Number(s)

PA-1148 (reciprocity)

5. Date(s) of Inspection

06/11/25; exit 07/01/25

LICENSEE:

The inspection was an examination of the activities conducted under your license as they relate to radiation safety and to compliance with the Nuclear Regulatory Commission (NRC) rules and regulations and the conditions of your license. The inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector. The inspection findings are as follows:



1. Based on the inspection findings, no violations were identified.



2. Previous violation(s) closed.



3. During this inspection, certain of your activities, as described below and/or attached, were in violation of NRC requirements, and were assessed at Severity Level IV, in accordance with the NRC Enforcement Policy.



A. The violation(s), specifically described to you by the inspector as non-cited violations, are not being cited because they were self-identified, non-repetitive, corrective action was or is being taken, and the remaining criteria in the NRC Enforcement Policy were satisfied.

(Non-cited violation(s) was/were discussed involving the following requirement(s))

B. The following violation(s) is/are being cited in accordance with NRC Enforcement Policy. This form is a NOTICE OF VIOLATION, which may be subject to posting in accordance with 10 CFR 19.11.
(Violations and Corrective Actions)


Statement of Corrective Actions

I hereby state that, within 30 days, the actions described by me to the Inspector will be taken to correct the violations identified. This statement of corrective actions is made in accordance with the requirements of 10 CFR 2.201 (corrective steps already taken, corrective steps which will be taken, date when full compliance will be achieved). I understand that no further written response to NRC will be required, unless specifically requested.

TITLE	PRINTED NAME	SIGNATURE AND DATE
LICENSEE'S REPRESENTATIVE	(not required)	
NRC INSPECTOR	Ryan Craffey	 Digitally signed by RYAN CRAFFEY Date: 2025.07.07 08:29:18 -05'00'
BRANCH CHIEF	Rhex Edwards	 Digitally signed by RHEX EDWARDS Date: 2025.07.18 10:10:36 -05'00'



Materials Inspection Record

1. Licensee Name: System One Holdings, LLC		2. Docket Number(s): 150-00037		3. License Number(s) PA-1148 (Reciprocity)	
4. Report Number(s): 2025-001			5. Date(s) of Inspection: June 11, 2025; exit July 1, 2025		
6. Inspector(s): Ryan Craffey		7. Program Code(s): 03320		8. Priority: 1	9. Inspection Guidance Used: IP 87121
10. Licensee Contact Name(s): Mark Leach, Jr. - RSO		11. Licensee E-mail Address: mark.leach@systemone.com		12. Licensee Telephone Number(s): 412-418-9561	
13. Inspection Type: <input type="checkbox"/> Routine <input checked="" type="checkbox"/> Non-Routine <input type="checkbox"/> Initial <input checked="" type="checkbox"/> Announced <input type="checkbox"/> Unannounced		14. Locations Inspected: <input type="checkbox"/> Main Office <input checked="" type="checkbox"/> Temporary Job Site <input type="checkbox"/> Hybrid <input type="checkbox"/> Field Office <input type="checkbox"/> Remote		15. Next Inspection Date (MM/DD/YYYY): TBD <input type="checkbox"/> Normal <input type="checkbox"/> Extended <input type="checkbox"/> Reduced <input checked="" type="checkbox"/> No change	
16. Location(s) Inspected List: Holtec Palisades Power Plant - 27780 Blue Star Highway, Covert, MI					
17. Scope and Observations: <p>System One Holdings, a diversified staffing and services provider, was authorized by the Commonwealth of Pennsylvania to use and store byproduct material for radiographic operations at its field office in Cheswick, and at temporary job sites in the jurisdiction of the Commonwealth. The company performed work at temporary job sites in NRC jurisdiction per a reciprocity notification filed in June 2025 for the remainder of the calendar year. The scope of this inspection was limited to an evaluation of licensed activities (radiographic testing of heat exchanger repairs using a QSA 880D exposure device containing a category 3 quantity of Ir-192) at the Holtec Palisades Power Plant in Covert, Michigan.</p> <p>The inspector accompanied the company's radiography crew to the job site at Palisades. The inspector evaluated the licensee's radiography equipment, instrumentation, and dosimetry (some of which was provided by the plant). All was in good working condition and had been inspected/calibrated/evaluated as required. The inspector observed the preparation and performance of radiographic operations, noting the use of adequate postings, barricades, and surveillance by the crew and plant RP staff to minimize exposures to others in the area. The crew utilized survey instruments as required, and employed extensive ALARA practices as provided and required by the plant.</p> <p>The inspector also reviewed a selection of records available on the job site, including results of current leak test and DU contamination checks, equipment maintenance records, shipping papers, and copies of the the company's current Pennsylvania license and approved NRC Form 241 dated June 5, 2025, which accurately reflected the activities observed.</p> <p>No violations of NRC requirements were identified as a result of this inspection.</p>					
Signature and Date - Branch Chief  Digitally signed by RHEX EDWARDS Date: 2025.07.18 10:10:11 -05'00'					