



Sequoyah Nuclear Plant, Post Office Box 2000, Soddy Daisy, Tennessee 37384

August 18, 2025

10 CFR 50.54(q)
10 CFR 72.44(f)

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Sequoyah Nuclear Plant, Units 1 and 2
Renewed Facility Operating License Nos. DPR-77 and DPR-79
NRC Docket Nos. 50-327, 50-328, and 72-034

Subject: Emergency Plan Implementing Procedure Revision

In accordance with the requirements of 10 CFR 50.54(q) and 10 CFR 72.44(f), the Tennessee Valley Authority is submitting a description of changes to the Sequoyah Nuclear Plant (SQN) Radiological Emergency Plan. The affected document, and current revision level, is the SQN Emergency Plan Implementing Procedure (EPIP) listed below.

EPIP	Revision	Title	Effective Date(s)
6	64	Activation and Operation of the Technical Support Center	July 29, 2025

The above referenced revision was evaluated in accordance with 10 CFR 50.54(q)(3) and 10 CFR 72.44(f) and determined that the change does not reduce the effectiveness of the Emergency Plan. Details of the revision are included in the enclosure.

There are no new regulatory commitments contained in this letter. Should you have any questions concerning this submittal, please contact Mr. Paul Gain, Site Emergency Preparedness Manager, at (423) 843-7088.

Respectfully,

Michael, Kevin
Mckinley

Digitally signed by
Michael, Kevin Mckinley
Date: 2025.08.18
12:24:22 -04'00'

Kevin Michael
Site Vice President
Sequoyah Nuclear Plant

U.S. Nuclear Regulatory Commission
Page 2
August 18, 2025

Enclosure: SQN Units 1 & 2 Description of Revision/Change

cc: NRC Regional Administrator – Region II
NRC Senior Resident Inspector – Sequoyah Nuclear Plant
NRC Director – Division of Fuel Management, NMSS

ENCLOSURE: SQN UNITS 1 & 2 DESCRIPTION OF REVISION/CHANGE

EPIP-6, Revision 64

- Added step for the Site Emergency Director to provide Technical Support Center (TSC)/Operations Support Center (OSC) briefing once initial turnover is complete.
- Updated TSC Emergency Preparedness Manager Operational Responsibilities to include utilizing alternate communication methods as needed.
- Moved Post Accident Sampling Operational Responsibilities from the Technical Assessment Manager to the TSC Chemistry Manager to better align with the Radiological Emergency Plan Appendix B.