

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
BWRX-300 Design-Centered Subcommittee

Docket Number: (n/a)

Location: videoconference

Date: Wednesday, August 20, 2025

Work Order No.: NRC-0433

Pages 1-137

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +
BWRX-300 DESIGN-CENTERED REVIEW SUBCOMMITTEE

+ + + + +

WEDNESDAY

AUGUST 20, 2025

+ + + + +

The Subcommittee met via Videoconference,
at 8:30 a.m. EDT, Craig Harrington, Chair, presiding.

SUBCOMMITTEE MEMBERS:

CRAIG D. HARRINGTON, Chair

VESNA B. DIMITRIJEVIC

GREGORY H. HALNON

WALTER L. KIRCHNER

ROBERT P. MARTIN

THOMAS E. ROBERTS

ACRS CONSULTANTS:

RONALD G. BALLINGER

DENNIS BLEY

DESIGNATED FEDERAL OFFICIAL:

QUYNH NGUYEN

ALSO PRESENT:

KELLI BANKS, GE Vernova

DAVID HINDS, GE Vernova

SCOTT HUNNEWELL, Tennessee Valley Authority

BRIAN McDERMOTT, Tennessee Valley Authority

RAY SCHIELE, Tennessee Valley Authority

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR HARRINGTON: The meeting will now come to order.

I'm Craig Harrington, Chairman of the BWRX-300 Design-Centered Subcommittee.

We've got feedback -- okay.

ACRS members in attendance in person, Greg Halnon, Robert Martin, and Thomas Roberts. ACRS members Vesna Dimitrijevic, Walt Kirchner -- and Walt Kirchner are participating virtually via Teams. We, I think, have consultants Ron Ballinger and Dennis Bley participating virtually.

Have I missed anyone, either ACRS members or consultants, please speak up now?

MEMBER DIMITRIJEVIC: Vesna is also here. I just joined. Good morning.

CHAIR HARRINGTON: Okay, very good. Thanks, Vesna.

Quynh Nguyen of the ACRS staff is the Designated Federal Officer for today's meeting.

No member conflicts of interest were identified for today's meeting. And we have a quorum.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act, or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 FACA.

2 NRC implements FACA in accordance with our
3 regulations. Per these regulations and the
4 Committee's bylaws, this ACRS speaks only through its
5 published letter reports.

6 All member comments should be regarded as
7 only the individual opinion of that member, not the
8 Committee position.

9 All relevant information related to ACRS
10 activities such as letters, rules for meeting
11 participation, and transcripts are located on the NRC
12 public website and can be easily found by typing about
13 the ACRS in the search field on NRC's home page.

14 The ACRS, consistent with the Agency's
15 value of public transparency and regulation of nuclear
16 facilities provides opportunity for public input and
17 comment during our proceedings.

18 For this subcommittee meeting, we have
19 received no written comments. Written statements may
20 be forwarded to today's Designated Federal Officer.

21 We have also set aside time at the end of
22 this meeting for public comments which will be added
23 to the record and considered by the Committee in
24 future deliberations.

25 However, the Committee does not plan to --

1 on responding to specific comments during today's
2 meeting.

3 The purpose of today's meeting is to hear
4 a general overview from TVA of their construction
5 permit application for the Clinch River site.

6 Following that overview, hear a general
7 presentation of the BWRX-300 Design from GE Vernova,
8 which is the designated design for this site.

9 Previously, in December 2019, an early
10 site permit, ESP, was issued for the Clinch River
11 site.

12 A transcript of the meeting is being kept
13 and will be posted on our website.

14 When addressing the committee, the
15 participants should first identify themselves and
16 speak with sufficient clarity and volume so that they
17 may be readily heard. If you are not speaking, please
18 mute your computer on Teams.

19 If you are participating by phone, press
20 star six to mute your phone and star five to raise
21 your hand in Teams. The Teams chat feature will not
22 be available for use during the meeting.

23 For everyone in the room, please put all
24 your electronic devices in silent mode and mute your
25 laptop microphone speakers. In addition, please keep

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 sidebar discussions in the room to a minimum since the
2 ceiling microphones are live.

3 For the presenters, table microphones are
4 fairly unidirectional and need to be close. So, you
5 need to speak into the front of the microphone to be
6 heard online.

7 And finally, if you have any feedback for
8 the ACRS about today's meetings, we encourage you to
9 fill out the public meeting feedback form on the NRC's
10 website.

11 And, with that, Scott Hunnewell from TVA
12 will kick off the meeting.

13 MR. HUNNEWELL: Thank you. I'm Scott
14 Hunnewell. I'm the Vice President of the New Nuclear
15 Program for the Tennessee Valley Authority.

16 Good morning, and thank you for inviting
17 us to share our work on the BWRX-300 at the Clinch
18 River site in Oak Ridge, Tennessee with you today.

19 So, TVA was formed in 1933 as part of the
20 New Deal by FDR. In the 1940s, we primarily deployed
21 dams, hydroelectricity. 1950s, fossil fuel. The
22 1960s saw us enter the nuclear realm. And then,
23 1970s, primarily natural gas generation.

24 And as we look forward to the future, we
25 look at a diverse slate of generation, including,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 potentially, new nuclear power.

2 So, East Millinocket, Maine, is a small
3 town about an hour north of Bangor on the edge of the
4 Allagash Wilderness.

5 I want to read portions of the
6 valedictorian speech from the 1958 high school
7 graduating class.

8 The Italian navigator has arrived in the
9 New World. With these humorously cryptic words,
10 Arthur H. Compton telephoned James B. Conant to
11 announce the dawn of the Atomic Age. The navigator
12 was Enrico Fermi, the Italian-born American physicist.

13 The date was December 2nd, 1942. The
14 scene, a squash court under the stadium of the
15 University of Chicago. There, a select audience
16 watched, not sure what to expect, as a cadmium rod was
17 pulled slowly, foot by foot, from a strange structure
18 of carbon and uranium that looked somewhat like a
19 giant beehive.

20 At 3:20 p.m., Fermi achieved the first
21 self-sustaining atomic chain reaction and operated the
22 world's first atomic furnace. He had, indeed, arrived
23 in the New World.

24 The achievements of atomic energy are
25 possible because of the atomic furnace, more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 accurately called a nuclear reactor.

2 The reactor is a very unusual machine, for
3 it does two separate and entirely different jobs.
4 Both its abilities are of great practical value and
5 they are being developed simultaneously.

6 On the one hand, the reactor is a furnace.
7 It makes heat just as a furnace that consumes coal,
8 oil, gas, wood, gasoline, or any other fuel does.

9 The atomic furnace, flameless, strangely
10 quiet, almost entirely automatic, is used to make
11 steam for generating electricity. Generating
12 electricity is probably the biggest use for atomic
13 heat, but there are other important applications.

14 It can propel ships, and an atomic engine
15 now keeps vessels cruising smoothly over vast
16 distances without need for refuel.

17 An unusual type of atomic furnace could
18 drive a railroad locomotive and still others are
19 developed to fly airplanes and rocket ships.

20 Medicine and agriculture have made perhaps
21 the biggest use of atomic energy so far. Radioactive
22 tools have given us new plants, fertilizers, and
23 insecticides, as well as improved cancer treatments.

24 Despite the Manhattan Project's
25 preoccupation with war work, they found time to plan

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 for the peacetime use of atomic energy that they
2 foresaw so clearly.

3 Many industrialists looked upon
4 radioactive isotopes as little more than a promising
5 toy for esoteric research. Most experts on electrical
6 power considered atomic electricity a dream that might
7 come true in 50, 75, perhaps 100 years.

8 Yet, only five years later, radio isotopes
9 were hailed as the most important instrument since the
10 invention of a microscope.

11 Within ten years, electricity from atomic
12 power plants was operating lights and toasters and
13 radios in the homes of ordinary people.

14 The optimists were right, but we are just
15 entering the Atomic Age. Noted atomic scientists say
16 that only the surface of atomic energy has been
17 scratched. What changes the atom will bring in the
18 future are unknown, only time can tell.

19 I'd like to thank Linda McDonald for
20 allowing me to share her speech with you here today.

21 The headlines are full of the power needs
22 across the country to power data centers in support of
23 artificial intelligence. There are daily stories of
24 industries returning manufacturing back to the United
25 States, plants that need electricity to operate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 We have gone from shrinking demand for
2 electricity to growth not seen in generations.

3 Utilities are deploying new generating
4 assets to meet this rapidly rising demand. And when
5 it comes down to it, there are only two forms of
6 dispatchable base load generation that can be
7 deployed, either a natural gas power plant or a
8 nuclear plant.

9 Utilities strive for a diverse portfolio
10 of generation to best weather unforeseen future
11 events, like the war in Ukraine. Nuclear is one of
12 the most resilient, reliable, and dependable sources
13 of electrical generation.

14 TVA is leading the country in advancing
15 the next generation of nuclear reactors and our work
16 on the BWRX-300 at the Clinch River site is helping us
17 lead that charge.

18 I'd like to thank the NRC, when you look
19 at history, again, this is one of the first Part 50
20 applications in over 40 years. And many of the
21 regulations have been modified over the years to
22 really align to Part 52.

23 And that was one of our concerns three
24 years ago when we started our construction permit
25 application was, how were we going to navigate a Part

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 50 pathway that hasn't been used in 40 years with
2 regulations that have changes.

3 So, I really want to thank the NRC.
4 They've really worked with us. It's evidenced in the
5 questions they ask, the engagements that we've had,
6 the audit that we've had, that has really prepared us
7 to submit what we hope is a high-quality construction
8 permit application.

9 So, I first read this speech about ten
10 years ago and it strikes me every time I read it how
11 much progress we have made and the vast potential
12 still ahead of us.

13 When we're in the middle of fray, we often
14 don't realize that history is being made. But I think
15 if you look around this room and at the innovation
16 happening with nuclear energy throughout the country,
17 I believe that we are making history that future
18 generations will learn about in school.

19 Thank you for inviting us here today and
20 I will turn it over to Ray Schiele.

21 MR. SCHIELE: Thanks, Scott.

22 Good morning, I'm Ray Schiele, Senior
23 Licensing Manager for the TVA New Nuclear Program. It
24 is a pleasure to present to ACRS again. Last time was
25 for the full Committee the TVA CRN early site permit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 licensing effort.

2 Presenting to the ACRS today is not just
3 a new chapter for TVA, but a continuation of the
4 effort back in December of 2019 when the early site
5 permit was issued.

6 On the slide we have on the screen right
7 now is just a pictorial of the location of the Clinch
8 River site as it relates to the Oak Ridge Reservation
9 and the Clinch River arm of the Watts Bar Reservoir.
10 It's 935 acres.

11 Next slide, please, Allen?

12 So, this slide is an overview of the
13 journey to submit the CPA from the time our early site
14 permit was issued.

15 The first thing we pursued was a
16 technology evaluation. The early site permit was
17 technology neutral. A plant parameter envelope was
18 used to compare four designs of various levels of
19 technical maturity.

20 The technology evaluation considered many
21 feature including supply chain constraints, advanced
22 manufacturing, seismic issues, modular construction,
23 advanced construction techniques.

24 From that, while we were doing technology
25 evaluation, we realized, looking forward towards the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 development of a construction permit, that Part 50 had
2 not been done for some time.

3 So, we pursued developing annotated
4 outlines comparing the content of Reg Guide 1.70,
5 which is the standard format and content for nuclear
6 power plants to NUREG-0800 to identify where gaps or
7 inconsistencies existed.

8 When the drafts of the annotated outlines
9 were complete, we provided them to the NRC staff in
10 the electronic reading room for review.

11 Staff comments were incorporated and the
12 annotated outlines to further de-risk the scope of a
13 construction permit application development.

14 As part of the technology evaluation, the
15 BWRX-300 design was selected. And in June of 2022,
16 TVA and GVH agreed upon a contract and path forward to
17 develop a construction permit application for CRN-1.

18 The annotated outlines informed the
19 development of the regulatory framework documents
20 which further de-risked the development of a
21 construction permit application.

22 Question?

23 MEMBER MARTIN: This is Bob Martin.

24 You mentioned for the 2019 ESP and the
25 plant parameters envelope, was the BWRX-300 among

1 those four plants?

2 MR. SCHIELE: No, it was not.

3 MEMBER MARTIN: Okay, so you've obviously
4 done some looking to see if that envelope was broad
5 enough?

6 MR. SCHIELE: So, that's correct. So, the
7 four technologies evaluated were for PWRs of various
8 labels and maturity. And in the early site permit,
9 there are some tables towards the end that lists the
10 parameters that enveloped the permit.

11 So, when we were doing our technology
12 evaluation, yes, one of the things we looked at right
13 away is, what technology at the level of maturity that
14 it was at right now would fit into that -- those
15 boundaries in the envelope there?

16 MEMBER MARTIN: And I mean, how much did
17 level maturity matter? And I understand we're all
18 some -- been around the block and we kind of know and
19 followed TVA's progress on this stuff.

20 MR. SCHIELE: I think it was significant.
21 One of the biggest things was fuel design. The fuel
22 design and the supply chain assessment table was one
23 of the biggest factors in selecting the technology at
24 the time.

25 MEMBER MARTIN: That makes a lot of sense,

1 supply chain's everything, isn't it?

2 MR. SCHIELE: Yes.

3 MEMBER MARTIN: Can you build it and can
4 you operate it?

5 MR. SCHIELE: Exactly.

6 MEMBER MARTIN: All right, thanks.

7 MR. SCHIELE: Sure. So, CNR site -- early
8 site permit was incorporated by reference where
9 appropriate and the content was developed, and site
10 specific content was developed like TVA estimates.

11 A freeze date of April of 2024 was chosen
12 to control the scope of the application that we
13 intended to submit to the NRC.

14 In parallel with PSAR development, TVA
15 additionally developed a topical report for NQA-A for
16 the site new nuclear. We developed and submitted an
17 exempt request for a Part 2.101(a)(5) which further
18 enabled us to leverage submitting for a Part 50 either
19 the environmental report or the PSAR first gave us
20 that option.

21 We also submitted an exemption request for
22 early site excavation. Currently, as you know, the
23 definition for excavation does not allow anything to
24 be permanently left in the excavation because that
25 would fall into the definition of construction.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 However, for this deeply embedded
2 containment and reactor building, we're talking about
3 an excess of 120 feet in excavating and in stages,
4 rock bolts, shotcrete wire would be left on the walls
5 in stages to stabilize the wall with no really support
6 for any safety features other than safety for the
7 workers. And if those things were being removed,
8 you'd further destabilize the walls.

9 So, we submitted an exemption request to
10 allow those features to stabilize the walls to be left
11 in and not be considered part of the construction.

12 CHAIR HARRINGTON: So, this is Craig.

13 I take it from that, then, you have
14 already started digging the hole, basically?

15 MR. SCHIELE: No, we have not started
16 digging yet.

17 CHAIR HARRINGTON: Okay.

18 MR. SCHIELE: This is all in preparation
19 to dig the hole.

20 CHAIR HARRINGTON: Okay. Thanks.

21 MEMBER HALNON: Greg Halnon. You
22 mentioned a freeze date of April 2024, what is that
23 mean? What made you freeze?

24 MR. SCHIELE: So, the design is continuing
25 to mature. And it's pretty impossible to keep an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 application in step with design maturity.

2 So, we picked a date that -- to ensure
3 that the application was current with all the design
4 features as of that date with the anticipation that,
5 either part of the review process or afterwards where
6 certain critical functions had matured, we would
7 update the application with those things.

8 Now, there's been a couple exceptions to
9 that. One is the isolation condenser system. We
10 actually updated that because there was a design
11 change on that. But I'd say 95-plus percent of the
12 application was frozen to the design as presented in
13 April of 2024.

14 MEMBER HALNON: Okay, so, you internally
15 made a judgment that that design at April 2024 was
16 adequate to get through at least the CPA?

17 MR. SCHIELE: That's correct.

18 MEMBER HALNON: And then, how will you
19 identify the changes going forward in the FSAR here?

20 MR. SCHIELE: So, that's a good question.

21 As part of the annotated outlines we
22 developed and the regulatory framework documents,
23 content was cataloged DSAR or FSAR.

24 So, for those things that are cataloged
25 FSAR, as we go forward in the licensing process and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 getting ready to prepare the operating license
2 application, we have to ensure all those items that
3 are coded FSAR are available to complete the
4 application.

5 MEMBER HALNON: I would encourage you to
6 continue to keep the review in mind, though, to the
7 deltas between. We had some applications come in that
8 did a very nice job with showing the deltas, the
9 Kairos Hermes 2, for example. That's one way of doing
10 it.

11 And we've had others come in that was just
12 a brand new thing and it takes a lot more effort to
13 review that to try to do a slew of delta documents.

14 MR. SCHIELE: Yes.

15 MEMBER HALNON: So, as you go through it,
16 it'd be very good to keep that delta document or
17 somehow --

18 MR. SCHIELE: No, 100 percent agree. In
19 fact, one of the things we did for the construction
20 permit, which we'll talk about in a few slides, was in
21 Chapter 2, where it talks about tomography and
22 meteorology and so forth, a lot of that information
23 was incorporated by reference from the early site
24 permit.

25 And we provided the staff markups for

1 those chapters of the information, redline markups in
2 the reading room, to show what was IBR and what was
3 new to support the review.

4 MEMBER HALNON: Yes, just keep the review
5 in mind --

6 MR. SCHIELE: Yes, absolutely.

7 MEMBER HALNON: -- that'll help smooth it
8 through.

9 MR. SCHIELE: Yes.

10 MEMBER ROBERTS: This is Tom Roberts, a
11 quick question.

12 You wrote to emphasize this is the first
13 construction permit application pertaining to Part 50
14 in 40 years, but there are two others that are
15 currently in house, one of which preceded you by a
16 year and as well as there's Kairos, which I know is a
17 test reactor, but it's probably, you know, has some
18 relevance to.

19 How much of that did look at? How much
20 coordination was there in looking at what the other
21 applicants were doing in terms of what the best
22 practices were for the CPA?

23 MR. SCHIELE: We have been following other
24 applicant challenges, specifically in the topical
25 reports that they were submitting to overcome those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Part 50 issues, many of them legacy items from Part
2 52. So, we have been following the other applications
3 of the challenges they've had.

4 MR. HUNNEWELL: So, I'll just add on that
5 we have a cooperation agreement with Kairos power and
6 we're actually actively involved in preparation of
7 their application.

8 MEMBER ROBERTS: I guess the question for
9 the staff maybe when it's their turn, presumably,
10 they're also profiting from the -- y'all's
11 interactions in kind of their own best practices. So,
12 I'll just follow up on that when the staff's up.

13 Thank you.

14 MR. SCHIELE: Also, during this time
15 period, in addition to exemption requests and the
16 topical report, we prepared an environmental report
17 per 10 CFR 51.59.

18 And also, TVA is a government agency, we
19 had to do our own NEPA. So, we were providing -- we
20 prepared a subsequent environmental impact statement
21 taking advantage of what was done in the early site
22 permit and processed that application.

23 As we were providing the -- or going
24 through development during '23, '24 time frame, we
25 requested the staff perform a readiness assessment per

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 LIC 116. The assessment findings were dispositioned
2 in the application prior to us submitting a
3 construction permit application.

4 So, finally, we get to CPA submittal. The
5 construction permit application was submitted in two
6 parts, the environmental report portion was submitted
7 in April of 2025 and the preliminary safety evaluation
8 report in May of 2025.

9 The acceptance review was completed in
10 June and July of 2025 and the NRC commenced the review
11 of the environmental report and the PSAR with audits.

12 The environmental audit is ongoing,
13 nearing completion right now.

14 And the safety site audit is just getting
15 underway.

16 MEMBER HALNON: And what's the schedule
17 say?

18 MR. SCHIELE: So --

19 MEMBER HALNON: For approval?

20 MR. SCHIELE: Approval of the construction

21 --

22 MEMBER HALNON: Yes, from the NRC when
23 you're done?

24 MR. SCHIELE: Right now, I believe it's
25 scheduled for issuance of the construction permit is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 December of '26.

2 MEMBER HALNON: Okay, and that's what you
3 got in you acceptance letter was 12/26?

4 MR. SCHIELE: Yes. Next slide, please.
5 So, this is just a quick summary of all the
6 regulations and Reg Guides that informed the various
7 enclosures for our application. The application was
8 over 4,000 pages.

9 Enclosure 1 is informed by 50.33.

10 Enclosure 2, public and private, Reg Guide
11 1.70, as we talked about, 0800, and 50.34(a) for our
12 PSAR. And the environmental report was 51.50, NUREG
13 1555, standard review plan, and Reg Guide 4.2.

14 Next slide, please. So, this is a little
15 more detailed look at the site. And the red on the
16 left is the area of proposed disturbance.

17 And on the right is a high-level, but
18 plant layout where we expect certain features to be
19 deployed.

20 Chapter 1 summarizes the principle aspects
21 of the design, conformance with the regulatory
22 requirements, and material that is incorporated by
23 reference in the PSAR.

24 Chapter -- Section 1.5 also provides, as
25 allowed by Reg Guide 1.70, requirements for further

1 technical information. Reg Guide 1.70 states that the
2 PSAR should identify and describe and discuss those
3 features or components for which further technical
4 information is required in support of the issuance of
5 the construction permit, but which has not been
6 supplied in the PSAR.

7 Currently, we have two items in Section --
8 Chapter 1.5. The first are Appendices 3(b) through
9 3(h). These are the summary of the preliminary
10 analyses that demonstrate the design of a seismic Cat
11 I structure. Tentatively, we are going to provide
12 those in a supplement no later than September of '25.

13 The second item is an evaluation assuming
14 fission product release based on a hypothetical event.
15 This is your containment performance analysis. It's
16 being developed right now and we believe it will be
17 submitted within six months after we submitted the
18 CPA, so sometime this fall.

19 MEMBER HALNON: Ray, is the seasonal --
20 this is Greg -- the seasonal control, the river level
21 going to be accurate the way it's done or do you have
22 to modify that with the Authority?

23 MR. SCHIELE: So, that's a good question.
24 The Clinch River arm of the Watts Bar Reservoir, it is
25 a reservoir. It's not a free-flowing river. And the

1 bypass flow from Melton Hill Dam, big topic of
2 discussion during the that permit for what was
3 proposed to be initially pursued there, there may have
4 been a need for a bypass.

5 At this time, with just deploying a single
6 unit, we don't believe a bypass is going to be
7 required. But the river is not a free-flowing river.
8 It's part of the bigger Watts Bar Reservoir, which is
9 a controlled level between the two dams, Watts Bar Dam
10 and the dams upstream.

11 MEMBER HALNON: This goes back a long
12 ways, I don't want to put you on the spot if you don't
13 remember, but one of your boreholes had -- they found
14 diesel fuel in it.

15 MR. SCHIELE: Yes.

16 MEMBER HALNON: Can you remind me what the
17 root cause of that or is it --

18 MR. SCHIELE: So, we did subsequent
19 evaluations on that with TDEC, the Tennessee
20 Department of Environment Control and we did
21 additional sampling and it was determined that that
22 was naturally occurring product. And those wells were
23 subsequently closed. And we've annotated those
24 details.

25 MEMBER HALNON: Yes, it was a big head

1 scratcher back then --

2 MR. SCHIELE: It was.

3 MEMBER HALNON: -- when it happened. And
4 it almost felt like somebody just poured a five-gallon
5 can of diesel fuel in that.

6 MR. SCHIELE: No, it was determined it was
7 naturally occurring.

8 MEMBER HALNON: Naturally occurring, yes.

9 MR. SCHIELE: Next slide, please. So,
10 Chapter 2 is site characteristics provides an
11 evaluation against the early site permit PPE and
12 justification of exceedances.

13 Site characteristics parameters, those
14 items that were incorporated by reference from that
15 SSAR, which is the site safety analysis report in the
16 early site permit, early site permit conditions and
17 early site permit COL action items.

18 On the slide you have in front of you
19 right now, those portions have some or a majority of
20 the content carried forward from the early site
21 permit.

22 There's a table in Chapter 1 that
23 describes the cross reference of all the chapter
24 sections that have been incorporated by reference in
25 the PSAR.

1 Next slide, please. In addition to
2 updating many of the site characteristics, once we
3 transitioned from the early site permit which had a
4 footprint for the deployment of two reactors, the
5 footprint for the BWRX-300 was identified and, per
6 regulations, we had to have some conforming or some
7 additional cohorts done at centerline and the four
8 corners.

9 And then, additional core bores where the
10 cooling towers would be and where the switch out would
11 be. So, as part of Chapter 2, we've performed
12 additional core bores for the footprint for the
13 deployment for CRN-1. And for those of you were part
14 of the early site permit, you'll remember that there
15 was a tremendous amount of core bores from the breeder
16 reactor and then, from the mPower reactor, and then,
17 for the early site permit.

18 But in the picture, you can see the gray
19 hashed markings, those are some of the ones from the
20 previous efforts. They just didn't fall exactly where
21 we needed them for four corners and center.

22 So, Clinch River is highly, from a
23 subsurface perspective, highly characteristic.

24 Next slide, Allen?

25 MEMBER MARTIN: And you probably cover it

1 somewhere, you mentioned the plan right now is for a
2 single unit. But when you went into this with ESP
3 were you're thinking multi-unit or, I mean, is there
4 a potential to expand at some point? Or is this --

5 MR. SCHIELE: Well, the early site permit
6 demonstrated that the site characteristics could
7 handle the deployment of two or more with some certain
8 boundaries, 800 megawatts electric.

9 MEMBER MARTIN: So, 800 --

10 MR. SCHIELE: Yes, 800 megawatts electric
11 plus all the other parameters that would confine you
12 to operating two reactors, whether it's the MET data
13 or a heat to the river, all these things informed the
14 early site permit. And that was for a PPE approach to
15 a permit.

16 MEMBER MARTIN: Yes, right.

17 MR. SCHIELE: Going forward, we decided to
18 deploy one, and Scott, you want to talk more about it?

19 MR. NGUYEN: Excuse me, Ray, can you speak
20 directly into the mic? Thank you.

21 MR. HUNNEWELL: Yes, so, let me just touch
22 on that briefly, right? So, the first thing is that
23 TVA has not decided to deploy a reactor at Clinch
24 River. The environmental report and CPA for a single
25 BWRX-300 at the site, we are performing contingency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 planning for the potential deployment of additional
2 reactors at the site of either BWRX-300 technology or
3 potentially a different technology.

4 So, from a planning standpoint, we're
5 targeting a single reactor, but we are thinking beyond
6 that.

7 MEMBER MARTIN: Okay.

8 MR. SCHIELE: Chapter 3, design of
9 structures, systems, and components. Chapter 3
10 describes the classification of SSCs as well as
11 compliance with the general design criteria and
12 appendices that provide safety class, design analysis
13 of seismic structures, and a computer program for
14 design analysis of SSCs, and aircraft impact
15 assessment.

16 On the slide in front of you is an
17 illustration of how the reactor building containment
18 would be constructed using DPSC, diaphragm plate steel
19 composite method.

20 This chapter is also additionally informed
21 by the safety strategy LTR which is in flight right
22 now and being reviewed by the NRC, and also, the DPSC
23 LTR, both of which I believe GVH will discuss later in
24 their presentation.

25 MEMBER HALNON: Ray, this is Greg.

1 On the picture on the left, where's the
2 current ground level on that?

3 So, you go, one two, three, four --

4 MR. SCHIELE: So, you see where it's the
5 reactor building with wall the arrow right there, it's
6 just above that, you'll see on the right hand of the
7 reactor building, there's like -- do you see where the
8 fuel -- spent fuel pool is?

9 MEMBER HALNON: Yes.

10 MR. SCHIELE: Just above that is ground
11 zero.

12 MEMBER HALNON: Okay, so, then that area
13 is completely under --

14 MR. SCHIELE: And I believe in the next
15 presentation, David's got an elevation presentation.

16 MEMBER HALNON: Okay, good, thanks.

17 MR. SCHIELE: Okay.

18 MEMBER ROBERTS: I want to follow up, this
19 is Tom, with a follow up to my question earlier about
20 the first CP application for the area. And one thing
21 I had mentioned I'd ask the staff a little later, but
22 the staff's not here, so I'm not going to ask them,
23 I'll try to follow up later with them.

24 What occurred to me is the other CPAs we
25 have in are based on the TICAP, ARCAP advanced reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 concept application and there's some streamlining,
2 significant streamlining that went into that.

3 And I was wondering if you'd looked at
4 that when you considered using that structure instead
5 of the existing in Reg Guide 1.70, you know, meaning
6 light water reactor chapter, for instance?

7 It doesn't necessarily focuses is well on
8 safety and your safety strategy and topical report?

9 MR. SCHIELE: No, we did look at that, but
10 that was primarily designed for non-light water
11 reactors and this is a light water reactor
12 application.

13 So, a lot of the things in the Part 53 and
14 LMP and TICAP and ARCAP really didn't apply. But
15 there were some good insights on how we managed
16 information demonstrating complaint and conformance
17 for Part 50 in there for an advanced reactor.

18 And this isn't an advanced reactor, it's
19 passive having been informed by safety strategy, yes.
20 But it follows like the passive plant rules. Which,
21 if you look at Part 53 and LMP and TICAP and ARCAP,
22 it's the same information. It's catalogued a little
23 differently but it's very close, very close.

24 MEMBER ROBERTS: Yes, this is probably
25 something to look at in a couple years after testing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 these three CP applications to see if there's some
2 common lessons in that. It maybe TICAP, ARCAP didn't
3 exactly hit the mark, either.

4 But it just occurs to me that it has the
5 potential to be more closely focused on safety and not
6 have a lot extraneous material in there that's
7 sometimes hard to integrate into the overall safety
8 case. So, you know, more to come on that, but thanks.

9 MR. SCHIELE: Yes, thank you.

10 MR. NGUYEN: For clarification, Member
11 Roberts, the NRC staff is not scheduled to present
12 today.

13 MR. SCHIELE: Let's go on to the next
14 slide, please. So, the BWRX-300 is a natural
15 circulation on boiling water reactor. Chapter 4
16 describes the design of the fueling reactor, reactor
17 core, including fuel rods, fuel assemblies, reactivity
18 control system, nuclear design, and thermal hydraulic
19 parameters.

20 There is an LTR being reviewed right now
21 by the NRC for stability control that will inform this
22 natural circulation reactor.

23 And I believe GVH will talk about -- more
24 about that LTR in the next presentation.

25 Chapter 5 describes the reactor cooling

1 system and connected systems that form the reactor
2 coolant pressure boundary.

3 The reactor coolant system is comprised of
4 Safety Class 1 called SC-1 as far as safety strategy
5 terminology goes, a portion of the nuclear boiler
6 system and condensate feed.

7 The RCS extends to and includes the
8 outermost containment isolation valves and the main
9 feed and feed piping.

10 So, on this illustration, and I know it's
11 just a one line diagram, is something that's kind of
12 unique and interesting as compared to other designs.

13 The reactor isolation valves, and I
14 believe David's going to discuss this more in the next
15 presentation, but the reactor isolation valves for
16 these major systems, feed steam and so forth, are also
17 your in-core isolation valves on the vessel.

18 So, that's very interesting and that
19 informs your reactor coolant pressure boundary with
20 your isolation valves on the outside of containment.

21 Next slide, please. Chapter 6,
22 engineering safety features, for the BWRX-300, passive
23 systems that are not dependent on external source heat
24 power or operator action and fulfill the fundamental
25 safety functions for at least 72 hours after a design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 basis accident, there's three primary fundamental
2 safety functions, control reactivity, removal of heat
3 from the fuel, and confinement of radioactive
4 material.

5 For the BWRX-300, it only credits three
6 systems, containment, the passive containment cooling
7 system, and the isolation condenser system.

8 So, on this illustration on the left,
9 you'll see the three trains of the isolation condenser
10 system and how they tie into the vessel.

11 And on the right, you'll see an
12 illustration of the trains of the passive containment
13 cooling system and how they tie in.

14 Next slide, please.

15 MEMBER HALNON: I'm sorry, Ray, this is
16 Greg.

17 Did you say that the condenser --
18 isolation condenser system was added post-April 2024?

19 MR. SCHIELE: No, it was already in the
20 design -- could you go back a slide, please. It was
21 already in the design -- sorry, go to the Chapter 6
22 slide, please.

23 It was already in the design. What the
24 design had was three independent pools for the three
25 trains.

1 You see this illustration here, there's a
2 pool for Train A, and there's another pool for Train
3 B and C. So, the major change for it to go from three
4 pools to two pools, so what you have right now is the
5 pool for Train A that's guaranteed to support 72
6 hours, and the pool with two trains, 7-day pool.

7 MEMBER HALNON: So, that is an example of
8 a significant modification that you updated the PSAR?

9 MR. SCHIELE: Exactly.

10 MEMBER HALNON: Okay, thanks.

11 MR. SCHIELE: And I'm sure David will talk
12 about it more, but this is your primary ECCS system
13 for 50.46, very important.

14 Let's go to Chapter 7, please?

15 So, Chapter 7, it describes the
16 instrumentation and control systems used for normal,
17 abnormal, and accident conditions.

18 Specifically, Chapter 7 includes the
19 integrated digital based I&C design, the architectural
20 arrangement that supports a plant-level defense-in-
21 depth framework.

22 This framework relates to the safety
23 analysis framework and the inner loop bases for the
24 defense lines. Classifications scheme is based on
25 importance of the individual defense lines.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 The BWRX-300 I&C architecture and
2 associated system components are designed with
3 international standards and proven engineering design
4 practices, we present state of the art methods.

5 This illustration is just a block diagram
6 of the architecture and the trains that it supports
7 and how it goes from the defense lines balance
8 deployment and the data highways.

9 Next slide, please. Chapter 8, electric
10 power, Chapter 8 provides the description of the
11 alternating current and direct current power systems
12 and power requirements for normal, abnormal, and
13 accident conditions.

14 The electrical distribution system
15 architecture is a configuration of generators, buses,
16 transformers, and load centers that supply power to
17 all the design loads.

18 The BWRX-300 design minimizes the reliance
19 on electrical power support Category I functions. The
20 passive design of the plant is not dependent on any AC
21 power sources, including diesel generators to mitigate
22 design basis accidents.

23 Safety Class 1 power is supplied from
24 battery backed DC power.

25 The uninterruptible power system has a

1 coping period of 72 hours for design basis accidents.

2 In the illustration on this slide right
3 there, it shows you two trains for a to batteries
4 battery buses and the flows to supply the
5 uninterruptible power system. It is the single source
6 of power for you credited SC-1 design.

7 MEMBER ROBERTS: Hey, Ray, can you talk
8 briefly about the control of those retro isolation
9 valves? It seems like it's hard to call them as
10 passive because I understand they need to shut to
11 contain your inventory for subsequent design?

12 MR. SCHIELE: Sure, so, the SECY-94-084,
13 the definition, the differentiation between passive
14 and active is what provides the mode of force for a
15 function to happen.

16 So, in this case, these valves, the RIBs,
17 they are powered by stored energy, stored energy
18 signal via the DC buses here.

19 It's not that the valves don't move or not
20 as far as passive or active, it's where they get the
21 energy to perform their function. And so, by the
22 definition of passive, they perform their function
23 using stored energy.

24 MEMBER ROBERTS: Okay, thanks.

25 But they rely on the batteries for mode of

1 power and for sensing when to shut?

2 MR. SCHIELE: And from the I&C system to
3 recognize that a certain event has happened. And not
4 all the valves go shut, some of them are already shut,
5 some will have to go shut to perform their function.

6 MEMBER ROBERTS: Right, but they don't
7 shut on loss of power? Do they shut on loss of power
8 to the I&C system?

9 MR. SCHIELE: I do not believe so.

10 David, can you --

11 MR. HINDS: Hi, this is David Hinds from
12 GVH.

13 So, the reactor isolation valves, we have
14 the -- those that I'll call power generation related
15 that are all configured to fail in a closed position.
16 They have stored energy such that if they lose power
17 and/or control to that reactor isolation valve, the
18 stored energy would cause the valves to go closed.

19 I will note that that power to them is
20 battery backed, so that means loss of all power.

21 There is a set of valves for the isolation
22 condenser system which are configured to fail as is.

23 I'll touch on that some more when I go
24 through slide presentations, if that's okay.

25 MEMBER ROBERTS: Okay, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 CHAIR HARRINGTON: And so, Ray, this is
2 Craig.

3 I assume from the comments that there are
4 no diesel generators at all?

5 MR. SCHIELE: No, there are diesel
6 generators and the diesel generators are credited SC-3
7 power for those features after 72 hours like to
8 replenish other systems. But they are credited after
9 72 hours.

10 CHAIR HARRINGTON: Thank you.

11 MR. SCHIELE: So, Chapter 9, please?

12 Chapter 9 describes systems used to
13 support fuel storage and letting normal cooling water
14 process auxiliaries, heat sink values and cooling fire
15 power protection, power auxiliaries, communication
16 light.

17 Appendix 9A presents the fire hazards
18 analysis and the methodology for the fire safe
19 shutdown analysis, both of which will be finalized and
20 provided prior to the FSCRB issue.

21 On the slide right there is an
22 illustration of the pool that has the fuel racks and
23 the control blade racks in it. That's on the left.

24 And on the right, you'll see how it's part
25 of the bigger scheme of pools at that level which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 provides your ultimate heat sink so you can see the
2 Alpha pools for the condenser system and the Bravo,
3 Charlie pools for the condenser system and the fuel
4 storage racks.

5 MEMBER HALNON: Ray, this is Greg.

6 We haven't seen the word multiple in front
7 of ultimate before. When -- does that mean that
8 there's multiple or different heat sinks for different
9 portions of the plant or is it a redundancy or how
10 does that --

11 MR. SCHIELE: Sure.

12 So, for the isolation condenser system,
13 the ultimate heat sink is the pools to atmosphere.

14 For the containment, the primary
15 containment cooling system is another heat sink.

16 Both of those are for like modes, what you
17 would call modes one through four or five.

18 But then, when you get into refueling,
19 going back to that other illustration where you saw
20 the very, very tall chimney, that whole column of
21 water that would be filled up for the reactor cavity,
22 that's the ultimate heat sinking mode which you would
23 call mode six for refueling.

24 MEMBER HALNON: So, these are all safety
25 class?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. SCHIELE: Dedicated bodies of water
2 that will give you --

3 (Simultaneous speaking.)

4 MEMBER HALNON: -- the ultimate heat sink
5 like a --

6 MR. SCHIELE: It sounds like the river, I
7 don't know, Chesapeake Bay or something, you know, - or
8 the ponds that look -- you know, some reactors had to
9 build ponds next to them for their heat sink.

10 MEMBER HALNON: Is that unique to the
11 country area or maybe, David, is that the way the
12 plant was originally thought of relative here?

13 MR. SCHIELE: I think this is by design.
14 David, go ahead.

15 MR. HINDS: Hi, David Hinds, GVH.

16 So, the heat sink for safety is what Ray
17 was describing. There is, of course, a heat sink for
18 power generation. That's when we get to cooling tower
19 and make up water.

20 Heat sink for safety -- I'll cover some
21 more in the slides, but primarily focus on the
22 isolation condenser system for the stored water within
23 the safety Class 1 as to about safety Class 1 or
24 safety related reactor building structure.

25 So, we store the water in the reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 building. Similarly, we do the same thing for the
2 fuel pool.

3 MEMBER HALNON: Okay, so, not unique to
4 the site it's just that --

5 MR. HINDS: No, it's --

6 MEMBER HALNON: -- just this kind of set
7 --

8 MR. HINDS: -- part --

9 MEMBER HALNON: -- so you can be nimble
10 and place it anywhere in the country, then?

11 MR. HINDS: That's correct, it is part of
12 the standard.

13 MEMBER HALNON: Okay.

14 CHAIR HARRINGTON: This is Craig.

15 This drawing on the right, we have a
16 similar version in GE slides, so I'll ask it now, the
17 inner and outer pools can you speak to how they relate
18 to each other? Are they just communicated that it's
19 weir walls or what's the details?

20 MR. SCHIELE: I don't know, David, do you
21 have that that shows the weir wall?

22 MR. HINDS: I'll just describe it, we
23 don't picture that.

24 MR. SCHIELE: We may look it as if there's
25 a weir wall where, if one goes down, one will overflow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 into the other one and provide the cooling. Because
2 effectively, you're steaming -- during an accident,
3 you're steaming that water down. It goes out through
4 the vents natural to the atmosphere.

5 So, the inner pools will feed into the
6 outer pools as they steam down.

7 MR. HINDS: I do have a storage level
8 figure when I get to that.

9 CHAIR HARRINGTON: Okay, good, so we'll
10 have a better picture and talk about it some more.

11 Okay, thank you.

12 MR. SCHIELE: Slide Chapter 10, please?

13 So, the Chapter 10 describes the systems
14 used for steam and power conversion. And this
15 illustration is just a typical 1-HP wheel, 2-LP
16 wheels, feedwater heaters, MSRs.

17 So, this chapter talks about turbine
18 generator, main steam, and the associated system
19 support for power conversion.

20 Next slide, please.

21 CHAIR HARRINGTON: This is Craig, again.
22 On the power conversion, have you selected a vendor
23 yet or is that still in progress?

24 MR. SCHIELE: It is not selected, that's
25 why it's a very generic one. Chapter 11, radioactive

1 waste management, Chapter 11 describes the
2 capabilities of the plant to control, collect, handle,
3 process, store, and dispose of liquid gaseous and
4 solid waste.

5 There's two source terms that are
6 discussed in Chapter 11. One is the realistic model
7 which is based on nuclear concentrations that you
8 would find typically in BWRs.

9 This model is referred to as the normal
10 operation source term.

11 The other source term is the conservative
12 design basis model. And it's based on GHGO clad
13 defect and it's referred to in the chapter discussions
14 as the design basis coolant source term.

15 Chapter 12, radiation protection covers
16 the policy, design, and operational considerations for
17 ALARA. Pretty straightforward.

18 Chapter 13, Chapter 13 discusses
19 organizational structure, programs, procedures, staff
20 qualifications.

21 For emergency preparedness, the early site
22 permit had the major features of both a site boundary
23 and a two-mile EPZ.

24 For a PSAR Appendix E of 10 CFR Part 50
25 requires a limited amount of information which is

1 about the same amount of information we had in the
2 early site permit.

3 So, we updated that information to conform
4 to Appendix E and that's what you'll see in the
5 application.

6 At this time, TVA has not decided to
7 continue down the 15.47 pathway that the exemptions
8 were provided for or to go down the 51.60 which is
9 performance based. That'll be decided in part in the
10 operating licensing application.

11 Chapter 13 also includes physical security
12 and fitness for duty. As far as physical security,
13 the security by design Reg Guide 5.90 I don't believe
14 is quite approved yet. It's been through all the
15 reviews. Again, TVA will evaluate security by design
16 when it comes time to put together our operating
17 license application.

18 MEMBER HALNON: So, on your operational,
19 you see it being pretty traditional from the
20 standpoint of the operations maintenance or is it --
21 or are you going to try something a bit more codec and
22 to reduce staff to like on the BWR now?

23 MR. SCHIELE: The answer is yes, we're
24 looking at all kind of aspects to lower the ultimate
25 O&M costs post-staffing maintenance and so forth.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER HALNON: Okay, so you sort of
2 started with the traditional and trying to figure down
3 or are you coming from the bottom up?

4 MR. SCHIELE: You want to talk about this?

5 MR. HUNNEWELL: Absolutely.

6 So, we've got a targeted head count that
7 supports our O&M costs going to LCOE. And that does
8 assume certain things are automated.

9 For example, for work room management
10 system, highly automated compared to today where
11 you've got work room managers and schedulers who
12 manually do everything.

13 So, there is -- and then, I've actually
14 got somebody that is just over O&M reviewing the
15 design with GVH to constantly give them feedback in
16 areas where the design could be improved to help on
17 the O&M side.

18 MEMBER HALNON: So, you're taking after
19 the building in what you would love to have in your
20 other plants now?

21 MR. HUNNEWELL: Correct.

22 MEMBER HALNON: Okay.

23 MR. SCHIELE: Chapter 14, initial test
24 program. The initial test program is composed of
25 phases characterized as construction, pre-op, and

1 startup.

2 The construction tests serve as
3 prerequisites to pre-operational tests which work its
4 way up to your startup testing requirements.

5 Next slide, please. Chapter 15, safety
6 analysis. The safety analysis provides information on
7 the hazard analysis, deterministic safety, and
8 probabilistic safety assessment.

9 The safety analysis scope includes normal
10 operation, anticipated operational occurrences, AOOs,
11 design basis accidents, design extension conditions,
12 which you'll see that acronym, DEC, in the
13 application, which is beyond design basis accidents.

14 Chapter 15 also includes two appendices,
15 15A which discusses the practically eliminated
16 provisions, and also 15B which discusses complimentary
17 design features for mitigating design extension
18 conditions.

19 MEMBER MARTIN: Ray, I can probably guess
20 the answer to this, but do you expect much of a
21 departure on the NUREG-0800 Chapter 15? You know,
22 obviously, the natural circulation, you know, probably
23 brings in a unique stability event or something. But
24 for the most part, it will kind of look familiar?

25 MR. SCHIELE: So, the licensing topical

1 report that GVH is processing right now, I believe
2 will overcome most of those hurdles because when those
3 safety evaluations are issued and we disposition the
4 limitations conditions for lifesaving strategy, that
5 should help manage most of those differences, which
6 SSCs are credited for passive slant.

7 MEMBER MARTIN: I mean, go back 15 years
8 ago when, of course, NuScale and mPower would doing a
9 thing and they had a lot of design specific standards.
10 I don't know, we don't have the staff here, you know,
11 and although they're kind of here, but has there been
12 talk of DSRS for the BWRX?

13 MR. SCHIELE: Not for Chapter 15. I mean,
14 we used for Chapter 7 the design reviews DRG for
15 Chapter 7 for instrumentation. So, that was used to
16 perform the content of Chapter 7.

17 But I haven't heard any conversations
18 about getting over Chapter 15.

19 MEMBER ROBERTS: So, the PRA, there's a
20 lot of discussion certainly in the LMP world for the
21 degree of quality that has to go into a CP of PRN. We
22 had a meeting a couple months ago on how that applies
23 to 10 CFR 50.

24 How much did you use PRA in the CPA and
25 how did you resolve the, you know, the deficit quality

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 questions?

2 MR. SCHIELE: So, as you know, a Part 50
3 application does not include Chapter 19 PRA.

4 However, we do have a Section 15.6 that
5 has PRA information in it. And TVA participated with
6 the staff in the initial discussion on the white paper
7 on what is the scope of PRA for a construction permit
8 application?

9 And as you know, there's an ISG that's
10 been through you all getting ready to get approved
11 that frames the scope for a construction permit or
12 PRA.

13 Also TVA hosted in the electronic reading
14 room a GEH design information on their PRA for the
15 staff to review.

16 So, we've been very involved in the
17 information sharing on PRA between the design that's
18 already in the NRC. But the design right now, it's
19 not mature enough to have even a preliminary PRA put
20 in our application.

21 MEMBER ROBERTS: So, the motivation for
22 that ISG was if folks were going to use PRA
23 information in their application, but you're saying
24 you don't really use PRA information at this point?

25 MR. SCHIELE: No, there are certain design

1 features that are risk informed, yes. But there is
2 not enough information to put together the initial PRA
3 for a construction permit on a design that's still
4 maturing. It would be different if we had like a
5 design cert, but we don't.

6 MR. HUNNEWELL: Yes. So our approach to
7 PRA at this phase is much more qualitative than
8 quantitative. The quantitative, once the design
9 matures to that point, is developed.

10 MEMBER ROBERTS: Okay. Thank you.

11 MEMBER DIMITRIJEVIC: This is Vesna. So
12 did you use any quantitative information for your
13 identification, categorization and grouping of the
14 initial events and accident scenarios?

15 MR. SCHIELE: I'm going to have to defer
16 that.

17 MS. BANKS: Good morning, everybody. This
18 is Kelli Banks. I'm with GE Vernova licensing. So we
19 do use also PRA techniques to prevent categorization.
20 It's not that we're using the PSA model itself. So,
21 for example, NRC has INL database where it has failure
22 data, initiating event frequencies; so we use that
23 type of information that is also an input to our PRA
24 to determine the frequency of a given event. And we
25 do categorize events according to frequency with some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 exceptions like LOCAs. For example, even if they are
2 in a beyond design basis event frequency category, we
3 still categorize those breaks as on-basis accidents.

4 So we use, I would say, similar
5 information, but it's not that the PRA itself is being
6 used. It's we use PRA engineers who are used to doing
7 event sequence frequency determinations, and we use
8 similar inputs.

9 MEMBER DIMITRIJEVIC: Thank you. But how
10 about safety objectives and acceptance criteria?

11 MS. BANKS: So we do have preliminary
12 appraisal to 15.6 for CDF and LERF. So based on, you
13 know, the preliminary PSA that we have done up to the
14 point, you know, that the design, when the PSAR was
15 submitted, we do submit and show that, you know, the
16 safety goals are also on track to being met. And, of
17 course, once the design is finalized, the process for
18 establishing a technically adequate PRA is finished,
19 then those, you know, results would be also updated in
20 the PSAR.

21 MEMBER DIMITRIJEVIC: All right. Thank
22 you.

23 MR. SCHIELE: Thank you, Kelli. We'll go
24 on to Chapter 16. Chapter 16, technical
25 specifications. Chapter 16 provides the methodology

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for developing technical specifications and the
2 associated bases that ensure compliance with the
3 safety analysis inputs, assumptions, and results. It
4 identifies preliminary variables, conditions, and
5 items as a result of the descriptions of safety
6 analyses contained elsewhere in the PSAR.

7 The selection methodology informs a
8 preliminary table of contents, including the reason
9 for inclusion of that selected content. The improved
10 standard tech spec ISTS NUREG-1433 for BWR/4 plants
11 and ISTS 1434 for BWR/6 plants were used as a template
12 for the BWRX-300 tech specs and bases. A complete set
13 of tech specs and bases will be provided as part of
14 the operating license.

15 Quality assurance, Chapter 17. Chapter 17
16 describes the QA program used during design and
17 construction of Clinch River 1 to ensure conformance
18 with regulatory requirements and the design bases
19 specified in the CPA. And, as I said earlier, we have
20 a approved topical report that governs design,
21 construction, and operation that is included in 17.5
22 of Chapter 17.

23 And the last thing is Enclosure 4.
24 Enclosure 4 contains exemptions and variances that
25 were included as part of the application. Currently,

1 it has one exemption associated with reactor vessel
2 material surveillance program requirements.

3 Variances. Right now, there are seven
4 variances identified. These variances are based on --
5 there were over 40 COL action items in the early site
6 permit. These seven variances are those items that
7 the design put us outside the boundary for those items
8 in the early site permit. An example is site grade
9 level. The finished elevation in the site grade is
10 814.5, but in the finished elevation that was assumed
11 in the ESP was 821. So we had to put a variance in
12 for the difference.

13 So all of these are, for whatever reason,
14 the variance, the difference, and the justification
15 where we were outside the boundary of what was in the
16 early site permit.

17 MEMBER HALNON: So some of those variances
18 are actually conservative then to --

19 MR. SCHIELE: Yes.

20 MEMBER HALNON: -- for all the dirt you
21 got to bring in.

22 MR. SCHIELE: Yes.

23 MEMBER MARTIN: I just wanted a
24 clarification. I had asked a couple questions about
25 the single unit and the PPE. Where you have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 variance of the single unit thermal megawatts, talk a
2 little bit about what that is.

3 MR. SCHIELE: So it was 300 megawatts
4 electric. And this unit is -- David, you'll have to
5 help me. I think it's what, 347?

6 MR. HINDS: I'd say nominally 300
7 electric.

8 MR. SCHIELE: That's nominal; but, actual,
9 it's a little more than that?

10 MR. HINDS: So we had to justify why
11 that's okay.

12 MEMBER MARTIN: Okay.

13 MR. SCHIELE: But the early site permit
14 allowed for 800 for two or more, so we're still inside
15 the permit, but we're higher than the single unit.

16 MEMBER MARTIN: Okay. That's interesting.
17 So maybe you were anticipating another four PWRs were
18 all smaller, but you went with probably the maximum
19 power of the four.

20 MR. SCHIELE: Yes. And another way to
21 look at it is that the early site permit justified a
22 certain set of boundaries for the deployment of two or
23 more. If TVA just chooses to deploy something else
24 there, we would have to justify that application of
25 that design separately. We couldn't use the early

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 site permit.

2 MEMBER MARTIN: I took your 800 number and
3 divided it by two. I'm going, oh, okay.

4 MEMBER HALNON: Ray, you know, you always
5 think about, when you start building SMRs, you're
6 thinking the end of the kind type thing. How close is
7 this, what you submitted, do you think is going to be
8 the next unit? I know Darlington's working on them,
9 and you're probably informed by that. Did you take
10 anything you see going into this PSAR something that
11 may not carry through the rest of the nth of a kind?

12 MR. SCHIELE: Don't know that I can
13 answer that right now. Darlington is first. It's the
14 lead plant.

15 MEMBER HALNON: Yes. By all years, may be
16 an nth of a kind --

17 MR. SCHIELE: We're watching Darlington
18 closely.

19 MEMBER HALNON: -- even though it's a
20 different unit.

21 MR. SCHIELE: But, as I said, in April of
22 '24, we froze it. Lots of things have changed since
23 then.

24 MEMBER HALNON: So we should expect a lot
25 of red lines in the FSAR.

1 MR. SCHIELE: The FSAR will look
2 definitely different than the PSAR. It's too early to
3 say how it's going to change, but it will reflect the
4 latest and greatest design maturity that we choose at
5 the time.

6 CHAIR HARRINGTON: Can you say just a
7 couple of words about the vessel surveillance program?

8 MR. SCHIELE: Yes. What we took the
9 change on that was the ASTM year dates. So that was
10 it.

11 CHAIR HARRINGTON: It's an administrative
12 decision. I can't remember what all -- I've been
13 reading, but I haven't got it.

14 MEMBER HALNON: Any other questions on the
15 content of the application? Members, anyone online?
16 Thank you.

17 MR. HINDS: Hi, I'm David Hinds. For GE
18 Vernova Hitachi. Thank you for time today. So I'm
19 here to give a brief overview of the design of the
20 BWRX-300.

21 The BWRX-300, the acronym there, is, of
22 course, the BWR. It stands for boiling water reactor.
23 That's been our legacy at GE Vernova Hitachi. Sorry,
24 new company name. But, anyway, so we have quite a
25 legacy of design and fabrication, construction of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 boiling water reactors. So the X is Roman numeral 10.
2 So this is 10th generation of boiling water reactor
3 design in our evolutionary design. The 300 is just to
4 represent the nominal electrical output. Of course,
5 electrical output varies, primarily driven by cooling
6 water of the specific site.

7 Go to the next slide, please.

8 MEMBER HALNON: Thank you. All right. Go
9 ahead.

10 MR. HINDS: Okay. Thank you. So
11 continuing on, just an outline to indicate some of the
12 information covered. This is only a partial overview
13 of the design with a focus on these areas. As always,
14 questions are fine in any area, but these are areas
15 that we've highlighted in the presentation and it also
16 introduces some of the acronyms that may have filtered
17 through the presentation. So talking about the
18 reactor pressure vessel, or RPV. The reactor
19 isolation valves, we've used an acronym RIV for
20 reactor isolation valves. Isolation condenser system,
21 or ICS, and the passive containment cooling system, or
22 PCCS.

23 Go to the next slide, please. Thank you.
24 As I indicated, the evolutionary design at GVH, we
25 based many of our design decisions, design principles,

1 analytical methods, codes, informed by prior
2 generations. So I thought it would be appropriate
3 here just to show a quick visual of some of that
4 evolutionary design, and we noted and segregated the
5 forced circulation design, which is in the green arrow
6 here, and the natural circulation design in the blue
7 or purple-looking arrow.

8 So the BWRX-300 is natural circulation.
9 It is, though, informed by both forced circulation,
10 and, when I say forced circulation, I'm talking
11 reactor recirculation flow; and it's also informed by
12 the natural circulation design predecessors. So some
13 of the presentation will focus on those plants in the
14 blue or purple.

15 Note Dodewaard is of particular interest
16 in that it informed much of the design and operation
17 of the BWRX-300. We did go through design
18 certification of the ESBWR, which is also natural
19 circulation, and we started a certification of the
20 SBWR. So there's a significant amount of information
21 related to the design and analysis and the regulatory
22 treatment of the ESBWR from our design certification.
23 So that highly informs our development of the BWRX-
24 300. The sizes are different, but technology and
25 principles are very similar.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER MARTIN: Could you -- this is Bob
2 Martin -- speak to Dodewaard? Now, I just did a quick
3 Google search, and I did know a little about it, but
4 it looked like it was more of a demonstration plant,
5 maybe an opportunity to do some interesting things
6 with it and then collect data. Is there data that we
7 might see at a later time that supports the eventual
8 design certification?

9 MR. HINDS: Yes. So the bid for --

10 MEMBER MARTIN: There's juicier things,
11 obviously, but it seemed like that was a huge
12 opportunity, but it was a long time ago and things get
13 lost.

14 MR. HINDS: Yes. Dodewaard actually
15 operated for many years. I think it was approximately
16 25 years. It's in Europe and in Holland, and we
17 gathered a significant amount of data, information,
18 that informed our development of our analytical
19 methods. Our TRACG computer code has a significant
20 amount of benchmark data from the actual operation of
21 Dodewaard. So it was very, very effective at
22 informing and giving us confidence in our ability to
23 design and operate a natural circulating reactor.

24 Dodewaard, as you can see by its coloring,
25 it was a natural circulation. It's no longer in

1 operation. However, it operated, as I said, for
2 approximately 25 years. And, yes, the simple answer
3 to your question is we did gather significant data,
4 and that data is used to confirm our methods,
5 analytical methods, design configurations are informed
6 by the learnings at Dodewaard. The evolution such as
7 startups, shutdowns, and power maneuvers are informed
8 by Dodewaard. So, yes, it's very beneficial.

9 MEMBER MARTIN: Again, I'm kind of making
10 assumptions about its use. Obviously, it was
11 generating power. Now, would they have entertained
12 tests that might have challenged the stability
13 criteria design limits? And as far as what's, you
14 know, most unique novel new here, you know, the
15 circulation and stability questions are near the top
16 of the list.

17 MR. HINDS: So, yes, we certainly gather
18 data associated with stability performance at many
19 different operating points within Dodewaard.
20 Similarly, at even forced circulation plants, we've
21 gathered stability data associated with it. Even
22 though there are forced circulation and BWRX's natural
23 circulation, the information is still relevant. So
24 there are specific stability tests that were performed
25 on a forced circulation power plant in Europe that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 highly informs our stability knowledge and methods.

2 So a combination of the forced circulation
3 fleet, primarily in cases where there's some change in
4 flow, such as stopping the reactor recirculation pumps
5 on a forced circulation plant. But, yes, Dodewaard
6 data highly informed our stability design or overall
7 configuration of the reactor.

8 MEMBER MARTIN: Thank you.

9 CHAIR HARRINGTON: This is Craig. Not to
10 turn this into a history lesson, but is there any
11 particular reason or thought behind why there are two
12 paths and why the Dodewaard plant was natural
13 circulation?

14 MR. HINDS: Some of them get into business
15 decisions. And I will say that the power density
16 within the reactor is very somewhat driven by whether
17 there's forced circulation or not. Generally, we have
18 a higher power density for circulation reactors. So
19 I'll say much of it is there's certainly technology
20 feeders into that decision making, but there's also
21 business aspects, too, of what's the desired output of
22 a power plant, for instance; what's the limitation,
23 whether it be business or technical or a combination
24 thereof, on sizes of reactor pressure vessels. The
25 configuration of the reactor pressure vessel is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 substantially or significantly impacted by the choice
2 of natural circulation or forced circulation. So some
3 are in the fabrication of components and many are
4 business decisions but always informed by technology.

5 CHAIR HARRINGTON: Even utility or
6 regulator influence, I suppose.

7 MR. HINDS: Yes. There's also operational
8 differences and maneuvering differences between the
9 different types of designs.

10 Can we go to the next slide, please. This
11 slide has got many words, but it's meant to be, since
12 this was a relatively short overview of something we
13 could spend a long time on, we tried to pack quite a
14 lot of information into this slide, so hopefully it's
15 helpful to you. Some of these we've already touched
16 on, or at least one or two of them. Okay. It's a
17 nominal 300-megawatt electric gross output and, again,
18 varies based upon cooling water. That's the power
19 generation cooling water.

20 The reactor pressure vessel I mentioned,
21 since it's natural circulation, the configuration of
22 the reactor pressure vessel is substantially or
23 significantly impacted by the choice of natural
24 circulation. So the reactor pressure vessel height is
25 selected accordingly. It's approximately a 27-meter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 tall vessel. It's approximately a 4-meter in diameter
2 vessel. The diameter of the vessel is sized such
3 that, based upon the core sizing plus the annular
4 space for core flow, natural circulation, highly
5 informed by fire-operating plants.

6 We have 240 fuel bundles. It was
7 mentioned by Ray that part of the decision-making was
8 the availability and maturity of the fuel for the
9 reactor. We're using Global Nuclear Fuel, GNF-2 fuel,
10 which is very highly experienced fuel. It's currently
11 being manufactured and operated today, so it's not a
12 new fuel development. It is fuel that's already
13 proven, and so that was a very strategic choice.

14 The GNF-2 fuel, out of the various GNF
15 fuel product lines, GNF-2 was specifically chosen,
16 one, because it has a history and it's been proven,
17 but also because it has favorable natural circulation
18 behavior, low pressure drop, pressure drop that's
19 acceptable for a natural circulation reactor. So it
20 was a nice synergy, experienced fuel, currently
21 manufactured, proven in the industry, and the pressure
22 drop characteristics matched what's needed for our
23 natural circulating reactor.

24 CHAIR HARRINGTON: This is Craig again.
25 Are the fuel bundles standard length?

1 MR. HINDS: Yes. Very good question. If
2 any of you have studied or been involved in our ESBWR,
3 we did, in the ESBWR, just going back in history for
4 a minute, we actually chose a special fuel design for
5 ESBWR where we reduced the height or length of the
6 fuel bundles for the purpose of pressure drop
7 characteristics. What we found by selecting GNF-2
8 fuel and part of that strategic objective of not
9 developing new fuel, we were able to use the standard
10 fuel length. So simple answer is standard fuel
11 length.

12 MR. HUNNEWELL: It's the same fuel that we
13 use at our Browns Ferry reactor.

14 MR. HINDS: We have 57 control rods. I
15 mentioned briefly that this actual core configuration.
16 I'll show a core here in a little while, but it was
17 also informed by an operating plant, KKM. I might
18 mispronounce it; it's in Europe, but operating
19 reactor, which is very, very similar core design. It
20 was a forced circulation plant. However, the core
21 design, highly informed by that. So a lot of history.

22 MEMBER HALNON: Are the control rods
23 relatively standard? It's probably not a great word
24 for it --

25 MR. HINDS: Yes.

1 MEMBER HALNON: But proven technology.

2 MR. HINDS: Yes.

3 MEMBER HALNON: You don't have to do cycle
4 testing to see how many cycles or anything.

5 MR. HINDS: They are proven control rods.
6 So we were very selective about the introduction of
7 new features that haven't been used in the industry.
8 Fuel and control rods are not new features. They are
9 used in the industry.

10 So simple answer, yes, the control rods
11 are quite similar to the exact same as our Marathon-
12 Ultra type of control rods. So they are proven in the
13 industry, so no new introduction of control rods.
14 There is a slight adjustment between, depending upon
15 which plant we're comparing to. We have a slide
16 coming up, but this plant uses fine motion control rod
17 drafts, so it has a special coupling. So the coupling
18 is different between this plant design and a locking
19 piston older plant design.

20 But outside of the coupling design, it's
21 the same. We have history with the coupling as well.

22 Passive design. This is a passive safety
23 power plant. So natural circulation and passive
24 safety. And we've found that there is a very nice
25 synergy between the passive safety and natural

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 circulation.

2 As I display here with the height of the
3 reactor pressure vessel, there is a need for, I'll
4 just say a relatively tall reactor pressure vessel to
5 support the natural circulation and to create the
6 flow.

7 There's also a synergy with our passive
8 safety with the coolant preservation approach, which
9 I'll touch on through upcoming slides. So we have a
10 lot of coolant relative to our past designs of forced
11 circulation plants. A lot of coolant is already in
12 the system, so that is a very nice synergy with
13 passive design and the 72-hour requirement associated
14 with passive power plants.

15 It was mentioned by Ray that we do not
16 depend upon electrical power for safety. Actually, we
17 do have diesel generators, but those diesel generators
18 are not credited in our conservative safety analysis.
19 We do have DC-backed buses. The highest safety class
20 1 DC buses are credited in our safety analysis.
21 However, we configure it such that, even upon loss of
22 DC, the plant is ensured to be safe. So we have this
23 plant such that, in the end, if loss of all
24 electricity, the plant will be in a safe
25 configuration. We'll talk more about the safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 features here in a minute.

2 So some other key features. I've already
3 mentioned some numerous times here already natural
4 circulation. I'll show a figure of the reactor
5 pressure vessel, but a key feature to support natural
6 circulation is the chimney. So I'll talk more about
7 that.

8 The coolant preservation approach which I
9 briefly touched on. So we have more coolant in this
10 plant because it is natural circulation in this
11 reactor. We also introduce a coolant what we call
12 coolant preservation approach where we strategically
13 place nozzles on the reactor pressure vessel
14 relatively high, well above the top of active fuel,
15 so, thereby, improving the ability to cool the fuel
16 even in the event of a loss of coolant accident. So
17 we remove by design threats to cooling the reactor by
18 doing that.

19 And mentioned the reactor isolation
20 valves. I'll show more in upcoming slides. The
21 containment is a dry containment. It is nitrogen
22 inerted and it does have passive cooling. Mentioned
23 the acronym SCCV, Steel Plate Composite Containment
24 Vessel. So the construction of this plant is a steel
25 concrete steel, steel plate, diaphragm plate, or DPSC,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Diaphragm Plate Steel Composite construction. That's
2 both for the containment and for the reactor building.

3 MEMBER HALNON: Can you tell me what the
4 approximate volume of the containment is?

5 MR. HINDS: It's a little less than 7,000
6 cubic meters.

7 MEMBER HALNON: That's a couple orders of
8 magnitude less than the big ones that we're used to
9 seeing. I think the standard PWR is around 2 million
10 cubic feet.

11 MR. HINDS: I can't quote off memory the
12 PWR standard.

13 MEMBER HALNON: Yeah, it's anomalous, at
14 least the ones I've worked on.

15 MR. HINDS: Okay. Thank you.
16 Overpressure protection is provided by the isolation
17 condenser system along with the reactor scram
18 function. We have submitted LTR on that which I'll
19 bring up in upcoming slides. Emergency core cooling
20 is performed by the isolation condenser system in
21 conjunction with the reactor isolation valves. Some
22 of the upcoming figures will help reinforce these last
23 two bullets because they're quite significant bullets.

24 Can we go to the next slide please?

25 MEMBER ROBERTS: Yes, I guess we'll get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 into some of this with the detailed picture. This big
2 picture, it seems like the safety system is predicated
3 on shutting RIVs quickly on a leak and not shutting
4 isolation condenser valves on almost any scenario; is
5 that right?

6 MR. HINDS: That's a good observation, and
7 yes. So, in accident configurations, for example, if
8 we were to postulate a loss of coolant accident, then
9 the configuration would be similar to what you
10 described or the same as what you described, meaning
11 power generation-associated piping systems connected
12 to the reactor vessel are automatically isolated.
13 Isolation condenser system is placed in service to
14 provide cooling and pressure control. So, yes, you're
15 correct.

16 MEMBER ROBERTS: What kind of prototype
17 response are you assuming for the isolation valves?

18 MR. HINDS: The isolation valves, we have
19 an overall 15 seconds credited. That includes sense,
20 you know, the signal to be generated, to be sensed, to
21 go through the IEC platform, and then the closure
22 function. Closure function is generally credited to
23 be around five seconds once all the commands, once the
24 sensing command is all complete.

25 MEMBER ROBERTS: Okay. I guess it goes

1 without saying you've tested that with the various DPs
2 you will have during the event.

3 On the isolation condenser valves, are
4 they serving a containment isolation function?

5 MR. HINDS: So the isolation condenser
6 system valves, as with other reactor isolation valves,
7 they serve a dual function of reactor isolation and
8 containment isolation. I'll note that for the
9 isolation condenser system, there's very, very little
10 of that system that goes outside of containment. It
11 goes straight up through the top of containment to the
12 heat exchanger and straight back. So the only portion
13 that's outside of containment is the heat exchanger
14 immersed in a pool.

15 But the answer to your question is the
16 reactor isolation valves serve a dual role of
17 containment and reactor isolation.

18 MEMBER ROBERTS: Yes. I think with the
19 isolation condenser valves, obviously, the lesson we
20 learned from Fukushima is there can be conflicting
21 design requirements on needing to keep them open for
22 decay removal and for containment isolation, and
23 that's part of the longer list of problems that caused
24 that accident. If we could sort of talk about that
25 later, about how you'd meet the dual requirement of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 shutting them for containment isolation and keep them
2 open for decay removal?

3 MR. HINDS: I'll touch on it now, but I'll
4 try to touch it on again. But very good observation.
5 The isolation condenser system performs a high safety
6 significant function. We protect that function. And
7 keeping the system in service when it's needed is
8 highly important.

9 So, yes, there is also containment and
10 reactor isolation function. The high priority safety
11 function of that system is to cool the fuel. So the
12 prioritization is that the system will cool the fuel,
13 and the design is accordingly. We do have leak
14 detection and isolation functions if there were to be
15 a loss of coolant via that system. But there was a
16 high priority given to within the design of ensuring
17 that system remains in service. That's a safety
18 function.

19 MEMBER ROBERTS: Okay. Obviously, the
20 devil is in the details on this one, but it just seems
21 like it's a challenge going in to have safety
22 functions that are basically conflicting and having to
23 manage both of them.

24 MR. HINDS: I understand your question.
25 It was a very good question.

1 This slide is a busy slide, but I'll call
2 it a brief overview of our defense in depth and safety
3 strategy approach. We have a safety strategy
4 licensing topical report with the NRC, and this is a
5 graphical or figure representation of much of the
6 information within that. I'll give a brief overview,
7 which should be coming through -- there will be
8 further communication associated with the safety
9 strategy since it is currently under review.

10 So we've taken a very, very rigorous
11 approach to defense in depth on this plant design from
12 the beginning. It's not an overlay or not an
13 afterthought. It's embedded in the design, and this
14 figure helps to represent.

15 So at the top we have physical barriers
16 that we're protecting. That's the fuel cladding, your
17 reactor coolant pressure boundary, and the
18 containment. Then we have what we call defense lines
19 labeled there in the center of the figure. The
20 defense lines 2, 3, 4A, 4B, that's the way we stack up
21 our defense in depth approach and we align within the
22 design functions that are assigned to defense lines to
23 ensure that those physical barriers are protected and
24 maintained and that the fundamental safety functions
25 of fuel cooling, confinement of radioactivity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 material, and radioactivity control are maintained.

2 So we rigorously go through postulations
3 of events and ensure for each and every event that's
4 postulated that not only do we have a defense line
5 function, such as an actuation of a reactor scram for
6 reactivity control, not only do we have function
7 within a defense line to defend against that threat to
8 safety, we also have a defense in depth measure such
9 that we also, at the same time, are protecting from
10 failures within our safety functions, such as a common
11 cause failure. It's built in to our designs, so we
12 can withstand a common cause failure of a control's
13 platform, for instance. It's built in to this layered
14 approach, such that we have two layers of defense to
15 the event sequences that we've postulated that begin
16 with a postulated initiating event. We characterize
17 those events into categories of AOO, or anticipated
18 operational occurrence, design basis accident, or
19 design extension conditions. So we cover the whole
20 spectrum of event sequences from the more frequent to
21 the very infrequent. And we apply this approach to
22 ensure safety is maintained if that event were to
23 occur.

24 The event sequences are layered such that
25 we postulate the initiator, then we take the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 event and we'll postulate failure of a mitigating
2 feature to prove effectiveness of the next line of
3 defense within defense in depth. Defense line 1,
4 shown in a couple of places on this figure, is a way
5 that we capture robust design to start with, such that
6 our goal is we don't even want the event to occur to
7 start with. But if the event were to occur, these
8 defense lines 2 through 4B are there to defend against
9 the event and ensure safety is maintained.

10 A lot of information on this slide, but it
11 is a very, very rigorous approach of defense in depth.
12 I would say the functions that are assigned to those
13 defense lines, we also apply design rules to them and
14 classification rules. So the safety classification of
15 these different defense lines varies.

16 The one in the center, defense line 3, is
17 what's been safety category 1 or what's analogous to
18 safety related. But we can't ignore the defense lines
19 2 and the 4A and 4B, which also have a safety
20 classification using a classification approach that's
21 aligned well with the International Atomic Energy
22 Agency and other programs within the industry, such
23 that we have a safety category 1, safety category 2,
24 safety category 3, and a non-safety category within
25 our design. And that flows all the way through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 design, as well as the procurement of the associated
2 components.

3 MEMBER HALNON: Quick question then.
4 These are all just design features, not operational
5 programs, correct? Or do you have operational
6 programs embedded in the defense lines?

7 MR. HINDS: I'd say much of the
8 operational programs would be, I'd characterize as
9 embedded in the defense line 1 in that the operational
10 programs, as well as the maintenance and other
11 programs, help to ensure that the plant is in a proper
12 state for operation and is a robust design and
13 operation. And that underlies part of our thinking of
14 minimize the event to start with.

15 Now, there are programs also that are
16 graded on the associated quality programs and controls
17 programs for the procurement of components within each
18 of the physical defense lines, as well.

19 MEMBER HALNON: So it's sort of
20 cross-cutting defense?

21 MR. HINDS: Yes.

22 MEMBER HALNON: Is the operator credited
23 for any LDE incident?

24 MR. HINDS: So the operator is not
25 credited for design basis accidents. Our design has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 been that if we see that -- if we postulate an event,
2 event sequence, and, therefore, we design a defense
3 line feature to mitigate that event, it is never the
4 operator. It is a feature within the design. Of
5 course, the operator is important to be there and is
6 part of the overall insurance that the plant has
7 operated within its expected operational bands.
8 However, the defensive measures that I'm labeling
9 here, defense lines 2 through 4B, those are design
10 features that are highly automated or fail safe and
11 fail in a safe state, not the operator.

12 MEMBER HALNON: Okay. Thanks.

13 MR. HINDS: Next slide, please.

14 CHAIR HARRINGTON: I think this is
15 probably a convenient time to take a short break. We
16 do have one question from Dennis Bley, I believe.
17 We'll do that before we break. Okay. Dennis.

18 DR. BLEY: Thank you. You kind of already
19 answered this question, but I like, I think I like the
20 approach you're taking, and it struck me it's a very
21 similar approach IAEA and others in Europe have worked
22 on, and I think you said that.

23 That approach also looks at each level of
24 either lowering the likelihood of getting into the
25 state you're in or reducing somehow the consequences

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 at that point. Is that right, that it's an evolution
2 of what they did over there, or is this something you
3 develop more on your own?

4 MR. HINDS: Yes. You're correct that it
5 is heavily based upon the IAEA approach. However,
6 there's very much work that we've done in order to
7 develop our implementation of that because, in many
8 cases, the guidance programs that we're both referring
9 to from IAEA are a little more general than the
10 specifics that we need to design and analyze the power
11 plant.

12 So we developed a significant amount of
13 detail to come up with the implementation program.
14 And like this figure, for instance, we developed
15 informed by IAEA, but we created this program and
16 figure. But I'd say it's very, very well aligned with
17 the IAEA.

18 DR. BLEY: Okay. Thanks. I've always
19 liked that approach, and I'm glad you found a way to
20 adapt it to what you're doing.

21 MEMBER HALNON: Dennis, you have a squeal
22 on your line. If you're on the same computer, I
23 suggest, during the break, you log off and log back
24 in. Maybe they'll fix it.

25 DR. BLEY: Okay. Thanks. I have a

1 problem with this computer as the NRC one. If Quynh
2 could send me another invitation so I could use my
3 other computer, that would help.

4 CHAIR HARRINGTON: Okay. We'll let this
5 this slide soak in for a few minutes. So we'll
6 reconvene at 25 after the hour. Thank you.

7 (Whereupon, the above-entitled matter went
8 off the record at 10:11 a.m. and resumed at 10:29
9 a.m.)

10 MEMBER HALNON: So, David, since we lost
11 the record there for a little while, could you start
12 back up on the first LTR?

13 MR. HINDS: Yes. So this is a brief
14 summary of the licensing topical reports that have
15 been submitted and reviewed and then, in further
16 slides, we'll go through licensing topical reports
17 that are currently under review. So this slide has
18 licensing topical reports that have been submitted and
19 already reviewed.

20 The first LTR was NEDC-33910, and that
21 focused on reactor isolation, reactor pressure vessel
22 isolation function and overpressure protection
23 function. And in brief summary, this function was to
24 isolate the reactor, including there would be a
25 reactor scram that would occur, reactor scram,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 isolation, and isolation condenser systems come into
2 service, overpressure protection would be performed by
3 the function of the reactor scram plus isolation
4 condenser system cooling. I'll note the isolation
5 condenser system has a substantial capacity such that
6 it can handle the cooling function of decay heat,
7 including those of a pressurization transient. We'll
8 go through that a little more on an upcoming slide of
9 isolation condenser, but this was all introduced in
10 the 33910.

11 The next LTR is 33911, or NEDC-33911,
12 move from reactor boundary to the containment
13 boundary. We introduce the type of containment, which
14 is a dry nitrogen inerted containment with passive
15 containment cooling, and also included in this LTR was
16 the containment isolation function, which includes an
17 integration between an outside reactor or containment
18 isolation, coupled with the inside containment
19 isolation being performed by the reactor isolation
20 valves. This was all introduced in the 33911.

21 The next topic introduced by the LTR was
22 NEDC-33912. Yes.

23 CHAIR HARRINGTON: This is Craig real
24 quick. For the piping segment from the RIVs to
25 containment moment restraint, do you have to treat

1 that piping differently in any way?

2 MR. HINDS: Well, I'll say that piping is
3 very specially designed to special stress rules. It's
4 extremely robust as such that it would meet any rules
5 associated with, for example, break exclusion zone,
6 which is part of the French technical position with
7 the U.S. NRC. It meets those rules, so maybe that's
8 getting to the point.

9 CHAIR HARRINGTON: Yes, that's what I'd
10 suspect. Okay.

11 MR. HINDS: The 33912 LTR was reactivity
12 control. Much of the reason for this LTR and the
13 focus is on the means of reactor shutdown. And this
14 plant uses fine motion control rod drives, which have
15 both a hydraulic insertion method and a motor
16 insertion method. This design and the associated
17 controls and platforms associated with it, giving us
18 two means of shutdown via fast reactor scram and a
19 fast motor run-in, along with the controls platform,
20 since command and actuate type of platform, to give us
21 protection mitigation for an assurance of a reactor
22 shutdown when needed. And compliance was addressed
23 associated with the ATWS rule for the U.S. NRC.

24 And I'll note that we did justify and
25 credit those two means of control rod insertion. I'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 note from a design perspective, I think most of you
2 are probably very well familiar with the history of
3 the hydraulic scram functions. For the motor run-in
4 function for this plant, we did include some special
5 design features such as the speed of the motor is such
6 that it gives effective mitigation even in the case of
7 loss of the hydraulics if we have a common cause
8 failure. And we did include a UPS system for
9 insurance that power would be available for that
10 second means of shutdown. Topics of reactivity
11 control were addressed in this LETTER.

12 Next slide. Okay. This is continuing on
13 into already reviewed LTRs. So the first one on this
14 page is 33922, which is containment evaluation
15 methods. If you remember on the prior slide, there
16 was one on containment functional performance. This
17 continued all in the theme of and more detail
18 associated with how the containment is designed and
19 analyzed. So this licensing topical report introduced
20 the analytical methods and qualification of those
21 analytical methods for containment performance in the
22 presence of a design basis accident. So this LTR
23 built upon what was already introduced in 33911 and
24 33910 focused on the containment.

25 The next LTR was for civil structural

1 area, and it was 33914, advanced civil construction
2 and design approach associated with the reactor
3 building design. It's an embedded reactor building
4 design with a Diaphragm Plate Steel Composite
5 construction. So those aspects of embedding the
6 reactor building in the ground and being constructed
7 with the steel plate and concrete composite
8 construction, the associated design requirements and
9 analytical methods were introduced in this licensing
10 topical report.

11 MEMBER MARTIN: I'll ask a question here
12 on your containment evaluation methods. As you noted
13 early in your presentation, you've been through this
14 with the ESPWR, ESBWR. So really much departure from
15 those methods that you introduced, I guess, over a
16 decade ago.

17 MR. HINDS: We did change the methods. So
18 there's an evolution. We changed the design, which
19 prompted us to change the methods. So, in ESBWR, we
20 actually use TRACG as the analytical tool for both
21 reactor cooling system and containment. And, as I
22 think you're probably aware, the ESBWR had a wet
23 containment, pressure suppression, suppression pool
24 type containment. BWRX-300 has a dry containment, no
25 suppression pool.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 That change in design type prompted us to
2 revisit our analytical methods, so that's what we
3 introduced in 33922. We transitioned from the TRACG
4 tool for containment. TRACG is still used on BWRX-300
5 for the analytical tool for reactor coolant system.
6 But for the containment performance, we are using
7 GOTHIC as far as the primary tool. The mass and
8 energy release comes from TRACG and is handed off to
9 GOTHIC for the response that the containment performs.

10 MEMBER MARTIN: Pretty standard in that
11 sense, yes.

12 MR. HINDS: It's recognized tools.

13 MEMBER MARTIN: Yes, exactly.

14 MR. HINDS: We just selected a different
15 one than we had in our predecessor designs that we
16 introduced at the LDR.

17 Next slide, please. Okay. Now we're into
18 licensed topical reports that are still under review.
19 The prior ones, just for a reminder, have already
20 completed their review. So the first one of these is
21 33926. And since these are still under review, I
22 would assume you'll hear more.

23 The one on the prior slide that I
24 mentioned that was civil structural oriented was for
25 the reactor building Diaphragm Plate Steel Composite

1 construction. This one's focused on the same type of
2 construction of the Diaphragm Plate Steel Composite,
3 but on the containment is included in this LTR. And
4 so it really builds upon what was already introduced
5 in the prior page LTR, but it gets more into the
6 containment, as well. You can see within here the
7 bullets of what's introduced, the design approach and
8 methodology, materials, fabrication, many topics
9 covered, and the associated criteria for this seismic
10 and ASME. From the containment perspective, seismic
11 and ASME structure/component. Functionally, it's a
12 component; but, physically, it's a structure.

13 So this is all still under review, so I
14 didn't intend to go very deep into this since it'll be
15 more introduced as it continues through the review.
16 It looks like Ray has a comment maybe.

17 MR. SCHIELE: For Greg, to answer a
18 question about where zero was? If you look on there,
19 at that picture, zero's right at the bottom base of
20 the fuel pool. If you look on the right-hand figure,
21 see the red floor? That's a green.

22 MEMBER HALNON: The thicker one.

23 MR. HINDS: Yes, the thicker one. Yes.
24 The top red floor. So, basically, the majority of the
25 containment is embedded underground, as you can see by

1 what we just discussed, and the majority of the reactor
2 pressure vessel is underground, and the pools are
3 above ground.

4 I'll note that while we're on the figure
5 also that with the pools above ground, but they're
6 near grade; it's very easy to get water in them.
7 They're for refill. These pools are non-pressurized.
8 So just in your thinking about defense in depth and,
9 you know, eventually a pool needs refilled, it's not
10 very hard to get water in these pools. They're very
11 close to grade elevation, and they're not pressurized.

12 But, anyway, I'll just highlight that, and
13 also I'll highlight a couple of other things. Okay.
14 So the green here is just colored like that to show
15 the outline of containment, and the red is the reactor
16 building structure around the containment. They're
17 both cylindrical, cylindrical containment inside of a
18 cylindrical reactor building, and we just spoke about
19 the embedment.

20 The refueling area is that area up in the
21 top, of course, and in those pools, many of the pools
22 up top have, from the pool it would look like a roof,
23 but from above it would look like a floor and it
24 serves as refilled floor. So the isolation condenser
25 system pools are underneath concrete so, basically,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 underneath the refueling floor. The fuel pool is an
2 open pool. So the isolation condenser system pools
3 are again covered by concrete, and the reactor cavity
4 pool is an open pool which is right above the reactor
5 pressure vessel. You can see here it's got blue there
6 indicating there's water in it and it does have water
7 in it. It's normally a flooded reactor cavity as
8 opposed to a dry reactor cavity.

9 MEMBER MARTIN: So these pools, so,
10 obviously, the boundaries are concrete, but they're
11 steel lined? Is that the intent or what's the support
12 for the pool?

13 MR. HINDS: Yes. The structural support
14 is concrete. Concrete, yes. And then there's
15 appropriate liners, where appropriate, for liners to
16 ensure that there's no, you know, there's watertight
17 boundaries. Exactly, yes.

18 CHAIR HARRINGTON: So more than just the
19 steel composite plate, steel in their surface, there
20 would be a pool liner in addition to that?

21 MR. HINDS: Where appropriate. So, for
22 instance, in the fuel, yes.

23 CHAIR HARRINGTON: And with the concrete
24 roof, floor, over those pools? I guess there's then
25 a vent path forward.

1 MR. HINDS: Exactly, exactly, yes; you're
2 correct. So I'll have another figure on the isolation
3 condenser system. It may help highlight some of these
4 features. I'm just trying to show the physical layout
5 within the building, but your statement is correct.
6 The isolation condenser system pool surface is vented
7 to atmosphere and there is, as we both said now, a
8 roof over and there's a vapor space above the water
9 surface and that vapor space is vented.

10 CHAIR HARRINGTON: Dennis has a question,
11 but, first, let me ask one other clarifying thing. On
12 the earlier cross-section of this area of containment,
13 there's one segment that was not marked as a pool. I
14 guess that's access for shipping fuel in and out and
15 things like that.

16 MR. HINDS: Oh, I understand your question
17 now. Yes. There is an area that allows for access
18 from grade level into the structure for, like, for
19 instance, one of the figures that Ray had shown has
20 showed a cask in there. So a spent fuel container
21 cask can be moved and loaded within the pool, lifted,
22 moved out via that access, for example. And there's
23 also access such that equipment can be moved to and
24 from the refueling floor.

25 So, yes, you're correct. There is an

1 access area in one of the quadrants, and there's also
2 a personnel access area over in another quadrant. But
3 we do take up a lot of real estate of the upper
4 portion of the building near grade with water.

5 And back to the heat sink question you
6 asked earlier, the safety heat sink you're looking at,
7 the safety heat sink is all protected within that
8 safety category 1 or safety related structure. The
9 power generation heat sink is the one that's outside.
10 So it makes for quite a robust protection of ensuring
11 the cooling is maintained for safety. It's all inside
12 the structure.

13 CHAIR HARRINGTON: Dennis.

14 DR. BLEY: Yes. Over on the right side,
15 just below the 15-foot level, there's what looks like
16 a penetration. Is that a way to bring outside water
17 in an emergency, or what is that?

18 MR. HINDS: I was having a little trouble
19 seeing the -- okay. I see where you're looking.
20 There are some penetrations up above grade. For
21 example, HVAC has to come in and out of the buildings.
22 We do have penetrations for HVAC. We do have other
23 service penetrations that aren't shown here for piping
24 and cables. There is, since you're asking about
25 penetrations, I'll also mention there is a steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 tunnel area that's a quadrant where it's right up at
2 the top of containment. On this representation, I
3 believe it'd be over on the left side of the figure,
4 just underneath the pool surfaces. There's a
5 dedicated room there that's radiation controlled where
6 the steam and feed water pipes, for example, exit
7 containment, go through a steam tunnel, and go out to
8 the turbine building.

9 But I believe the penetration you're
10 pointing to, I believe, is HVAC. It's just
11 representative penetration.

12 DR. BLEY: Okay. And they just don't show
13 what's going on inside. Okay. Thanks.

14 MR. HINDS: Okay. Can we go to the next
15 slide, please.

16 MEMBER MARTIN: Where is the load to
17 support the reactor vessels? What level is it at?

18 MR. HINDS: The reactor vessel is
19 supported by a pedestal structure. If you see the
20 blue --

21 MEMBER MARTIN: Yeah.

22 MR. HINDS: -- RPV pedestal shown there.
23 It's a cylinder. So, we have lots of cylinders here.
24 So, we have a reactor building cylinder, containment
25 cylinder inside of that, and inside of the containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cylinder is another cylinder, the reactor pressure
2 vessel cylinder, and the reactor pressure vessel sits
3 down inside of that cylinder.

4 It has a dual function. It provides
5 shielding and it also provides support of the reactor
6 pressure vessel. There's a skirt assembly you can see
7 up about mid-height on the reactor pressure vessel,
8 which is part of the reactor pressure vessel assembly,
9 and that's where the connection is made between the
10 reactor pressure vessel and the pedestal, and the
11 pedestal is supported down on the base mat.

12 MEMBER MARTIN: So, like in your seismic
13 analysis --

14 (Simultaneous speaking.)

15 MR. HINDS: Yes.

16 MEMBER MARTIN: A lot of attention there.

17 MR. HINDS: The pedestal is a very big
18 focus area in the seismic analysis, yes. Good
19 question.

20 CHAIR HARRINGTON: And this is Craig
21 again. I guess the little gray circles there and down
22 below are airlocks?

23 MR. HINDS: Yes, we do have accesses to
24 the containment, and we have airlock access. We have
25 equipment. We have upper and a lower access, and so,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 yes, you're pointing at the upper and the lower.

2 Upper is focused on doing maintenance on
3 valves and other components of the upper portion of
4 the containment, and the lower is focused on doing
5 maintenance on under-vessel components normally sealed
6 and closed as part of containment boundary during
7 operation. Okay, next slide, please.

8 This is, I believe, the last one of the
9 licensee topical reports that we have listed here for
10 under review, and this -- no, I'm sorry, there's one
11 more, but anyway, this is the safety strategy. The
12 safety strategy is still under review.

13 I introduced that on the prior slide with
14 that figure with the defense-in-depth. Those types of
15 concepts are introduced in this safety strategy LTR,
16 and then there's a regulatory evaluation associated
17 with our design and analysis associated with that
18 approach that's introduced in this licensing topical
19 report.

20 As I mentioned before, we do have a graded
21 safety class, Safety Class 1, 2, and 3, and on safety,
22 and we made the connections between the design
23 analysis and the regulatory evaluation associated with
24 that defense-in-depth approach, and this includes
25 evaluation against the GDCs, for example, so that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 all embedded within this safety strategy LTR still
2 here under review.

3 CHAIR HARRINGTON: And so, the
4 implementation of this will be reflected in the FSAR
5 or will there be another separate report that captures
6 that?

7 MR. HINDS: In all aspects of our design
8 information, and analysis information, and then the
9 applications submitted by TVA define aspects of this
10 safety strategy embedded within there, the terminology
11 used and the classification of SSCs. It's already
12 embedded in there.

13 CHAIR HARRINGTON: Okay.

14 MR. HINDS: This gives the wrapper, if you
15 will, of introducing the whole concept, and the
16 process by which it's treated, and the regulatory
17 evaluation such that it's in a focused type of review
18 as opposed to scattering the review only within the
19 application.

20 CHAIR HARRINGTON: That's about where I am
21 in the PSAR, so I haven't seen that, okay.

22 (Laughter.)

23 MR. HINDS: Okay, next slide, please.
24 Okay, now I think we're to the last one. So, this is
25 also under review, a stability analysis licensing

1 topical report.

2 We introduced some concepts associated
3 with stability or the regulatory treatment of
4 stability within the reactivity control LTR that I had
5 previously mentioned of 33912, but this one goes
6 deeper and gets into the stability analysis of this
7 plant. It's a natural circulating power plant, so
8 many, including us, focus on ensuring thermal-
9 hydraulic stability is maintained within the plant.

10 Just a couple of notes on stability, I
11 mentioned previously in the other side that the core
12 design heavily leverages the prior design and
13 operation of the KKM core configuration, the same
14 number of fuel bundles and core configuration.

15 It leverages the learnings from the prior
16 natural circulators, and the analytical methods are
17 built upon that. Also, I have test and development
18 programs that further feed into that. So, the
19 specific topic of stability and the associated
20 analysis is introduced in this licensing topical
21 report.

22 The core design that I've mentioned
23 several times here, its behavior is such that it's
24 very tightly coupled and we do not see threats to
25 regional instability in these. The core is not big

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 enough.

2 If we don't see threats to regional
3 instability, I'll contrast it to the larger ESBWR,
4 which has already been reviewed by the U.S. NRC. We
5 did focus on regional stability on the ESBWR, but we
6 found with the size and the type of core we selected
7 for this plant, it's very closely coupled and regional
8 stability is not an issue.

9 And we present those concepts and topics
10 within a combination of the construction permit
11 application, the 33912 which has already been removed,
12 and this LTR here, but it behaves quite well with
13 stability. I've got some more topics, or more tidbits
14 on that that will come up in some future slides.

15 MEMBER HALNON: So, you're not going to be
16 worried about project power until the last stage, and
17 we think we're getting away from the mid-cycle
18 readjustment of control rods.

19 MR. HINDS: We're not ruling out rod
20 sequence exchange if that's what your last --

21 MEMBER HALNON: Yeah, yeah.

22 MR. HINDS: So, there will be some rod
23 pattern changes within the cycles. So, we have been
24 doing quite a lot of analysis with core design,
25 including the entirety of, you know, going through a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 cycle, and so there would be some rod pattern changes
2 within the cycle.

3 It's quite simple rod patterns on this
4 plant though. Primarily, we use a control cell core,
5 and primarily, it's four control rods doing --

6 (Simultaneous speaking.)

7 MR. HINDS: Well, that's what's doing the
8 -- in control at any one moment.

9 MEMBER HALNON: Okay.

10 MR. HINDS: Now, at another point in the
11 cycle, those four, we swap to a different four, but
12 it's typically two to three groups of control rods.
13 We have them in groups, two to three groups of control
14 rods primarily with groups of four, and the center rod
15 plays in some, that are actively in control. It's
16 quite simple.

17 MEMBER HALNON: So, you say you're trying
18 to design those out or at least minimize it?

19 MR. HINDS: We'll minimize sequence
20 exchanges, but I'm not ruling them out.

21 MEMBER HALNON: That would be very
22 helpful, especially with the low number of operators
23 and other things. That all complicates life when you
24 have to do sequence exchange.

25 MR. HINDS: Sure, sure, and the small, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 relatively small number of control rods helps as well,
2 as also the control cell core helps, and the
3 relatively small number of rods.

4 We also have, I'll mention to you since
5 you mentioned operations, we do have an automation
6 system which helps with control. So, we have
7 capability in the design to automate basically the
8 majority, if not all, of the functions you're alluding
9 to.

10 MEMBER HALNON: Okay.

11 MR. HINDS: Okay, next slide?

12 MEMBER MARTIN: Just real quick, Bob
13 Martin. The TRs that you've presented, is that the
14 extent to which TRs are otherwise incorporated by
15 reference in the CPA? I anticipate that maybe there's
16 a fuel one maybe that follows from other designs that
17 may already have been approved, but --

18 MR. HINDS: I don't know. Kelli, do you
19 have a comment to that, topical reports incorporated
20 by reference?

21 MS. BANKS: So, the topical report that is
22 incorporated by reference is NEDC-33922, I think, is
23 the right number, the containment evaluation
24 methodology licensing topical report. That one is
25 incorporated by reference because it, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 provides summaries of the methodology and things like
2 that.

3 The remainder of the LTRs are referenced
4 within the PSAR where appropriate. Limitations and
5 conditions, you know, are addressed within the PSAR.
6 The only one that is incorporated by reference is that
7 containment I had mentioned.

8 MEMBER MARTIN: Okay, well, I wasn't
9 really covering all of that, so, but nothing else,
10 like, related to fuel?

11 MR. HINDS: Well, as we've said, we're
12 highly leveraging the past history of methods, use of
13 TRACG, for example, that do continue.

14 MEMBER MARTIN: You mentioned GNF2 fuel
15 and I know there's a topical report, possibly, once
16 upon a time.

17 MR. HINDS: I'll need to defer to --

18 MEMBER MARTIN: I think it incorporated it
19 into --

20 MR. HINDS: -- Ray or Kelli on the
21 regulatory treatment.

22 MR. SCHIELE: So, there are quite a few
23 topical reports that are referenced.

24 MR. HINDS: Yeah.

25 MR. SCHIELE: But in Chapter 1, I believe

1 there's two things listed as incorporated by
2 reference, and that's the containment performance that
3 Kelli mentioned and the QA topical report for 17.5.
4 Those are the only two things we have listed as
5 totally incorporated by reference.

6 MR. HINDS: Thank you.

7 MR. SCHIELE: Go ahead.

8 MR. HINDS: Okay, next slide, please.
9 Okay, so now transitioning off of the LTRs and just
10 going back to the same design features that I
11 introduced before, so just a transition slide. If you
12 could move to the next slide, please.

13 We've already hit on some of these topics,
14 but I give you little quick visuals as well anyway
15 just to reinforce the history. Natural circulation is
16 known and we do have historical data as well from
17 plant, excuse me, plant operation, as well as from
18 tests, and so this is just a very brief summary of
19 some of the history.

20 So, I'll highlight a few things on here,
21 one I've already mentioned, but I'll mention again, is
22 that Dodewaard is heavily leveraged in our history and
23 analysis. We also have stability testing that was
24 performed. We have, that was mentioned, operating
25 plant.

1 Again, that was a forced circulation plant
2 that had a recirc pump trip, and we did stability data
3 gathering, which once the pumps are tripped, it
4 becomes a natural circulator, and so the data is
5 useful for both forced circulation plants as well as
6 natural circulating plants.

7 We've done chimney two-phase flow testing
8 to ensure that the chimney, which is the area annular
9 space up above the reactor pressure vessel where the
10 steam transitions up to the separators and dryer, the
11 chimney two-phase flow, it's very important that we
12 understand that, and we do, and we've done testing to
13 show that, and our computers models for tests check
14 against the analytical, I'm sorry, the test data.

15 Start-up characteristics, a natural
16 circulator starts up differently than the forced
17 circulating plants. We've done testing for start-up,
18 and I've already mentioned TRACG is qualified to this
19 type of data.

20 The part I mentioned on stability, we were
21 very strategic about our selection of core size and
22 also the core power density. So, we've selected core
23 size and power density to make it behave very well,
24 natural circulation in a stable fashion, and we've
25 proven that analytically and it's backed up by these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 tests. So, much of this, I've already covered, but
2 it's just a reinforcement. Next slide?

3 CHAIR HARRINGTON: This is Craig, real
4 quick.

5 MR. HINDS: Yes?

6 CHAIR HARRINGTON: The chimney, and two-
7 phase flow, and start-up characteristics, were those
8 primarily non-nuclear test facilities or a little of
9 both?

10 MR. HINDS: Yes, those tests were not using
11 nuclear fuel. Now, of course, that operating BWR
12 stability test was an operating plant, but the other
13 bullets that you're pointing to or referring to,
14 those, there was no nuclear fuel. Of course, we used
15 nuclear-grade quality controls. However, they were
16 not nuclear fuel.

17 CHAIR HARRINGTON: Okay.

18 MR. HINDS: But the thermal-hydraulics
19 still stand.

20 CHAIR HARRINGTON: Sure.

21 MR. HINDS: Okay, next slide, please.
22 This is just showing the configuration of the reactor
23 pressure vessel and the internals. Just, and some of
24 it is talking about our operating experience to also
25 give a brief summary of the configuration of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reactor pressure vessel.

2 So, the design and fabrication of the RPV
3 is consistent with our past designs and very well
4 know, so operating experience, as well as design and
5 fabrication experience. There's the KKM plant I
6 mentioned, which we leveraged for the core size and
7 design, the chimney, the Dodewaard plant did have a
8 chimney, and we've done testing to also prove chimney
9 behavior.

10 So, to make sure everyone knows what I'm
11 talking about with the chimney, maybe you can see it's
12 pointing to the chimney region. It's in the center of
13 the RPV in this figure, and the chimney is simply a
14 cylindrical steel structure on top of the core shroud
15 assembly. The core shroud is underneath and the fuel
16 is within the core shroud. If you can read the
17 labeling, it will help.

18 The shroud is the cylinder, steel cylinder
19 around the fuel. The chimney is the steel cylinder
20 with just a steam space. The control rods come in
21 from the bottom, and as with our other BWRs, they
22 control reactor power.

23 So, the left descriptions give just a
24 little more about our history and understanding of
25 these individual components. The steam dryer is

1 virtually the same or very similar to past dryers, and
2 the separators are the same or similar to past steam
3 separators.

4 The separators and dryers, of course, are
5 in the upper portion of the reactor vessel on top of
6 the chimney drying the steam as it exits. I already
7 mentioned the fuel is widely used and the control rods
8 as well.

9 The fine motion control rod drives, we
10 have experience from them, from the design and
11 operation of the ABWR and the design of the ESBWR.
12 So, they have operational experience, two means of
13 insertion, and one means of withdrawal. The one means
14 of withdrawal is by motors. The two means of
15 insertion is hydraulics and motors. I have another
16 figure that shows the simple assembly of the fine
17 motion control rod drive. Next slide, please.

18 CHAIR HARRINGTON: Real quick.

19 MR. HINDS: Yes?

20 CHAIR HARRINGTON: This is Craig. The
21 shrouds on there --

22 MR. HINDS: Yes.

23 CHAIR HARRINGTON: -- between the core
24 plate and the top guide --

25 MR. HINDS: Yes.

1 CHAIR HARRINGTON: -- is there something
2 in there?

3 MR. HINDS: That's the fuel. That's the
4 core. So, sorry, we didn't -- we only have one, it
5 looks like one bundle in this visual here, but the
6 core is inside the shroud.

7 So, the core -- the fuel, the 240 fuel
8 bundles fit inside that area above the core plate and
9 supported on the bottom by fuel support castings,
10 which are inserted into the core plate, and the top,
11 you get lateral support there from the top guide.

12 CHAIR HARRINGTON: I failed to read the
13 label of control rod guide tubes at the bottom and was
14 assuming that was the core.

15 MR. HINDS: It's easy -- it's a lot of
16 stack-up here. So, the control guide tubes are down
17 there now as you see, and then the control rod drives
18 down below.

19 CHAIR HARRINGTON: That makes entirely --
20 (Simultaneous speaking.)

21 CHAIR HARRINGTON: I just didn't study it
22 close enough.

23 MR. HINDS: Okay? And again, that's just
24 a steam space up above the core. So, this would be
25 very similar to an existing boiling water reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 except for we insert the chimney in there, and there's
2 an annular space around both the chimney as well as
3 the shroud, which is where the downflow comes for
4 natural circulation. Okay, next slide, please.

5 This is just a representation of the fine
6 motion control rod drives, and again, there's motors
7 and there's hydraulics, and the motors provide for
8 insert and withdrawal. The hydraulics will lift if
9 needed, and if a hydraulic scram occurs, lift the
10 control rod basically up off of the ball nut and
11 insert it.

12 And so, these two means, although they
13 move the same control rods, they can function
14 independently. So, a scram from hydraulics is not
15 impacted by the motors, and the motors can insert
16 regardless of whether the scram worked or not, so two
17 means of shutdown of inserting control rods. Normal
18 power control is with the motors, with our fine motion
19 and very small movements. Next slide, please.

20 This is showing the core representation
21 and some instrumentation. We have in-core
22 instrumentation similar or basically the same as our
23 operating experience with local power range monitors
24 or LPRMs. They're inserted within the core and spaced
25 around to their appropriate locations within the core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 such that we get a full power reading at power, during
2 power operation.

3 And then for startup and low-power
4 operation, we also have, within the core, wide-range
5 neutron monitors. All of those neutron monitors, they
6 are non-movable. They're fixed in-core. We calibrate
7 our local power range monitors by using gamma
8 thermometers that are integral on the LPRM string.

9 They sense the gamma flux and equate that
10 to a neutron flux and use that as a calibration
11 standard for the local power range monitors. We also
12 have a small little representation out on the
13 periphery showing of an in-core water level
14 measurement from below.

15 CHAIR HARRINGTON: So, two questions. As
16 a PWR guy, the neutron monitors, do they also provide
17 flux mapping capability axially or --

18 MR. HINDS: Yes, the LPRMs have sensors
19 that are spread in a predetermined fashion on the
20 axial, as well as we have them placed in the
21 designated locations you can see on the figure here
22 radially, but yes, there's four sensors there giving
23 power levels at different axial locations.

24 And then the gamma thermometers are there
25 to actually give a diverse indication of the neutron

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 flux that can be used or the gamma flux that can be
2 correlated to the neutron flux and that then can be
3 used to compare for calibration standard, but yes,
4 there is an axial measurement.

5 CHAIR HARRINGTON: And then the water
6 level, water sensing, what type of sensor?

7 MR. HINDS: That's a heated junction
8 thermocouple type, yeah, and it's just a diverse means
9 of water level sensing. It's only in the worst case,
10 if water level were to be extremely low. Our normal
11 water level sensing should sense normal operation as
12 well as the majority of accidents. For a very extreme
13 low-frequency accident, if the water level were to get
14 very low, this is the backup.

15 CHAIR HARRINGTON: Thank you.

16 MR. HINDS: Next slide, please.

17 MEMBER ROBERTS: I'm not very familiar
18 with this technology. How do you correlate the gamma
19 flux to power?

20 MR. HINDS: We've done in-core testing,
21 operating reactors, and we've done a significant
22 amount of analysis. There was quite a number of
23 submittals to the NRC under the ESBWR where that
24 technology was covered in licensing space, but there's
25 a significant amount of testing, both up to and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 including in operating reactors, and the gamma flux
2 does have, we have a correlation of gamma flux to
3 neutron flux which can be used to correlate to actual
4 reactor power.

5 MEMBER ROBERTS: So, there's no
6 calorimetric calibration required?

7 MR. HINDS: We do have a heat balance
8 that's running live time at all times. So, we have a
9 heat balance that's checking and used to calibrate for
10 the gain adjustment factors for the neutron monitors.

11 So, the gamma thermometers are primarily
12 there to -- they're local. The heat balance is global
13 or the whole system. So, the heat balance for the
14 whole system, the gamma thermometers can give us a
15 flux distribution across the various locations, both
16 radial and axial, within the core.

17 So, we can take that heat balance and
18 correlate that to the total core power, and then we
19 can use the gamma thermometers to assign that to the
20 various locations within the radial and axial
21 locations within the core, so we do both, but yes,
22 there is a, quote-unquote, calorimetric. We call it
23 heat balance.

24 MEMBER ROBERTS: Okay, that makes sense.
25 Thank you.

1 MR. HINDS: Okay, I've mentioned several
2 times the reactor isolation valves. Here's a visual
3 representation, dual valves attached directly to the
4 reactor pressure vessel and supports the coolant
5 preservation approach.

6 There is no piping between the reactor
7 isolation valves and the reactor vessel, so thereby,
8 there is no pipe that could break inboard of the
9 reactor isolation valves.

10 The nozzles associated with the reactor
11 pressure vessel are forged nozzles. They're
12 integrally fabricated with the reactor pressure
13 vessel, and then very significant bolting is used,
14 meaning, when I say significant, very high-strength
15 bolting used to connect a dual valve assembly directly
16 to the reactor pressure vessel, thereby supporting the
17 coolant preservation approach. So, if there were some
18 threat to coolant loss in the connective system, these
19 two redundant valves would close to isolate the
20 associated system.

21 MEMBER ROBERTS: Can you explain what
22 large means in that first bullet? So, that implies
23 there are some penetrations that are so --

24 MR. HINDS: Yes.

25 MEMBER ROBERTS: -- large they don't have

1 valves?

2 MR. HINDS: Excellent question. Yes, so
3 we've characterized every reactor vessel nozzle as
4 whether it needs the reactor isolation valve or not.
5 The only ones without reactor isolation valves are
6 very small instrument line connections for reactor
7 water level and pressure sensing.

8 And those are very carefully located
9 height-wise. They're at least four meters above the
10 top of active fuel, and they're also sized such that
11 even if we were to have a double-ended break of those
12 sensing lines, we would still maintain fuel cooling
13 over an extended period of time.

14 And within the PSAR, within the
15 construction permit application, we present an
16 analysis to show the response of the plant if we were
17 to have a break of those sensing lines, but anything
18 bigger than those sensing lines, which are less than
19 an inch in size, they would have integral isolation
20 valves.

21 MEMBER ROBERTS: So, there's some sort of
22 makeup capability that can keep up with a small line
23 break?

24 MR. HINDS: Well, as I mentioned in some
25 of the lead-in of the coolant preservation approach,

1 we start with a lot of coolant in this plant. Being
2 a natural circulator, we can break one of those
3 instrument lines, have zero makeup, provide decay heat
4 removal with the isolation condenser system.

5 There's enough coolant to last in excess
6 of three days. So, the passive capability requirement
7 of three days' cooling can be maintained, zero makeup,
8 even in the presence of an instrument line break, and
9 that's demonstrated by analysis in the PSAR.

10 MEMBER ROBERTS: Within the three days,
11 you'd have the capability to --

12 (Simultaneous speaking.)

13 MR. HINDS: Yes, we do have -- so, the
14 control rod drive system that was shown with the
15 control rod drives in the bottom of the vessel has a
16 normally running, at-all-times running purge water
17 system function to keep the control rod drives nice
18 and clean, and that purge water does serve a dual
19 function as a makeup.

20 Not much water is needed. Those
21 instrument lines, the coolant loss is minimal,
22 especially with the isolation condenser system
23 providing the cool down and depressurization in those
24 types of events.

25 MEMBER ROBERTS: Okay, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR HARRINGTON: And I read someplace,
2 I think, that you also credit those, that kind of a
3 leak as helping to achieve pressure balance between
4 containment and the vessel or --

5 MR. HINDS: We don't --

6 CHAIR HARRINGTON: -- am I making that up?

7 MR. HINDS: We don't -- I understand the
8 topic, I think, that you're touching on. The
9 containment pressurization actually can help to limit
10 any potential coolant loss. I think that's what
11 you're referring to, is --

12 CHAIR HARRINGTON: Yeah.

13 MR. HINDS: -- meaning we would catch and
14 collect that coolant if it were to be lost, say, for
15 instance, in an instrument line break or other line
16 breaks.

17 As the containment pressurizes and as the
18 reactor depressurizes, the equalization serves to
19 limit the coolant loss, and the isolation condenser
20 system capacity is large enough that it does
21 depressurize the reactor.

22 CHAIR HARRINGTON: And so, between the two
23 isolation valves, I would assume that trapped volume
24 is ported back to the vessel side somehow if it, so
25 that it doesn't heat up and --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. HINDS: We do evaluate the potential
2 for pressure lock or any of those types of functions,
3 but it's not ported back to the reactor vessel, and
4 that is a dual-valve assembly that we're showing here.

5 We're running either out or very short of
6 time, so you can stop me at any moment, but I'll keep
7 on moving until the point where you would like me to
8 stop. Next slide, please.

9 MEMBER MARTIN: I just can't help myself,
10 sorry, Craig. What's the technology maturity of those
11 IAVs or RIVs? Have you all fabricated and done some
12 testing or are you still on paper?

13 MR. HINDS: So, the testing, physical
14 testing of our specific valves has not yet occurred,
15 but is planned. We are using, I'll say -- I'll avoid
16 mentioning company names right now, but we are using
17 well-known, reputable valve and actuator suppliers
18 such that it's not their first introduction of valves.

19 We're leveraging their technology
20 evolution and basis, similar to what we were
21 leveraging our own technology evolution such that we
22 have high confidence in the concepts and the specific
23 application, but the physical specific tests that
24 we've asked them for has not yet been performed.

25 Because we've asked them to perform steam

1 shutoff tests to prove that, with our conditions, in
2 a worst-case type coolant loss, that the valves can
3 close and --

4 (Simultaneous speaking.)

5 MEMBER MARTIN: But ultimately, it's also
6 trying to eliminate breaks at those locations, right?

7 MR. HINDS: The, again, the --

8 MEMBER MARTIN: Well, in, say, a LOCA,
9 eventual LOCA analysis, will you still --

10 MR. HINDS: Just to clarify, there is no
11 piping, or to repeat, there is no piping inboard of
12 the reactor isolation valves --

13 MEMBER MARTIN: Right.

14 MR. HINDS: -- and that is a reactor
15 pressure vessel nozzle that's directly attached to a
16 valve, and that nozzle is very robust, similar,
17 basically thicker than the reactor pressure vessel by
18 virtue of the shape --

19 MEMBER MARTIN: Right.

20 MR. HINDS: -- and fabricated to the same
21 standards of the reactor pressure vessel, and the
22 bolting is quite significant.

23 MEMBER MARTIN: Okay, I just wanted to
24 make sure.

25 MR. HINDS: There are --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 (Simultaneous speaking.)

2 MEMBER MARTIN: -- record, really, or you
3 hadn't said it yet.

4 MR. HINDS: There are no piping welds
5 inboard.

6 MEMBER MARTIN: Are these --

7 MR. HINDS: Oh, and there is forged
8 assembly, and it's a forged valve assembly, forged
9 nozzle assembly and forged valve assembly directly
10 bolted together. The only weld for the nozzle, the
11 nozzle is actually part of the reactor pressure vessel
12 fabrication, which, you know, reactor pressure vessels
13 have full penetration welds.

14 MEMBER MARTIN: Sure.

15 MR. HINDS: Those nozzles are part of the
16 reactor pressure vessel fabrication.

17 MEMBER HALNON: Is this a feature of the
18 Darlington reactors?

19 MR. HINDS: It is.

20 MEMBER MARTIN: Okay, that was my
21 question, whether -- okay.

22 MR. HINDS: Yes, okay, next slide, please.
23 Okay, this is somewhat of a repeat, and the only
24 reason I included it is just to trace out one system,
25 this is the main steam system, to show you how it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 configured as a system.

2 So, you can see the reactor isolation
3 valves directly attach. We have two steam lines
4 directly attached to the reactor pressure vessel.
5 Then the piping runs out of containment. The
6 containment penetration is shown as that sleeve area,
7 and then there's additionally an outside containment
8 isolation valve for the main steam system.

9 So, there's three valves in series where
10 historically we've had two, and historically they've
11 been further removed from the energy source. So, now
12 we're having the ability to shut off right at the
13 energy source. That's our strategy there, coolant
14 preservation, and the isolation condenser systems help
15 to enable that to occur because the cooling is
16 maintained. Next slide, please.

17 You can stop me any time you're ready to
18 move on, but this is the isolation condenser system,
19 which I've mentioned several times. We have -- we
20 meet the passive plant rules of in excess of three
21 days of cooling of our passive system, but we, instead
22 of having a makeup to get between three and seven
23 days, we have already sized the cooling such that we
24 have in excess of seven days' worth of heat removal
25 contained in these pools.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 And Ray had already told you about the
2 pool figuration. There's a pool on one side of the
3 structure, with the Alpha heat exchanger immersed in
4 it, and there's a pool on the other side with the
5 Bravo and Charlie heat exchangers immersed in it.

6 So, there's three trains of isolation
7 condensers, and all that's needed to place them in
8 service -- you can see the blue valves down towards
9 the lower portion of the figure. There's two parallel
10 redundant valves. They're condensate return valves.

11 All that has to happen is one of those two
12 valves has to open. They're configured to fail open.
13 So, the failsafe nature here is this system fails in
14 a cooling function. Those valves, if they lose either
15 a mode of force or electrical power signal, they would
16 fail open and the system would go into service,
17 similar to all our other safety functions, fail in a
18 scram.

19 So, the failsafe nature of this plant is
20 that it would fail with the reactor shutdown via
21 hydraulic scram with stored energy. The reactor would
22 isolate via the reactor isolation valves.

23 The isolation condenser system would be
24 placed in service by simply opening one or two, or
25 both of those valves, allowing condensate flow to come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 back from the heat exchanger. All it is, is steam
2 flows in from the reactor into the heat exchanger.
3 It's condensed.

4 The LEGO (phonetic) condensate comes back
5 to the reactor vessel and it flows. We've chosen to
6 pour it into the chimney region of the reactor. It
7 helps to suppress pressure very well by putting it in
8 the chimney region. It actually suppresses core flow
9 and helps in even more severe events.

10 MEMBER HALNON: Is each ICS 100-percent
11 duty?

12 MR. HINDS: Yes, so for --

13 MEMBER HALNON: How are you going to swing
14 -- I mean, the Charlie one is sort of an extra?

15 MR. HINDS: We have a consideration of a
16 rotation, if you will, for -- I think you were talking
17 about duty on them. In a transient, all we would need
18 is one, and in a pressurization transient, all we
19 would need is one.

20 In a LOCA, we've chosen to configure the
21 logic such that all three will initiate. So, all
22 three will initiate, and that provides the maximum
23 cooling, and therefore depressurization in a LOCA to
24 help minimize coolant loss. I'll keep moving and stop
25 at any time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 CHAIR HARRINGTON: And we're going to try
2 to get through all of these slides, but do you have a
3 concern about overcooling since you've got 300
4 percent?

5 MR. HINDS: Excellent question. So, yeah,
6 there was some -- we looked very hard at did we over-
7 design and oversize? And, you know, it's very, very
8 beneficial to have them large from the standpoint of
9 pressure suppression, over-pressure control,
10 depressurization of LOCA.

11 And, oh, by the way, these have undergone
12 full-scale testing of this specific design as part of
13 our evolutionary design for SBWR and ESBWR. So, we
14 wanted to preserve that testing and we also wanted the
15 excess capacity.

16 So, to your question, part of our design
17 of the reactor pressure vessel and the isolation
18 condenser system is to build into it the thermal
19 cycles and the stress associated with the cool-down
20 effects of both transients as well as accidents.

21 We select the numbers of postulation
22 through postulation of how many we would put into the
23 design of those metal components to build those stress
24 cycles, so it's already built-in, the stress cycles,
25 into the nozzles, the RPV, the system, so we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 built in the cooling effect.

2 Now, of course, we select the cycles
3 appropriately based upon the probability of a LOCA and
4 how many the plant would be postulated to have in the
5 life of the plant.

6 CHAIR HARRINGTON: And reactivity as well,
7 I assume, is not a concern for that kind of --

8 MR. HINDS: Oh, no. Now, I mentioned
9 briefly that it discharges into the chimney area.
10 Discharging into the chimney area mitigates the
11 reactivity portion since we're not shooting cold water
12 directly into the inlet of the reactor, so it actually
13 helps to suppress power.

14 So, if we were to have a fail-to-scream,
15 initiation of the isolation condenser system helps
16 with both pressure control and reactivity control, as
17 opposed to herding reactivity control. Good question.

18 MEMBER HALNON: Seven days' coping time is
19 -- days four through seven, any operator action at
20 all?

21 MR. HINDS: No operation action.

22 MEMBER HALNON: So, it's fully happening
23 --

24 MR. HINDS: Yes.

25 MEMBER HALNON: -- all the way through?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: The other thing about the
2 seven-day, I assume that's assuming all your
3 uncertainties, your conservative, your safety
4 analysis. Realistically --

5 MR. HINDS: We can go a long time beyond
6 that.

7 MEMBER MARTIN: I mean, have you -- you
8 know, of course, you have 300-percent capacity to
9 cool, but is your pool sized? I mean, is it --

10 MR. HINDS: Yes.

11 MEMBER MARTIN: -- really 21 days, you
12 know what I mean, or --

13 MR. HINDS: I won't commit to you all how
14 many days beyond seven, but it's beyond seven. There
15 is some detailing of some of the, you know, overflows,
16 drains, and all of the details of the pools that can
17 have impacts to that.

18 (Simultaneous speaking.)

19 MEMBER MARTIN: -- connectors between the
20 pools, right?

21 MR. HINDS: Yes. Oh, yeah, let me
22 describe that a little further, and we significantly
23 will exceed seven days, so, to your general point, but
24 the pool, the inner and the outer pools. The inner
25 pools are segregated such there's no communication out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of the inner pools. You cannot lose water from the
2 inner pools even if you lose the entire outer pools.

3 The outer pools serve -- they are
4 interconnected. The outer pool is basically one
5 functionally, and the outer pool provides passive flow
6 into the inner pool, and it's via underwater piping
7 and check vales, so one-way flow, the water from the
8 outer to the inner, but it cannot come out of the
9 inner, regardless of what you do to the outer pool.

10 And so, the outer can makeup to any of the
11 inner pool, both of the inner pools, and the inners
12 are segregated such that the Bravo Charlie does not
13 communicate at all with the Alpha pool.

14 MEMBER MARTIN: So, the inner pool, just
15 so I'm 100 percent, the outer pools will cover the
16 other maybe 200 pools.

17 (Simultaneous speaking.)

18 MR. HINDS: Yeah, you know, for the seven-
19 day coping, we're going to need the outer pool.

20 MEMBER MARTIN: Okay.

21 MR. HINDS: But the inner pool is
22 primarily there just to protect the first few days.

23 MEMBER MARTIN: Sure.

24 CHAIR HARRINGTON: Is there some logic or
25 issue for having two trains in one pool?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. HINDS: It's mostly geography within
2 the building. Yeah, and so what we wanted to do was
3 have the nozzles coming off the reactor pressure
4 vessel around, you know, and segregate the trains
5 within the containment, and we wanted to shoot as
6 close to straight out.

7 We want to minimize crossties and things
8 such as running all the way around containment, and so
9 we go almost straight up, so it's mostly geography of
10 the piping runs.

11 CHAIR HARRINGTON: And you had a quadrant
12 for access outside for casks, and fuel, and all that?

13 MR. HINDS: Yes, so the center between
14 them is used primarily for refueling activities. So,
15 there needs to be a segregation of one side of the
16 building to the other basically primarily for the
17 reactor cavity and the refueling.

18 CHAIR HARRINGTON: And one side had more
19 real estate to fuel and the other side --

20 MR. HINDS: Yes.

21 CHAIR HARRINGTON: -- needed some real
22 estate?

23 MR. HINDS: Yes, because as you noted,
24 there is, in some quadrant, there is accesses with no
25 water, so, yes, you're correct. Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 This is just more of the same. I think I've covered
2 everything here. It's just a different figure to show
3 more functionally with the valves.

4 But again, I'll reinforce that this system
5 is always pressurized, steam pressure on top and then
6 condensate back on the backside, and the only thing
7 preventing it from actually flowing is one of the two,
8 the two closed condensate return valves that are
9 configured such that they'll fail open.

10 MEMBER ROBERTS: So, what is the strategy
11 for containment isolation, your third bullet there?
12 We talked about it earlier this morning. There's a
13 conflicting safety requirement.

14 MR. HINDS: Yeah.

15 MEMBER ROBERTS: You want to have the
16 system online for cooling, but you need to sometimes
17 isolate it for containment.

18 MR. HINDS: Yes, we've prioritized this
19 system and we designed -- first off, we designed from,
20 like, our Defense Line 1 type of approach. We've
21 given the highest ASME class, the highest safety
22 class, and the highest treatment of this system to
23 ensure that it will not break, and stress rules, et
24 cetera.

25 This is an ASME Class 1 system in its

1 entirety. It's considered part of the reactor coolant
2 system boundary. The valves for isolation are all
3 attached directly to the reactor pressure vessel,
4 those reactor isolation valves. There is no valve
5 outside of containment for isolation.

6 It's a closed-loop, a simple closed-loop
7 that goes in the heat exchanger and comes immediately
8 right back. The prioritization within our logic and
9 control scheme is that cooling wins. The cooling
10 function is the safety function of this system.

11 The likelihood that we were to have a
12 coolant loss from this system is very, very low. The
13 likelihood that we would need this system for cooling
14 is significantly higher. The safety function is the
15 high-priority function. We do not ignore the
16 potential for loss of coolant, and we do have leak
17 detection and isolation, but we do prioritize the
18 cooling function.

19 Next slide, please. This is just showing
20 a little more on the containment. I've already
21 covered most of this, but it's an evolutionary
22 containment design.

23 But I'll note that the choice for BWRX-300
24 was dry containment as opposed to pressure suppression
25 wet containment. And our containment LTRs that we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 presented to the NRC and already reviewed presented
2 both the analytical methods, the safety performance.
3 This works very well in conjunction with our coolant
4 preservation approach.

5 We don't have valves that blow the system
6 down to -- we don't have SRVs to a suppression pool is
7 really what I was alluding to. We have the isolation
8 condenser system rather that's discharging its heat
9 through the closed loop up in the isolation condenser
10 system pool.

11 So, dry containment was chosen and it's a
12 60 psi design pressure containment, cylindrical
13 containment, and we built upon both the structural as
14 well as the analytical and safety learnings from the
15 past. Next slide?

16 This is -- I've mentioned we have a
17 passive containment cooling system. This is it. It's
18 quite simple. It's an array of piping, and the array
19 of piping simply takes water from the pool up above.
20 Now, this is leveraging other pools.

21 I mentioned briefly that, you know, when
22 we were talking about the geography of the pools, on
23 one side of the building is the Bravo Charlie pool and
24 the other side of the building is Alpha pool for
25 isolation condensers. In the center alley between

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there is an equipment pool, and a reactor cavity pool,
2 and a fuel pool.

3 There's gates that segregate the fuel pool
4 from those other pools, but those other pools are
5 always flooded during operation. We've leveraged the
6 water within them for a dual purpose for -- they're
7 used for refueling, but we also use that same water as
8 the heat sink for the passive containment cooling
9 system.

10 It's very simple. There's no moving parts
11 needed to place this in service. It's always in
12 service. It's just its flow is determined by the heat
13 demand, so just the differential density drives water
14 down the cold leg and runs it back up the hot leg, and
15 so the differential head and differential density
16 causes water movement there, so it acts similar to a
17 radiator, but it's a piping array that's spaced around
18 inside the containment, up very close to the
19 containment inner surface.

20 It removes heat. It's very, very
21 effective as a condensing surface for steam. If there
22 were to be a loss-of-coolant accident, the steam would
23 condense on these tubes and help to suppress the
24 pressure within the containment.

25 MEMBER HALNON: I know you've got seismic

1 isolated, but are you concerned, anything about
2 sloshing? You've got these pools that are at the
3 highest point of their structure.

4 MR. HINDS: Well, they're actually not at
5 the highest point of the structure, but they are up
6 there. They're up --

7 (Simultaneous speaking.)

8 MR. HINDS: They're actually right around
9 grade elevation. So, they are, relative to the base
10 mat, they're pretty high, but relative to the ground,
11 they're not high, so that's the kind of --

12 MEMBER HALNON: Yeah.

13 MR. HINDS: But, yes, and, of course, we
14 look at any dynamic loads as well.

15 CHAIR HARRINGTON: And I suppose since all
16 three of those heat exchanger panels lead into the
17 same pool --

18 MR. HINDS: They do.

19 CHAIR HARRINGTON: -- the single pool is
20 somehow treated in the safety case as, I guess, it's
21 further down the list of concerns, so having them all
22 in a common pool is not --

23 MR. HINDS: Yeah, it's just a -- treat it
24 as a common heat sink, but yes, you're correct, and we
25 haven't found failure modes that would cause concern

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there. It is a very simple system and it doesn't have
2 moving parts. And anyway, we did not see the need for
3 creating a segregation scheme in there, and we do
4 multipurpose these pools.

5 CHAIR HARRINGTON: And you've got 15
6 seconds to stop the LOCA in progress so you don't have
7 a huge heat dump to containment.

8 MR. HINDS: The heat load on these is not
9 -- the heat load on the isolation condenser systems is
10 relatively large. The heat load on these is not
11 anywhere even close. We don't even boil these pools.
12 We boil the isolation condenser pools, but these do
13 help to minimize the peak pressure within the
14 containment, but the majority in a LOCA --

15 Remember, when an isolation condenser
16 system is initiated, it's depressurizing the reactor.
17 That's where the energy's coming from, and if we're in
18 a LOCA, you know, theoretically, we're communicating
19 -- if we haven't isolated it, we're communicating with
20 the containment, so this is taking what got discharged
21 to the containment and just helping to minimize the
22 pressurization.

23 We do -- you know, it's a 60 psi
24 containment, so we do have pressurization, but this
25 helps to limit the peak, especially in a small break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 LOCA like the one that we were talking about for the
2 instrument line break, you know, where we postulate a
3 continual steam discharge. It's condensing on these
4 tubes.

5 I think this was the last slide. Is there
6 another slide? That's the last one. Sorry for my
7 time management. I went over.

8 PARTICIPANT: No, it's completely our
9 fault.

10 CHAIR HARRINGTON: And this was -- the
11 point of today is yeah, yeah, to cover all of this
12 information, and I think it's been very helpful. Many
13 of us are new on the committee since a detailed
14 presentation from GE on this design, so that was
15 getting us all kind of up to the same point was really
16 the intent today --

17 MR. HINDS: Thank you.

18 CHAIR HARRINGTON: -- and we very much
19 appreciate that. Are there other questions?

20 MEMBER HALNON: Real briefly, from a
21 multi-reactor site perspective, have you envisioned
22 what systems would be shared and economies of scale?
23 How would that look?

24 MR. HINDS: The current design as
25 developed -- that's a very good question. You know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 of course, things could change with time, but the
2 current concept is these, this standard plan is
3 standalone, so it doesn't matter if it's single unit
4 or multi-unit.

5 Where the sharing is primarily implemented
6 to be design site specific is when you get into
7 support functions around the power block structures.
8 So, the current approach is to make the power block
9 stand alone, and then as desired by individual
10 customers, optimize sharing of administration --

11 (Simultaneous speaking.)

12 MR. HINDS: -- security administration,
13 security, even, you know, replenishment or makeup, you
14 know, fire protection.

15 MEMBER HALNON: What about diesel
16 generators? Do you think that -- is that --

17 MR. HINDS: Currently not shared. That's
18 an excellent question, but currently there are two
19 diesel generators as part of this standard design
20 dedicated to that unit. That was a very reasonable
21 question.

22 MEMBER HALNON: Is it designed to be an
23 energy island to where it could be disconnected from
24 the grid?

25 MR. HINDS: That would be a site-specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 customization. The standard design is neutral on
2 that. Now, I will say a little bit to the point you
3 were alluding to. The standard design is not, does
4 not have the 100-percent bypass capability of steam
5 bypass to the condenser.

6 Therefore, if there's a load reject from
7 100-percent power, the standard design has a reactor
8 scram because there's, you know, the load reject. We
9 have, within our experience base, certainly the
10 capability to introduce a higher bypass capacity, but
11 the current standard design does not have 100-percent
12 bypass.

13 MEMBER HALNON: It's not a black start, is
14 it?

15 MR. HINDS: Not part of the --

16 (Simultaneous speaking.)

17 MEMBER HALNON: Not the diesel generators,
18 I mean.

19 MR. HINDS: Not part of the standard
20 design. We would need a power source to power
21 features such as condenser cooling water or
22 circulating water.

23 The diesel generators back with the
24 standard design are sized to back functions such as
25 fuel pool cooling, shutdown cooling, but more nuclear-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 specific functions, from a defense-in-depth, and
2 restoration of battery chargers and recharge your
3 batteries.

4 This is all sized for that, but not sized
5 large enough to power and configure it in the bus work
6 to power the circulating condenser cooling water or
7 cooling towards, for example, so additional power
8 would be needed for, you know, for example, cooling
9 tower loads.

10 MEMBER HALNON: Last question, extreme
11 temperatures, how does it look for very hot and very
12 cold?

13 MR. HINDS: I can't recall the TVA PSAR
14 temperature extreme limit, but we do have quite a
15 range of temperatures from cold, very cold to very
16 hot, you know.

17 MEMBER HALNON: I mean, you're putting it
18 in Canada, so.

19 MR. HINDS: Yes, you know, working in a
20 snowbound territory.

21 MEMBER HALNON: Just so you know more
22 about the cold, I mean --

23 MR. HINDS: Yeah.

24 MEMBER HALNON: -- they have a pod.

25 MR. HINDS: Yes, we do have consideration

1 for adjustments primarily within the HVAC system on a
2 site-specific basis because it doesn't make great
3 sense to have all of the HVAC sizing completely
4 standard, so there is allowance for site-specific
5 adaptation to, you know, resizing of some of the HVAC
6 components. Their structures are built to accommodate
7 that.

8 MEMBER HALNON: Thanks.

9 MEMBER MARTIN: I'll just follow that up.
10 See, you do have a specific design. These guys have
11 a specific design in mind. Are you all just looking
12 to deploy the standard plant or have you asked for
13 anything unique that might touch on some of the things
14 Greg said?

15 MR. HUNNEWELL: So, we have not started
16 the site-specific design. We have considered things
17 such as islanding and black start capabilities, and
18 that would be really driven by if there was a need.
19 For example, we're adjacent to the Oak Ridge facility.

20 If Oak Ridge came along and said, hey, we
21 want you to be part of our resilient power supply and
22 you need to have black start capability, that's when
23 we would likely look at that, because it does add
24 costs and we are very cost conscious on it.

25 MEMBER MARTIN: Yeah, I know, of course,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Clinch River has been thought of in the sense of
2 supporting Oak Ridge for a long time specifically, so
3 you can see them having unique needs.

4 MEMBER HALNON: Yeah, and you've also got
5 Hermes up there too.

6 MEMBER MARTIN: And then you have Hermes,
7 so, yeah, a little competition for small things there,
8 huh?

9 MR. HUNNEWELL: Very small.

10 CHAIR HARRINGTON: Other questions? Do
11 any ACRS members or consultants online have questions?

12 MEMBER KIRCHNER: Yes, I have one, Craig.
13 This is Walt Kirchner. Thank you for the
14 presentation, everyone. Just, it was mentioned that
15 when the containment, when the isolation condenser
16 system is operated, that would probably lead to
17 boiling.

18 Would the normal configuration be to close
19 the reactor building, isolate that as well, and would
20 that then contribute to a very wet atmosphere inside
21 the building in terms of the equipment qualification,
22 et cetera?

23 MR. HINDS: For the isolation condenser
24 system, as I mentioned, there's a roof, if you will,
25 or there's a slab up above the isolation condenser

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 pools.

2 MEMBER KIRCHNER: Right.

3 MR. HINDS: And that slab serves as, you
4 know, a top for the pools, and there is a vapor space
5 between the top of the pool surface and the slab.
6 That vapor space is vented outside. So, there is a --

7 MEMBER KIRCHNER: That's vented outside,
8 okay.

9 MR. HINDS: Yes.

10 MEMBER KIRCHNER: Can you isolate that if
11 necessary?

12 MR. HINDS: It's --

13 MEMBER KIRCHNER: Or you would isolate a
14 condenser, one of the three trains if you, for
15 whatever reason, detected a release?

16 MR. HINDS: Yes, the latter, what you just
17 said, in that --

18 MEMBER KIRCHNER: Okay, okay.

19 MR. HINDS: -- we do not isolate them. We
20 do not isolate the vent because that would basically
21 plug up the, you know, basically tend to pressurize
22 the pool vapor area --

23 MEMBER KIRCHNER: Sure.

24 MR. HINDS: -- but we do have the leak
25 detection and isolation for, if there was a leak

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 within a train, to isolate that train and that train
2 only.

3 MEMBER KIRCHNER: Okay, thank you.

4 CHAIR HARRINGTON: I noticed in the PSAR
5 that it mentions that you are not distinguishing
6 between identified and unidentified leakage? I don't
7 know. I'm a PWR guy. I don't know if that's
8 typically in a BWR or is new here. Can you speak to
9 that?

10 MR. HINDS: So, on past BWRs, say current
11 forced circulation BWRs, for example, like Browns
12 Ferry, for example, there is reactor recirculation
13 pumps. They took the green, what is it, green side
14 there, you know, so that's a forced circulation plant,
15 reactor recirculation pumps. Those recirculation
16 pumps have a designed seal leak-off. That designed
17 seal leak-off is routed to an equipment train tank
18 within that design.

19 It's planned to have flow there, and
20 because there's planned flow, then there is the
21 segregation for things that were to leak in the
22 containment, so you could segregate the two. In this
23 plant, we do not have design leak-offs such as that
24 within the containment.

25 So, anything that were to be, call them

1 present coolant, collect in the sump, it would be from
2 something that's not planned. It would be a leaking
3 component, for example, so that's the unidentified
4 leakage.

5 So, because there was no designed leak-
6 off, we did not include the equipment trains. They're
7 all just unidentified and collected in a common sump.

8 CHAIR HARRINGTON: And not a lot of other
9 water sources in containment that would be confused
10 without any --

11 MR. HINDS: No, it's --

12 CHAIR HARRINGTON: Okay.

13 MR. HINDS: There are coolers within
14 containment, but we also collect the condensate from
15 the coolers, which would be indicative. If there's
16 condensate in the dry containment, then it must have
17 been some vapor coming out of some component, for
18 example.

19 CHAIR HARRINGTON: Okay, all right, that
20 all makes sense. Thanks. Any other last questions?
21 Okay, well, we very much appreciate your time today to
22 prepare and come. As we -- in the coming months,
23 we'll be starting our review and trying to figure out
24 how to focus that. I mean, this session today is very
25 helpful.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER HALNON: Public comments?

2 MR. HINDS: Yeah, we do have to do that,
3 appreciate that. So, anything else before we go out
4 for public comments?

5 MR. NGUYEN: Yes, I was going to say
6 public comments.

7 CHAIR HARRINGTON: Okay, if there is
8 anyone online in public that has a comment to make
9 yourself, then do so. Identify yourself and your, any
10 organizational affiliation, and make your comment.

11 I don't see any indication of any public
12 comments, so I think, with that, we can adjourn the
13 meeting. Thank you again very much for coming today.
14 With that, the meeting is adjourned.

15 (Whereupon, the above-entitled matter went
16 off the record at 11:46 a.m.)

17

18

19

20

21

22

23

24

25

TVA Clinch River Nuclear Project

Construction Permit Application – Application Overview

Ray Schiele
Senior Licensing Manager

FOR ILLUSTRATIVE PURPOSES ONLY

Topics

Introductions

TVA Mission and the Role of New Reactors


Pathway from Early Site Permit to Construction Permit Application

Structure/Content of the Construction Permit Application

Questions

TVA Mission and the Role of New Reactors


BUILT FOR THE PEOPLE OF THE VALLEY



Since its inception, TVA has innovated to meet the needs of the Valley.


Today and in the future, the Valley needs **affordable, reliable, resilient, and secure energy** to lead the nation in energy innovation and economic development.

TVA's Clinch River Nuclear Site



The CRN Site is located on 935-acres of TVA land in Oak Ridge, Roane County, Tennessee adjacent to US Department of Energy Oak Ridge Reservation.

TVA's ESP to CPA Submittal Timeline



Construction Permit Application Content (CPA)

Content of TVA CRN-1 CPA

Enclosure 1- General and Administrative Information

- 10 CFR 50.33 Contents of applications; general information

Enclosure 2 – Preliminary Safety Analysis Report [Non- Public]

- 10 CFR 50.34(a) Contents of applications; technical information.
- NUREG 0800 Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: (LWR Edition)
- Reg Guide 1.70 Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)

Enclosure 3 – Preliminary Safety Analysis Report [Public]

Enclosure 4 – Exemptions and Variances



- 10 CFR 50.12 Specific exemptions
- 10 CFR 52.39 Finality of early site permit determinations

Enclosure 5 – Environmental Report

- 10 CFR 51.50 Environmental report-construction permit, early site permit, or combined license stage
- NUREG 1555 Standard Review Plans for Environmental Reviews for Nuclear Power Plants
- ⁶ Reg Guide 4.2 Preparation Of Environmental Reports For Nuclear Power Stations




PSAR Chapter 1 Introduction and General Plant Description




PSAR Chapter 2 – Site Characteristics and Site Parameters

- Dispositions ESP-006 Permit Conditions and COL Action Items
- Updated CRN Site Characteristics and Parameters
- Aspects of CRN ESPA Site Safety Analysis Report Incorporated by Reference
- PSAR Table 1.8-1 provides a cross reference of Site Safety Analysis Report information that is incorporated by reference into this PSAR:
 - ❑ 2.0 Plant Parameter Envelope Evaluation
 - ❑ 2.1 Geography and Demography
 - ❑ 2.2 Nearby Industrial, Transportation and Military Facilities
 - ❑ 2.3 Meteorology
 - ❑ 2.4 Hydrologic Engineering
 - ❑ 2.5 Geology, Seismology, and Geotechnical Engineering
 - ❑ 13.3 Emergency Preparedness
 - ❑ 13.6 Physical Security

CRN-1 Site Plan Confirmatory Core Bores




Chapter 3-Design of Structures, Systems, and Components




BWRX-300 Design Feature

- Safety Strategy LTR in Review (Section 3.2)
- DPSC LTR Rev 3 in Review (Section 3.8)



Chapter 4 – Reactor & Chapter 5 – Reactor Coolant System and Connected Systems



BWRX-300 Design Feature

- Natural Circulation BWR
- Increased RPV height
- Tall chimney
- Reactor Isolation Valves
- Flow Stability LTR In Review
- Reactor Isolation Valves

Chapter 6 – Engineered Safety Features






Figure 6.3-1 Isolation Condenser System Simplified Diagram



Note: Valves are not shown.

Figure 6.2-1 Passive Containment Cooling System Configuration



UDH is segmented into nuclear SC3 controllers and functions and BOP Non-Safety Classified controllers and functions. Each network segment is redundant and can function independently.

Operator workstations and historians are associated with each segment and also operate independently.

For reliability and avoidance of AOO failures, the non-safety plant mechanical systems are controlled by triplicated controllers.

Workstations, controllers, gateways and historians are always SC3 quality.

Network segmentation is transparent in normal operation.


The UDH bus segmentation and the system architectures within a Safety Class represent an initial decomposition of the overall I&C systems based on safety classification. Further refinement of the bus arrangement and system decomposition (based on functional grouping within a safety class and equipment selection), will be performed as the I&C Architecture design process progresses.

Chapter 7 – Instrumentation and Controls

Chapter 8 – Electric Power


Chapter 8 Contents Includes:

- Offsite and Onsite Power Systems
- Uninterruptible Power Supply



NOTES:

1. TRANSIENT VOLTAGE SURGE SUPPRESSORS MAY BE SEPARATE DEVICES OR INTEGRAL TO RVTs AS SHOWN.



BWRX-300 Design Feature

- The BWRX-300 does not require AC power to reach a safe, stable shutdown following an Anticipated Operational Occurrence or a Design Basis Accident
- Stored energy via batteries is provided:
 1. Ensure that all functions that maintain the plant in a safe condition are available
 2. Monitoring equipment can be powered for at least 72 hours following a Design Basis Accident.




Figure 9.1-2 Fuel Pool Arrangement

Chapter 9- Auxiliary Systems

BWRX-300 Design Feature

- Multiple credited Ultimate Heat Sinks
- BWRX-300 water is strategically located during operations in SC1 pools to last for 7 days until FLEX/EME replenishment




Figure 9.2-3 Ultimate Heat Sink Pools Simplified Diagram

Chapter 10 – Steam and Power Conversion System

Chapter Contents Includes:

- Turbine Generator
- Main Steam System
- Additional Steam and Power Conversion Systems




Figure 10.1-1 Simplified Flow Diagram with Representative Heat Balance of the Steam and Power Conversion System

Chapter 11 – Radioactive Waste Management

Chapter Contents Includes:

- Source Terms
- Liquid Waste Management System
- Gaseous Waste Management System
- Solid Waste Management System
- Process Radiation Monitoring

Chapter 12 –Radiation Protection

Chapter Contents Includes:

- Occupational Radiation Exposure ALARA
- Radiation Sources
- Radiation Protection Design Features
- Dose Assessment
- Health Physics Program

Chapter 13 – Conduct of Operations

Chapter Contents Includes:

- Organizational Structure
- Training
- Emergency Preparedness
- Operational Programs
- Plant Procedures
- Physical Security
- Fitness for Duty

Chapter 14 – Initial Test Program

Chapter Contents Includes:

- Scope of Initial Test Program
- Design Features that are Specific, Unique or First of a Kind
- Conformance of Test Programs with Regulatory Guides
- Test Program Schedule
- Augmenting Staff During Test Program

Chapter 15 – Safety Analyses

Chapter Contents Includes:

- Considerations of the BWRX-300 Safety Analysis
- Identification, Categorization and Grouping of Postulated Initiating Events and Accident Scenarios
- Safety Objectives and Acceptance Criteria
- Human actions
- Deterministic Safety Analyses
- Probabilistic Safety Assessment
- Results of Deterministic Safety Analyses and Probabilistic Safety Assessment

BWRX-300 Design Feature

- Re-characterization of Safety Related/Non-Safety Related to the Safety Class 1, 2, 3, N structure

Chapter 16 – Technical Specifications

Chapter Contents Includes:

- Preliminary Safety Analysis Report Requirements
- Regulatory Guidance for Preliminary Technical Specification Contents
- Conformance with Industry Standards and Practices
- Methodology for Selection of Preliminary Technical Specification Contents
- Results of Selection Methodology Application

Chapter 17 – Quality Assurance

Chapter Contents Includes:

- Quality Assurance During Design and Construction Phases
- Design Reliability Assurance Program
- Quality Assurance Program Description-New Reactor Applicants

Topical Report - NNP-TR-001-NP

- Quality Assurance Program Description for TVA New Nuclear incorporated by reference.
- Final Safety Evaluation contains Limitations and Conditions (PSAIs) and are disposition in Chapter 17.5

Enclosure 4 – Exemptions and Variances

Exemptions

- Reactor Vessel Material Surveillance Program

Variances

- CRN ESP VAR 2.0-1 Site Grade Level
- CRN ESP VAR 2.0-2 Ground Water Level
- CRN ESP VAR 2.0-3 Single Unit Thermal Megawatts
- CRN ESP VAR 2.1-1 2020 Census Data
- CRN ESP VAR 2.2-1 Nearby Industrial, Transportation and Military Facilities
- CRN ESP VAR 2.4.12-1 Groundwater Level Models
- CRN ESP VAR 2.4.12-1 C-1 Groundwater Vistas Version 8.19 Build 4

Questions/Comments/Actions






BWRX-300 DESIGN

Outline



- BWRX-300 Design Overview
- Unique design features for:
 - Reactor Pressure Vessel (RPV)
 - Reactor Isolation Valves (RIVs)
 - Isolation Condenser System (ICS)
 - Passive Containment Cooling System (PCCS)

Boiling Water Reactor (BWR) Innovation



- BWR concept developed in the 1950s
- Continuous evolution in the design
- Main changes related to:
 - Steam cycle
 - Recirculation flow
 - Nuclear fuel
 - Containment

BWRX-300 Design Overview



Size

~300 MWe gross electrical output
RPV inner diameter ~ 4 meters
RPV height ~ 27 meters
240 bundles of GNF2 fuel
57 control rods


Passive Design

Safety Category 1 functions are not dependent on AC generated sources of power nor operator action to control reactivity, remove heat from the fuel, and confine radioactive material for 72 hours following a design basis accident

Select Key Features

Natural circulation BWR with increased height relative to a forced circulation BWR
RPV contains tall chimney, nozzles are well above Top of Active Fuel (TAF), and RIVs are attached directly to RPV
Dry, nitrogen inerted containment, which is cooled passively
Steel-Plate Composite Containment Vessel (SCCV)
Emergency Cooling System is made up of ICS and RIVs
Overpressure protection is provided via ICS and reactor scram function

Defense In Depth ... Built Into The Design From The Start



NRC Approved Licensing Topical Reports (LTRs) for BWRX-300



NEDC-33910P-A, BWRX-300 RPV Isolation and Overpressure Protection (NRC Final Safety Evaluation Report (SER) Issued 11/18/2020)

Describes design requirements, acceptance criteria, and regulatory basis for RPV isolation and overpressure protection design functions for mitigation of loss-of-coolant accidents (LOCAs) and RPV overpressure events. LTR established ECCS for BWRX-300 as ICS and RIVs, and established overpressure protection to be made up of reactor scram and ICS functions. This allowed for the elimination of an automatic depressurization system, suppression pool, additional water inventory source, relief valves, and safety valves.

NEDC-33911P-A, BWRX-300 Containment Performance (NRC Final SER Issued 3/12/2021)

Addresses physical design requirements for new dry, inerted containment design (including containment vessel, containment penetrations and PCCS), and acceptance criteria requirements (design basis pressures and temperatures) for containment performance following the specified design basis accidents.

NEDC-33912P-A, BWRX-300 Reactivity Control (NRC Final SER Issued 1/12/2021)

Describes design requirements, acceptance criteria, and regulatory basis for reactivity control functions for shutting down the reactor following anticipated operational occurrences and design basis accidents. Allows removal of safety-related standby liquid control system from design, as one is not needed to comply with NRC Anticipated Transient Without Scram (ATWS) regulations.

NRC Approved LTRs for BWRX-300



NEDC-33922P-A, BWRX-300 Containment Evaluation Method (NRC Final SER Issued 4/27/2022)

Addresses development of and qualification of analytical methods for determining containment response (calculated containment pressures and temperatures over time) after a design basis accident for comparison with acceptance criteria of NEDC-33911P-A.

NEDO-33914-A, BWRX-300 Advanced Civil Construction and Design Approach (NRC Final SER Issued 4/27/2022)

Describes regulatory basis, analytical methods, design and inspection requirements, acceptance criteria and guidelines specific to the innovative approaches implemented for design and construction of the BWRX-300 Reactor Building vertical shaft design.

Applicable Limitations and Conditions (L&Cs) from previously approved LTRs are addressed in TVA PSAR


BWRX-300 LTRs Currently Under NRC Review



NEDC-33926P, BWRX-300 Steel-Plate Composite Containment Vessel (SCCV) and Reactor Building (RB) Structural Design (Initially Submitted to NRC 5/4/2023)

Seeks NRC approval for

- (1) The design approach and methodology of Diaphragm Plate Steel-Plate Composite (DP-SC) structural elements for the Seismic Category I SCCV and RB structures,
- (2) Requirements for the material, fabrication, construction, inspection, examination and testing of the DP-SC modules for the SCCV and RB structures,
- (3) Proposed criteria and requirements for materials, design, fabrication, construction, inspection, examination, and testing for the SCCV adapted from specific Section III requirements, and
- (4) Modified criteria and requirements for material, design, analysis, fabrication, construction, inspection, examination, and testing of non-containment Seismic Category I structural members, including slabs and curved walls, built using DP-SC modules



BWRX-300 LTRs Currently Under NRC Review



NEDC-33934P, BWRX-300 Safety Strategy (Initially Submitted to NRC 3/8/2024)

The BWRX-300 Safety Strategy applies a Defense-in-Depth design approach to achieve an internationally deployable design with an inherent high level of safety. NEDC-33934P describes the use of DL functions to mitigate design basis and beyond design basis events, and the resulting Structures, Systems, and Components (SSC) classification and seismic categorization.

NEDC-33934P, Rev. 1, seeks the following NRC approvals:

- (1) BWRX-300 Safety Class 1 (SC1) SSCs are equivalent to the “safety-related SSCs” definition in 10 CFR 50.2
- (2) The LTR identifies the correct set of SSCs that are applicable to GDCs involving “important to safety” or “protection system”
- (3) Safety Strategy event categorization process is acceptable
- (4) The LTR identifies the correct set of SSCs that are applicable to Technical Specifications Limiting Conditions for Operation Criteria
- (5) Identification of Regulatory Treatment of Non-Safety Systems (RTNSS) SSCs is not necessary, as the Safety Strategy already classifies such SSCs as Safety Class 3 (SC3) or higher.

BWRX-300 LTRs Currently Under NRC Review



NEDC-34270P, BWRX-300 Stability Analysis (Initially Submitted to NRC 3/31/2025)

The BWRX-300 Stability Analysis LTR supports an applicant fulfilling L&C 5.3 from NEDC-33912P-A, *BWRX-300 Reactivity Control*, thereby conforming to NUREG-0800 Standard Review Plan (SRP) 15.9, *Boiling Water Reactor Stability*, and demonstrating compliance to the acceptance criteria provided therein. NEDC-34270P requests NRC approval of the BWRX-300 stability analysis, which utilizes implicit numerical integration for channel components and a nominal core wide Decay Ratio acceptance criterion of ≤ 0.80 .

Design concepts for LTRs currently under NRC review are not expanded in this presentation, since these LTRs will get their own ACRS meeting, if required.


Unique Design Features



- Because GVH has utilized LTRs extensively for new or unique design features, ACRS has previously reviewed associated BWRX-300 design phenomena
- However, it's been several years since ACRS has seen some of these LTRs
- Presentation will focus on the following design features:
 - RPV
 - RIVs
 - ICS
 - PCCS

Natural Circulation – Background & Overview

- Proven effective operating power reactor technology
 - EBWR (20→100 MWt), Chicago
 - Dodewaard reactor (163 MWt), Netherlands
 - Humbolt Bay 3 (215 MWt), California
- Operating BWR data gathered from Stability tests under Natural Circulation and from Recirc Pump trip events benchmarks flow at higher power (> 1000 MWt)
- Chimney two phase flow testing conducted
- Startup characteristics testing performed
- TRACG code qualification includes above data – predicts natural circulation flow well at power when flows are much higher and at decay heat powers when flows are very low.
- Core power density/size and RPV configuration to support natural circulation flow are designed to ensure thermohydraulic stability




BWRX-300 Reactor Pressure Vessel (RPV) and Internals




Proven Components with Operational Experience

- **RPV** same material and fabrication processes as ABWR and much of the operating BWR fleet
- **RPV** diameter and fuel assembly arrangement similar to Kernkraftwerk Mühleberg (KKM)
- **Partitionless Chimney** drives core flow.
- **Steam Dryer** has same features as ABWR and replacement dryers in operating BWRs
- **Steam Separator** is same as in BWR/6s and ABWR
- **GNF2 Fuel** is widely used
- **Control Rods** essentially same technology used in operating BWRs
- **Fine Motion Control Rod Drives (FMCRDs)** essentially same as ABWR




BWRX-300 Fine Motion Control Rod Drives (FMCRD)

- Positive insertion means of controlling reactivity include:
 - Hydraulic scram control rod insertion function using the hydraulic control units and control rods
 - Motor-driven control rod run-in insertion function using the FMCRDs and control rods



Normal Configuration
(Hollow Piston resting on Ball Nut)




Hydraulic Scram
(Hollow Piston lifted from Ball Nut)


BWRX-300 Simplified View of FMCRD with Hydraulic Scram

Reactor Core Monitoring Instrumentation

- Local Power Range Monitors (LPRMs) and Wide Range Neutron Monitors (WRNMs) are distributed across the core to measure neutron flux
 - Each LPRM detector provide neutron monitoring sensitivity from ~10% core thermal power to greater than 100% reactor thermal power
 - Each WRNM detector is sensitive to neutrons from below criticality to power operation
- Fixed, in-core Gamma Thermometers (GTs) convert local gamma flux to an electrical signal, providing a diverse means of detecting core thermal power
 - GTs are used for neutron instrument calibration
 - Fixed, in-core GTs were also used in ESBWR




Reactor Isolation Valves (RIVs)



- All large RPV penetrations have two integral RIVs (excludes instrumentation lines)
 - Valves are installed directly on the RPV nozzles via flanged connections
 - Design consists of two valves in a single body
- RIVs are part of the reactor coolant pressure boundary and are ASME Class 1 components


Reactor Isolation Valves (RIVs)

- RIVs effectively mitigate large pipe breaks
 - Coolant loss is limited by one of two RIV closure for large breaks
- RIVs are also part of the containment isolation function (i.e., are the containment isolation valve inside containment)




Isolation Condenser System (ICS)

- Isolation Condenser System (three trains) provides heat removal/pressure control
- Mild transient response due to large steam volume in RPV
- No need for safety relief valves – ICS along with scram function provides overpressure protection
- Only one Isolation Condenser (IC) train required to respond to the transient.
- Seven-day coping time for station blackout and with passive system response to transients and design basis accidents
- Simple actions of adding water using installed systems or FLEX after seven days to increase time indefinitely




SEVEN DAYS COPING TIME

Isolation Condenser System (ICS) Functions




- ICS along with RIVs perform ECCS function since inventory is being retained and decay heat is being removed
- ICS in conjunction with reactor scram provides reactor pressure boundary overpressure protection when system is isolated
- ICS provides isolation capability to maintain Primary Containment integrity
- ICS returns condensate to the chimney in the RPV
- ICS provides heat removal in all modes when the RPV head is in place
- ICS mitigates pressurization transients, provides decay heat removal for isolation events, and provides pressure reduction in LOCA events to limit coolant loss


BWR Containment Design Evolution



BWRX-300 has a dry containment like the earliest BWRs



Passive Containment Cooling System (PCCS)



- During normal operation heat is removed from the containment by active cooling
- Following an accident, PCCS provides containment heat removal using passive natural circulation flow
- Heat is also removed from Containment naturally through the containment head
- PCCS is always in service unless portions are manually isolated (i.e., no active components or actuation signals required to initiate or maintain function)
- Equipment pool provides the cooling source for the PCCS heat exchangers
- Three independent trains each with a Passive Containment Cooling Pipe Array (PCCPA)
- Mounted to interior of Primary Containment wall
- Piping to and from the Equipment Pool



GE VERNOVA

1. Summary

Meeting title: Clinch River CPA - Overview

Attended participants: 98

Start time: 8/20/25, 7:26:52 AM

End time: 8/20/25, 1:35:51 PM

Meeting duration: 6h 8m 59s

Average attendance time: 2h 20m 33s

2. Participants

Name

Quynh Nguyen

Allen Fetter

Ricky Vivanco

Stacy Joseph

Thomas Dashiell

William Roggenbrodt

Ravi Penmetsa

Elias Haddad

India Banks

Shandeth Walton

Thomas Scarbrough

Steven Bloom

John Honcharik

Derek Widmayer

Theresa Buchanan

John Parillo

Angie Buford

Joshua Miller

Alexandra Terres

Walt Kirchner

Stewart Bailey

Allegra Chilstrom

Khadijah West

Shanlai Lu

13014153220

Dan Widrevitz

Michele Sampson

Steve Sarver

Stephen Cumblidge

Matthew Mitchell

Luisette Candelario-Quintana

Marissa Bailey

17035177420 (Unverified)

Karkour, Suzanne (GE Vernova)

Matthew Humberstone

Michael Benson

Jan Mazza

Mike Gallagher (Unverified)
Lentz, Tony Fraley
Roberts Banks, Kelli (GE Vernova)
Jackson, Tony
Petrarca, Dennis Allen
Syed Haider
George Thomas
Tammy Skov
Keith Miller
Gregory Halnon
Adakou Foli
Flynn, Martin (GE Vernova)
Hinojosa, Luis (GE Vernova)
Montague, Kelvin Jevon
Moorrees, Michele Yvette
Vesna Dimitrijevic
Dominik Muszynski (Unverified)
Ryan Nolan
Gordon Curran
Wadkins, George (GE Vernova)
Spencer Toohill (Unverified)
Casey Emler
Jason Thompson
Fanta Sacko
Robert Martin
Dave Gasperson
Lauren Gibson
dennis bley (Unverified)
Janet Riner
Andrea Torres
Stephen P O'Hearn (Services - 6)
Harrison Ngo
Kazanas, Marc T (GE Vernova)
Steven Pope
Jonathan DeJesus
Spencer Toohill (Unverified)
Carol Moyer
Christina Antonescu
Hosung Ahn
Christopher Brown
Joseph Staudenmeier
Raul Hernandez
Karen Sida
Mary H Miller (Services - 6)
Jordan Glisan
Michael Snodderly
Wendell Morton
Sandra Walker
Matthew Yoder

Tuccillo, Karen [DEP]
Roberto Torres Davis
Hossein Nourbakhsh
Edward Stutzcage
Dennis Bley
Cory Padilla
Spencer Toohill (Unverified)
Weidong Wang
Yoshinori TAKECHI_NRA Japan (Unverified)
Getachew Tesfaye
Madeleine Arel
John Bozga

3. In-Meeting Activities

Name

Quynh Nguyen
Allen Fetter
Ricky Vivanco
Stacy Joseph
Thomas Dashiell
William Roggenbrodt
William Roggenbrodt
Ravi Penmetsa
Ravi Penmetsa
Elias Haddad
Elias Haddad
India Banks
Shandeth Walton
Thomas Scarbrough
Steven Bloom
John Honcharik
Derek Widmayer
Theresa Buchanan
Theresa Buchanan
John Parillo
Angie Buford
Angie Buford
Joshua Miller
Alexandra Terres
Alexandra Terres
Alexandra Terres
Alexandra Terres
Walt Kirchner
Walt Kirchner
Stewart Bailey
Stewart Bailey
Stewart Bailey
Allegra Chilstrom
Khadijah West

Shanlai Lu
Shanlai Lu
13014153220
Dan Widrevitz
Michele Sampson
Steve Sarver
Steve Sarver
Stephen Cumblidge
Matthew Mitchell
Luisette Candelario-Quintana
Marissa Bailey
17035177420 (Unverified)
Karkour, Suzanne (GE Vernova)
Matthew Humberstone
Matthew Humberstone
Michael Benson
Jan Mazza
Mike Gallagher (Unverified)
Lentz, Tony Fraley
Roberts Banks, Kelli (GE Vernova)
Jackson, Tony
Petrarca, Dennis Allen
Syed Haider
George Thomas
Tammy Skov
Keith Miller
Keith Miller
Keith Miller
Gregory Halnon
Adakou Foli
Flynn, Martin (GE Vernova)
Hinojosa, Luis (GE Vernova)
Montague, Kelvin Jevon
Moorrees, Michele Yvette
Moorrees, Michele Yvette
Vesna Dimitrijevic
Dominik Muszynski (Unverified)
Ryan Nolan
Gordon Curran
Wadkins, George (GE Vernova)
Spencer Toohill (Unverified)
Casey Emler
Jason Thompson
Fanta Sacko
Robert Martin
Dave Gasperson
Dave Gasperson
Lauren Gibson
Lauren Gibson

Lauren Gibson
dennis bley (Unverified)
Janet Riner
Andrea Torres
Stephen P O'Hearn (Services - 6)
Harrison Ngo
Kazanas, Marc T (GE Vernova)
Steven Pope
Jonathan DeJesus
Spencer Toohill (Unverified)
Spencer Toohill (Unverified)
Spencer Toohill (Unverified)
Carol Moyer
Christina Antonescu
Hosung Ahn
Hosung Ahn
Hosung Ahn
Hosung Ahn
Christopher Brown
Joseph Staudenmeier
Raul Hernandez
Karen Sida
Mary H Miller (Services - 6)
Jordan Glisan
Michael Snodderly
Wendell Morton
Sandra Walker
Matthew Yoder
Tuccillo, Karen [DEP]
Tuccillo, Karen [DEP]
Roberto Torres Davis
Roberto Torres Davis
Hossein Nourbakhsh
Edward Stutzcage
Edward Stutzcage
Dennis Bley
Cory Padilla
Spencer Toohill (Unverified)
Weidong Wang
Yoshinori TAKECHI_NRA Japan (Unverified)
Getachew Tesfaye
Madeleine Arel
John Bozga
Getachew Tesfaye NRR
Mahmoud Jardaneh NRR
Ray Schiele TVA
David Hinds GE Verona
Scott Hunnewell TVA
Brian McDermott TVA

Kelli Banks

Stacy Joseph

Allen Fetter

GVH

NRR

NRR