

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: ACRS Accident Analysis Subcommittee

Docket Number: N/A

Location: Teleconference

Date: 9/16/2025

Work Order No.: NRC-0461

Pages 1-57

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 ACCIDENT ANALYSIS SUBCOMMITTEE

8 + + + + +

9 OPEN SESSION

10 + + + + +

11 TUESDAY

12 SEPTEMBER 16, 2025

13 + + + + +

14 The Subcommittee met via hybrid
15 Video-Teleconference, at 8:30 a.m. EDT, Robert Martin,
16 Chair, presiding.

17
18 MEMBERS PRESENT:

19 ROBERT P. MARTIN, Chair

20 VESNA B. DIMITRIJEVIC*

21 GREGORY H. HALNON*

22 CRAIG D. HARRINGTON

23 WALTER L. KIRCHNER*

24 SCOTT P. PALMTAG

25 DAVID A. PETTI*

1 THOMAS E. ROBERTS

2 MATTHEW W. SUNSERI*

3 ACRS CONSULTANT:

4 RONALD BALLINGER

5

6 DESIGNATED FEDERAL OFFICIAL:

7 WEIDONG WANG

8

9 ALSO PRESENT:

10 KEVIN BARBER, WEC

11 JEREMY DEAN, NRR*

12 AARON EVERHARD, WEC

13 JERROD EWING, WEC

14 BRIAN ISING, WEC

15 JEFFREY KOBELAK, WEC*

16 JOHN LEHNING, NRR

17 SCOTT KREPEL, NRR

18 JACK VANDE POLDER, NRR

19 BRANDON WISE, NRR

20

21 *Present via telephone

22

23

24

25

CONTENTS

PAGE

ACRS Subcommittee Chairman Open Remarks

Robert Martin 4

NRR Staff Leadership Opening Remarks

Scott Krepel 9

WEC Opening Remarks

Jerrod Ewing 10

Open Session: Discussion WCAP-18850

Jeffrey Kobelak 11

Open Session: Staff Safety Evaluation

John Lehning 37

Jeremy Dean 38

Brandon Wise 43

Jack Vande Polder 41

Opportunity for Public Comment 55

Break 56

NEAL R. GROSSCOURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR MARTIN: The meeting will now come to order. This is the meeting of the Accident Analysis Subcommittee on the Advisory Committee on Reactor Safeguards. I am Robert Martin, I'm Chairman of today's Subcommittee meeting. ACRS Members in attendance and present are Craig Harrington, Scott Palmtag, Thomas Roberts and myself. ACRS Members in attendance via virtual via Teams, I'm going to check here and see, make sure everyone is here, are Vesna Dimitrijevic, Matt Sunseri, I don't see Vicki Bier, Greg Halnon and Walt Kirchner and Dave Petti. We have one of our consultants participating in person, it is Ron Ballinger. If I have missed anyone, which I don't think I have, either ACRS Members or Consultants, please speak up?

Weidong Wang, the ACRS staff, is the designated federal officer for this meeting. No member or conflicts of identified for today's meeting. We have a quorum.

During today's meeting the Subcommittee will receive a briefing on topical report and staff's Draft Safety evaluation for Westinghouse Topical Report WCAP-18850, Adaptation of the Full Spectrum of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 LOCA, Loss Coolant Accident, Evaluation Methodology to
2 Perform Analysis Cladding Rupture for High Burnup
3 Fuel.

4 The Westinghouse full spectrum LOCA
5 evaluation model was licensed for the purpose of
6 allowing licensees to demonstrate compliance with the
7 emergency core cooling system acceptance criteria
8 described in Title 10 of the Code of Regulations Part
9 50.46. The original full spectrum LOCA EM, evaluation
10 model, was developed to analyze and demonstrate
11 compliance, safety regulations for fuel burnups up to
12 a certain limit.

13 With the Industry moving towards higher
14 burnup fuel, which offers economic and operational
15 benefits, a new methodology was required to address
16 the unique behaviors of this advance fuel cycle. The
17 primary objective of WCAP-18850 is to extend the
18 applicability of Westinghouse's existing FSLOCA,
19 particularly for the risk of cladding rupture and fuel
20 fragmentation, relocation and disbursement.

21 ACRS was established by statute and is
22 governed by the Federal Advisory Committee Act, or
23 FACA. The NRC implements FACA in accordance with its
24 regulations. Additionally, the importance of Sections
25 29 in 1(a), 2(b) of the Atomic Energy Act.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 The ACRS advises the Commission with
2 regard to the hazards of proposed or existing reactor
3 susceptibilities and adequacy of the proposed safety
4 standards. In addition, the ACRS is implementing
5 Executive Order 14300 ordering to reform the Nuclear
6 Regulatory Commission dated May 23rd, 2025. Section
7 4(b) of the EO states, in part, the functions of the
8 ACRS shall be reduced to the minimum necessary to
9 fulfill ACRS's statutory obligations and that review
10 by ACRS shall focus on issues that are unique, novel
11 and noteworthy.

12 The review and reporting on new reactor
13 facilities and proposed safety standards are the
14 minimum required functions of the ACRS under Section
15 29 and 2(b) of the Atomic Energy Act. The Commission
16 may refer additional duties to the ACRS in accordance
17 with the Act.

18 Per these regulations and the Committee's
19 bylaws, the ACRS speaks only through it's published
20 letter reports. All member comments should be
21 regarding as only the individual opinion of that
22 member, not a Committee position.

23 All relevant information related to ACRS
24 activities, such as letters, rules for meeting
25 participation and transcripts are located on the NRC

1 public website and can be easily found by typing about
2 us ACRS in the search field on the NRC's homepage.

3 The ACRS, consistent with the Agency's
4 value of public transparency and regulation of nuclear
5 facilities provides opportunity for public input and
6 comment during our proceedings. We have received no
7 written statements or requests to make an oral
8 statement from the public.

9 We have also set aside at the time of this
10 meeting for public comments. Portions of this meeting
11 may be closed to protect sensitive information as
12 required by FACA, and the Government and Sunshine Act.

13 Attendance during the closed portion of
14 this meeting will be limited to the NRC staff and its
15 consultants, Westinghouse, and those individuals or
16 organizations that have entered into an appropriate
17 confidentiality agreement. We will confirm that only
18 eligible individuals are in the closed portion of the
19 meeting.

20 The ACRS will gather information, analyze
21 relevant issues and facts and formulate proposed
22 conclusions and declarations as appropriate for
23 deliberation by the full committee. A transcript of
24 the meeting is being kept and will be posted on our
25 website.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 When addressing the Subcommittee, the
2 participants should first identify themselves and
3 speak with sufficient clarity and volume so that they
4 may be readily heard. If you are not speaking, please
5 mute your computer on Teams, by pressing *6 if you're
6 on the phone. Please do not use the Teams chat
7 feature to conduct sidebar discussions related to the
8 presentations, rather limit use to limiting chat
9 function to report IT functions.

10 For everyone in the room, please put all
11 your electronic devices in silent mode. And mute your
12 laptop microphone and speakers. In addition, please
13 keep sidebar discussions in the room to a minimum
14 since the ceiling microphone, particularly the one
15 behind me, are live.

16 For presenters, your table microphones are
17 unidirectional, and you'll need to speak into the
18 front of the microphone to be heard. Notice how close
19 I am at the moment.

20 Finally, if you have any feedback for the
21 ACRS about today's meeting, we encourage you to fill
22 out the public meeting feedback form on the NRC's
23 website. All right, we will now proceed with the
24 meeting. And to begin with, following the agenda,
25 public's agenda, I'm going to turn to Scott Krepel for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 staff leadership opening remarks.

2 MR. KREPEL: Well thank you very much.
3 I'm Scott Krepel speaking through a sign language
4 interpreter, as I typically do, and I am the branch
5 chief for the thermal methods and fuel analysis
6 branch. And my staff is going to be presenting today
7 their review of the WCAP-18850. And we will be giving
8 a little bit of background about this topical report.

9 About one year ago my staff presented to
10 you all on another topical reported related to
11 incremental burnup. And so, that was to improve an
12 increase in the burnup limits that the LOCA methods
13 had been analyzed. So this topical report will go
14 beyond that level. And it will support the fuel that
15 the full high burnup for the Industry. And this will
16 feed into the ALS that you will hear about in the
17 future presentations.

18 But I want to emphasize that this method
19 is not intended to address the FFRD explicitly. And
20 so that will not be a topic of this discussion here
21 today. But we will find out more when we get to the
22 ALS presentation. So thank you.

23 CHAIR MARTIN: Okay. Thank you, Scott.
24 And just to go on record here, a couple acronyms.
25 ALS, Alternative Licenses Strategy. FFRD, Fuel

1 Fragmentation Relocation and Dispersal.

2 With that introduction we will now turn to
3 Westinghouse. I believe Jerrod Ewing you are on deck
4 here.

5 MR. EWING: I am indeed. Thank you, Mr.
6 Chairman. Thank you, Members, for the opportunity to
7 come in and discussion of our adaption of our Full
8 Spectrum LOCA method to high burnup fuel as part of
9 that EPRI alternative licensing strategy that Scott
10 talked about.

11 This is obviously a very important
12 initiative for the Industry as we like to add more
13 megawatts on the grid. And I'm very excited to be
14 able to present this to you all.

15 I want to thank Scott's staff for their
16 review. It's been a good look at our method over the
17 past year. And appreciate that.

18 And then also want to thank our partners
19 in EPRI as part of this. And our customers as well.
20 Can't forget them. So both those that are here in the
21 room and those that are on the phone. Thank you.

22 CHAIR MARTIN: Do you want to introduce
23 your speaker here --

24 MR. EWING: Sure.

25 CHAIR MARTIN: -- Jeffrey?

1 MR. EWING: Yes. So we have Mr. Kobelak
2 will be presenting today. He is remote. I'll turn it
3 over to him.

4 MR. KOBELAK: Okay, thank you, Jerrod, and
5 thank you, Chairman Martin. I guess I did want to do
6 a quick sound check. Are you able to hear me clearly
7 in the room?

8 CHAIR MARTIN: We are. Go ahead.

9 MR. KOBELAK: Okay. Perfect. Thank you.
10 Thank you very much.

11 So as Jerrod said, thank you for allowing
12 us an opportunity on your agenda for the current
13 Subcommittee meeting to present on WCAP-18850. This
14 is a very important part of Westinghouse strategy
15 moving forward with, I'd say really three different
16 initiatives which kind of all mean the same thing. We
17 typically refer to this as either ATF, meaning
18 Accident Tolerant Fuel, HEF, meaning High Energy Fuel,
19 or LEU+, all kind of referring to operating fuel
20 products from a higher initial enrichment into a
21 higher burnup regime.

22 So as part of my presentation today for
23 the open session there are really four areas that I
24 would like to cover in detail. The first one I wanted
25 to talk a little bit about how this particular topical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 report interacts with our high energy fuel strategy,
2 how it ties into the EPRI ALS for fuel dispersal. And
3 really also the fourth coming 10 CFR 50.46(a) aspects
4 of the increased enrichment rulemaking.

5 From there I'll move into an overview and
6 purpose of WCAP-18850. The third topic I'd like to
7 touch on is the focus areas within the topical report.
8 And in the open session I will keep this relatively
9 high level, but that will be a primary focus of the
10 closed session presentations, which will happen later.
11 And then finally, just a high level overview of the
12 limitation and conditions associated with the topical
13 report.

14 And I did want to point out there are a
15 lot of acronyms used throughout this presentation. I
16 did try to spell them out. For those who have a
17 printed copy, there are tables at the end with all of
18 the acronyms defined. And I will pause at the end of
19 every slide for any questions.

20 Okay. So I wanted to start out with an
21 overview of the integrated timeline for high energy
22 fuel, or LEU+ deployment. And what you can see on
23 this slide are bars indicating the relative timing of
24 some of the key activities associated with the high
25 energy fuel program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So that first bar which shows the prime
2 fuel futures, ADOPT fuel pellets and AXIOM cladding,
3 those are all now products which have been reviewed
4 and approved by the NRC available for region
5 deliveries, and in some cases already being delivered
6 as part of regions to utility customers.

7 The second bar there is the one that was
8 referenced by Scott in his opening remarks. The
9 incremental burnup topical report where we extended a
10 number of our codes and methods up to an incremental
11 increase in burnup which is in-between the limit of 62
12 gigawatt days per MTU and the limit that we're seeking
13 for WCAP-18850.

14 The review on that has already been
15 completed. And that is also an approved topical
16 report by the NRC.

17 Where we're at today is working primarily
18 on the next couple of lines here. So the next three,
19 or four really, are all things that are running in
20 parallel. So that third bar down is all of the
21 different codes and methods that are needed to be
22 developed for higher enrichment and higher burnup.
23 And that is the grouping of topical reports that
24 includes WCAP-18850, as indicated on this slide.

25 The fourth one is our chromium coated

1 cladding. So that's part of our encore ATF products.
2 And the first topical report to license chromium
3 coated cladding was already submitted to the NRC and
4 it's currently under review by the NRC.

5 And then the third, the third piece there
6 is the LEU+ manufacturing. So that's the facility
7 that will produce the higher enriched fuel. That is
8 also ongoing right now.

9 And then of course complementing many of
10 these activities is the ongoing testing. Whether it's
11 being done by Westinghouse or through cooperative
12 agreements with National Labs on various high burnup
13 and other ATF fuel samples that have been provided by
14 Westinghouse. So the primary purpose in this scheme
15 of WCAP-18850 is to demonstrate cladding rupture will
16 not occur in high burnup fuel thereby precluding any
17 concerns about the consequences of fuel dispersal.

18 CHAIR MARTIN: Okay. Jeff, this is Bob
19 Martin. Just as a point of clarification, and maybe
20 just, and really just for the record.

21 You currently have, Westinghouse currently
22 has, I believe the TR is WCAP-16996, correct? That is
23 your Full Strength LOCA that was approved a number of
24 years ago. This is in addition, because that goes up
25 to certain burnup limit, and then from that burnup

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 limit on you have this new topical report. And it is
2 a separate analysis that hangs on each of the
3 original, is that correct?

4 MR. KOBELAK: Yes, that is correct. Maybe
5 just one small clarification is that we are working on
6 extended that WCAP-16996 approved methodology to
7 higher enrichment and higher burnup to demonstrate
8 compliance with the ECCS criteria. So that's a
9 submittal that we're expecting to make at the end of
10 this year.

11 And then as you indicated, WCAP-18850 is
12 an additional separate method and separate analysis
13 that's done in addition to the ECCS analysis specific
14 to demonstrating no cladding rupture, to preclude fuel
15 dispersal. So taking fuel up the higher burnup for
16 LOCA requires both of those components. The analysis
17 for the ECCS criteria and the application of 18850, as
18 envisioned by Westinghouse.

19 CHAIR MARTIN: Okay. So that begs the
20 question, again, obviously you're kind of thinking
21 about it in that step, is why not just one analysis
22 method that covers all these questions?

23 How do you think you need the two
24 separate, or could you not incorporate into a single
25 methodology both the questions related to ECCS 10 CFR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 50.46 compliance and the high burnup into, let's say
2 a single analysis evaluation model?

3 MR. KOBELAK: Yes, I'd say there is a
4 couple reasons for that. The first one is that the
5 fuel of interest for fuel dispersal is not necessarily
6 the same fuel that's going to be limited when
7 assessing the ECCS acceptance criteria. So the
8 population of fuel rods that we're interested in
9 relative to fuel dispersal is a different population
10 of fuel rods than what we're interested in when we're
11 trying to capture a limiting result anywhere in the
12 core to demonstrate compliance with the 50.46
13 criteria.

14 So I would say that's probably the
15 predominant reason. But there are at least one, or
16 maybe a handful of parameters, that are treated
17 differently for conservative reasons in demonstrating
18 compliance with the ECCS criteria versus cladding
19 rupture. So I'd say because of those two factors
20 primarily it was easier, and maybe even required, to
21 develop two separate methods rather than trying to do
22 it all within a single analysis.

23 CHAIR MARTIN: Yes, I appreciate that.
24 And I guess some of that information we might get into
25 in closed session --

1 MR. KOBELAK: Yes.

2 CHAIR MARTIN: -- right?

3 MR. KOBELAK: Yes, I apologize. I kind of
4 went a little bit higher level with that second
5 response because it is the open session.

6 CHAIR MARTIN: Sure. I understand that.
7 I see that we have a question from our full Committee
8 Chair Walt. Go ahead.

9 MR. KIRCHNER: Yes, good morning. This is
10 Walt Kirchner. I'm looking at this slide. It's a
11 rather interesting choice of words. It's a view
12 graph. Are you designing fuel for dispersal?

13 MR. KOBELAK: Walt, could I maybe ask you
14 to clarify, when you say designing fuel for dispersal
15 what you mean by that?

16 MR. KIRCHNER: Well you just stated that
17 WCAP-18850, you were going to use to demonstrate no
18 rupture for cladding bursts. So, what fuel dispersal
19 are you talking about?

20 MR. KOBELAK: So, yes. So the intent of
21 WCAP-18850 is to demonstrate that there would be no
22 cladding rupture in the higher burnup fuel rods with
23 the intent of then demonstrating that there is no fuel
24 dispersal. And if there is no fuel dispersal, than
25 there is not a need to analyze the downstream

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 consequences.

2 So at least in the near-term leveraging
3 this WCAP-18850, in conjunction with EPRI ALS, or
4 potentially the 50.46(a) rulemaking as part of the
5 increased enrichment rulemaking, our intent would be
6 to demonstrate no cladding rupture and no dispersal in
7 the near-term without having change aspects of the
8 fuel design to particularly address fuel dispersal.

9 MR. KIRCHNER: So --

10 MR. KOBELAK: Did that answer your
11 question?

12 MR. KIRCHNER: I just wanted you to go on
13 record and say you're not designing for fuel
14 dispersal. You're developing a methodology to
15 demonstrate that you do not have fuel dispersal?

16 MR. KOBELAK: Yes, that is correct.

17 MR. KIRCHNER: All right, thank you.

18 CHAIR MARTIN: Kevin, you don't have to
19 raise your hand.

20 MR. BARBER: Yes --

21 CHAIR MARTIN: You're in the room.

22 MR. BARBER: Yes, I just wanted Jeff to
23 know that he may be giving me a second here since he's
24 remote.

25 CHAIR MARTIN: Okay, go ahead.

1 MR. BARBER: I just wanted to note that we
2 were here as part of the increased enrichment
3 rulemaking ACRS Committee in December and January. We
4 presented in conjunction with NEI and the other
5 vendors and utilities in the Industry.

6 And just to be crystal clear, it's still
7 Westinghouse's intention, because we see by precluding
8 dispersal, precluding burnup of high, precluding
9 rupture of high burnup rod we are able to avoid a lot
10 of the uncertainties that are associated with coming
11 up with a high probability statement related to fuel
12 dispersal. I think that our intention is to avoid
13 quantification of uncertainties.

14 And we have talked about it with the staff
15 at a lot of the FFRD workshops we've had over the
16 summer, and we have later this week, to kind of spawn
17 from those ACRS meetings earlier this year. And
18 again, so from our point of view, especially with the
19 status with 50.46(a) rulemaking and the potential
20 demarcation of beyond design basis analysis and design
21 basis analysis.

22 Everything we're presented today is within
23 the context of the design basis analysis. So we're
24 looking at this in a high probability lens. And
25 because there is so much uncertainty from our point of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 view related to coolability aspects after the fuel is
2 dispersed, given the nature of the data that's
3 existing in the Industry.

4 As Jeff mentioned, you know, we're working
5 closely, obviously with the National Labs and skip
6 program and invitees, et cetera. We're still trying
7 to keep that same, on that same track where we were
8 nine months ago. And so, just to be crystal clear,
9 for Walt's question, we, at this time, have no
10 intention of coming up with any fuel dispersal high
11 probability calculations.

12 MR. PALMTAG: So this is Scott Palmtag.
13 I just want to follow-up a little bit on the strategy
14 here. So this is all for AXIOM fuel? Chromium coated
15 fuel.

16 MR. BARBER: Yes, and, Scott, we have
17 actually, Jeff is going to give a, maybe, Jeff, if you
18 can jump to the next slide?

19 MR. KOBELAK: Yes, I was going to say,
20 I'll cover that in just a moment, if we can hold the
21 question. I'm going to get to the applicability of
22 the method.

23 MR. ROBERTS: This is Tom Roberts. I want
24 to follow-up on what Kevin and Jeff are saying in
25 response to one question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 If I understand right, there is two
2 branches, at least two branches, they're looking at.
3 One is ALS, which says there would not be a
4 calculation of anything beyond what you could show no
5 plant rupture for. So that would be 1(a) 50 topical
6 report where we can find the method you used.

7 The second approach would be, if you used
8 50.46(a) but it requires some sort of calculation for
9 the larger break, beyond transition break. I think
10 what you said at that future work, that you're not
11 covering that today. And you would cover that either
12 in future topical or some other way. But that would
13 not be a no rupture, I would think, in your current
14 thought. That it would not be demonstrated in these
15 methods with the, you know, the beyond transition
16 break, size break that you could show no rupture, is
17 that right?

18 MR. BARBER: Yes. Yes, that's right. Go
19 ahead, Jeff.

20 MR. KOBELAK: Yes. So I guess I could
21 jump to this slide because I was just about to come to
22 this one. I think I tend to agree that, yes, what you
23 said is consistent with our planned approach. So I
24 put this slide in here just to kind of differentiate
25 the potential approaches exactly as you would outline.

1 So one possibility of using this
2 WCAP-18850 is under EPRI ALS. So for EPRI ALS we
3 would define a transition break size, which is
4 essentially aligned with the largest connecting line
5 to the main loop RCCS piping.

6 And for all LOCAs that are at break sizes
7 equal to or smaller than the connected line piping,
8 we would demonstrate no cladding rupture using this
9 method. So that's the top left blue box on this
10 slide.

11 And then for breaks that are larger than
12 that transition break size, we would aim to credit the
13 EPRI ALS method that's currently under review by the
14 staff to demonstrate that a large break LOCA with fuel
15 dispersal was not a credible event. So no explicit
16 analysis is needed. So that's the ALS option that you
17 mentioned.

18 Under the increased enrichment rulemaking,
19 10 CFR 50.46(a) framework, I think that that's a
20 little bit more uncertain until we see what the final
21 state of that rule is. But for the small breaks that
22 are under the transition break size the approach would
23 essentially be identical. We would aim to demonstrate
24 no cladding rupture.

25 And for breaks that are larger than that

1 transition break size where we would be able to use
2 design basis analysis methods, I think one option
3 could be to potentially leverage the margin that comes
4 out of that more best estimate or nominal analysis and
5 potentially demonstrate that rupture doesn't occur.
6 If that's not the case I do think that it would likely
7 reduce the extent of potential dispersal and then we
8 could look at other means to address coolability.

9 From my perspective, that's something that
10 would be done on a longer timeline given, as Kevin
11 mentioned a lot of the uncertainties that we're still
12 trying to resolve around important phenomena for
13 coolability with dispersed fuel.

14 MR. ROBERTS: Okay, thanks, Jeff.

15 MR. KOBELAK: Did that --

16 MR. ROBERTS: Yes, thank you.

17 MR. KOBELAK: No problem. Did that cover
18 your question?

19 MR. ROBERTS: Yes. Have you done some
20 sort of a quick look analysis that it's plausible to
21 show no rupture for the large break? Or is that --

22 MR. KOBELAK: Yes, Kevin --

23 (Simultaneous speaking.)

24 MR. KOBELAK: Kevin, Kevin actually has
25 done some work on that. We have a paper that will be

1 presented at top fuel. I don't know, Kevin, if you
2 want to take a moment just to provide a high level
3 summary?

4 MR. BARBER: Yes. So, I mean, I think
5 that was another hot topic during the December and
6 January ACRS meeting on the rulemaking what exactly it
7 to mean to be beyond design basis in a LOCA
8 methodology. So that's something that we've looked at
9 in, for both Ps and BWRs, which is interesting because
10 obviously FSLOCA is with a state of the art as far as
11 best estimate plus uncertainty methodology, and that's
12 only applicable to PWRs. But we also have
13 methodologies that are Appendix A based that the staff
14 is actually looking at right now for some updates for
15 boilers.

16 And so, you know, it was a very different
17 starting place. Whether you have an appendix A
18 methodology or something like that, that's LOCA.

19 So at the time being, that's in the paper
20 that Jeff mentioned is going to be presented at Top
21 Hill next month, will primarily focus on adaptations
22 to the FSLOCA method. And looking at all the
23 uncertainty contributors that we have in the, as
24 approved topical report and trying to look at
25 different ways of defining what we would consider to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 be best estimate true nominal or something that's
2 reflective of beyond design basis analysis
3 requirement.

4 And in that paper we looked at different
5 Westinghouse PWR designs. Obviously from our
6 experience base we understand that some different
7 plants denied attributes leading to more limiting LOCA
8 events or a higher P, calculated PCTs and local
9 oxidation, et cetera.

10 So we used, we looked at a handful of
11 plants to look at this. And as you kind of start
12 ratcheting back these different uncertainty
13 contributors we do see a potential path for avoiding
14 cladding rupture in that beyond design basis accident,
15 with the criteria that would be expected for the
16 treatment uncertainties in that scenario.

17 There are some of the more limiting plant
18 design that are kind of very close to that threshold
19 of cladding rupture. And I think that's something
20 that as a couple will become public for comment, I
21 think the current schedule that the Agency had
22 communicated to Industry and to the public that they
23 will be able to see in February in 2026 to provide
24 public comment.

25 At that point we're hoping to get a little

1 more clarity on exactly what we may or may not be able
2 to credit in that beyond design basis circumstance.
3 But we do see, indeed, a large majority of the PWRs
4 expecting to not predict cladding rupture for the
5 large break conditions.

6 MR. ROBERTS: Okay, thank you.

7 MR. BARBER: Just one other note, for the
8 Members knowledge. So one of the things would be
9 taken back from recent meetings here is that we were
10 trying to provide more information in the open
11 session. There are going to be slides that are quite
12 similar to Jeff's presented in the closed session, so
13 if there is, we'll have another kind of opportunity to
14 ask maybe more direct questions related to proprietary
15 information in a few hours.

16 MR. PALMTAG: This is Scott again. So
17 going back to the accident question. So is this all
18 for the accident fuel? And I guess where I'm really
19 going is, are the older fuel designs going to go to
20 the higher burnup or are you only allowing the AXIOM
21 fuel to go to the higher burnup?

22 MR. KOBELAK: So let me, let me, yes, let
23 me just jump to that real quick and then I'll come
24 back. So here is where we're aiming as far as the
25 applicability of what can operate within this higher

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 initial enrichment, higher burnup regime.

2 So for cladding we are focused on the
3 AXIOM cladding. At least for near-term applications.
4 We also would expect that the chromium coated cladding
5 could operate in this regime. That that's listed as
6 future because it's not yet approved by the NRC it's
7 currently under review. But we would certainly expect
8 that cladding to be appropriate as well.

9 At present we are not looking to support
10 some of the older alloys, like Zirc-4, ZIRLO. For the
11 extended cycle lengths, and the higher fuel duty, the
12 corrosion and hydrogen becomes less desirable to
13 operate into high burnup than some of the more modern
14 alloys.

15 For fuel we are including both our
16 standard UO2 and ADOPT fuel pellets. No real change
17 to burnable absorbers. We would allow unpoisoned rods
18 if by gad and discrete burnable absorbers within this
19 regime.

20 As far as the specific enrichment and
21 burnup, we'll talk about that more in the closed
22 session. But needless to say, higher than five weight
23 percent and greater than 68 gigawatt days per MTU.

24 And then as far as plant classes, I know
25 it goes a little beyond the question, but this method

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 was designed for two-loop, three-loop and four-loop
2 Westinghouse plants as well as C-design plants.

3 MR. PALMTAG: Okay. And just to, I think
4 you said, just to clarify, the existing fuel that the
5 Zirc-4 cladding will not be allowed to go to high
6 burnup fuel?

7 MR. KOBELAK: That's correct. Zirc-4
8 would not. ZIRLO would not. At least as current
9 envisioned, or is supported, by these methods.

10 MR. PALMTAG: Okay.

11 MR. BALLINGER: This is Ron Ballinger. As
12 a practical matter, nobody is using Zirc-4 anymore
13 anyway, right? And that includes ZIRLO. So are there
14 any plants that you would, that are using this
15 material?

16 MR. KOBELAK: There are a handful --
17 (Simultaneous speaking.)

18 MR. BALLINGER: -- by the time it gets
19 approved?

20 MR. KOBELAK: There are actually a still
21 a handful of plants that use ZIRLO cladding material.
22 I think that there is relatively near-term plans for
23 those plants that transition off of them. But there
24 is still some plants that use that material.

25 MR. BARBER: Yes, maybe to expand a little

1 bit on Jeff's response. I mean, the majority of the
2 Westinghouse is, utilizes optimizes ZIRLO cladding.

3 And when we licensed AXIOM, and AXIOM
4 presented to the Committee, we showed some comparisons
5 and how optimized ZIRLO and AXIOM cladding performed
6 at these high burnup, high duty scenarios. And one of
7 the, one of the goals at AXIOM was to enable a higher
8 burnup operation to the reasons that Jeff had noted.
9 The corrosion and the hydrogen pick up.

10 I think the well-established fuel
11 performance aspect, fuel cladding performance aspects
12 that have been discussed with Westinghouse and the
13 Committee and the staff. And certainly others within
14 the Industry. So that's why we were very specific in
15 our, in the slide that Jeff just had up there, and the
16 applicability of what materials and what plant classes
17 would potentially be applied in this method.

18 CHAIR MARTIN: Jeff, this is Bob Martin.

19 MR. KOBELAK: Okay, so -- oh, sorry.

20 CHAIR MARTIN: And I'm also kind of
21 looking at the clock here and looking at your slides.
22 I think looking at what, the slides in between where
23 you're at now and the applicability slide, you're
24 probably, I know the contact we have certainly sat in
25 on several meetings discussing ALS. In fact, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 identified three topical proportioned to EPRI. We
2 will be looking at those on some level. That one.

3 We had a conversation, I think at our last
4 full committee meeting just two weeks ago where I
5 reported in my impressions of those. So we understand
6 this slide.

7 The next slide, I think we talked
8 something about the background here. Objectives
9 already.

10 The next slide. I think we've already
11 kind of addressed, okay, we know the 50.46 limits,
12 right? Somewhat familiar with the code. Maybe there
13 is some nuance here that you might want to mention,
14 just knowing that there is a difference here between
15 this topical report and your previous that you might
16 want to throw in. Right? You're relying more on
17 WCOBRA/TRAC with this methodology more than, say with
18 ECCS.

19 MR. KOBELAK: Yes, Bob. Maybe, so in the
20 interest of time, if I keep my comments very brief,
21 yes, I would say that it's important to know that
22 WCOBRA/TRAC-TF2 is associated with the FSLOCA EM.
23 It's a very different code than some of the prior
24 codes that you and others may be familiar with. It
25 was updated specifically focusing on the core and fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 rod models for high burnup and higher initial
2 enrichment.

3 And then it utilizes fuel performance data
4 from PAD5 for the fuel rod initialization. And PAD5
5 is similarly being updated to support higher
6 enrichment and high burnup.

7 CHAIR MARTIN: And just, can you all
8 agree, I think we saved a little bit of time.

9 MR. KOBELAK: Okay. You want me to resume
10 from Slide 12 then?

11 CHAIR MARTIN: Yes. If you've already
12 talked about it just kind of skip on through.

13 MR. KOBELAK: Okay.

14 CHAIR MARTIN: We can start with 16 if you
15 like, but --

16 MR. KOBELAK: Okay. Yes, not too much
17 more to say on this one. I think we've already talked
18 in the introductory remarks and earlier on about
19 incremental burnup, so I'll move on past this one then
20 just noting that that was approved by the NRC last
21 year.

22 I think we've also kind of covered this
23 slide at length. The purpose of this method. So I
24 will jump then to 16.

25 So this is just a very high level flavor

1 of the focus areas within the topical report. A large
2 portion of it is focused on ensuring that we have
3 appropriate fuel rod and core models to analyze higher
4 enrichment and higher burnup fuel.

5 Details will be provided in the closed
6 session, but just to mention here, the areas that we
7 looked at on the fuel rod are the pellet clad and gap
8 conductance model, cladding deformation and cladding
9 rupture. How the fuel rod is initialized.

10 And then a number of things that are kind
11 of newly important to the higher burnup fuel rod. So
12 susceptibility to find fragmentation where we see a
13 lot of this phenomena starting to occur. The
14 potential for fission gas release within the fuel rod
15 during the LOCA transition itself, in addition to the
16 preexisting fission gas in the fuel rods.

17 Looking at pre-birth fuel relocation. So
18 the ability of fuel to fragment and relocate within
19 the rod prior to rupture occurring. And then ensuring
20 that the fuel pellet thermal conductivity is
21 appropriate modeled up the higher burnup.

22 And on the core-wide front, the main focus
23 was on the kinetics and the decay heat. And the idea
24 there is of course to assess those models to make sure
25 that the energy addition being modeled during the LOCA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 transient is reasonably to conservatively captured.

2 CHAIR MARTIN: And maybe I'll just fill in
3 a gap for you. These of course weren't just pulled
4 out of the air, right? There was an NRC PIRT done 20
5 some odd years ago. And I believe you also did maybe
6 your own PIRT type exercise to kind of at least
7 confirm some of the conclusions from the NRC's PIRTs,
8 as well as maybe new insights you gained from the past
9 20 years of maybe in-house testing and just Industry
10 experience, correct?

11 MR. KOBELAK: Yes, that's correct. We
12 leveraged both the Industry PIRT, and as you indicated
13 we did create our own internal PIRT focused on a high
14 burnup fuel rod response during a LOCA so those were
15 factored into determining this list. And I think the
16 NRC is planning to speak a bit more about that in
17 their presentation as well.

18 CHAIR MARTIN: Thanks.

19 MR. KOBELAK: Okay. Here, again, just
20 very high level as far as methodology in the areas of
21 focus within this topical report. So a lot of the
22 discussion centered around the treatment of regions
23 and ensuring that we have appropriate coverage of the
24 entire break spectrum. So when I say regions I'm
25 talking about basically portions of that break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 spectrum which have common phenomena.

2 So as you go through the entire spectrum,
3 different phenomena become important at different
4 break sizes. And we wanted to make sure that all of
5 those were appropriately captured.

6 Reviewing the methodology uncertainties to
7 ensure that they remain appropriate or updating them
8 for higher burnup and higher enrichment fuel rods.
9 And of course, as was mentioned earlier, factoring in
10 information available since the original FSLOCA EM was
11 approved. And then some discussion regarding the
12 treatment of offsite power availability, while there's
13 a few other miscellaneous considerations.

14 And then finally, I have just a handful of
15 slides on the limitations and conditions. And again,
16 I think the NRC staff will cover this in much greater
17 detail in their presentation. But there were two
18 different types of limitations and conditions on the
19 topical report. A subset that were inherited from the
20 base Full Spectrum LOCA EM.

21 So any limitations and conditions from the
22 FSLOCA EM, which remained applicable, were generally
23 imposed on this topical report as well. There were a
24 number of limitations and conditions that weren't
25 applicable since we were focused just on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 prediction of cladding rupture rather than the ECCS
2 criteria as a whole. So things like long-term core
3 cooling, those were not included.

4 And then there is a number that were
5 superseded. So for example, the burnup limit in the
6 FC LOCA EM was superseded by a new limit imposed on
7 this topical report.

8 In summary there is 11 limitations and
9 conditions on this topical report. I just wanted to
10 touch on them at a very high level. The first
11 limitation and condition covers the different PWR
12 designs, which are included within the applicability
13 of the topical report.

14 The second one covers some limitations and
15 conditions relative to the decay heat modeling to make
16 sure it remains appropriate and conservative.
17 Limitation and condition 3 covers the maximum allowed
18 fuel rod average burnup. Limitation and Condition 4
19 covers the fuel performance data that is allowed to be
20 used for initialization of the fuel rods.

21 Limitation and Condition Number 5 is
22 specific to a particular uncertainty analysis
23 parameter. And Limitation and Condition Number 6
24 covers requirements related to the seed and the
25 uncertainty analysis inputs. As well as what needs to

1 be done if we get an unacceptable analysis result and
2 reporting of the analysis ranges to the NRC.

3 Limitation and Condition 7 is a
4 requirement relative to the offsite power availability
5 analyzed. Limitation and Condition 8 just pulls
6 forward three of the limitations and conditions from
7 the base FSLOCA EM.

8 Limitation and Condition 9 covers the
9 applicable cladding materials and fuel designs that I
10 mentioned on an earlier slide. Limitation and
11 Condition 10 covers the allowable burnable absorbers
12 that I also presented earlier. And then Limitation
13 and Condition 11 covers the maximum initial fuel rod
14 enrichment.

15 So that was all the remarks I had for the
16 open session. Happy to take any other questions.

17 CHAIR MARTIN: A little gun shy to ask
18 some questions because of course it might touch on
19 proprietary content. It's not so unusual for it to be
20 a little quite during an open session when we know
21 there is a closed session later.

22 I will turn to my colleagues here in the
23 room or online. Are there any questions to
24 Westinghouse before we transition to the staff? Not
25 seeing any I will thank you all very much.

1 And we'll make that transition over to the
2 staff's presentation. Give us a few minutes online.

3 MR. KOBELAK: Okay, thank you very much.

4 CHAIR MARTIN: Thank you.

5 Are you ready?

6 MR. LEHNING: Yes, we are ready. It's my
7 pleasure, and our pleasure, to be here in front of you
8 all this morning. My name is John Lehning from the
9 Nuclear Methods and Fuel Analysis Branch in the Office
10 of Nuclear Reactor Regulation, as are my colleagues
11 too who are here, and one who is virtual. One of us
12 who participated in the review, Patrick right now has
13 left the Agency but was a principle contributor. And
14 we present somewhat on his behalf.

15 We will tag team this presentation. We'll
16 introduce ourselves as we transition speakers. I'm
17 just going to help out, do the introductions right
18 now. So to my left, Brandon, do you want to introduce
19 yourself really quickly?

20 MR. WISE: I'm Brandon Wise in the Nuclear
21 Methods and Fuel Analysis Branch in the Division of
22 Safety Systems.

23 MR. LEHNING: And Jack?

24 MR. VANDE POLDER: I am Jack Vande Polder
25 in the Division of Safety Systems, Nuclear Methods and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Fuel Analysis Branch.

2 MR. LEHNING: And remotely our lead
3 review, Jeremy is going to take it from here and do
4 the first five slides I think. So go ahead, Jeremy.

5 MR. DEAN: Great, thank you, John. My
6 name is Jeremy Dean, I'm the lead reviewer for this
7 topical report. As said, I'm in the same branch as my
8 colleagues and report to Scott Krepel.

9 So we're going to cover, here in the open
10 session, just at a high level, what the staff's review
11 of this topical report. So next slide, John.

12 Here is just a quick presentation outline.
13 This is more important in the closed session to show
14 where we spent most of our time reviewing. And then
15 the, trying to be brief, we'll try to skip through
16 these pretty fast.

17 Next slide. So Westinghouse submitted a
18 topical report, WCAP-18850, to extend Full Spectrum
19 LOCA to incorporate effects of high enrichment and
20 high burnup. During this one new phenomena is of
21 primary interest for this. For fuel fragmentation,
22 relocation dispersal.

23 And one means of addressing that is to
24 prevent rods that are susceptible to this phenomena
25 and just prevent their rupture from occurring. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 from the NRC staff's point of view, right, this is the
2 highest standard you can apply to this in regards to
3 health and safety of the public.

4 So WCAP-18850 provides a method of
5 applying FSLOCA, the original framework, to determine
6 with high probability that cladding rupture is not
7 going to occur during a loss coolant accident.

8 Next slide, John. So a little bit of
9 background on the original Full Spectrum LOCA. Just
10 a best estimate, realistic loss of coolant accident
11 and evaluation model that accounts for uncertainties.
12 It covers the entire break spectrum, up to a full
13 double ended guillotine break. It was approved in
14 2017, and applicable to Westinghouse three and
15 four-loops.

16 And as a sub note, they're working on
17 expanded their trivariate analysis for 50.46
18 acceptance criteria to other pressurized reactor water
19 designs. And to be clear, the FSLOCA methodology does
20 not address fuel dispersal, there is so many
21 complexities with dispersal of fuel into the coolant.
22 Whether it meets regulations, the uncertainties of
23 coolability and where that fuel goes. So those, there
24 are some models included for fragmentation relocation
25 in the initial model, but 18850 will not address that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 piece.

2 Next slide, John.

3 CHAIR MARTIN: You didn't include
4 dispersal, that's the key, right?

5 MR. DEAN: Yes.

6 CHAIR MARTIN: Okay.

7 MR. DEAN: Absolutely.

8 CHAIR MARTIN: If anything, the
9 fragmentation relocation is really the, kind of
10 creating more local power at the rupture site, which
11 gives you --

12 MR. DEAN: Yes. So again, we'll get into
13 that in the closed section. But right, once the
14 pellet starts to become very, very small and
15 fragmented along it's green boundaries, it can
16 relocate axially in the fuel rod. In particular, if
17 it starts to balloon it can start to pack into the
18 region. And models need to be included for that.

19 MR. LEHNING: If you can hear me? This is
20 John Lehning speaking. I'll just add, we will touch
21 on a little bit of the distinction. And, you know,
22 obviously the full spectrum when it was approved, the
23 amount of knowledge we had was not quite up to what we
24 know now, and so we'll touch just briefly on some of
25 the distinctions there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. DEAN: Yes. Next slide, John, unless
2 there is any more questions on that one?

3 Really quickly on the review timeline.
4 18850 was submitted in February 2024. We did our
5 acceptance review in the spring. We spent the summer
6 reviewing and preparing for an audit in the fall with
7 numerous questions going into that. We were able to
8 resolve a lot of those and issued RAIs in November of
9 last year.

10 Westinghouse, just so you know, they
11 responded in two separate responses to answer all of
12 our questions. Then we took the latter part of the
13 spring into mid-summer to come up with our draft
14 safety evaluation. And now we're here ready to
15 present to you folks on the Subcommittee meeting.

16 Next slide. So I'm going to turn it over
17 to Jack here and let him talk about the regulatory
18 background and what's applicable there.

19 MR. VANDE POLDER: Hello, everyone. So
20 here are the key regulatory requirements and guidance
21 for LOCA. Of note, our 10 CFR 50.46 and general
22 design criteria 35. 10 CFR 50.46 is the main reason
23 which guided Westinghouse into their approach. And
24 then GDC 35 had the LOOP requirements, Loss of Offsite
25 Power, for Westinghouse in their review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Next slide please. So Westinghouse
2 WCAP-18850, the methodology must be capable of
3 predicting an occurrence of cladding rupture. The
4 methodology is based on the previously approved Full
5 Spectrum LOCA methodology. Westinghouse evaluated the
6 PIRT phenomena for increased burnup. And there were
7 two key model updates that were needed. Fuel rod
8 modeling and kinetics and decay heat modeling.

9 Next slide please. For further detail --

10 CHAIR MARTIN: One point of clarification.
11 So when you say two main areas, okay, fuel, but under
12 that title there are several --

13 MR. VANDE POLDER: Yes.

14 CHAIR MARTIN: -- updates.

15 MR. VANDE POLDER: Yes, there are several
16 updates.

17 CHAIR MARTIN: Okay. As opposed to, I
18 guess kinetics decay heat. There are obviously two
19 distinct phenomena due to the same site closure
20 models, okay.

21 MR. VANDE POLDER: Yes. So to the PIRT,
22 Westinghouse evaluated the FSLOCA PIRT and the
23 Industry high burnup PIRT. They didn't identify,
24 there were no new phenomena identified that needed to
25 be evaluated.

1 They did find some, there were three
2 categories of areas. There were things that would be
3 conservative or would have no effect if left as the,
4 such as void generation or the water volume. There
5 were several things that need to be change, such as
6 the after mentioned fuel rod models and decay heat.

7 And then there are items that we precluded
8 by their methodology, such as time and location of
9 bursts. The NRC staff found that the PIRT evaluation
10 by Westinghouse was comprehensive and adequate.

11 Next slide. So the fuel rod models, it's
12 more complex than just one model as there are several
13 things, such as cladding rupture, cladding
14 deformation. All the models that go into the fuel rod
15 modeling would be impacted or potentially impacted so
16 Westinghouse had to evaluate those. So the details
17 for these are a little too proprietary though so they
18 will be discussed in the closed section.

19 And I will be handed it off to my
20 colleague Brandon.

21 MR. WISE: Thank you. I am Brandon Wise
22 and I'm going to discuss the kinetics in the heat
23 model, as well as the cladding rupture methodology.

24 Westinghouse updated the WCOBRA/TRAC-TF2
25 kinetics and the heat models to be applicable to the

1 higher burnup and higher enrichment readings. The
2 updates are performed used PARAGON2, which was
3 approved in June 2021. That topical report has an
4 enrichment and power applicability that bound
5 WCAP-18850.

6 These same updates were applied in
7 WCAP-18446, which is the incremental burnup extension.
8 And WCAP-18773, which is the high enrichment for PWR
9 topical report. In both those topical reports the
10 staff found that the methodology could prove the new
11 kinetics and decay heat model was acceptable.

12 The staff found that the model is
13 acceptable and that the heat sources that are being
14 modeled are appropriately characterized for the
15 purposes of cladding rupture calculations. For the
16 cladding rupture methodology I'm going to discuss some
17 of the important topics proposed in WCAP-18850.

18 First, the FSLOCA EM is the base
19 methodology with some modifications discussed in
20 WCAP-18850. The purpose of the methodology is to
21 preclude cladding rupture of fuel rods susceptible to
22 cladding fragmentation. The cladding rupture analysis
23 is performed parallel to a typical FSLOCA EM analysis
24 demonstrating compliance with 10 CFR 50.46 Bravo 133.

25 The cladding rupture -- sorry. CAP-18850

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 provides a new analysis region. That's region 1(b),
2 which lies between the small and large break
3 representing the intermediate break spectrum. And
4 closes a methodology for analyzing that region, which
5 is a mix between Region 1 and 2, being mostly related
6 to Region 1. Which is small break LOCA. WCAP-18850
7 also proposes a few changes to Region 1 and 2
8 uncertainty analysis for cladding rupture
9 calculations.

10 CHAIR MARTIN: Point of clarification on
11 cladding rupture. Historically LOCA evaluation models
12 have leveraged the latest NUREG-0630, right? Looking
13 over at John, he's nodding his head so I did remember
14 something from a long time ago.

15 And it's a very, it's a relatively simply
16 type of cladding cooling rupture model. Has
17 Westinghouse departed from that? Is that a
18 proprietary type thing?

19 And in general, are fuel vendors moving
20 away from that old lot?

21 MR. LEHNING: We will cover somewhat in
22 the closed session in more detail.

23 CHAIR MARTIN: Okay.

24 MR. LEHNING: I don't want to speak out of
25 turn here. I will say that I think just in general,

1 in the broad sense, that vendors in general tend to
2 use that, I think as you know, maybe their own
3 versions or their own sort of data sets. It may
4 sometimes be cladding specific or other times they may
5 demonstrating the certain claddings fall within other
6 data that they have, but basically I would say that
7 the overall methods and approaches are highly
8 consistent with what was developed for that
9 NUREG-0630.

10 CHAIR MARTIN: Okay. Maybe some of the
11 parametrization is a little different based on, say
12 fuel specific testing?

13 I will say that if our Committee, I think
14 it was a couple years ago, so prior to a couple
15 members, did visit Westinghouse and we did get to look
16 through their testing program where they were
17 specifically looking at FFRD phenomena and trying to
18 improve their fuel designs.

19 And I can see how that, that work could
20 feed into a new model. Or at least maybe, maybe a
21 parametrization, re-parametrization, of an old model.

22 MR. LEHNING: And I'm sure Westinghouse
23 has a slide or two on that, and the staff does too, in
24 our closed presentation.

25 CHAIR MARTIN: Okay.

1 MR. LEHNING: So we will talk more on --

2 CHAIR MARTIN: All right, thanks.

3 MR. WISE: Next slide please. So based on
4 the changes discussed on the previous slide the NRC
5 staff made the following findings. We found that the
6 adaptation of the FSLOCA EM is a base methodology
7 appropriate to prevent cladding rupture calculations.

8 Including in that there were several model
9 updates that were found to be acceptable for the
10 applicable burnup and enrichment range. We also found
11 that the methodology was supported by significant data
12 and has been acceptable for predicting the occurrence
13 of cladding rupture and rods susceptible to cladding
14 fragmentation.

15 Additionally the staff compiled a
16 definition of Revision 1(b) and its treatment of the
17 FSLOCA EM to be comprehensively described and
18 acceptable. Found that the proposed changes to
19 Revision 1 and uncertainty analysis is acceptable.

20 The exact details of these two topics are
21 closely provided here. And we discuss it in more
22 detail in the closed session. But we can say that the
23 proposed treatments are supported by sensitivity
24 studies compared to calculations of engineering
25 judgment that the staff found to be acceptable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 Now I'll turn the presentation back to
2 Jeremy Dean, who will discuss limitations and
3 conditions.

4 MR. DEAN: Thank you, Brandon. So for
5 limitations and conditions the staff asked
6 Westinghouse to address all the 15 limitations and
7 conditions from their FSLOCA evaluation model.

8 We also, we did this for a couple of
9 reasons. One, it helps the NRC staff, you know, if
10 the applicant helps define the range of applicability
11 for their analysis rather than having the staff do
12 that for them, it's advantageous to them because we
13 would likely be more restrictive. And so in some
14 cases we did modify the suggested limitations and
15 conditions.

16 So several were directly propagated.
17 These were limitations and conditions 3, 12 and 13.
18 Several were modified, 2, 4, 5, 6, 8, 11 and 15.

19 Next slide. The NRC's draft safety
20 evaluation ultimately resulted in 11 limitations and
21 conditions that the licensees must adopt. Again,
22 these were originally proposed by Westinghouse in
23 their submittal. And we modified several of these.

24 We covered three limitations and
25 conditions during, in this open session, but the most,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I would say interesting and more restrictive, 8, will
2 be discussed during the closed session.

3 Next slide. And here are the ones that
4 were directly transferred. And we can talk a little
5 bit during the open session here, so.

6 Limitation and Condition 1 can only be
7 applied to Westinghouse two-loop and combustion
8 engineering plants after the base models have been
9 approved for these applications. And the applicable
10 differences and deviations are addressed. And what
11 that really means is the FSLOCA EM needs to then
12 include these new reactor types.

13 As Jeff alluded to in his portion,
14 Limitation and Condition 9, they're only applying this
15 to standard UO2 pellets and their ADOPT pellets. And
16 it's only applicable to AXIOM cladding.

17 And then Limitation and Condition Number
18 10 is just a repeat of Jeff's. That's it's applicable
19 to unpoisoned fuel, fuel with inoperable, fuel
20 burnable absorbers, particularly gadolinia. And it
21 doesn't preclude the other discrete burnable absorbers
22 that Westinghouse may use.

23 Next slide.

24 CHAIR MARTIN: Just a quick question. Bob
25 here.

1 MR. DEAN: Sure.

2 CHAIR MARTIN: You mentioned, previous
3 slide, about limits, limitations and conditions
4 related to range of applicability. And of course,
5 maybe pushing that back to Westinghouse to incorporate
6 that under PR. Some range of applicabilities relate
7 to inputs that are easy to control. Were any of those
8 ranges of applicabilities related to a calculated
9 parameter, variable that might have to be tracked by,
10 tracked through the calculation and require maybe a
11 little bit more effort on their part to assure maybe
12 a wording or something like that?

13 Sometimes that happens more than often
14 than not it's the former. Where they're relatively
15 easy. But sometimes you're dealing with, say some
16 closure limit. And as a calculated result that is
17 constrained by a range of applicability and it has to
18 be checked.

19 MR. LEHNING: Jeremy, this is John.

20 MR. DEAN: Yes, go ahead.

21 MR. LEHNING: And I guess I, to answer
22 that one. And Westinghouse, feel free to jump in and
23 offer your perspective. I don't think that there are
24 any like that that are, and I'm sort of reading your
25 question as if maybe sometimes, I've seen where maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 if a certain model gets activated, maybe you have to
2 go back and check through the files and output and
3 see.

4 CHAIR MARTIN: Yes.

5 MR. LEHNING: I don't think there are any
6 like that. I think all the ones that are associated
7 with it, that come to my mind, are ones where either
8 a parameter is set right at the beginning and it's
9 just to wrap around, there is nothing to check or so
10 forth. But, Westinghouse, if you have a different
11 view please feel free to address that.

12 MR. KOBELAK: No, John. This is Jeff
13 Kobelak from Westinghouse. I agree with your
14 assessment relative to the parameters. And maybe the
15 only other thing I would add are, there are one or two
16 that are kind of more procedural in terms of reporting
17 certain results to the NRC. Or at least reporting
18 results under certain conditions. And we have placed
19 those type of requirements into our analysis guidance
20 to make sure that they are not lost or forgotten as we
21 apply these methods.

22 CHAIR MARTIN: John, would those guidance
23 documents be something you reviewed?

24 MR. LEHNING: I don't know that we
25 reviewed any of the guidance documents of how

1 Westinghouse does their calculations as part of this
2 review. It might have been during some of the initial
3 review of the base methodology. We may have, we did
4 a lot of audits and that might have been.

5 I know some of the statistical parts of
6 this, we did talk through at a high level. I don't
7 know that we reviewed their actual documents, but we
8 did get pretty detailed into that part for sure.

9 CHAIR MARTIN: Okay, appreciate that.

10 MR. DEAN: Yes, I concur with that. Most,
11 it's really bias in certain parameters that are
12 applicable to this, you know, sort of single variate
13 for fuel rod burst that would be different than
14 you would do for the tried varied analysis for
15 50.46 acceptance criteria.

16 All right, so conclusions. So during our
17 review we found that WCAP-18850 does provide an
18 acceptable approach for determining the high
19 probability that cladding rupture will not occur.
20 We'll go into great detail in the closed session of
21 how we were able to accomplish that. And of course,
22 that's for fuel rods that are only susceptible to find
23 fragmentation.

24 The staff conclusions are, of course,
25 predicated on the methodology being used within its

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 approved range of applicability. And we'll outline
2 that a little bit more as well in the closed section.
3 And specifically addressing all the limitations and
4 conditions of Section 4 of the safety evaluation. I
5 believe that's the last slide.

6 CHAIR MARTIN: It is.

7 MR. DEAN: So any more questions we can
8 answer for you during this open session?

9 MR. ROBERTS: Yes, this is Tom Roberts.
10 I was wondering if you could resolve the arithmetic
11 for these license, LNC slides?

12 If you start with the first slide it says
13 there are 15 that were assessed, then the next part of
14 that slide says there were ten that were adopted or
15 modified. That's ten of 15. And then it says on the
16 next slide you adopted 11. Then the slide after that
17 lists three that aren't on that first slide, which
18 brings you up to, you know, I think it was 13. So
19 what is it arithmetic here?

20 MR. LEHNING: This is John Lehning --
21 (Simultaneous speaking.)

22 MR. DEAN: Go ahead, John.

23 MR. LEHNING: So the three that are shown
24 in the open presentation, those are part of the 11
25 that are on Topical Report WCAP-18850. There are

1 eight more that we will cover that will be in the
2 closed session.

3 Now the 15 that came from the original
4 base methodology it looks like, yes, I think if you
5 add those up, which I hadn't necessarily thought to do
6 before, but there are three, four, five, six, seven,
7 eight, nine, ten there. So none of those that are in
8 the WCAP-18850 propagated from the base method. And
9 apparently there is one that came in that essentially
10 is a new one that is not sort of covered in this
11 paradigm based on the way it's presented here. So
12 hopefully that's resolve the numbers.

13 And obviously out of this --

14 MR. DEAN: Remember also --

15 MR. LEHNING: -- 15 that there were five
16 that did not, were not applicable for whatever reason.
17 And obviously the different objectives of these
18 analyses, so some of them were perceived by
19 Westinghouse and the staff found acceptable that they
20 weren't necessary to do the calculation for this
21 cladding rupture.

22 MR. ROBERTS: So there were 15, five were
23 resolved as not applicable, and then one was added?
24 That's how you get to 11?

25 MR. LEHNING: That seems to be correct.

1 I hesitate to, I mean, because like I said, we hadn't
2 really done that math but that is what I believe to be
3 true.

4 MR. DEAN: Hey, John --

5 (Simultaneous speaking.)

6 CHAIR MARTIN: -- details coming in the
7 closed session, I guess we can rectify the numbers
8 there.

9 MR. DEAN: -- just a little bit tricky
10 that one limitation and condition pulls over three
11 into one. So yes, at first glance it looks like maybe
12 we didn't add it up right, but I assure you we did.

13 MR. ROBERTS: That is all right. Okay,
14 thank you.

15 CHAIR MARTIN: Any further questions or
16 topics of discussion from the Committee? Consultant
17 stab at this? Anything on your mind, Ron?

18 MR. BALLINGER: No.

19 CHAIR MARTIN: Okay. I think at this
20 point we need to go to public comments. Looking over
21 here? Okay. So if there is any member of the public
22 that has a burning question, this is your opportunity
23 to speak up.

24 Please use, if you're on Teams, please
25 raise your hand and we will give you a couple minutes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 here to provide your comment. Is there anyone out
2 there? Gave it a good 15 seconds, huh? All right,
3 not seeing any I believe we can close our open
4 session.

5 And of course there is some logistics that
6 we have to take care of going into the closed session
7 to make sure everyone that is here is allowed to be
8 here. And for those of you that can be here
9 virtually, I believe there is going to be a, there is
10 a different link so be aware of that.

11 And we're going to have a break. Right
12 now it is 9:41. We're going to break until 10:00.
13 It's what's on the schedule. So meeting is recessed
14 until 10:00.

15 (Whereupon, the above-entitled matter went
16 off the record at 9:41 a.m.)
17
18
19
20
21
22
23
24
25

NRC Staff's Review of
Westinghouse Topical Report
WCAP-18850-P,
*“Adaptation of the FULL SPECTRUM™ LOCA (FSLOCA™)
Evaluation Methodology to Perform Analysis of
Cladding Rupture for High Burnup Fuel”*

Open Presentation to
Advisory Committee on Reactor Safeguards,
Accident Analysis Subcommittee
September 16, 2025

J. Dean, U.S. NRC

B. Wise, U.S. NRC

J. Vande Polder, U.S. NRC


J. Lehning, U.S. NRC

Presentation Outline

Topic	# of Slides
Introduction / Background	4
Review History	1
Requirements and Guidance	1
Technical Evaluation (open portion)	7
• Modeling Basics	(1)
• Phenomenon Identification and Ranking	(1)
• Fuel Rod Modeling Updates	(1)
• Kinetics and Decay Heat Model Updates	(1)
• Cladding Rupture Methodology	(3)
Applicability, Limitations and Conditions	3
Conclusions	1
Acronyms	1
Presentation Total	18

Introduction

- Westinghouse proposed WCAP-18850-P to extend its approved FULL SPECTRUM LOCA methodology to higher fuel enrichment and burnup levels
- One means of addressing fuel dispersal is preventing rupture of fuel rods susceptible to fragmentation
- WCAP-18850-P provides a method for applying FSLOCA framework to determine with high probability that cladding rupture will not occur during a LOCA




FSLOCA Background

WCAP-16996-A

- FSLOCA is a realistic LOCA evaluation model that accounts for uncertainty
- Methodology addresses scenarios across entire postulated spectrum of break sizes
- Current methodology applicable to Westinghouse 3- and 4-loop pressurized-water reactors was approved in 2017
 - Extensions currently being pursued for additional pressurized-water reactor designs
- Licensed FSLOCA methodology does not address fuel dispersal
 - Models are included for fragmentation and relocation

Review Timeline


Westinghouse



NRC


Key Regulatory Requirements and Guidance for LOCA

- 10 CFR 50.46
- General Design Criterion 35
- NUREG-0800, Standard Review Plan
 - Chapter 15.6.5, Loss-of-Coolant Accident
 - Chapter 15.0.2, “Review of Transient and Accident Analysis Methods”
- Regulatory Guide 1.157, “Best-Estimate Calculations of Emergency Core Cooling System Performance”
- Regulatory Guide 1.203, “Transient and Accident Analysis Methods”



Loss-of-Coolant Accident Analysis Methods

- WCAP-18850-P methodology must be capable of predicting occurrence of cladding rupture during a LOCA
 - Modeling based on FULL SPECTRUM LOCA methodology (WCAP-16996-P-A)
 - WCOBRA/TRAC-TF2 code
- Westinghouse evaluated PIRT phenomena for impacts of increased burnup
- Key model updates in two main areas
 - Fuel rod modeling
 - Kinetics and decay heat modeling




Phenomena Identification and Ranking

- WCAP-18850-P evaluated the FSLOCA PIRT and an industry high burnup PIRT.
 - No new phenomena identified
 - Updates to WCOBRA/TRAC-TF2 and other models where appropriate
 - Fuel Rod Models, Kinetics and Decay Heat, Burst Criteria
 - Burst size, location, etc. determined to be unimportant.
- The NRC staff found that the PIRT evaluation is comprehensive and adequately identifies where model updates are needed to account for FFRD and high burnup and enrichment.

Fuel Rod Model Updates

- WCAP-18850-P addresses fuel rod models that could be impacted by increased burnup:
 - Pellet-cladding gap conductance
 - Cladding deformation
 - Cladding rupture
 - Fuel rod initialization
 - Susceptibility to fine fragmentation
 - Transient fission gas release
 - Pre-burst fuel relocation
 - Fuel rod material properties
- Proprietary details discussed further in closed session



WCOBRA/TRAC-TF2

Kinetics and Decay Heat Model Updates

- Westinghouse updated the models to incorporate increased enrichment and higher burnup
 - Nuclear physics data provided by PARAGON2 (Approved June 2021)
- Similar model updates were previously approved in:
 - WCAP-18446-P-A (Approved June 2024)
 - WCAP-18773-P (Final SE Issued July 2025)
- The NRC Staff found the model updates to be acceptable because they were consistent with previous approvals. Unique characteristics associated with the expanded range of applicability and cladding rupture calculations were examined.

Cladding Rupture Methodology

- WCAP-18850-P...
 - Uses the FSLOCA EM as a base methodology and adapts it as appropriate
 - The purpose of the methodology is to preclude cladding rupture of rods susceptible to fine fragmentation.
 - The WCAP-18850-P cladding rupture analysis is performed parallel to the WCAP-16996-A FSLOCA base analysis that demonstrates compliance with 10 CFR 50.46(b)(1)-(b)(3).
 - Defines a new break spectrum region, Region IB
 - Proposes a methodology for analyzing cladding rupture in Region IB
 - A mix of Regions I and II, with some unique characteristics
 - Proposes changes to Region I and II uncertainty analyses

Cladding Rupture Methodology

- The NRC Staff...
 - Found the adaptation of the FSLOCA EM base methodology appropriate to perform cladding rupture calculations. Several models were updated to incorporate the increase range of applicability for burnup and enrichment
 - Found the methodology to be supported by significant data and is acceptable for predicting the occurrence of cladding rupture of rods susceptible to fine fragmentation.

Cladding Rupture Methodology

- The NRC Staff...
 - Found the definition of Region IB and its treatment in the FSLOCA EM to be comprehensively described and acceptable.
 - Found the proposed changes to Region I and II uncertainty analyses acceptable.
 - The proposed treatments are supported by sensitivity studies, comparison calculations, and engineering judgment.

Review of Limitations and Conditions from FSLOCA (WCAP-16996, R1)

- Westinghouse assessed the 15 limitations and conditions from WCAP-16996, R1, for applicability to the derivative WCAP-18850-P methodology
- Applicable limitations and conditions from WCAP-16996, R1, were propagated into WCAP-18850-P topical report
 - Direct propagation of FSLOCA L&Cs 3, 12, and 13
 - Others adopted in modified form (FSLOCA L&Cs 2, 4, 5, 6, 8, 11, 15)

Limitations and Conditions for WCAP-18850-P

- The NRC staff's draft safety evaluation contains 11 limitations and conditions that licensees adopting the methodology must address
 - These limitations were originally proposed by Westinghouse in WCAP-18850-P
 - NRC staff modified several of these limitations
- Three limitations and conditions will be covered in the open presentation
 - Remaining eight will be discussed during the closed presentation

Limitations and Conditions: Methodology Applicability

- Per Limitation and Condition 1, the methodology can only be applied to Westinghouse 2-Loop and Combustion Engineering plants after
 - The base model is approved for these applications
 - Applicable differences and deviations have been addressed
- Per Limitation and Condition 9, WCAP-18850-P is only applicable to fuel products with
 - Uranium dioxide or ADOPT fuel pellets
 - AXIOM cladding
- Per Limitation and Condition 10, WCAP-18850-P is only applicable to
 - Unpoisoned fuel
 - Fuel with integral fuel burnable absorbers
 - Fuel with gadolinia

(this limitation does not preclude use of discrete burnable absorbers)

Conclusions

- The NRC staff found the WCAP-18850-P methodology provides an acceptable approach for determining, with high probability, that cladding rupture will not occur for fuel rods susceptible to fine fragmentation
- The NRC staff's conclusions are predicated upon
 - The methodology being used within its approved range of applicability
 - Licensees acceptably addressing limitations and conditions in Section 4.0 of the staff's safety evaluation

Table of Abbreviations

10 CFR	Title 10 of the <i>Code of Federal Regulations</i>
ACRS	Advisory Committee on Reactor Safeguards
FULL SPECTRUM™ LOCA, FSLOCA™	WCAP-16996-P-A, Revision 1, 'Realistic LOCA Evaluation Methodology Applied to the Full Spectrum of Break Sizes (Full Spectrum LOCA Methodology)
L&C	Limitation and Condition
LOCA	Loss-of-Coolant Accident
NRC	U. S. Nuclear Regulatory Commission
PIRT	Phenomenon Identification and Ranking Table
RAI	Request for Additional Information
SC	Advisory Committee on Reactor Safeguards Subcommittee
SE	Safety Evaluation
WCAP-18850	WCAP-18850-P/NP, Revision 0, "Adaptation of the FULL SPECTRUM LOCA (FSLOCA) Evaluation Methodology to Perform Analysis of Cladding Rupture for High Burnup Fuel"

Enclosure 2

Westinghouse Open Session Slide Package for the ACRS Subcommittee Meeting on WCAP-18850-P/NP

(Non-Proprietary)

September 2025

ADOPT™, AXIOM®, FSLOCA™, and FULL SPECTRUM™ are trademarks of Westinghouse Electric Company LLC, its affiliates, and/or its subsidiaries through the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.

**Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, PA 16066**

**© 2025 Westinghouse Electric Company LLC
All Rights Reserved**

ADOPT, AXIOM, FSLOCA and **FULL SPECTRUM** are trademarks or registered trademarks of Westinghouse Electric Company LLC, its subsidiaries and/or its affiliates in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.

© 2025 Westinghouse Electric Company LLC
All Rights Reserved



Overview of WCAP-18850: Adaptation of the FULL SPECTRUM LOCA (FSLOCA) Evaluation Methodology to Perform Analysis of Cladding Rupture for High Burnup Fuel

Jeffrey Kobelak

Westinghouse Electric Company

September 2025

Overview

- Interaction of WCAP-18850 with Westinghouse high energy fuel (HEF) / accident tolerant fuel (ATF) / low enriched uranium+ (LEU+) program
 - Fuel dispersal during a postulated LOCA and Electric Power Research Institute (EPRI) alternative licensing strategy (ALS)
- Overview and purpose of WCAP-18850 (Westinghouse Cladding Rupture Methodology)
- Focus areas within topical report
- Topical report limitations and conditions (L&Cs)

Westinghouse Activities for HEF / ATF / LEU+



Introduction to WCAP-18850

Methodology Overview

Limitations and Conditions

EnCore High Energy Fuel Program

Integrated Timeline for LEU+ Fuel Deployment



Fuel Fragmentation, Relocation, and Dispersal (FFRD)

55 GWd/MTU Rod
Average Burnup
Large Fuel Fragments



Figure 4-42 Images of fuel particles collected from test rod (a) 196 and (b) 198 revealing large fragments

72 GWd/MTU Rod
Average Burnup
Fine Fragmentation





Figure 4-41 Images of fuel particles collected from test rod (a) 192 and (b) 193 revealing a very small, sand-like fragmentation size

Addressing fuel dispersal for design basis accidents such as LOCA is one key element of code and method updates

Fuel Dispersal

EPRI ALS versus Draft Increased Enrichment Rulemaking



Current Status of EPRI ALS

Westinghouse Submittal

WCAP-18850:
Methodology for
Cladding Rupture
Calculations

- Submitted February 2024
- Accepted May 2024
- Audited October 2024
- RAI Responses March 2025
- Draft SER July 2025
- **ACRS Subcommittee
September 2025**
- Potential ACRS November 2025



3002028674:
LOCA Cladding
Rupture
Calculations

- RAI Responses Complete (except uncertainty analysis reruns)
- Draft SER Expected February 2026

EPRI Submittals

3002028673:
Alternative
Licensing Strategy
for Fuel Dispersal

- Submitted April 2024
- Accepted June 2024
- Audits Completed June 2025
- RAI Responses in progress
- Draft SER Expected February 2026

3002023895:
xLPR Estimation of
PWR LOCA
Frequencies

- RAI Responses Complete
- Draft SER Expected December 2025

Westinghouse Activities for HEF / ATF / LEU+

Introduction to WCAP-18850

Methodology Overview

Limitations and Conditions

Objective

- Provide an overview of the Westinghouse methodology to perform cladding rupture calculations for high burnup fuel
 - Initial driver was to support the EPRI ALS for fuel dispersal
 - Topical report is generically applicable to perform rupture calculations
- Builds on prior Westinghouse methods that are NRC approved
 - **FULL SPECTRUM™** LOCA (**FSLOCA™**) Methodology (WCAP-16996-A, Revision 1)
 - Incremental Burnup Extension (WCAP-18446-A)

Background: FULL SPECTRUM LOCA EM

- The FSLOCA evaluation model (EM) is NRC-approved to demonstrate compliance with the 10 CFR 50.46 ECCS acceptance criteria
 - Peak cladding temperature (PCT) less than 2,200°F
 - Maximum local oxidation (MLO) less than 17%
 - Core-wide oxidation (CWO) less than 1%
- WCOBRA/TRAC-TF2 (TF2) is the thermal-hydraulic system code associated with the FSLOCA EM
- Fuel performance data utilized for fuel rod initialization in TF2 is from PAD5

Background: Incremental Burnup

- Incremental burnup topical report leveraged the FSLOCA EM framework to perform cladding rupture calculations for higher burnup, lower power fuel rods
 - Demonstrate no cladding rupture with high probability
- WCOBRA/TRAC-TF2 code was reviewed and updated as part of incremental burnup
 - Revised models appropriate to higher burnup fuel
 - New models necessary to analyze higher burnup fuel

Introduction to Cladding Rupture Methodology (WCAP-18850)

- Code and method used to perform the cladding rupture calculations adapted from the FSLOCA EM and Incremental Burnup program
 - WCOBRA/TRAC-TF2 code was modified to analyze higher burnup fuel with higher initial enrichment
 - Considers all higher burnup fuel rods in the core
 - Not just peripheral rods as in incremental burnup
 - Analysis is focused on cladding rupture
 - Lessons learned from licensing of incremental burnup were accounted for in the development of the cladding rupture methodology

Applicability of Cladding Rupture Methodology

- **Cladding:** **AXIOM**® Cladding (current), coated cladding (future)
- **Fuel:** Standard UO_2 , **ADOPT**™ fuel pellets
- **Burnable Absorbers:** Un-poisoned, IFBA, Gadolinia, Discrete BAs
- **Initial Enrichment:** Greater than 5 w/o enrichment
- **Fuel Rod Average Burnup:** Greater than 68 GWd/MTU
- **Plant Classes:** 2-loop, 3-loop, 4-loop W-NSSS plants, CE-NSSS plants

Westinghouse Activities for HEF / ATF / LEU+

Introduction to WCAP-18850

Methodology Overview

Limitations and Conditions

Topical Report Focus Areas

Fuel Rod and Core Models

- Pellet-Cladding Gap Conductance
- Cladding Deformation
- Cladding Rupture
- Fuel Rod Initialization
- Susceptibility to Fine Fragmentation
- Transient Fission Gas Release
- Pre-Burst Fuel Relocation
- Fuel Pellet Thermal Conductivity

Models were assessed and/or updated primarily to ensure that all fuel rod phenomena associated with higher burnup levels were appropriately captured to support high probability, licensing basis calculations

- Kinetics and Decay Heat

Models were assessed and/or updated to ensure energy addition from kinetics and decay heat models is reasonably-to-conservatively modeled

Topical Report Focus Areas Methodology

- Treatment of regions
 - Coverage of entire break spectrum
- Methodology uncertainties
 - Assessed relative to higher burnup, higher enrichment, and information available since the approval of the FSLOCA EM
- Offsite power availability
- Miscellaneous considerations

**Additional Details will be Provided in the
Closed Session Presentation**

Westinghouse Activities for HEF / ATF / LEU+

Introduction to WCAP-18850

Methodology Overview

Limitations and Conditions

Type of Limitations and Conditions

- Two different types of limitations and conditions
 - L&Cs inherited from the FSLOCA EM
 - L&Cs which remain applicable are generally inherited into this topical report
 - Some are not applicable (e.g., long-term cooling)
 - Some are superseded (e.g., prior burnup limitations)
 - New L&Cs imposed on this topical report

Limitations and Conditions

- **L&C #1:** Applicability to different PWR designs
- **L&C #2:** Conditions related to decay heat modeling and uncertainty
- **L&C #3:** Maximum fuel rod average burnup
- **L&C #4:** Fuel performance data should be from a code that is approved for the intended analysis conditions, and explicitly accounts for thermal conductivity degradation (TCD)
- **L&C #5:** Condition related to an analysis uncertainty parameter
- **L&C #6:** Conditions related to the seed and uncertainty analysis inputs; also requirements for unacceptable analysis results and reporting of analysis ranges

Limitations and Conditions

- **L&C #7:** Requirement to perform the Region II (LBLOCA) analysis with offsite power available (OPA) and loss-of-offsite power (LOOP)
- **L&C #8:** L&Cs number 3, 12, and 13 from the FSLOCA EM (WCAP-16996-P-A, Revision 1) remain applicable to WCAP-18850
- **L&C #9:** Applicability to cladding materials and fuel designs
- **L&C #10:** Applicability to various burnable absorbers
- **L&C #11:** Maximum initial fuel rod enrichment

Questions



Acronyms / Codes / Labels

Acronym	Definition
ACRS	Advisory Committee on Reactor Safeguards
ALS	Alternate Licensing Strategy (for FFRD)
ATF	Accident Tolerant Fuel
CE	Combustion Engineering
CFR	Code of Federal Regulations
CWO	Core-Wide Oxidation
ECCS	Emergency Core Cooling System
EM	Evaluation Model
EPRI	Electric Power Research Institute
FFRD	Fuel Fragmentation, Relocation, and Dispersal

Acronyms / Codes / Labels

Acronym	Definition
FSLOCA	FULL SPECTRUM LOCA
HEF	High Energy Fuel
IBLOCA	Intermediate-Break LOCA
IE	Increased Enrichment
IFBA	Integral Fuel Burnable Absorber
L&C	Limitation and Condition
LBLOCA	Large-Break LOCA
LEU+	Low Enriched Uranium+ (between 5 and 10 w/o)
LOCA	Loss-of-Coolant Accident
LOOP	Loss-of-Offsite Power

Acronyms / Codes / Labels

Acronym	Definition
LTA	Lead Test Assembly
LTR	Lead Test Rod
MLO	Maximum Local Oxidation
NRC	Nuclear Regulatory Commission
NSSS	Nuclear Steam Supply System
OPA	Offsite Power Available
PAD	Performance Analysis and Design
PCT	Peak Cladding Temperature
PIE	Post-Irradiation Examination
PWR	Pressurized Water Reactor

Acronyms / Codes / Labels

Acronym	Definition
RAI	Request for Additional Information
SBLOCA	Small-Break LOCA
SER	Safety Evaluation Report
TBS	Transition Break Size
TCD	Thermal Conductivity Degradation
TF2	<u>W</u> COBRA/TRAC-TF2; thermal-hydraulic code licensed as part of the FSLOCA EM
W	Westinghouse