

CONSTELLATION NUCLEAR

CRANE CLEAN ENERGY CENTER (CRANE) RADIOLOGICAL EMERGENCY PLAN

Part I: INTRODUCTION

Section A: Purpose	Part 1, 1
Section B: Background.....	Part 1, 2
Section C: Scope	Part 1, 2
Section D: Planning Basis	Part 1, 3
Section E: Contiguous - Jurisdiction Governmental Emergency Planning	Part 1, 3
Section F: Integrated Emergency Planning.....	Part 1, 3
Section G: Funding and Technical Assistance	Part 1, 3
Section H: Emergency Response Organization	Part 1, 3
Section I: Federal Response	Part 1, 4
Section J: Form and Content of Plan.....	Part 1, 4

Part II: PLANNING STANDARDS AND CRITERIA

Section A: Assignment of Responsibility	1
1. Concept of Operations	1
2. State and County Functions and Responsibilities	6
3. Agreements in Planning Effort.....	6
4. Continuous Coverage	7
Section B: Crane Emergency Response Organization	1
1. On-Shift Emergency Response Organization Assignments	1
2. Authority Over the Emergency Response Organization	2
3. Criteria for Assuming Command and Control (Succession)	2
4. Non-Delegable Responsibilities	3
5. Emergency Response Organization Positional Responsibilities	4
6. Constellation Emergency Response Organization Block Diagram.....	22
7. Constellation Corporate Emergency Response Organization	16
8. Industry/Private Support Organizations.....	17
9. Supplemental Emergency Assistance to the ERO	21
Section C: Emergency Response Support and Resources	1
1. Federal Response Support and Resources	1
2. Liaisons	1
3. Radiological Laboratories.....	2
4. Other Assistance	2

Section D: Emergency Classification System	1
1. Emergency Classification System	1
2. Emergency Action Level Technical Bases	5
3. Timely Classification of Events.....	6
4. Offsite Classification Systems	7
5. Offsite Emergency Procedures	7
Section E: Notification Methods and Procedures	1
1. Bases for Emergency Response Organization Notification	1
2. Notification and Mobilization of Emergency Response Personnel	1
3. Initial Notification Messages.....	3
4. Follow-up Messages	3
5. State and County Information Dissemination	4
6. Notification of the Public.....	4
7. Messages to the Public	4
Section F: Emergency Communications.....	1
1. Communications/Notifications	1
2. Medical Communications	3
3. Communications Testing.....	3
Section G: Public Education and Information	1
1. Public Information Publication	1
2. Public Education Materials	1
3. Media Accommodations	1
4. Coordination of Public Information	3
5. Media Orientation.....	3
Section H: Emergency Facilities and Equipment	1
1. Control Room, Technical Support Center, and Operations Support Center	1
2. Emergency Operations Facility (EOF).....	3
3. Emergency Operations Centers	4
4. Activation.....	5
5. Monitoring Equipment Onsite	6
6. Monitoring Equipment Offsite	9
7. Offsite Monitoring Equipment Storage	10
8. Meteorological Monitoring	10
9. OSC Capabilities	10
10. Facility and Equipment Readiness	11
11. General Use Emergency Equipment.....	11
12. Collection Point for Field Samples	11

Section I: Accident Assessment.....	1
1. Plant Parameters and Corresponding Emergency Classification	1
2. Onsite Accident Assessment Capabilities	1
3. Source Term Determination	1
4. Effluent Monitor Data and Dose Projection	3
5. Meteorological Information	4
6. Unmonitored Release	4
7. Field Monitoring.....	4
8. Field Monitoring Teams.....	4
9. Iodine Monitoring.....	5
10. Dose Estimates	5
11. State Monitoring Capabilities.....	5
Section J: Protective Response.....	1
1. Notification of Onsite Personnel	1
2. Evacuation Locations	1
3. Radiological Monitoring of Evacuees	1
4. Evacuation	2
5. Accountability	2
6. Provisions for Onsite Personnel	3
7. Mechanism for Implementing Protective Action Recommendations.....	3
8. Evacuation Time Estimates (ETEs).....	4
9. Capability of Implementing Protective Action Recommendations	5
10. Implementation of Protective Action Recommendations	5
11. Ingestion Pathway Protective Measures	7
12. Monitoring of Evacuees.....	7
Section K: Radiological Exposure Control	1
1. Emergency Exposure Guidelines	1
2. Emergency Radiation Protection Program	2
3. Personnel Monitoring	2
4. Non-Constellation Personnel Exposure Authorization.....	3
5. Contamination and Decontamination	3
6. Contamination Control Measures	3
7. Decontamination of Relocated Personnel	4
Section L: Medical and Public Health Support.....	1
1. Offsite Hospital and Medical Services	1
2. Onsite First Aid Capability	1
3. Medical Service Facilities	2
4. Medical Transportation.....	2

Section M: Reentry and Recovery Planning	1
1. Reentry and Recovery.....	1
2. Recovery Organization.....	4
3. Recovery Phase Notifications	7
4. Total Population Exposure	7
Section N: Drill and Exercise Program.....	1
1. Exercises.....	2
2. Drills	3
3. Conduct of Drills and Exercises	4
4. Critique and Evaluation	5
5. Resolution of Drill and Exercise Findings	5
Section O: Emergency Response Training.....	1
1. Assurance of Training	1
2. Functional Training of the ERO	1
3. First Aid Response	2
4. Emergency Response Organization Training Program	2
5. General, Initial, and Annual Training Program Maintenance	6
Section P: Responsibility for the Maintenance of the Planning Effort	1
1. Emergency Preparedness Staff Training.....	1
2. Authority for the Emergency Preparedness Effort.....	1
3. Responsibility for Development and Maintenance of the Plan	1
4. Emergency Plan and Agreement Revisions	4
5. Emergency Plan Distribution	5
6. Supporting Emergency Response Plans.....	5
7. Implementing and Supporting Procedures	6
8. Cross Reference to Planning Criteria	6
9. Audit/Assessment of the Emergency Preparedness Program.....	6
10. Maintenance of Emergency Response Facilities (ERF) Telephone Directory	6

Part III: APPENDICES

Appendix 1: References	1-1
Appendix 2: Procedure Cross-Reference to NUREG-0654	2-1
Appendix 3: List of Corporate Letters of Agreement.....	3-1
Appendix 4: Glossary of Terms and Acronyms.....	4-1
Appendix 5: Emergency Response Organization (ERO) Staffing and Augmentation Plan ...	5-1

STATION ANNEX

The Station Annex subject to the requirements of this plan is as follows:

EP-AA-1009: Radiological Emergency Plan Annex for Crane Clean Energy Center

REVISION HISTORY

<u>REVISION</u>	<u>EFFECTIVE DATE</u>	<u>DOCUMENT</u>
0	March 2018	EP-TM-1000
1	December 2018	EP-TM-1000
2	September 2019	EP-TM-1000
3	September 2020	EP-TM-1000
0	TBD	EP-CR-1000
1	TBD	EP-CR-1000

Revision History Summary:

In 2017, Constellation (at the time Exelon) announced the intent to permanently shut down the operating Unit-1 reactor at Three Mile Island Station by the fall of 2019. Constellation revised the station Emergency Plan to establish the Three Mile Island Station Emergency Plan as an independent Emergency Plan separated and de-linked from the fleet Standardized Radiological Emergency Plan (Standard Plan). This allowed decommissioning changes to be made to the Station Emergency Plan without impacting the Standard Plan.

A new Emergency Plan procedure was created for Three Mile Island. It contained regulatory commitments applicable to Three Mile Island which were in the fleet Standardized Radiological Emergency Plan. The new procedure was EP-TM-1000, *Three Mile Island (TMI) Station Radiological Emergency Plan*. The 10CFR.54(q) evaluation #17-122 evaluated the changes between the Standard Plan, the Station Annex, and EP-TM-1000.

Upon implementation, the revised Three Mile Island Emergency Plan was independent of the fleet Emergency Plan. The new Three Mile Island Emergency Plan formed the regulatory basis for developing and submitting License Amendment Requests to the NRC to support decommissioning.

In 2024 Constellation announced the intent to restart Three Mile Island Station Unit 1 as the Crane Clean Energy Center, pending NRC approval. Constellation is revising the station Emergency Plan to support restart. The Emergency Plan in place at the time operations were halted was EP-TM-1000 Revision 0. EP-TM-1000 Revision 1 updated the List of Corporate LOAs and update the definition of the Exercise Cycle to eight years. Subsequent revisions to EP-TM-1000 implemented approved regulatory exemptions as the station progressed through the stages of decommissioning. EP-AA-1009, TMI Radiological Emergency Plan Annex, Revision 29 was in effect at the time. As with EP-TM-1000, subsequent revisions to EP-AA-1009 reflected the station's progression through the stages of decommissioning.

The Emergency Plan document was renumbered and revised to reflect the transition from EP-TM-1000 Rev. 1 to EP-CR-1000 Rev. 0. The station annex was revised to reflect the transition from EP-AA-1009 Rev. 29 to EP-AA-1009 Rev. 32.

Section A: Purpose

As required in the conditions set forth by the Nuclear Regulatory Commission (NRC) for the operating licenses for the Constellation Nuclear Stations, the management of Constellation recognizes its responsibility and authority to operate and maintain the nuclear power stations in such a manner as to provide for the safety of the general public. This document describes the Crane Clean Energy Center, henceforth known as CRANE, Emergency Preparedness Program. The philosophy that guides the development and maintenance of this program is the protection of the health and safety of the general public in the communities around the station and the personnel who work at the plant.

The Crane Clean Energy Center Radiological Emergency Plan establishes the concepts, evaluation and assessment criteria, and protective actions that are necessary in order to limit and mitigate the consequences of potential or actual radiological emergencies. It has been prepared to establish the procedures and practices for management control over unplanned or emergency events that may occur at CRANE. It also provides the necessary pre-arrangements, directions and organization so that all nuclear emergencies can be effectively and efficiently resolved.

The Crane Clean Energy Center Emergency Preparedness Program consists of the Emergency Plan, the Station Annex, emergency plan implementing procedures, and associated program administrative documents. The CRANE Emergency Plan outlines the basis for response actions that would be implemented in an emergency. This document is not intended to be used as a procedure.

The Crane Annex contains information and guidance that are unique to the station. The annex addresses site-specific criteria, including:

- Emergency Action Levels (EALs) located in Addendum 3 to the Annex,
- Deviations from the Emergency Plan (such as station specific on-shift staffing, unique aspects of ERO augmentation, and so forth).
- Facility geography and location for a full understanding and representation of the station's emergency response capabilities.
- Plant specific facilities and equipment associated with the Emergency Preparedness Program.

The Station Annex and its Addenda are part of the plan and are subject to the same review and audit requirements as the plan. In the areas where the Station Annex deviates from the general requirements of the Emergency Plan, the Station Annex shall serve as the controlling document.

Detailed Emergency Plan implementing procedures are maintained separately and are used to guide those responsible for implementing emergency actions.

Section B: Background

In the context of the Emergency Plan, the Station Annex, and implementing procedures, Constellation Nuclear manages the operations of the NRC licensed facility designated as Crane Clean Energy Center.

The primary hazard consideration at the nuclear power station is the potential unplanned release of radioactive material resulting from an accident. The probability of such a release is considered very low due to plant design and strict operational guidelines enforced by the NRC. Notwithstanding, federal regulations require that a solid emergency preparedness program exist for each commercial nuclear power station. A detailed description of the station is in the Updated Final Safety Analysis Report (UFSAR).

In order to minimize the number of ad-hoc decisions made during an emergency and to ensure that necessary equipment, supplies, and essential services are available to meet the needs of an emergency, Constellation Nuclear has developed this Emergency Plan for the Crane Clean Energy Center. The Emergency Plan considers the consequences of radiological emergencies, as required by 10 CFR 50, Paragraph 50.47 and Appendix E.

Additionally, it addresses the guidance and adheres to the intent of the criteria established and provided within NUREG-0654 Rev. 1, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants". The Emergency Plan also considers the consequences of non-radiological emergencies.

Section C: Scope

This document describes actions to be taken in the event of a radiological accident at CRANE that may impact the health and safety of the general public or station employees. It also serves to limit the damage to facilities and property and provide for the restoration of such facilities in the event of an emergency. If such an accident were to occur, the Emergency Response Organization (ERO) would be put in place and maintained until such time when the plant is returned to a stable condition and the threat to the general public or station personnel no longer exists. This plan describes the functions and operation of the ERO, including assignments of authority and responsibility. It does not, nor is it intended to, provide guidance for actual plant equipment manipulations. These instructions are contained in site-specific normal and emergency operating procedures as required by Technical Specifications and other regulatory guidance. The Emergency Plan provides for: identification and evaluation of emergency situations, protective measures, communications, coordination and notification of governmental authorities, document review and control, emergency preparedness assessment, and training of all emergency personnel. An emergency recovery phase is also described in this Emergency Plan.

Section D: Planning Basis

The Emergency Plan, in conjunction with the Station Annex and implementing and administrative procedures, documents the methods by which the CRANE Emergency Preparedness Program meets the planning standards set forth in 10 CFR 50.47(b) and the requirements of 10 CFR 50 Appendix E. Development of the Emergency Plan was based on NUREG-0654/FEMA-REP-1, Rev. 1.

Acceptable alternate methods, which deviate from NUREG-0654, Rev. 1, are allowed under Regulatory Guide 1.101, "Emergency Planning and Preparedness for Nuclear Power Reactors." However, deviations will be documented in the Station Annex and evaluated as continuing to meet the Planning Standards of 10 CFR 50.47(b) and Appendix E to 10 CFR 50 under the 10 CFR 50.54(q) process to ensure the continued effectiveness of the Emergency Plan and Station Annex.

Other applicable regulations, publications, and guidance were used (see Appendix 1, "References") along with site-specific documents to ensure consistency in the planning effort.

Section E: Contiguous-Jurisdiction Governmental Emergency Planning

The Emergency Plan recognizes the state, in cooperation with the local EPZ communities, as the overall authority responsible for protective action directives in order to protect the health and safety of the general public.

Section F: Integrated Emergency Planning

State and local (county level) emergency response plans were utilized in the development of this plan to ensure a consistent and integrated response to a classified event.

Section G: Funding and Technical Assistance

Constellation Nuclear is dedicated to providing the level of support necessary, as dictated by federal regulation, to ensure appropriate integration of the state, county, and utility radiological emergency programs.

Section H: Emergency Response Organization

Constellation Nuclear acknowledges its primary responsibility for planning and implementing emergency measures within the site boundary and for overall plant accident assessment. These emergency measures include corrective actions, protective measures, and aid for personnel onsite. To accomplish these responsibilities, advance arrangements have been made with offsite organizations for special emergency assistance such as ambulance, medical, hospital, fire, and police services.

Section I: Federal Response

Provisions are made within the Emergency Plan for the integration of appropriate elements of the federal assistance activities. Arrangements have been made to accommodate a federal response organization presence at the Constellation Nuclear emergency response facilities as well as support communications between utility and federal emergency facilities.

Section J: Form and Content of Plan

As required by federal regulations, the Emergency Plan is governed by and contained (or referenced) in the Station UFSAR. The Emergency Plan is administratively maintained as a separate document. The Emergency Plan has been formatted similar to NUREG-0654/FEMA-REP-1, Rev. 1. The use of this format lends itself to uncomplicated comparison with the criteria set forth in NUREG-0654/FEMA-REP-1.

Appendix 2, "Procedure Cross-Reference to NUREG-0654", provides a cross-reference between the NUREG-0654 evaluation criteria and the Emergency Plan implementing procedures and applicable administrative documents.

Required Content of the Station Annex

Information that is in the plan need not be restated in the Annex. The Annex shall address what means, methods, and resources are used to satisfy the requirements and responsibilities set forth in the Emergency Plan.

Annex Format and Specific Content: As a minimum, the Station Annex shall address the areas described as follows:

1. Section 1: Introduction

The station and surrounding area are described by the inclusion of maps, drawings and/or diagrams. A summary statement describes the Annex interface with the Emergency Plan.

2. Section 2: Organizational Control of Emergencies

The agencies with which the station has independent agreements for support during an emergency are provided. Station specific differences from the Emergency Plan, such as on-shift staffing or ERO augmentation, shall be outlined. The justification for differences shall be provided as required under 50.54(q) documentation.

3. Section 3: Classification of Emergencies

The Classification levels are described in this Section. Note that the Site Specific EALs are located in Addendum 3 to the Annex and are included for all emergency classes for the purpose of event classification.

4. Section 4: Emergency Measures

Maps indicating the location of Assembly Areas, site evacuation routes, and centers for the monitoring of evacuated nonessential personnel are included. Roadway/traffic control measures of roads under control of the station are addressed.

5. Section 5: Emergency Facilities and Equipment

- Descriptions of the station Control Room, Technical Support Center, and Operational Support Center are provided.
- A description of the specific equipment is provided.
- A description of the capability and resources available to categorize accidents.

Section A: Assignment of Responsibility

This section describes the primary responsibilities and organizational control of Constellation, federal, state, county, and other emergency response organizations within the Plume Exposure Pathway and the Ingestion Pathway Emergency Planning Zones (EPZs). Various supporting organizations are also described as well as staffing for initial and continuous response.

1. Concept of Operations

The relationships and the concept of operations for the organizations and agencies who are a part of the overall ERO are as follows:

a. Identified below are federal, state, and county organizations that are involved in a response to an emergency at Crane Clean Energy Center.

1) Federal Agencies: The National Response Framework (NRF), Nuclear/Radiological Incident Annex outlines the statutory and regulatory responsibilities. The primary federal response for supporting an emergency at a Constellation station include:

a) Nuclear Regulatory Commission (NRC): The NRC is responsible for licensing and regulating nuclear facilities and materials and for conducting research in support of the licensing and regulatory process. These responsibilities include protecting the public health and safety, protecting the environment, protecting and safeguarding materials and plants in the interest of national security and assuring conformity with antitrust laws.

The NRC Regional Office has the responsibility for auditing of nuclear power stations. It is responsible for ensuring that such activities are conducted in accordance with the terms and conditions of such NRC licenses and that as a result of such operations, there is no undue risk to the health and safety of the public.

The NRC Office of Nuclear Reactor Regulation, established by the Energy Reorganization Act of 1974, as amended, performs licensing functions associated with the construction and operation of nuclear reactors and with the receipt, possession, ownership, and use of special nuclear and byproduct materials used at reactor facilities.

With regard to emergency preparedness, the NRC shall:

- Assess licensee emergency plans for adequacy;
- Review the Federal Emergency Management Agency findings and determinations on the adequacy and capability of implementation of state and local plans; and
- Make decisions with regard to the overall state of emergency preparedness and issuance of operating licenses.

The NRC shall respond to incidents at licensed facilities or vehicular accidents involving licensed materials, including radionuclides, in transit. The NRC shall act as the lead Federal agency with regard to technical matters during a nuclear incident including radiological assistance. The NRC shall be prepared to recommend appropriate protective actions for the public and technical actions to the licensee. FEMA shall act as the lead Federal agency for offsite, non-technical concerns.

During an incident, the Chairman of the Commission is the senior NRC authority for all aspects of a response. The Chairman shall transfer control of emergency response activities to the Director of Site Operations when deemed appropriate by the Chairman.

All NRC Regions as well as Headquarters are prepared to respond to potential emergencies. All Regions and Headquarters have developed plans and procedures for responding to radiological incidents involving NRC licensees. Headquarters has developed the NRC Incident Response Plans and Implementing Procedures. Each NRC Region has developed Regional Supplements that detail how the Region will fulfill all of the responsibilities assigned in the NRC Incident Response Plan. All NRC organizations are responsible for maintaining an effective state of preparedness through periodic training, drills and exercises.

Each Region and Headquarters have established and maintain an Incident Response Center designed to centralize and coordinate the emergency response function. Adequate communications are established to link the licensee, Headquarters and the Region. The NRC has established lines of communications with local government, state government, other Federal agencies, Congress and the White House. Public information will be disseminated in a timely manner and periodically.

Each Region is prepared to send a team of qualified specialists to the scene expeditiously. All of the necessary supplies and equipment needed for emergency response will be provided and maintained by the NRC.

The NRC Incident Response Plan objectives are to provide for protection of the public health and safety, property, and the environment, from the effects of radiological incidents that may occur at licensed facilities or which involve licensed materials, including radio-nuclides in transit.

The objectives of the agency plan set forth the organizational and management concepts and responsibilities needed to assure that NRC has an effective emergency response program.

The plan is intended to ensure NRC preparedness:

- To receive and evaluate notification information of incidents, accidents and unusual events and determine the extent of NRC response necessary to meet NRC responsibilities for mitigating the consequences of these events;
- To determine the cause of incidents, accidents, and unusual events in order to ensure that appropriate corrective actions are taken by the licensee to minimize the consequences of these events;
- To provide onsite expertise in a timely manner, to evaluate the nature and extent of the incident, ascertain plant status (for reactors and fuel facilities), monitor licensee activities, determine compliance, make recommendations, and, if necessary, issue orders relative to the event;
- To inform the public and others of plant status and technical details concerning the incident;
- To recommend adequate protective actions to the responsible local and/or state agencies;
- To provide technical assistance;
- To ensure the plant is returned to a safe condition; and
- To return the NRC Headquarters and Regional office to normal operations.

b) Federal Emergency Management Agency (FEMA): Per the National Response Framework (NRF), FEMA is responsible for the overall coordination of a multi-agency Federal response to a significant radiological incident. The primary role of FEMA is to support the state by coordinating the delivery of Federal non-technical assistance. FEMA coordinates state requests for Federal assistance, identifying which Federal agency can best address specific needs. If deemed necessary by FEMA, it will establish a Federal Response Center from which it will manage its assistance activities.

c) Federal Radiological Preparedness Coordinating Committee (FRPCC): The FRPCC consists of the Federal Emergency Management Agency, which chairs the Committee, the Nuclear Regulatory Commission, the Environmental Protection Agency, the Department of Health and Human Services, the Department of Energy, the Department of Transportation, the Department of Defense, the Department of Agriculture, the Department of Commerce, and where appropriate and on an ad hoc basis, other Federal departments and agencies. The FRPCC shall assist FEMA in providing policy direction for the program of Federal assistance to state and local governments in their radiological emergency planning and preparedness activities.

- d) U.S. Department of Energy (DOE): The Department of Energy (DOE) has extensive radiological monitoring equipment and personnel resources that it can assemble and dispatch to the scene of a radiological incident. The Department of Energy (DOE) local operations office can assist Constellation Nuclear following a radiological incident as outlined in the Federal Radiological Monitoring and Assessment Plan (FRMAP). If Constellation Nuclear, the NRC or the affected state(s) deem that assistance from DOE is necessary or desirable, the affected state(s) would notify the appropriate DOE operations office.
- e) Environmental Protection Agency (EPA): Assists with field radiological monitoring/sampling and non-plant related recovery and reentry guidance.
- f) The U.S. Coast Guard (USCG): The USCG patrols and ensures the safety of navigable waterways in the United States. The USCG is promptly notified of any oil or hazardous substance discharges into rivers or lakes or radioactive contamination of rivers or lakes under its jurisdiction at levels requiring assistance to effect protective actions. The USCG is contacted by the appropriate state agencies in the event of an incident at an applicable nuclear power plant. The USCG is responsible for officially closing the waterways to all commercial traffic [Refer to the appropriate State Plan].
- g) U.S. Army Corps of Engineers: The U.S. Army Corps of Engineers control barge and boat traffic at locks and dams on navigable waterways in the United States. The Corps of Engineers will be contacted by the appropriate state agencies in the event of an incident at an applicable nuclear power plant. The Corps will be responsible for closing their locks and dams to all waterway traffic leading to the affected area, allowing only traffic leaving the area [Refer to the State Plan].
- h) Federal Bureau of Investigation (FBI): Support from the FBI is available through its statutory responsibility based in Public Law and the US code, and through a memorandum of understanding for cooperation with the NRC. Notification to the FBI of emergencies in which they would have an interest will be through provisions of the Nuclear Station's Security Plan, or by the NRC.
- i) National Weather Service (NWS): Provides meteorological information during emergency situations, if required. Data available will include existing and forecasted wind directions, wind speed, and ambient air temperature.

2) State Agencies

- a) The Commonwealth of Pennsylvania: The Commonwealth organizations having prime responsibility in matters of radiation hazards are the Pennsylvania Emergency Management Agency and the Bureau of Radiation Protection (BRP) of the Pennsylvania Department of Environmental Protection.

- Pennsylvania Emergency Management Agency: Responsibilities of PEMA are outlined in The Nuclear/Radiological Plan (formerly Annex E) of the Commonwealth of Pennsylvania Emergency Operations Plan. PEMA is the primary State agency to interface with FEMA. Any BRP requests for non-technical assistance from FEMA are coordinated through PEMA.
- Department of Environmental Protection, Bureau Of Radiation Protection (DEP/BRP): Responsibilities of DEP/BRP are outlined in the Nuclear/Radiological Plan (formerly Annex E).
- Pennsylvania State Police: Responsibilities of the State Police are set forth in the Nuclear/Radiological Plan (formerly Annex E).

3) County Government Agencies

Constellation and the surrounding communities that comprise the Plume Exposure Pathway EPZs have developed integrated emergency response programs that call upon the resources of their community. The community organizations are responsible for implementing and coordinating the community response to an emergency.

The County Emergency Operations Centers (EOCs) serve as the primary coordinating center for local government response within the county's jurisdiction and for coordination between counties.

b. During an event classified as an Alert, Site Area Emergency, or General Emergency, the Constellation Nuclear ERO replaces the normal plant organization. The ERO consists of three major response sub-organizations:

1) The Station Organization, directed by the Station Emergency Director, provides for:

- Control and operation of the plant.
- Mitigation of the emergency condition.
- Protection of station personnel.
- Emergency event classification.
- Notification of the appropriate individuals and Federal agencies prior to EOF taking Command and Control.
- Emergency support for operations, engineering, maintenance, firefighting, material acquisition, security, and first aid.

2) The Corporate Organization, directed by the Corporate Emergency Director, provides for:

- Emergency notifications to state and local agencies.
- Offsite radiological accident assessment and Protective Action Recommendations to offsite authorities.
- The primary interface between Constellation Nuclear and outside organizations responsible for the protection of the public.

3) The Public Information Organization, directed by the Corporate Spokesperson, coordinates with public information officers from other organizations to provide information to the public through the news media.

c. Interrelationships between major Constellation Nuclear organizations and sub-organizations in the total response effort are illustrated in a block diagram in Figures A-1 and A-2. For a more detailed diagram of the Constellation Nuclear ERO, see Figures CRANE B-1a to CRANE B-1d.

d. The Corporate Emergency Director is a senior Constellation employee with overall responsibility for coordinating emergency response actions in support of the affected Constellation Nuclear station, Emergency Public Information Organization, and affected state and local agencies.

e. Procedures for training and maintenance of the emergency organization are in place to ensure 24-hour per day staffing for emergency response, including established communication links.

2. State and County Functions and Responsibilities

The state and counties have emergency response plans that specify the responsibilities and functions for the major agencies, departments, and key individuals of their emergency response organizations. This information is located in their respective plans.

3. Agreements in Planning Effort

Written agreements establishing the concept of operations developed between Constellation and other support organizations having an emergency response role within the EPZs have been developed. These agreements identify the emergency measures to be provided, the mutually accepted criteria for implementation, and the arrangements for exchange of information. Agreement letters are not necessary with Federal Agencies who are legally required to respond based on Federal law; however, agreements are necessary if the agency was expected to provide assistance not required by law. Letters of Agreement with private contractors and others who provide services in support of the station shall be obtained by the station and are maintained on file at the station. Constellation Corporate Emergency Preparedness maintains Letters of Agreement with organizations that provide support to multiple stations. A contract/purchase order with a private contractor is considered acceptable in lieu of a Letter of Agreement for the specified duration of the contract.

4. Continuous Coverage

Constellation maintains 24-hour emergency response capability at CRANE. The normal on-shift complement provides the initial response to an emergency. This group is trained to handle emergency situations (e.g. initiate implementation of the Emergency Plan, make initial accident assessment, emergency classification, notifications, communications, protective action recommendations) until the augmented ERO arrives. The ERO is composed of a broad spectrum of personnel with specialties in operations, maintenance, engineering, radiochemistry, health physics, material control, fire protection, security, and emergency planning and are available and trained to augment on-shift personnel in an emergency. Procedures for training and maintenance of the emergency organization are in place to provide the capability of continuous (24-hour) operations.

The Corporate Emergency Director, located in the EOF, has the authority and responsibility for assuring continuity of resources (technical, administrative, and material) in the event of the activation of the ERO.





Figure A-1: Constellation Emergency Response Organization Interrelationships**Station Emergency Response****Corporate Emergency Response**

Figure A-2: Agency Response Organization Interrelationships

Section B: Constellation Nuclear Emergency Response Organization

This section describes the Constellation Nuclear ERO, its key positions, and associated responsibilities. It outlines the staffing requirements which provide initial emergency response actions and provisions for timely augmentation of on-shift personnel when required. It also describes interfaces among Constellation Nuclear emergency response personnel and specifies the offsite support available to respond to CRANE.

1. On-Shift Emergency Response Organization Assignments

The normal plant personnel complement is established with the Station Plant Manager having overall authority for station operations. The Station Plant Manager directs the site organization in the management of the various departments while the Shift Manager retains the responsibility for actual operation of plant systems. Emergency Preparedness must consider the capabilities of the normal plant organization, the Station and Corporate Emergency Response Organizations of Constellation Nuclear, and the non-Constellation Nuclear Emergency Response agencies. The initial phases of an emergency situation at a nuclear station will most likely involve a relatively small number of individuals. These individuals must be capable of (1) determining that an emergency exists; (2) providing initial classification and assessment; and (3) promptly notifying other groups and individuals in the emergency organization. The subsequent phases of the emergency situation may require an increasing augmentation of the emergency organization.

CRANE has personnel on-shift at all times that can provide an initial response to an emergency event. ERO staffing tables contained within this Emergency Plan outline the plant on-shift emergency organization and its relation to the normal staff complement. Members of the on-shift organization are trained on their responsibilities and duties in the event of an emergency and are capable of performing all response actions in an Unusual Event or the initial actions of higher classifications.

On-Shift Personnel: CRANE has the capability at all times to perform detection, mitigation, classification, and notification functions required in the early phases of an emergency. Shift augmentation and further ERO involvement will be determined by the extent and magnitude of the event.

Shift Manager: While acting as Shift Emergency Director, will take immediate action during an emergency and will activate the Station ERO, as appropriate. In the Shift Manager's absence or incapacitation, the line of succession is defined by CRANE procedures.

Shift Technical Advisor (STA): During normal plant operations, the Senior Reactor Operators report to the Shift Manager and directly supervise the licensed Reactor Operators and all activities in the Control Room. During an abnormal condition, the Shift Manager assumes direct supervision of personnel and all activities in the Control Room while a qualified individual steps back and assumes an overview role as an STA with the specific responsibility of monitoring the maintenance of core cooling and containment integrity. An individual assigned the duty as the STA shall be available to the Control Room at all times.

Radiation Protection: The Station Radiation Protection personnel are responsible for the handling and monitoring of radioactive materials. Included in this organization are Health Physicists, Radiation Protection Supervisors, and Technicians.

Security: The Station Security personnel are responsible for the physical security of the site. Included in this organization are Security Supervisors and Security Guards.

2. Authority Over the Emergency Response Organization

The Emergency Director in Command and Control is the designated Constellation Nuclear individual who has overall authority and responsibility, management ability, and technical knowledge for coordinating all emergency response activities at the nuclear power station.

- Control Room: Shift Emergency Director (Shift Manager)
- TSC: Station Emergency Director
- EOF: Corporate Emergency Director

3. Criteria for Assuming Command and Control (Succession)

Emergency personnel assume responsibility for their positions upon receiving notification to activate. The responsibility for initial assessment of and response to an emergency rests with the Shift Manager. The Shift Manager is the Shift Emergency Director and has the Station and Corporate Emergency Director's responsibilities and authority until relieved. The Corporate Emergency Director, once having relieved the Shift Manager of the Emergency Director responsibilities, is responsible for continued assessment of the severity of the emergency and for the necessary functions as described in the Emergency Plan, the Station Annex, and the emergency implementing procedures.

The Shift Emergency Director is relieved of Command and Control as soon as possible after the declaration of an Alert (or higher classification if Alert not declared). Following the Command and Control turnover, the Corporate Emergency Director shall have overall Command and Control of the Emergency Response. Note that the Station Emergency Director takes responsibility for onsite Non-Delegable Responsibilities including Classification and Emergency Exposure Control. The Corporate Emergency Director takes responsibility for offsite Non-Delegable Responsibilities including Protective Action Recommendations and State/local Notifications. Command and Control does not transfer until the following criteria have been met:

- Adequate staff levels are present in support of the non-delegable responsibilities.
- The staff has been fully briefed as to the status of the event and the currently proposed plan of action.
- A turnover between the Emergency Director relinquishing Command and Control and the Emergency Director assuming Command and Control has been made.

Although the CRANE ERO fulfills all regulatory requirements for emergency response, it may be altered by the Emergency Director. This type of alteration will be based upon identified needs within the ERO, event dependent criteria, and identified needs of the company as a whole.

4. Non-Delegable Responsibilities

Non-delegable responsibilities include the following functions:


- Event classification.
- Protective Action Recommendations (PARs) for the general public.
- Notification of offsite authorities (approval of state/local and NRC notifications).
- Authorization of emergency exposure controls in excess of 5 Rem TEDE and the issuance of potassium iodide (KI), for Constellation Nuclear emergency workers per EPA-400.

The Shift Manager is responsible for the initial classification of an event and assumes the position as Shift Emergency Director. In this capacity, the Shift Manager has responsibility for performing the non-delegable responsibilities until relieved.

The Shift Emergency Director is relieved of Command and Control as soon as possible after the declaration of an Alert (or higher classification if Alert not declared). Command and Control is transferred to the Station Emergency Director but may be transferred directly to the Corporate Emergency Director.

When the Station Emergency Director assumes overall authority and responsibility for Classification and Emergency Exposure Control and NRC Communications. The Corporate Emergency Director (EOF) will assume the non-delegable responsibilities for PAR determination and notifications to State and Local authorities.

Transition of “Non-Delegable” Responsibilities



5. Emergency Response Organization Positional Responsibilities

The Emergency Plan designates two types of augmented ERO responders. Those designated as Minimum Staff are those key ERO needed to relieve the on-shift staff of key EP functions/tasks required in response to the Emergency and are those required to activate their respective Emergency Response Facility (ERF). Specifically, these are the ERO that are the absolute minimum needed to implement the emergency plan (i.e., if any position or function is not staffed then the emergency plan may not be effectively implemented). These positions in most cases are required to respond to their respective ERF within 60 minutes of the declaration of an Alert or higher classification. See Appendix 5, Table 5-1 for the list of On-shift and Minimum Staff positions.

The positions which are considered Full Augmented staff (i.e., non-minimum staff) are those positions which provide support for the minimum staff in their response to the Emergency. The Full Augmentation positions consist mostly of liaisons, coordinators and additional communicators which help facilitate communication and the emergency response effort over time but are not directly needed to implement the functions/tasks identified in the Emergency Plan.

ERO staffing tables contained within this Emergency Plan outline ERO positions required to meet minimum staffing of the on-shift complement at an Alert or higher classification, and the major tasks assigned to each position. The full augmentation staffing levels described in Emergency Preparedness Implementing Procedures (EPIPs). For extended events (ones which last for more than 24 hours), actual staffing will be established by the Emergency Director based on the event and personnel availability. However, additional staffing or reduced staffing will only occur after discussion concerning the impact on plant operations and emergency response.

In addition to maintaining adequate documentation of the event, responsibilities for each position are as follows:

- a. Station Emergency Response Organization: The Station ERO is the onsite group that is activated during an emergency. It functions under the Station Emergency Director, who is responsible for organizing and coordinating the emergency efforts at and within the immediate vicinity of the station (including carrying out all onsite emergency efforts and the initial offsite environs monitoring efforts necessary to assess plant releases).

The Station ERO consists of station personnel who are involved with emergency response efforts necessary to control the plant during an incident. This organization operates out of the Control Room, the Technical Support Center (TSC) and the Operations Support Center (OSC). Collectively, members of the Station ERO provide for the following activities during an emergency:

- Plant systems operations
- Radiological survey and monitoring (including Environs Monitoring)

- Firefighting
- Rescue operations and First Aid
- Decontamination
- Security of plant and access control
- Repair and damage control
- Personnel protection including Assembly, Accountability and Evacuation
- Communications

1) Shift Manager (Shift Emergency Director) Control Room

A Shift Manager is on duty 24 hours a day and is the Shift Emergency Director in a declared emergency until relieved of this function. While serving in this capacity the Shift Manager is responsible for:

- Activating the ERO (as deemed appropriate or as procedurally required).
- Performing those duties outlined in Section B.5.a.2 for the Station Emergency Director. The on-duty Shift Manager directs the activities of the operating crew and is responsible for the safe operation of the plant in compliance with the station NRC operating license and the station operating procedures. The Shift Manager, after relinquishing Command and Control, functionally reports to the Operations Manager in the TSC.

The Shift Manager's responsibilities, when not in Command and Control, are described below:

- The authority and responsibility to shut down the reactor when determined that the safety of the reactor is in jeopardy or when operating parameters exceed any of the reactor protection circuit set-points and automatic shutdown does not occur.
- To ensure a review has been completed to determine the circumstance, cause, and limits under which operations can safely proceed before the reactor is returned to power following a trip or an unscheduled or unexplained power reduction.
- The responsibility to be present at the plant and to provide direction for returning the reactor to power following a trip or an unscheduled or unexplained power reduction.
- The responsibility to adhere to the station Technical Specifications and to review routine operating data to assure safe operation.
- The responsibility to identify applicable EALs and emergency classifications; and

- The responsibility to adhere to plant operating procedures and the requirements for their use. During an emergency, operations personnel may depart from approved procedures where necessary to prevent injury to personnel, including the public, or damage to the facility consistent with the requirements of 10 CFR 50.54(x) and (y).
- Supervise the activities of the Control Room Crew.

2) Station Emergency Director**TSC**

The Station Emergency Director reports to the Corporate Emergency Director and supervises and directs the Station ERO. The Station Emergency Director's responsibilities include organizing and coordinating the onsite emergency efforts. Additionally, the Station Emergency Director has the requisite authority, plant operating experience and qualifications to implement in-plant recovery operations.

a) Station Emergency Director Responsibilities while in Command and Control:

- Activate the facility.
- Conduct personnel assembly/accountability and evacuation of non-essential personnel at Site Area Emergency, General Emergency or as conditions warrant.
- If the emergency involves a hazardous substance and/or oil discharges, ensure that appropriate notifications and responses have been made.
- Determine if the OSC is to remain activated at the Alert Classification.
- Event classification.
- Emergency exposure controls.
- Protective actions for all onsite personnel.
- Supervision of the Station ERO.
- Inform the Corporate Emergency Director and onsite NRC as to the status of the plant.
- Assist the Corporate Emergency Director in the acquisition of information for the state/local notifications, NRC notifications and offsite agency updates.
- Provide information and recommendations to the Corporate Emergency Director.

- Implement plans, procedures and schedules to meet emergency response objectives as directed by the Corporate Emergency Director.
- Request from the Corporate ERO any additional material, personnel resources or equipment needed to implement response plans and operations.

3) ENS Communicators**CR/TSC**

Responsibilities assigned to all the ENS Communicators include:

- Establish communications with appropriate parties as directed.
- Transmit information that has been reviewed and/or approved by the responsible Manager or Coordinator.
- Document time, date and information being transmitted or received on appropriate forms.
- Record and relay inquiries and the responses to those inquiries.
- Assist appropriate Managers and Coordinators in maintaining proper records and logs of emergency related activities.
- Gather, record, and post appropriate information.
 - Notify the NRC of changes in event classification, , and assist in completing the NRC Event Notification Worksheet and responding to NRC inquiries.
 - Provide real time updates of significant changes to plant and system status and responses to NRC inquiries.
 - Maintain continuous communications with the NRC, if requested, via the NRC ENS phone or commercial telephone line.

4) Operations Manager**TSC**

The Operations Manager reports to the Station Emergency Director. Major functions include determining the extent of station emergencies, initiating corrective actions, and implementing protective actions for onsite personnel. In the event that the Station Emergency Director becomes incapacitated and can no longer fulfill the designated responsibilities, the Operations Manager will normally assume the responsibilities until relieved by another qualified Station Emergency Director. Responsibilities include:

- Coordinate TSC efforts in determining the nature and extent of emergencies pertaining to equipment and plant facilities in support of Control Room actions.

- Initiate immediate corrective actions to limit or contain the emergency invoking the provisions of 10 CFR 50.54(x) if appropriate.
- Recommend equipment operations checks and miscellaneous actions to the Control Room in support of restoration and accident mitigation.
- Approve emergency special procedures, and implement as required under the provisions of 10 CFR 50.54(x).
- Assist in determining the priority assigned to OSC activities.
- Organize and direct medical response efforts for injured personnel.
- Ensure adequate staffing of the Control Room and TSC subordinates.
- Ensure the Shift Manager is informed of OSC staffing utilization and activities.
- Identify steps or procedures that the Operations staff should be utilizing to properly respond to the emergency condition.
- Assist the Station Emergency Director in evaluating changes in event classification.
- Supervise the activities of the ENS Communicator in the TSC.
- Act as the TSC liaison with the appropriate NRC Site Team Representative.

5) Technical Support Staff**TSC**

The TSC Technical Support Staff consists of the following minimum staff engineering positions:

- Electrical Engineer
- Mechanical Engineer
- Core/Thermal Hydraulic Engineer - serves as Core Damage Assessment Methodology (CDAM) Evaluator, as applicable.

In addition, station Engineering support will be augmented on an as needed basis to support accident assessment and mitigation activities.

6) Radiation Protection Manager (RPM)**TSC**

The Radiation Protection Manager reports to the Station Emergency Director. The TSC RPM directs a staff in determining the extent and nature of radiological or hazardous material problems onsite. Responsibilities include:

- Accumulate, tabulate, and evaluate data on plant conditions such as meteorological and radiological monitoring readings, and other pertinent data.
- Act as the TSC liaison with the appropriate NRC Site Team representative.
- Ensure use of protective clothing, respiratory protection, and access control within the plant as deemed appropriate to control personnel exposures.
- Ensure that appropriate bioassay procedures have been implemented for onsite personnel when a radioactivity incident has occurred.
- Ensure that personnel are decontaminated, if necessary.
- Authorize personnel exposures below 5 Rem TEDE (EPA-400 lower limit).
- Assist the Station Emergency Director in determining if exposures in excess of the 5 Rem TEDE (EPA-400 lower limit) are necessary.
- Advise the Station Emergency Director of situations when the use of KI should be considered.
- Advise the Station Emergency Director and EOF Radiation Protection Manager of changes in radiological release status.
- Assist the Operations Manager in planning rescue operations and provide monitoring services as required, including the transfer of injured and/or contaminated personnel.
- Coordinate with the Security Coordinator to determine the routes to be used for evacuation of non-essential personnel.
- Assure additional radiation protection personnel and/or equipment is arranged for, as necessary.

7) Security Coordinator**TSC**

The Security Coordinator reports to the Station Emergency Director and maintains plant security and personnel accountability at the nuclear station. Responsibilities include:

- Maintain plant security and account for all personnel within the protected area.

- Assist the Station Emergency Director in evaluating changes in security related threats and event classifications.
- Identify any non-routine security procedures and/or contingencies that are in effect or that require a response.
- Expedite ingress and egress of emergency response personnel.
- Coordinate with the Radiation Protection Manager in controlling ingress and egress to and from the Protected Area if radiological concerns are present.
- Provide for access control to the Control Room, TSC and OSC, as appropriate.
- Expedite entry into the Protected Area, as necessary, for the NRC Site Team.
- Act as the TSC liaison with the appropriate NRC Site Team representative.
- Assist the Radiation Protection Manager in determining personnel evacuation routes as necessary.
- Coordinate the evacuation of station non-essential personnel with the appropriate Local Law Enforcement Agencies (LLEAs).

8) Operations Support Center Director OSC

The OSC Director reports to the Emergency Director and supervises the activities of OSC personnel. Responsibilities include:

- Assign tasks to designated Leads as available:
 - I&C Maintenance
 - Mechanical Maintenance
 - Electrical Maintenance
 - Radiation Protection
- Coordinate with the OSC Operations Lead in the dispatch of Operations personnel to support Control Room and OSC Team activities.
- Notify the Control Room and TSC prior to dispatch of any OSC teams into the plant.
- Maintain OSC resources including personnel, material, and equipment.

- Maintain accountability for all individuals dispatched from the OSC.
- Conduct periodic briefings on the overall plant status, emergency response activities, and station priorities.
- Assemble and dispatch the Field Monitoring Teams as required.

9) OSC Leads**OSC**

OSC Leads report to the OSC Director and are assigned from the following station departments:

- Mechanical Maintenance
- Electrical
- Instrument and Control
- Radiation Protection

The OSC Lead assigned to an OSC team is responsible at all times for the safety of team personnel and to keep the OSC Director apprised of team status. Specifically, the OSC Leads are responsible for the managing and supervising OSC team personnel, including:

- Conduct of adequate pre-dispatch briefings.
- Ensuring adequate protective equipment and measures have been identified.
- Tracking of OSC team activities while dispatched.
- Debriefing of team personnel upon return to the OSC.

b. Corporate Emergency Response Organization**1) Corporate Emergency Director****EOF**

a) The ongoing responsibilities include:

- Coordinate all Constellation Nuclear activities involved with the emergency response.
- Ensure off-site agency updates are periodically communicated as required/requested.
- Coordinate Constellation Nuclear press releases with the Nuclear Duty Officer and Constellation Communications and Public Affairs.
- Request assistance from non-Constellation Nuclear emergency response organizations, as necessary.

- Direct and coordinate the activation of the EOF.
- b) Following assumption of Command and Control, the additional responsibilities assigned to the Corporate Emergency Director include:
 - Assume overall Command and Control of emergency response activities and the non-delegable responsibilities for PAR determination and the notification of offsite authorities.
 - Ensure that Federal, state and local authorities and industry support agencies remain cognizant of the status of the emergency situation. If requested, dispatch informed individuals to offsite governmental Emergency Operation Centers (EOCs).
 - Approve the technical content of Constellation Nuclear press releases prior to their being released to the media.
- 2) Radiation Protection Manager EOF

The Radiation Protection Manager directs the activities of the EOF Radiation Protection staff. Specific responsibilities include:

 - Recommend changes in event classification and PARs based upon effluent releases or dose projections.
 - Assist the Corporate Emergency Director in the evaluation of the significance of an emergency with respect to the public.
 - Notify the Corporate Emergency Director of meteorological changes that may impact identification of downwind areas.
 - Advise the Corporate Emergency Director of protective actions taken by the station for plant personnel.
 - Assist the TSC in the planning and coordination of activities associated with the evacuation of non-essential personnel.
 - Advise the Corporate Emergency Director on the need for emergency exposures or for issuance of KI to the Field Monitoring Teams or Constellation personnel required to enter the plume.
 - Determine the need for and contact Occupational Health/Industrial Safety Services personnel for assistance.
 - Monitor plant radiological conditions and advise the TSC Radiation Protection Manager of any adverse trends or potential release pathways that may impact existing event classification.
 - Assist in the completion and review of the state/local notification form.

- Maintain cognizance of environmental sampling activities.
- Ensure state authorities are provided information pertaining to Constellation Field Monitoring Team activities and sample results.
- Assist the affected station in the following areas:
 - Planning and coordination of activities associated with the evacuation of non-essential personnel.
 - Acquisition of additional instrumentation, dosimetry, protective equipment and radiological support personnel.
- Assist and interface with the EOF Technical Support Group and the station in the development of plans for plant surveys, sampling, shielding, and special tools in support of waste systems processing and design modification activities.
- Upon request, provide in-plant health physics data to Emergency Public Information personnel.
- Coordinate Field Monitoring Team Activities.
- Determine needs of the Dose Assessment Coordinator and the Environmental Coordinator for updates on Field Monitoring Team data and ensure distribution of new data to them in accordance with those needs.
- Promptly report new environmental or Field Monitoring Team exposure data to the Dose Assessment Coordinator.

3) Dose Assessment Coordinator**EOF**

The Dose Assessment Coordinator reports to the EOF Radiation Protection Manager. Responsibilities include:

- Interpret radiological data and provide PARs based upon dose projections to the EOF Radiation Protection Manager.
- Advise the EOF Radiation Protection Manager of changes in event classification based on effluent releases or dose projections.
- Initiate evaluation of the need for administering KI to Constellation nuclear workers.
- Remain cognizant of forecast and meteorological data and ensure the status is updated periodically.
- Notify the EOF Radiation Protection Manager of meteorological changes that may impact identification of downwind areas.

- Upon request, provide release and dose assessment data to Emergency Public Information personnel.
- Perform dose projections using the Dose Assessment computer models
- Monitor meteorological and plant effluent conditions.
- Evaluate the need for administering KI to Constellation nuclear workers.

4) Computer Specialist EOF

The Computer Specialist reports to the Emergency Director. Responsibilities include:

- Assist any personnel in logging in, initializing or using a desired computer program.
- Investigate and repair problems encountered with communications equipment and computer equipment/applications.

5) State/Local Communicator EOF

The State/Local Communicator reports to the Corporate Emergency Director. Responsibilities include:

- Communicate and receive information via the Nuclear Accident Reporting System (NARS) circuit or commercial telephone line with appropriate state and county agencies.

c. Public Information Emergency Response Organization

1) Corporate Spokesperson JIC

The Corporate Spokesperson reports to the Corporate Emergency Director and is responsible for directing the Constellation Emergency Public Information Organization and providing news information to the media. Responsibilities include:

- Maintain command and control of the Joint Information Center.
- Coordinate with Federal, state and local agencies, as well as with other organizations involved in the emergency response, to maintain factual consistency of information to be conveyed to the news media/public.
- Conduct periodic briefings with the news media.
- Interface with the Public Information Director.
- Coordinate and direct responses to media inquiries.

- Ensure that the composition and timeliness of Constellation News Releases are adequate.
- Provide for timely exchange of information between other spokespersons.

2) JIC Director JIC

The JIC Director reports the Corporate Spokesperson to ensure the operability of and to supervise the activities in the JIC. Responsibilities include:

- Maintain cognizance of conditions of the plant and environment, and the actions of Constellation Nuclear and governmental support personnel.
- Coordinate with Federal, state and local agencies, as well as with other organizations involved in the emergency response, to maintain factual consistency of information to be conveyed to the news media/public.
- Participate, as needed, in rumor control activities.
- Ensure that adequate information flow between the EOF and the JIC is coordinated through the Public Information Director.
- Authorize admittance of non-Constellation Nuclear officials to the JIC.
- Until the JIC is fully staffed, work with Corporate Communications to compose draft news releases.
- Provide the drafted news releases to the Corporate Emergency Director for technical review prior to Public Information Director approval.
- Until the JIC is fully staffed, work with Corporate Communications to ensure that rumors are reviewed, documented and responded to by Constellation Nuclear personnel as deemed appropriate.
- Until the JIC is fully staffed, work with Corporate Communications to document and respond to rumors as quickly as possible, through the Constellation Communications and Public Affairs.
- Until the JIC is fully staffed, work with Corporate Communications to ensure that the media is being monitored and that Constellation Nuclear personnel review the information detailed or contained in media releases.

3) Public Information Director (PID) JIC

When the Emergency Public Information Organization is activated, the Public Information Director reports to the Corporate Spokesperson and is responsible for all emergency event related information intended to be conveyed from Constellation Nuclear to the news media/public. The Public Information Director may perform this function at remote locations. Responsibilities include:

- Provide the Corporate Emergency Director with an overview of the public and media impacts resulting from the Constellation Nuclear and governmental activities.
- Participate with the Corporate Emergency Director regarding information to be released to the public.
- Authorize the issuance of news releases.
- Interface with the Corporate Spokesperson at the JIC.
- Act as a liaison between the ERO and Constellation Nuclear's corporate executives.
- Maintain cognizance of conditions of the plant and environment, and the actions of Constellation Nuclear and governmental support personnel.
- Coordinate information flow between the EOF and the JIC.
- Review and access media coverage of the emergency event.

6. Crane Clean Energy Center Emergency Response Organization Block Diagram

ERO staffing tables contained within the Emergency Plan in Appendix 5, list the key positions of the ERO. Figures CRANE B-1a through CRANE B-1d illustrate the overall emergency response organization. Section B.5 discusses specific responsibilities and the interrelationships for key positions.

7. Constellation Corporate Emergency Response Organization

The Corporate ERO consists of the EOF Organization and the Emergency Public Information Organization. Personnel staffing these corporate organizations are covered in detail in Section B.5 of this plan.

The Corporate Emergency Response Organization is staffed by Constellation personnel, and operates out of the Emergency Operations Facility (EOF) and the Joint Information Center (JIC). The Corporate ERO is supported by News Media Spokespersons, environmental assessment staff and monitoring teams that provide long-term support to the affected station. Additionally, the Corporate ERO has long term liaison responsibilities with federal, state, and local authorities. These positions are further described in the EPIPs.

The Emergency News Center (ENC) function is responsible for the collection and analysis of event information and status, and development of Company news statements. This information is then communicated to the JIC Spokespersons. The ENC function may be located at either the EOF or the JIC.

The EOF is activated at an Alert. The EOF Organization is responsible for evaluating, coordinating and directing the overall company activities involved in the emergency response. Within the EOF, the Corporate Emergency Director shall assume Command and Control from the Shift Emergency Director when classification escalates to an Alert or higher, unless the EOF capabilities are limited such that the overall control and responsibility for PARs and offsite notifications cannot be assumed. The EOF may also function in a supporting role to the station when the Station Emergency Director maintains Command and Control. The JIC is activated within 90 minutes of an Alert or higher. Some JIC functions may continue to be performed by the Constellation Communications organization until transferred to the JIC.

8. Industry/Private Support Organizations

Constellation Nuclear retains contractors to provide supporting services to nuclear generating stations. A contract/purchase order with a private contractor is acceptable in lieu of an agreement letter for the specified duration of the contract. Among services currently provided are the following:

a. Institute of Nuclear Power Operations (INPO): Experience has shown that a utility may need resources beyond in-house capabilities for the recovery from a nuclear plant emergency. One of the roles of the Institute of Nuclear Power Operations (INPO) is to assist affected utilities by quickly applying the resources of the nuclear industry to meet the needs of an emergency. INPO has an emergency response plan that enables it to provide the following emergency support functions:

- Assistance to the affected utility in locating sources of emergency personnel, equipment and operational analysis.
- INPO, Electric Power Research Institute (EPRI) and Nuclear Energy Institute (NEI) maintain a coordination agreement on emergency information with their member utilities.
- INPO provides the "Nuclear Network", or its replacement, electronic communications system to its members, participants, NEI, and EPRI to coordinate the flow of media and technical information about the emergency.

- Constellation Nuclear may obtain utility industry information and assistance from any party to this agreement through the coordination of INPO.

To support these functions, INPO maintains the following emergency support capabilities:

- A dedicated emergency call number.
- Designated INPO representative(s) who can be quickly dispatched to the utility emergency response organization to coordinate INPO support activities and information flow.
- The 24-hour per day operation of an Emergency Response Center at INPO headquarters.

Constellation Nuclear will notify INPO (via the designated emergency call number) for all situations involving an Alert, Site Area Emergency, or General Emergency declaration per the Constellation Nuclear Reportability Manual.

INPO has coordinated the preparation of a Voluntary Assistance Agreement for Transportation Accidents. Constellation Nuclear has signed this agreement which establishes the rights and responsibilities of electric utilities in requesting or providing assistance for response to a nuclear materials Transportation Accident.

b. American Nuclear Insurers (ANI): In early 1982, ANI issued Bulletin #5B (1981) "Accident Notification Procedures for Liability Insurers" which provides revised criteria for the notification of the Pools in the event of a nuclear emergency at one of the liability insured nuclear power reactor sites. This revision brings the ANI/MAELU (Mutual Atomic Energy Liability Underwriters) notification criteria into alignment with the standard emergency classification system adopted by the nuclear industry. This document also identifies a suitable channel for follow-up communication by ANI after initial notification.

- ANI/MAELU Emergency Assistance: In the event of an extraordinary nuclear occurrence (as defined in the Price-Anderson Law) ANI and MAELU (the insurance pools) have plans prepared to provide prompt emergency funding to affected members of the public.
- ANI/MAELU Emergency Assistance (Claims Handling Procedures): The pools' emergency assistance arrangements contemplate the mobilization and dispatch of emergency claims teams to directly dispense emergency assistance funds to affected members of the public.

The pools should be notified in the event of a nuclear emergency requiring notification of state or Federal governmental agencies, or if the insured believes that offsite persons may be affected and financial assistance of a nature discussed may be required. In these instances, ANI expects notification as soon as possible after the initiation of the emergency. Constellation notification to the pools in the event of an Alert, Site Area Emergency, or General Emergency will be in accordance with the Constellation Nuclear Reportability Manual.

Even if it appears to be remote that offsite persons will be affected, the pools should be notified in order that response plans can be initiated to the point of alerting teams of adjusters to stand by. Response activity can be discontinued if it proves less severe and does not require pool response.

All nuclear occurrences of an emergency or non-emergency nature that fall under the nuclear liability policy should be reported formally in writing to ANI by the Constellation Nuclear Insurance Administrator.

- Emergency Notification and Follow-up Procedures: Pre-established lines of communication exist between each utility and ANI in order to exchange all required information during a developing emergency situation.

ANI Bulletin 11-01, "Revised Emergency Notification Procedures for ANI Policyholders", has four specific instances which require notification to ANI. They generally include 1) Notification of A Facility Nuclear Incident, 2) Notification of a Transportation Incident Involving Radioactive Materials, 3) Notification of a Drill or Test of the ANI Emergency Number, and 4) Continued Incident Reporting.

ANI maintains 24-hour coverage of an emergency notification number. ANI's emergency notification call center is fully automated with no hold times for reporting a nuclear incident, a transportation event, a facility drill, or a test of the ANI emergency contact. The ANI emergency response contact number has not changed and continues to be: (877) 680-2644. The contact number is monitored 24 hours a day, 7 days a week, 365 days a year. Emergency response procedures and records must include this number.

In addition to ANI emergency response telephone contact, the insured must include ANI on copies of all e-mail data and/or written facsimile emergency notifications that are required and sent to State and Federal authorities. Email data should be delivered to ANI.ER@amnucins.com. The ANI facsimile number is: (860)-659-0002

In order that follow-up information is available to the Insurance Pool Constellation Nuclear has established the Corporate Emergency Director or their designee as a Point of Contact that ANI personnel may use to update themselves regarding the status of the emergency.

NOTE: For the below listed support services, the specific contractors may change but the functions are maintained.

c. Environmental Monitoring Services:

Environmental Inc.: Environmental Inc. provides emergency Radiological Environmental Monitoring Program (REMP) services. These services include:

- Sample collection
- Handling, packaging and storage of test samples
- Sample shipment
- Chain of Custody

The Environmental Inc. Midwest Laboratory in Northbrook, Illinois analyzes environmental samples for their radioactivity content and reports results to Constellation Nuclear. The REMP sample collection activities at certain Mid-Atlantic and Northeast stations have been subcontracted to Constellation Industrial Services (also referred to as Fort Smallwood) while others are performed by station personnel.

d. Teledyne Brown Engineering: Teledyne Brown Engineering provides bioassay analysis and radiochemical analysis services.

e. Department Of Energy (DOE) Radiation Emergency Assistance Center/Training Site (REAC/TS): DOE REAC/TS provides services of medical and health physics support. REAC/TS advises on the health physics aspects of situations requiring medical assistance.

f. Murray and Trettel, Inc.: Murray and Trettel, Inc. provide meteorological monitoring services, including weather forecasts. Murray and Trettel maintain all Constellation Nuclear station meteorological facilities. Murray and Trettel have computer capability to poll remotely the meteorological facilities to ascertain local conditions and to detect instrument failure.

g. Landauer, Inc.: Landauer provides extremity dosimetry services. In an emergency Landauer would provide additional dosimetry to the affected nuclear station and EOF, if needed.

h. Manufacturer Design and Engineering Support: Under established contracts, the following will provide available engineering expertise, specialized equipment and other services identified as needed and deemed appropriate to assist in an emergency situation:

- General Electric (GE) Nuclear Energy
- Westinghouse Electric Company

- Framatome Inc.

9. Supplemental Emergency Assistance to the ERO

Agreements are maintained with outside support agencies who do not take part in the organizational control of the emergency that provide assistance when called on during an emergency or during the recovery phase. These agreements identify the emergency measures to be provided, the mutually accepted criteria for implementation, and the arrangements for exchange of information. These support agencies (named in the Station Annex) provide services of:

- a. Law enforcement;
- b. Fire protection;
- c. Ambulance services;
- d. Medical and hospital support

Support groups providing transportation and treatment of injured station personnel are described in Section L of this plan.

Figure CRANE B-1a: Constellation Overall ERO Command Structure





Figure CRANE B-1b: Emergency Onsite Organization

ERO response pool personnel do not include the on-shift complement.

Figure CRANE B-1c: Emergency Offsite Organization





Figure CRANE B-1d: Emergency Public Information Organization



Section C: Emergency Response Support and Resources

This section describes the provisions for requesting and effectively utilizing support resources and for accommodating offsite officials at the Constellation Nuclear emergency response facilities.

1. Federal Response Support and Resources

Assistance is available from federal agencies through the National Response Framework (NRF). The lead federal agency who provides direct assistance to Constellation during an emergency is the Nuclear Regulatory Commission (NRC). Other federal agencies, such as the Federal Emergency Management Agency (FEMA) and the Department of Energy (DOE), provide assistance to the state through implementation of the NRF.

- a. Sections A and B of this plan identify the specific individuals by title who are authorized to request federal assistance.
- b. Federal agencies that may provide assistance in direct support of Constellation Nuclear in the event of an accident are identified in Section A of this plan. If needed, federal resources are made available to Constellation Nuclear in an expeditious and timely manner.
- c. Each emergency response facility has the equipment and communications capability necessary for a continuous high level of response, interaction, and communication among key personnel during emergency conditions. The emergency facilities are able to accommodate federal representatives with working areas provided for their use. Accommodations for the expected NRC site response team assume the following approximate numbers for each facility:

	Initial Activation (minimum)	Full Activation
EOF	9	16
TSC	3	5
CR	1	1
JIC	1	10

The Constellation Emergency Response Organization will provide senior management support for site response teams and communications over a Management Counterpart Link to federal response headquarters.

2. Liaisons

- a. The NRC, FEMA, and the state may dispatch representatives to the EOF where accommodations have been provided.
- b. At the Alert level and above, Constellation Nuclear personnel may be assigned as liaisons to the requesting state and/or county Emergency Operations Center (EOC). These representatives act as technical liaisons to interpret emergency action levels and protective action recommendations made by Constellation.

3. Radiological Laboratories

Support of the radiation monitoring and analysis effort is provided by an onsite laboratory. The onsite laboratory is the central point for receipt and analysis of all onsite samples and includes equipment for chemical analyses and for the analysis of radioactivity. Additional facilities for counting and analyzing samples can be provided by the other Constellation Nuclear generating stations, state, federal or contracted laboratory services. These laboratories can act as backup facilities in the event that the plant's counting room and laboratory become unusable or the offsite radiological monitoring and environmental sampling operation exceeds the capacity or capability of the station laboratory during an emergency. Additional outside analytical assistance may be requested from contracted vendors or state and federal agencies. The equipment and analytical capabilities for Crane laboratories are listed in the Station Annex. The state, federal and contract laboratories maintain independent evaluation and certification processes and have the capability of quantitative analysis of terrestrial, marine and air samples.

4. Other Assistance

Any unaffected Constellation Nuclear Generating station is available to provide certain types of assistance and support, including engineering, design, consultation, whole body counting, and dosimetry evaluation and equipment. Additional facilities, organizations, and individuals, as listed in the Emergency Response Facilities (ERF) Telephone Directory, are available and may be used in support of emergency response. In addition, American Nuclear Insurers (ANI) provides insurance to cover Constellation legal liability up to the limits imposed by the Price-Anderson Act, for bodily injury and/or property damage caused by the nuclear energy hazard resulting from an incident at the plant. Written agreements which describe the level of assistance and resources provided to Constellation Nuclear by external sources are included in Appendix 3 as applicable.

Section D: Emergency Classification System

This section describes the classification and emergency action level scheme used to determine the minimum response to an abnormal event. This scheme is based on plant systems, effluent parameters, and operating procedures. The initial response of federal, state, and county agencies is dependent upon information provided by the ERO. Constellation works closely with the state and county agencies to ensure consistency in classification schemes and procedural interfaces.

1. Emergency Classification System

The Emergency Plan provides for classification of emergencies into five (5) categories or conditions, covering the postulated spectrum of emergency situations. The first four (4) categories: Notification of Unusual Event (referred to as Unusual Event), Alert, Site Area Emergency, and General Emergency, are characterized by Emergency Action Levels (EALs) or event initiating conditions and address emergencies of increasing severity. The fifth, the Recovery classification, is unique in that it may be viewed as a phase of the emergency requiring specific criteria to be met and/or considered prior to its declaration. Recovery is that period when the emergency phase is over and activities are in progress to return the situation to a normal state (acceptable condition).

- a. **Unusual Event** - Events are in process or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been initiated. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs.

This is the least severe of the four (4) levels. The purpose of this classification is to bring response personnel and offsite agencies to a state of readiness in the event the situation degrades and to provide systematic handling of information and decision making. The Shift Manager, as Shift Emergency Director will classify an Unusual Event.

Required actions at this classification include:

- Notifications to station management and the NDO.
- Notification, within 15 minutes, of the state and local communities.
- At the discretion of the Emergency Director, station management or the Nuclear Duty Officer (NDO), full or selective staffing of the TSC, OSC, and EOF may be initiated.
- Notification of the NRC immediately after notification of the appropriate State and local agencies and not later than 60 minutes of classification.
- Assessment of the situation and response as necessary, which may include escalating to a higher classification if conditions warrant.

- When the event is terminated, close-out is performed over communication links to offsite authorities participating in the response (i.e., NRC, state, county), followed by formal transmission of a state/local notification form within 24 hours.
- b. Alert - Events are in process or have occurred which indicate an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life-threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. Any releases are expected to be limited to small fractions of EPA Protective Action Guideline exposure levels.

The purpose of this classification is to ensure that emergency response personnel are readily available and to provide offsite authorities with current status information. An Alert will be classified as the initiating event or as escalation from an Unusual Event. In either case, the classification will most likely be made by the Shift Manager (Shift Emergency Director) prior to the transfer of Command and Control.

Required actions at this classification include:

- Notifications to station management and the NDO.
- Notification, within 15 minutes, of the state and local communities. The EOF will assume state update responsibilities.
- Activation of the TSC, OSC, EOF, and the JIC organizations.
- Transfer of Command and Control.
- Notification of the NRC immediately after notification of the appropriate State and local agencies and not later than 60 minutes of classification.
- Notification of ANI.
- Assessment of the situation and response as necessary, which may include escalating to a higher classification if conditions warrant.
- On-site and off-site Field Monitoring Teams are sent to staging areas or dispatched to monitor for releases of radiation to the environment.
- Keeping offsite authorities informed of plant status by providing periodic updates to include meteorological and radiological data.
- When the event is terminated, notification is performed over communication links followed by an Initial Incident Report to offsite authorities participating in the response (i.e., NRC, state, county) within 8 hours.

c. Site Area Emergency - Events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public or HOSTILE ACTION that results in intentional damage or malicious acts; 1) toward site personnel or equipment that could lead to the likely failure of or; 2) that prevent effective access to equipment needed for the protection of the public. Any releases are not expected to result in exposure levels which exceed EPA Protective Action Guideline exposure levels beyond the site boundary.

The purpose of this classification, in addition to those of the Alert level, is to ensure that all emergency response centers are staffed and provisions are made for information updates to the public through offsite authorities and the news media. The classification will most likely be made by the Station Emergency Director following activation of the TSC.

Required actions at this classification, in addition to those listed under the Alert level, include:

- If not previously performed, Assembly/Accountability shall be performed and Site Evacuation of non-essential personnel shall be initiated.
- Keeping offsite authorities informed of plant status by providing periodic updates to include meteorological data and projected or actual doses for any releases that have occurred.

d. General Emergency - Event(s) are in process or have occurred which involve actual or imminent substantial fuel degradation or melting or HOSTILE ACTION that results in an actual loss of physical control of the facility. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.

The purpose of this classification, in addition to those of the Site Area Emergency level, is to initiate predetermined protective actions for the public and provide continuous assessment of information from monitoring groups. The classification will most likely be made by the Station Emergency Director following activation of the TSC.

Required actions at this classification, in addition to those listed under the Alert and Site Area Emergency, include:

- A Protective Action Recommendation will be determined.
- Assessment of the situation and response as necessary.

e. Recovery: That period when the emergency phase is over and activities are being taken to return the situation to a normal state (acceptable condition). The plant is under control and no potential for further degradation to the plant or the environment is believed to exist.

Recovery will be classified by the Station Emergency Director after obtaining authorization from the Corporate Emergency Director.

Required actions at this classification include:

- The affected state(s) and the NRC should be consulted prior to entry into Recovery.
- Notifications will be made to station management, the NDO, state(s) and NRC.
- A Recovery organization will be established to manage repairs to return the Unit to an acceptable condition, and support environmental monitoring activities as requested in coordination with Federal and state efforts.
- ANI is notified of Recovery classification.

f. Classification Downgrading: Constellation Nuclear policy is that emergency classifications shall not be downgraded to a lower classification. Once declared, the event shall remain in effect until no Classification is warranted or until such time as conditions warrant classification to Recovery.

g. Guidance for Termination of an Emergency: The purpose of terminating an emergency is to provide an orderly turnover of plant control from the Emergency Response Organizations to the normal plant organization. Termination of the emergency is authorized by the Emergency Director in Command and Control. The considerations provided in the Recovery/Termination Checklist in the emergency implementing procedures must be performed prior to exiting the emergency event. Consultation with governmental agencies and other parties should be conducted prior to termination of an event classified as Site Area or General Emergency. Notifications shall be transmitted to appropriate agencies to terminate an event.

h. Station Nuclear Security Plan: The station has a Security Plan that complies with the requirements of 10 CFR 73. The interface between the Emergency Plan and the Security Plan is one of parallel operation. The plans are compatible. The Emergency Plan response measures, once initiated, are executed in parallel with measures taken in accordance with the Security Plan.

Threats made to Crane Clean Energy Center are evaluated in accordance with established threat assessment procedures and the Security Plan. The Security Plan, Appendix C, Contingency Events, identifies situations that could be initiating conditions for EAL classifications. Contingency events include bomb threats, attack threats, civil disturbances, protected area intrusions, loss of guard/post contact, vital area intrusions, bomb devices discovered, loss of guard force, hostages, extortion, fire/explosions, internal disturbances, security communications failure, and obvious attempts of tampering. The Security Plan provides guidance for decisions and actions to be taken for each security contingency event. As guidance, the Security Plan allows for differing responses depending upon the assessment of the actual situation within each contingency event classification.

The assessment of any security contingency event and the decision to initiate, or not to implement the Emergency Plan, will be the responsibility of the Shift or Station Emergency Director. All identified security contingency events have the potential of being assessed as initiating conditions for a radiological emergency declaration.

Determination of a credible security threat may require the staffing of emergency response facilities based on the classification of an Unusual Event per the Emergency Action Levels (EALs).

2. Emergency Action Level Technical Bases

Addendum 3 to the Station Annex includes Site Specific Emergency Action Levels (EALs) consistent with the general class descriptions and provided in NEI guidance documentation in accordance with Regulatory Guide 1.101, "Emergency Planning and Preparedness for Nuclear Power Reactors." Where possible, these EALs will be related to plant instrumentation readings.

Emergency classifications are characterized by Emergency Action Levels (EALs). The Threshold Values are referenced whenever an Initiating Condition is reached. An Initiating Condition is one of a predetermined subset of unit conditions where either the potential exists for a radiological emergency, or such an emergency has occurred. Defined in this manner, an Initiating Condition is an emergency condition, which sets it apart from the broad class of conditions that may or may not have the potential to escalate into a radiological emergency. Initiating Conditions are arranged in one of the Recognition Categories.

EALs are for unplanned events. A planned evolution involves preplanning to address the limitations imposed by the condition, the performance of required surveillance testing, and the implementation of specific controls prior to knowingly entering the condition. Planned evolutions to test, manipulate, repair, perform maintenance or modifications to systems and equipment that result in an EAL Threshold Value being met or exceeded are not subject to classification and activation requirements as long as the evolution proceeds as planned. However, these conditions may be subject to the reporting requirements of 10 CFR 50.72.

An emergency is classified after assessing abnormal plant conditions and comparing them to EAL Threshold Values for the appropriate Initiating Conditions. Matrix tables organized by recognition categories are used to facilitate the comparison.

All recognition categories should be reviewed for applicability prior to classification. The initiating conditions are coded with a letter and/or number designator. All initiating conditions, which describe the severity of a common condition (series), have the same initial designator.

3. Timely Classification of Events

Classification of an emergency condition occurs within 15 minutes after the availability of indications from plant instrumentation, plant alarms, computer displays, or incoming verbal reports that an EAL has been exceeded and, is then promptly made upon identification of the appropriate EAL. The 15-minute period encompasses all assessment, classification, and declaration actions associated with making an emergency declaration from the first availability of a plant indication or receipt of a report up to and including the declaration of the emergency.

Validation or confirmation of plant indications or reports of the condition are to be accomplished within the 15-minute period as part of the assessment. Since this validation or confirmation is being performed to determine the validity of an alarm, indication, or report, the 15-minute period starts with the availability of the alarm, indication, or report to any qualified EAL assessor, and not the completion of the validation or confirmation, because the former is the time that the information was first available.

A qualified EAL assessor means any member of the plant staff who, by training and experience, is qualified to assess the indications or reports for validity and to compare the same to the EALs. A qualified EAL assessor may be, but need not be, a licensed operator or member of the ERO. Qualified EAL assessors may be in the MCR or in another facility where emergency declarations are performed. A qualified EAL assessor does not include personnel such as chemists, radiation protection technicians, craft personnel, security personnel, and others whose positions require they report, rather than assess, abnormal conditions to the MCR.

The 15-minute criterion ends as soon it is determined that an EAL has been exceeded and upon identification of the appropriate Emergency Classification Level (ECL) and when the Emergency Director makes the emergency declaration. The emergency condition should be declared as soon as possible following the identification of the appropriate ECL. As used here, "promptly" means the next available opportunity unimpeded by activities not related to the emergency declaration, unless such activities are necessary for protecting health and safety.

The 15-minute criterion is not to be construed as a grace period in which attempts to restore plant conditions are taken to avoid declaring an EAL that has already been exceeded. This statement does not preclude taking actions to correct or mitigate an off-normal condition, but once an EAL has been recognized as being exceeded, the emergency declaration shall be made promptly without waiting for the 15-minute period to elapse. The 15-minute criterion shall not prevent the implementation of response actions deemed necessary to protect public health and safety provided that any delay in the declaration would not deny the State and local authorities the opportunity to implement measures necessary to protect the public health and safety.

For EAL thresholds that specify duration of the condition, the emergency declaration process runs concurrently with the specified threshold duration. Once the condition has existed for the duration specified in the EAL or it is determined that the duration time will likely be exceeded, no further assessment is necessary—the EAL has been exceeded.

4. Offsite Classification Systems

Constellation Nuclear works with the state to ensure consistency between classification schemes. The content of the EALs is reviewed with the state and county authorities on an annual basis.

5. Offsite Emergency Procedures

Constellation Nuclear works with the state and county authorities to ensure that procedures are in place that provide for emergency actions to be taken which are consistent with the protective actions recommended by Constellation accounting for local offsite conditions that exist at the time of the emergency.

Section E: Notification Methods and Procedures

This section describes the notification of state and county response organizations and Constellation emergency response personnel. It outlines the content of initial and follow-up messages to response organizations within the Plume Exposure Pathway Emergency Planning Zone (EPZ).

1. Bases for Emergency Response Organization Notification

Constellation Nuclear, in cooperation with state and county authorities, has established mutually agreeable methods and procedures for notification of offsite response organizations consistent with the emergency classification and action level scheme. Notifications to offsite agencies include a means of verification or authentication such as the use of dedicated communications networks, verification code words, or providing call back verification phone numbers.

Notification for Transportation Accidents: A Transportation Accident is defined in 49 CFR 171.15 and 49 CFR 171.16. If a Transportation Accident involving material in the custody of an Constellation facility occurs, Constellation Nuclear will notify the appropriate internal and offsite agencies in accordance with the Constellation Nuclear Reportability Manual.

2. Notification and Mobilization of Emergency Response Personnel

Emergency implementing procedures are established for notification and mobilization of emergency response personnel as follows:

- a. Onsite: When an emergency is declared, reclassified, or terminated an announcement is made (over the plant public address system or by other means) that includes the emergency classification declared and response actions to be taken by site personnel.

At the Unusual Event classification, select ERO augmentation personnel are notified and requested to remain available to respond. At an Alert classification or higher ERO augmentation personnel are notified for activation of the TSC, OSC, EOF, and JIC using the ERO Notification System.

- b. Offsite: Notifications are promptly made to offsite emergency response organizations as follows:

- 1) State/Local Agencies: A notification shall be made within fifteen (15) minutes of:

- The initial emergency classification.
- Classification escalation.
- The issuance of or change to a Protective Action Recommendation (PAR) for the general public.

- Changes in radiological release status, occurring outside of an event classification or PAR notification, based on an agreement with the state(s).

The emergency warning points are simultaneously notified using the Nuclear Accident Reporting System (NARS), or a commercial telephone line as backup.

A notification will also be initiated to cognizant state/local government agencies as soon as possible but within one hour of the termination of an event classification, or entry into Recovery Phase.

2) Nuclear Regulatory Commission (NRC): An event will be reported to the NRC Operations Center immediately after notification of the appropriate state or local agencies but not later than one (1) hour after the time of initial classification, escalation, termination or entry into the Recovery Phase. The NRC is notified by a dedicated telephone system called the Emergency Notification System (ENS). If the ENS is inoperative, the required notification is made via commercial telephone service, other dedicated telephone service, or any other method that shall ensure that a report is made as soon as practical. An NRC Event Notification Worksheet should be utilized to transmit initial information to the NRC. If a continuous communication is requested and established, a log is used in lieu of the ENS Worksheet.

Specific requirements for the notifications to the NRC for classified emergency events are detailed in 10 CFR 50.72 with guidance provided in the Constellation Reportability Manual.

Mobilization of federal, state, and county response organizations is performed in accordance with their applicable emergency plan and procedures. At a minimum, mobilization of federal response organizations and activation of state and county EOCs is expected to occur at the declaration of a Site Area Emergency.

The state and county authorities are responsible for the process of notification of the general public.

c. Support Organizations: When an emergency is initially classified, escalated or terminated, notifications are promptly made to the following support organizations:

- Medical, rescue, and firefighting support services are notified for assistance as the situation dictates.
- The American Nuclear Insurers (ANI) are notified at an Alert or higher classification with requests for assistance as necessary.
- Vendor and contractor support services are notified for assistance as the situation dictates.

3. Initial Notification Messages

Constellation Nuclear, in conjunction with state and county authorities, has established the contents of the initial notification message form transmitted during a classified emergency. The contents of the form include, as a minimum:

- Designation ("This is a Drill" or "Actual Event").
- Identity of site.
- Event classification.
- EAL number (as agreed upon with state authorities).
- Non-technical event description (as agreed upon with state authorities).
- Date and time of declaration (or entry into Recovery or Termination).
- Whether a release is taking place (Note: "Release" means a radiological release attributable to the emergency event.)
- Wind direction and speed.
- Whether offsite protective measures may be necessary.
- Potentially affected Subareas (or Sectors as applicable) when a General Emergency is declared.

Notification approval, transmittal date and time, and offsite agencies contacted are recorded either on the notification form or in an event logbook.

4. Follow-up Messages

For all emergency classifications, update messages to state authorities will be provided at the time of the notification on a prearranged frequency. The facility in Command and Control is responsible for ensuring that the updates are completed. State updates contain the prearranged information plus any additional information requested at the time of the notification.

Follow-up notifications are provided to the NRC Operations Center as soon as possible, but not later than one (1) hour after significant new information is available involving:

- a. The results of evaluations or assessments of plant conditions.
- b. The effectiveness of response or protective measures taken.
- c. Information related to plant behavior that is not understood.

If requested by the NRC, an open, continuous communications channel will be maintained with the NRC Operations Center over the Emergency Notification System (ENS) and/or Health Physics Network (HPN) Circuits.

5. State and County Information Dissemination

The state and county emergency response plans describe procedures for state and county officials to make a public notification decision promptly (within about 15 minutes) on being informed by the plant of an emergency. The system for disseminating information to the public includes notification by pre-scripted messages through appropriate broadcast media such as the Emergency Alert System (EAS).

6. Notification of the Public

The capability exists for the prompt notification of the general public within the Plume Exposure Pathway Emergency Planning Zone (EPZ) for CRANE.

The Alert and Notification System (ANS) for Crane relies on the Integrated Public Alert Warning System (IPAWS)-WEA (Wireless Emergency Alerts) and IPAWS-EAS (Emergency Alert System) as the primary means of alerting and notifying the public, respectively, and an independent electronic Mass Notification System (MNS) as the backup means.

The Integrated Public Alert Warning System (IPAWS) is operated by local governmental agencies and maintained by FEMA. A more specific description of the various prompt public notification systems is presented in the FEMA ANS Design Report for Crane.

7. Messages to the Public

The respective States have developed EAS messages for the public consistent with the classification scheme. These draft messages are included as part of the States' Emergency Plan and contain instructions with regard to specific protective actions to be taken by occupants and visitors of affected areas. Messages may include instructions such as: take shelter and go indoors, close windows and doors, turn off ventilation systems; directions given for evacuation; directions to stay tuned to specific stations for further information, ad-hoc respiratory protection, (e.g. handkerchief over mouth, etc.). Constellation will provide support for the content of these messages when requested. The States control the distribution of radioprotective drugs to the general public.

Section F: Emergency Communications

This section describes the provisions utilized for prompt communications among principal emergency response organizations, communications with the ERO and communications with the general public.

1. Communications/Notifications

Constellation Nuclear has extensive and reliable communication systems installed at CRANE and Corporate Headquarters. Examples of the communications network include systems such as normal and dedicated telephone lines on landlines, and fiber-optic voice channels, cell phones, satellite phones, mobile radio units, handi-talkies and computer peripherals. This network provides:

- Voice communication through normal telephone, dedicated lines, conference call capability, speaker phones, and operator assistance where required.
- Communications between selected Constellation vehicles and appropriate fixed locations, as well as with state mobile units and fixed locations.
- Facsimile, network, and modem transmission.

Figure F-1 depicts the initial notification paths and the organizational titles from the Constellation Nuclear Emergency Response Facilities (ERFs) to federal, state and local emergency response organizations, and industry support agencies. The Constellation primary and alternate methods of communication, and the NRC communications network, are illustrated on Figures F-2 and F-3.

- a. Constellation Nuclear maintains the capability to make initial notifications to the designated offsite agencies on a 24-hour per day basis. The offsite notification system, referred to as the Nuclear Accident Reporting System (NARS) provides communications to state and county warning points and Emergency Operations Centers from the CR, TSC, and EOF. Backup methods include facsimile and commercial telephone lines. state and county warning points are continuously staffed. The Emergency Offsite Notification System (EONS) supports the notification of State/local agencies.
- b-d. Constellation Nuclear has established several dedicated communication systems that ensure reliable and timely exchange of information necessary to provide effective Command and Control over any emergency response; (1) between Constellation and state and local agencies within the EPZs, (2) with federal emergency response organizations, (3) between the plant, the EOF, and the state and county EOCs, and (4) between Emergency Response Facilities and Field Monitoring Teams. A general description of the systems is as follows:

- 1) Nuclear Accident Reporting System (NARS): The NARS is a dedicated communications system that has been installed for the purpose of notifying state and local authorities of declared nuclear emergencies. This system links together the station Control Rooms, the EOF, TSCs and state and local authorities as appropriate. The specific design, operation, and responsibility for maintenance of the NARS systems vary between Constellation Nuclear regions.
- 2) Operations Status Line: A vendor-hosted conference bridge called the Operations Status Line that enables communication between the Control Room, the TSC, OSC and the EOF to monitor the activities throughout the Emergency Response Facilities (see Figure F-2). The Operations Status line consists of a Voice Over Internet Protocol (VoIP) system.
- 3) Director's Hotline: A vendor-hosted conference bridge called the Director's Hotline that enables direct Emergency Director communication between the Control Room, TSC, and the EOF (see Figure F-2).
- 4) Local Commercial Telephone System: This system provides standard commercial telephone service through the public infrastructure, consisting of central offices and the wire line.
- 5) Emergency Response Data System (ERDS): ERDS will continuously supply the NRC with selected plant data points on a near real time basis. The selected data points are transmitted automatically to the NRC at approximately 1-minute intervals.
- 6) Field Monitoring Team (FMT) Communications: A separate communications system has been installed to allow coordinated environmental monitoring and assessment during an emergency. This system consists of the necessary hardware to allow communication via Satellite phones, TSC, EOF, and mobile units in Constellation Nuclear vehicles. Commercial cell phones are available as back up to the primary field team communications system.
- 7) Electronic Offsite Notification System (EONS): EONS is a system of software and hardware components that supports off-site State & Local notifications via an electronic transfer of data between Constellation Emergency Response Facilities and offsite agencies.

In addition, station communication links exist to ensure appropriate information transfer capabilities during an emergency. The station may also utilize its Public Address System, station radios and notification devices to augment its emergency communications.

- e. **ERO Notification System:** Constellation Nuclear utilizes an automated ERO Notification System to rapidly notify members of the ERO. The system consists of a network of physical infrastructure capable of initiating and receiving contact via multiple notification devices. When activated, the system contacts the notification devices (e.g., through commercial and cellular phone, email, text message) belonging to members of the ERO. The System includes redundant activation methods via the internet as well as redundant, geographically separated call centers and data centers, with redundant power sources. Implementing procedures specify the course of action to be taken if the primary ERO Notification System activation path fails to respond. The ERO Notification System provides primary and back-up notification functions.
- f. **NRC Communications (ENS and HPN)**
Communications with the NRC Operations Center will be performed via the ENS and HPN circuits or commercial telephone line. Information is normally communicated from an approved NRC Event Notification Worksheet prior to establishing an open ENS and/or HPN line.

Installation and use of these NRC telephones is under the direction of the NRC (see Figure F-3).

Emergency Notification System (ENS): Dedicated telephone equipment is in place between the Control Room and the NRC, with an extension of that line in the TSC. A separate line is available in the EOF with the capability of being patched with the station through the NRC. This line is used for NRC event notifications and status updates.

Health Physics Network (HPN): There also exists a separate dedicated telephone between the NRC, the TSC, and EOF for conveying health physics information to the NRC as requested or as an open line.

2. Medical Communications

Communications are established with the primary and backup medical hospitals and transportation services via commercial telephone that is accessed by station personnel.

3. Communications Testing

Communications equipment is checked in accordance with Section H.10. Communications drills between Constellation Nuclear and state and county government facilities are conducted in accordance with Section N.2.a. In addition, minimum ANS testing is performed in accordance with the site-specific ANS Design Report.



Figure F-1: Constellation Notification Scheme (For Full Augmentation)


Figure F-2: ERF Communications Matrix



A = Operational Status Line between the OSC, TSC, EOF, and Control Room.

B = Directors Hotline line between the Control Room, TSC and EOF.

E = Station telephone line.

Figure F-3: NRC Communications for Nuclear Response

NOTE: ENS circuits may use the Federally maintained system, company tie lines or PBX as dedicated primary communications systems and have commercial backups.

Section G: Public Education and Information

This section describes the Constellation Nuclear public education and information program. It outlines the methods for distributing public information materials on an annual basis and describes how the public is informed in the event of an emergency.

1. Public Information Publication

The state has overall responsibility for maintaining a continuing disaster preparedness public education program. The emergency public information publication for the Constellation Nuclear generating stations is updated annually, in coordination with state and county agencies, to address how the general public is notified and what their actions should be in an emergency. Constellation distributes the publication, or internet links to the publication on an annual basis by mail to all residents within the ten-mile plume exposure EPZs and to appropriate locations where a transient population may obtain a copy. The public information publication includes the following information:

- a. Educational information on radiation.
- b. A description of the times that require public notification (what to do if a take-shelter or evacuate recommendation is given).
- c. A map of major evacuation routes.
- d. A list of communities likely to serve as host shelter areas and instructions on how to obtain additional information, especially for the disabled or their caretakers and those without transportation.

2. Public Education Materials

Public information publications instruct the public to follow the IPAWS-WEA messages which will provide information and instructions related to the emergency.

3. Media Accommodations

- a. The Constellation Communications and Public Affairs Department is notified when an Unusual Event or higher Emergency condition exists. They will handle public and media inquiries in the early stages of the event (until the JIC is activated) by distributing background information, news releases, and providing information to corporate management.
 - 1) The Emergency Public Information Organization: The Emergency Public Information Organization is part of the Corporate ERO. It may be activated at any time at the discretion of the Nuclear Duty Officer. However, when there is a procedural requirement to activate the EOF, the Emergency Public Information Organization shall also be activated.

The primary purpose of the Emergency Public Information Organization is to disseminate information from Constellation Nuclear's ERO about the emergency events to the public, via the news media. However, the authority for issuance of news releases for the classification of an Unusual Event or prior to ERO activation will always reside with the Constellation Communications and Public Affairs Department. Upon activation, the Emergency Public Information Organization has the responsibility and authority for issuance of news releases to the public.

The Emergency Public Information Organization is comprised of senior managers from Constellation Nuclear who will function as spokespersons, and other Constellation Nuclear individuals including personnel from the Governmental Affairs and Human Relations areas. Constellation Nuclear's spokespersons disseminate information to the news media/public concerning the emergency events out of a Joint Information Center (JIC).

- 2) The Joint Information Center (JIC): The JIC is the facility in which media personnel gather to receive information related to the emergency event. The JIC is the location where approved news releases will be provided to the media for dissemination to the public. News releases are coordinated between the EOF and JIC personnel and state and/or Federal representatives in the JIC. Constellation public information personnel operate from the EOF and the JIC, which is under the direction of the Corporate Spokesperson and functions as the single point contact to interface with Federal, state, and local authorities who are responsible for disseminating information to the public.

Each station has a designated JIC. Each JIC is equipped with appropriate seating, lighting and visual aids to allow for public announcements and briefings to be given to the news media. Additionally, JICs are equipped with commercial telephone lines for making outgoing calls. The Emergency Public Information Organization functions from the JIC and EOF in preparing and releasing utility information about the emergency event. The JIC is activated at the declaration of an Alert or higher classification. Some JIC personnel may perform functions remotely from alternate locations while remaining in contact with personnel in the JIC facility (e.g., media monitoring, rumor control, news writers, issuance of press releases). The JIC Director and Corporate Spokesperson will ensure communication and coordination of these functions with the EOF and JIC staff. Functions of the JIC include:

- Serving as the primary location for accumulating accurate and current information regarding the emergency conditions and writing news releases.
- Providing work space and phones for public information personnel from the state, counties, NRC, FEMA, and industry-related organizations.
- Providing telephones for use by the news media personnel.

- Providing responses to media inquiries through telephones that the media can call for information about an emergency.
- b. The news media is not permitted into the EOF during an emergency.

4. Coordination of Public Information

- a. The JIC is staffed by Constellation and government public information representatives who will be the source of public information during an emergency at the station. The Corporate Spokesperson is the primary spokesperson for Constellation Nuclear. The Corporate Spokesperson has direct access to all necessary information (see Section B.5).
- b. The JIC is staffed by federal, state, county, and utility personnel to assure timely, periodic exchange and coordination of information. Representatives coordinate information prior to conducting news briefings.
- c. Rumors or misinformation are identified during an emergency by the JIC Staff. They respond to public and news media calls and monitor media reports.
- d. The JIC for the MA Region Stations is co-located with the EOF at 175 North Caln Road, Coatesville, Pennsylvania.

5. Media Orientation

Emergency Preparedness, in conjunction with Constellation Communications and Public Affairs Department, offers training (at least annually) to acquaint news media with the Emergency Plan, information concerning radiation, and points of contact for release of public information in an emergency. Training is provided for those media agencies that accept the training offer.

Section H: Emergency Facilities and Equipment

Onsite and offsite facilities are available for emergency assessment, communications, first aid and medical care, and damage control. Of particular importance are the Emergency Response Facilities (ERFs); the Control Room (CR), the Technical Support Center (TSC), the Operations Support Center (OSC), the Emergency Operations Facility (EOF), and the Joint Information Center (JIC).

This section describes the emergency facilities and equipment used by the Emergency Response Organization and outlines the requirements which aid in timely and accurate response actions. It also describes the surveillance programs used to monitor and ensure that these facilities and equipment are maintained in a high degree of constant readiness.

1. Control Room, Technical Support Center, and Operations Support Center

Crane has established a TSC and an on-site OSC, which are activated upon declaration of an Alert or higher classification. Until they become operational, required functions of these facilities are performed in the Control Room.

Under certain adverse conditions for Security-Based Events, personnel may be assembled in an "ERO Alternative Facility" prior to being dispatched to one of the facility ERFs.

a. Station Control Room: The Control Room is the centralized onsite location from which the Nuclear Station's plant systems necessary to support the spent fuel pool are operated. The Control Room is equipped with instrumentation to supply detailed information on the plant systems. The Control Room is continuously staffed with qualified operators. The Control Room is the first onsite facility to become involved with the response to emergency events. Control Room personnel must evaluate and effect control over the emergency and initiate activities necessary for coping with the emergency until such time that support centers can be activated. These activities shall include:

- Plant control.
- Initial direction of all plant related operations.
- Accident recognition, classification, mitigation and initial corrective actions.
- Alerting of onsite personnel.
- Notification of appropriate individuals.
- Activation of emergency response facilities and ERO notification.
- Notification of offsite agencies.
- Continuous evaluation of the magnitude and potential consequences of an incident.

- Initial dose projections.
- Recommendations for immediate protective actions for the public.

As other ERFs become activated, they will supply support to the Control Room, although overall Command and Control of the emergency will transfer to the SED (TSC) or the CED (EOF). Throughout all emergencies, the Control Room maintains its emergency activation status until its normal operational status may be resumed.

b. Technical Support Center (TSC): CRANE has established a TSC for use during emergency situations by station management, technical, and engineering support personnel. The TSC is activated for all emergencies classified as Alert or higher. Activation for other events is optional. When activated the TSC functions include:

- Support for the Control Room's emergency response efforts.
- Support the SED with assigned Command & Control functions.
- Continued evaluation of event classification.
- Assessment of the plant status and potential offsite impact.
- Coordination of emergency response actions.
- Notification of appropriate corporate and station management.
- Notification and update of the NRC via Emergency Notification System (ENS).

The TSC is the onsite location utilized to support the Control Room for assessment of plant status and potential offsite impact, and for implementation of emergency actions. TSC provides technical data and information to the EOF.

Figure CRANE B-1b illustrates the staffing and organization of the TSC.

The TSC provides reliable voice communications to the Control Room, the OSC, the EOF, the NRC, and state and local Emergency Operations Centers. In addition, it provides facsimile transmissions capability (see Section F.1).

The TSC is sized to accommodate a minimum of 25 spaces and supporting equipment. This includes provisions for five NRC representatives. Adequate space is also available for the appropriate state representative(s).

Personnel in the TSC shall be protected from radiological hazards, including direct radiation and airborne contaminants under accident conditions with similar radiological habitability as Control Room personnel. To ensure adequate radiological protection, permanent radiation monitoring systems have been installed in the TSC and/or periodic radiation surveys are conducted. These systems indicate radiation dose rates and airborne radioactivity inside the TSC while in use. In addition, protective breathing apparatus (full-face air purifying respirators) and KI are available for use as required.

The TSC has access to a complete set of as-built drawings and other records, including general arrangement diagrams, P&IDs, and the electrical schematics. The TSC has the capability to record and display vital plant data, in real time, to be used by knowledgeable individuals responsible for engineering and management support of operations, and for implementation of emergency procedures.

c. Operations Support Center (OSC): CRANE has established an OSC. The OSC is the onsite location to where station support personnel report during an emergency and from which they will be dispatched for assignments or duties in support of emergency operations. The OSC shall be activated whenever the TSC is activated, but need not remain activated at the Alert level if its use is judged unnecessary by the Station Emergency Director. At the Site Area and General Emergency levels, the OSC or an alternate OSC shall be activated at all times. The OSC is not activated for a HOSTILE ACTION when the Alternative Facility is implemented. Activation for other events is optional. Station disciplines that may be called in to support the OSC include, but are not limited to:

- Operating personnel not assigned to the Control Room,
- Radiation Protection Personnel,
- Chemistry Personnel,
- Maintenance Personnel (mechanical, electrical and I&C).

Figure CRANE B-1b illustrates the staffing and organization for the OSC.

Each OSC is equipped with communication links to the Control Room, the TSC and the EOF (see Section F). A limited inventory of supplies will be kept for the OSC. This inventory will include respirators, protective clothing, flashlights and portable survey instruments.

2. Emergency Operations Facility (EOF)

The EOF is the location where the Corporate Emergency Director will direct a staff in evaluating and coordinating the overall company activities involved with an emergency. Activation of the EOF is mandatory within 60 minutes of declaration of an Alert or higher classification. The EOF provides for:

- Management of overall emergency response.

- Coordination of radiological and environmental assessments.
- Determination of recommended public protective actions.
- Management of recovery operations.
- Coordination of emergency response activities with federal, state, and local agencies.

The common MA Region EOF is located west of Philadelphia, in Coatesville PA. This facility supports Limerick, Peach Bottom, Calvert Cliffs and Crane energy centers.

The facility is designed with the following considerations:

- The location provides optimum functional and availability characteristics for carrying out overall strategic direction of Constellation Nuclear onsite and support operations, determination of public protective actions to be recommended to offsite officials, and coordination with Federal, state and local organizations.
- It is well engineered for the design life of the plant and is of sufficient size to accommodate about 50 people.
- It is equipped with reliable voice communications capabilities to the TSC, the OSC, the Control Room, NRC, and state and local emergency operations centers. In addition, the EOF has facsimile transmission capability.
- Equipment is provided to gather, store, and display data needed in the EOF to analyze and exchange information on plant conditions with the Station. The EOF technical data system receives, stores, processes, and displays information sufficient to perform assessments of the actual and potential onsite and offsite environmental consequences of an emergency condition.
- The EOF has ready access to plant records, procedures, and emergency plans needed for effective overall management of Constellation Nuclear emergency response resources.

3. Emergency Operations Centers

EOCs operated by the state and local communities have been established to perform direction and control of emergency response functions.

The Pennsylvania state EOC is capable of continuous (24-hour) operations for a protracted period. The center contains sufficient communications (radio, telephone and teletype) equipment, maps, emergency plans, and status boards to provide the necessary interfaces with other federal, state, county, and Constellation emergency facilities.

The county EOCs serve as Command and Control headquarters for local emergency response activities as well as a center for the coordination of communications to field units and to the state EOC. The EOC has the equipment necessary, (such as facsimile machines, telecommunications equipment, radio gear, photocopiers, wall maps, etc.) to carry out their emergency responsibilities.

4. Activation

NOTE: NUREG-0654 Criterion II.B.5 states that the "licensee must be able to augment on-shift capabilities within a short period after declaration of an emergency". It further defines that short period as 30 and 60 minutes. The time frames for rapid augmentation of a nuclear power plant staff in the event of an emergency are not rigid inviolate requirements but rather goals. It is Constellation Nuclear's intent to expend its best efforts to meet the augmentation criteria goals regarding staffing Emergency Response Facilities with sufficiently skilled individuals capable of handling an emergency. Both the NRC and Constellation Nuclear realize that due to diversity of normal residential patterns for the stations' staff, possible adverse weather conditions, road congestion and site access restrictions, these time frames might be exceeded.

Constellation Nuclear has put into place plans and procedures to ensure timely activation of its emergency response facilities. The Shift Manager (as Shift Emergency Director) will initiate a call-out in accordance with the implementing procedures. The ERO augmentation process identifies individuals who are capable of fulfilling the specific response functions that are listed in ERO staffing tables contained within this Emergency Plan.

Although the response time will vary due to factors such as weather and traffic conditions, a goal of 60 minutes for minimum staffing, following the declaration of an Alert or higher emergency classification, has been established for the ERO personnel responding to the station emergency facilities and the EOF. Additionally, plans have been developed to ensure timely functional activation and staffing of the JIC within 90 minutes of when the classification of Alert or higher is declared.

It is the goal of the organization to be capable of activating the applicable Emergency Response Facility upon achieving minimum staffing. The facility can be declared activated when the following conditions are met:

- a. Minimum staffing has been achieved.
- b. The facility is functional.

The Director in charge may elect to activate their facility without meeting minimum staffing; if it has been determined that sufficient personnel are available to fully respond to the specific event (this would not constitute a successful minimum staff response).

5. Monitoring Equipment Onsite

CRANE is equipped with instrumentation for seismic monitoring, radiation monitoring, fire protection and meteorological monitoring. Instrumentation for the detection or analysis of emergency conditions is maintained in accordance with station Technical Specifications, if applicable, or commitments made to the NRC. Descriptions of the equipment will appear in the Station Annex. This equipment includes but is not limited to the following:

a. Geophysical Monitors

- 1) **Meteorological Instrumentation**: A permanent meteorological monitoring station is located near each station for display and recording of wind speed, wind direction, and ambient and differential temperature for use in making offsite dose projections. Meteorological information is presented in the CR, TSC, and EOF by means of the plant computer system.

With regard to Constellation Nuclear's meteorological monitoring program, there has been a quality assurance program adopted from 10 CFR 50, Appendix B. However, since the meteorological facilities are not composed of structures, systems, and components that prevent or mitigate the consequences of postulated accidents and are not "safety related," not all aspects of 10 CFR 50, Appendix B, apply. Those aspects of quality assurance germane to supplying good meteorological information for a nuclear power station were adopted into the meteorological quality assurance program. The meteorological program is also subject to the requirements of the Restoration Quality Assurance Program.

The National Weather Service (NWS), or regional weather forecast providers, may be contacted during severe weather periods. These providers analyze national and local weather in order to provide localized weather forecasts for the system or for the station area as appropriate.

- 2) **Seismic Monitoring**: The seismic monitoring system measures and records the acceleration (earthquake ground motion) of the structure. Earthquakes produce low frequency accelerations which, when detected by the remote sensing devices, are permanently recorded as information which defines the response spectrum. The system remains in a standby condition until an earthquake causes the remote unit(s) to activate the recording circuits and tape transports. It also provides signals for immediate remote indication that specific preset response accelerations have been exceeded.
- 3) **Hydrological Monitors**: The design basis flood, probable maximum precipitation, and other improbable, conceivable extremes in hydrologic natural phenomena are well below any design limits for the station as detailed in the UFSAR.

b. Radiological Monitors and Sampling

- 1) **The Radiation Monitoring System (RMS):** In-plant radiological measurements provide information that may help determine the nature, extent and source of emergency conditions. The RMS is available to give early warning of a possible emergency and provides for a continuing evaluation of the situation in the Control Room. Radiation monitoring instruments are located at selected areas within the facility to detect, measure, and record radiation levels. In the event the radiation level should increase above a preset level, an alarm is initiated in the Control Room. Certain radiation monitoring instruments also alarm locally in selected areas of the facility. The RMS is divided into 3 subsystems:
 - a) Area Radiation Monitors (ARMs) are used for the direct measurement of in-plant exposure rates. The ARM readings allow in-plant exposure rate determinations to be made remotely without requiring local hand-held meter surveys. This information may be used, initially, to aid in the determination of plant area accessibility. In addition to permanent monitors, portable Continuous Air Monitors (CAMs) measure airborne particulate and airborne iodine activities at various locations within the operating areas.
 - b) Process Radiation Monitors (PRMs) are used for the measurement of radioactive noble gas, iodine, and particulate concentrations in plant effluent and other gaseous and fluid streams.
 - c) The accident, or high range, radiation monitoring system monitors radiation levels at various locations within the operating area. These are high range instruments used to track radiation levels under accident or post-accident conditions.

The RMS provides the necessary activity or radiation levels required for determining source terms in dose projection procedures. Key RMS data is linked to the plant computer, which allows information to be passed to the TSC and EOF. The isotopic mix, including isotopes such as those in Table 3 of NUREG-0654, is based upon a default accident mix. Refer to the UFSAR for further detail on the RMS capabilities and design.

- 2) **Liquid and Gaseous Sampling Systems:** The process sampling system consists of the normal sampling system and additional sampling panels located throughout the plant. Sampling systems are installed or can be modified to permit sampling even under severe accident conditions.

The sampling systems use a number of manual sampling techniques to enable sampling operations over a wide range of plant conditions. It is capable of providing information relative to post-accident plant conditions to allow operator actions to be taken to mitigate and control the course of an accident. Refer to the UFSAR for further detail on sampling capabilities.

3) Portable Radiation Monitoring Equipment: Portable radiation survey instruments are available for a wide variety uses such as area, sample, and personnel surveys and continued accident assessment. Instruments are stored throughout the plant and in the emergency facilities.

c. Process Monitors: The Control Room and applicable redundant backup locations are equipped with extensive plant process monitors for use in both normal and emergency conditions. These indications include but are not limited to liquid levels, flow rates, status or lineup of equipment components. This instrumentation provides the basis for initiation of corrective actions.

1) Plant Monitoring/Information System: A plant monitoring/information system provides the data acquisition and database capability for performing plant monitoring and functions. The system is designed to scan, convert to engineering units, make reasonability and alarm limit checks, apply required transformations, store for recall and analysis, and display the reading of transformed data from plant instrumentation. The system scans flows, pressures, temperatures, fluid levels, radiation levels, equipment, and valve status at required frequencies. Scanned variables are quality tagged. The system provides for short and mid-term storage of data for on-line retrieval and fast recall, and long term storage to appropriate media.

2) Safety Parameter Display (SPDS) & Plant Parameter Display (PPDS) Systems: SPDS and PPDS provide a display of plant parameters from which the safety status of operation may be assessed in the Control Room, TSC and EOF. The primary function of the SPDS and PPDS is to help operating personnel in the Control Room make quick assessments of plant safety status. SPDS and/or PPDS displays in the TSC and EOF promote the exchange of information between these facilities and the Control Room and assists the emergency organization in the decision making process.

d. Fire Detection System: The Fire Detection System is designed to quickly detect visible or invisible smoke (or other products of combustion) and/or heat in designated areas of the plant. The fire alarm communication systems and subsystems are located at strategic points throughout the plant to warn personnel of a nuclear incident or other emergency conditions. Existing plant alarm systems are sufficiently audible to alert personnel in the event of a fire or need for assembly. These alarm communication systems consist of warning sirens and lights (in high noise areas) and the PA system. Refer to the Fire Hazards Analysis for further description of the station's fire protection system.

6. Monitoring Equipment Offsite

Constellation has made provisions to acquire data from and have access to the following offsite sources of monitoring and analysis equipment:

- a. Geophysical Monitors: In the event that the onsite meteorological tower or monitoring instrumentation becomes inoperative and the contracted weather provider cannot be contacted, meteorological data may be obtained directly from the National Weather Service or the internet.

A considerable array of seismometers are located in the region. A central point of contact to obtain information about a seismic event is the National Earthquake Information Service in Golden, Colorado.

Constellation Nuclear Corporate Offices can coordinate hydrology and seismology expertise in the event onsite information becomes unavailable.

- b. Radiological Environmental Monitors and Sampling: Constellation Nuclear has contracted with a company to conduct an extensive offsite environmental monitoring program to provide data on measurable levels of radiation and radioactive materials in the environs. The program (described fully in the Offsite Dose Calculation Manual), includes:

- Fixed continuous air samplers.
- Routine sampling of river water; milk and fish.
- A fixed dosimeter monitoring network.

The dosimeter program consists of the following elements:

- A near-site ring of dosimeters covering the 16 meteorological sectors.
- A 16-sector ring of dosimeters placed in a zone within about 5 miles from the plant.
- Dosimeters placed at each of the normal fixed air sampler locations (typically about 8-15 air samplers per nuclear station).

- c. Laboratory Facilities: External facilities for counting and analyzing samples can be provided by the other Constellation Nuclear stations, state, federal or contracted laboratories. These laboratories can act as backup facilities in the event that the affected station's counting room and laboratory become unusable or the offsite radiological monitoring and environmental sampling operation exceeds the capacity or capability of the station laboratory during an emergency. It is estimated that these laboratories will be able to respond within several hours from initial notification.

Outside analytical assistance may be requested from state and federal agencies, or through contracted vendors. The state maintains a mobile radiological laboratory that provides the primary means of analyzing off-site environmental samples. The NRC mobile laboratory may be made available for Site Area and General Emergencies. The DOE, through the Radiological Assistance Program (RAP) has access to any national laboratory with a Bell Lab contract (e.g., Brookhaven, Oak Ridge, Lawrence Livermore, etc.).

A general description of the laboratory capabilities is provided in Section C.3.

7. Offsite Monitoring Equipment Storage

CRANE maintains a sufficient supply of emergency equipment (such as portable survey, counting, and air sampling instrumentation and other radiological monitoring equipment and supplies) that may be used for environmental monitoring. These supplies meet the initial requirements of two environmental Field Monitoring Teams. During subsequent phases of an emergency, additional equipment is available from other Constellation Nuclear generating stations, vendors and offsite response organizations.

8. Meteorological Monitoring

The station has installed and maintains a meteorological tower equipped with instrumentation for continuous reading of the wind speed, wind direction, air temperature and delta air temperature. Additional capabilities are available to obtain representative current meteorological information from other sources, such as the National Weather Service. A full description of the onsite meteorological capabilities is given in Section H.5.a of this Plan.

9. OSC Capabilities

The OSC provides area for coordinating and planning of OSC activities and the staging of personnel. Further space is available in adjacent offices and locker rooms to accommodate additional personnel as may be required. Alternate locations are available. The onsite storeroom maintains a supply of parts and equipment for normal plant maintenance. These parts, supplies and equipment are available for damage control use as necessary.

Sufficient radiation protection equipment (i.e., protective clothing, respiratory protection gear, KI, and other health physics equipment and supplies) is stored and maintained near the OSC (as well as the other emergency response facilities). Damage Control Team equipment is available near the OSC as well as in the maintenance shops. This equipment includes items such as, portable lighting, and additional portable communications equipment. The OSC is stocked with an assortment of first aid and medical treatment equipment and supplies. The OSC maintains reliable voice communications with the CR, TSC, and EOF. For a complete description of communications equipment, refer to Section F. When an emergency condition exists at one station, additional supplies can be obtained from other unaffected stations and Constellation resources upon request.

10. Facility and Equipment Readiness

Emergency facilities and equipment are inspected and inventoried in accordance with emergency preparedness procedures. These procedures provide information on location and availability of emergency equipment and supplies. An inventory of all emergency equipment and supplies is performed on a quarterly basis and after each use in an emergency or drill. During this inventory, radiation monitoring equipment is checked to verify that required calibration period and location are in accordance with the inventory lists. Inspections include an operational check of instruments and equipment. Equipment, supplies, and parts which have a shelf-life are identified, checked, and replaced as necessary. Sufficient reserves of instruments and equipment are maintained to replace those which are removed from emergency kits or lockers for calibration or repair. The station is responsible for maintaining a supply of KI at the site.

11. General Use Emergency Equipment

Inventory procedures identify the equipment that makes up kits used in an emergency situation available within each emergency facility.

12. Collection Point for Field Samples

The onsite chemistry lab has been designated as the central point for the receipt of radiological field monitoring samples. Sampling and analysis equipment is available for quantitative activity determination of marine and air samples, and qualitative activity determination of terrestrial samples. Sufficient field monitoring equipment is maintained at the station for initial sampling. Instrumentation and equipment utilized for sample activity determination are routinely calibrated to ensure timely availability. Additional facilities as described in C.3 and H.6.c are available for sample and analysis of environmental samples.

Refer to the Station Annex for further description of contracted environmental sampling and analysis support for the site.

Section I: Accident Assessment

To effectively coordinate and direct all facets of the response to an emergency situation, diligent accident assessment efforts are required throughout the emergency. All four emergency classifications have similar assessment methods, however, each classification requires a greater magnitude of assessment effort dependent upon the plant symptoms and/or initiating event(s).

1. Plant Parameters and Corresponding Emergency Classification

Plant system and effluent parameter values are utilized in the determination of accident severity and subsequent emergency classification. Environmental and meteorological events are also determining factors in emergency classification. An emergency condition can be the result of just one parameter or condition change, or the combination of several. The specific symptoms, parameter values or events for each level of emergency classification are detailed in the emergency implementing procedures. Specific plant system and effluent parameters that characterize a classifiable event (EALs) are presented in Addendum 3 to each Station Annex.

In order to adequately assess the emergency condition, each emergency facility has the necessary equipment and instrumentation installed to make available essential plant information on a continuous basis. Evaluation of plant conditions is accomplished through the monitoring of plant parameters both from indication in the Control Room and within the plant. Some of the more important plant parameters to be monitored in the Control Room are assembled into a single display location, which is entitled the "Safety Parameter Display System" (SPDS). The SPDS monitors such parameters as: safety system status and effluent monitor readings. The instrumentation and equipment capabilities available for each emergency facility are described in Section H.

2. Onsite Accident Assessment Capabilities

The resources available to provide initial and continuing information for accident assessment throughout the course of an event include plant parameter display systems, liquid and gaseous sampling system, Area and Process Radiation Monitoring Systems, and Accident Radiation Monitoring Systems. Descriptions of these systems are given in Section H.5.b.

3. Source Term Determination

Source term (or fuel damage) estimations serve several roles within the Constellation Emergency Preparedness Program. For planning purposes, fuel damage considerations are used as the bases for several of the Emergency Action Level (EAL) Initiating Conditions and as the threshold for the declaration of a General Emergency (the definition of a General Emergency specifies conditions which involve 'substantial' fuel degradation or melting as one of the bases for classification).

From an implementation perspective, fuel damage estimations provide a means of realistically differentiating between no damage, clad failure, and fuel melt to:

- Evaluate the status of the fuel clad and how their status relates to the risks and possible consequences of the accident.

- Provide input on fuel configuration (coolable or uncoolable) for prioritization of mitigating activities.
- Determine the potential quality (type) and/or quantity (%) of source term available for release in support of projected offsite doses and protective action recommendations.
- Provide information that quantifies the severity of an accident in terms that can be readily understood and visualized.
- Support the determination of radiological protective actions that should be considered for long term recovery activities.

The assessment methodologies utilized by CRANE are intended to provide a rapid best estimate of fuel damage which, when evaluated together, help to develop an overall picture of the extent of fuel damage.

- * Containment Radiation Monitors: An indirect method used to determine the amount of core damage. Applicable to Loss of Coolant Accident (LOCA) scenarios. Based upon an end-of-life source term and static nuclide ratio assumptions yielding a limited accuracy. Valid any time following an accident.
 - * Core Temperatures: Methods such as Core Exit Thermocouple (CET), Peak Core Temperatures and Hot Leg Temperatures provide indirect methods used to indicate the type and/or amount of core damage. Applicable for all types of accidents. Valid any time following an accident.
 - * Core Uncovery: Methods such as Core Uncovery Time, RVLIS Level and Source Range Monitor count rate provide indirect methods used to indicate the type of core damage (clad failure or fuel melt). Applicable for all types of accidents. Provides a relatively accurate estimate of the state of the core early in the event. Valid any time following an accident.
 - * Containment Hydrogen Concentration: An indirect method used to establish the type of core damage. Applicable to LOCA type accidents where all the hydrogen generated by the metal-water reaction is released into containment. Valid any time following an accident.
 - * Sample Analysis - Isotopic Ratio Comparison: A direct method used to establish the type of core damage. Compares expected isotopic ratios with a sample to determine a general core state. Applicable under all types of accidents. Valid any time following an accident.
 - * Sample Analysis - Presence of Abnormal Isotopes: A direct method used to provide a go/no go indication of fuel melt by the presence of unusually high concentrations of the less volatile fission products. Applicable under all types of accidents. Valid any time following an accident.
 - * Sample Analysis - Concentration Evaluation: A direct method that yields the most accurate numerical estimations of the amount of core damage. Applicable for all types of accidents. Requires the sampled system(s) be in a steady state that usually prevents its use until the plant is in a stable condition.

4. Effluent Monitor Data and Dose Projection

Dose assessment or projection represents the calculation of an accumulated dose at some time in the future if current or projected conditions continue. During an accident, the Plant Parameter Display System and personal computers will provide the ERO with the timely information required to make decisions. Radiological and meteorological instrumentation readings are used to project dose rates at predetermined distances from the station, and to determine the integrated dose received. Dose assessment methods used by Constellation personnel to project offsite doses include:

- A. Monitored Release Points - This method utilizes the plant's effluent radiation monitors and system flow rates. Effluent release points are used to directly calculate a release rate. The point of the release determines the way the source term is affected and is adjusted by the dose assessment process.
- B. Containment Leakage/Failure - This method uses a variety of containment failures or leak rates in conjunction with available source term estimations to develop a release rate to the environment. A direct vent of containment can be modeled as a failure to isolate.
- C. Release Point Samples - This method uses a sample at the release point and an estimated flow rate to develop a release rate at the point of release.
- D. Field Monitoring Team Data - This method uses a field survey or sample and the atmospheric model to back calculate a release rate and ratio concentrations of radioactive material at various points up and downwind of plume centerline.

The computer applications used to provide dose calculations are evaluated against the EPA-400 plume exposure Protective Action Guides (PAGs) applicable for the early phase of an accident. These evaluations place an emphasis on determining the necessity for offsite protective action recommendations. Dose assessment actions will be performed in the following sequence:

First: Onset of a release to 1 hour post-accident: Shift personnel will rely on a simplified computerized dose model to assist them in developing offsite dose projections using real time data from effluent monitors and site meteorology.

Second: 1 hour post-accident to event termination: Estimates of off-site doses based on more sophisticated techniques are provided. Dedicated ERO personnel will analyze the offsite consequences of a release using more complex computerized dose modeling. These additional methods are able to analyze more offsite conditions than the simplified quick method, as well account for more specific source term considerations.

5. Meteorological Information

Local meteorological data is available from an onsite meteorological tower. The data available includes wind speed, wind direction, temperature, and delta temperature. These data are used by the utility, state, and NRC to provide near real-time predictions of the atmospheric effluent transport and diffusion. Meteorological data from the tower is available in the CR, TSC, and EOF. A full description of the onsite meteorological capabilities is given in Section H.5.a.

6. Unmonitored Release

Dose projections can be made during a release through use of actual sample data in situations where effluent monitors are either off-scale or inoperative or the release occurs by an unmonitored flow path. In the absence of effluent sample data, a dose projection can be performed simply by specifying the accident category as a default. The selection of a default accident category defines the mix, the total curies, and the release pathway(s). The total number of curies from a default mix for each isotope is used to provide an upper bound for release concentration, and hence, an upper bound for the dose rate and dose to the public.

7. Field Monitoring

In addition to the capabilities and resources described in Section H.6.b and H.7, CRANE maintains the ability to take offsite air samples and to directly measure gamma dose rates the event of an airborne or liquid release. The capability to take offsite soil, water, and vegetation samples is also provided by either the Field Teams or a contracted vendor.

The environmental monitoring equipment, as described in Section H, contain portable survey, counting, and air sampling instrumentation and other radiological monitoring equipment and supplies to be used by the Field Monitoring Teams. Samples are taken at predetermined locations as well as those specified both during and after a release. Environmental measurements are used as an aid in the determination and assessment of protective and recovery actions for the general public.

8. Field Monitoring Teams

Field Monitoring Teams are dispatched by CRANE to perform a variety of functions during conditions that may involve significant releases of radioactive materials from the plant. Radiological survey and sample data is used to define affected area boundaries, verify or modify dose projections and protective action recommendations, and assess the actual magnitude, extent, and significance of a liquid or gaseous release.

In addition to contamination and dose rate measurements, the change out of dosimeters and air sampler cartridges can be performed. Other actions may include soil, water and vegetation sampling.

The initial environmental surveys involve simple-to-perform measurements to quickly confirm or modify the dose projections based on plant parameters. Subsequent environmental monitoring efforts will be aimed at further defining the offsite consequences including instituting an expanded program to enable prompt assessments of any subsequent releases from the plant.

The expertise necessary to conduct limited offsite environmental survey and sampling exists onsite 24 hours a day. A minimum of two offsite Field Monitoring Teams are notified and activated at an Alert or higher classification. Teams are composed of two individuals are assembled at the station to test and inventory dedicated survey and sampling equipment. Teams are then dispatched in company or personal vehicles into the surrounding area when a release is or is expected to occur. Radiological survey and sample data is transmitted to the emergency facilities. Vendor/contractor support can be used to perform collection, shipment and analysis of environmental sample media as described in Section B.8.c.

9. Iodine Monitoring

Field monitoring equipment has the capability to detect and measure airborne radioiodine concentrations as low as $1 \times 10^{-7} \mu\text{Ci}/\text{cm}^3$ in the presence of noble gases. Interference from the presence of noble gas and background radiation will be minimized by ensuring that monitoring teams move to areas of low background prior to analyzing the sample cartridge. The collected air sample is measured by hand held survey meter as an initial check of the projection derived from plant data to determine if significant quantities of elemental iodine have actually been released (the chemical form that would pose a health hazard).

10. Dose Estimates

Specific procedures exist for the correlation of air activity levels to dose rate for key isotopes. Provisions have been established for estimating integrated dose from the projected and actual dose rates and for the comparison of these estimates with the protective action guides.

11. State Monitoring Capabilities

The states have the ability to dispatch their own field monitoring teams to track the airborne radioactive plume. The states also have the ability and resources to coordinate with federal and utility monitoring teams to compare sample results.

Section J: Protective Response

Protective response consists of emergency actions, taken during or after an emergency situation, which are intended to minimize or eliminate hazards to the health and safety of the public and/or station personnel. A range of protective actions has been developed for emergency workers and the general public in the Plume Exposure Pathway EPZ. Additionally, guidelines have been established to aid in choosing protective actions during an emergency that are consistent with federal guidance. CRANE is responsible for onsite actions, while the responsibility for offsite actions rests with the state, county, and other offsite response agencies.

1. Notification of Onsite Personnel

For all emergency classifications, all personnel within the Protected Area are notified within 15 minutes of the initial classification or escalation of an emergency by recognizable alarms and/or verbal announcements over the plant Public Address (PA) System. Announcements include the emergency classification and response actions to be taken by personnel onsite (such as ERO, non-ERO, contractor personnel, and visitors). Provisions are made to alert personnel in high noise areas and outbuildings within the Protected Area as applicable.

CRANE has identified locations where people might be expected to be present outside the Protected Area but within the Owner Controlled Area. Accountability of persons within the Owner Controlled Area but outside the Protected Area is not required. However, provisions are established for notification of personnel within the Owner Controlled Area any time a Site Evacuation has been initiated, or as otherwise deemed appropriate.

2. Evacuation Locations

If a Site Evacuation is required, nonessential personnel are directed to either assemble within designated Assembly Areas or to immediately evacuate the site. Personnel will be directed to either proceed to their homes or to reassemble at designated offsite locations. Visitors to the station will assemble with and follow the instructions of their escorts. Nonessential personnel within the Protected Area will normally exit through the security building. Personal transportation (if available) will normally be used and established evacuation routes will be followed. Personnel without transportation will be identified and provided transportation as necessary.

3. Radiological Monitoring of Evacuees

Personnel evacuating the site will be monitored for contamination by the portal monitors as they exit the Protected Area, with portable friskers in Assembly Areas, or sent to offsite monitoring locations on an as needed basis.

4. Evacuation

Evacuation is the primary protective action anticipated for onsite personnel not having immediate emergency response assignments. CRANE has identified locations that serve as Assembly Areas and offsite locations for non-essential personnel when they are not instructed to proceed home. The specific locations of these areas are shown in the Station Annex. Implementing procedures describe equipment, supplies and general operation of these facilities. The Station Emergency Director will designate personnel within the Site Boundary as essential or nonessential. Evacuation of non-essential personnel is usually conducted immediately after accountability if a Site Area Emergency or General Emergency has been declared and conditions permit. Evacuation shall commence in accordance with station procedures as directed by the Station Emergency Director or his/her designee, unless one of the following conditions exist:

- a. Severe weather conditions threaten safe transport.
- b. A significant radiological hazard would be encountered.
- c. There is a security threat occurring, which would have an adverse impact on the personnel while leaving the site.
- d. A condition similar to the above in magnitude, which in the opinion of the Station Emergency Director would adversely affect the site personnel.

Security forces will be dispatched, when available, to access road(s) to control entry to site facilities. Unauthorized and non-ERO personnel will be denied entry.

The initiation of a site evacuation will be reported to the appropriate state/local agency.

Constellation has established the implementation of alternate onsite protective actions for security-based events that are more appropriate than the actions for radiological emergencies. These alternate protective actions could include taking immediate cover, immediate protected area evacuation, immediate owner controlled area evacuation, and dispatch of the ERO to their alternate reporting center.

5. Accountability

The purpose of Accountability is to determine the locations of all personnel inside the Protected Area and to muster emergency personnel at prearranged locations. When Accountability of onsite personnel is determined to be necessary by the Station Emergency Director, all personnel within the protected area shall be accounted for and the names of missing individuals (if any) are determined within thirty (30) minutes of a Site Area Emergency or higher classification.

Accountability is usually performed in conjunction with Assembly, and is required to be initiated whenever a Site Area Emergency or higher classification is declared. The movement of personnel for the purposes of Accountability may be delayed if their health and safety could be in jeopardy, such as severe weather or for security concerns.

If it is determined that the prearranged Assembly Area is unfit for personnel, the Station Emergency Director may designate an alternative Assembly Area and direct personnel using appropriate communication systems that are available.

Once established, Accountability within the Protected Area is maintained throughout the course of the event. Should missing personnel be identified, search and rescue operations are initiated.

6. Provisions for Onsite Personnel

CRANE maintains an inventory of respiratory protection equipment, anti-contamination clothing, and KI that is made available to emergency workers remaining onsite should conditions warrant. During the course of an emergency, protective actions are considered to minimize radiological exposures or contamination problems associated with all onsite personnel. For those who must work within the restricted area of the affected site, measures that are considered are:

- a. Use of Respirators: On-shift and emergency response personnel use respiratory protection in any environment involving exposure to high level gaseous activity or oxygen deficient atmosphere, or where air quality is in doubt. In the presence of airborne particulates, emergency response personnel may be directed by health physics personnel to use full-face filter type respirators. The criteria for issuance of respiratory protection are described in Radiation Protection procedures.
- b. Use of Protective Clothing: Anti-contamination clothing, located in the TSC, OSC and station dress out areas is available for use by onsite personnel. The criteria for issuance of protective clothing are described in Radiation Protection procedures.
- c. Use of Potassium Iodide (KI): The use of KI may be recommended when a projected dose of 50 Rem Committed Dose Equivalent (CDE) is exceeded for an emergency worker's thyroid. The basis of the 50 Rem is specified in EPA 400-R-92-001, "Manual of Protective Action Guides and Protective Actions for Nuclear Incidents." CRANE is responsible for maintaining a supply of KI onsite. The Station Emergency Director has the responsibility for approval of issuing KI to Constellation Nuclear emergency workers.

7. Mechanism for Implementing Protective Action Recommendations

Plant conditions, projected dose and dose rates, and/or field monitoring data are evaluated to develop PARs for the purpose of preventing or minimizing exposure to the general public. PARs are provided to the offsite agencies responsible for implementing protective actions for the general public within the 10-mile EPZ. PARs are approved by the Emergency Director in Command and Control.

In an emergency that requires immediate protective actions be taken prior to activation of the offsite emergency facilities, PARs are provided directly to the state and county 24 hour warning points by the Emergency Director.

8. Evacuation Time Estimates (ETEs)

The evacuation time estimates (ETE) were developed in accordance with NUREG/CR-7002, Criteria for Development of Evacuation Time Estimate Studies. Section IV of Appendix E to 10CFR50 requires that an analysis of the time required to evacuate be provided for various sectors and distances within the plume exposure pathway EPZ for transient and permanent residents which includes special facilities schools, nursing homes, hospitals, and recreational areas. The evacuation time estimate (ETE) is a calculation of the time to evacuate the plume exposure pathway emergency planning zone (EPZ), which is an area with a radius of about 10 miles around the station.

The ETE study uses population data from the decennial census. The evacuation times are based on a detailed consideration of the EPZ roadway network and population distribution. The ETE Study is contained in an addendum to the station Annex and presents evacuation times for daytime and nighttime scenarios under various weather conditions for the evacuation of various areas around the station.

Within 365 days of the availability of each decennial census data from the U.S. Census Bureau, each station shall develop an ETE analysis using this decennial data and submit it under 10CFR50.4 to the NRC. The ETE analysis shall be submitted to the NRC at least 180 days before using it to form protective action recommendations and providing it to State and local governmental authorities for use in developing offsite protective action strategies.

During the years between decennial censuses, EPZ permanent resident population changes are estimated once a year, but no later than 365 days from the date of the previous estimate, using the most recent U.S. Census Bureau annual resident population estimate and State/local government population data, if available. If at any time during the decennial period, the EPZ permanent resident population increases such that it causes the longest ETE value for the 2-mile zone or 5-mile zone, including all affected Emergency Response Planning Areas, or for the entire 10-mile EPZ to increase by 25 percent or 30 minutes, whichever is less, from the currently NRC approved or updated ETE, the ETE analysis will be updated to reflect the impact of that population increase. These estimates are available for NRC inspection during the period between decennial censuses and will be submitted to the NRC with any updated ETE analysis under 10CFR50.4 no later than 365 days after the determination that the criteria for updating the ETE have been met and at least 180 days before using it to form protective action recommendations and providing it to State and local governmental authorities for use in developing offsite protective action strategies.

9. Capability of Implementing Protective Action Recommendations

The responsibility for implementing protective measures based on protective action guides for the offsite population at risk is the responsibility of the state and local governments. Detailed procedures for public protective actions are contained in the state and other local radiological emergency response plans as appropriate.

The state agencies are responsible for evaluation of Constellation Nuclear recommended protective actions and preparing a recommendation to the Governor, or his/her appointed agent. Only when the state acts under the Governor's order does a recommended protective action become a directed protective action.

If the plant conditions are stable and offsite radiological conditions are such that the public health and safety are not endangered, then return to evacuated areas may be discussed with the affected state(s). State authorities are responsible for actually recommending return and transmitting this recommendation.

10. Implementation of Protective Action Recommendations

The utility, state, and county emergency plans used to implement the protective measures for the plume exposure pathway take numerous factors into consideration as stated in NUREG-0654 II.J. Among these considerations are:

- a. Most of the public evacuees are expected to travel in their own vehicles, leaving the EPZ via designated evacuation routes. The Station Annex shows the evacuation routes, EPZ Subareas and pre-selected sampling/monitoring points. The state and county plans contain official maps and information on the locations of off-site centers.
- b. The population distribution around the station. Population distribution for the plume exposure EPZ is illustrated in the Station Annexes.
- c. As indicated in Section E, offsite agencies are notified in the event the Emergency Plan is activated. State and county agencies have the capability to notify all members of the transient and resident population within the Plume Exposure Pathway EPZ.
- d. NUREG-0654 II.J.10.d-l items are addressed separately in state and county emergency plans.
- e. At a General Emergency classification, Constellation Nuclear will provide the state with recommendations for protective actions for the public. For incidents involving actual, potential, or imminent releases of radioactive material to the atmosphere, EPA 400-R-92-001, the NRC Response Technical Manual (RTM-96) and NUREG-0654, Supp. 3, Revision 1 are used as the basis for the general public PARs.

1) Plant Based PARs

Station specific PAR Flowcharts have been developed to aid Constellation Nuclear personnel providing PARs based on the above. Station specific PAR Flowcharts with Subarea or Sector tables are documented in the Constellation EP Implementing Procedures, including station-specific requirements regarding PAR determination. These flowcharts and tables provide technically based Protective Action Recommendations based on plant conditions and core damage indicators as applicable to the Constellation site and described within the implementing procedures. Possible plant based PARs issued by Constellation Nuclear, in support of NUREG-0654 Supp. 3, at a General Emergency could include as appropriate for the Station:

- Response to a Rapidly Progressing Severe Accident.
- Utilization of the staged evacuation concept as determined by station ETE's.
- Shelter of the general public in response to but not limited to impediments to evacuation, or Hostile Action event.
- Evacuation of the general public.

In addition to the above actions to minimize or prevent potential exposure to radiation, a recommendation of "monitor and prepare" will be issued for the remainder of the EPZ.

2) Dose Based PARs

Evacuation is recommended if projected doses reach the minimum EPA PAGs (≥ 1 Rem EPA TEDE¹ or ≥ 5 Rem CDE Thyroid).

Many assumptions exist in dose assessment calculations, involving both source term and meteorological factors, which make computer predictions over long distances highly questionable. However, in the event dose assessment results indicate the need to recommend actions beyond the outer EPZ boundaries, which is past 10 miles, Field Monitoring Teams are dispatched to downwind areas to verify the calculated exposure rates prior to issuing PARs outside the EPZ. In the event dose assessment results indicate the need to recommend actions beyond the outer EPZ boundaries (past 10 miles):

- If Field Monitoring Teams have been dispatched from the site, then dose assessment exposure rates will be verified prior to issuing any recommended action.
- If Field Monitoring Teams have not been dispatched from the site, then issuing recommended actions will not be delayed waiting on Field Teams.

¹ EPA TEDE is defined as the sum of the doses from external exposure and inhalation from the plume, and from 4 days of external exposure to deposited materials.

Constellation personnel normally do not have the necessary information to determine whether off site conditions would require sheltering instead of evacuation. External factors (such as road conditions, traffic/traffic control, weather, or offsite emergency response capabilities) are determined by the state.

11. Ingestion Pathway Protective Measures

The responsibility for specifying protective measures to be used for the ingestion pathway rests with the state. These measures include the methods for protecting the public from consumption of contaminated water and foodstuffs.

12. Monitoring of Evacuees

The state and county organizations have the capability to register and monitor evacuees at designated reception centers. This capability includes personnel and equipment capable of monitoring residents and transients evacuating from the plume exposure EPZ and arriving at the reception centers, in accordance with FEMA guidelines.

Section K: Radiological Exposure Control

This section of the plan describes the means for controlling emergency worker radiological exposures during an emergency, as well as the measures that are used by Constellation to provide necessary assistance to persons injured or exposed to radiation and/or radioactive materials. Exposure guidelines in this section are consistent with EPA Emergency Worker and Lifesaving Activity Protective Action Guides described in EPA 400-R-92-001.

1. Emergency Exposure Guidelines

Being licensed by the NRC, all Constellation Nuclear generating stations maintain personnel exposure control programs in accordance with 10 CFR 20 under normal operating conditions. The Station Emergency Director is assigned the non-delegable responsibility for authorizing personnel exposure levels under emergency conditions per EPA-400. In emergency situations, workers may receive exposure under a variety of circumstances in order to assure safety and protection of others and of valuable property. These exposures will be justified if the maximum risks or costs to others that are avoided by their actions outweigh the risks to which the workers are subjected. The Emergency Worker Dose Limits are as follows:

Dose Limit (Rem TEDE)	Activity	Condition
0-5	All	Personnel should be kept within normal 10 CFR 20 limits during bona fide emergencies, except as authorized for activities as indicated below.
5-10	Protecting valuable property	Lower dose not practicable.
10-25	Lifesaving or protection of large populations	Lower dose not practicable.
> 25	Lifesaving or protection of large populations	Only on a voluntary basis to persons fully aware of the risks involved.

Limit dose to the lens of the eye to 3 times the above values and doses to any other organ (including skin and body extremities) to 10 times the above values.

Whenever possible, the concurrence of the Station's Radiation Protection (Department) Manager should be secured before exposing individuals to dose equivalents beyond the EPA-400 lower limit.

2. Emergency Radiation Protection Program

The TSC Radiation Protection Manager is the individual responsible for the implementation of the radiation protection actions during an emergency. Radiation protection guidelines include the following:

- Volunteers over forty-five years of age are considered first for any emergency response action requiring exposure greater than normal limits. Routine dose limits shall not be extended to emergency dose limits for declared pregnant individuals. As in the case of normal occupational exposure, doses received under emergency conditions should be maintained as low as reasonably achievable.
- Persons undertaking any emergency operation in which the dose will exceed 25 Rem TEDE should do so only on a voluntary basis and with full awareness of the risks involved including the numerical levels of dose at which acute effects of radiation will be incurred and numerical estimates of the risk of delayed effects.
- In the context of the emergency limits, exposure of workers that is incurred for the protection of large populations may be considered justified for situations in which the collective dose avoided by the emergency operation is significantly larger than that incurred by the workers involved.
- Exposure accountability is maintained and proper personnel radiological monitoring equipment is provided for all personnel during emergency conditions.
- Access to high radiation areas is only permitted with prior approval of the applicable Radiation Protection Manager. Personnel are not allowed to enter known or potential high radiation areas unless their exposure has been properly evaluated.
- Periodic habitability surveys of emergency facilities are performed during an emergency. If the facility is determined to be uninhabitable, the facility is evacuated in order to prevent or minimize exposure to radiation and radioactive materials. Alternate assembly areas are established, as necessary, to relocate and monitor evacuated personnel.

3. Personnel Monitoring

- a. Emergency workers will receive DLR badges and personal self-reading dosimeters capable of measuring expected exposures on a real time basis. The capability exists for the emergency processing of DLRs on a 24-hour per day basis, if necessary.
- b. Emergency worker dose records are maintained by the Radiation Protection Managers (as appropriate) in accordance with the emergency and radiological protection procedures. Emergency workers are instructed to read their dosimeters frequently. DLRs may be processed with increased periodicity.

4. Non-Constellation Personnel Exposure Authorization

The responsibility for authorizing non-Constellation emergency workers (i.e. state and local agency emergency workers) to receive exposures in excess of the EPA General Public Protective Action Guides rests with the state and county organizations, except when such emergency workers are onsite. Authorization of exposures in excess of EPA General Public Protective Action Guides, in this latter instance, rests with the Station Emergency Director.

5. Contamination and Decontamination

During an emergency, the Station Emergency Director is responsible for preventing or minimizing personnel exposure to radioactive materials deposited on the ground or other surfaces. Special consideration should be given to setting up contamination control arrangements for personnel entering the OSC after completion of assigned activities.

- a. During emergency conditions, normal plant contamination control criteria will be adhered to as much as possible. However, these limits may be modified by the applicable Radiation Protection Manager per existing Radiation Protection procedures, should conditions warrant.
- b. Contamination Control Means: Personnel found to be contaminated will normally be attended to at decontamination areas located onsite. Temporary decontamination areas can also be set up inside at various locations. Decontamination showers and supplies are provided onsite with additional personnel decontamination equipment and capabilities. Shower and sink drains in the controlled area are routed to the miscellaneous waste processing system where the liquid is processed and monitored prior to discharge. Potentially contaminated emergency vehicles will be surveyed before they are allowed to leave the plant or offsite assembly area. If the survey area is not suitable for monitoring and decontamination due to radiological or other concerns, vehicles will be surveyed at an alternate location.

6. Contamination Control Measures

Controls are established 24 hours per day to contain the spread of loose surface radioactive contamination.

- a. Contaminated areas are isolated as restricted areas with appropriate radiological protection and access control. Personnel leaving contaminated areas are monitored to ensure they and their clothing are not contaminated. If contamination above acceptable levels is found, they will be decontaminated in accordance with plant procedures. If normal decontamination procedures do not reduce personnel contamination to acceptable levels, the case will be referred to a competent medical authority. Supplies, instruments, and equipment that are in contaminated areas or have been brought into contaminated areas will be monitored prior to removal. If found to be contaminated, they will be decontaminated using normal plant decontamination techniques and facilities or may be disposed of as radwaste. Contaminated vehicles will be decontaminated before being released.

- b. Measures will be taken to control onsite access to potentially contaminated potable water and food supplies. Under emergency conditions when uncontrolled releases of activity have occurred, eating, drinking, smoking, and chewing are prohibited in all station emergency response facilities until such time as habitability surveys indicate that such activities are permissible.
- c. Restricted areas and contaminated items will be returned to normal use when contamination levels have been returned to acceptable levels. Contamination control criteria for returning areas and items to normal use are contained in the plant procedures.

7. Decontamination of Relocated Personnel

Nonessential onsite personnel may be evacuated to an offsite relocation center or assembly area, as discussed in Section J. Radiological controls personnel at that location monitor evacuees and determine the need for decontamination. Existing and temporary facilities to limit contamination and exposure will be utilized and established at the site as necessary during an emergency situation. In the event that decontamination of evacuees locally is not possible, personnel will be sent to designated locations for monitoring and decontamination. Provisions for extra clothing are made and suitable decontaminates are available for the expected type of contaminations, particularly with regards to skin contaminations.

Section L: Medical and Public Health Support

This section describes the arrangements for medical services for contaminated injured individuals sent from the station.

1. Offsite Hospital and Medical Services

Hospital personnel have been trained, and hospitals are equipped to handle contaminated or radiation injured individuals. Specifically, training of medical support personnel at the agreement hospitals will include basic training on the nature of radiological emergencies, diagnosis and treatment, and follow-up medical care. Station personnel are available to assist medical personnel with decontamination radiation exposure and contamination control. Arrangements, by letter of agreement or contract, are maintained by Crane Clean Energy Center with a qualified hospital located in the vicinity of Crane for receiving and treating contaminated or exposed persons with injuries requiring immediate hospital care. Constellation Nuclear shall provide medical consultants to aid in any special care necessary at these facilities.

Arrangements are also maintained with a qualified medical facility well equipped and staffed for dealing with persons having radiation injuries and whenever necessary, such persons will be transferred to this hospital facility for extended specialized treatment. Constellation Nuclear will have available to the staff of this hospital, medical consultants who will provide the direction of the special care necessary for the treatment of persons having radiation injuries.

These agreements are verified annually. Refer to section II.P.4 for details.

2. Onsite First Aid Capability

CRANE maintains onsite first aid supplies and equipment necessary for the treatment of contaminated or injured persons. In general, physicians or nurses are not staffed at CRANE, and as such, medical treatment given to injured persons is of a "first aid" nature. CRANE does have an industrial hygiene advisor. Additionally, the Radiation Protection Technicians at CRANE are experienced in controlling radioactive contamination and decontamination work. Station personnel are also trained and qualified to administer first aid. At least two of these individuals are available on-shift at all times. The functions of station personnel in handling onsite injured people are:

- 1) Afford rescue;
- 2) Administer first aid including such resuscitative measures as are deemed necessary;
- 3) Begin decontamination procedures; and
- 4) Arrange for suitable transportation to a hospital when required.

Primary attention shall be directed to the actual factors involved in the treatment of casualties, such as: control of bleeding, resuscitation including heart and lung, control of bleeding after resuscitation, protection of wounds from bacterial or radioactive contamination and the immobilization of fractures.

Station personnel provide an initial estimate of the magnitude of surface contamination of the injured and preliminary estimates of total body dose to the injured. Primary rapid and simple decontamination of the surface of the body (when possible and advisable) before transportation to a designated hospital may be carry out as directed or performed by Radiation Protection personnel. When more professional care is needed, injured persons are transported to a local clinic or hospital. Contaminated and injured persons are transported to a dedicated specified facility.

3. Medical Service Facilities

Because of the specialized nature of the diagnosis and treatment of radiation injuries, Corporate Emergency Preparedness maintains an agreement with REAC/TS. REAC/TS is a radiological emergency response team of physicians, nurses, health physicists and necessary support personnel on 24-hour call to provide consultative or direct medical or radiological assistance at the REAC/TS facility or at the accident site. Specifically, the team has expertise in and is equipped to conduct: medical and radiological triage; decontamination procedures and therapies for external contamination and internally deposited radionuclides, including chelation therapy; diagnostic and prognostic assessments or radiation-induced injuries; and radiation dose estimates by methods that include cytogenetic analysis, bioassay, and in vivo counting.

In addition to REAC/TS, the Station Annex may identify additional medical consultants, based on agreements with local hospitals, to support personnel training and medical response.

4. Medical Transportation

Arrangements are made by CRANE for prompt ambulance transport of persons with injuries involving radioactivity to designated hospitals. Such service is available on a 24-hour per day basis and is confirmed by letter of agreement. Radiation monitoring services shall be provided by CRANE whenever it becomes necessary to use the ambulance service for the transportation of contaminated persons.

A qualified Radiation Protection person shall accompany the ambulance to the hospital. Additional Radiation Protection personnel may be contacted and dispatched to local hospitals to assist in the monitoring and decontamination of the injured victim and hospital and ambulance facilities and personnel.

Section M: Reentry and Recovery Planning

This section describes the measures to be taken for reentry into the areas of CRANE which have been evacuated as a result of an accident. It also outlines the Constellation Nuclear Recovery Organization and its concepts of operation.

1. Reentry and Recovery

a. Evaluating Reentry Conditions

During an emergency, immediate actions are directed toward limiting the consequences of the accident to afford maximum protection to station personnel and the general public. Once corrective measures have been taken and effective control of the plant has been re-established, a more methodical approach to reentry is taken. This Emergency Plan divides reentry into two separate categories:

- Reentry *during the emergency phase of an accident* is performed to save a life, control a release of radioactive material, prevent further damage to plant equipment or restore plant equipment. If necessary, this category of reentry may be performed using emergency exposure limits. Briefings, rather than written radiation protection procedures, may be used when making these entries.

All reentry activities conducted during the emergency are authorized by the Station Emergency Director and coordinated by the OSC Director and the Radiation Protection Manager.

- Reentry *during the recovery phase of an accident* is performed using normal exposure limits. Either normal procedures or procedures that consider existing as well as potential conditions inside affected areas are developed specifically for each reentry.

Reentry activities during the recovery phase are authorized by the Recovery Director and coordinated by the recovery organization managers in charge of personnel making the reentry.

The following items are considered when planning for any reentry:

- Review of available radiation surveillance data to determine plant areas potentially affected by radiation and/or contamination.
- Review of radiation exposure history of personnel required to participate in the accident mitigation or recovery operations.
- Determination of the need for additional personnel and the sources of these additional personnel.
- Review of adequacy of radiation survey instrumentation and equipment (types, ranges number, calibration, etc.).

- Review of non-radiological hazards and required protective measures (e.g., fire, electrical, Hazmat).
- Pre-planning of activities and briefings for the reentry team that include the following:
 - Personnel knowledge requirements.
 - Methods and procedures that will be employed during the entry.
 - Specific tasks to be performed.
 - Anticipated radiation and contamination levels.
 - Radiation survey equipment and types and ranges of dosimetry required.
 - Shielding requirements and availability.
 - Appropriate communications.
 - Protective clothing and equipment requirements.
 - Access control procedures.
 - Decontamination requirements.
 - De-briefing requirements.
 - Respiratory protection.
- A review of security controls to prevent unauthorized or unintentional entry into hazardous areas.

b. Evaluating Entry into Recovery

The Recovery Phase is that period when major repairs are being performed to return the plant to an acceptable condition and the possibility of the emergency condition degrading no longer exists. Once the plant has been stabilized, contained and controlled, the Recovery Phase may be entered. It is the responsibility of the Station Emergency Director to classify Recovery after obtaining authorization from the Corporate Emergency Director.

Establishment of Recovery can be conducted from any emergency classification level. However, it is possible that the lower classifications of Unusual Event and Alert will conclude with the event being terminated. There may be cases where certain EAL initiating conditions remain exceeded, but the station is under control and no further danger of degradation exists. In such a case, it may be appropriate to enter Recovery. Site Area and General Emergencies will require a Recovery Phase to be established prior to event termination. Constellation Nuclear may consult with/notify cognizant governmental agencies prior to declaring Recovery or event termination.

Termination/Recovery considerations are contained in the implementing procedures to provide guidance for evaluating the risk of entering Recovery without alleviating the intent of the Initiating Condition. The purpose of Recovery is to provide the necessary personnel to handle the long-term activities and to return the plant to an acceptable condition.

The following conditions are guidelines for the determination of establishing Recovery (this is not intended to be a complete list and additional criteria may apply, depending on the specifics of the event):

- The risk to the health and safety of the public has been mitigated.
- Plant parameters and equipment status have been established and controlled.
- In-plant radiation levels are stable or decreasing, and acceptable, given the plant conditions.
- The potential for uncontrolled releases of radioactive material to the environment has been eliminated.
- Environmental monitoring has been established.
- The radioactive plume has dissipated and plume tracking is no longer required (the only environmental assessment activities in progress are those necessary to assess the extent of deposition resulting from passage of the plume).
- Constellation Nuclear workers have been protected.
- Any security threat has been neutralized, and/or plant security is under the direction of Constellation Nuclear personnel.
- Adequate plant safety systems are operable.
- The reactor is in a stable shutdown condition and long-term core cooling is available.

- The fuel pool damage has been mitigated, or spent fuel damage has been contained and controlled.
- Primary and/or secondary containment integrity has been established.
- Plant systems and equipment are restored and/or replaced such that plant conditions are stable highly unlikely to degrade further.
- Conditions that initiated the emergency have been contained, controlled, eliminated or stabilized such that the classification is no longer applicable.
- The operability and integrity of radioactive waste systems, decontamination facilities, power supplies, electrical equipment and of plant instrumentation including radiation monitoring equipment.
- Any fire, flood, earthquake or similar emergency condition or threat to security no longer exists.
- All required notifications have been made.
- Discussions have been held with federal, state and county agencies and agreement has been reached to terminate the emergency.
- At an Alert or higher classification, the ERO is in place and emergency facilities are activated.
- Any contaminated injured person has been treated and/or transported to a medical care facility.
- Offsite conditions do not unreasonably limit access of outside support to the station and qualified personnel and support services are available.

It is not necessary that all conditions listed above be met; however, all items must be considered prior to entering the recovery phase. For example, it is possible after a severe accident that some conditions remain that exceed an Emergency Action Level, but entry into the Recovery Phase is appropriate.

2. Recovery Organization

Once plant conditions have been stabilized and the Recovery Phase has been initiated, the Emergency Director may form a Recovery Organization for long-term operations. These types of alterations will be discussed with the NRC prior to implementation.

- For events of a minor nature, (i.e. for Unusual Event classifications) the normal on-shift organization is normally adequate to perform necessary recovery actions.

- For events where damage to the plant has been significant, but no offsite releases have occurred and/or protective actions were not performed, (i.e. for Alert classifications) the station Emergency Response Organization, or portions thereof, should be adequate to perform the recovery tasks prior to returning to the normal station organization.
- For events involving major damage to systems required to maintain safe shutdown of the plant and offsite radioactive releases have occurred, (i.e. for Site Area Emergency or General Emergency classifications) the station recovery organization is put in place.

The specific members of the station recovery organization are selected based on the sequence of events that preceded the recovery activities as well as the requirements of the recovery phase. The basic framework of the station recovery organization is as follows:

- a. The Recovery Director: The Corporate Emergency Director is initially designated as the Recovery Director. The Recovery Director is charged with the responsibility for directing the activities of the station recovery organization. These responsibilities include:

- Ensuring that sufficient personnel, equipment, or other resources from Constellation and other organizations are available to support recovery.
- Directing the development of a recovery plan and procedures.
- Deactivating any of the plant Emergency Response Organization which was retained to aid in recovery, in the appropriate manner. Depending upon the type of accident and the onsite and offsite effects of the accident, portions of the ERO may remain in place after initiation of the recovery phase.
- Coordinating the integration of available federal and state assistance into onsite recovery activities.
- Coordinating the integration of Constellation support with federal, state and county authorities into required offsite recovery activities.
- Approving information released by the public information organization which pertains to the emergency or the recovery phase of the accident.
- Determining when the recovery phase is terminated.

- b. The Recovery Plant Manager: The Station Manager or a designated alternate will become the Recovery Plant Manager. The Recovery Plant Manager reports to the Recovery Director and is responsible for:

- Coordinating the development and implementation of the recovery plan and procedures.

- Ensuring that adequate engineering activities to restore the plant, are properly reviewed and approved.
- Directing all onsite activities in support of the station recovery effort.
- Designating other Constellation recovery positions required in support of onsite recovery activities.

c. The Recovery Offsite Manager: A senior Corporate Emergency Preparedness or Regulatory Affairs individual, or a designated alternate, is the Recovery Offsite Manager. The Recovery Offsite Manager reports to the Recovery Director and is responsible for:

- Providing liaison with offsite agencies and coordinating Constellation assistance for offsite recovery activities.
- Coordinating Constellation ingestion exposure pathway EPZ sampling activities and the development of an offsite accident analysis report.
- Developing a radiological release report.
- Designating other Constellation recovery positions required in support of offsite recovery activities.

d. The Company Spokesperson: A senior Constellation management individual is designated as the Company Spokesperson. The Company Spokesperson reports to the Recovery Director and is responsible for:

- Functioning as the official spokesperson to the press for Constellation on all matters relating to the accident or recovery.
- Coordinating non-Constellation public information groups (federal, state, county, etc.).
- Coordinating media monitoring and rumor control.
- Determining what public information portions of the ERO will remain activated.

The remainder of the recovery organization is established and an initial recovery plan developed at the end of the emergency phase or just after entry into the recovery phase. Consideration is given to recovery activity needs and use of the normal station organizations. Individual recovery supervisors may be designated in any or all of the following areas:

- Training
- Radiation Protection
- Chemistry
- Technical/Engineering Support

- Nuclear Oversight
- Operations
- Security
- Maintenance
- Special Offsite Areas (Community Representatives, Environmental Samples, Investigations, etc.)

3. Recovery Phase Notifications

When the decision is made to enter the recovery phase, all members of the Constellation ERO are informed of the change. All Constellation personnel are instructed of the Recovery Organization and their responsibilities to the recovery effort.

4. Total Population Exposure

Total population exposure calculations are performed and periodically updated during the recovery phase of an accident. A method has been developed for estimating the total population exposure resulting from the accident from data collected in cooperation with the state and other federal agencies. Total population exposure is determined through a variety of procedures including:

- Examination of pre-positioned dosimeters.
- Bioassay.
- Estimates based on release rates and meteorology.
- Estimates based on environmental monitoring of food, water, and ambient dose rates.

The state will be the lead agency in the collection and analysis of environmental air, soil, foliage, food, and water samples and for the generation of radiation monitoring reports. Constellation Nuclear environmental sampling activities will be coordinated with state efforts, as requested, and results shared with cognizant agencies.

Section N: Drill and Exercise Program

This section describes the Drill and Exercise Program that Constellation Nuclear has implemented to:

- Verify the adequacy of the Emergency Preparedness Program.
- Develop, maintain, and evaluate the capabilities of the ERO to respond to emergency conditions and safeguard the health and safety of station personnel and the general public.
- Identify deficiencies in the Emergency Plan and the associated procedures, or in the training of response personnel, and ensure that they are promptly corrected.
- Ensure the continued adequacy of emergency facilities, supplies and equipment, including communications networks.

The Exercise Cycle is defined as an eight-year period of time. At each station, the eight-year cycle began in the same year that the first Hostile Action based exercise was performed. During each eight-calendar year exercise cycle, sites shall vary the content of scenarios during exercises to provide the opportunity for the ERO to demonstrate proficiency in the key skills necessary to respond to the following scenario elements:

- hostile action directed at the plant site,
- no radiological release or an unplanned minimal radiological release that does not require public protective actions,
- an initial classification of or rapid escalation to a Site Area Emergency or General Emergency,
- implementation of strategies, procedures, and guidance developed under § 50.155 and integration of offsite resources with onsite response.

Constellation uses drill and exercise scenarios that provide reasonable assurance that anticipatory responses do not result from preconditioning of participants. Such scenarios include a wide spectrum of radiological releases and events, including hostile action

1. Exercises**a. Biennial Exercises**

Federally prescribed exercises are conducted at CRANE in order to test the adequacy of timing and content of implementing procedures and methods; to test emergency equipment and communication networks; and to ensure that emergency personnel are familiar with their duties. Exercises involving offsite agency participation, required under Section F.2.c & d to 10 CFR 50 Appendix E, are conducted based on the FEMA Radiological Emergency Preparedness Manual and the state and local emergency response plans.

Partial participation means appropriate offsite authorities shall actively take part in the exercise sufficient to test direction and control functions to include protective action decision making related to Emergency Action Levels and communication capabilities among affected state and local authorities and Constellation Nuclear.

Full participation exercises will include appropriate offsite local and state authorities and Constellation personnel physically and actively taking part in testing the integrated capability to adequately assess and respond to an accident at the plant. Additionally, full participation exercises will include testing the major observable portions of the onsite and offsite emergency plans and mobilization of state, local, and Constellation personnel and other resources in sufficient numbers to verify the capability to respond to the accident scenario.

Where partial or full participation by offsite agencies occurs, the sequence of events simulates an emergency that results in the release of radioactivity to the offsite environs, sufficient in magnitude to warrant a response by offsite authorities.

b. Off-Year Exercises

An Off-Year Exercise is conducted at each station during the calendar year when an NRC Evaluated Exercise is not scheduled. An Off-Year Exercise shall involve a combination of at least two facilities in order to demonstrate at least two of the functions of management and coordination of emergency response, accident assessment, protective action decision-making, or plant system repair and corrective actions. For Off-Year Exercises involving no or limited participation by offsite agencies, emphasis is placed on development and conduct of an exercise that is more mechanically and operationally realistic. Players will be able, by implementing appropriate procedures and corrective actions, to determine the outcome of the scenario to a greater extent than when core damage and the release of radioactivity are prerequisites for demonstration of all objectives.

Exercises provide an opportunity to evaluate the ability of participating organizations to implement a coordinated response to postulated emergency conditions. Exercises are conducted to ensure that all major elements of the Emergency Plan and preparedness program are demonstrated at least once in each exercise cycle. Each station shall conduct at least one off-hours exercise between 6:00 p.m. and 4:00 a.m. every exercise cycle. Weekends and holidays are also considered off-hours periods. Provisions will be made for qualified personnel from Constellation, federal, state, or local governments to observe and critique each exercise as appropriate.

2. Drills

In addition to the exercises described above, Constellation conducts drills for the purpose of testing, developing, and maintaining the proficiency of emergency responders. Drills are scheduled on the Emergency Preparedness annual events plan, which contains provisions for the following drills:

a. Communication Drills

- Monthly - The capability of the Nuclear Accident Reporting System (NARS) to notify the state and local government warning points and EOCs within the plume exposure pathway EPZ are demonstrated. Also, the capability to notify the NRC is demonstrated using the Emergency Notification System (ENS) and the Health Physics Network (HPN) where available.
- Quarterly - The capability to notify the NRC Region, FEMA Region, American Nuclear Insurers (ANI) and federal emergency response organizations as listed in the Emergency Response Facilities (ERF) Telephone Directory are demonstrated from the EOF. Also, computer and critical communications equipment shall be functionally tested.

Communications between states outside the 10 mile EPZ but within the 50-mile EPZ are tested by the host state.

- Annually - The emergency communications systems outlined in Section F are fully tested. This includes (1) communications between the plant and the state and local EOCs and Field Monitoring Teams, and (2) communications between the CR, the TSC, and the EOF.

Each of these drills includes provisions to ensure that all participants in the test are able to understand the content of the messages.

- b. Fire Drills: Fire drills shall be conducted at CRANE in accordance with Station Technical Specifications and/or Station procedures.

- c. Medical Emergency Drills: A medical emergency drill, involving a simulated contaminated individual, and containing provisions for participation by local support services organizations (i.e., ambulance and support hospital) are conducted annually. Local support service organizations, which support more than one station, shall only be required to participate once each calendar year. The offsite portions of the medical drill may be performed as part of the required biennial exercise.
- d. Radiological Monitoring Drills: Plant environs and radiological monitoring drills (onsite and offsite) are conducted annually. These drills include collection and analysis of all sample media (such as, water, vegetation, soil, and air), and provisions for communications and record keeping.
- e. Health Physics Drills: Health Physics Drills involving a response to, and analysis of, simulated airborne and liquid samples and direct radiation measurements within the plant are conducted semi-annually. At least annually, these drills shall include a demonstration of the sampling system capabilities, or the Core Damage Assessment Methodology (CDAM) objectives as applicable.
- f. Augmentation Drills: Augmentation drills serve to demonstrate the capability of the process to augment the on-shift staff with a TSC, OSC and EOF in a short period after declaration of an emergency. These drills are conducted using the following methods:
 - Quarterly, each station will initiate an unannounced off-hours ERO augmentation drill where no actual travel is required. Each region's Corporate ERO shall also perform an unannounced off-hours ERO augmentation drill that may be conducted independent of, or in conjunction with, a station drill.
 - At least once per exercise cycle, an off-hours unannounced activation of the ERO Notification System with actual response to the emergency facilities is conducted by each station. Each region's Corporate ERO need only participate once per cycle.
- g. Accountability Drills: Accountability drills are conducted annually. The drill includes identifying the locations of all individuals within the protected area.

3. Conduct of Drills and Exercises

Advance knowledge of the scenario will be kept to a minimum to allow "free-play" decision making and to ensure a realistic participation by those involved. Prior to the drill or exercise, a package will be distributed to the controllers and evaluators that will include the scenario, a list of performance objectives, and a description of the expected responses.

For each emergency preparedness exercise or drill conducted, a scenario package is developed that includes at least the following:

- a. The basic objective(s) of the drill or exercise and the appropriate evaluation criteria.

- b. The date(s), time period, place(s), and participating organizations.
- c. The simulated events.
- d. A time schedule of real and simulated initiating events.
- e. A narrative summary describing the conduct of the scenario to include such things as simulated casualties, offsite fire department assistance, rescue of personnel, use of protective clothing, deployment of radiological monitoring teams, and public information activities.
- f. A description of the arrangements for and advance materials to be provided to official observers.

Prior approval by the appropriate station management is obtained for all drills and exercises conducted in support of the Emergency Preparedness Program.

4. Critique and Evaluation

Drill and exercise performance objectives are evaluated against measurable demonstration criteria. As soon as possible following the conclusion of each drill or exercise, a critique is conducted to evaluate the ability of the ERO to implement the Emergency Plan and procedures.

A formal written critique report is prepared by Emergency Preparedness following a drill or exercise involving the evaluation of designated objectives or following the final simulator set with ERO participation. The report will evaluate the ability of the ERO to respond to a simulated emergency situation. The report will also contain corrective actions and recommendations.

Biennially, representatives from the NRC observe and evaluate the licensee's ability to conduct an adequate self-critical critique. For partial and full offsite participation exercises both the NRC and FEMA will observe, evaluate, and critique.

Critique comments identified by participants during a training drill where objectives are not formally being evaluated will be reviewed and dispositioned by Emergency Preparedness, but do not require a formal report.

5. Resolution of Drill and Exercise Findings

The critique and evaluation process is used to identify areas of the Emergency Preparedness Program that require improvement. The Emergency Preparedness Manager is responsible for evaluation of recommendations and comments to determine which items will be incorporated into the program or require corrective actions, and for the scheduling, tracking, and evaluation of the resolution to the items.

Whenever exercises and/or drills indicate deficiencies in the Emergency Plan or corresponding implementing procedures, such documents will be revised as necessary.

Remedial exercises will be required if the emergency plan is not satisfactorily tested during the Biennial Exercise, such that NRC, in consultations with FEMA, cannot find reasonable assurance that adequate protective measures can be taken in the event of a radiological emergency. The extent of State and local participation in remedial exercises must be sufficient to show that appropriate corrective measures have been taken regarding the elements of the plan not properly tested in the previous exercises.

Section O: Emergency Response Training

This section describes the emergency response training that is provided to those who may be called upon in an emergency. It outlines the training provided by Constellation Nuclear to both its employees and offsite support personnel requiring site access.

1. Assurance of Training

The Emergency Plan Training Program assures the training, qualification, and requalification of individuals who may be called on for assistance during an emergency. Specific emergency response task training, prepared for each Emergency Plan position, is described in lesson plans and study guides. The lesson plans, study guides, and written tests are contained in the ERO Training Program. Responsibilities for implementing the training program are contained in plant procedures. Constellation personnel who are assigned an Emergency Plan position will receive retraining at a frequency of once per calendar year not to exceed 18 months between training sessions.

Offsite training is provided to support organizations that may be called upon to provide assistance in the event of an emergency. The following outlines the training received by these organizations:

- a. Emergency Preparedness shall annually train, or document an annual written offer to train, those non-Constellation Nuclear organizations referenced in the Station Annex that may provide specialized services during a nuclear plant emergency (e.g., local law enforcement, fire-fighting, medical services, transport of injured, etc.). The training made available is designed to acquaint the participants with the special problems potentially encountered during a nuclear plant emergency, notification procedures and their expected roles. Those organizations that must enter the site shall also receive site-specific emergency response training and be instructed as to the identity (by position and title) of those persons in the onsite organization who will control their support activities.
- b. Training of offsite emergency response organizations is described in their respective radiological emergency plans, with support provided by Constellation Nuclear as requested.

2. Functional Training of the ERO

In addition to general and specialized classroom training, members of the CRANE ERO receive periodic performance based emergency response training. Performance based training is provided using one or more of the following methods:

- Familiarization Sessions: A familiarization session is an informal, organized tabletop discussion of predetermined objectives.
- Walk Throughs: Consists of a facility walk through to familiarize plant ERO personnel with procedures, communications equipment, and facility layout. Walk throughs also provide the opportunity to discuss facility activities, responsibilities and procedures with an instructor.

- **Drills:** A drill is a supervised instruction period aimed at testing, developing and maintaining skills in a particular operation. Drills described in Section N of this plan are a part of training. These drills allow each individual the opportunity to demonstrate the ability to perform their assigned emergency functions. During drills, on-the-spot correction of erroneous performance may be made and a demonstration of the proper performance offered by the Controller.

3. First Aid Response

Selected station personnel are trained in accordance with the Constellation Nuclear approved First Aid Program. First-Aid Teams will likely be augmented with additional personnel such as Fire Brigade Members and other personnel qualified to assist in the rescue.

4. Emergency Response Organization Training Program

CRANE ERO personnel who are responsible for implementing this plan receive specialized training. The training program for emergency response personnel is developed based on the requirements of 10 CFR 50, Appendix E and position specific responsibilities as defined in this document.

On-Shift emergency response personnel perform emergency response activities as an extension of their normal duties and are trained annually as part of their duty specific training. Additional Emergency Preparedness information is provided as part of the Station Nuclear General Employee Training.

New ERO personnel receive an initial overview course that familiarizes them with the Emergency Plan by providing basic information in the following areas as well as specific information as delineated in the sections below:

- Planning Basis
- Emergency Classifications
- Emergency Response Organization and Responsibilities
- Call-out of Emergency Organization
- Emergency Response Facilities
- Communications Protocol/Emergency Public Information
- Offsite Organizations

Emergency response personnel in the following categories receive knowledge and/or performance based training initially and retraining thereafter once per calendar year not to exceed 18 months between training sessions.

a. Directors, Managers and Coordinators within the station and corporate ERO:

Personnel identified by the Emergency Response Organization Telephone Directory as Directors, Managers and Coordinators for the station and corporate EROs receive training appropriate to their position in accordance with the approved ERO Training Program. These personnel receive specialized training in the areas of:

- Notifications
- Emergency Classifications
- Protective Action Recommendations
- Emergency Action Levels
- Emergency Exposure Control

Selected Directors, Managers, Coordinators and Shift Emergency Directors receive training in accordance with the approved ERO Training Program. Training in accident assessment sufficient to classify an event and to mitigate the consequences of an event are also covered.

b. Personnel Responsible for Accident Assessment:

The skills and knowledge required to perform plant stabilization and mitigation are a normal function of operations specific positions, as identified in Section B of this plan. Power changes and planned and unplanned reactor shutdowns are handled on a normal operation basis. Subsequent plant stabilization and restoration is pursued utilizing normal operating procedures. Licensed Operators receive routine classroom and simulator training to ensure proficiency in this area.

1) Active Senior Licensed Control Room Personnel shall have training conducted in accordance with the approved ERO Training Program such that proficiency is maintained on the topics listed below. These subjects shall be covered as a minimum on an annual basis.

- Event Classification.
- Protective Action Recommendations.
- Radioactive Release Rate Determination.
- Notification form completion and use of the Nuclear Accident Reporting System (NARS).
- Federal, state and local notification procedures as appropriate.

- Site specific procedures for activating the onsite and offsite ERO.

To remove peripheral duties from the Operations shift, the following group of positions responsible for accident assessment, corrective actions, protective actions, and related activities receive the training listed below:

2) Core Damage Assessment Personnel: During an emergency when core/cladding damage is suspected, a specialized group of trained individuals perform core damage assessment. At a minimum, personnel responsible for core damage assessment receive classroom and hands-on training in the following areas:

- Available Instrumentation and Equipment
- Isotopic Assessment and Interpretation
- Computerized Core Damage Assessment Methodology (CDAM) and/or proceduralized assessment methods.

c. Radiological Monitoring Teams and Radiological Analysis Personnel

1) Offsite Radiological Monitoring: Offsite radiological monitoring is performed by trained individuals who provide samples and direct readings for dose assessment calculations and dose projection comparisons.

Personnel identified as members of Field Monitoring Teams receive training in accordance with the approved training program. Field Monitoring Team members receive classroom and hands-on training in the following areas:

- Equipment and Equipment Checks
- Communications
- Plume Tracking Techniques

2) Personnel Monitoring: Personnel monitoring is performed by trained individuals who monitor station personnel and their vehicles for contamination during an emergency. Personnel Monitoring Team members receive classroom and hands-on training in the following areas:

- Personnel Monitoring Equipment and Techniques
- Decontamination Techniques for Personnel
- Decontamination Techniques for Vehicles

3) **Dose Assessment:** Dose Assessment training includes the skills and knowledge necessary for calculation and interpretation of an offsite release and its impact on the environment under varying meteorological conditions. Individuals responsible for performing dose assessment are trained in the following areas:

- Computerized Dose Assessment
- Protective Action Recommendations
- Field Monitoring Team Interface
- Protective Action Guidelines associated with offsite plume exposure doses
- Basic Meteorology

d. **Police, Security, and Fire Fighting Personnel**

1) **Local Police and Fire Fighting Personnel:** The local Police and Fire Departments are invited to receive training as outlined in Part 1.a of this section.

2) **Security Personnel:** Station security personnel are trained in accordance with training defined by the Nuclear General Employee Training (NGET) and Constellation Nuclear Security Program.

3) **Fire Control Teams (fire brigades):** Station fire brigades are trained in accordance with training defined by the Constellation Nuclear Fire Protection Program. Fire Brigade personnel are considered the primary members of rescue teams and will receive the appropriate EP training as part of their training program. Training also includes rescue of personnel from hazardous environments.

e. **Repair and Damage Control Teams:** Operations, Maintenance and Radiation Protection personnel are trained as part of their normal job specific duties to respond to both normal and abnormal plant operations.

Operations personnel are trained to: (1) recognize and to mitigate degrading conditions in the plant, (2) mechanically and electrically isolate damaged or malfunctioning equipment, (3) isolate fluid leaks, and (4) minimize transients.

Maintenance personnel are trained to troubleshoot and repair damaged or malfunctioning electrical, mechanical, or instrumentation systems as appropriate to their job classification.

Radiation Protection personnel are trained to assess the radiological hazards associated with equipment repair and instruct personnel as to the appropriate protective clothing requirements, respiratory protection requirements, stay times, and other protective actions specific to the conditions present.

At least 50% of personnel from those departments, who are potential responders to the OSC as Damage Control Team members, are required to be qualified in the use of respiratory protection equipment. This includes in-plant supervision and craft/technicians for the following departments:

- Operations
- Radiation Protection/Chemistry
- Maintenance (mechanical, electrical and I&C)

f. First Aid and Rescue Personnel: First aid and rescue team members receive training as outlined in Part 3 of this section.

g. Local Support Service Personnel: Local support service personnel providing assistance during an emergency are invited to receive training as outlined in Parts 1.a and 1.b of this section.

h. Medical Support Personnel: Onsite medical personnel receive specialized training in the handling of contaminated victims and hospital interface. Offsite ambulance and hospital personnel are offered annual training in accordance with a program provided by Emergency Preparedness.

i. Public Information Personnel: Corporate and station personnel responsible for disseminating emergency public information and responding to media and public information requests receive specialized public information training.

j. Communications Personnel: ERO personnel receive training on communications protocol as a part of the initial Emergency Response Overview Course. Personnel using specialized communications equipment that is not part of their normal daily function receive initial and requalification training on the equipment. Personnel involved in notifications to offsite agencies receive specialized training in the notification process.

5. General, Initial, and Requalification Training Program Maintenance

a. Station Departments and Emergency Preparedness share the responsibility for ensuring that the ERO receives all necessary training and retraining. In order to carry this out, responsibilities are assigned as follows:

Corporate Responsibilities for Corporate ERO Personnel

- Scheduling and conducting initial, retraining, and make-up classes.
- Acting as the sole contact point for ensuring attendance.
- Record keeping for the training courses, including dates of scheduled classes and non-attendance information.
- Verifying that all emergency response personnel training records are current.

- Ensure instructional materials are prepared and reviewed every two years.

Station Responsibilities for Station ERO Personnel

- Station management shall ensure the attendance of onsite personnel for training, including required Emergency Plan courses.
- Each Station shall conduct onsite emergency personnel initial and retraining for station Emergency Response Personnel using approved lesson plans.
- The Station Training Department shall provide those shift personnel included in a continuing training program an annual review of the following items as a minimum:
 - Assembly Areas
 - Emergency Response Facility assignment
 - Potential Hazards (radiological and non-radiological)
 - Anticipated actions including assembly requirements, protective equipment requirements (clothing, masks, SCBA, etc.), the use of KI, emergency exposure limits and accountability requirements.

b. **Initial and Requalification ERO Training:** The proficiency of emergency response personnel (as defined in 10 CFR 50 Appendix E) is ensured by the following means:

- Assigning persons to emergency duties that are similar to those performed as a part of their regular work assignment or experience.
- Initial training and annual retraining on applicable generic and site-specific portions of the Emergency Plan and the corresponding implementing procedures. Individuals not demonstrating the required level of knowledge in initial or retraining classes receive additional training on the areas requiring improvement. Annual retraining is conducted **once** per calendar year not to exceed 18 months between training sessions.
- Training is required for changes to the Emergency Plan and Station Annexes that are not editorial or minor in nature including changes that impact the resources, capabilities, or methods associated with Planning Standards, Program Elements, or 10CFR50 Appendix E, and modify program requirements or commitments. Training on Emergency Plan changes shall be completed within one hundred twenty (120) days of implementation of the change.

- Participation in exercises and/or drills as developed or authorized by the Emergency Preparedness Department and designed to sharpen those skills that they are expected to use in the event of a nuclear emergency.

All personnel assigned position specific responsibilities in the ERO are documented by inclusion in the Emergency Response Organization Telephone directory listing of positions and personnel.

- c. Nuclear General Employee Training (NGET): All personnel with unescorted station access are provided with initial orientation training on the notification and instruction methods used in the event of an emergency. Additionally, all badged individuals also receive initial orientation on the basic principles of radiological safety including the effects of radiation and the theory and use of radiation detection devices. Appropriate actions for escorted individuals shall be the responsibility of the escort. NGET provides initial and annual requalification training on the basic elements of the Emergency Plan for all personnel working at the plant. Specifically, these elements include:

- Station emergency alarms and their meaning
- Assembly areas
- Site and Exclusion Area Evacuation procedures
- Special precautions and limitations during an emergency
- Purpose of the Emergency Plan

Section P: Responsibility for the Maintenance of the Planning Effort

This section describes the responsibilities for development, review and distribution of the Emergency Plan and actions that must be performed to maintain the emergency preparedness program. It also outlines the criteria for insuring that personnel who perform the planning are properly trained.

1. Emergency Preparedness Staff Training

The Emergency Preparedness staff is involved in maintaining an adequate knowledge of state of the art planning techniques and the latest applications of emergency equipment and supplies. At least once each calendar year each member of the Emergency Preparedness staff is involved in one of the following activities:

- Training courses specific or related to emergency preparedness.
- Observation of or participation in drills and/or exercises at other stations.
- Participation in industry review and evaluation programs.
- Participation in regional or national emergency preparedness seminars, committees, workshops or forums.
- Specific training courses in related areas, such as systems, equipment, operations, radiological protection, or Problem Identification & Resolution (PI&R).

2. Authority for the Emergency Preparedness Effort

The Site Vice President is responsible for the safe and reliable operation of the generating station. The issuance and control of this plan and the activities associated with emergency preparedness at CRANE shall be the overall responsibility of the Vice President, Licensing and Regulated. This individual is assigned the responsibility for overall implementation of the Emergency Plan and Station Annexes.

3. Responsibility for Development and Maintenance of the Plan

The Corporate Emergency Preparedness Managers are responsible for the overall radiological emergency preparedness program associated with the operation of the nuclear power stations within their respective responsibility and to administer the program to ensure availability of resources in the event of an emergency. The Corporate Emergency Preparedness Managers report to an EP Functional Area Manager who in turn reports to the Vice President, Licensing and Regulated.

The Emergency Preparedness Managers are assisted by regional corporate and Station Emergency Preparedness staff. Specific responsibilities include the following:

Program Administration

- Develop and maintain the Emergency Plan, Station Annex, implementing procedures and administrative documents.
- Develop and maintain 50.54(q) evaluations for changes to EP documents.
- Coordinate and maintain the EP Activities Schedule.
- Develop and maintain working relationships and coordinate meetings with Federal, state and local agencies.
- Ensure integration of plans between Constellation and offsite agencies.
- Provide an opportunity to discuss Emergency Action Levels and the availability of Nuclear Oversight audit results relating to interface with governmental agencies.
- Coordinate, negotiate and maintain agreements and contracts with offsite agencies and support organizations.
- Obtain Letters of Agreement with medical facilities, and medical consultants specifically skilled in the medical aspects of radiation accidents and other medical consultants as might be necessary for the case of a person involved in a radiation incident.
- Coordinate the development and annual distribution of the station's public information publication.
- Coordinate and administer the Self Evaluation Program to monitor and evaluate the adequacy of the Emergency Preparedness Program.
- Coordinate and support EP Self-Assessments, Audits and Inspections.
- Ensure the documentation and resolution of adverse conditions in the emergency preparedness program discovered through drills, audits, etc. in accordance with the Constellation Nuclear Corrective Action Program.
- Coordinate and develop Operational Experience responses.
- Coordinate, document and review Performance Indicator data and reports.
- Provide oversight of Drill and Exercise Performance (DEP) evaluations during Operator Requalification Training.
- Coordinate and conduct EP Event reviews and reports.

- Maintain adequate documentation/files to support EP activities.
- Develop and manage the EP budget.
- Maintain the Emergency Response Facilities (ERF) Telephone Directory.

Drills and Exercises

- Coordinate and maintain the EP Drill and Exercise Schedule.
- Coordinate and conduct exercises and drills.
- Coordinate NRC, FEMA, state, and local exercise scheduling and development activities.
- Coordinate drill and exercise scenario development activities.
- Develop and publish drill and exercise scenario manuals.
- Coordinate and perform controller and evaluator functions for drills and exercises.
- Coordinate response cells for drills and exercises.
- Develop and issue drill and exercise reports.

Facilities and Equipment

- Provide maintenance and administration of the Alert and Notification System (ANS).
- Provide maintenance of the ERO call-out system.
- Ensure the Emergency Response Facilities are maintained in a constant state of readiness.
- Coordinate and review the EP equipment inventories.
- Coordinate and conduct maintenance and testing of the communications systems.
- Maintain the EP computer applications.

ERO Qualification and Administration

- Develop and maintain ERO Lesson Plans, Examinations, and Qualification Cards.
- Maintain EP NGET training content.

- Coordinate, schedule and conduct ERO qualification and requalification training.
- Oversee the maintenance of ERO training records.
- Maintain and coordinate publishing of the ERO Duty Rosters.
- Provide adequate oversight and support for the training of offsite response personnel.
- Coordinate conduct of Emergency Medical Assistance Program training.
- Coordinate annual training for the media.

The CRANE Plant Manager is responsible for implementation of the Emergency Plan at CRANE. The Plant Manager has the following responsibilities for maintenance of the Emergency Preparedness Program:

- Ensure the adequate staffing and training of station ERO members.
- Schedule and conduct drills and exercises to maintain the state of readiness of the Emergency Preparedness Program.
- Ensure the operational readiness of station facilities and communication systems for use during an emergency.
- Ensure the operational readiness of station emergency equipment and supplies is maintained.
- Ensure the emergency response procedures and the training and retraining of Station Emergency Response personnel are maintained.

4. Emergency Plan and Agreement Revisions

The Emergency Plan, its Annex, and supporting Agreements are reviewed on an annual basis. This review may also include applicable state and local emergency response agencies based on established agreements.

The annual Emergency Plan review/update includes required changes identified during audits, assessments, training, drills, and exercises. The Emergency Preparedness Director is responsible for determining which recommended changes are incorporated into a plan or emergency procedure revision. In those years when the review does not warrant a revision, a letter to that affect will be issued.

The Emergency Plan and its Annex shall be revised as needed and the most current approved revisions shall remain in effect so long as they are certified as current. Revisions to the Emergency Plan are reviewed by the Station's Plant Operational Review Committee (PORC) prior to approval. Changes to the plan are made without NRC approval only if such changes do not result in a reduction in effectiveness of the plan per 10 CFR 50.54(q), and the plan as changed continues to meet the standards of 10 CFR 50.47(b) and the requirements of 10 CFR 50, Appendix E. Proposed changes that reduce or have a potential to reduce the effectiveness of the approved plan are not implemented without prior approval by the NRC.

- Proposed revisions to the Emergency Plan and Station Annex shall be completed in accordance with the Constellation Nuclear review and approval processes.
- Emergency Plan and Station Annex changes shall be categorized as (1) minor/administrative or (2) significant programmatic changes. Minor/administrative changes shall be implemented within 30 days of approval. Significant programmatic changes shall be implemented as soon as practical and within 60 days of final approval.
- After review and approval, the Emergency Plan and Station Annex shall be:
 - a) Reviewed by the applicable Emergency Preparedness Manager(s) and EP Corporate Functional Area Manager, or designee(s), and
 - b) Approved for use by the Vice President, Licensing and Regulated or designee.
- The Implementing Procedures shall be developed and revised concurrent with the Emergency Plan and Annex, and reviewed every two years.

Annually, each Letter of Agreement is reviewed and certified current in order to assure the availability of assistance from each supporting organization not already a party to the individual State Plan for Radiological Accidents.

5. Emergency Plan Distribution

Emergency Plan manuals, Station Annex, and implementing procedures are distributed on a controlled basis to the Emergency Response Facilities. All controlled documents holders are issued revision changes upon approval. Selected Federal, state, and local agencies, and other appropriate locations requiring them are also issued copies. Procedures are in place that control the revision of the Emergency Plan and require the use of revision bars and individual page identifications (i.e. section of plan, revision number, etc.).

6. Supporting Emergency Response Plans

Other plans that support this Emergency Plan are:

- MD 8.2, US Nuclear Regulatory Commission, "NRC Incident Response Program"
- National Response Framework (NRF), Nuclear/Radiological Incident Annex.

- Commonwealth of Pennsylvania Radiological Emergency Response Plan.
- Nuclear Station Security Plans - Note: The Station Security Plan contains industrial security information that must be withheld from public disclosure under provisions of 10 CFR 2.390(d).

7. Implementing and Supporting Procedures

Appendix 2 of this plan contains a listing, by number and title, of those procedures that implement this plan during an emergency. Additionally, administrative procedures that outline the steps taken to maintain the Constellation Emergency Preparedness Program have been developed and are listed in Appendix 2.

8. Cross Reference to Planning Criteria

The Plan is formatted in the same manner as NUREG-0654, FEMA-REP-1, Revision 1, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in support of Nuclear Power Plants." The use of this format lends itself to uncomplicated comparison of the criteria set forth in NUREG-0654, FEMA-REP-1.

9. Audit/Assessment of the Emergency Preparedness Program

To meet the requirements of 10 CFR 50.54(t), Constellation Nuclear Oversight shall coordinate an independent review the Emergency Preparedness Program to examine conformance with 10 CFR 50.47, 10 CFR 50.54, and 10 CFR 50 Appendix E. Included in the audit/assessment are the following:

- The Emergency Plan and associated implementing procedures.
- The Emergency Preparedness Training Program including drills and exercises.
- The readiness of the station Emergency Response Organization to perform its function.
- The readiness of facilities and equipment to perform as outlined in the plan and procedures.
- The interfaces between Constellation, the state, and county governmental agencies pertaining to the overall Emergency Preparedness Program.

Results of this audit are submitted for review to Corporate Management and the Station Vice President. The Emergency Preparedness Manager ensures that any findings that deal with offsite interfaces are reviewed with the appropriate agencies. Written notification will be provided to the state and counties of the performance of the audit and the availability of the audit records for review at Constellation facilities. Records of the audit are maintained for at least five years.

10. Maintenance of Emergency Organization Telephone Directory

Names and phone numbers of the Emergency Response Organization and support personnel shall be reviewed and updated at least quarterly.

Appendix 1: References

References consulted in the writing of this Emergency Plan are listed in this section. With exception of regulatory requirements, inclusion of material on this list does not imply adherence to all criteria or guidance stated in each individual reference.

1. 10 CFR 50.47, Emergency Plans
2. 10 CFR 50.72, Immediate Notification Requirements for Operating Nuclear Power Reactors
3. 10 CFR 50 Appendix B, Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants
4. 10 CFR 50 Appendix E, Emergency Planning and Preparedness for Production and Utilization Facilities
5. 10 CFR 20, Standards for Protection Against Radiation
6. 10 CFR 70, 73, and 100.
7. 33 CFR 153.
8. 40 CFR 110, 112, 116, 118, 265, 302, and 355.
9. 44 CFR 350.
10. 44 CFR 401.
11. 49 CFR 171 and 172.
12. NUREG-0654, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants," Revision 1, November 1980 and Revision 2, December 2019.
13. NUREG-0654, Supplement 1, "Criteria for Utility Offsite Planning and Preparedness."
14. NUREG-0654, Supplement 3, "Criteria for Protective Action Recommendations for Severe Accidents."
15. NUREG-0396, "Planning Basis for the Development of State and Local Government Radiological Emergency Response Plans in Support of Light Water Nuclear Power Plants," Dec. 1978.
16. NUREG-0578, "TMI-2 Lessons Learned Task Force Status Report and Short-Term Recommendations."
17. NUREG-0696, Functional Criteria for Emergency Response Facilities

18. NUREG-0737, Clarification of TMI Action Plan Requirements, dated October 1980.
19. NUREG-0737, Supplement 1, Requirements for Emergency Response Capability, December 1982.
20. NUREG-0728, "Report to Congress: NRC Incident Response Plan."
21. US NRC Regulatory Guide 1.101, "Emergency Planning and Preparedness for Nuclear Power Reactors," revision 4, July, 2003.
22. U.S. NRC Response Technical Manual (RTM-96)
23. NEI 99-01, Methodology for Development of Emergency Action Levels.
24. EPA 400-R-92-001, October 1991, "Manual of Protective Action Guides and Protective Actions for Nuclear Incidents."
25. FEMA-REP-10, Guide for Evaluation of Alert and Notification Systems for Nuclear Power Plants
26. FEMA Radiological Emergency Preparedness Program Manual, December 2023
27. FEMA-Guidance Memorandum, MS-1 "Medical Services"
28. Constellation Nuclear Quality Assurance Topical Report (QATR), NO-AA-10
29. INPO Emergency Resources Manual
30. "Maintaining Emergency Preparedness Manual," dated December, 1996 INPO 96-009.
31. "Federal Bureau of Investigation and Nuclear Regulatory Commission Memorandum of Understanding for Cooperation Regarding Threat, Theft, or Sabotage in U.S. Nuclear Industry," Federal Register, Vol. 44, p. 75535, December 20, 1979.
32. "Voluntary Assistance Agreement By and Among Electric Utilities involved in Transportation of Nuclear Materials," dated November 1, 1980.
33. Comprehensive Environmental Response, Compensation and Liability Act of 1980.
34. Accidental Radioactive Contamination of Human Food and Animal Feeds; Recommendation for State and Local Agencies, Volume 47, No. 205, October 22, 1982.
35. American Nuclear Insurers Bulletin #5B (1981), "Accident Notification Procedures for Liability Insureds".

36. "Potassium Iodide as a Thyroid Blocking Agent in a Radiation Emergency: Final Recommendations on Use," Federal Register Vol. 47, No. 125, June 29, 1982.
37. Letter from William J. Dircks, Executive Director for Operations, NRC, to Dr. Donald F. Knuth, President KMC, Inc. dated October 26, 1981.
38. INPO Coordination agreement on emergency information among USCEA, EPRI, INPO, NUMARC and their member utilities, dated April (1988).
39. Babcock and Wilcox Company, Post Accident Sample Offsite Analysis Program (1982).
40. ANI/MAELU Engineering Inspection Criteria For Nuclear Liability Insurance, Section 6.0, Rev. 1, "Emergency Planning."
41. NRC RIS 2006-12, Endorsement of Nuclear Energy Institute Guidance "Enhancement to Emergency Preparedness Programs for Hostile Action."
42. NRC Bulletin 2005-02, "Emergency Preparedness and Response Actions for Security-Based Events."
43. NRC Information Notice 2009-01, National Response Framework
44. American Nuclear Insurers Bulletin #11-01 (Rev. 2) (2024), "Emergency Notification Procedures for ANI Policyholders"

Appendix 2: Procedure Cross-Reference to NUREG-0654

Criteria	Planning Standard	Procedure/Document
NUREG-0654.II.A	Assignment of Responsibility (Organization Control)	EP-AA-120, Emergency Plan Administration
		Letters of Agreement
NUREG-0654.II.B	Onsite Emergency Organization	EP-AA-112, Emergency Response Organization (ERO) / Emergency Response Facility (ERF) Activation and Operation
NUREG-0654.II.C	Emergency Response Support and Resources	EP-AA-112-400, Emergency Operations Facility Activation and Operations
NUREG-0654.II.D	Emergency Classification System	EP-AA-111, Emergency Classification and Protective Action Recommendations
NUREG-0654.II.E	Notification Methods and Procedures	EP-AA-114, Notifications EP-MA-121-1002, Alert and Notification System (ANS) Program
NUREG-0654.II.F	Emergency Communications	EP-AA-114, Notifications
		EP-AA-124, Inventories and Surveillances
NUREG-0654.II.G	Public Education and Information	EP-AA-120, Emergency Plan Administration
NUREG-0654.II.H	Emergency Facilities and Equipment	EP-AA-112, Emergency Response Organization (ERO) / Emergency Response Facility (ERF) Activation and Operation
		EP-AA-121, Emergency Response Facilities and Equipment Readiness
		EP-AA-120-1006, EP Reportability – Loss of Emergency Preparedness Capabilities
		EP-AA-123, Computer Programs
		EP-AA-124, Inventories and Surveillances
		EP-AA-125-1004, Emergency Response Facilities & Equipment Performance Indicators Guidance
NUREG-0654.II.I	Accident Assessment	EP-AA-110, Assessment of Emergencies
		EP-AA-123, Computer Programs
NUREG-0654.II.J	Protective Response	EP-AA-113, Personnel Protective Actions
		EP-AA-123, Computer Programs
NUREG-0654.II.K	Radiological Exposure Control	EP-AA-110, Assessment of Emergencies
		EP-AA-113, Personnel Protective Actions
NUREG-0654.II.L	Medical and Public Health Support	EP-AA-120, Emergency Plan Administration
UREG-0654.II.M	Recovery and Reentry Planning and Post-Accident Operations	EP-AA-115, Termination and Recovery
		EP-AA-120-1002, Offsite Readiness Evaluation
NUREG-0654.II.N	Exercises and Drills	EP-AA-122, Drills & Exercises Program

PART III: Appendices

Constellation Nuclear

Criteria	Planning Standard	Procedure/Document
		EP-AA-125-1001, EP Performance Indicator Guidance
		EP-AA-125-1002, ERO Performance – Performance Indicators Guidance
		EP-AA-125-1003, ERO Readiness - Performance Indicators Guidance
NUREG-0654.II.O	Radiological Emergency Response Training	TQ-AA-113, ERO Training And Qualification
NUREG-0654.II.P	Responsibility for the Planning Effort: Development, Periodic Review and Distribution of Emergency Plans	EP-AA-1, Emergency Preparedness
		EP-AA-10, Emergency Preparedness Program Description
		EP-AA-11, Operating Stations Emergency Preparedness Process Description
		EP-AA-1101, EP Fundamentals
		EP-AA-1102, ERO Fundamentals
		EP-AA-120, Emergency Plan Administration
		EP-AA-125, Emergency Preparedness Self Evaluation Process
		Emergency Response Facilities Telephone Directory

Appendix 3: List of Corporate Letters of Agreements**Organization/Agreement Type**

Department Of Energy (DOE) Radiation Emergency Assistance Center/Training Site, REAC/TS (Letter on File)
Medical Consultant

Environmental, Inc. (P.O.)
Radiological Environmental Monitoring

Landauer, Inc. (P.O.)
Emergency Dosimetry

INPO (Letter on File)
Emergency Event Support

Murray & Trettel, Inc. (P.O.)
Meteorological Support

Teledyne Brown Engineering (P.O.)
Bioassay Analysis/Radiochemical Analysis

Red Alert Service (P.O.)
Fire Foam Supply

Appendix 4: Glossary of Terms and Acronyms

Accident Assessment	Accident assessment consists of a variety of actions taken to determine the nature, effects and severity of an accident and includes evaluation of reactor operator status reports, damage assessment reports, meteorological observations, seismic observations, fire reports, radiological dose projections, in plant radiological monitoring, and environmental monitoring.
Activation	<p>(1) "ERO Activation" is the process of initiating actions to notify and mobilize Emergency Response Organization (ERO) personnel following an event classification under the emergency plan.</p> <p>(2) "Facility Activation" refers to the decision to consider a facility fully operational based on the minimum staffing required in ERO staffing tables contained within the station specific Annex and the ability of facility staffing and equipment to perform its designed function(s).</p>
Annual	Frequency of occurrence equal to once per calendar year, January 1 to December 31.
Assembly/Accountability	A procedural or discretionary protective action taken for all persons within the security "Protected Area", which involves the gathering of personnel into pre-designated areas, and the subsequent verification that the location of these personnel is known.
Assessment Actions	Those actions taken during or after an emergency to obtain and process information that is necessary to make decisions to implement specific emergency measures.
Biennial	Frequency of occurrence equal to once per two calendar year periods.
Biennial Exercise	An event that tests the integrated capability and a major portion of the basic elements existing within an emergency plan. An exercise usually involves participation of personnel from state and local governments, utility personnel, and may involve participation of Federal government personnel.

Classification	The classification of emergencies is divided into FIVE (5) categories or conditions, covering the postulated spectrum of emergency situations. The first four (4) emergency classifications are characterized by Emergency Action Levels (EALs) or event initiating conditions and address emergencies of increasing severity. The fifth, the Recovery classification, is unique in that it may be viewed as a phase of the emergency, requiring specific criteria to be met and/or considered prior to its declaration.
Command and Control	When in Command and Control, the designated Emergency Director (Shift, Station or Corporate) has overall responsibility for Constellation Nuclear's emergency response efforts, including the nondelegable responsibilities of Command and Control.
Committed Dose Equivalent (CDE)	The Dose Equivalent to organs or tissues of reference that will be received from an intake of radioactive material by an individual during the 50-year period following the intake.
Corrective Action	Those emergency measures taken to lessen or terminate an emergency situation at or near the source of the problem, to prevent an uncontrolled release of radioactive material, or to reduce the magnitude of a release. Corrective actions include, equipment repair or shutdown, installation of emergency structures, firefighting, repair, and damage control.
Damage Assessment	Estimates and descriptions of the nature and extent of damages resulting from an emergency or disaster; of actions that can be taken to prevent or mitigate further damage; and of assistance required in response and recovery efforts based on actual observations by qualified engineers and inspectors.
Damage Control	The process of preventing further damage from occurring and preventing the increase in severity of the accident.
Decontamination	The reduction or removal of contaminated radioactive material from a structure, area, material, object, or person. Decontamination may be accomplished by (1) treating the surface so as to remove or decrease the contamination; (2) letting the material stand so that the radioactivity is decreased as a result of natural decay; and (3) covering the contamination.

Dedicated Communications	A communications link between two or more locations, access to which is limited to designated locations, and used only for the purpose intended. The communications link may be either telephone or radio.
Deep Dose Equivalent (DDE)	The dose equivalent at a tissue depth of 1 cm (1000 mg/cm^2); applies to external whole body exposure.
Dose	A generic term that means absorbed dose, dose equivalent, effective dose equivalent, deep dose equivalent, committed dose equivalent, committed effective dose equivalent, or total effective dose equivalent.
Dose Equivalent (DE)	The product of the absorbed dose in tissue, quality factor, and all other necessary modifying factors at the location of interest. The unit of dose equivalent is the Rem.
Dose Projection	The calculated estimate of a radiation dose to individuals at a given location (normally off-site), determined from the source term/quantity of radioactive material (Q) released, and the appropriate meteorological dispersion parameters (X/Q).
Dose Rate	The amount of ionizing (or nuclear) radiation to which an individual would be exposed per unit of time. As it would apply to dose rate to a person, it is usually expressed as rems per hour or in submultiples of this unit, such as millirems per hour. The dose rate is commonly used to indicate the level of radioactivity in a contaminated area.
Dosimeter	An instrument such as a Dosimeter of Legal Record (DLR), self-reading pocket dosimeter (SRPD), or electronic dosimeter (ED) for measuring, registering, or evaluating total accumulated dose or exposure to ionizing radiation.
Dosimeter of Legal Record (DLR)	Specific station type dosimeters used for monitoring personnel and the environment.
Drill	A supervised instruction period aimed at testing, developing and maintaining skills in a particular operation.
Early Phase	The period at the beginning of a nuclear incident when immediate decisions for effective use of protective actions are required and must be based primarily on predictions of radiological conditions in the environment. This phase may last from hours to days. For the purposes of dose projections it is assumed to last four days.

Emergency Action Levels (EALs)	A pre-determined, site-specific, observable threshold for a plant Initiating Condition that places the plant in a given emergency class. An EAL can be an instrument reading; an equipment status indicator; a measurable parameter (onsite or offsite); a discrete, observable event; or another phenomenon which, if it occurs, indicates entry into a particular emergency class.
Emergency Alert System (EAS)	A network of broadcast stations and interconnecting facilities which have been authorized by the Federal Communications Commission to operate in a controlled manner during a war, state of public peril or disaster, or other national or local emergency. In the event of a nuclear reactor accident, instructions/notifications to the public on conditions or protective actions would be broadcast by state or local government authorities on the EAS.
Emergency Director	Individual in Command and Control. One of the following: the Shift Emergency Director (Control Room), Station Emergency Director (TSC) or the Corporate Emergency Director (EOF).
Emergency Notification System (ENS)	The NRC Emergency Notification System hot line is a dedicated telephone system that connects the plant with NRC headquarters in White Flint, Maryland. It is directly used for reporting emergency conditions to NRC personnel.
Emergency Operations Facility (EOF)	Designated location from which the Licensee Emergency Response Organization conducts the company's overall emergency response in coordination with Federal, State and designated emergency response organizations.
Emergency Operating Procedures (EOPs)	EOPs are step-by-step procedures for direct actions taken by qualified operators to mitigate and/or correct an off normal plant condition through the control of plant systems.
Emergency Operations Center (EOC)	A facility designed and equipped for effective coordination and control of emergency operations carried out within an organization's jurisdiction. The site from which civil government officials (municipal, county, state, and Federal) exercise direction and control in a civil defense emergency.
Emergency Personnel	Those organizational groups that perform a functional role during an emergency condition. Within Constellation Nuclear, emergency personnel include the Managers and Directors of the Emergency Response Organization, accident assessment personnel, radiological monitoring teams, fire brigades, first aid teams and security personnel.

Emergency Planning Zones (EPZ)	That area surrounding a nuclear station in which emergency planning is conducted for the protection of the public. With respect to protecting the public from the plume exposure resulting from an incident, the EPZ is usually an area with a radius of about 10 miles surrounding the facility. With respect to the ingestion exposure pathway, the EPZ is usually an area with a radius of about 50 miles.
Emergency Preparedness	A state of readiness that provides reasonable assurance that adequate protective measures can and will be taken upon implementation of the Emergency Plan in the event of a radiological emergency.
Emergency Response Data System (ERDS)	ERDS is a continuous direct near real-time electronic data link between the licensee's onsite computer system and the NRC Operations Center that provides for the automated transmission of a limited data set of selected parameters.
Environmental Monitoring	The use of radiological instruments or sample collecting devices to measure and assess background radiation levels and/or the extent and magnitude of radiological contamination in the environment around the plant. This may be done in various stages such as pre-operational, operational, emergency, and post operational.
Essential Personnel	Essential personnel are those needed to achieve the goals and tasks as deemed necessary by the Station Emergency Director.
Evacuation	The urgent removal of people from an area to avoid or reduce high level, short-term exposure usually from the plume or from deposited activity.
Exclusion Area	An Exclusion Area is an area specified for the purpose of reactor site evaluation in accordance with 10 CFR 100. It is an area of such size that an individual located at any point on its boundary for two hours immediately following onset of the postulated release would not receive a total radiation dose to the whole body in excess of 25 rem or a total radiation dose of 300 rem to the thyroid from iodine exposure.
Exercise	An event that tests the integrated capability of a major portion of the basic elements existing within emergency preparedness plans and organizations.
Exercise Cycle	An eight-year period.

Fission Product Barrier	The fuel cladding, reactor coolant system boundary, or the containment boundary.
Hazardous Material	A substance or material which has been determined by the United States Secretary of Transportation to be capable of posing an unreasonable risk to health, safety, and property when transported in commerce, and which has been so designated in 49 CFR 172.
Health Physics Network (HPN) Line	In the event of a Site Area Emergency, the NRC HPN line will be activated by the NRC Operations center in White Flint, Maryland. This phone is part of a network that includes the NRC Regional Office and the NRC Operations Headquarters in White Flint, Maryland. This system is dedicated to the transmittal of radiological information by plant personnel to NRC Operations Center and the Regional office. HPN phones are located in the TSC and EOF.
High Radiation Sampling System	Post-accident sampling capability to obtain and perform radioisotopic and chemical analyses of reactor coolant and containment atmosphere samples.
Imminent	Mitigation actions have been ineffective and trended information indicates that the event or condition will occur within 2 hours.
Ingestion Exposure Pathway	The potential pathway of radioactive materials to the public through consumption of radiologically contaminated water and foods such as milk or fresh vegetables. Around a nuclear power plant this is usually described in connection with the 50-mile radius Emergency Planning Zone (50 mile EPZ).
Initiating Condition	A predetermined UNIT condition where either the potential exists for a radiological emergency or such an emergency has occurred.
Integrated Drill	A drill conducted in the year that a Biennial Exercise is not scheduled including at least two Emergency Response Facilities in order to demonstrate at least two of the functions of management and control of emergency response, accident assessment, protective action decision-making, or plant system repair and corrective action.
Intermediate Phase	The period beginning after the source and releases have been brought under control and reliable environmental measurements are available for use as a basis for decisions on additional protective actions.

Joint Information Center	A Corporate Emergency Facility activated by Constellation and staffed by Constellation, state, and Federal Public Information personnel. This facility serves as the single point of contact for the media and public to obtain information about an emergency.
Late Phase	The period beginning when recovery action designed to reduce radiation levels in the environment to acceptable levels for unrestricted use are commenced and ending when all recovery actions have been completed. This period may extend from months to years (also referred to as the recovery phase).
Local Evacuation	The evacuation of personnel from a particular area, such as a room or building.
Low Population Zone (LPZ)	As defined in 10 CFR 100.3, the area immediately surrounding the exclusion area which contains residents, the total number and density of which are such that there is a reasonable probability that appropriate protective measures could be taken in their behalf in the event of a serious accident.
Main Control Room	The operations center of a nuclear power plant from which the plant can be monitored and controlled.
Monthly	Frequency of occurrence equal to once per calendar month.
Non-Essential Site Personnel	Those personnel not needed for the continuing existence or functioning of the ERO. They are personnel not required to fill certain positions in the ERO. Identification of non-essential personnel is circumstance-oriented as determined by the Station Emergency Director.
Notification, Public	Public notification means to communicate instructions on the nature of an incident that prompted the public alerting/warning and on protective or precautionary actions that should be taken by the recipients of the alert. A state and local government process for providing information promptly to the public over radio and TV at the time of activating the alerting (warning) signal (ANS). Initial notifications of the public might include instructions to stay inside, close windows, and doors, and listen to radio and TV for further instructions. Commercial broadcast messages are the primary means for advising the general public of the conditions of any nuclear accident. (See Emergency Alert System.)

Off-Site	The area around a nuclear generating station that lies outside the station's "site boundary".
Offsite Dose Calculation Manual (ODCM)	<p>The ODCM presents a discussion of the following:</p> <ol style="list-style-type: none">1. The ways in which nuclear power stations can affect their environment radiologically2. The regulations which limit radiological effluents from the nuclear power stations; and3. The methodology used by the nuclear power stations to assess radiological impact on the environment and compliance with regulations.
On-Site	The area around a nuclear generating station that lies within the station's "site boundary".
Owner Controlled Area	Company owned property on which a Nuclear Station is located and may include Constellation Nuclear leased lands adjacent to that Nuclear Station.
Operations Support Center (OSC)	An emergency response facility at the Plant to which support personnel report and stand by for deployment in an emergency situation.
Personnel Monitoring	The determination of the degree of radioactive contamination on individuals, using standard survey meters, and/or the determination of dosage received by means of dosimetry devices.
Plume Exposure Pathway	The potential pathway of radioactive materials to the public through: (a) whole body external exposure from the plume and from deposited materials, and (b) inhalation of radioactive materials.
Population-at-Risk	Those persons for whom protective actions are being or would be taken. In the 10-mile EPZ the population-at-risk consists of resident population, transient population, special facility population, and industrial population.
Potassium Iodide	(Symbol KI) A chemical compound that readily enters the thyroid gland when ingested. If taken in a sufficient quantity prior to exposure to radioactive iodine, it can prevent the thyroid from absorbing any of the potentially harmful radioactive iodine-131.

Potential	Mitigation actions are not effective and trended information indicates that the parameters are outside desirable bands and not stable or improving.
Projected Dose	That calculated dose that some individuals in the population group may receive if no protective actions are implemented. Projected doses are calculated to establish an upper limit boundary.
Protected Area	That onsite area within the security boundary as defined in each station's Security Plan.
Protection Factor (PF)	The relation between the amount of radiation that would be received by a completely unprotected person compared to the amount that would be received by a protected person such as a person in a shielded area. PF = Shielded dose rate / Unshielded dose rate.
Protective Action	Those emergency measures taken for the purpose of preventing or minimizing radiological exposures to affected population groups.
Protective Action Guide (PAG)	Projected radiological dose values to individuals in the general population that warrant protective action. Protective Action Guides are criteria used to determine if the general population needs protective action regarding projected radiological doses, or from actual committed (measured) dose values.
Protective Action Recommendations (PARs)	Recommended actions to the States for the protection of the offsite public from whole body external gamma radiation, and inhalation and ingestion of radioactive materials. Access control and other recommendations concerning the safeguards of affected food chain processes may be issued by the States as PARs.
Public Alerting/Warning	The Alert and Notification System (ANS) for Crane relies on the Integrated Public Alert Warning System (IPAWS)-WEA (Wireless Emergency Alerts) and IPAWS-EAS (Emergency Alert System) as the primary means of alerting and notifying the public, respectively, and an independent electronic Mass Notification System (MNS) as the backup means.

Puff Release	A controlled containment vent that will be terminated prior to exceeding 60 minutes in duration and is less than the limit as defined in the Station Annex.
Quarterly	Frequency of occurrence equal to once in each of the following four periods: January 1 through March 31; April 1 through June 30; July 1 through September 30; October 1 through December 31.
Recovery	The process of reducing radiation exposure rates and concentrations of radioactive material in the environment to levels acceptable for unconditional occupancy or use.
Release	A ' <i>Release in Progress</i> ' is defined as <u>ANY</u> radioactive release that is a result of, or caused by, the emergency event.
Restricted Area	Any area, access to which is controlled by Constellation for purposes of protection of individuals from exposure to radiation and radioactive materials.
Restricted Area Boundary	For classification and dose projection purposes, the boundary is a 400-meter (1/4-mile) radius around the plant. The actual boundary is specified in the ODCM.
Safety Analysis Report, Updated Final (UFSAR)	The UFSAR is a comprehensive report that a utility is required to submit to the NRC as a prerequisite and as part of the application for an operating license for a nuclear power plant. The multi-volume report contains detailed information on the plant's design and operation, with emphasis on safety-related matters.
Semi-Annual	Frequency of occurrence equal to once in each of the following periods: January 1 through June 30; July 1 through December 31.
Shall, Should, and May	The word "shall" is used to denote a requirement, the word "should" to denote a recommendation and the word "may" to denote permission, neither a requirement nor a recommendation.
Shielding	Any material or barrier that attenuates (stops or reduces the intensity of) radiation.
Site Boundary	The Site Boundary is described in detail in the ODCM.
Site Evacuation	The evacuation of non-essential personnel from the plant site.

Source Term	Radioisotope inventory or amount of radioisotope released to the environment, often as a function of time.
Technical Support Center (TSC)	A center outside of the Control Room in which information is supplied on the status of the plant to those individuals who are knowledgeable or responsible for engineering and management support of site operations in the event of an emergency, and to those persons who are responsible for management of the on-site emergency response.
Threshold Value	Measurable, observable detailed conditions which must be satisfied to determine an EAL applicability.
Thyroid Blocking Agent	An agent which when properly administered to an individual will result in sufficient accumulation of stable iodine in the thyroid to prevent significant uptake of radioiodine. Potassium Iodide is such an agent.
Total Effective Dose Equivalent (TEDE)	The sum of the deep dose equivalent (for external exposure) and the committed effective dose equivalent (for internal exposure) and 4 days of deposition exposure.
Unrestricted Area	Any area to which access is not controlled by the licensee for protecting individuals from exposure to radiation and radioactive materials, and any area used for residential quarters.
Vital Areas	Areas within the station security fence which contain vital equipment. Examples include Control Rooms, Reactor Buildings, Turbine Buildings and Electrical Equipment Rooms.
Vital Equipment	Any equipment, system, device or material, the failure, destruction, or release of which could directly or indirectly endanger the public health and safety by exposure to radiation. Equipment or systems which would be required to function to protect public health and safety following such failure, destruction, or release are also considered to be vital.
Weekly	Frequency occurrence equal to once per calendar week: Monday through Sunday.

Any abbreviation followed by a lower case 's' denotes the plural form of the term.

ACRONYMS

ac	alternating current
ALARA	as low as reasonably achievable
ANI	American Nuclear Insurers
ANS	Alert and Notification System
ANSI	American National Standards Institute
ARM	Area Radiation Monitor
ASLB	Atomic Safety Licensing Board
CB	citizen band
cc	cubic centimeter
CDE	Committed Dose Equivalent
CEOOC	County Emergency Operation Center
CFR	Code of Federal Regulations
CHRMS	Containment High Range Monitoring System
CHRRMS	Containment High Range Radiation Monitoring System
cm ²	square centimeter
CNO	Chief Nuclear Officer
cpm	count per minute
CR	Control Room
CRO	Control Room Operator
CRT	Cathode Ray Tube
Cs	Cesium
dc	direct current
DEP	Drill and Exercise Performance
DEQ	Department of Environmental Quality
DER/BRP	Dept of Environmental Resources, Bureau of Radiation Protection (PA)

PART III: Appendices

Constellation Nuclear

DFO	Disaster Field Office
DGI	Digital Graphics Incorporated
DHFS	Department of Health and Family Services
DLR	Dosimeter of Legal Record
DOE	U. S. Department of Energy
DOT	U. S. Department of Transportation
DPH	Department of Public Health
dpm	disintegration per minute
EAL	Emergency Action Level
EAS	Emergency Alerting System
EMA	Emergency Management Agency
ENC	Emergency News Center
ENS	Emergency Notification System (NRC)
EOC	Emergency Operations (or Operating) Center
EOF	Emergency Operations Facility
EOP	Emergency Operating Procedure
EPA	U. S. Environmental Protection Agency
EPDS	Emergency Preparedness Data System
EPZ	Emergency Planning Zone
ERF	Emergency Response Facility
ESF	Engineered Safety Feature
FEMA	Federal Emergency Management Agency
FRMAC	Federal Radiological Monitoring and Assessment Center
FRMAP	Federal Radiological Monitoring and Assessment Plan
FRPCC	Federal Radiological Preparedness Coordinating Committee
FSAR	Final Safety Analysis Report

PART III: Appendices

Constellation Nuclear

Ge	Germanium
GET	General Employee Training
GM	Geiger Mueller (radiation detection tube)
HEPA	high efficiency particulate air
HPN	Health Physics Network (NRC)
hr	hour
I	Iodine
INPO	Institute of Nuclear Power Operations
JIC	Joint Information Center
LGEOC	Local Government Emergency Operations Center
Li	Lithium
LOCA	Loss of Coolant Accident
LPZ	Low Population Zone
MAELU	Mutual Atomic Energy Liability Underwriters
MCP	Municipal Command Post
mR	milliroentgen
NARS	Nuclear Accident Reporting System
NCRP	National Council on Radiation Protection
NOP	Nuclear Organization Procedure
NRC	U. S. Nuclear Regulatory Commission
NRF	National Response Framework
NRR	Nuclear Reactor Regulation (NRC)
NWS	National Weather Service
NSRAC	Nuclear Safety Review and Audit Committee
OSC	Operations Support Center
PAG	Protective Action Guide
TBD	

PART III: Appendices

Constellation Nuclear

PANS	Prompt Alert and Notification System
PAR	Protective Action Recommendation
PASS	Post Accident Sampling System
PEMA	Pennsylvania Emergency Management Agency
QATR	Quality Assurance Topical Report
R	roentgen
RAA	Remote Assembly Area (off-site)
RAC	Regional Advisory Committee (FEMA)
REP	Radiological Emergency Preparedness
RERP	Radiological Emergency Response Plan
RMS	Radiation Monitoring System
SCBA	Self Contained Breathing Apparatus
SEOC	State Emergency Operations Center
SFCP	State Forward Command Post
SGTS	Standby Gas Treatment System
SPCC	Spill Prevention Control and Countermeasure
SPDS	Safety Parameter Display System
Sr	Strontium
SRC	State Radiological Coordinator
SSC	State Staging Center
STA	Shift Technical Advisor
TDD	Telecommunications Device for the Deaf
TEDE	Total Effective Dose Equivalent
TSC	Technical Support Center
μ Ci	microcurie
UFSAR	Updated Final Safety Analysis Report

Appendix 5

Table 5-1: Emergency Response Organization (ERO) Staffing and Augmentation Plan

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF - Alert or Greater Augment w/in 60 min.
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
Command and Control <ul style="list-style-type: none">Provide overall ERO command and control, until relieved.Approve emergency action level (EAL) and/ or protective action recommendation (PAR) classifications, until relieved.Authorize personnel dose extensions, until relieved.	(1) Shift Emergency Director	(1) Station Emergency Director	Not applicable	(1) Corporate Emergency Director
Communications³ <ul style="list-style-type: none">Communicate EAL and PAR classifications to offsite response organizations (OROs), including the NRC, until relieved.	Shift Communicator ¹	(1) ENS Communicator (TSC)	Not applicable	(1) State / Local Communicator
Radiation Protection⁴ <ul style="list-style-type: none">Provide qualified radiation protection coverage for responders accessing potentially unknown radiological environments during emergency conditions.Provide in-plant surveys.Control dosimetry and radiologically controlled area access.	(2) Radiation Protection Personnel	(3) Additional Radiation Protection Personnel [<i>In addition to personnel on-shift</i>] (OSC)	(3) Additional Radiation Protection Personnel [<i>In addition to personnel on-shift and those responding within 60 min.</i>] (OSC)	Not applicable

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF - Alert or Greater Augment w/in 60 min.
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
<p>Supervision of Radiation Protection Staff and Site</p> <p>Radiation Protection</p> <ul style="list-style-type: none"> • Evaluate and assess plant and offsite radiological data in the development of onsite protective actions and offsite PARs, until relieved. • Recommend onsite protective actions and offsite PARs to the applicable decision- maker, until relieved. • Direct all radiation protection activities, including field monitoring team (FMT) direction, until relieved. • Provide relevant information to applicable communicators who are communicating offsite PARs to OROs, until relieved. 	(1) Shift Emergency Director	(1) TSC Radiation Protection Manager (RPM) (TSC)	Not applicable	(1) EOF Radiation Protection Manager (EOF)
<p>Dose Assessments/Projections</p> <ul style="list-style-type: none"> • Perform dose assessments/projections and provide input to applicable PAR decision- maker, until relieved. 	(1) Shift Dose Assessor 1,	Not applicable	Not applicable	(1) Dose Assessment Coordinator (EOF)

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF - Alert or Greater Augment w/in 60 min.
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
Emergency Classifications <ul style="list-style-type: none">Evaluate plant conditions and recommend emergency classifications, until relieved.	Emergency Classification Advisor ¹	(1) Operations Manager (TSC)	Not applicable	Not applicable
Engineering <ul style="list-style-type: none">Provide engineering coverage related to the specific discipline of the assigned engineer, until relieved.	(1) Core/ Thermal Hydraulics Engineer - STA ¹ <ul style="list-style-type: none">Evaluate reactor conditions.	TSC Engineering Staff <ul style="list-style-type: none">(1) Electrical/ Instrumentation and Control (I&C): Provide engineering coverage for the ERO related to electrical or I&C equipment.(1) Mechanical: Provide engineering coverage for the ERO related to mechanical equipment.(1) Core/Thermal Hydraulics: Evaluate reactor conditions.	As needed	Not applicable
Security	Security staffing per the site-specific security plan.	(1) Security Coordinator (TSC) <ul style="list-style-type: none">Coordinate security- related activities and information with the Emergency Coordinator.	Not applicable	Not applicable

PART III: Appendices

Constellation Nuclear

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF - Alert or Greater Augment w/in 60 min.
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
Repair Team Activities	Not applicable	<p>Maintenance Personnel (OSC)</p> <ul style="list-style-type: none"> • (1) Electrical Maintenance Technician: Provide electrical support for ECCS equipment, event mitigation, and equipment repair. • (1) Mechanical Maintenance Technician: Provide mechanical support for ECCS equipment, event mitigation, and equipment repair. 	<p>Maintenance Personnel (OSC)</p> <ul style="list-style-type: none"> • (1) I&C Technician: Provide assistance with logic manipulation, support for event mitigation and equipment repair, and support of digital I&C if applicable. Additional I&C staff may be called out if needed. • Electrical Maintenance Technicians – As needed. • Mechanical Maintenance Technicians – As needed. 	Not applicable

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF - Alert or Greater Augment w/in 60 min.
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
Supervision of Repair Team Activities	Not applicable	<p>(1) OSC Director/Repair Team Lead</p> <ul style="list-style-type: none"> Supervise OSC activities as directed by Emergency Coordinator. 	<p>OSC Supervisors</p> <ul style="list-style-type: none"> (1) Electrical Maintenance Supervisor /Lead: Supervise OSC activities related to electrical equipment. (1) Mechanical Maintenance Supervisor / Lead: Supervise OSC activities related to mechanical equipment. (1) I&C Supervisor / Lead: Supervise OSC activities related to I&C equipment. May be combined with Electrical Supervisor. (1) Radiation Protection Supervisor / Lead: Supervise OSC activities related to radiation protection. 	Not applicable

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF - Alert or Greater Augment w/in 60 min.
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
Field Monitoring Teams (FMTs)	Not applicable	<p>Onsite FM Individual</p> <ul style="list-style-type: none"> • (1) Qualified individual to assess the protected area for radiation and contamination and provide input to the TSC RPM. • Responsible for radiation protection coverage for the FMT as directed by TSC RPM or EOF RPM. • <p>Offsite FMT A</p> <ul style="list-style-type: none"> • (1) Qualified individual to assess the area(s) outside the protected area for radiation and contamination, and for radioactive plume tracking, as directed by, and under the control of, the EOF DAC or RPM. Responsible for the radiation protection coverage of the FMT as directed by EOF RPM. • (1) Driver to provide transportation. 	<p>Offsite FMT B</p> <ul style="list-style-type: none"> • (1) Qualified individual to assess the area(s) outside the protected area for radiation and contamination, and for radioactive plume tracking, as directed by, and under the control of, the EOF DAC or RPM. • Responsible for the radiation protection coverage of the FMT as directed by EOF RPM. • (1) Driver to provide transportation. 	Not applicable

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF/JIC - Alert or Greater ² Augment w/in 90 min.
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
Media Information <ul style="list-style-type: none">Manage and coordinate media information related to the event.	Not applicable	Not applicable	Not applicable	(1) Corporate Spokesperson (1) JIC Director (1) Public Information Director

Emergency Preparedness (EP) Functions	On-Shift	TSC / OSC		EOF/JIC - Alert or Greater ² Augment w/in 90 Min
		Alert or Greater Augment w/in 60 min.	Alert or Greater Augment w/in 90 min.	
JIC/EOF Information Technology (IT)	Not applicable	Not applicable	Not applicable	(1) EOF/JIC Computer Specialist (@ 90 min from Alert or higher) ¹

Notes:

1. Other personnel may be assigned this function if no collateral duties are assigned to an individual that are beyond the capability of that individual to perform at any given time.
2. Constellation's Communication Department will perform necessary JIC functions at the Unusual Event declaration and initially upon a higher initial EAL declaration. The JIC facility will be activated within 90 minutes of an Alert declaration; however, some functions may continue to be performed by the Constellation Communications Department. Some JIC functions such as Public Information Director, News Writer, Media Monitor, Rumor Control may be performed remotely.
3. Additional Communications will be staffed at the EOF or TSC if needed.
4. Note for the purposes of this table, RP Personnel consists of RP Technicians or qualified RP Staff members. This is consistent with the guidance provided in the NRC's Technical Basis for the Proposed Guidance in NUREG-0654/FEMA-REP-1, Section II.B, "Emergency Response Organization".