

## Long Mott Generating Station Preliminary Safety Analysis Report

Table 2.0-1: Long Mott Generation Station (LMGS) Site Characteristics (Sheet 1 of 3)

Site	Characteristic	LMGS Site Value	PSAR Section
Geography and Demograph	hy		
Exclusion Area Boundary (EAB)		400 m	Section 2.1.2
Low Population Zone (LPZ)		400 m	Section 2.1.2
Population Center Distance		22 mi (Victoria, TX)	Section 2.1.1.1
	Nearby Industrial, Transpor	tation, and Military Facilities	I.
Explosion Hazards		Probability of occurrences is less than 1.0E-6 per year	Section 2.2.3.3.7
Aircraft Hazards		Annual aircraft crash probability is less than 1.0E <sup>-</sup>	Section 2.2.2.7.1
	Meteo	prology	
Air Temperature and Humi	dity		
Maximum Dry-Bulb Temperature	2% Annual Exceedance	94.1 °F (DBT) 76.6 °F (MCWB)	Section 2.3.1.2.6.2
	1% Annual Exceedance	95.9 °F (DBT) 76.6 °F (MCWB)	Section 2.3.1.2.6.2
	0.4% Annual Exceedance	97.9 °F (DBT) 76.5 °F (MCWB)	Section 2.3.1.2.6.2
	100-Year Return Period	84.7 °F (DBT) 75.2 °F (MCWB)	Section 2.3.1.2.6.2
Minimum Dry-Bulb Temperature	99% Annual Exceedance	34.5 °F	ASHRAE 2017 "Fundamentals" Victoria, TX
	99.6% Annual Exceedance	31.4 °F	ASHRAE 2017 "Fundamentals" Victoria, TX
	100-Year Return Period	54 °F	Section 2.3.1.2.6.2
	1% Annual Exceedance	79.8 °F	Section 2.3.1.2.6.2
Maximum Wet-Bulb	0.4% Annual Exceedance	80.3 °F	Section 2.3.1.2.6.2
Temperature	100-Year Return Period	84.3 °F	ASHRAE 2017 "Fundamentals" Victoria, TX
Basic Wind Speeds			
3-Second Gust		122 mph	Section 2.3.1.2.4
Hurricane			
Maximum Wind Speed		210 mph	RG 1.221, Figure 1 NUREG/CR-7005, App. B
Tornado			1
Maximum Wind Speed		200 mph	Section 2.3.1.2.2
1 Additional site-specific da groundwater model.	ata will be provided by the end of	second quarter 2026 to update	and recalibrate the
2 Additional site-specific and	alyses will be provided by the end o	f 2025.	
32 Additional site-specific a	nalyses and associated evaluations	for these items will be provided b	by the end of 2025.

SUBJECT TO DOE COOPERATIVE AGREEMENT NO. DE-NE0009040 Copyright © 2025 Long Mott Energy, LLC All Rights Reserved



## Table 2.0-1: Long Mott Generation Station (LMGS) Site Characteristics (Continued) (Sheet 2 of 3)

Site	Characteristic	LMGS Site Value	PSAR Section
Maximum Translational Speed		40 mph	Section 2.3.1.2.2
Maximum Rotational Speed		160 mph	Section 2.3.1.2.2
Radius of Maximum Rotational Speed		150 ft	RG 1.76, Table 1
		150 10	Region II
Maximum Pressure Drop		0.9 psi	RG 1.76, Table 1
			Region II
Rate of Pressure Drop		0.4 psi/s	RG 1.76, Table 1
		0.4 psi/s	Region II
Winter Precipitation		-	-
Normal Annual Snowfall		0.1 in	Section 2.3.1.2.5
Maximum Monthly Snowfall		2.1 in	Section 2.3.1.2.5
Short-Term (Accident Re	lease) Atmospheric Dispersion		
Control Room χ/Q		2.97E-03 s/m <sup>3</sup>	Section 2.3.4.2
DBAs (EAB/LPZ)		3.57E-04 s/m <sup>3</sup>	Section 2.3.4.3
Non-DBEs (EAB/LPZ)		1.89E-04 s/m <sup>3</sup>	Section 2.3.4.3
Long-Term (Normal Rele	ase) Atmospheric Dispersion		
Site Boundary 0.25 mi	Undepleted No Decay	1.00E-04 s/m <sup>3</sup>	Section 2.3.5 Table 2.3.5-2
	χ/Q Value		Table 2.3.3-2
	Undepleted 2.26-Day Decay	1.00E-04 s/m <sup>3</sup>	Section 2.3.5
	χ/Q Value	1.002 01 0/111	Table 2.3.5-2
0.23 1111	Depleted		Section 2.3.5
	8-Day Decay χ/Q Value	9.70E-05 s/m <sup>3</sup>	Table 2.3.5-2
	D/Q Value	3.50E-07 1/m <sup>2</sup>	Section 2.3.5
	·	3.50E-07 I/III	Table 2.3.5-2
Location of Interest Receptor 1 0.87 mi NNW	Undepleted No Decay	6.40E-06 s/m <sup>3</sup>	Section 2.3.5
	χ/Q Value	0.402-00 \$/111	Table 2.3.5-3
	Undepleted		Section 2.3.5
	2.26-Day Decay χ/Q Value	6.20E-06 s/m <sup>3</sup>	Table 2.3.5-3
	Depleted		Continuo 2.2.5
	8-Day Decay	5.60E-06 s/m <sup>3</sup>	Section 2.3.5 Table 2.3.5-3
	χ/Q Value		
	D/Q Value	3.90E-08 1/m <sup>2</sup>	Section 2.3.5 Table 2.3.5-3
Hydrology			
· • • • • • • • • • • • • • • • • • • •		Water level varies by	
Maximum Ground Water Elevation <sup>1</sup>		geologic strata and	Section 2.4.12
		seasonal variation	

<sup>1</sup> Additional site-specific data will be provided by the end of second quarter 2026 to update and recalibrate the groundwater model.

<sup>2</sup> Additional site specific analyses will be provided by the end of 2025.

<sup>32</sup> Additional site-specific analyses and associated evaluations for these items will be provided by the end of 2025.



## Table 2.0-1: Long Mott Generation Station (LMGS) Site Characteristics (Continued) (Sheet 3 of 3)

Site Characteristic	LMGS Site Value	PSAR Section
Maximum Still Water Flood Elevation <sup>2</sup> ©West Coloma Creek	32 ft	Section 2.4.2.2
Wave Runup <sup>2</sup> (West Coloma Creek)	1 ft	Section 2.4.2.2
Combined Effects Maximum Flood Elevation <sup>2</sup> (West Coloma Creek)	33 ft	Section 2.4.2.2
Maximum Still Water Flood Elevation On-Site Pond Failure (wave runup not applicable to this flooding mechanism)	32.5 ft	Section 2.4.4.3
Local Intense Precipitation	19.4 in/hr	Section 2.4.2.3.1 Table 2.4.2-5
Probable Maximum Storm Surge	36.38 <b>41.47 ft</b> (still water) 46.49 ft (with wave runup)	Section 2.4.5.6 <del>2.2.5</del>
Site Grade	31 ft	Section 2.4.10
Hydraulic Conductivity	Table 2.4.12-12	Section 2.4.12.2.2
Hydraulic Gradient	Table 2.4.12-12	Section 2.4.12.2.2
Geology, Seismology, and Geotechnical Engineering	•	1
Basic Geological and Seismic Information		
Capable Tectonic Structures	No capable tectonic structures within the site region.	Section 2.5.3.6
Foundation Type	Drilled Piers	Section 2.5.4.3
Lateral Soil Variability	Minor due to depositional environment	Section 2.5.4.2.1
Vibratory Ground Motion	<u> </u>	
Ground Motion Response Spectra	Figure 2.5.2-48	Section 2.5.2
	0.1853 g (horizontal)	Section 2.5.2,
Peak Ground Acceleration	0.1160 g (vertical)	Table 2.5.2-21
Stability of Subsurface Materials and Foundations		<u> </u>
Liquefaction Potential <sup>32</sup>	Site data from predominate cohesive site is being analyzed.	Section 2.5.4.6
Maximum Settlement <sup>3-2</sup>	3.8 in.	Section 2.5.4.10.2
Minimum Shear Wave Velocity <sup>32</sup>	Site data is being analyzed.  Vs <sup>30</sup> > 789 ft/sec from STP used.	Table 2.5.2-5
Fault Displacement Surface Deformation Potential	No	Section 2.5.3.2.2.3
Slope Failure Potential	No	Section 2.5.5.2
1 Additional site-specific data will be provided by the end groundwater model.	of second quarter 2026 to update	e and recalibrate the
2-Additional site specific analyses will be provided by the end	d of 2025.	
32 Additional site-specific analyses and associated evaluation	ns for these items will be provided I	by the end of 2025.