



# NRC QA Update

## **NRC Standards Forum Part II: Codes and Standard for Nuclear Energy Applications**

**Yamir Diaz-Castillo  
Reactor Operations Engineer  
Quality Assurance & Vendor Inspection Branch  
Division of Reactor Oversight  
Office of Nuclear Reactor Regulation**

# Quality Assurance Update

- Ongoing review of an alternative approach to meeting the requirements of Appendix B to 10 CFR Part 50 for the procurement of safety-related components and services: NEI 22-04, “Utilization of ISO 9001 and Other Non-nuclear Suppliers for Safety-Related Applications” (ADAMS Accession No. ML25162A176).
- Ongoing review of a process for allowing a licensee or applicant to accept for use safety-related ASME Code items that were fabricated by an ASME Certificate Holder prior to the identification of an Owner: NEI 25-05, “Fabrication of ASME Code Items Prior to the Identification of an Owner/Licensee” (ML25192A126).

# Quality Assurance Update

- Issuance of Information Notice (IN) 25-04, “Use of Approved Quality Assurance Alternatives During Exigent Conditions.”
  - The purpose of the IN is to inform the nuclear industry of the potential for inappropriate implementation of the QA alternatives approved for use during exigent conditions
- IN 25-06, “Lessons Learned from U.S Nuclear Regulatory Commission Inspections of Commercial Grade Dedication at Nuclear Power Plants.”
  - The purpose of the IN is to alert the nuclear industry to recent information related to lessons learned from the commercial-grade dedication inspections at nuclear power plants.



# QUESTIONS?

**Yamir Diaz-Castillo**  
**Reactor Operations Engineer**  
**301-415-2228**  
**[Yamir.Diaz-Castillo@nrc.gov](mailto:Yamir.Diaz-Castillo@nrc.gov)**

