

Event #: 58118	
Event Type: Part 21	
Reporting Org: RSCC dba Marmon	Notify Date/Time: 2024-07-25 11:05 (EDT)
Licensee:	Event Date/Time: 2024-07-23 00:00 (EDT)
	Modify Date/Time: 2026-02-05 13:56
Region: 1	
City: East Granby	Agreement State: No
County:	License #:
State: CT	
Notified by: Phillip Sargenski	Notifications: Lilliendahl, Jon R1DO
HOO: Robert A. Thompson	Feliz-Adorno, Nestor R3DO
Emergency Class: Non Emergency	Azua, Ray R4DO
10 CFR Sections:	Part 21/50.55 Reactors, - EMAIL
21.21(d)(3)(i) Defects And Noncompliance	
PART 21 REPORT - NON-COMPLAINT INSULATED CONDUCTOR	
* * * This is not a new Part 21 condition. This EN will document all updates for this Part 21 condition, originally documented in EN 57243 and described below, that are made after November 2025. Refer to EN 57243 for updates made after the initial notification through November 2025. * * *	
The following is a synopsis of information received via fax:	
A reel of insulated conductor was found non-compliant due to failure of insulation tensile and elongation at break test following air oven aging. Wire from the non-compliant reel was delivered to nine plants.	
Affected plants: Wolf Creek, Dresden, LaSalle, Limerick, Peach Bottom, Arkansas Nuclear One, Waterford, Susquehanna, and Davis Besse.	
Reporting company point of contact:	
RSCC Wire and Cable LLC	
dba Marmon Industrial Energy and Infrastructure	
20 Bradley Park Road	
East Granby, CT 06026	
Phillip Sargenski - Quality Assurance Manager	
Phone: 860-653-8376	
Fax: 860-653-8301	
Phillip.sargenski@marmoniei.com	
* * * UPDATE ON 12/04/2025 AT 1602 EST FROM CAROL GROSSO TO KERBY SCALES * * *	
The vendor provided an update on their ongoing evaluation. The vendor continues to receive product from their customers to perform testing and evaluations. Test results for completed testing have been forwarded to customers. The process is still ongoing.	
Notified R1DO (Schussler), R3DO (Hills), R4DO (Deese), and Part 21 group via email.	
* * * UPDATE ON 01/12/2026 AT 1351 EST FROM CAROL GROSSO TO BRIAN P. SMITH * * *	

The vendor provided an update on their ongoing evaluation. The vendor continues to receive product from their customers to perform testing and evaluations. Test results for completed testing have been forwarded to customers. The process is still ongoing.

Notified R1DO (Schussler), R3DO (Feliz-Adorno), R4DO (Dixon), and Part 21 group via email.

* * * UPDATE ON 02/05/2026 AT 1313 EST FROM CAROL GROSSO TO ERNEST WEST * * *

The following information was provided by the licensee via email:

"RSCC is awaiting samples from customers to complete our evaluation. As such, the evaluation is ongoing. To date, there has been no issues with the product we've received and tested. Test results have been forwarded to customers who have provided samples. We will continue this evaluation until all samples have been provided and we complete our testing."

Notified R1DO (Bickett), R3DO (Nguyen), R4DO (O'Keefe), and Part 21 group via email.