



December 11, 2025

Constellation Energy Company, LLC  
Dresden Clean Energy Center  
6500 North Dresden Road  
Morris, IL 60450-9709

**Subject:** 2025 Annual RGPP Monitoring Report  
Summary of Results and Conclusions  
Dresden Clean Energy Center  
Morris, Illinois

This letter report presents the summary of Radiologic Groundwater Protection Plan (RGPP) results for the 2025 groundwater and surface water monitoring rounds conducted at the Constellation Dresden Clean Energy Center site. RGPP data for previous monitoring rounds is summarized in AMO's semi-annual/quarterly reports.

### **Background**

In 2006, Conestoga-Rovers & Associates (CRA) was retained by Exelon Nuclear (now Constellation Energy Generation) to perform a hydrogeologic investigation at the Dresden Clean Energy Center to evaluate whether groundwater at or near the Site has been impacted by releases of radionuclides. Prior to performing the investigation, CRA evaluated available information concerning historic releases, as well as components, structures, and areas of the facility that have the potential to release radioactive liquid to the environment.

The results of the 2006 investigation identified that almost half of the 39 wells within the protected area showed measurable concentrations of tritium. It was concluded that the tritium in groundwater within the protected area came from historic spills from above ground tanks and leaks of underground lines within the protected area. Groundwater samples collected outside the protected area showed no detectable tritium for 24 of the 26 wells. The two exceptions for the wells outside the protected area include wells DSP 149(R) and DSP-159-I (M).

The results of the fleet wide study for the Dresden Clean Energy Center (the Site) are presented in the report, entitled *Hydrogeologic Investigation Report, Fleetwide Assessment, Dresden Generating Station, Morris, Illinois* (Conestoga-Rovers & Associates, September 2006). The referenced report also provides detailed descriptions of the Site's location, surrounding features and land use, subsurface geology and hydrogeology, and a summary of groundwater use in the area of the Site.

GHD completed four five-year update hydrogeologic investigation reports for the Site (*NEI 07-07, Hydrogeologic Investigation Report*, dated May 2011, December 2015, December 2020, and December 2025). The reports summarized Site activities since the 2006 hydrogeologic investigation, including changes at the Site that may potentially affect the RGPP, as well as RGPP sampling activities and groundwater flow. Relevant conclusions from the most recent 2025 report are:

- Tritium is not migrating off the Site at concentrations greater than the State of Illinois criteria of 200 pCi/L.
- Tritium in groundwater was detected at concentrations greater than the USEPA drinking water standard two times between 2020 and 2025. The tritium concentration in groundwater extraction well RW-DN-101S had a tritium concentration of 41,000 pCi/L in May 2021 and 20,400 pCi/L in November 2022. Extraction well RW-DN-101S was installed to assist the groundwater remediation in the area of a 2014

release at the “B” CST. The maximum detected tritium concentration in April 2025 was 6,100 pCi/L (monitoring well RW-DN-101S).

- No gamma-radionuclides associated with licensed plant operations were detected at concentrations greater than their respective LLDs.
- Select transuranics were not detected in samples collected between 2020 and April 2025.
- Nickel-63 (Ni-63) was detected at concentrations greater than the LLD (5 pCi/L) in samples collected from MW-DN-101I and MW-DN-119I between 2020 and 2022. However, Ni-63 was not detected in samples collected in 2024 and 2025.
- Strontium-90 (Sr-90) was detected at concentrations greater than the LLD (1 pCi/L) in samples collected from DSP-108 and MW-DN-105S between 2020 and 2023. However, Sr-90 was not detected in samples collected in 2024 and 2025.
- AFE-1 remains an ongoing tritium source to groundwater. No new AFEs were identified in 2025.
- One groundwater recovery well (RW-DN-100S) was extracting tritiated groundwater from the “B” CST area, south of the Unit 2 & 3 Turbine Building and discharging the groundwater to Outfall 002. However, this extraction well has not operated since December 2024 due to issues with the pump.

The next hydrogeologic investigation update is due by the end of 2030.

### “B” Condensate Storage Tank

Elevated tritium concentrations in surface water (Sewage Treatment Plant (STP) samples and RGPP surface water samples), shallow aquifer samples, and intermediate aquifer samples were detected during the 2<sup>nd</sup> quarter 2014 RGPP sampling round. The source of the tritiated groundwater was determined to be the “B” Condensate Storage Tank (CST) south of the Turbine Buildings. The groundwater sample collected from shallow aquifer well MD-11, which is in the immediate vicinity of the CST, had a tritium concentration of approximately 1.5 million pCi/L. Subsequent samples collected from MD-11 have had a maximum tritium concentration of approximately 2.3 million pCi/L (June 27, 2014). The CST was taken out of service and water from the CST removed. The CST was inspected and subsequently repaired in August 2015.

A tritium monitoring plan was developed and implemented in June 2014, with weekly sampling of surface water, storm sewer water, sewer treatment plant water, shallow aquifer groundwater, and intermediate aquifer groundwater to evaluate and delineate the tritium plume. A modified tritium monitoring plan was implemented in November 2014. Based on tritium data collected, the plume was relatively small and only encompassed the area between the CST and Turbine Building.

Two groundwater extraction wells (RW-DN-100S and RW-DN-101S) were installed in January 2015 to assist in the mitigation of tritiated groundwater in the area of the CST. Aquifer testing was completed on the two extraction wells near the end of 2015. Results of the aquifer test concluded that only RW-DN-100S produced sufficient water to operate as a viable groundwater extraction well. RW-DN-100S began intermittent operation during the 1<sup>st</sup> quarter 2016 and continued operating intermittently through August 2019. In August 2019, the extraction well began pumping groundwater on a continuous basis. The extracted water is discharged to the Kankakee River through NPDES permitted Outfall 002. However, this extraction well has not operated since December 2024 due to issues with the pump.

Overall, tritium concentrations in the area of the CST continue to decrease since the CST was repaired. As of the end of 2025, the maximum tritium concentration in the area of the CST was approximately 6,680 pCi/L (RW-DN-101S).

## MW-DN-119I Nickel 63

Hard-to-detect radionuclide Nickel-63 was detected at a concentration over 50 pCi/L in a sample collected during the 2<sup>nd</sup> quarter 2017. An investigation into the source of the Nickel-63 was completed and additional samples were collected from MW-DN-119I and surrounding wells. Results and recommendations of the evaluation are included in AMO's *Evaluation of Nickel -63 detections in MW-DN-119I Update* (March 28, 2018). Hard-to-detects (Fe-55 and Ni-63) are currently analyzed annually to monitor concentrations in the area of MW-DN-119I.

As of the end of 2025, Ni-63 was not detected in the sample collected from MW-DN-119I.

## Current RGPP Summary

The Site has 61 wells (twenty Background wells, twenty Source wells, six Mid-Field wells, ten Long-Term Shutdown wells, and five perimeter wells), that are part of the Site RGPP (EN-DR-408-4160 Revision 11). Note that Long-Term Shutdown well MW-DN-117I and Perimeter well MW-DN-108I were not sampled in 2025. MW-DN-117I has been covered by compacted gravel since 2020 and MW-DN-108I has been damaged since 2018. Figure 1a shows the shallow aquifer RGPP sample locations and Figure 1b shows the intermediate aquifer RGPP sample locations.

RGPP sampling at the Site is performed by Microbac, under contract to Constellation. Laboratory testing is performed by Teledyne Brown Engineering. The laboratory data, field data, and depth to water readings are uploaded to the RACER website, which is a data repository for the RGPP sampling rounds. The uploaded data is used by AMO for quarterly RGPP reporting.

## Gross-Alpha Alert Level

Gross-alpha (dissolved and suspended fractions) was analyzed annually from 2011 through 2019 at the Site. In 2020, gross-alpha data was evaluated to establish an Alert Level for the dissolved and suspended gross-alpha fractions. The gross alpha data was evaluated by looking at the average concentration for each gross-alpha fraction for each well. Statistical outlier results were considered during the gross-alpha evaluation. An outlier is a value that is significantly higher or lower than most of the results, that can skew the results and not reflect the true dataset. Therefore, outlier results are not factored into the average gross-alpha concentrations. Outliers were established using methods an online website such as *Statisticshowto.com*. Additional websites identified similar statistical models for removing outlier data.

Procedure EN-DR-408-4160 (Revision 9) established an Alert Level of three times the ongoing average gross-alpha concentration for each RGPP monitoring well that had gross-alpha analyzed more than one time and that will continue to be monitored for during future RGPP sampling rounds. Note that in 2024, the Alert Level changed from three times the ongoing average to three times the ongoing standard deviation. According to the EN-DR-408-4160 (Revision 10), samples from the eighteen Source designated sample points and ten Long-Term Shutdown designated wells will be analyzed once every two years for gross alpha dissolved and suspended fractions in the future. The Alert Level will be able to account for fluctuations in naturally occurring alpha activity in the area of wells, while identifying a result that may be indicative of a potential release. Beginning in 2021, select transuranics were analyzed if a gross alpha concentration exceeded the Alert Level in a particular well, to ensure that the Alert Level is conservative enough to detect whether licensed material could be present in groundwater. If the results of the select transuranics analysis showed no unusual activity, the gross-alpha result that triggered the select transuranics analysis, was incorporated into the ongoing average concentration for that well.

Table 1 provides a gross-alpha (dissolved and suspended) results summary as well as the average concentration and Alert Level for each well. Gross-alpha analysis was most recently performed on samples collected from Long-Term Shutdown and Source designated wells during the 2<sup>nd</sup> and 3<sup>rd</sup> quarter 2025 RGPP sampling rounds. Note that a sample could not be collected from Long-Term Shutdown well MW-DN-117I because the well was inaccessible in 2025. Gross-alpha (suspended) exceeded the Alert Level for the sample collected from MW-DN-107S during the 3<sup>rd</sup> quarter 2025 RGPP sampling round. Per the RGPP, a subsequent sample was collected from MW-DN-107S in

September 2025 and analyzed for select transuranics. No select transuranics associated with Site licensed material, were detected in the September 2025 sample.

Per the RGPP, all Long-Term Shutdown and Source designated wells will have gross-alpha analysis performed again in 2027.

### Tritium

The Site has 61 monitoring wells that are sampled for tritium. Samples collected from Long-Term Shutdown and Source designated wells are analyzed for tritium quarterly; samples collected from Mid-Field designated wells are analyzed for tritium semi-annually; and samples collected from the Perimeter and Background designated wells are analyzed for tritium annually.

### Gamma-Radionuclides

Gamma-radionuclide analysis has been performed on RGPP samples (quarterly to annually) at the Site since 2006. This extensive sampling and analysis produced over 19,300 data records for the Site. Site-related gamma-radionuclides have not been detected at concentrations greater than their respective LLDs, in RGPP samples submitted to the vendor laboratory since 2006. Therefore, in the 2020 RGPP, gamma-radionuclide analysis frequency was reduced from annual to every two years.

Samples collected from all RGPP wells were most recently analyzed for gamma-radionuclides during the 2<sup>nd</sup> and 3<sup>rd</sup> quarter 2025 RGPP sampling rounds. Note that a sample could not be collected from Long-Term Shutdown well MW-DN-117I, and Perimeter well MW-DN-108I because the wells were inaccessible in 2025. Site-related gamma radionuclides were not detected at concentrations greater than their respective LLDs in the samples collected in 2025. All wells will have gamma-radionuclide analysis performed again in 2027.

### Select Transuranics

Select transuranics analysis is procedurally required annually for RGPP sample locations that were identified as Elevated designated wells in the historic EN-DR-408-4160 revisions and continued additional evaluation is warranted. At the Dresden Site, these monitoring wells include MW-DN-124S, MW-DN-124I, and MD-11. Additionally, the current RGPP requires select transuranics analysis if a gross alpha concentration exceeds the Alert Level in a particular well, there is an unexpected increase in tritium activity, or if a non-tritium licensed material result exceeds the High Level as established by the RGPP. In 2025, the 3<sup>rd</sup> quarter gross-alpha (suspended) result for the sample collected from MW-DN-107S exceeded it's Alert Level. Therefore, a subsequent sample was analyzed for select transuranics.

Select transuranics analysis was performed on former Elevated designated wells MD-11, MW-DN-124S, MW-DN-124I, and MW-DN-107S during the 2<sup>nd</sup> or 3<sup>rd</sup> quarter 2025 RGPP sampling round. Select Transuranics were not detected at concentrations greater than their respective LLDs in the samples collected during the 2<sup>nd</sup> or 3<sup>rd</sup> quarter 2025 RGPP sampling round. Table 2 provides a summary of select transuranics results (U-233/234 and U-238) since 2006.

### Hard-to-Detects (Fe-55 and Ni-63)

Hard-to-detect analysis (Fe-55 and Ni-63) is procedurally required annually for RGPP sample locations that were identified as Elevated designated wells in the historic EN-DR-408-4160 revisions and continued additional evaluation is warranted, as well as Long-Term Shutdown designated wells. Wells previously designated as Elevated include MW-DN-124S, MW-DN-124I, and MD-11. As part of the current EN-DR-408-4160, hard-to-detect analysis is required on samples collected from Source designated wells once every 5 years, starting in 2021. Additionally, hard-to-detect analyses is required if there is an unexpected increase in tritium activity, or if a non-tritium licensed material result exceeds the High Level as established by the RGPP.

In 2025, samples collected from the nine Long-Term Shutdown designated wells and three former Elevated designated wells were analyzed for hard-to-detects (Fe-55 and Ni-63). Fe-55 and Ni-63 were not detected in the samples collected during the 2<sup>nd</sup> or 3<sup>rd</sup> quarter 2025 RGPP sampling round.

In 2026, samples collected from Source designated wells will be analyzed for hard-to-detects (Fe-55 and Ni-63) to be in conformance with the 5-year schedule.

### Sr-89 and Sr-90

Sr-89 and Sr-90 have been an annual procedurally required analysis on Detection, Long-Term Shutdown, and Elevated designated wells since sample point designations became part of the RGPP in 2010. The current EN-DR-408-4160 states that Sr-89 and 90 analyses should be performed annually for Source and Long-Term Shutdown designated sample locations. If a positive result is reported, samples collected from the wells with Sr-89 and Sr-90 detections will be analyzed quarterly to evaluate the activity in the area of the well. In 2025, samples collected from the twenty Source designated wells, nine Long-Term Shutdown designated wells, and one Mid-Field designated well (former Elevated designation) were analyzed for Sr-89 and Sr-90. Sr-89 and Sr-90 were not detected in any of the samples collected in 2025.

### Precipitation Recapture

The Site is a Boiling Water Reactor (BWR) generating Site. The RGPP requires BWR generating stations to sample precipitation on a semi-annual basis. The RGPP states that a minimum of eight samples should be collected from within the protected area in a manner that surrounds the Turbine Building and Reactor Building as well as ancillary structures that could vent tritiated vapor to the atmosphere.

In 2025, four sample rounds were completed in March, April, July, and October to evaluate if tritium was present in the atmosphere at the Site. Nine onsite samples were collected during the March 2025 sampling; ten onsite samples were collected during the April 2025 sampling; ten onsite samples were collected during the July 2025 sampling; and six onsite samples were collected during the October 2025 sampling round. A summary of 2025 precipitation recapture results is presented in Table 3 and sample locations are depicted on Figure 3. A summary of historic precipitation recapture results is provided in Appendix A.

Tritium was detected in one or more samples during three of the four sampling rounds completed in 2025. The maximum recapture tritium concentration in March 2025 was 815 pCi/L (FW-14 – northern sector); the maximum recapture tritium concentration in April 2025 was 622 pCi/L (FW-14 – northern sector); tritium was not detected in the samples collected in July 2025; and the only detection in samples collected in October 2025 was 226 pCi/L (FW-11 – east-southeast sector).

## **Summary of 2025 RGPP Sampling Rounds**

### ***March 2025 RGPP Sampling Round Activities (1<sup>st</sup> Quarter 2025)***

#### *Data Summary*

A total of 30 groundwater samples were collected during the 1<sup>st</sup> quarter 2025 sampling round. A sample was not collected from MW-DN-117I due to the well being inaccessible during the 1<sup>st</sup> quarter 2025. Per the RGPP, the Background, Perimeter, and Mid-Field designated wells were not sampled during the 1<sup>st</sup> quarter 2025 RGPP sampling round. All samples were analyzed for tritium.

Tritium was detected in ten shallow aquifer samples with a maximum tritium concentration of 9,930 pCi/L (RW-DN-101S). Tritium was detected in seven intermediate aquifer samples with a maximum tritium concentration of 2,540 pCi/L (MW-DN-124I).

The tritium concentration in MW-DN-111S averaged 412 pCi/L since the inception of the RGPP in 2006 through the 4<sup>th</sup> quarter 2019. The tritium concentration in MW-DN-111S increased from approximately 1,000 pCi/L to almost 3,500 pCi/L between the 4<sup>th</sup> quarter 2019 and 1<sup>st</sup> quarter 2020. The tritium concentration in the area of this well has been fluctuating between 1,470 pCi/L and 5,530 pCi/L since the 1<sup>st</sup> quarter 2020. The 1<sup>st</sup> quarter 2025 RGPP tritium result for this well was 6,200 pCi/L. The Site reviewed documents and performed an assessment of potential tritium sources in the area of MW-DN-111S and did not find any potential sources. The increased tritium activity in this well could be due to historic plumes migrating around the building structures.

The tritium concentration in MW-DN-141S increased from 2,910 pCi/L to 4,430 pCi/L between the 3<sup>rd</sup> and 4<sup>th</sup> quarter 2022 RGPP sampling rounds and shows an increasing tritium concentration trend since the beginning of 2022. The 1<sup>st</sup> quarter 2025 tritium result was 4,320 pCi/L. It was recommended that the Site evaluate SSCs in the area of MW-DN-141S for potential sources of the increased tritium activity and sample MW-DN-141S on a monthly basis to further evaluate the tritium concentration in the area of the well.

Tritium concentrations in samples collected from wells (other than MD-11 and extraction well RW-DN-101S) used to monitor the CST leak have decreased to less than 500 pCi/L, indicating the extent of the CST leak is confined to a small geographic area south of the Turbine Building.

#### *Water Elevations*

All groundwater sample locations, with the exception of MW-DN-117I, had depth to water measurements collected during the 1<sup>st</sup> quarter 2025 sampling round. The 1<sup>st</sup> quarter 2025 groundwater elevation data was compared to the 1<sup>st</sup> quarter 2024 sampling round to evaluate if changes in groundwater elevations occurred that may have an effect on groundwater flow direction. The variations in groundwater elevations have no significant effect on groundwater flow direction. Based on comparison of groundwater elevations, the wells sampled effectively monitored groundwater conditions at the Site.

#### ***April 2025 RGPP Sampling Round Activities (2<sup>nd</sup> Quarter 2025)***

##### *Data Summary*

A total of 59 groundwater samples were collected during the 2<sup>nd</sup> quarter 2025 sampling round. Samples were not collected from MW-DN-108I and MW-DN-117I due to inaccessibility or well damage. All samples were analyzed for tritium and gamma-radionuclides. The samples collected from Long-Term Shutdown and Source designated wells were also analyzed for gross-alpha (dissolved and suspended) and Sr-89/90. Samples collected from Long-Term Shutdown designated wells were also analyzed for hard-to-detects (Fe-55 and Ni-63). Samples collected from Mid-Field designated well MW-DN-124I and source designated well MW-DN-124S were also analyzed for select transuranics and hard-to-detects (Fe-55 and Ni-63).

Tritium was detected in ten shallow aquifer samples with a maximum tritium concentration of 6,100 pCi/L (RW-DN-101S). Tritium was detected in seven intermediate aquifer samples with a maximum tritium concentration of 1,460 pCi/L (DSP-107).

Elevated tritium activity in the area of MW-DN-111S continued during the 2<sup>nd</sup> quarter 2025 RGPP sampling round. The 2<sup>nd</sup> quarter 2025 RGPP tritium result for MW-DN-111S was 3,260 pCi/L. The increased tritium activity in this well could be due to historic plumes migrating around the building structures.

Tritium concentrations in samples collected from wells (other than MD-11 and extraction well RW-DN-101S) used to monitor the CST leak have generally decreased to less than 500 pCi/L, indicating the extent of the CST leak is confined to a small geographic area south of the Turbine Building.

While the tritium concentration in MW-DN-141S has been decreasing since the end of 2023, concentrations remained elevated in the 2<sup>nd</sup> quarter 2025 at 2,800 pCi/L. Due to the continued elevated tritium concentrations, it was recommended that the Site evaluate SSCs in the area of MW-DN-141S for potential sources of the increased

tritium activity and sample MW-DN-141S on a monthly basis to further evaluate the tritium concentration in the area of the well.

Select transuranics analysis was performed on samples collected from MW-DN-124S, and MW-DN-124I during the 2<sup>nd</sup> quarter 2025 RGPP sampling round. Select Transuranics were not detected at concentrations greater than their respective LLDs in the samples collected during the 2<sup>nd</sup> quarter 2025 RGPP sampling round.

No gamma-radionuclides related to Site licensed material, were detected at concentrations greater than their respective LLDs in the samples collected during the 2<sup>nd</sup> quarter 2025 RGPP sampling round.

Gross-alpha (dissolved) was detected in the sample collected from MW-DN-136S at 5.63 pCi/L. The result did not exceed the Alert Level for MW-DN-136S. The sample collected from MW-DN-141S had a non-detect result of 4.47 pCi/L, which exceeded the Alert Level. The turbidity in samples collected from this well have historically been high. The elevated detection limit for this sample is likely due to the turbidity in the sample. Therefore, while the result exceeded the Alert Level, additional analyses was not warranted since the result was non detect.

Ni-63 has historically been detected in samples collected from MW-DN-119I and MW-DN-101I. Ni-63 was not detected in any of the samples collected during the 2<sup>nd</sup> quarter 2025 RGPP sampling round.

Sr-90 has historically been detected in samples collected from MW-DN-105S and DSP-108. However, Sr-90 was not detected in the samples collected from these wells during the 2<sup>nd</sup> quarter 2025 RGPP sampling round. Sr-90 was also not detected in the other samples collected during the 2<sup>nd</sup> quarter 2025 RGPP sampling round.

#### *Water Elevations*

All groundwater sample locations had depth to water measurements collected during the 2<sup>nd</sup> quarter 2025 sampling round. The 2<sup>nd</sup> quarter 2025 sampling round groundwater elevation data was compared to the 2<sup>nd</sup> quarter 2024 sampling round to evaluate if changes in groundwater elevations occurred that may have an effect on groundwater flow direction. The variations in groundwater elevations have no significant effect on groundwater flow direction. Based on comparison of groundwater elevations, the wells sampled effectively monitored groundwater conditions at the facility.

### ***September 2025 RGPP Sampling Round Activities (3<sup>rd</sup> Quarter 2025)***

#### *Data Summary*

A total of 31 groundwater samples were collected during the 3<sup>rd</sup> quarter 2025 sampling round. A sample was not collected from MW-DN-117I due to inaccessibility. All samples were analyzed for tritium. The sample collected from MD-11 was also analyzed for gamma-radionuclides, gross-alpha (dissolved and suspended), select transuranics, hard-to-detects (Fe-55 and Ni-63), and Sr-89/90. The sample collected from MW-DN-107S was also analyzed for select transuranics.

Tritium was detected in five shallow aquifer samples with a maximum concentration of 7,550 pCi/L (RW-DN-101S). Tritium was detected in seven intermediate aquifer samples with a maximum concentration of 2,180 pCi/L (MW-DN-124I).

Elevated tritium activity in the area of MW-DN-111S continued during the 3<sup>rd</sup> quarter 2025 RGPP sampling round. The 3<sup>rd</sup> quarter 2025 RGPP tritium result for MW-DN-111S was 2,890 pCi/L. The increased tritium activity in this well could be due to historic plumes migrating around the building structures.

Elevated tritium activity in the area of MW-DN-141S continued during the 3<sup>rd</sup> quarter 2025 RGPP sampling round. The 3<sup>rd</sup> quarter 2025 RGPP tritium result for MW-DN-141S was 1,310 pCi/L. While tritium concentrations are lower than those reported in 2023, it was recommended that the Site evaluate SSCs in the area of MW-DN-141S

for potential sources of the increased tritium activity and sample MW-DN-141S on a monthly basis to further evaluate the tritium concentration in the area of the well.

Tritium concentrations in samples collected from wells (other than MD-11 and extraction well RW-DN-101S) used to monitor the CST leak have generally decreased to less than 500 pCi/L, indicating the extent of the CST leak is confined to a small geographic area south of the Turbine Building.

Gross-alpha (suspended) was detected in the samples collected from MW-DN-114S and MW-DN-107S at 1.05 pCi/L and 20.6 pCi/L, respectively. The gross-alpha (suspended) result for MW-DN-107S exceeded the Alert Level (11.18 pCi/L) for that well. Per the RGPP, a sample was collected from MW-DN-107S and analyzed for select transuranics.

Gamma-radionuclides, hard-to-detects (Fe-55 and Ni-63), select transuranics, and Sr-89/90 were not detected at concentrations greater than the laboratory detection limit in samples collected during the 3<sup>rd</sup> quarter 2025 RGPP sampling round.

#### *Water Elevations*

All groundwater sample locations had depth to water measurements collected during the 3<sup>rd</sup> quarter 2025 sampling round. The 3<sup>rd</sup> quarter 2025 sampling round groundwater elevation data was compared to the 3<sup>rd</sup> quarter 2024 sampling round to evaluate if changes in groundwater elevations occurred that may have an effect on groundwater flow direction. The variations in groundwater elevations have no significant effect on groundwater flow direction. Based on comparison of groundwater elevations, the wells sampled effectively monitored groundwater conditions at the facility.

#### ***October 2025 RGPP Sampling Round Activities (4<sup>th</sup> Quarter 2025)***

##### *Data Summary*

A total of 35 groundwater samples were collected during the 4<sup>th</sup> quarter 2025 sampling round. A sample was not collected from MW-DN-117I due to the well being inaccessible at the time of the 4<sup>th</sup> quarter 2025 RGPP sampling. All samples were analyzed for tritium. Tritium was detected in seven shallow aquifer samples with a maximum concentration of 6,680 pCi/L (RW-DN-101S). Tritium was detected in eight intermediate aquifer samples with a maximum concentration of 1,360 pCi/L (MW-DN-114I).

Elevated tritium activity in the area of MW-DN-111S continued during the 4<sup>th</sup> quarter 2025 RGPP sampling round. The 4<sup>th</sup> quarter 2025 RGPP tritium result for MW-DN-111S was 1,560 pCi/L. The increased tritium activity in this well could be due to historic plumes migrating around the building structures.

Elevated tritium activity in the area of MW-DN-141S continued during the 4<sup>th</sup> quarter 2025 RGPP sampling round. The 3<sup>rd</sup> quarter 2025 RGPP tritium result for MW-DN-141S was 1,430 pCi/L. While tritium concentrations are lower than those reported in 2023, it was recommended that the Site evaluate SSCs in the area of MW-DN-141S for potential sources of the increased tritium activity and sample MW-DN-141S on a monthly basis to further evaluate the tritium concentration in the area of the well.

Tritium concentrations in samples collected from wells (other than MD-11 and extraction well RW-DN-101S) used to monitor the CST leak have generally decreased to less than 200 pCi/L, indicating the extent of the CST leak is confined to a small geographic area south of the Turbine Building.

#### *Water Elevations*

All sampled groundwater locations had depth to water measurements collected during the 4<sup>th</sup> quarter 2025 sampling round. Groundwater elevations and groundwater flow direction for the shallow aquifer are provided on Figure 2a and groundwater elevations and groundwater flow direction for the intermediate aquifer are provided on Figure 2b.

Based on the groundwater flow depicted on figures 2a and 2b, the wells sampled effectively monitored groundwater conditions at the facility.

### **2026 RGPP Sample Locations**

Samples could not be collected from MW-DN-108I and MW-DN-117I in 2025 due to inaccessibility and/or well damage. Not being able to sample these wells and assess data associated with the area of these wells is considered a data gap. Therefore, these wells should be repaired and made accessible to sampling crews to complete the RGPP.

### **Summary of 2025 RGPP Conformance**

The Site did not conform with its RGPP in 2025 with respect to RGPP sampling protocol because water levels and samples were not collected from one Perimeter designated well and one Long Term Shutdown well. These wells have not been accessible for over two years.

### **Conclusions**

Based on the review of the data collected during the 2025 RGPP sampling rounds AMO concludes:

- The Site continued to implement the tritium monitoring plan for the “B” CST. The tritium concentrations in the area of the CST showed a decreasing trend at the Site through 2024. While the tritium concentration in MD-11 decreased from its maximum reported tritium concentration of approximately 2.29 million pCi/L, an elevated concentration persists in the area of the CST. However, tritium concentrations in samples collected from wells (other than MD-11 and extraction well RW-DN-101S) used to monitor the CST leak have generally decreased to less than 200 pCi/L, indicating the extent of the CST leak is confined to a small geographic area south of the Turbine Building.
- The tritium concentration in MW-DN-111S averaged 412 pCi/L since the inception of the RGPP in 2006 through the 4<sup>th</sup> quarter 2019. The tritium concentration in MW-DN-111S increased from approximately 1,000 pCi/L to almost 3,500 pCi/L between the 4<sup>th</sup> quarter 2019 and 1<sup>st</sup> quarter 2020. The tritium concentration in the area of this well has been fluctuating between 1,470 pCi/L and 5,530 pCi/L since the 1<sup>st</sup> quarter 2020. Tritium concentrations in samples collected from MW-DN-111S showed a decreasing trend in 2025. As of the end of October 2025, the tritium concentration in MW-DN-111S was 1,560 pCi/L. The increased tritium activity in this well is likely due to historic plumes migrating around the building structures.
- The tritium concentration in samples collected from MW-DN-141S ranged between 1,310 pCi/L (April 2025) and 4,320 pCi/L (March 2025).
- Gamma-radionuclides, Hard-to-detects (Fe-55 and Ni-63), select transuranics, and Sr-89/90 were not detected at concentrations greater than their respective LLDs in the samples collected in 2025 RGPP sampling rounds.
- Gross-alpha (suspended) was detected in the samples collected from MW-DN-114S and MW-DN-107S at 1.05 pCi/L and 20.6 pCi/L, respectively. The gross-alpha (suspended) result for MW-DN-107S exceeded the Alert Level (11.18 pCi/L) for that well. Per the RGPP, a sample was collected from MW-DN-107S and analyzed for select transuranics. No select transuranics were detected in the sample collected from MW-DN-107S in 2025.
- Based on recapture tritium results, shallow groundwater could potentially be affected by precipitation recapture.

- Samples were not collected from MW-DN-108I and MW-DN-117I in 2025 due to inaccessibility and/or well damage. Not being able to sample these wells and assess data associated with the area of these wells is considered a data gap.
- Based on the evaluation of groundwater flow direction, the wells sampled effectively monitored groundwater conditions at the facility.

Please call me at 215-230-8282 if you have questions.

Respectfully,

**AMO Environmental Decisions**

Ralph T. Golia, P.G.  
Principal  
Hydrogeologist

attachments

File

SITE	Well ID	Well Average (-Outliers)	ALERT LEVEL (STDEV - Outliers)	ALERT LEVEL (Hist Avg)	Gross Alpha - Dissolved Results																																							
					2011				2012				2013				2014				2015				2016				2017				2018				2019		2021		2023		2025	
					Feb	Mar	Jun	Dec	Mar	May	Jun	Mar	Jun	Jul	May	Jun	Jun	Nov	May	Jun	Aug	Oct	Feb	May	Nov	Feb	Jun	Sep	Nov	May	Dec	May	Jun	Apr	Jul									
Dresden	DSP-105	1.71	4.0577	5.14	--	--	--	--	--	0.611	--	--	1.15	--	--	3.06	1.9	--	--	2.5	--	--	--	1.79	--	--	1.31	--	--	1.39	--	--	--	--	--									
	DSP-106	1.63	3.6314	4.90	--	--	--	--	--	1.04	--	--	0.744	--	--	2.84	1.61	--	--	1.77	--	--	--	1.53	--	--	1.07	--	--	1.1	--	1.5	2.16	2.59	--									
	DSP-107	1.79	4.1177	5.36	1.05	--	--	--	--	0.847	--	--	1.03	--	--	2.96	1.74	--	--	2.72	--	--	--	2.73	--	--	1.17	--	--	1.21	--	1.35	2.14	2.48	--									
	DSP-108	3.56	7.9880	10.67	--	--	--	--	--	1.05	--	--	1.37	7.87	--	12.4	5.79	--	--	2.95	--	--	--	3.84	--	--	4.71	--	--	3.2	--	4.59	3.74	4.32	--									
	DSP-122	5.35	9.7889	16.04	6.93	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3.91	4.27	6.27	--										
	DSP-123	2.05	3.7495	6.14	0.893	--	--	--	--	1.99	--	--	1.71	--	--	2.45	--	--	2.81	--	--	--	--	1.7	--	--	1.86	--	--	1.95	--	5.29	11.4	2.49	--									
	DSP-124	3.62	9.5845	10.85	0.91	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3.58	5.62	4.35	--	--										
	DSP-125	8.36	16.0417	25.07	--	--	4.93	--	--	9.1	--	--	6.84	--	--	6.81	--	35.4	--	--	12.6	--	--	--	10.7	--	--	5.11	--	--	9.6	--	6.41	11.4	8.42	--								
	MD-11	1.18	1.9444	3.54	--	--	6.17	--	--	--	--	--	--	--	--	--	--	0.977	--	--	--	1.22	1.67	--	1.22	1.21	--	--	0.978	0.996	1.59	0.978	1.24	--	0.904									
	MW-DN-101-I	2.93	6.6397	8.79	--	--	--	--	--	2.39	--	--	1.25	--	--	2.32	--	1.26	--	3.05	--	--	--	4.81	--	--	4.6	--	--	1.86	--	3.14	3.6	3.95	--									
	MW-DN-101-S	4.23	11.3963	12.70	--	--	--	--	--	6.2	--	--	1.54	--	--	5.96	--	4.33	--	8.7	--	--	--	6.55	--	--	4.28	--	--	3.3	--	1.55	1.78	2.36	--									
	MW-DN-102-I	2.30	6.7215	6.89	--	--	0.675	--	--	--	1.46	--	1.29	--	--	3.03	4.08	--	2.63	--	--	--	--	13.8	--	--	4.46	--	--	0.758	--	--	--	--	--									
	MW-DN-102-S	19.59	44.9566	58.78	--	--	9.44	--	--	--	13.9	--	15.6	--	--	19.9	28.3	--	51.8	--	--	--	--	35.2	--	--	20.2	--	--	14.2	--	--	--	--	--									
	MW-DN-104-S	5.56	15.5601	16.69	2.44	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	7.55	9.21	3.05	--	--										
	MW-DN-105-S	5.06	8.0250	15.19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	6.2	4.57	4.42	--	--										
	MW-DN-106-S	#DIV/0!	#DIV/0!	#DIV/0!	--	--	1.42	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--									
	MW-DN-107-S	4.01	15.8648	12.03	--	--	--	6.37	9.86	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.895	1.45	--	1.48	--									
	MW-DN-108-I	1.53	3.0601	4.58	1.39	--	--	--	--	1.13	--	--	0.828	--	1.73	--	1.87	--	2.22	--	--	--	--	3.35	--	--	--	--	--	--	--	--	--	--	--									
	MW-DN-109-I	3.10	8.8607	9.30	--	--	--	--	--	1.04	--	--	0.499	--	0.936	--	3.81	--	4.29	--	--	--	--	4.02	--	--	3.79	--	--	3.71	--	6.06	5.07	0.883	--									
	MW-DN-109-S	5.01	11.1039	15.04	--	--	--	--	--	3.74	--	--	2.74	--	4.01	--	1.97	--	6.52	--	--	--	--	5.93	--	--	5.15	--	--	5.17	--	6.57	9.23	4.12	--									
	MW-DN-111-S	1.14	2.1199	3.42	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.816	1.13	1.47	--	--										
	MW-DN-113-I	2.31	6.6897	6.93	--	--	0.485	--	--	--	0.531	--	3.87	--	--	1.54	1.53	--	8.9	--	--	--	--	3.91	--	--	3.66	--	--	2.95	--	--	--	--	--									
	MW-DN-113-S	2.24	4.0151	6.71	--	--	2.34	--	--	--	1.76	--	2.56	--	--	2.08	1.45	--	3.02	--	--	--	--	3.16	--	--	2.1	--	--	1.65	--	--	--	--	--									
	MW-DN-114-S	1.89	3.9061	5.68	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1.12	2.32	--	2.24	--										
	MW-DN-115-S	3.13	4.0000	9.39	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3.42	2.84	3.13	--	--										
	MW-DN-116-I	3.01	5.8624	9.04	--	--	--	--	--	3.31	--	--	1.64	--	3.01	--	4.16	--	3.77	--	--	--	--	3.79	--	--	1.68	--	--	2.74	--	--	--	--	--									
	MW-DN-116-S	2.82	6.9243	8.45	--	--	--	--	--	2.53	--	--	3.55	--	1.15	--	5.21	--	4.83	--	--	--	--	3.82	--	--	1.57	--	--	2.08	--	1.97	2.79	1.5	--									
	MW-DN-117-I	1.06	1.5277	3.19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1	--	--	1.24	0.884	--	1.13	--	--	--	--	--									
	MW-DN-118-S	1.97	6.1185	5.91	--	--	--	--	--	0.745	--	--	1.24	--	--	1.84	0.897	--	4.81	--	--	--	--	2.34	--	--	0.551	--	--	1.11	--	1.41	3.97	2.77	--									
	MW-DN-119-I	3.20	5.6431	9.60	--	--	--	--	--	1.86	--	--	3.62	--	2.42	--	3.18	--	--	4.44	--	--	--	28.9	6.25	--	2.95	--	3.85	2.24	3.29	2.53	4.03	3.99	--									
	MW-DN-119-S	2.86	6.3760	8.57	--	--	--	--	--	2.35	--	--	1.55	--	4.23	--	4.95	--	--	7.23	--	--	--	1.57	--	--	3.03	--	--	2.98	--	1.44	2.92	3.53	--									
	MW-DN-122-I	#DIV/0!	#DIV/0!	#DIV/0!	--	1.41	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--									
	MW-DN-124-I	3.41	7.2523	10.22	2.13	--	--	--	--	2	--	--	3.35	--	--	9.99	4.06	--	5.33	--	--	--	--	7.19	--	--	3.74	--	--	4.15	--	3.99	1.09	4.23	--									
	MW-DN-124-S	3.96	8.5414	11.89	--	--	--	--	--	--	2.63	--	1.71	--	--	4.74	5.76	--	5.77	--	--	--	--	6.35	--	--	3.72	--	--	2.96	--	4.26	2.8	2.9	--									
	MW-DN-125-S	3.03	7.8080	9.09	--	--	--	--	--	--	2.62	--	1.83	--	--	4.83	1.38	--	--	3.63	--	--	--	30	--	--	5.32	--	--	1.6	--	--	--	--	--									
	MW-DN-126-S	6.58	19.3950	19.75	--	--	--	--	--	--	11.5	--	12.7	--	--	13.1	6.66	--	4.16	--	--	--	--	6.85	--	--	1.56	--	--	3.46	--	2.5	2.18	7.74	--									
	MW-DN-127-S	2.45	8.6690	7.35	--	--	--	--	--	2.1	--	--	2.36	--	--	5.27	1.09	--	2.03	--	--	--	--	5.89	--	--	0.476	--	--	0.393	--	--	--	--	--									
	MW-DN-134-S	2.78	6.1589	8.33	--	--	--	--	--	--	--	1.65	2.62	--	--	3.65	3.77	--	4.38	--	--	--	--	1.06	--	--	2.88	--	--	2.21	--	--	--	--	--									
	MW-DN-135-S	2.48	5.2802	7.44	--	--	--	--	--	--	--	2.81	4.2	--	--	1.64	1.7	--	3.21	--	--	--	--	2.06	--	--	1.5	--	--	2.71	--	--	--	--	--									
	MW-DN-136-S	5.27	11.9751	15.82	--	--	--	--	--	--	--	2.31	3.28	--	--	4.51	6.46	--	7.85	--	--	--	--	3.65	--	--	3.27	--	--	8.84	--	4.16	8.06	5.63	--									
MW-DN-137-S	4.88	11.5010	14.63	--	--	--	--	--	--	--	8.52	1.58	--	--	4.9	--	5.57	6.65	--	--	--	--	5.46	--	--	3.43	--	--	2.89	--	--	--	--	--										
MW-DN-140-S	2.20	5.0836	6.59	--	--	--	--	--	--	--	6.59	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1.1	2.59	--	2.9	--	--										
MW-DN-141-S	1.11	2.6101	3.34	--	--	--	--	--	--	--	0.837	0.769	--	2.08	--	1.33	--	1.12	--	--	--	--	0.78	--	--	0.722	--	--	0.852	--	0.757	1.89	4.47	--										
MW-DN-142-S	4.56	10.2241	13.67	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	7.27	--	--	2.98	--	--	4.31	--	--	3.66	--	--	--	--										
MW-DN-143-S	3.10	6.5062	9.31	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2.16	--	--	4.71	--	--	3.06	--	--	2.48	--	--	--	--										
MW-DN-144-S	3.66	6.7243	10.97	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	4.17	--	--	4.76	--	--	3.27	--	--	2.43	--	--	--	--										
RW-DN-100-S	5.22	8.1141	15.67	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	4.57	6.33	4.77	--	--											
RW-DN-101-S	4.10	10.8987	12.29	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1.48	5.48	5.33	--	--	--										

SITE	Well ID	Well Average (-Outliers)	ALERT LEVEL (STDEV - Outliers)	ALERT LEVEL (Hist Avg)	Gross Alpha - Suspended Results																															
					2011				2012			2013			2014		2015		2016			2017			2018				2019		2021	2023	2025			
					Feb	Mar	Jun	Dec	Mar	May	Jun	Mar	Jun	Jul	May	Jun	Jun	Nov	May	Jun	Aug	Oct	Feb	May	Nov	Feb	Jun	Sep	Nov	May	Dec	May	Jun	Apr	Jul	
Dresden	DSP-105	0.86	1.6990	2.59	--	--	--	--	--	0.82	--	--	0.793	--	--	0.63	0.923	--	--	0.599	--	--	--	0.617	--	--	1.13	--	--	1.39	--	--	--	--	--	
	DSP-106	0.66	1.4430	1.97	--	--	--	--	--	0.809	--	--	0.793	--	--	0.63	0.923	--	--	0.599	--	--	--	0.617	--	--	1.13	--	--	4.28	--	0.367	0.346	0.346	--	
	DSP-107	0.57	1.4383	1.72	0.345	--	--	--	--	0.349	--	--	0.361	--	--	0.63	0.918	--	4.74	--	--	--	0.618	--	--	1.13	--	--	0.896	--	0.367	0.346	0.346	--		
	DSP-108	0.65	1.4670	1.95	--	--	--	--	--	0.348	--	--	0.361	0.851	--	0.63	0.933	--	--	0.605	--	--	--	0.619	--	--	1.14	--	--	0.897	--	1.83	0.432	0.346	--	
	DSP-122	3.65	13.9159	10.94	0.245	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--		
	DSP-123	0.63	1.4084	1.89	0.614	--	--	--	--	0.347	--	--	0.601	--	1.9	--	0.923	--	0.608	--	--	--	--	0.617	--	--	1.16	--	--	0.719	--	0.369	1.74	0.346	--	
	DSP-124	0.69	1.4730	2.06	0.616	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.912	0.872	0.346	--		
	DSP-125	1.63	3.4944	4.88	--	--	1.28	--	--	0.66	--	--	1.69	--	1.9	--	0.892	--	--	2.88	--	--	--	2.21	--	--	1.65	--	--	3.72	--	1.84	1.75	1.15	--	
	MD-11	0.65	1.1808	1.94	--	--	0.639	--	--	--	--	--	--	--	--	--	--	0.711	--	--	--	0.777	0.347	--	0.822	0.624	--	--	0.844	0.898	0.628	0.366	0.6	--	0.49	
	MW-DN-101-I	0.76	1.6859	2.28	--	--	--	--	--	0.78	--	--	0.267	--	1.24	--	0.923	--	1.04	--	--	--	--	0.62	--	--	1.14	--	--	0.719	--	0.717	0.347	0.576	--	
	MW-DN-101-S	1.81	4.9505	5.42	--	--	--	--	--	1.12	--	--	0.695	--	1.24	--	0.962	--	3.41	--	--	--	--	13.55	--	--	1.73	--	--	3.82	--	2.14	1.77	1.17	--	
	MW-DN-102-I	1.02	3.3470	3.05	--	--	2	--	--	--	0.495	--	0.496	--	--	0.63	0.359	--	0.361	--	--	--	--	2.33	--	--	1.73	--	--	0.752	--	--	--	--		
	MW-DN-102-S	2.82	7.6781	8.45	--	--	3.58	--	--	--	1.8	--	1.88	--	--	0.63	2.14	--	4.99	--	--	--	--	3.8	--	--	1.37	--	--	5.16	--	--	--	--		
	MW-DN-104-S	3.57	10.3794	10.72	0.62	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3.59	6.14	3.94	--		
	MW-DN-105-S	6.35	16.4570	19.04	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3.58	10.1	5.36	--		
	MW-DN-106-S	#DIV/0!	#DIV/0!	#DIV/0!	--	--	1.17	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--		
	MW-DN-107-S	3.05	11.1769	9.16	--	--	--	2.5	6.96	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.742	2.01	--	20.6	--		
	MW-DN-108-I	2.12	11.2784	6.37	0.64	--	--	--	--	0.781	--	--	0.608	--	1.24	--	1.15	--	8.33	--	--	--	--	36.3	--	--	--	--	--	--	--	--	--	--		
	MW-DN-109-I	1.00	2.7634	3.00	--	--	--	--	--	0.502	--	--	0.604	--	1.24	--	0.51	--	0.357	--	--	--	--	1.84	--	--	1.6	--	--	1.48	--	3.56	1.52	0.346	--	
	MW-DN-109-S	1.53	4.6950	4.58	--	--	--	--	--	0.396	--	--	0.503	--	1.24	--	0.508	--	2.05	--	--	--	--	1.84	--	--	1.6	--	--	1.48	--	3.56	3.04	0.576	--	
	MW-DN-111-S	0.49	0.9032	1.48	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.517	0.617	0.347	--	--		
	MW-DN-113-I	2.70	11.8613	8.09	--	--	1.18	--	--	--	0.499	--	1.3	--	--	1.21	0.361	--	20.18	--	--	--	--	1.85	--	--	7.89	--	--	7.27	--	--	--	--		
	MW-DN-113-S	4.70	19.8243	14.10	--	--	0.649	--	--	--	1.63	--	0.446	--	--	2.47	3.24	--	15.7	--	--	--	--	7.59	--	--	8.62	--	--	1.94	--	--	--	--		
	MW-DN-114-S	0.86	1.5518	2.59	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.931	0.606	--	1.05	--		
	MW-DN-115-S	1.33	3.9226	4.00	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1.06	0.64	2.3	--	--		
	MW-DN-116-I	0.70	1.5728	2.11	--	--	--	--	--	1.02	--	--	0.503	--	1.24	--	0.503	--	0.374	--	--	--	--	0.623	--	--	0.627	--	--	0.726	--	--	--	--		
	MW-DN-116-S	0.74	1.4769	2.23	--	--	--	--	--	0.69	--	--	0.502	--	1.24	--	0.506	--	0.746	--	--	--	--	1.02	--	--	0.871	--	--	0.747	--	3.35	0.608	0.488	--	
	MW-DN-117-I	0.82	1.6274	2.46	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.807	--	0.491	0.831	--	1.15	--	--	--	--		
	MW-DN-118-S	0.85	1.9016	2.56	--	--	--	--	--	0.622	--	--	0.491	--	--	1.79	0.511	--	0.938	--	--	--	--	0.809	--	--	0.862	--	--	0.892	--	1.66	0.605	1.13	--	
	MW-DN-119-I	0.91	1.7870	2.72	--	--	--	--	--	0.62	--	--	1.03	--	2.83	--	0.515	--	--	0.912	--	--	--	2.78	0.85	--	0.501	--	0.981	1.54	1.03	0.849	1.22	0.814	--	
	MW-DN-119-S	2.53	8.2037	7.58	--	--	--	--	--	0.622	--	--	0.557	--	1.24	--	0.509	--	--	2.38	--	--	--	3.73	--	--	4.28	--	--	5.52	--	4.07	0.616	4.27	--	
	MW-DN-122-I	#DIV/0!	#DIV/0!	#DIV/0!	--	3.2	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	
	MW-DN-124-I	1.21	3.2975	3.64	0.345	--	--	--	--	0.491	--	0.665	--	--	1.21	1.28	--	1.73	--	--	--	--	2.78	--	--	1.5	--	--	1.5	--	4.33	0.613	1.23	--		
	MW-DN-124-S	1.94	5.9948	5.83	--	--	--	--	--	0.356	--	0.49	--	--	1.21	1.28	--	2.41	--	--	--	--	2.87	--	--	3.46	--	--	0.982	--	4.4	0.889	3.03	--		
	MW-DN-125-S	1.14	2.7651	3.43	--	--	--	--	--	0.362	--	0.798	--	--	1.21	1.94	--	--	0.739	--	--	--	--	2.87	--	--	1.51	--	--	1.44	--	--	--	--		
	MW-DN-126-S	1.87	3.6578	5.62	--	--	--	--	--	1.33	--	1.5	--	--	1.21	1.29	--	1.79	--	--	--	--	2.77	--	--	1.5	--	--	2.57	--	4.54	2.31	2.46	--		
	MW-DN-127-S	0.92	1.7664	2.77	--	--	--	--	--	0.817	--	--	0.488	--	--	1.21	1.34	--	0.731	--	--	--	--	0.815	--	--	0.862	--	--	1.13	--	--	--	--		
	MW-DN-134-S	0.72	1.3220	2.15	--	--	--	--	--	--	0.925	0.513	--	--	0.657	0.345	--	0.721	--	--	--	--	0.807	--	--	0.868	--	--	0.886	--	--	--	--	--		
	MW-DN-135-S	0.75	1.4555	2.25	--	--	--	--	--	--	1.08	0.538	--	--	0.657	0.345	--	0.721	--	--	--	--	0.843	--	--	0.932	--	--	0.884	--	--	--	--	--		
	MW-DN-136-S	1.71	5.5110	5.13	--	--	--	--	--	--	0.4	0.545	--	--	0.657	0.346	--	2.55	--	--	--	--	1.76	--	--	1.36	--	--	1.43	--	4.33	3.01	2.44	--		
MW-DN-137-S	1.41	3.8084	4.24	--	--	--	--	--	--	1.25	0.645	--	--	1.1	--	0.351	2.5	--	--	--	--	2.61	--	--	1.42	--	--	1.44	--	--	--	--	--			
MW-DN-140-S	1.02	2.3230	3.06	--	--	--	--	--	--	1.49	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.869	1.23	--	0.493	--			
MW-DN-141-S	0.87	1.6258	2.62	--	--	--	--	--	--	0.973	0.513	--	1.24	--	0.504	--	0.894	--	--	--	--	0.83	--	--	1.03	--	--	0.884	--	0.909	0.608	1.22	--			
MW-DN-142-S	1.16	2.6527	3.49	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2.62	--	--	0.591	--	--	1.47	--	--	1.43	--	--	--	--			
MW-DN-143-S	1.26	2.6054	3.78	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.819	--	--	1.81	--	--	1.43	--	--	0.982	--	--	--	--			
MW-DN-144-S	1.89	4.7607	5.66	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3.23	--	--	1.44	--	--	1.02	--	--	--	--	--			
RW-DN-100-S	10.99	37.0737	32.98	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	6.68	21	5.3	--	--			
RW-DN-101-S	1.10	1.6584	3.31	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	0.89	1.2	1.22	--	--			

Explanation:  
**2.83** Historic data outlier removed from the calculation of the average concentration that was used to calculate the Alert Level.  
**20.6** Result exceeds the Alert Level and requires select transuranic analyses.  
**3.35** Alert Level Exceedance where select transuranics were analyzed and found to be less than their respective LLDs. The result is now used in generating the Alert Level.  
**3.56** Alert Level Exceedance. However, the result is ND.

Well ID	U-233/234 Results																																			
	2011				2012		2013		2014	2015		2016		2017			2018					2019				2020			2021	2022	2023	2024	2025			
	Feb	Mar	Jun	Dec	Mar	Jun	Mar	Jun	Jun	Jun	Nov	May	Oct	Feb	May	Nov	Jan	Feb	Jun	Oct	Nov	Mar	May	Aug	Dec	Mar	Jul	Nov	May	Jun	Jun	May	Apr	Jul	Sept	
DSP-107	0.09023																																			
DSP-122	0.1733																																			
DSP-123	0.1647																																			
DSP-124	0.03502																																			
DSP-125			0.1329																																	
MD-11			0.05616							0.1496			0.1019	0.03347		0.1252		0.1154			0.1121		0.04995		0.1377			0.1474	0.1156	0.1418	0.08067	0.07021	0.0272	0.1478		
MW-DN-101-I																	0.3894	0.05872	0.4567		0.2605	0.527	0.4477	0.2788	0.5173	0.2971										
MW-DN-102-I			0.5784																																	
MW-DN-102-S			0.1116																																	
MW-DN-104-S	0.8506																																			
MW-DN-106-S			1.091																																	
MW-DN-107-S				0.371	0.9135																														0.1309	
MW-DN-108-I	0.3799																																			
MW-DN-111S																																			0.03651	
MW-DN-113-I			0.09059																																	
MW-DN-113-S			0.544																																	
MW-DN-116-S																																				0.07296
MW-DN-119-I																0.8408	0.09179		0.1428	0.0229	0.0217	0.04698	0.1045	0.1441	0.1718	0.1187	0.08836						0.06477			
MW-DN-122-I		0.324																																		
MW-DN-124-I	0.05192					0.06465	0.08076	0.1292	0.143	0.08868		0.1273		0.104				0.1055									0.1186	0.1395	0.04893	0.1451	0.07568	0.06281				
MW-DN-124-S						0.05753	0.9742	0.1876	0.7096		0.03498			0.113				0.02586								0.1191	0.1802	0.092303	0.07651	0.07268	0.04798					
RW-DN-100S																																			0.1454	
RW-DN-101S																																			0.05042	
SW-DN-101			0.4082																																	
SW-DN-102			0.441																																	
SW-DN-103			0.6737																																	
SW-DN-104			0.7946																																	
SW-DN-105			0.553																																	
SW-DN-106			0.489																																	


Well ID	U-238 Results																																			
	2011				2012		2013		2014	2015		2016		2017			2018					2019				2020			2021	2022	2023	2024	2025			
	Feb	Mar	Jun	Dec	Mar	Jun	Mar	Jun	Jun	Jun	Nov	May	Oct	Feb	May	Nov	Jan	Feb	Jun	Oct	Nov	Mar	May	Aug	Dec	Mar	Jul	Nov	May	Jun	Jun	May	Apr	Jul	Sept	
DSP-107	0.07626																																			
DSP-122	0.1605																																			
DSP-123	0.0743																																			
DSP-124	0.06065																																			
DSP-125			0.1879																																	0.0433
MD-11			0.07942							0.1058			0.09531	0.05797		0.1252		0.1233			0.1068		0.06118		0.1124			0.1575	0.03103	0.07612	0.05733	0.07166	0.1478			
MW-DN-101-I																	0.1488	0.08303	0.1215		0.1775	0.2164	0.1499	0.1993	0.124	0.1755										
MW-DN-102-I			0.1066																																	
MW-DN-102-S			0.1116																																	
MW-DN-104-S	0.4353																																			
MW-DN-106-S			0.845																																	
MW-DN-107-S				0.4338	0.6638																															0.1309
MW-DN-108-I	0.2105																																			
MW-DN-111S																																				0.06802
MW-DN-113-I			0.06406																																	
MW-DN-113-S			0.2991																																	
MW-DN-116-S																																				0.07296
MW-DN-119-I																0.4422	0.1124		0.08746	0.04265	0.0217	0.08136	0.08333	0.1556	0.1403	0.1346	0.1141						0.1295			
MW-DN-122-I		0.3512																																		
MW-DN-124-I	0.1465					0.07465	0.08076	0.0914	0.1891	0.05121		0.2437		0.1644				0.08823									0.08389	0.1801	0.04893	0.1451	0.1993	0.06281				
MW-DN-124-S						0.04069	0.3889	0.1532	0.2626		0.1399			0.04273				0.1274								0.1191	0.1472	0.09203	0.1803	0.07268	0.1264					
RW-DN-100S																																				0.1781
RW-DN-101S																																			0.05042	
SW-DN-101			0.5516																																	
SW-DN-102			0.5302																																	
SW-DN-103			0.4086																																	
SW-DN-104			0.4812																																	
SW-DN-105			0.3978																																	
SW-DN-106			0.5952																																	

If a sample was re-analyzed on a particular date, only the highest concentration is noted.

Sample Location	Sample Date	Directional Sector	Result	Qual
FW-1	3/10/2025	NW	354	+
FW-10	3/10/2025	E	188	U
FW-11	3/10/2025	ESE	186	U
FW-13	3/10/2025	S	185	U
FW-14	3/10/2025	N	815	+
FW-2	3/10/2025	NNE	191	U
FW-3	3/10/2025	NNW	447	+
FW-4	3/10/2025	SW	189	U
FW-5	3/10/2025	NE	185	U
FW-1	4/24/2025	NW	346	+
FW-10	4/24/2025	E	197	+
FW-11	4/25/2025	ESE	183	U
FW-12	4/23/2025	SSE	185	U
FW-13	4/23/2025	S	185	U
FW-14	4/24/2025	N	622	+
FW-2	4/24/2025	NNE	345	+
FW-3	4/24/2025	NNW	564	+
FW-4	4/23/2025	SW	184	U
FW-5	4/22/2025	NE	184	U
FW-1	7/23/2025	NW	183	U
FW-10	7/23/2025	E	183	U
FW-11	7/24/2025	ESE	182	U
FW-12	7/24/2025	SSE	180	U
FW-13	7/22/2025	S	191	U
FW-14	7/22/2025	N	185	U
FW-2	7/23/2025	NNE	187	U
FW-3	7/23/2025	NNW	186	U
FW-4	7/22/2025	SW	181	U
FW-5	7/21/2025	NE	181	U
FW-1	10/29/2025	NW	192	U
FW-11	10/28/2025	ESE	226	+
FW-12	10/28/2025	SSE	197	U
FW-14	10/29/2025	N	195	U
FW-4	10/29/2025	SW	191	U
FW-5	10/28/2025	NE	197	U

Explanation:


- U - Tritium not detected at a concentration greater than the laboratory detection limit.
- + - Tritium detected at a Concentration greater than the laboratory detection limit.
- All results presented in pCi/L.



**Explanation:**  
**Shallow Aquifer RGPP Monitoring Location**

- Background
- ⌂ Long-Term Shutdown
- Mid-Field
- Perimeter
- Source


Figure 1a  
 RGPP Sample Locations Shallow  
 Aquifer  
 Constellation Energy Corporation  
 Dresden Generating Station



**Explanation:**  
**Intermediate Aquifer RGPP Monitoring Location**

- Background
- ⌘ Long-Term Shutdown
- Mid-Field
- Perimeter
- Source

Figure 1b  
 RGPP Sample Locations  
 Intermediate Aquifer  
 Constellation Energy Corporation  
 Dresden Generating Station




\* - Groundwater elevation not used.

**Explanation:**

- 4th Qtr. 2025 (October) RGPP Surface Water and Shallow Aquifer Monitoring Location
  - 4th Qtr. 2025 (October) Groundwater Elevation Contour
  - Groundwater Elevation Contour
  - - - Inferred Groundwater Elevation Contour
  - Estimated Flow Direction
- 508.45 - Groundwater elevation with respect to mean sea level


Figure 2a  
 4th Quarter 2025 (October) RGPP  
 Groundwater Elevations and  
 Water Elevation Contours  
 Constellation Energy Corporation  
 Dresden Clean Energy Center



**Explanation:**

- 4th Qtr. 2025 (October) RGPP Intermediate Aquifer Monitoring Location
  - 4th Qtr. 2025 (October) Groundwater Elevation Contour
  - Groundwater Elevation Contour
  - - - Inferred Groundwater Elevation Contour
  - ➔ Estimated Flow Direction
- 508.45 - Groundwater elevation with respect to mean sea level

Figure 2b  
 4th Quarter 2025 (October) RGPP  
 Groundwater Elevations and  
 Water Elevation Contours  
 Intermediate Aquifer  
 Constellation Energy Corporation  
 Dresden Clean Energy Center



**Explanation:**

2025 Precipitation Recapture Sample Location

- Result >200 pCi/L
- Result <200 pCi/L

- Precipitation sampling completed in March, April, July, and October in 2025.

404 - Tritium concentration in pico-curies per liter (pCi/L).

Figure 3  
 2025 Precipitation Recapture  
 Sample Locations  
 Constellation Energy Corporation  
 Dresden Clean Energy Center

Sample ID	Date	Directional Sector	Result	Qual	Units
RB-1	7/28/2011	NW	400	+	pCi/L
RB-10	7/28/2011	E	630	+	pCi/L
RB-11	7/28/2011	ESE	300	+	pCi/L
RB-12	7/28/2011	SSE	100	U	pCi/L
RB-2	7/28/2011	NNE	630	+	pCi/L
RB-3	7/28/2011	NNW	200	U	pCi/L
RB-4	7/28/2011	SW	100	U	pCi/L
RB-5	7/28/2011	NE	100	U	pCi/L
RB-6	7/28/2011	ENE	200	U	pCi/L
RB-7	7/28/2011	SE	200	U	pCi/L
RB-8	7/28/2011	S	100	U	pCi/L
RB-9	7/28/2011	SSW	100	U	pCi/L
RB-1	10/21/2011	NW	300	+	pCi/L
RB-10	10/21/2011	E	0	U	pCi/L
RB-11	10/21/2011	ESE	200	+	pCi/L
RB-12	10/21/2011	SSE	100	U	pCi/L
RB-2	10/21/2011	NNE	300	+	pCi/L
RB-3	10/21/2011	NNW	300	+	pCi/L
RB-4	10/21/2011	SW	400	+	pCi/L
RB-5	10/21/2011	NE	300	+	pCi/L
RB-6	10/21/2011	ENE	200	U	pCi/L
RB-7	10/21/2011	SE	200	U	pCi/L
RB-8	10/21/2011	S	100	U	pCi/L
RB-9	10/21/2011	SSW	0	U	pCi/L
RB-1	1/11/2012	NW	400	+	pCi/L
RB-10	1/11/2012	E	300	+	pCi/L
RB-11	1/11/2012	ESE	100	U	pCi/L
RB-12	1/11/2012	SSE	300	+	pCi/L
RB-2	1/11/2012	NNE	600	+	pCi/L
RB-3	1/11/2012	NNW	600	+	pCi/L
RB-4	1/11/2012	SW	500	+	pCi/L
RB-5	1/11/2012	NE	400	+	pCi/L
RB-6	1/11/2012	ENE	300	+	pCi/L
RB-7	1/11/2012	SE	400	+	pCi/L
RB-8	1/11/2012	S	300	+	pCi/L
RB-9	1/11/2012	SSW	100	U	pCi/L
RB-1	5/23/2012	NW	191	U	pCi/L
RB-10	5/23/2012	E	199	U	pCi/L
RB-11	5/30/2012	ESE	168	U	pCi/L
RB-12	5/30/2012	SSE	167	U	pCi/L
FW-1	6/6/2013	NW	161	U	pCi/L
FW-10	6/7/2013	E	160	U	pCi/L
FW-11	6/13/2013	ESE	169	U	pCi/L
FW-12	6/14/2013	SSE	168	U	pCi/L
FW-1	5/29/2014	NW	194	U	pCi/L
FW-10	5/30/2014	E	191	U	pCi/L
FW-11	5/30/2014	ESE	194	U	pCi/L
FW-12	5/30/2014	SSE	196	U	pCi/L
FW-1	6/1/2015	NW	190	U	pCi/L
FW-10	6/2/2015	E	188	U	pCi/L
FW-11	6/3/2015	ESE	182	U	pCi/L
FW-12	6/8/2015	SSE	175	U	pCi/L
FW-1	06/07/2016	NW	181	U	pCi/L
FW-10	06/01/2016	E	183	U	pCi/L
FW-11	06/01/2016	ESE	181	U	pCi/L
FW-12	06/01/2016	SSE	182	U	pCi/L
FW-1	05/15/2017	NW	177	U	pCi/L
FW-10	05/23/2017	E	177	U	pCi/L
FW-11	05/17/2017	ESE	175	U	pCi/L
FW-12	05/24/2017	SSE	178	U	pCi/L
FW-1	06/12/2018	NW	193	U	pCi/L

Sample ID	Date	Directional Sector	Result	Qual	Units
FW-10	06/12/2018	E	193	U	pCi/L
FW-11	06/12/2018	ESE	196	U	pCi/L
FW-12	06/02/2018	SSE	196	U	pCi/L
FW-1	5/28/2019	NW	188	U	pCi/L
FW-10	5/28/2019	E	181	U	pCi/L
FW-11	5/28/2019	ESE	186	U	pCi/L
FW-12	5/28/2019	SSE	187	U	pCi/L
FW-1	11/12/2020	NW	207	+	pCi/L
FW-10	11/12/2020	E	170	U	pCi/L
FW-11	11/12/2020	ESE	175	U	pCi/L
FW-12	11/12/2020	SSE	276	U	pCi/L
FW-11	3/8/2021	ESE	182	U	pCi/L
FW-10	3/8/2021	E	187	U	pCi/L
FW-1	3/9/2021	NW	404	+	pCi/L
FW-4	3/11/2021	SW	180	U	pCi/L
FW-12	3/11/2021	SSE	186	U	pCi/L
FW-2	3/11/2021	NNE	184	U	pCi/L
FW-3	3/11/2021	NNW	182	U	pCi/L
FW-5	3/11/2021	NE	182	U	pCi/L
FW-11	8/10/2021	ESE	169	U	pCi/L
FW-5	8/10/2021	NE	169	U	pCi/L
FW-10	8/11/2021	E	161	U	pCi/L
FW-2	8/11/2021	NNE	176	U	pCi/L
FW-3	8/11/2021	NNW	421	+	pCi/L
FW-1	8/12/2021	NW	177	U	pCi/L
FW-4	8/12/2021	SW	176	U	pCi/L
FW-12	8/12/2021	SSE	173	U	pCi/L
FW-4	11/8/2021	SW	193	U	pCi/L
FW-5	11/8/2021	NE	177	U	pCi/L
FW-12	11/9/2021	SSE	187	U	pCi/L
FW-11	11/9/2021	ESE	181	U	pCi/L
FW-10	11/9/2021	E	186	U	pCi/L
FW-2	11/9/2021	NNE	192	+	pCi/L
FW-3	11/9/2021	NNW	239	+	pCi/L
FW-1	11/10/2021	NW	215	+	pCi/L
FW-1	3/15/2022	NW	229	+	pCi/L
FW-10	3/15/2022	E	195	U	pCi/L
FW-11	3/15/2022	ESE	193	U	pCi/L
FW-12	3/15/2022	SSE	175	U	pCi/L
FW-2	3/15/2022	NNE	360	+	pCi/L
FW-3	3/15/2022	NNW	589	+	pCi/L
FW-4	3/15/2022	SW	171	U	pCi/L
FW-5	3/16/2022	NE	172	U	pCi/L
FW-1	6/7/2022	NW	735	+	pCi/L
FW-10	6/7/2022	E	204	+	pCi/L
FW-11	6/7/2022	ESE	173	U	pCi/L
FW-12	6/7/2022	SSE	182	+	pCi/L
FW-2	6/7/2022	NNE	377	+	pCi/L
FW-3	6/7/2022	NNW	394	+	pCi/L
FW-4	6/7/2022	SW	470	+	pCi/L
FW-5	6/6/2022	NE	229	+	pCi/L
FW-1	7/27/2022	NW	418	+	pCi/L
FW-10	7/27/2022	E	196	U	pCi/L
FW-11	7/26/2022	ESE	194	U	pCi/L
FW-12	7/28/2022	SSE	195	U	pCi/L
FW-2	7/27/2022	NNE	234	+	pCi/L
FW-3	7/27/2022	NNW	266	+	pCi/L
FW-4	7/27/2022	SW	195	U	pCi/L
FW-5	7/25/2022	NE	196	U	pCi/L
FW-1	11/16/2022	NW	1,860	+	pCi/L
FW-10	11/16/2022	E	176	U	pCi/L

Sample ID	Date	Directional Sector	Result	Qual	Units
FW-11	11/16/2022	ESE	242	+	pCi/L
FW-12	11/16/2022	SSE	230	+	pCi/L
FW-2	11/16/2022	NNE	902	+	pCi/L
FW-3	11/16/2022	NNW	1,330	+	pCi/L
FW-4	11/16/2022	SW	353	+	pCi/L
FW-5	11/16/2022	NE	191	U	pCi/L
FW-4	3/15/2023	SW	212	+	pCi/L
FW-12	3/15/2023	SSE	281	+	pCi/L
FW-1	3/15/2023	NW	332	+	pCi/L
FW-2	3/15/2023	NNE	218	+	pCi/L
FW-3	3/15/2023	NNW	422	+	pCi/L
FW-10	3/15/2023	E	196	U	pCi/L
FW-5	3/15/2023	NE	198	U	pCi/L
FW-11	3/16/2023	ESE	193	U	pCi/L
FW-5	9/18/2023	NE	197	U	pCi/L
FW-4	9/20/2023	SW	264	+	pCi/L
FW-11	9/21/2023	ESE	195	U	pCi/L
FW-10	9/21/2023	E	198	U	pCi/L
FW-12	9/21/2023	SSE	197	U	pCi/L
FW-2	9/22/2023	NNE	189	U	pCi/L
FW-3	9/22/2023	NNW	188	U	pCi/L
FW-1	9/22/2023	NW	369	+	pCi/L
FW-5	12/5/2023	NE	190	U	pCi/L
FW-4	12/6/2023	SW	191	U	pCi/L
FW-1	12/6/2023	NW	619	+	pCi/L
FW-2	12/7/2023	NNE	524	+	pCi/L
FW-3	12/7/2023	NNW	914	+	pCi/L
FW-10	12/7/2023	E	184	U	pCi/L
FW-11	12/7/2023	ESE	189	U	pCi/L
FW-12	12/7/2023	SSE	191	U	pCi/L
FW-11	2/27/2024	ESE	187	U	pCi/L
FW-3	2/28/2024	NNW	820	+	pCi/L
FW-1	2/28/2024	NW	734	+	pCi/L
FW-13	5/28/2024	S	190	U	pCi/L
FW-5	5/29/2024	NE	191	U	pCi/L
FW-14	5/30/2024	N	231	+	pCi/L
FW-1	5/30/2024	NW	615	+	pCi/L
FW-2	5/30/2024	NNE	249	+	pCi/L
FW-3	5/30/2024	NNW	567	+	pCi/L
FW-10	5/30/2024	E	190	U	pCi/L
FW-12	5/31/2024	SSE	187	U	pCi/L
FW-11	5/31/2024	ESE	189	U	pCi/L
FW-11	8/15/2024	ESE	190	U	pCi/L
FW-13	8/15/2024	S	186	U	pCi/L
FW-1	8/15/2024	NW	291	+	pCi/L
FW-14	8/15/2024	N	221	+	pCi/L
FW-2	8/15/2024	NNE	196	U	pCi/L
FW-10	8/15/2024	E	192	U	pCi/L
FW-12	8/15/2024	SSE	188	U	pCi/L
FW-5	8/15/2024	NE	189	U	pCi/L
FW-12	11/26/2024	SSE	182	U	pCi/L
FW-4	11/26/2024	SW	177	U	pCi/L
FW-13	11/26/2024	S	186	U	pCi/L
FW-1	11/26/2024	NW	519	+	pCi/L
FW-14	11/26/2024	N	340	+	pCi/L
FW-2	11/26/2024	NNE	245	+	pCi/L
FW-3	11/26/2024	NNW	390	+	pCi/L
FW-10	11/26/2024	E	179	U	pCi/L
FW-11	11/26/2024	ESE	185	U	pCi/L
FW-5	11/26/2024	NE	182	U	pCi/L
FW-1	3/10/2025	NW	354	+	pCi/L

Sample ID	Date	Directional Sector	Result	Qual	Units
FW-10	3/10/2025	E	188	U	pCi/L
FW-11	3/10/2025	ESE	186	U	pCi/L
FW-13	3/10/2025	S	185	U	pCi/L
FW-14	3/10/2025	N	815	+	pCi/L
FW-2	3/10/2025	NNE	191	U	pCi/L
FW-3	3/10/2025	NNW	447	+	pCi/L
FW-4	3/10/2025	SW	189	U	pCi/L
FW-5	3/10/2025	NE	185	U	pCi/L
FW-1	4/24/2025	NW	346	+	pCi/L
FW-10	4/24/2025	E	197	+	pCi/L
FW-11	4/25/2025	ESE	183	U	pCi/L
FW-12	4/23/2025	SSE	185	U	pCi/L
FW-13	4/23/2025	S	185	U	pCi/L
FW-14	4/24/2025	N	622	+	pCi/L
FW-2	4/24/2025	NNE	345	+	pCi/L
FW-3	4/24/2025	NNW	564	+	pCi/L
FW-4	4/23/2025	SW	184	U	pCi/L
FW-5	4/22/2025	NE	184	U	pCi/L
FW-1	7/23/2025	NW	183	U	pCi/L
FW-10	7/23/2025	E	183	U	pCi/L
FW-11	7/24/2025	ESE	182	U	pCi/L
FW-12	7/24/2025	SSE	180	U	pCi/L
FW-13	7/22/2025	S	191	U	pCi/L
FW-14	7/22/2025	N	185	U	pCi/L
FW-2	7/23/2025	NNE	187	U	pCi/L
FW-3	7/23/2025	NNW	186	U	pCi/L
FW-4	7/22/2025	SW	181	U	pCi/L
FW-5	7/21/2025	NE	181	U	pCi/L
FW-1	10/29/2025	NW	192	U	pCi/L
FW-11	10/28/2025	ESE	226	+	pCi/L
FW-12	10/28/2025	SSE	197	U	pCi/L
FW-14	10/29/2025	N	195	U	pCi/L
FW-4	10/29/2025	SW	191	U	pCi/L
FW-5	10/28/2025	NE	197	U	pCi/L