

Annual Radiological Environmental Operating Report 2025

TABLE OF CONTENTS

| | | |
|------|---|----|
| 1.0 | LIST OF ACRONYMS AND DEFINITIONS | 3 |
| 2.0 | EXECUTIVE SUMMARY..... | 4 |
| 2.1 | Summary of Conclusions: | 5 |
| 3.0 | INTRODUCTION..... | 6 |
| 4.0 | SITE DESCRIPTION AND SAMPLE LOCATIONS..... | 7 |
| 5.0 | RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM REQUIREMENTS | 8 |
| 6.0 | MAPS OF COLLECTION SITES | 18 |
| 7.0 | REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES..... | 23 |
| 8.0 | SAMPLING PROGRAM, PROGRAM MODIFICATION AND INTEPRETATION OF RESULTS | 24 |
| 8.1 | Environmental Direct Radiation Dosimetry Results | 25 |
| 8.2 | Air Particulate and Radioiodine Sample Results | 26 |
| 8.3 | Waterborne Sample Results | 27 |
| 8.4 | Ingestion Pathway Sample Results..... | 31 |
| 9.0 | LAND USE CENSUS | 32 |
| 10.0 | SAMPLE DEVIATIONS, ANOMALIES AND UNAVAILABILITY | 34 |
| 11.0 | OTHER SUPPLEMENTAL INFORMATION | 37 |
| 11.1 | NEI 07-07 Onsite Radiological Groundwater Monitoring Program..... | 37 |
| 11.2 | Independent Spent Fuel Storage Installation (ISFSI) Monitoring Program | 37 |
| 11.3 | Corrections to Previous Reports | 37 |
| 12.0 | BIBLIOGRAPHY | 38 |

TABLES

| | |
|---|----|
| Table 1, Radiological Environmental Monitoring Program – Direct Radiation | 8 |
| Table 2, Radiological Environmental Monitoring Program – Airborne..... | 9 |
| Table 3, Radiological Environmental Monitoring Program – Waterborne | 10 |
| Table 4, Radiological Environmental Monitoring Program – Ingestion..... | 12 |
| Table 5, REMP Sampling Locations – Direct Radiation..... | 14 |
| Table 6, Reporting Levels for Radioactivity Concentrations in Environmental Samples | 23 |
| Table 7, Maximum Values for the Limit of Detection | 24 |
| Table 8: Land Use Census – Nearest Receptors within 5 miles | 33 |
| Table 9: Sample Deviation Summary..... | 34 |
| Table 10: Airborne Cartridge: Radioiodine (pCi/m3)..... | 48 |
| Table 11: Airborne Particulates: Gross Beta (pCi/m3)..... | 52 |
| Table 12: Quarterly Gamma Isotopic Data – Air Station M-1 (pCi/m3) | 55 |
| Table 13: Quarterly Gamma Isotopic Data – Air Station M-2 (pCi/m3) | 56 |
| Table 14: Quarterly Gamma Isotopic Data – Air Station M-3 (pCi/m3) | 57 |
| Table 15: Quarterly Gamma Isotopic Data – Air Station M-4 (pCi/m3) | 58 |
| Table 16: Quarterly Gamma Isotopic Data – Air Station M-5 (pCi/m3) | 59 |
| Table 17: Sediment Gamma Isotopic Data – M-8c Upstream of Plant (pCi/kg) | 60 |

| | |
|--|----|
| Table 18: Sediment Gamma Isotopic Data – M-9 Downstream of Plant (pCi/kg)..... | 61 |
| Table 19: Sediment Gamma Isotopic Data – M-15 Montissippi Park (pCi/kg) | 62 |
| Table 20: Tissue-Fish Gamma Isotopic Data – M-8c Upstream of Plant (pCi/kg, wet) | 63 |
| Table 21: Tissue-Fish Gamma Isotopic Data – M-9 Downstream of Plant (pCi/kg, wet)..... | 64 |
| Table 22: Tissue-Plant Gamma Isotopic Data – M-41 Training Center (pCi/kg) | 65 |
| Table 23: Tissue-Plant Gamma Isotopic Data – M-42 Biology Station Road (pCi/kg)..... | 66 |
| Table 24: Tissue-Plant Gamma Isotopic Data – M-43c Imholte Farm (pCi/kg) | 67 |
| Table 25: Water Tritium Data (pCi/kg)..... | 68 |
| Table 26: Drinking Water Gross Beta Data (pCi/kg)..... | 69 |
| Table 27: Groundwater Gamma Isotopic Data – M-11 City of Monticello (pCi/m3)..... | 70 |
| Table 28: Groundwater Gamma Isotopic Data – M-12 Plant Well #11 (pCi/m3)..... | 71 |
| Table 29: Groundwater Gamma Isotopic Data – M-43c Imholte Farm (pCi/m3) | 72 |
| Table 30: Groundwater Gamma Isotopic Data – M-55 Hasbrouck Residence (pCi/m3) | 73 |
| Table 31: Drinking Water Gamma Isotopic Data – M-14 City of Minneapolis | 74 |
| Table 32: Surface Water Gamma Isotopic Data – M-8c Upstream of Plant..... | 76 |
| Table 33: Surface Water Gamma Isotopic Data – M-9 Downstream of Plant | 78 |
| Table 34: Direct Radiation Data – TLD: Gamma (mrem/91 day)..... | 80 |
| Table 35: Direct Radiation Data – ISFSI: Gamma (mrem/91 day)..... | 82 |

FIGURES

| | |
|---|----|
| Figure 1, Potential exposure pathways to Members of the Public due to Plant Operations [7] | 6 |
| Figure 2, REMP Sample Locations (Surface Water, Sediment, Well Water, Air, and Vegetation) | 18 |
| Figure 3, REMP Sample Locations (5 Mile Ring and Special Interest TLD Locations) | 19 |
| Figure 4, REMP Sample Locations (Site Boundary TLD Locations)..... | 20 |
| Figure 5, REMP Sample Locations (Control Locations) | 21 |
| Figure 6, REMP Sample Locations (ISFSI TLD Locations) | 22 |
| Figure 7, Air Particulate: Analysis for Gross Beta, Average for All Indicator vs. Control Locations | 26 |
| Figure 8: Surface Water Tritium Results | 28 |
| Figure 9: REMP Groundwater Tritium Sample Results | 29 |
| Figure 10: Drinking Water Gross Beta Samples Control | 30 |
| Figure 11: Drinking Water Tritium Sample Results..... | 30 |

ATTACHMENTS

| | |
|---|----|
| Attachment 1, Data Table Summary | 40 |
| Attachment 2, Complete Data Table for All Analysis Results Obtained In 2025 | 48 |
| Attachment 3, Cross Check Intercomparison Program..... | 83 |
| Attachment 4, Environmental Direct Radiation Dosimetry Results | 84 |
| Attachment 5, Laboratory Quality Assurance Reports (Enclosed)..... | 86 |

1.0 LIST OF ACRONYMS AND DEFINITIONS

1. Airborne Activity Sampling: Continuous sampling of air through the collection of particulates and radionuclides on filter media.
2. ARERR: Annual Radioactive Effluent Release Report
3. AREOR: Annual Radiological Environmental Operating Report
4. BWR: Boiling Water Reactor
5. Composite Sample: A series of single collected portions (aliquots) analyzed as one sample. The aliquots making up the sample are collected at time intervals that are very short compared to the composite period.
6. Control: A sampling station in a location not likely to be affected by plant effluents due to its distance and/or direction from the station.
7. Curie (Ci): A measure of radioactivity; equal to 3.7×10^{10} disintegrations per second, or 2.22×10^{12} disintegrations per minute.
8. Direct Radiation Monitoring: The measurement of radiation dose at various distances from the plant is assessed using Thermoluminescent Dosimeters (TLD), Optically Stimulated Luminescence Dosimeters (OSLD) and pressurized ionization chambers.
9. EPA: Environmental Protection Agency
10. GPI: Groundwater Protection Initiative
11. Grab Sample: A single discrete sample drawn at one point in time.
12. Indicator: A sampling location that is likely to be affected by plant effluents due to its proximity and/or direction from the plant.
13. Ingestion Pathway: The ingestion pathway includes milk, fish, drinking water and garden produce. Also sampled (under special circumstances) are other media such as vegetation or animal products when additional information about particular radionuclides is needed.
14. ISFSI: Independent Spent Fuel Storage Installation
15. Lower Limit of Detection (LLD): An *a priori* measure of the detection capability of a radiochemistry measurement based on instrument setup, calibration, background, decay time, and sample volume. An LLD is expressed as an activity concentration. The MDA is used for reporting results. LLD are specified by a regulator, such as the NRC and are typically listed in the ODCM.

16. MDA: Minimum Detectable Activity. For radiochemistry instruments, the MDA is the *a posteriori* minimum concentration that a counting system detects. The smallest concentration or activity of radioactive material in a sample that will yield a net count above instrument background and that is detected with 95% probability, with only 5% probability of falsely concluding that a blank observation represents a true signal.
17. MDC: Minimum Detectable Concentration. Synonymous with MDA for the purposes of radiological monitoring.
18. Mean: The sum of all of the values in a distribution divided by the number of values in the distribution, synonymous with average.
19. Microcurie: 3.7×10^4 disintegrations per second, or 2.22×10^6 disintegrations per minute.
20. N/A: Not Applicable
21. NEI: Nuclear Energy Institute
22. NIST: National Institute of Standards and Technology.
23. NRC: Nuclear Regulatory Commission
24. ODCM: Offsite Dose Calculation Manual
25. OSLD: Optically Stimulated Luminescence Dosimeter
26. pCi/L: picocuries / Liter
27. PWR: Pressurized Water Reactor
28. REMP: Radiological Environmental Monitoring Program
29. TLD: Thermoluminescent Dosimeter

2.0 EXECUTIVE SUMMARY

Monticello Nuclear Generating Plant (MNGP) Radiological Environmental Monitoring Program (REMP) was established prior to the station becoming operational to provide information on background radiation present in the area. The goal of MNGP REMP is to evaluate the impact of the station on the environment. Environmental samples from different media are monitored as part of the program in accordance with specifications detailed in the Offsite Dose Calculation Manual (ODCM), provisions of NRC's NUREG-1302, NRC Generic Letter 79-65 Branch Technical Position, and MNGP Technical Specifications. The program compares data from Indicator locations near the plant, to Control locations farther away from the site to assess operation impacts.

| | | |
|--|--|--------------|
| Annual Radiological Environmental Operating Report | YEAR: 2025 | Page 5 of 86 |
| Company: Xcel Energy | Plant: Monticello Nuclear Generating Plant | |

The Annual Radiological Environmental Operating Report (AREOR) provides data obtained through analyses of environmental samples collected at MNGP for the reporting period of January 1st through December 31st, 2025. During that time period 1907 analyses were performed on 818 samples. In assessing all the data gathered for this report and comparing these results with preoperational data and/or 10-year average values, it was concluded that the operation of MNGP did not result in detection of plant related radionuclides in the environment.

2.1 **Summary of Conclusions:**

No measurable activities above background levels were detected. All values were consistent with historical results which indicate no adverse radiological environmental impacts associated with the operation of MNGP. Naturally occurring radionuclides are present in the Earth's crust and atmosphere and exists in detectable quantities throughout the world. It is common to detect naturally occurring radionuclides in many of the samples collected for REMP. Some examples of naturally occurring radionuclides that are frequently seen in samples are potassium-40, beryllium-7, actinium-228 (present as a decay product of radium-228), and radium-226. Additionally, some relatively long-lived anthropogenic radioisotopes, such as strontium-90 and cesium-137, are also seen in some REMP samples; these radionuclides exist in measurable quantities throughout the world as a result of fallout from historic atmospheric nuclear weapons testing. Naturally occurring beryllium-7 and potassium-40 were detected in sediments as part of MNGP's REMP program. Detailed information on the exposure of the U.S. population to ionizing radiation can be found in NCRP Report No. 160 [1].

3.0 INTRODUCTION

The Radiological Environmental Monitoring Program (REMP) provides data on measurable levels of radiation and radioactive materials in the environment. This program also evaluates the relationship between quantities of radioactive materials released from the plant and resultant doses to individuals from principal pathways of exposure. In this capacity, REMP provides a check on the effluent release program and dispersion modeling to ensure that concentrations in the environment due to radioactive effluents conform to the "As Low As (is) Reasonably Achievable" (ALARA) design objectives of 10 CFR 50, Appendix I [2], and implements the requirements of Section IV.B.2 and IV.B.3 of Appendix I. REMP is designed to conform to the Nuclear Regulatory Commission (NRC) Regulatory Guide 4.1 [3], NUREG 1301/1302 [4] [5], and the 1979 NRC Branch Technical Position [6].




Figure 1, Potential exposure pathways to Members of the Public due to Plant Operations [7]

Quality assurance aspects of the sampling program and TLD/OSLD data collection are conducted in accordance with Regulatory Guides 4.15 [8] and 4.13 [9]. REMP also adheres to the requirements of the State of Minnesota, MNGP Technical Specifications, and Offsite Dose Calculation Manual (ODCM). These governing documents dictate the environmental sampling, sample analysis protocols, data reporting and quality assurance requirements for the environmental monitoring program.

The Annual Radiological Environmental Operating Report provides summaries of the environmental data from exposure pathways, interpretations of the data, and analyses of trends of the results. Routinely monitored pathways include ingestion, inhalation, and direct radiation. Routes of exposure are based on site specific information such as meteorology, receptor locations, and water usage around the plant.

4.0 SITE DESCRIPTION AND SAMPLE LOCATIONS

Monticello Nuclear Generating Plant is a commercial nuclear power plant that achieved initial criticality in 1971. Located in Wright County, Minnesota, MNGP is located along the Mississippi River and is approximately 40 miles northwest of the Twin Cities of Minneapolis and St. Paul. MNGP generates commercial electrical power via a boiling water reactor with a nominal generating capacity of 681 megawatts electric (MWe).

MNGP sampling media are selected based on site specific information such as meteorology, receptor locations, and water usage around the plant. Sampling and analysis frequencies are documented in the Offsite Dose Calculation Manual and site procedures. Required sampling, analysis frequencies and location of sample collected are captured in the following tables and figures:

- Table 1, Radiological Environmental Monitoring Program – Direct Radiation
- Table 2, Radiological Environmental Monitoring Program – Airborne
- Table 3, Radiological Environmental Monitoring Program – Waterborne
- Table 4, Radiological Environmental Monitoring Program – Ingestion
- Table 5, REMP Sampling Locations – Direct Radiation
- Figure 2, REMP Sample Locations (Surface Water, Sediment, Well Water, Air, and Vegetation)
- Figure 3, REMP Sample Locations (5 Mile Ring and Special Interest TLD Locations)
- Figure 4, REMP Sample Locations (Site Boundary TLD Locations)
- Figure 5, REMP Sample Locations (Control Locations)
- Figure 6, REMP Sample Locations (ISFSI TLD Locations)

5.0 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM REQUIREMENTS

Table 1, Radiological Environmental Monitoring Program – Direct Radiation

| Requirement | Sample Location Description, Distance, and Direction | Sampling Collection/ Frequency | Type and Frequency of Analyses |
|---|--|--------------------------------|-------------------------------------|
| <p>Direct Radiation 40 Routine monitoring stations with two or more dosimeters placed as follows: An inner ring of stations, using the 16 meteorological sectors as guidelines, in the general area of the site boundary.¹ An outer ring of stations, one in each compass sector at approximately 5 miles from the site; and Special interest areas, such as population centers, nearby recreation areas, and control stations.² Three neutron and gamma dosimeter sets along the OCA fence. Three neutron and gamma dosimeters with special interest and inner ring TLDs and four neutron control dosimeters are stationed with the REMP control TLDs.</p> | <p>See Table 5</p> | <p>Quarterly</p> | <p>Gamma/Neutron dose/Quarterly</p> |

¹ Because of inaccessibility, two sectors in the inner ring are not covered.

² Three control TLD locations only have one dosimeter.

Table 2, Radiological Environmental Monitoring Program – Airborne

| Requirement | Sample Location Description, Distance, and Direction | Sampling Collection/Frequency | Type and Frequency of Analyses |
|---|--|---|--|
| <p><u>Airborne Radioiodine and Particulates</u> Samples from 5 locations:</p> <p>Three locations close to the site boundary in different sectors of the highest calculated annual average ground level D/Q.</p> <p>One sample from the vicinity of a community having the highest calculated annual average D/Q.</p> <p>One sample from a Control Location, approximately 10 to 20 miles away in the least predominant wind direction</p> | <p>Station M-1c: 11 miles 307 degrees</p> <p>Station M-2: 0.8 miles 140 degrees</p> <p>Station M-3: 0.6 miles 104 degrees</p> <p>Station M-4: 0.8 miles 147 degrees</p> <p>Station M-5: 2.6 miles 134 degrees</p> | <p>Continuous sampler operation with sample collection weekly</p> | <p>Particulate sampler: Analyze for gross beta radioactivity \geq 24 hours following filter change / Weekly. Perform gamma isotopic analysis on each sample when gross beta activity is $>$ 10 times the yearly mean of control samples. Perform gamma isotopic analysis on composite sample (by location)/Quarterly.</p> <p>Radioiodine canister: I-131 analysis/Weekly.</p> |

Table 3, Radiological Environmental Monitoring Program – Waterborne

| Requirement | Sample Location Description, Distance, and Direction | Sampling Collection/Frequency | Type and Frequency of Analyses |
|---|---|---|---|
| Surface Water One sample upstream (control) and one sample downstream (indicator) | <p>Station M-8c: 1,000 ft upstream of Plant intake</p> <p>Station M-9: 1,000 ft downstream of Plant discharge</p> | Monthly composite of weekly samples (water and ice conditions permitting); samples from monthly composites are combined to form quarterly composite samples to be analyzed for H-3. | Gamma isotopic /Monthly, H-3 /Quarterly |
| Drinking Water One sample of the City of Minneapolis water supply | Station M-14: City of Minneapolis 37 miles 132 degrees | Composite sample over 2-week period when I-131 is performed; monthly composite otherwise. | I-131 /on each composite when dose calculated for consumption of the water is >1 mrem/year ³ /Bi-weekly, Gross beta and gamma /Monthly, H-3 /Quarterly |
| Groundwater One control location greater than 10 miles from the plant and three indicator locations within 5 miles of the plant. | <p>Station M-43c: Imholte Farm 12.3 miles 313 degrees</p> <p>Station M-11: City of Monticello 3.3 miles 127 degrees</p> <p>Station M-12: Plant Well No. 11 0.26 miles 252 degrees</p> <p>Station M-55: Hasbrouck Residence 1.60 miles 255 degrees</p> | Grab samples quarterly | Gamma isotopic and H-3 /Quarterly |

³ The dose shall be calculated for the maximum organ and age group, using the methodology and parameters in the ODCM.

Table 3, Radiological Environmental Monitoring Program – Waterborne

| Requirement | Sample Location Description, Distance, and Direction | Sampling Collection/ Frequency | Type and Frequency of Analyses |
|--|---|--------------------------------|--------------------------------|
| Sediment from Shoreline One sample upstream (control), one sample downstream (indicator), and one sample from the shoreline of the recreational area (indicator). | <p>Station M-8c: Upstream of plant within 1,000 ft of plant intake</p> <p>Station M-9: Downstream of plant within 1,000 ft of plant discharge</p> <p>Station M-15: Montissippi Park 1.27 miles 114 degrees</p> | Semiannual | Gamma isotopic /Semiannually |

Table 4, Radiological Environmental Monitoring Program – Ingestion

| Requirement | Sample Location Description, Distance, and Direction | Sampling Collection/ Frequency | Type and Frequency of Analyses |
|--|--|---|--|
| <p>Milk: One sample from milking animals in three locations within 3 miles distance having the highest dose potential. If there are none, then one sample from milking animals in each of three areas between 3 to 5 miles distant where doses are calculated to be greater than 1 mrem per yr.⁴</p> <p>One sample from milking animals at a control location 10 to 20 miles distant and in the least prevalent wind direction.</p> | <p>This pathway is currently unavailable at MNGP.</p> | <p>Biweekly when animals are on pasture; monthly at other times</p> | <p>Gamma isotopic and I-131 analysis/ Biweekly when animals are on pasture; monthly at other times</p> |
| <p>Vegetation:⁵ Samples of vegetation grown closest to each of the two offsite locations of highest predicted annual average D/Q if milk sampling is not performed, and one sample from 10 to 20 miles in the least prevalent wind direction</p> | <p>Station M-41: Training center near 0.8 miles 151 degrees</p> <p>Station M-42:⁶ Biology station road near 0.7 miles 136 degrees</p> <p>Station M-42A: near 0.7 miles 108 degrees</p> <p>Station M-43c: Imholte farm near 12.3 miles 313 degrees</p> | <p>Monthly during growing season</p> | <p>Gamma Isotopic and Iodine-131 analysis/ Each sample</p> |

⁴ The dose shall be calculated for the maximum organ and age group, using the methodology and parameters in the ODCM.

⁵ Actual location for vegetation sampling may vary depending on availability of broad leaf plant species. The nearest available broad leaf specimens to the location should be used.

⁶ M-42 is the preferred sampling location; however, M-42A may be used in place of M-42, if samples are not available at the preferred location.

Table 4, Radiological Environmental Monitoring Program – Ingestion

| Requirement | Sample Location Description, Distance, and Direction | Sampling Collection/ Frequency | Type and Frequency of Analyses |
|--|---|--------------------------------|---|
| <p>Fish:</p> <p>One sample of one game species of fish located upstream and downstream of the plant site.</p> | <p>Station M-8c: Upstream of plant within 1,000 ft of plant intake.</p> <p>Station M-9: Downstream of plant within 1,000 ft of plant discharge.</p> | Semiannually | Gamma isotopic analysis on edible portions/ Each sample |
| <p>Food Products:⁷</p> <p>One sample of corn and potatoes from any area that is irrigated by water in which liquid plant wastes have been discharged.⁸</p> | <p>This pathway is currently unavailable at MNGP since there are not any crops irrigated from the Mississippi River within 5 miles downstream from MNGP.</p> | At time of harvest | Gamma isotopic analysis of edible portion/ Each sample |

⁷ Collected only if Plant discharges radioactive effluent into the river, then only from river irrigated fields, as determined by Section 2.1 of the ODCM 07.01.

⁸ As determined by methods outlined in Section 2.3 of the ODCM 07.01.

Table 5, REMP Sampling Locations – Direct Radiation

| Site # ⁹ | Location Type | Sector | Distance | Description |
|---------------------------|---------------|--------|----------|---------------------|
| M01A | Inner Ring | N | 0.75 | Sherburne Ave. So. |
| M02A | Inner Ring | NNE | 0.79 | Sherburne Ave. So. |
| M03A | Inner Ring | NE | 1.29 | Sherburne Ave. So. |
| M04A | Inner Ring | E | 0.5 | Biology Station Rd. |
| M05A | Inner Ring | ESE | 0.48 | Biology Station Rd. |
| M06A | Inner Ring | SE | 0.54 | Biology Station Rd. |
| M07A | Inner Ring | SSE | 0.43 | Parking Lot H |
| M08A | Inner Ring | S | 0.45 | Parking Lot F |
| M09A | Inner Ring | SSW | 0.38 | County Road 75 |
| M10A & ISFSI-15 (neutron) | Inner Ring | SW | 0.38 | County Road 75 |
| M11A | Inner Ring | WSW | 0.4 | County Road 75 |
| M12A & ISFSI-14 (neutron) | Inner Ring | W | 0.5 | County Road 75 |

⁹ Code letters are defined below:

- A = Locations in the general area of the site boundary
- B = Locations about 4 to 5 miles distant from MNGP
- C = Locations of control samples (used for control air sampler and water control sample)
- S = Special interest locations

Table 5, REMP Sampling Locations – Direct Radiation

| Site # ^a | Location Type | Sector | Distance | Description |
|---------------------|---------------|--------|----------|---------------------------------|
| M13A | Inner Ring | NW | 0.89 | North Boundary Rd. |
| M14A | Inner Ring | NNW | 0.78 | North Boundary Rd. |
| M01B | Outer Ring | N | 4.65 | 117th Street |
| M02B | Outer Ring | NNE | 4.4 | County Road 11 |
| M03B | Outer Ring | NE | 4.3 | County Rd. 73 & 81 |
| M04B | Outer Ring | ENE | 4.2 | County Rd. 73 (196th Street) |
| M05B | Outer Ring | E | 4.3 | City of Big Lake |
| M06B | Outer Ring | ESE | 4.3 | County Rd 14 & 196th Street |
| M07B | Outer Ring | SE | 4.3 | Monticello Industrial Dr. |
| M08B | Outer Ring | SSE | 4.6 | Residence Hwy 25 & Davidson Ave |
| M09B | Outer Ring | S | 4.7 | Weinand Farm |
| M10B | Outer Ring | SSW | 4.2 | Reisewitz Farm - Acacia Ave |
| M11B | Outer Ring | SW | 4.0 | Vanlith Farm - 97th Ave |
| M12B | Outer Ring | WSW | 4.2 | Lake Maria St. Park |
| M13B | Outer Ring | W | 4.1 | Bridgewater Sta. |
| M14B | Outer Ring | WNW | 4.3 | Anderson Res. - Cty Rd 111 |

Table 5, REMP Sampling Locations – Direct Radiation

| Site # ⁹ | Location Type | Sector | Distance | Description |
|---------------------------|------------------|--------|----------|---------------------------------------|
| M15B | Outer Ring | NW | 4.3 | Barton Ave NW |
| M16B | Outer Ring | NNW | 4.4 | University Ave and Hancock St, Becker |
| M01C & Neutron Control D | Control | NW | 11.5 | Kirchenbauer Farm |
| M02C & Neutron Control C | Control | NE | 11.2 | Cty Rd 4 & 15 |
| M03C & Neutron Control A | Control | SE | 11.6 | Cty Rd 19 & Jason Ave |
| M04C & Neutron Control B | Control | SW | 10.3 | Maple Lake Water Tower |
| M01S | Special Interest | WSW | 0.66 | 127th Street NE |
| M02S & ISFSI-16 (neutron) | Special Interest | SW | 0.5 | Krone Residence |
| M03S | Special Interest | ESE | 1.53 | Big Oaks Park |
| M04S | Special Interest | SE | 2.3 | Pinewood School |
| M05S | Special Interest | ESE | 3.0 | 20500 Co. Rd 11, Big Lake |
| M06S | Special Interest | SE | 2.6 | Monticello Public Works |

Table 5, REMP Sampling Locations – Direct Radiation

| Site #⁹ | Location Type | Sector | Distance | Description |
|---------------------------|----------------------|---------------|-----------------|--------------------------------|
| I-11 & ISFSI-11 (neutron) | Special Interest | SW | 0.31 | OCA Fence South, on exit road |
| I-12 & ISFSI-12 (neutron) | Special Interest | SW | 0.32 | OCA Fence Middle, on exit road |
| I-13 & ISFSI-13 (neutron) | Special Interest | WSW | 0.34 | OCA Fence North, on exit road |

6.0 MAPS OF COLLECTION SITES




Figure 2, REMP Sample Locations (Surface Water, Sediment, Well Water, Air, and Vegetation)




Figure 3, REMP Sample Locations (5 Mile Ring and Special Interest TLD Locations)




Figure 4, REMP Sample Locations (Site Boundary TLD Locations)




Figure 5, REMP Sample Locations (Control Locations)




Figure 6, REMP Sample Locations (ISFSI TLD Locations)

7.0 REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES

Table 6, Reporting Levels for Radioactivity Concentrations in Environmental Samples

| Radionuclide | Water (pCi/L) | Air Particulates or Gases (pCi/m ³) | Fish (pCi/Kg-wet) | Milk (pCi/L) | Food Products (pCi/Kg-wet) |
|--------------|------------------------|---|-------------------|---------------------|----------------------------|
| H-3 | 20,000 ⁽¹⁰⁾ | NA | NA | NA | NA |
| Mn-54 | 1,000 | NA | 30,000 | NA | NA |
| Fe-59 | 400 | NA | 10,000 | NA | NA |
| Co-58 | 1,000 | NA | 30,000 | NA | NA |
| Co-60 | 300 | NA | 10,000 | NA | NA |
| Zn-65 | 300 | NA | 20,000 | NA | NA |
| Zr-Nb-95 | 400 ⁽¹¹⁾ | NA | NA | NA | NA |
| I-131 | 2 ⁽¹²⁾ | 0.9 | NA | 3 | 100 |
| Cs-134 | 30 | 10 | 1,000 | 60 | 1,000 |
| Cs-137 | 50 | 20 | 2,000 | 70 | 2,000 |
| Ba-La-140 | 200 ⁽¹¹⁾ | NA | NA | 300 ⁽¹¹⁾ | NA |

¹⁰ For drinking water samples: If no drinking water pathway exists, a value of 30,000 pCi/L may be used.

¹¹ Total for parent and daughter product.

¹² If no drinking water pathway exists, a value of 20 pCi/L may be used.

Table 7, Maximum Values for the Limit of Detection

| Radionuclide | Water (pCi/L) | Air Particulates or Gases (pCi/m ³) | Fish (pCi/Kg-wet) | Milk (pCi/L) | Food Products (pCi/Kg-wet) | Sediment (pCi/Kg-dry) |
|--------------|-----------------------|---|----------------------|-----------------|-------------------------------|--------------------------|
| Gross Beta | 4.0 | 0.01 | NA | NA | NA | NA |
| H-3 | 2,000 ⁽¹³⁾ | NA | NA | NA | NA | NA |
| Mn-54 | 15 | NA | 130 | NA | NA | NA |
| Fe-59 | 30 | NA | 260 | NA | NA | NA |
| Co-58, Co-60 | 15 | NA | 130 | NA | NA | NA |
| Zn-65 | 30 | NA | 260 | NA | NA | NA |
| Zr-Nb-95 | 15 ⁽¹⁴⁾ | NA | NA | NA | NA | NA |
| I-131 | 1 ⁽¹⁵⁾ | 0.07 | | 1 | 60 | |
| Cs-134 | 15 | 0.05 | 130 | 15 | 60 | 150 |
| Cs-137 | 18 | 0.06 | 150 | 18 | 80 | 180 |
| Ba-La-140 | 15 ⁽¹⁴⁾ | | | 15 | | |

8.0 SAMPLING PROGRAM, PROGRAM MODIFICATION AND INTERPRETATION OF RESULTS

At most nuclear stations, data was collected prior to plant operation to determine background radioactivity levels in the environment. Annual data is routinely compared to preoperational and/or 10-year average values to determine if changes in the environs are present. Strict comparison is difficult to make due to fallout from historical nuclear weapon testing. Cesium-137 can be routinely found in environmental samples as a result of above ground nuclear weapons testing. It is important to note, levels of Cs-137 in environment are observed to fluctuate, for example as silt distributions shift due to natural erosion and transport processes, Cs-137 may or may not be observed in sediment samples. Results from samples collected and analyzed during the year 2025, are described below.

In the following sections, results from direct radiation, air, water, and food products analyzed as part of REMP in 2025 will be discussed. Sampling program descriptions and deviations will also be discussed.

¹³ If no drinking water pathway exists, a value of 3,000 pCi/L may be used. Some states may require a lower LLD for drinking water sources- per 40 CFR 141 Safe drinking water ACT.

¹⁴ The specified LLD applies to the daughter nuclide of an equilibrium mixture of the parent and daughter nuclides. Per the Radiological Assessment Branch Technical Position (BTP), the following values may be used for individual nuclide LLDs when equilibrium conditions are not met: 30 pCi/L for zirconium-95, 15 pCi/L for niobium-95, 60 pCi/L for barium-140, and 15 pCi/L for lanthanum-140.

¹⁵ If no drinking water pathway exists, a value of 15 pCi/l may be used.

| | | |
|--|--|---------------|
| Annual Radiological Environmental Operating Report | YEAR: 2025 | Page 25 of 86 |
| Company: Xcel Energy | Plant: Monticello Nuclear Generating Plant | |

8.1 Environmental Direct Radiation Dosimetry Results

Dose is measured as net exposure (field reading less transit reading) normalized to 91-day quarters. Data is treated and analyzed consistent with ANSI/HPS N13.37-2014, which compares the measured dose for each location to the baseline background dose for that location. Environmental dose rates vary by location, depending on geological and land use considerations, and remain relatively constant for any given location (unless land use changes). Some facilities observe seasonal variation in environmental doses. Baseline Background Doses have been determined for both quarterly and annual measurements at each location using historical field measurements.

ANSI/HPS N13.37-2014 uses the concept of minimum differential dose (MDD), which is the minimum facility-related dose that can be detected above background. Due to natural background variations and measurement sensitivities and uncertainties, minimum differential dose is not zero. MDD is calculated based on statistical performance of the dosimetry system in the environment and is site specific.

Normalized doses that exceed the Minimum Differential Dose value above the Baseline Background Dose are considered to indicate Facility-Related Dose; a quality assurance review is performed to verify that any results indicating Facility-Related Dose are accurate.

During the calendar year 2025, a total of 40 locations were monitored and data analyzed in accordance with the requirements in Table 1, Radiological Environmental Monitoring Program – Direct Radiation. Attachment 4, Environmental Direct Radiation Dosimetry Results, provides the annual direct radiation dosimetry analysis.

One of the TLD analysis results indicated detectable radiation above baseline during Q3 of 2025. The REMP TLDs are analyzed with ANSI 13.37 to determine any positive results. The 3rd Quarter 2025 REMP TLD M16B had a result of 20.9 mrem and after analysis shows a positive result of 7.5 mrem. The TLD vendor was contacted and confirmed the 20.9 mrem result was the correct reading. However, the vendor observed that the TLD arrived wet, as described in QIM 501000108865 and Table 9. Moisture can damage the TLD and affect results. The lab suspected the result was based on the wetness and the reading's high standard deviation. Additionally, there were no abnormal gaseous discharges from the site during this time and no other adjacent TLDs are positive. Even with this abnormal result, the annual facility dose at location M16B was still calculated to be a non-detectible amount. See Attachment 4, Environmental Direct Radiation Dosimetry Results.

M06B and M01S TLD were both missing in Q4 2024. The TLD was likely damaged due to weather or other environmental conditions. See Table 9: Sample Deviation Summary in Section 10.

8.2 Air Particulate and Radioiodine Sample Results

Air particulate filters and charcoal canisters were collected from locations specified in Table 2, Radiological Environmental Monitoring Program – Airborne. During the calendar year 2025, a total of 257 samples were collected and analyzed for iodine-131, gross beta, and/or gamma emitters (not including missed samples, noted below). Particulate samplers are used to continuously collect airborne particulates on a filter. The samples are analyzed for gross beta activity following filter changeout which occurs weekly. Gamma isotopic analysis is also performed on the samples collected at each location and is analyzed quarterly. Radioiodine (I-131) analysis is performed weekly on radioiodine sample cartridges.

Some of the air particulate and radioiodine samples were below detection and some contained radioactivity.

The average annual gross beta concentrations in airborne particulates were similar at the indicator (0.036 ± 0.013 picocuries per cubic meter (pCi/m³) for 2025) and control locations (0.035 ± 0.013 pCi/m³ for 2025). Air sampler M-1 was found with a partial sample the week of 02/05/2025 and the week of 07/30/2025. Partial samples are all considered missed samples. The M-3 weekly sample for the week of 09/03/2025 is also considered a missed sample due to a small hole the size of a ballpoint pen tip observed in the particulate filter. Further details are provided in Table 9: Sample Deviation Summary, in Section 10.

Air particulate and radioiodine results from this monitoring period, 2025, were compared to the average and range of the previous 10 years of data shown in Figure 7, and there were no changes in the baseline (specifically, the 2025 result was comparable to the previous 10-year dataset).




Figure 7, Air Particulate: Analysis for Gross Beta, Average for All Indicator vs. Control Locations

8.3 Waterborne Sample Results

8.3.1 Surface Water (i.e., Bay, Lake etc.)

Composite water samples are collected monthly at the upstream control location and at the downstream indicator locations. Monthly composite samples are analyzed for gamma emitters. Aliquots from the monthly composites are combined to form a quarterly composite which is then analyzed for tritium. During the calendar year 2025, a total of 21 surface water samples were collected and analyzed in accordance with the requirements in the ODCM and shown in Table 3, Radiological Environmental Monitoring Program – Waterborne. Barium-140 was detected at M-9 in May at 63.2 ± 88.3 pCi/L. Although this is below the laboratory MDC of 151 pCi/L, it exceeds the LLD of 60 pCi/L and therefore did not receive a U flag. Despite exceeding the Table 7 reporting level of 60 pCi/L, the quarterly average for April–June (with April and June values below the LLD) remains below 60 pCi/L.

Lanthanum-140 was detected at M-9 in November at 91.4 ± 160 pCi/L, which is below the MDC of 262 pCi/L but above the LLD of 15 pCi/L, so no U flag was assigned. The Q4 2025 average for lanthanum-140 is 5.82 pCi/L, well below the LLD. Per ODCM 07.01 (Section 2.1.3 C.), results that exceed the reporting level in Table 3.4-1 when averaged over any calendar quarter must be reported to the Commission within 30 days.

The vendor misplaced one of the July gamma isotopic samples at location M-9, which caused the July composite gamma isotopic sample to be categorized as a missed sample.

Samples could not be collected from M-8c in January and February of 2025 due to unsafe conditions for sampling (frozen river surface).

Table 9: Sample Deviation Summary contains further details on missed surface water samples.

Tritium concentrations in surface water were well below the EPA tritium drinking water limit of 20,000 pCi/L.




Figure 8: Surface Water Tritium Results

8.3.2 REMP Groundwater

Groundwater samples were collected from control location upgradient from the plant and indicator location downgradient from the plant. During the calendar year 2025, a total of 16 groundwater water samples were collected from offsite monitoring wells and analyzed in accordance with the requirements in the ODCM and shown in Table 3: Radiological Environmental Sampling Program – Exposure Pathway - Waterborne. A total of four control samples and a total of 12 indicator samples were collected. These samples were analyzed for tritium and gamma quarterly.

There were no samples containing detectable amounts of radioactivity. Tritium concentrations in groundwater were well below the EPA tritium drinking water limit of 20,000 pCi/L.




Figure 9: REMP Groundwater Tritium Sample Results

8.3.3 Drinking Water

A total of 12 drinking water samples were obtained in 2025. These samples were analyzed for gross beta and gamma analysis monthly and tritium quarterly in accordance with requirements in the ODCM and shown in Table 3, Radiological Environmental Monitoring Program – Waterborne. A detectible amount of gross beta resulted in samples taken on 06/02/2025 and 08/31/2025. Each of the results were slightly over the LLD value at 4.10 ± 2.2 pCi/L and 4.06 ± 3.06 pCi/L, respectively. The quarterly average for the third and fourth quarters of 2025 remained below the 4.0 pCi/L LLD. The 2025 quarterly average gross beta was below its respective LLD value, thus the annual dose for drinking water was assumed to be less than 1 mrem/year. Therefore, iodine-131 analyses were not conducted in 2025 per ODCM 07.01 Revision 27. Tritium concentrations in drinking water were well below the EPA tritium drinking water limit of 20,000 pCi/L.




Figure 10: Drinking Water Gross Beta Samples Control




Figure 11: Drinking Water Tritium Sample Results

8.3.4 Sediment from Shoreline

Shoreline sediment collections were made in May and September of 2025 and analyzed for gamma-emitting isotopes. Samples are collected at both indicator and control locations. A total of six shoreline samples were analyzed in accordance with requirements in the ODCM and shown in Table 3, Radiological Environmental Monitoring Program – Waterborne.

Naturally occurring beryllium-7 and potassium-40 were detected. There was no indication of a MNGP effect.

8.4 Ingestion Pathway Sample Results

8.4.1 Milk

Since 2019, one milk cow has been located in the NNE sector at 3.2 miles. The cow gave birth approximately five years ago and discussion with the owner confirmed they now milk the newer cow. Discussion with the owner indicates that when the cows are producing milk there is enough for the family to use, but not enough extra to provide samples in the quantity/frequency required for the site. There is also a beef cow and a garden at this location (Milk, Meat, and Vegetable exposure pathways present.) Due to the relatively low deposition parameter, the calculated dose at this location remains lower than other vegetable locations that are closer to the plant in high D/Q sectors. Milk samples are required for three locations within 1 mile or three locations where doses are calculated to be >1mRem/year per ODCM-07.01. The currently identified milk location is outside 3 miles and maximum calculated dose by all pathways was 0.0172 mRem to infant thyroid. Thus, vegetation sampling was performed in lieu of milk sampling. Samples are collected from broad leaf vegetation grown nearest each of two different offsite locations of highest predicated annual average ground level atmospheric deposition factors (D/Q). Samples were analyzed for gamma isotopic and I-131 monthly.

8.4.2 Fish

A total of seven fish samples were collected in 2025 from the indicator and control areas as required by the ODCM. These samples were analyzed for gamma emitting radionuclides in edible portions, in accordance with requirements of the ODCM and summarized in Table 4, Radiological Environmental Monitoring Program – Ingestion. These samples are collected from the indicator and control areas as required by the ODCM.

Smallmouth bass were unable to be obtained at the M-9 sampling location due to low river level during the second semiannual fish sampling event. However, samples of the red horse species collected at upstream and downstream locations fulfilled the one species at each location requirement per ODCM-07.01. Naturally occurring potassium-40 was detected in both indicator and control location fish samples during each sampling event.

8.4.3 Food Products

Food product samples were not analyzed in 2025, as this sample pathway is currently unavailable to MNGP.

There are no crops being irrigated from the Mississippi River within five miles downstream of the plant, based upon the most recent Water Use Resources Permit Index Report from the Minnesota Department of Natural Resources. The nearest downstream drinking water supplies drawn from the Mississippi River remain St. Paul and Minneapolis water supplies as currently documented in the ODCM and Updated Final Safety Analysis Report.

8.4.4 Leafy Vegetation

In accordance with the ODCM and as described in Table 4, Radiological Environmental Monitoring Program – Ingestion, in the highest predicted annual average ground level D/Q sectors, 12 broad leaf vegetation samples were collected from the growing locations near the site boundary. Samples are collected and analyzed for gamma isotopic and I-131 from the indicator and control locations monthly during growing season. It is common to detect Cs-137 in broadleaf samples at both indicator and control locations. Cs-137 can be attributed to offsite sources such as weapons testing, Chernobyl, and Fukushima events.

Leafy vegetation samples contained no detectable amounts of radioactivity in 2025.

9.0 LAND USE CENSUS

The ODCM requires the performance of an annual land use census, where changes in how the land is used at or beyond the site boundary are documented. These changes are evaluated and modifications to the REMP are made as needed. The land use census satisfies the requirements of Section IV.B.3 of Appendix I to 10 CFR 50 [2]. NUREG-1301/1302 Control 3.12.2 specifies that "a Land Use Census shall be conducted and shall identify within a distance of 8 km (5 mi.) the location in each of the 16 meteorological sectors of the nearest milk animal, the nearest residence and the nearest garden of greater than 50 m² (500 ft²) producing broad leaf vegetation." MNGP also located all milk animals, meat animals, and gardens of 500 ft² or greater with leafy green vegetables within a three-mile radius of the plant. Note, per NUREG-1301/1302, Broad leaf vegetation sampling of at least three different kinds of vegetation may be performed at the SITE BOUNDARY in each of two different direction sectors with the highest predicted D/Qs in lieu of the garden census.

The land use census was conducted within the growing season in the calendar year 2025 to identify changes in land use, receptor locations, and new exposure pathways. The results for the 2025 Land Use Census are listed in Table 8: Land Use Census – Nearest Receptors within 5 miles. In summary, the highest D/Q locations for nearest garden, nearest residence and nearest milk animal did not change following the 2025 census. In summary, the highest D/Q Residence remained the same. The highest D/Q garden has remained the same and is the critical receptor at 1.11 miles SE (G). The highest D/Q meat and Meat/Vegetable locations remained the same as last year (1.8 mi WSW and 1.8 mi W, respectively). There are two milk animals currently being milked at one location located between 3-5 miles from the plant with calculated dose <0.05 mrem so sampling is not required for this location.

Table 8: Land Use Census – Nearest Receptors within 5 miles

| Sector | Direction | Nearest Residence (Miles) | Meat Animal (Miles) | Nearest Milk Animal (Miles) | Meat and Garden (Miles) | Nearest Garden (Miles) |
|--------|-----------|---------------------------|---------------------|-----------------------------|-------------------------|------------------------|
| A | N | 2.58 | 3.78 | | | 3.31 |
| B | NNE | 2.63 | 3.28 | 3.24 | 3.30 | 3.30 |
| C | NE | 2.24 | 3.30 | | | 2.78 |
| D | ENE | 1.35 | | | | 2.41 |
| E | E | 1.38 | | | | 1.74 |
| F | ESE | 1.49 | | | | 1.50 |
| G | SE | 1.00 | | | | 1.14 |
| H | SSE | 0.99 | | | | 1.21 |
| J | S | 0.83 | 4.40 | | 4.40 | 0.90 |
| K | SSW | 0.64 | 4.54 | | | 1.64 |
| L | SW | 0.52 | 2.27 | | 3.40 | 2.01 |
| M | WSW | 0.72 | 1.78 | | 2.32 | 1.22 |
| N | W | 1.29 | 1.82 | | 1.82 | 1.38 |
| P | WNW | 1.32 | 3.15 | | 3.40 | 1.68 |
| Q | NW | 2.28 | 3.43 | | | 2.49 |
| R | NNW | 2.40 | | | | 2.39 |

10.0 SAMPLE DEVIATIONS, ANOMALIES AND UNAVAILABILITY

Sampling and analysis are performed for media types addressed in the Offsite Dose Calculation Manual. Sampling and analysis challenges may be experienced due to a multitude of reasons including environmental factors, loss of TLDs/OSLDs, contamination of samples, etc. To aid classification of sampling and analysis challenges experienced in 2025, the following three terms are used to describe the issues: Sample Anomalies, Sample Deviation, and Unavailable Samples.

Media that experienced downtime (i.e., air samplers or water samplers) during a surveillance period are classified a "Sample Deviation". "Sample Anomalies" are defined as errors that were introduced to a sample once it arrived in the laboratory, errors that prevents the sample from being analyzed as it normally would or may have altered the outcome of the analysis (i.e., cross contamination, human error).

"Sample Unavailability" is defined as sample collection with no available sample (i.e., food crop, TLD).

All required samples were collected and analyzed as scheduled except for the following:

Table 9: Sample Deviation Summary

| Sample Type and Analysis | Location | Collection Date or Period | Reason for not conducting REMP sampling as required by ODCM | Plans for preventing reoccurrence |
|------------------------------|----------|---------------------------|--|---|
| Surface Water Gamma Isotopic | M-8c | Jan-25 | Unsafe condition for sampling due to frozen river surface (501000093699 501000093881 501000094082 501000094265 501000094565). | Sample obtained when water thawed. Expected seasonal condition. |
| Surface Water Gamma Isotopic | M-8c | Feb-25 | Unsafe condition for sampling due to frozen river surface (501000094875 501000095584). | Sample obtained when water thawed. Expected seasonal condition. |
| Surface Water Tritium | M-8c | 1Q | Unsafe condition for sampling due to frozen river surface (501000093699 501000093881 501000094082 501000094265 501000094565 501000094875 501000095584 501000095872). | Sample obtained when water thawed. Expected seasonal condition. |

Table 9: Sample Deviation Summary

| | | | | |
|--|------|-----------------------|---|---|
| Airborne Particulate Gross Beta and Radioiodine | M-1 | Week of 02/05/2025 | Following quarterly pump calibration and pump changeout, GFCI outlet tripped and failed to reset. Declaring missed sample due to possibility of partial sample (501000094934). | Returned to M-1 air sampler and started sample pump. Documented these actions in CAP and 2025 DAR for missed/partial samples. GFCI replacement completed by commercial electrician. |
| Surface Water Gamma Isotopic | M-8c | Mar-25 | Unsafe condition for sampling due to frozen river surface (501000095872). | Sample obtained when water thawed. Expected seasonal condition. |
| Direct Radiation Gamma Dose | M16B | Q3 | TLD arrived wet, abnormal result value (501000108865). | Include result and discussion in 2025 ARERR. |
| Airborne Particulate Gross Beta and Radioiodine | M-1 | Week of 07/30/2025 | Pump was found not running when performing weekly filter replacement activities. After some troubleshooting, the GFCI was found to be tripped. The air sampler ran for a total of 80.30 hours and likely tripped off during one of the storms experienced earlier in the week. Declaring missed sample due to possibility of partial sample (501000101417). | After the GFCI was reset, the pump started, and the filter was replaced per procedure 1.05.33. Wrote CAP. Informed Shift Manager and Chemistry Supervision. |
| Surface Water Gamma Isotopic | M-9 | Jul-25 | Vendor misplaced sample (501000104658). | The site provided coaching to the vendor on improving their communication when these issues occur; the vendor is taking actions to prevent recurrence per their corrective action program. (GEL Report 737332_082125) |

Table 9: Sample Deviation Summary

| | | | | |
|---|-------------------|--------------------|---|---|
| Airborne Particulate Gross Beta and Radioiodine | M-3 | Week of 09/03/2025 | During weekly filter media replacement on the REMP air samplers, a small hole the size of a ballpoint pen tip was found in the particulate filter of REMP air sampler M-3 located near the MET tower. Some of the total air sample flow bypassed the particulate filter through the hole as evidenced by the staining on the charcoal cartridge (501000102650). | Informed Radiochemist and spoke with Shift Manager about any implications resulting from a missed weekly REMP air sample. Per procedure, shipped the partial sample along with the 4 other weekly samples for outside lab analysis. |
| Surface Water Gamma Isotopic | M-8c | Dec-25 | Unsafe condition for sampling due to frozen river surface (501000106407 501000106191). | Sample obtained when water thawed. Expected seasonal condition. |
| Direct Radiation Gamma Dose | M06B M01S | Q4 | TLDs found missing. M06B was mounted to a siren pole and siren pole was missing during sample collection. M01S was also found missing and its pole was found damaged (501000106606). | Attached a new TLD holder at each location for M06B and M01S. Updated REMP tracking DAR. |
| 2 nd semiannual smallmouth bass at M-9 | M-9 Downstream | Sep - 2025 | Bass were unable to be collected due to low river level prohibiting the use of electrofishing. | Obtained redhorse at both upstream and downstream locations, meeting the sampling requirements of the ODCM for one species at both upstream and downstream locations. |

11.0 OTHER SUPPLEMENTAL INFORMATION

11.1 NEI 07-07 Onsite Radiological Groundwater Monitoring Program

Monticello Nuclear Generating Plant has developed a Groundwater Protection Initiative (GPI) program in accordance with NEI 07-07, Industry Ground Water Protection Initiative – Final Guidance Document. The purpose of the GPI is to ensure timely detection and an effective response to situations involving inadvertent radiological releases to groundwater in order to prevent migration of licensed radioactive material off-site and to quantify impacts on decommissioning. It is important to note that samples and results taken in support of NEI 07-07 on-site groundwater monitoring program are separate from the Radiological Environmental Monitoring Program (REMP). Results of the NEI 07-07 Radiological Groundwater Monitoring Program for onsite groundwater wells are provided in the ARERR.

11.2 Independent Spent Fuel Storage Installation (ISFSI) Monitoring Program

Gamma and Neutron TLDs are located around the Independent Spent Fuel Storage Installation (ISFSI) to monitor direct radiation from stored fuel for trending purposes. The ISFSI TLDs are not considered true REMF TLDs and are not representative of the dose to members of the public. Results for monitoring are included in Attachment 2.

No additional spent fuel casks were moved to the ISFSI in 2025. Annual data trends at and in the vicinity of the ISFSI are consistent with expectations. There were no detectable dose rate increases observed at the Site boundary TLDs in 2025.

11.3 Corrections to Previous Reports

There are no corrections to any other AREORs included with this report.

| | | |
|---|---|----------------------|
| Annual Radiological Environmental Operating Report | YEAR: 2025 | Page 38 of 86 |
| Company: Xcel Energy | Plant: Monticello Nuclear Generating Plant | |

12.0 BIBLIOGRAPHY

- [1] NCRP, "Report No. 160, Ionizing Radiation Exposure of the Population of the United States," National Council on Radiation Protection, Bethesda, 2009.
- [2] "10 CFR 50, "Domestic Licensing of Production and Utilization Facilities"," US Nuclear Regulatory Commission, Washington, DC.
- [3] "Regulatory Guide 4.1, "Radiological Environmental Monitoring for Nuclear Power Plants", Revision 2," Nuclear Regulatory Commission, 2009.
- [4] "NUREG-1301, "Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent Controls for Pressurized Water Reactors," .," Nuclear Regulatory Commission, April 1991.
- [5] "NUREG-1302, "Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent Controls for Boiling Water Reactors," ,," Nuclear Regulatory Commission, April 1991.
- [6] "Branch Technical Position, Revision 1," NRC000096, Submitted March 30, 2012, November 1979.
- [7] "Japan Atomic Energy Agency," 06 November 2020. [Online]. Available: https://www.jaea.go.jp/english/04/ntokai/houkan/houkan_02.html.
- [8] "Regulatory Guide 4.15, Quality Assurance for Radiological Monitoring Programs (Inception through Normal Operations to License Termination) -- Effluent Streams and the Environment," Nuclear Regulatory Commission, July, 2007.
- [9] "Regulatory Guide 4.13, Performance, Testing, and Procedural Specifications for Thermoluminescence Dosimetry: Environmental Applications, Revision 2," Nuclear Regulatory Commission, June, 2019.
- [10] "NUREG/CR-2919, "XOQDOQ Computer Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations," ,," Nuclear Regulatory Commission, September, 1982.
- [11] "Measurements of Radionuclides in the environment Sampling and Analysis of plutonium in soil," Nuclear Regulatory Commission, 1974.
- [12] "Ionizing Radiation Exposure of the Population of the United States," Bethesda, MD, 2009.
- [13] Nuclear Regulatory Commission, 30 June 2015. [Online]. Available: <http://www.nrc.gov/reading-rm/basic-ref/students/animated-pwr.html>. [Accessed October 2020].
- [14] "ICRP Publication 60, "ICRP Publication 60: 1990 Recommendations of the International Commission on Radiological Protection, 60," Annals of the ICRP Volume 21/1-3,," International Commission on Radiation Protection, October, 1991.
- [15] "NRC Resource Page," [Online]. Available: <http://www.nrc.gov/about-nrc/radiation.html>. [Accessed 10 November 2020].
- [16] "NUREG-0133, Preparation of Effluent Technical Specifications for Nuclear Power Plants," Nuclear Regulatory Commission, 1987.
- [17] "Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Demonstrating Compliance with 10 CFR Part 50, Appendix I,," Nuclear Regulatory Commission, Ocotober, 1977.
- [18] [Online]. Available: <http://hps.org/hpspublications/radiationfactsheets.html>. [Accessed 2020].
- [19] "NEI 07-07, "Industry Ground Water Protection Initiative—Final Guidance Document," ,," Nuclear Energy Institute, Washington, D.C..

| | | |
|---|---|----------------------|
| Annual Radiological Environmental Operating Report | YEAR: 2025 | Page 39 of 86 |
| Company: Xcel Energy | Plant: Monticello Nuclear Generating Plant | |

- [20] "ANSI 13.37, Environmental Dosimetry- Criteria for System Design and Implementation," Health Physics Society (HPS), May, 2019.
- [21] "40 CFR Part 141, "National Primary Drinking Water Regulations,"" US Environmental Protection Agency, Washington, DC..
- [22] Nuclear Regulatory Commission, 25 June 2015. [Online]. Available: <http://www.nrc.gov/reading-rm/basic-ref/students/animated-bwr.html>. [Accessed October 2020].
- [23] "NEI 07-07, "Industry Ground Water Protection Initiative—Final Guidance Document," Rev. 1," Nuclear Energy Institute, Washington, D.C., 2019.
- [24] Nuclear Regulatory Commission, 25 June 2015. [Online]. Available: <http://www.nrc.gov/reading-rm/basic-ref/students/animated-bwr.html>. [Accessed October 2020].
- [25] [Online]. Available: <http://hps.org/hpspublications/radiationfactsheets.html>. [Accessed 2020].
- [26] "Japan Atomic Energy Agency," 06 November 2020. [Online]. Available: https://www.jaea.go.jp/english/04/ntokai/houkan/houkan_02.html.
- [27] "NRC Resource Page," [Online]. Available: <http://www.nrc.gov/about-nrc/radiation.html>. [Accessed 10 November 2020].
- [28] "NUREG-0133, Preparation of Effluent Technical Specifications for Nuclear Power Plants," Nuclear Regulatory Commission, 1987.
- [29] Nuclear Regulatory Commission, 30 June 2015. [Online]. Available: <http://www.nrc.gov/reading-rm/basic-ref/students/animated-pwr.html>. [Accessed October 2020].
- [30] "Regulatory Guide 4.13, Performance, Testing, and Procedural Specifications for Thermoluminescence Dosimetry: Environmental Applications, Revision 2," Nuclear Regulatory Commission, June, 2019.
- [31] "Regulatory Guide 4.15, Quality Assurance for Radiological Monitoring Programs (Inception through Normal Operations to License Termination) -- Effluent Streams and the Environment," Nuclear Regulatory Commission, July, 2007.
- [32] "10 CFR 50 - Domestic Licensing of Production and Utilization Facilities," US Nuclear Regulatory Commission, Washington, DC.
- [33] "40 CFR 190 - Environmental Radiation Protection Standards for Nuclear Power Operation," US Environmental Protection Agency, Washington, DC.
- [34] "NUREG-0324 - XOQDOQ, Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations," Nuclear Regulatory Commission, September, 1977.
- [35] "NCRP Report No. 160 - Ionizing Radiation Exposure of the Population of the United States," National Council on Radiation Protection and Measurements, Bethesda, MD, 2009.
- [36] "Regulatory Guide 1.109 - Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Demonstrating Compliance with 10 CFR Part 50, Appendix I," Nuclear Regulatory Commission, October, 1977.
- [37] "40 CFR 141 - National Primary Drinking Water Regulations," US Environmental Protection Agency, Washington, DC..
- [38] "10 CFR 20 - Standards for Protection Against Radiation," US Nuclear Regulatory Commission, Washington, DC.

Attachment 1, Data Table Summary

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed (e.g. I-131, 400) | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ (f) ¹⁷ Range ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ Range ¹⁶ | Number of Nonroutine Reported Measurements |
|---|---|---|--|-------------------------------------|------------------------------|---|--|
| | | | | Name | Mean ¹⁶ | | |
| | | | | Distance and Direction | (f) ¹⁷ | | |
| | | | | | Range ¹⁶ | | |
| Airborne Particulates (pCi/m ³) | Gross Beta (257) | 0.01 | 0.036 (207/207) 0.012 - 0.083 | M-2, Air Station 11.0 m @ 104 SE | 0.037 (50/50) 0.016-0.083 | 0.035 (50/50) 0.012-0.067 | 0 |
| | Gamma (20) | | | | | | 0 |
| | Be-7 ¹⁸ | - | 0.053 (20/20) 0.031 - 0.091 | M-2, Air Station 11.0 m @ 104 SE | 0.059 (5/5) 0.051 - 0.090 | 0.065 (4/4) 0.037 - 0.091 | |
| | Mn-54 | - | <LLD | - | - | <LLD | |
| | Co-58 | - | <LLD | - | - | <LLD | |
| | Co-60 | - | <LLD | - | - | <LLD | |
| | Zn-65 | - | <LLD | - | - | <LLD | |
| | Zr-Nb-95 | - | <LLD | - | - | <LLD | |
| | Ru-103 | - | <LLD | - | - | <LLD | |
| | Ru-106 | - | <LLD | - | - | <LLD | |
| | Cs-134 | 0.05 | <LLD | - | - | <LLD | |
| | Cs-137 | 0.06 | <LLD | - | - | <LLD | |
| | Ba-La-140 | - | <LLD | - | - | <LLD | |
| | Ce-141 | - | <LLD | - | - | <LLD | |
| Ce-144 | - | <LLD | - | - | <LLD | | |
| Airborne Radioiodine (pCi/m ³) | I-131 (257) | 0.07 | <LLD | - | - | <LLD | 0 |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

¹⁸ Natural and not due to Plant influence.

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ | Number of Nonroutine Reported Measurements |
|-----------------------------------|--|---|------------------------------|-----------------------------------|--------------------|--|--|
| | (e.g. I-131, 400) | | (f) ¹⁷ | Name | Mean ¹⁶ | Range ¹⁶ | |
| | | | Range ¹⁶ | Distance and Direction | (f) ¹⁷ | | |
| Broadleaf Vegetation (pCi/kg-wet) | Gamma (12) | | | | | | 0 |
| | Mn-54 | - | <LLD | - | - | <LLD | |
| | Fe-59 | - | <LLD | - | - | <LLD | |
| | Co-58 | - | <LLD | - | - | <LLD | |
| | Co-60 | - | <LLD | - | - | <LLD | |
| | Zn-65 | - | <LLD | - | - | <LLD | |
| | Zr-Nb-95 | - | <LLD | - | - | <LLD | |
| | I-131 | 60 | <LLD | - | - | <LLD | |
| | Cs-134 | 60 | <LLD | - | - | <LLD | |
| | Cs-137 | 80 | <LLD | - | - | <LLD | |
| Milk (pCi/L) | I-131 (0) | 1 | N/A | N/A | N/A | N/A | 0 |
| | Gamma (0) | N/A | N/A | N/A | N/A | N/A | 0 |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ | Number of Nonroutine Reported Measurements |
|--------------------------------------|---|---|---------------------------------|--------------------------------------|---------------------------|---|---|
| | (e.g. I-131, 400) | | (f) ¹⁷ | Name | Mean ¹⁶ | Range ¹⁶ | |
| | | | Range ¹⁶ | Distance and Direction | (f) ¹⁷ | | |
| | | | | Range ¹⁶ | | | |
| Fish (pCi/kg-wet) | Gamma (7) | | | | | | 0 |
| | K-40 ¹⁹ | - | 3020 (4/4) 2900 - 3150 | M-8 Upstream of Plant | 3147 (4/4) 2710 - 3960 | 3147 (4/4) 2710 - 3960 | |
| | Mn-54 | 130 | <LLD | - | - | <LLD | |
| | Fe-59 | 260 | <LLD | - | - | <LLD | |
| | Co-58 | 130 | <LLD | - | - | <LLD | |
| | Co-60 | 130 | <LLD | - | - | <LLD | |
| | Zn-65 | 260 | <LLD | - | - | <LLD | |
| | Zr-Nb-95 | - | <LLD | - | - | <LLD | |
| | Cs-134 | 130 | <LLD | - | - | <LLD | |
| | Cs-137 | 150 | <LLD | - | - | <LLD | |
| | Ba-La-140 | - | <LLD | - | - | <LLD | |
| | Ce-144 | - | <LLD | - | - | <LLD | |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

¹⁹ Natural and not due to Plant influence.

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ | Number of Nonroutine Reported Measurements |
|-----------------------------------|--|---|------------------------------|-----------------------------------|-----------------------------|--|--|
| | (e.g. I-131, 400) | | (f) ¹⁷ | Name | Mean ¹⁶ | Range ¹⁶ | |
| | | | | Distance and Direction | (f) ¹⁷ | | |
| | | | | | Range ¹⁶ | | |
| Shoreline Sediments (pCi/kg-dry) | Gamma (6) | | | | | | 0 |
| | Be-7 ⁽¹⁸⁾ | - | 639 (1/4) 639 | M-9 Downstream of Plant | 639 (1/4) 639 | - (0/2) - | |
| | K-40 ⁽¹⁸⁾ | - | 11267 (4/4) 9070 - 12900 | M-9 Downstream of Plant | 12900 (2/2) 9070 - 12900 | 11500 (2/2) 9800 - 10200 | |
| | Mn-54 | - | <LLD | - | - | <LLD | |
| | Fe-59 | - | <LLD | - | - | <LLD | |
| | Co-58 | - | <LLD | - | - | <LLD | |
| | Co-60 | - | <LLD | - | - | <LLD | |
| | Zn-65 | - | <LLD | - | - | <LLD | |
| | Zr-Nb-95 | - | <LLD | - | - | <LLD | |
| | Cs-134 | 150 | <LLD | - | - | <LLD | |
| | Cs-137 | 180 | <LLD | - | - | <LLD | |
| | Ba-La-140 | - | <LLD | - | - | <LLD | |
| | Ce-144 | - | <LLD | - | - | <LLD | |
| - | | | - | | | | |
| - | | | - | | | | |
| - | | | - | | | | |
| Drinking Water (pCi/L) | Gross Beta (12) | 4 | <LLD | M-14 City of Minneapolis | 4.08 (2/12) 4.06 - 4.10 | None | 0 |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ | Number of Nonroutine Reported Measurements |
|-----------------------------------|--|---|------------------------------|-----------------------------------|--------------------|--|--|
| | (e.g. I-131, 400) | | (f) ¹⁷ | Name | Mean ¹⁶ | Range ¹⁶ | |
| | | | Range ¹⁶ | Distance and Direction | (f) ¹⁷ | | |
| Drinking Water (pCi/L) | Gamma (12) | | | | | | 0 |
| | Mn-54 | 15 | <LLD | - | - | None | |
| | Fe-59 | 30 | <LLD | - | - | None | |
| | Co-58 | 15 | <LLD | - | - | None | |
| | Co-60 | 15 | <LLD | - | - | None | |
| | Zn-65 | 30 | <LLD | - | - | None | |
| | Zr-Nb-95 | 15 ⁽²⁰⁾ | <LLD | - | - | None | |
| | Cs-134 | 15 | <LLD | - | - | None | |
| | Cs-137 | 18 | <LLD | - | - | None | |
| | Ba-La-140 | 15 ⁽²⁰⁾ | <LLD | - | - | None | |
| | Ce-144 | - | <LLD | - | - | None | |
| | I-131 (0) | 1 | | - | - | None | 0 |
| Tritium (4) | 2000 | | <LLD | - | - | None | 0 |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

²⁰ The specified LLD applies to the daughter nuclide of an equilibrium mixture of the parent and daughter nuclides. Per the BPT, the following values may be used for individual nuclide LLDs when equilibrium conditions are not met: 30 pCi/L for zirconium-95, 15 pCi/L for niobium-95, 60 pCi/L for barium-140, and 15 pCi/L for lanthanum-140.

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ | Number of Nonroutine Reported Measurements |
|-----------------------------------|--|---|------------------------------|-----------------------------------|--------------------|--|--|
| | (e.g. I-131, 400) | | (f) ¹⁷ | Name | Mean ¹⁶ | Range ¹⁶ | |
| | | | Range ¹⁶ | Distance and Direction | (f) ¹⁷ | | |
| Groundwater (pCi/L) | Gamma (16) | | | | | | 0 |
| | Mn-54 | 15 | <LLD | - | - | <LLD | |
| | Fe-59 | 30 | <LLD | - | - | <LLD | |
| | Co-58 | 15 | <LLD | - | - | <LLD | |
| | Co-60 | 15 | <LLD | - | - | <LLD | |
| | Zn-65 | 30 | <LLD | - | - | <LLD | |
| | Zr-Nb-95 | 15 ⁽²⁰⁾ | <LLD | - | - | <LLD | |
| | Cs-134 | 15 | <LLD | - | - | <LLD | |
| | Cs-137 | 18 | <LLD | - | - | <LLD | |
| | Ba-La-140 | 15 ⁽²⁰⁾ | <LLD | - | - | <LLD | |
| | Ce-144 | - | <LLD | - | - | <LLD | |
| | I-131 ⁽²¹⁾ (0) | 1 ⁽²²⁾ | <LLD | - | - | <LLD | 0 |
| Tritium (4) | 2000 | <LLD | - | - | <LLD | 0 | |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

²⁰ The specified LLD applies to the daughter nuclide of an equilibrium mixture of the parent and daughter nuclides. Per the BPT, the following values may be used for individual nuclide LLDs when equilibrium conditions are not met: 30 pCi/L for zirconium-95, 15 pCi/L for niobium-95, 60 pCi/L for barium-140, and 15 pCi/L for lanthanum-140.

²¹ Not required.

²² If no drinking water pathway exists, a value of 15 pCi/L may be used.

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ | Number of Nonroutine Reported Measurements |
|---|--|---|------------------------------|-----------------------------------|----------------------------|--|--|
| | (e.g. I-131, 400) | | (f) ¹⁷ | Name | Mean ¹⁶ | Range ¹⁶ | |
| | | | Range ¹⁶ | Distance and Direction | (f) ¹⁷ | | |
| River Water (pCi/L) | Gamma (21) | | | | | | 0 |
| | Mn-54 | 15 | <LLD | - | - | <LLD | |
| | Fe-59 | 30 | <LLD | - | - | <LLD | |
| | Co-58 | 15 | <LLD | - | - | <LLD | |
| | Co-60 | 15 | <LLD | - | - | <LLD | |
| | Zn-65 | 30 | <LLD | - | - | <LLD | |
| | Zr-Nb-95 | 15 ⁽²⁰⁾ | <LLD | - | - | <LLD | |
| | Cs-134 | 15 | <LLD | - | - | <LLD | |
| | Cs-137 | 18 | <LLD | - | - | <LLD | |
| | Ba-La-140 | 15 ⁽²⁰⁾ | 77 (2/11) | M-9 Downstream of Plant | 77 (2/11) 63 - 91 | - (0/10) - | |
| Ce-144 | - | <LLD | - | - | <LLD | | |
| | Tritium (8) | 2000 | <LLD | - | - | <LLD | 0 |
| Direct Radiation: Control (10 to 12 miles distant) (mrem/91 days) | Gamma (16) | - | N/A | M03C 11.6 mi @ 130/SE | 14.0 (4/4) (12.0- 15.7) | 10.6 (16/16) (12.2 – 14.0) | 0 |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

²⁰ The specified LLD applies to the daughter nuclide of an equilibrium mixture of the parent and daughter nuclides. Per the BPT, the following values may be used for individual nuclide LLDs when equilibrium conditions are not met: 30 pCi/L for zirconium-95, 15 pCi/L for niobium-95, 60 pCi/L for barium-140, and 15 pCi/L for lanthanum-140.

| Medium or Pathway Sampled (Units) | Type, Total Number of Analyses performed | ODCM Table 3 Lower Limit of Detection (LLD) | Indicator Mean ¹⁶ | Location with Highest Annual Mean | | Control Mean ¹⁶ (f) ¹⁷ Range ¹⁶ | Number of Nonroutine Reported Measurements |
|--|--|---|-------------------------------|-----------------------------------|--|---|--|
| | (e.g. I-131, 400) | | (f) ¹⁷ | Name | Mean ¹⁶ | | |
| | | | Range ¹⁶ | Distance and Direction | (f) ¹⁷ Range ¹⁶ | | |
| Direct Radiation: Inner Ring (General Area at Site Boundary) (mrem/91 days) | Gamma (56) | - | 14.7 (56/56) (10.4 – 17.9) | M01A, 0.75 mi @ 353/N | 16.5 (4/4) (14.7-17.9) | | 0 |
| Direct Radiation: Outer Ring (4-5 mi. distant) (mrem/91 days) | Gamma (63) | - | 14.4 (63/63) (11.2 – 20.9) | M16B, 4.4 mi @ 341/NNW | 15.6 (4/4) (11.2 – 20.9) | | 0 |
| Direct Radiation: Special Interest Areas (mrem/91 days) | Gamma (35) | - | 14.4 (35/35) (11.1 – 17.3) | I-13 0.34 mi @ 240/WSW | 15.4 (4/4) (13.2- 17.3) | | 0 |

¹⁶ Mean and range are based upon detectible measurements only.

¹⁷ (f) Fraction of detectible measurements at a specific location.

Attachment 2, Complete Data Table for All Analysis Results Obtained In 2025

| Table 10: Airborne Cartridge: Radioiodine (pCi/m3) | | | | | |
|--|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Date | Air Station M-1 | Air Station M-2 | Air Station M-3 | Air Station M-4 | Air Station M-5 |
| 1/2/2025 | -7.17E-03 ± 1.14E-02 U | 1.12E-02 ± 1.02E-02 U | 8.20E-03 ± 7.66E-03 U | 4.32E-03 ± 1.28E-02 U | 4.36E-04 ± 1.23E-02 U |
| 1/8/2025 | -3.83E-03 ± 2.21E-02 U | -6.05E-03 ± 2.26E-02 U | 8.91E-03 ± 2.05E-02 U | 8.22E-03 ± 2.03E-02 U | 3.68E-03 ± 1.56E-02 U |
| 1/15/2025 | 6.56E-03 ± 2.58E-02 U | 1.61E-02 ± 2.09E-02 U | 1.66E-02 ± 2.23E-02 U | -1.04E-02 ± 2.59E-02 U | -5.99E-03 ± 2.07E-02 U |
| 1/22/2025 | -2.10E-03 ± 1.06E-02 U | 6.46E-03 ± 1.68E-02 U | -2.62E-03 ± 9.92E-03 U | 8.46E-03 ± 1.89E-02 U | -2.89E-03 ± 1.97E-02 U |
| 1/29/2025 | -1.24E-03 ± 1.68E-02 U | -1.38E-03 ± 1.67E-02 U | -7.28E-03 ± 1.44E-02 U | -4.01E-04 ± 1.61E-02 U | 1.18E-02 ± 1.64E-02 U |
| 2/5/2025 | 2.32E-04 ± 2.65E-02 U | -2.53E-02 ± 3.45E-02 U | 8.69E-05 ± 3.44E-02 U | -7.26E-04 ± 3.35E-02 U | 1.27E-02 ± 2.67E-02 U |
| 2/11/2025 | -6.22E-03 ± 2.07E-02 U | -1.85E-03 ± 2.15E-02 U | 6.73E-03 ± 1.79E-02 U | 2.20E-03 ± 1.41E-02 U | -1.47E-02 ± 2.96E-02 U |
| 2/19/2025 | 3.04E-03 ± 1.38E-02 U | -1.79E-03 ± 1.53E-02 U | 7.09E-03 ± 9.99E-03 U | 3.62E-03 ± 1.34E-02 U | -6.25E-04 ± 1.43E-02 U |
| 2/26/2025 | -2.20E-02 ± 3.04E-02 U | 3.06E-03 ± 2.71E-02 U | -8.56E-03 ± 3.32E-02 U | 2.76E-03 ± 2.49E-02 U | 1.49E-03 ± 2.72E-02 U |
| 3/6/2025 | 5.08E-03 ± 1.52E-02 U | 5.59E-03 ± 1.51E-02 U | 5.84E-03 ± 1.06E-02 U | -4.40E-03 ± 1.46E-02 U | 1.75E-03 ± 1.16E-02 U |
| 3/12/2025 | -1.26E-02 ± 2.46E-02 U | 1.38E-02 ± 1.52E-02 U | -3.79E-03 ± 1.34E-02 U | 7.81E-03 ± 1.86E-02 U | 9.55E-04 ± 1.50E-02 U |
| 3/18/2025 | 1.21E-02 ± 2.75E-02 U | 3.54E-03 ± 3.92E-02 U | -1.80E-02 ± 2.57E-02 U | -8.34E-03 ± 2.35E-02 U | 2.44E-02 ± 2.90E-02 U |
| 3/26/2025 | -4.38E-03 ± 1.36E-02 U | 8.18E-03 ± 1.71E-02 U | 2.58E-03 ± 1.09E-02 U | -6.08E-03 ± 1.63E-02 U | -4.08E-03 ± 1.13E-02 U |
| 4/3/2025 | -1.20E-02 ± 1.27E-02 U | 1.34E-03 ± 1.45E-02 U | 4.20E-03 ± 8.57E-03 U | 3.28E-04 ± 8.64E-03 U | -1.32E-03 ± 1.26E-02 U |
| 4/9/2025 | -4.31E-02 ± 4.83E-02 U | -9.88E-03 ± 3.29E-02 U | -2.49E-02 ± 3.52E-02 U | -9.21E-03 ± 3.07E-02 U | 3.00E-02 ± 2.93E-02 U |

Table 10: Airborne Cartridge: Radioiodine (pCi/m3)

| Date | Air Station M-1 | Air Station M-2 | Air Station M-3 | Air Station M-4 | Air Station M-5 |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| 4/16/2025 | 1.09E-02 ± 1.82E-02 U | 1.39E-02 ± 2.18E-02 U | -2.18E-02 ± 2.64E-02 U | 8.78E-04 ± 1.77E-02 U | 7.65E-03 ± 1.99E-02 U |
| 4/23/2025 | 3.50E-04 ± 2.79E-02 U | 1.12E-03 ± 3.69E-02 U | -2.81E-03 ± 3.19E-02 U | -1.59E-02 ± 4.20E-02 U | -2.12E-02 ± 3.72E-02 U |
| 4/30/2025 | 1.21E-02 ± 1.99E-02 U | 5.20E-03 ± 2.28E-02 U | -1.16E-03 ± 2.82E-02 U | -9.60E-03 ± 1.98E-02 U | 4.00E-03 ± 2.58E-02 U |
| 5/7/2025 | 1.44E-03 ± 2.18E-02 U | -9.82E-03 ± 2.22E-02 U | -1.63E-02 ± 2.64E-02 U | -2.77E-03 ± 1.93E-02 U | 1.04E-02 ± 3.32E-02 U |
| 5/14/2025 | 7.76E-03 ± 2.95E-02 U | 1.14E-02 ± 2.78E-02 U | -6.15E-03 ± 2.14E-02 U | 1.72E-02 ± 2.04E-02 U | -2.92E-02 ± 3.04E-02 U |
| 5/21/2025 | -4.41E-02 ± 4.04E-02 U | -6.83E-03 ± 3.15E-02 U | 4.20E-03 ± 3.94E-02 U | 7.39E-03 ± 2.69E-02 U | -2.11E-02 ± 3.43E-02 U |
| 5/28/2025 | -1.32E-03 ± 2.98E-02 U | 4.84E-02 ± 3.73E-02 U | -1.03E-02 ± 3.25E-02 U | -1.08E-02 ± 3.18E-02 U | -6.53E-03 ± 4.18E-02 U |
| 6/3/2025 | -1.11E-02 ± 2.62E-02 U | -3.52E-02 ± 2.64E-02 U | -6.70E-04 ± 2.55E-02 U | 1.63E-02 ± 3.42E-02 U | -4.30E-04 ± 2.73E-02 U |
| 6/10/2025 | -5.28E-03 ± 1.64E-02 U | -1.09E-03 ± 1.18E-02 U | -3.63E-03 ± 1.90E-02 U | 2.25E-02 ± 1.67E-02 U | 9.08E-03 ± 1.59E-02 U |
| 6/18/2025 | -1.72E-02 ± 2.97E-02 U | 1.17E-02 ± 2.77E-02 U | 1.76E-02 ± 3.41E-02 U | 5.00E-03 ± 2.39E-02 U | -2.17E-02 ± 4.21E-02 U |
| 6/26/2025 | -1.13E-02 ± 1.77E-02 U | 1.47E-04 ± 1.52E-02 U | -8.58E-03 ± 1.13E-02 U | 6.25E-03 ± 1.36E-02 U | -1.59E-04 ± 1.46E-02 U |
| 7/2/2025 | 6.99E-03 ± 1.59E-02 U | -7.93E-03 ± 1.35E-02 U | 5.56E-04 ± 1.82E-02 U | -9.63E-03 ± 1.57E-02 U | -7.45E-03 ± 2.46E-02 U |
| 7/9/2025 | 1.81E-03 ± 2.17E-02 U | 1.20E-02 ± 2.11E-02 U | 2.23E-02 ± 3.20E-02 U | -2.18E-03 ± 1.48E-02 U | 1.32E-02 ± 1.97E-02 U |
| 7/17/2025 | -7.33E-03 ± 1.44E-02 U | 3.71E-03 ± 1.20E-02 U | -6.18E-03 ± 1.25E-02 U | 2.08E-03 ± 1.12E-02 U | -2.57E-03 ± 1.48E-02 U |
| 7/24/2025 | -8.66E-04 ± 3.36E-02 U | 2.08E-02 ± 2.52E-02 U | -4.67E-04 ± 3.33E-02 U | -1.00E-02 ± 3.06E-02 U | 3.16E-03 ± 3.14E-02 U |
| 7/30/2025 | 1.35E-02 ± 3.95E-02 U | 2.50E-02 ± 3.51E-02 U | 3.63E-02 ± 2.67E-02 U | 8.70E-03 ± 3.38E-02 U | -5.15E-03 ± 3.56E-02 U |

Table 10: Airborne Cartridge: Radioiodine (pCi/m3)

| Date | Air Station M-1 | Air Station M-2 | Air Station M-3 | Air Station M-4 | Air Station M-5 |
|------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| 8/6/2025 | -2.06E-02 ± 1.44E-02 U | -1.24E-02 ± 2.36E-02 U | 1.25E-02 ± 1.35E-02 U | -6.55E-03 ± 1.53E-02 U | -8.74E-03 ± 1.41E-02 U |
| 8/14/2025 | 6.27E-03 ± 2.29E-02 U | 1.63E-02 ± 1.96E-02 U | 1.17E-02 ± 1.56E-02 U | 3.09E-03 ± 2.21E-02 U | -8.12E-03 ± 1.98E-02 U |
| 8/20/2025 | -5.98E-03 ± 1.27E-02 U | -3.25E-04 ± 1.30E-02 U | 2.42E-03 ± 9.38E-03 U | -4.04E-04 ± 1.11E-02 U | 7.48E-03 ± 1.17E-02 U |
| 8/27/2025 | 1.20E-02 ± 1.35E-02 U | 5.26E-03 ± 1.61E-02 U | -1.70E-02 ± 2.02E-02 U | 2.15E-03 ± 1.98E-02 U | -1.76E-02 ± 1.75E-02 U |
| 9/3/2025 | 1.44E-02 ± 1.84E-02 U | 1.87E-03 ± 1.14E-02 U | 5.20E-03 ± 1.38E-02 U | -4.71E-03 ± 1.15E-02 U | -2.63E-02 ± 1.69E-02 U |
| 9/10/2025 | 9.97E-03 ± 9.85E-03 U | -3.10E-03 ± 9.52E-03 U | 9.29E-03 ± 1.43E-02 U | -5.10E-03 ± 8.77E-03 U | 1.69E-03 ± 8.24E-03 U |
| 9/17/2025 | -5.99E-03 ± 1.35E-02 U | 2.08E-02 ± 1.24E-02 U | 4.15E-03 ± 7.20E-03 U | 5.34E-04 ± 1.29E-02 U | -1.87E-04 ± 6.46E-03 U |
| 9/24/2025 | 1.78E-03 ± 7.18E-03 U | 3.66E-03 ± 8.14E-03 U | -1.73E-02 ± 1.25E-02 U | -6.41E-03 ± 7.76E-03 U | 6.48E-03 ± 7.84E-03 U |
| 10/1/2025 | -8.19E-03 ± 1.04E-02 U | 1.99E-02 ± 9.59E-03 U | 6.24E-03 ± 1.36E-02 U | -3.02E-02 ± 2.17E-02 U | -1.74E-03 ± 1.16E-02 U |
| 10/8/2025 | 5.60E-03 ± 7.41E-03 U | -8.19E-03 ± 1.21E-02 U | -6.58E-03 ± 7.29E-03 U | 1.86E-04 ± 9.12E-03 U | -3.37E-03 ± 1.07E-02 U |
| 10/15/2025 | -1.52E-02 ± 1.52E-02 U | -4.34E-03 ± 1.21E-02 U | -6.75E-03 ± 1.65E-02 U | 1.40E-02 ± 1.25E-02 U | 2.15E-02 ± 1.39E-02 U |
| 10/22/2025 | -1.78E-02 ± 3.55E-02 U | 3.48E-02 ± 3.48E-02 U | 1.62E-02 ± 3.82E-02 U | -9.37E-03 ± 3.83E-02 U | 6.01E-03 ± 3.29E-02 U |
| 10/28/2025 | -4.32E-03 ± 4.83E-02 U | -6.67E-03 ± 4.83E-02 U | -8.32E-03 ± 4.57E-02 U | 5.22E-02 ± 4.53E-02 U | 8.70E-03 ± 3.96E-02 U |
| 11/5/2025 | 2.52E-03 ± 1.01E-02 U | 1.93E-02 ± 1.84E-02 U | 3.94E-03 ± 8.70E-03 U | 4.65E-03 ± 1.55E-02 U | -1.18E-03 ± 1.81E-02 U |
| 11/11/2025 | 8.47E-03 ± 2.42E-02 U | 3.20E-03 ± 2.59E-02 U | 9.96E-03 ± 2.84E-02 U | 2.52E-03 ± 2.55E-02 U | |
| 11/12/2025 | | | | | 1.15E-02 ± 2.27E-02 U |

Table 10: Airborne Cartridge: Radioiodine (pCi/m3)

| Date | Air Station M-1 | Air Station M-2 | Air Station M-3 | Air Station M-4 | Air Station M-5 |
|-------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|
| 11/19/2025 | 2.93E-04 ± 1.87E-02 U | -3.25E-03 ± 1.31E-02 U | -2.86E-04 ± 1.47E-02 U | 1.10E-02 ± 1.02E-02 U | 1.86E-02 ± 2.16E-02 U |
| 11/25/2025 | 2.07E-03 ± 1.26E-02 U | 1.14E-03 ± 1.10E-02 U | 2.94E-03 ± 9.10E-03 U | 2.94E-03 ± 1.02E-02 U | 3.95E-03 ± 1.06E-02 U |
| 12/3/2025 | 2.19E-03 ± 9.35E-03 U | 2.98E-03 ± 8.71E-03 U | -2.77E-03 ± 7.57E-03 U | -1.63E-03 ± 7.08E-0 U | -3.17E-04 ± 8.05E-03 U |
| 12/10/2025 | 5.83E-03 ± 2.69E-02 U | 1.98E-02 ± 2.31E-02 U | 4.51E-03 ± 3.20E-02 U | -9.41E-03 ± 2.92E-02 U | 2.40E-02 ± 2.63E-02 U |
| 12/17/2025 | 3.23E-03 ± 2.91E-02 U | 2.62E-03 ± 2.77E-02 U | 6.37E-03 ± 2.69E-02 U | -4.80E-03 ± 2.86E-02 U | 6.39E-03 ± 2.32E-02 U |
| 12/23/2025 | -5.15E-03 ± 2.48E-02 U | 1.26E-02 ± 1.72E-02 U | -4.12E-03 ± 2.58E-02 U | 4.37E-03 ± 2.03E-02 U | -1.13E-02 ± 1.71E-02 U |
| 12/31/2025 | -3.07E-03 ± 1.12E-02 U | -4.21E-03 ± 1.43E-02 U | 1.81E-03 ± 2.33E-02 U | -1.65E-03 ± 1.00E-02 U | -1.09E-03 ± 9.98E-03 U |

Table 11: Airborne Particulates: Gross Beta (pCi/m3)

| Date/ Sample ID | Air Station M-1 | Air Station M-2 | Air Station M-3 | Air Station M-4 | Air Station M-5 |
|-----------------|---------------------|---------------------|---------------------|---------------------|---------------------|
| 1/2/2025 | 4.81E-02 ± 5.08E-03 | 5.72E-02 ± 5.73E-03 | 4.47E-02 ± 4.82E-03 | 5.66E-02 ± 5.90E-03 | 4.68E-02 ± 5.21E-03 |
| 1/8/2025 | 4.04E-02 ± 4.93E-03 | 4.43E-02 ± 5.57E-03 | 3.96E-02 ± 4.69E-03 | 4.56E-02 ± 5.59E-03 | 5.10E-02 ± 5.92E-03 |
| 1/15/2025 | 5.01E-02 ± 4.98E-03 | 8.28E-02 ± 6.72E-03 | 4.35E-02 ± 4.45E-03 | 5.13E-02 ± 5.50E-03 | 6.07E-02 ± 5.91E-03 |
| 1/22/2025 | 3.46E-02 ± 4.37E-03 | 4.22E-02 ± 4.98E-03 | 3.66E-02 ± 4.41E-03 | 4.43E-02 ± 5.41E-03 | 4.28E-02 ± 4.98E-03 |
| 1/29/2025 | 3.66E-02 ± 4.50E-03 | 3.96E-02 ± 5.20E-03 | 4.25E-02 ± 5.05E-03 | 4.06E-02 ± 5.12E-03 | 3.96E-02 ± 5.12E-03 |
| 2/5/2025 | 3.26E-02 ± 4.32E-03 | 3.76E-02 ± 5.03E-03 | 3.26E-02 ± 4.35E-03 | 3.64E-02 ± 4.88E-03 | 3.49E-02 ± 4.61E-03 |
| 2/11/2025 | 3.95E-02 ± 5.72E-03 | 4.25E-02 ± 5.81E-03 | 4.67E-02 ± 5.88E-03 | 3.77E-02 ± 4.67E-03 | 4.61E-02 ± 5.62E-03 |
| 2/19/2025 | 4.91E-02 ± 4.70E-03 | 4.96E-02 ± 5.00E-03 | 4.62E-02 ± 4.47E-03 | 4.87E-02 ± 4.72E-03 | 5.26E-02 ± 5.05E-03 |
| 2/26/2025 | 4.38E-02 ± 4.89E-03 | 4.10E-02 ± 5.04E-03 | 3.50E-02 ± 4.20E-03 | 3.83E-02 ± 4.66E-03 | 4.51E-02 ± 5.16E-03 |
| 3/6/2025 | 3.06E-02 ± 3.88E-03 | 3.43E-02 ± 4.40E-03 | 3.10E-02 ± 3.90E-03 | 3.28E-02 ± 4.00E-03 | 3.03E-02 ± 4.04E-03 |
| 3/12/2025 | 3.09E-02 ± 4.62E-03 | 3.28E-02 ± 5.11E-03 | 2.89E-02 ± 4.50E-03 | 2.98E-02 ± 4.55E-03 | 3.02E-02 ± 4.80E-03 |
| 3/18/2025 | 3.27E-02 ± 4.70E-03 | 3.26E-02 ± 5.05E-03 | 3.26E-02 ± 4.97E-03 | 3.04E-02 ± 4.56E-03 | 3.31E-02 ± 4.95E-03 |
| 3/26/2025 | 2.72E-02 ± 3.65E-03 | 2.74E-02 ± 4.08E-03 | 5.57E-02 ± 5.38E-03 | 2.37E-02 ± 3.24E-03 | 2.72E-02 ± 3.81E-03 |
| 4/3/2025 | 2.02E-02 ± 3.21E-03 | 2.16E-02 ± 3.60E-03 | 1.95E-02 ± 3.37E-03 | 2.07E-02 ± 3.27E-03 | 2.19E-02 ± 3.46E-03 |
| 4/9/2025 | 3.73E-02 ± 5.18E-03 | 3.22E-02 ± 5.16E-03 | 3.25E-02 ± 4.90E-03 | 3.53E-02 ± 5.18E-03 | 3.33E-02 ± 4.82E-03 |
| 4/16/2025 | 2.97E-02 ± 4.01E-03 | 3.33E-02 ± 4.71E-03 | 3.21E-02 ± 4.51E-03 | 3.16E-02 ± 4.16E-03 | 3.03E-02 ± 4.20E-03 |
| 4/23/2025 | 2.04E-02 ± 3.58E-03 | 2.99E-02 ± 4.57E-03 | 2.31E-02 ± 3.95E-03 | 2.42E-02 ± 3.80E-03 | 2.39E-02 ± 4.27E-03 |
| 4/30/2025 | 1.92E-02 ± 3.42E-03 | 2.47E-02 ± 4.12E-03 | 1.92E-02 ± 3.68E-03 | 1.95E-02 ± 3.46E-03 | 2.31E-02 ± 4.08E-03 |
| 5/7/2025 | 2.21E-02 ± 3.58E-03 | 2.48E-02 ± 3.70E-03 | 1.87E-02 ± 3.14E-03 | 2.34E-02 ± 3.66E-03 | 2.46E-02 ± 4.04E-03 |
| 5/14/2025 | 2.37E-02 ± 3.74E-03 | 3.09E-02 ± 4.08E-03 | 2.47E-02 ± 3.70E-03 | 2.49E-02 ± 3.70E-03 | 3.05E-02 ± 4.45E-03 |
| 5/21/2025 | 1.17E-02 ± 2.83E-03 | 1.60E-02 ± 3.13E-03 | 1.17E-02 ± 2.81E-03 | 1.22E-02 ± 2.79E-03 | 1.37E-02 ± 3.24E-03 |
| 5/28/2025 | 1.93E-02 ± 3.42E-03 | 1.91E-02 ± 3.36E-03 | 1.69E-02 ± 3.22E-03 | 2.14E-02 ± 3.50E-03 | 2.03E-02 ± 3.77E-03 |
| 6/3/2025 | 3.02E-02 ± 4.47E-03 | 3.35E-02 ± 4.86E-03 | 2.74E-02 ± 4.34E-03 | 2.60E-02 ± 4.20E-03 | 2.85E-02 ± 4.70E-03 |
| 6/10/2025 | 2.58E-02 ± 3.98E-03 | 2.64E-02 ± 3.80E-03 | 2.09E-02 ± 3.51E-03 | 2.77E-02 ± 4.20E-03 | 2.53E-02 ± 4.01E-03 |

Table 11: Airborne Particulates: Gross Beta (pCi/m3)

| Date/ Sample ID | Air Station M-1 | Air Station M-2 | Air Station M-3 | Air Station M-4 | Air Station M-5 |
|-----------------|---------------------|---------------------|---------------------|---------------------|---------------------|
| 6/18/2025 | 2.19E-02 ± 3.23E-03 | 2.17E-02 ± 3.22E-03 | 2.17E-02 ± 3.28E-03 | 2.20E-02 ± 3.27E-03 | 2.42E-02 ± 3.63E-03 |
| 6/26/2025 | 2.66E-02 ± 3.74E-03 | 2.29E-02 ± 3.28E-03 | 2.25E-02 ± 3.25E-03 | 2.47E-02 ± 3.71E-03 | 2.64E-02 ± 3.79E-03 |
| 7/2/2025 | 1.85E-02 ± 3.43E-03 | 1.72E-02 ± 3.61E-03 | 1.98E-02 ± 3.78E-03 | 1.74E-02 ± 3.55E-03 | 2.28E-02 ± 4.24E-03 |
| 7/9/2025 | 2.76E-02 ± 3.83E-03 | 2.86E-02 ± 3.89E-03 | 2.67E-02 ± 3.85E-03 | 2.44E-02 ± 3.69E-03 | 2.61E-02 ± 4.02E-03 |
| 7/17/2025 | 2.88E-02 ± 3.71E-03 | 2.59E-02 ± 3.70E-03 | 2.39E-02 ± 3.40E-03 | 2.54E-02 ± 3.86E-03 | 3.25E-02 ± 4.20E-03 |
| 7/24/2025 | 1.90E-02 ± 3.33E-03 | 2.02E-02 ± 3.38E-03 | 1.65E-02 ± 3.12E-03 | 2.27E-02 ± 3.63E-03 | 2.04E-02 ± 3.48E-03 |
| 7/30/2025 | 4.38E-02 ± 7.13E-03 | 4.29E-02 ± 5.13E-03 | 2.42E-02 ± 3.52E-03 | 3.75E-02 ± 5.07E-03 | 3.10E-02 ± 4.25E-03 |
| 8/6/2025 | 3.39E-02 ± 4.17E-03 | 3.43E-02 ± 4.55E-03 | 3.44E-02 ± 4.01E-03 | 3.41E-02 ± 4.26E-03 | 2.72E-02 ± 3.60E-03 |
| 8/14/2025 | 3.14E-02 ± 3.91E-03 | 3.78E-02 ± 4.33E-03 | 3.58E-02 ± 3.84E-03 | 3.75E-02 ± 4.37E-03 | 3.29E-02 ± 3.79E-03 |
| 8/20/2025 | 2.28E-02 ± 3.75E-03 | 2.86E-02 ± 4.52E-03 | 2.07E-02 ± 3.27E-03 | 2.40E-02 ± 3.94E-03 | 2.70E-02 ± 3.94E-03 |
| 8/27/2025 | 2.65E-02 ± 3.81E-03 | 2.91E-02 ± 4.20E-03 | 2.37E-02 ± 3.47E-03 | 2.51E-02 ± 3.98E-03 | 2.35E-02 ± 3.57E-03 |
| 9/3/2025 | 4.08E-02 ± 4.83E-03 | 4.15E-02 ± 4.83E-03 | 4.10E-02 ± 4.52E-03 | 3.64E-02 ± 4.64E-03 | 3.84E-02 ± 4.40E-03 |
| 9/10/2025 | 2.77E-02 ± 3.85E-03 | 3.24E-02 ± 4.40E-03 | 2.65E-02 ± 3.57E-03 | 2.54E-02 ± 3.91E-03 | 2.80E-02 ± 3.78E-03 |
| 9/17/2025 | 6.73E-02 ± 6.03E-03 | 7.81E-02 ± 6.56E-03 | 6.45E-02 ± 5.43E-03 | 7.73E-02 ± 6.56E-03 | 6.59E-02 ± 5.65E-03 |
| 9/24/2025 | 4.28E-02 ± 4.94E-03 | 3.64E-02 ± 4.55E-03 | 3.92E-02 ± 4.43E-03 | 3.56E-02 ± 4.60E-03 | 3.70E-02 ± 4.34E-03 |
| 10/1/2025 | 6.03E-02 ± 5.75E-03 | 6.66E-02 ± 6.16E-03 | 6.33E-02 ± 5.64E-03 | 5.81E-02 ± 5.68E-03 | 5.06E-02 ± 4.99E-03 |
| 10/8/2025 | 6.61E-02 ± 6.01E-03 | 6.28E-02 ± 5.84E-03 | 6.62E-02 ± 5.65E-03 | 6.52E-02 ± 6.40E-03 | 6.17E-02 ± 5.47E-03 |
| 10/15/2025 | 3.18E-02 ± 4.34E-03 | 3.46E-02 ± 4.78E-03 | 2.92E-02 ± 3.88E-03 | 3.91E-02 ± 5.35E-03 | 2.83E-02 ± 3.87E-03 |
| 10/22/2025 | 3.77E-02 ± 4.88E-03 | 4.11E-02 ± 4.92E-03 | 3.96E-02 ± 4.53E-03 | 3.22E-02 ± 4.33E-03 | 3.26E-02 ± 4.30E-03 |
| 10/28/2025 | 3.95E-02 ± 5.06E-03 | 3.46E-02 ± 4.67E-03 | 3.97E-02 ± 5.12E-03 | 3.76E-02 ± 5.26E-03 | 3.06E-02 ± 4.52E-03 |
| 11/5/2025 | 2.70E-02 ± 3.60E-03 | 3.15E-02 ± 3.85E-03 | 3.17E-02 ± 4.06E-03 | 2.61E-02 ± 3.76E-03 | 2.61E-02 ± 3.54E-03 |
| 11/11/2025 | 3.53E-02 ± 5.04E-03 | 2.34E-02 ± 4.01E-03 | 3.23E-02 ± 4.80E-03 | 2.46E-02 ± 4.28E-03 | |
| 11/12/2025 | | | | | 2.75E-02 ± 4.38E-03 |
| 11/19/2025 | 4.11E-02 ± 4.66E-03 | 4.23E-02 ± 4.61E-03 | 3.43E-02 ± 4.06E-03 | 4.03E-02 ± 4.55E-03 | 3.87E-02 ± 4.85E-03 |
| 11/25/2025 | 6.54E-02 ± 6.44E-03 | 6.11E-02 ± 6.10E-03 | 6.13E-02 ± 6.37E-03 | 6.39E-02 ± 6.62E-03 | 5.80E-02 ± 6.09E-03 |
| 12/3/2025 | 4.54E-02 ± 4.83E-03 | 3.90E-02 ± 4.22E-03 | 5.40E-02 ± 5.78E-03 | 4.87E-02 ± 5.03E-03 | 3.85E-02 ± 4.49E-03 |
| 12/10/2025 | 5.95E-02 ± 5.89E-03 | 4.56E-02 ± 4.82E-03 | 6.24E-02 ± 6.15E-03 | 5.51E-02 ± 5.73E-03 | 4.94E-02 ± 5.42E-03 |
| 12/17/2025 | 5.52E-02 ± 5.65E-03 | 5.50E-02 ± 5.56E-03 | 5.27E-02 ± 5.37E-03 | 5.76E-02 ± 5.84E-03 | 5.30E-02 ± 5.55E-03 |

Table 11: Airborne Particulates: Gross Beta (pCi/m3)

| Date/ Sample ID | Air Station M-1 | Air Station M-2 | Air Station M-3 | Air Station M-4 | Air Station M-5 |
|-------------------|---------------------|---------------------|---------------------|---------------------|---------------------|
| 12/23/2025 | 3.41E-02 ± 4.23E-03 | 4.00E-02 ± 4.44E-03 | 4.29E-02 ± 4.99E-03 | 3.93E-02 ± 4.70E-03 | 3.74E-02 ± 4.63E-03 |
| 12/31/2025 | 4.62E-02 ± 4.35E-03 | 4.46E-02 ± 4.23E-03 | 5.34E-02 ± 5.09E-03 | 4.48E-02 ± 4.24E-03 | 4.54E-02 ± 4.32E-03 |

Table 12: Quarterly Gamma Isotopic Data – Air Station M-1 (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | 2.08E-03 ± 9.90E-03 U | -8.20E-03 ± 3.64E-02 U | 4.25E-03 ± 6.93E-03 U | 3.74E-04 ± 2.33E-03 U |
| Beryllium-7 | 3.72E-02 ± 8.35E-03 | 6.10E-02 ± 2.81E-02 | 6.09E-02 ± 8.25E-03 | 4.52E-02 ± 7.22E-03 |
| Cerium-141 | 5.38E-04 ± 9.80E-04 U | -6.97E-04 ± 2.16E-03 U | -1.03E-04 ± 4.17E-04 U | -3.22E-04 ± 2.94E-04 U |
| Cerium-144 | -1.45E-04 ± 1.07E-03 U | 2.27E-03 ± 3.40E-03 U | -4.93E-04 ± 7.53E-04 U | -6.98E-05 ± 1.04E-03 U |
| Cesium-134 | -2.92E-05 ± 3.16E-04 U | 3.51E-04 ± 9.45E-04 U | -5.07E-08 ± 2.14E-04 U | -9.74E-05 ± 2.94E-04 U |
| Cesium-137 | 1.07E-04 ± 2.69E-04 U | 2.26E-04 ± 7.71E-04 U | -4.61E-05 ± 1.62E-04 U | 1.02E-04 ± 2.22E-04 U |
| Cobalt-58 | -3.50E-04 ± 4.22E-04 U | 6.92E-04 ± 1.27E-03 U | 1.42E-04 ± 2.69E-04 U | -7.48E-05 ± 2.87E-04 U |
| Cobalt-60 | 1.26E-04 ± 2.77E-04 U | 6.58E-04 ± 1.04E-03 U | 3.11E-04 ± 3.09E-04 U | -1.30E-04 ± 2.83E-04 U |
| Lanthanum-140 | -1.93E-04 ± 3.89E-03 U | 1.27E-02 ± 1.41E-02 U | -2.01E-03 ± 2.68E-03 U | -8.94E-04 ± 1.09E-03 U |
| Manganese-54 | -6.05E-05 ± 2.54E-04 U | -2.68E-04 ± 8.73E-04 U | 4.25E-05 ± 2.40E-04 U | 5.10E-05 ± 3.44E-04 U |
| Niobium-95 | 3.23E-04 ± 3.99E-04 U | -2.78E-04 ± 9.86E-04 U | -7.69E-05 ± 2.91E-04 U | 5.21E-04 ± 5.58E-04 U |
| Ruthenium-103 | 3.90E-04 ± 4.50E-04 U | -4.32E-04 ± 1.40E-03 U | -1.30E-04 ± 3.84E-04 U | 5.51E-05 ± 2.72E-04 U |
| Ruthenium-106 | 1.25E-04 ± 2.58E-03 U | -1.56E-03 ± 8.29E-03 U | -1.15E-03 ± 2.24E-03 U | 8.52E-04 ± 2.56E-03 U |
| Zinc-65 | -2.49E-04 ± 6.71E-04 U | 7.92E-04 ± 2.19E-03 U | -1.55E-04 ± 5.69E-04 U | 5.16E-04 ± 5.04E-04 U |
| Zirconium-95 | -1.92E-04 ± 7.58E-04 U | 9.89E-04 ± 2.47E-03 U | 5.02E-05 ± 3.94E-04 U | -2.08E-04 ± 5.18E-04 U |

Table 13: Quarterly Gamma Isotopic Data – Air Station M-2 (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | 5.16E-03 ± 1.44E-02 U | 2.06E-02 ± 2.66E-02 U | 1.55E-03 ± 6.59E-03 U | 2.87E-03 ± 3.92E-03 U |
| Beryllium-7 | 5.58E-02 ± 1.23E-02 | 9.12E-02 ± 2.56E-02 | 7.21E-02 ± 9.60E-03 | 4.03E-02 ± 8.21E-03 |
| Cerium-141 | -8.49E-04 ± 1.34E-03 U | 3.47E-04 ± 3.26E-03 U | 1.27E-05 ± 5.18E-04 U | 1.14E-04 ± 3.44E-04 U |
| Cerium-144 | -1.42E-03 ± 1.99E-03 U | 1.26E-03 ± 3.03E-03 U | -6.84E-04 ± 1.01E-03 U | 4.02E-04 ± 1.06E-03 U |
| Cesium-134 | -2.88E-04 ± 4.26E-04 U | -5.06E-04 ± 9.59E-04 U | 2.64E-04 ± 2.34E-04 U | -1.28E-04 ± 3.49E-04 U |
| Cesium-137 | -1.14E-04 ± 3.33E-04 U | 1.33E-05 ± 7.69E-04 U | 1.23E-05 ± 2.54E-04 U | 1.38E-04 ± 2.77E-04 U |
| Cobalt-58 | -1.77E-05 ± 6.95E-04 U | -5.50E-05 ± 1.22E-03 U | -1.98E-04 ± 4.00E-04 U | -4.88E-05 ± 2.62E-04 U |
| Cobalt-60 | 7.29E-05 ± 2.67E-04 U | -2.90E-05 ± 4.82E-04 U | 9.42E-06 ± 2.26E-04 U | -9.09E-05 ± 2.64E-04 U |
| Lanthanum-140 | 3.48E-03 ± 4.46E-03 U | -1.03E-02 ± 1.17E-02 U | -9.63E-04 ± 1.89E-03 U | 6.80E-05 ± 1.25E-03 U |
| Manganese-54 | -1.61E-04 ± 4.02E-04 U | -2.41E-04 ± 7.32E-04 U | 1.23E-06 ± 3.00E-04 U | -9.84E-06 ± 2.41E-04 U |
| Niobium-95 | -1.48E-04 ± 6.41E-04 U | 1.45E-05 ± 1.38E-03 U | -8.15E-05 ± 3.69E-04 U | -5.63E-05 ± 2.83E-04 U |
| Ruthenium-103 | 1.70E-04 ± 7.26E-04 U | 4.10E-04 ± 1.33E-03 U | -2.83E-04 ± 5.12E-04 U | -1.00E-04 ± 3.18E-04 U |
| Ruthenium-106 | -1.16E-03 ± 3.63E-03 U | 1.55E-03 ± 6.96E-03 U | 6.33E-04 ± 2.10E-03 U | 4.96E-04 ± 2.16E-03 U |
| Zinc-65 | 1.35E-03 ± 1.09E-03 UI | 5.62E-04 ± 1.80E-03 U | 3.26E-04 ± 6.92E-04 U | -2.65E-04 ± 4.54E-04 U |
| Zirconium-95 | 2.57E-04 ± 1.24E-03 U | 5.32E-04 ± 1.43E-03 U | -2.82E-04 ± 6.75E-04 U | 6.71E-05 ± 5.49E-04 U |

Table 14: Quarterly Gamma Isotopic Data – Air Station M-3 (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | 4.17E-03 ± 9.43E-03 U | -2.13E-03 ± 2.36E-02 U | 2.05E-03 ± 4.75E-03 U | -3.84E-04 ± 2.23E-03 U |
| Beryllium-7 | 4.38E-02 ± 1.02E-02 | 6.30E-02 ± 1.33E-02 | 5.09E-02 ± 7.41E-03 | 4.49E-02 ± 6.77E-03 |
| Cerium-141 | 4.33E-04 ± 6.42E-04 U | 2.03E-04 ± 9.04E-04 U | 2.37E-04 ± 3.79E-04 U | 9.57E-05 ± 3.21E-04 U |
| Cerium-144 | 2.66E-04 ± 1.19E-03 U | 1.13E-03 ± 1.61E-03 U | -4.01E-05 ± 6.65E-04 U | -1.82E-04 ± 8.08E-04 U |
| Cesium-134 | 1.75E-04 ± 3.24E-04 U | -2.47E-04 ± 5.48E-04 U | 1.53E-04 ± 1.59E-04 U | -1.51E-04 ± 2.43E-04 U |
| Cesium-137 | 3.32E-05 ± 3.00E-04 U | 3.98E-04 ± 3.48E-04 U | 1.37E-05 ± 1.81E-04 U | 1.94E-04 ± 2.43E-04 U |
| Cobalt-58 | -1.65E-05 ± 4.01E-04 U | -3.00E-04 ± 6.65E-04 U | -1.20E-04 ± 2.71E-04 U | -1.32E-05 ± 2.50E-04 U |
| Cobalt-60 | 7.80E-06 ± 4.38E-04 U | -1.30E-04 ± 5.00E-04 U | -2.00E-04 ± 1.96E-04 U | 2.15E-04 ± 2.41E-04 U |
| Lanthanum-140 | 8.12E-04 ± 3.66E-03 U | 2.50E-03 ± 8.66E-03 U | -3.44E-05 ± 1.03E-03 U | 1.59E-04 ± 1.29E-03 U |
| Manganese-54 | 6.19E-05 ± 2.51E-04 U | 2.21E-04 ± 3.60E-04 U | -1.97E-04 ± 1.90E-04 U | 7.01E-05 ± 2.76E-04 U |
| Niobium-95 | -7.65E-05 ± 4.12E-04 U | -8.23E-05 ± 5.46E-04 U | 1.10E-05 ± 2.41E-04 U | 7.10E-05 ± 2.44E-04 U |
| Ruthenium-103 | 2.46E-04 ± 5.54E-04 U | 4.45E-04 ± 8.03E-04 U | 2.14E-04 ± 2.61E-04 U | 2.05E-04 ± 2.83E-04 U |
| Ruthenium-106 | 6.68E-04 ± 2.88E-03 U | 1.20E-03 ± 4.10E-03 U | -8.22E-04 ± 1.32E-03 U | 4.10E-04 ± 2.17E-03 U |
| Zinc-65 | -5.92E-04 ± 7.71E-04 U | -6.20E-04 ± 1.23E-03 U | 2.75E-05 ± 3.91E-04 U | -1.14E-04 ± 6.63E-04 U |
| Zirconium-95 | -2.05E-04 ± 7.93E-04 U | -3.47E-04 ± 1.25E-03 U | 2.26E-04 ± 3.47E-04 U | -1.00E-04 ± 4.60E-04 U |

Table 15: Quarterly Gamma Isotopic Data – Air Station M-4 (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | 6.78E-03 ± 9.79E-03 U | -3.70E-04 ± 2.80E-02 U | 3.65E-03 ± 6.48E-03 U | -1.19E-03 ± 2.72E-03 U |
| Beryllium-7 | 6.00E-02 ± 9.53E-03 | 7.25E-02 ± 1.65E-02 | 5.68E-02 ± 9.28E-03 | 4.13E-02 ± 8.94E-03 |
| Cerium-141 | -1.71E-04 ± 7.11E-04 U | -3.30E-04 ± 2.08E-03 U | 1.11E-04 ± 4.16E-04 U | -1.84E-04 ± 2.75E-04 U |
| Cerium-144 | -1.47E-04 ± 1.14E-03 U | 8.31E-04 ± 3.62E-03 U | -4.50E-04 ± 9.21E-04 U | 3.54E-04 ± 9.55E-04 U |
| Cesium-134 | -9.33E-05 ± 3.86E-04 U | 6.03E-05 ± 7.83E-04 U | 6.88E-05 ± 2.81E-04 U | 7.11E-05 ± 2.25E-04 U |
| Cesium-137 | 2.58E-04 ± 2.61E-04 U | 3.45E-04 ± 4.96E-04 U | -7.62E-05 ± 1.92E-04 U | -6.18E-05 ± 2.63E-04 U |
| Cobalt-58 | -2.08E-04 ± 4.38E-04 U | 8.07E-05 ± 7.98E-04 U | -3.96E-05 ± 2.87E-04 U | 1.16E-04 ± 3.63E-04 U |
| Cobalt-60 | 2.26E-04 ± 2.97E-04 U | 1.71E-05 ± 6.46E-04 U | 1.57E-04 ± 3.22E-04 U | -2.53E-05 ± 3.35E-04 U |
| Lanthanum-140 | 3.36E-04 ± 4.33E-03 U | 8.35E-03 ± 1.11E-02 U | -4.11E-04 ± 3.20E-03 U | -1.81E-04 ± 9.17E-04 U |
| Manganese-54 | 7.69E-05 ± 2.86E-04 U | -5.71E-04 ± 6.94E-04 U | 5.92E-05 ± 2.70E-04 U | 3.50E-05 ± 2.40E-04 U |
| Niobium-95 | -8.25E-06 ± 4.72E-04 U | 6.86E-04 ± 1.07E-03 U | -5.24E-04 ± 4.11E-04 U | 1.86E-04 ± 3.44E-04 U |
| Ruthenium-103 | -1.84E-04 ± 5.27E-04 U | 1.02E-04 ± 1.26E-03 U | -1.78E-04 ± 3.70E-04 U | 3.69E-05 ± 3.34E-04 U |
| Ruthenium-106 | 9.75E-04 ± 2.66E-03 U | 2.48E-03 ± 5.74E-03 U | -1.45E-03 ± 2.20E-03 U | -5.04E-04 ± 2.17E-03 U |
| Zinc-65 | -5.15E-05 ± 5.40E-04 U | 1.14E-03 ± 1.51E-03 U | 4.96E-04 ± 6.10E-04 U | 1.45E-04 ± 7.33E-04 U |
| Zirconium-95 | 1.78E-04 ± 6.86E-04 U | -4.99E-04 ± 1.62E-03 U | 8.08E-05 ± 5.40E-04 U | 2.70E-04 ± 3.71E-04 U |

Table 16: Quarterly Gamma Isotopic Data – Air Station M-5 (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | 1.18E-03 ± 1.19E-02 U | -1.80E-02 ± 2.40E-02 U | 5.04E-04 ± 8.08E-03 U | 1.99E-03 ± 2.29E-03 U |
| Beryllium-7 | 6.02E-02 ± 1.09E-02 | 7.13E-02 ± 1.55E-02 | 5.30E-02 ± 1.00E-02 | 3.88E-02 ± 6.74E-03 |
| Cerium-141 | -1.32E-04 ± 6.52E-04 U | -3.80E-04 ± 1.21E-03 U | -2.26E-04 ± 6.81E-04 U | -4.26E-04 ± 3.91E-04 U |
| Cerium-144 | 6.41E-04 ± 1.15E-03 U | 4.16E-04 ± 1.61E-03 U | 3.80E-06 ± 1.22E-03 U | -5.32E-05 ± 8.24E-04 U |
| Cesium-134 | 1.67E-04 ± 3.24E-04 U | -1.35E-04 ± 5.63E-04 U | -1.20E-04 ± 2.32E-04 U | -5.53E-05 ± 2.64E-04 U |
| Cesium-137 | 5.88E-06 ± 3.47E-04 U | 1.59E-04 ± 3.77E-04 U | 7.87E-05 ± 2.36E-04 U | 1.40E-04 ± 2.12E-04 U |
| Cobalt-58 | 1.05E-04 ± 4.73E-04 U | 3.78E-05 ± 6.24E-04 U | 3.71E-05 ± 3.50E-04 U | -2.25E-04 ± 2.42E-04 U |
| Cobalt-60 | 4.01E-05 ± 4.59E-04 U | -1.60E-04 ± 6.11E-04 U | 1.02E-04 ± 2.85E-04 U | -2.89E-05 ± 3.11E-04 U |
| Lanthanum-140 | -5.79E-03 ± 4.54E-03 U | -1.85E-03 ± 6.67E-03 U | 1.57E-03 ± 2.16E-03 U | 1.15E-06 ± 1.12E-03 U |
| Manganese-54 | -2.28E-04 ± 3.82E-04 U | 2.58E-04 ± 4.31E-04 U | -7.15E-05 ± 2.72E-04 U | -1.43E-04 ± 2.24E-04 U |
| Niobium-95 | 1.05E-04 ± 5.06E-04 U | -2.29E-04 ± 5.77E-04 U | 3.16E-05 ± 3.57E-04 U | 2.44E-04 ± 2.92E-04 U |
| Ruthenium-103 | -7.29E-05 ± 5.49E-04 U | 3.49E-04 ± 8.70E-04 U | 2.73E-04 ± 4.28E-04 U | -1.42E-04 ± 2.48E-04 U |
| Ruthenium-106 | -2.65E-03 ± 3.40E-03 U | 3.81E-04 ± 2.94E-03 U | -4.55E-05 ± 2.36E-03 U | -1.93E-04 ± 2.00E-03 U |
| Zinc-65 | 1.51E-04 ± 8.16E-04 U | -8.63E-04 ± 1.02E-03 U | -3.86E-04 ± 6.20E-04 U | 1.13E-04 ± 5.14E-04 U |
| Zirconium-95 | -4.34E-04 ± 9.10E-04 U | 1.22E-03 ± 1.26E-03 U | 7.73E-06 ± 7.22E-04 U | -4.08E-05 ± 5.02E-04 U |

Company: Xcel Energy

Plant: Monticello Nuclear Generating Plant

Table 17: Sediment Gamma Isotopic Data – M-8c Upstream of Plant (pCi/kg)

| Nuclide | May | September |
|---------------|---------------------------|---------------------------|
| Barium-140 | -3.40E+01 ± 3.29E+02 U | -1.65E+02 ± 2.84E+02 U |
| Beryllium-7 | 9.49E+01 ± 2.30E+02 U | 3.67E+02 ± 3.60E+02 UI |
| Cerium-144 | -1.35E+01 ± 9.94E+01 U | 3.58E+01 ± 1.22E+02 U |
| Cesium-134 | 1.79E+01 ± 2.92E+01 U | 4.49E-01 ± 2.99E+01 U |
| Cesium-137 | -1.28E+01 ± 2.45E+01 U | 1.82E+01 ± 3.38E+01 U |
| Cobalt-58 | -9.16E+00 ± 2.03E+01 U | 1.09E+01 ± 2.86E+01 U |
| Cobalt-60 | -1.58E+01 ± 2.04E+01 U | 1.10E+01 ± 3.48E+01 U |
| Iron-59 | 6.45E+00 ± 6.24E+01 U | 2.00E+00 ± 6.80E+01 U |
| Lanthanum-140 | -1.11E+02 ± 1.16E+02 U | -1.10E+02 ± 1.17E+02 U |
| Manganese-54 | -1.21E+01 ± 2.00E+01 U | 2.13E+01 ± 2.49E+01 U |
| Niobium-95 | 7.31E+00 ± 2.73E+01 U | -1.09E+01 ± 3.84E+01 U |
| Potassium-40 | 9.80E+03 ± 9.04E+02 | 1.02E+04 ± 1.29E+03 |
| Ruthenium-103 | 1.14E+01 ± 2.81E+01 U | -5.56E+00 ± 2.63E+01 U |
| Ruthenium-106 | -6.12E+01 ± 1.80E+02 U | -3.65E+01 ± 1.85E+02 U |
| Zinc-65 | 1.78E+01 ± 5.22E+01 U | 3.94E+00 ± 7.42E+01 U |
| Zirconium-95 | -1.71E+01 ± 4.37E+01 U | -1.86E+01 ± 5.26E+01 U |

Table 18: Sediment Gamma Isotopic Data – M-9 Downstream of Plant (pCi/kg)

| Nuclide | May | September |
|---------------|---------------------------|---------------------------|
| Barium-140 | -2.11E+02 ± 3.33E+02 U | -3.61E+01 ± 2.16E+02 U |
| Beryllium-7 | 3.93E+01 ± 2.20E+02 U | 6.39E+02 ± 3.12E+02 |
| Cerium-144 | -4.62E-01 ± 1.16E+02 U | -1.92E+01 ± 1.14E+02 U |
| Cesium-134 | 1.30E+01 ± 3.25E+01 U | 1.28E+02 ± 6.52E+01 UI |
| Cesium-137 | 4.15E+01 ± 5.42E+01 UI | 1.37E+01 ± 2.44E+01 U |
| Cobalt-58 | -2.39E+01 ± 2.78E+01 U | -2.05E+00 ± 2.46E+01 U |
| Cobalt-60 | -7.49E+00 ± 2.45E+01 U | -1.32E+01 ± 2.02E+01 U |
| Iron-59 | -3.92E+01 ± 7.04E+01 U | 3.10E+01 ± 5.95E+01 U |
| Lanthanum-140 | -5.12E+01 ± 1.38E+02 U | -4.28E+01 ± 9.91E+01 U |
| Manganese-54 | 8.90E+00 ± 2.59E+01 U | 3.71E+00 ± 2.63E+01 U |
| Niobium-95 | -1.68E+01 ± 3.12E+01 U | -1.75E+01 ± 2.63E+01 U |
| Potassium-40 | 1.29E+04 ± 1.20E+03 | 9.07E+03 ± 1.14E+03 |
| Ruthenium-103 | 1.73E+01 ± 3.12E+01 U | -4.76E+00 ± 2.48E+01 U |
| Ruthenium-106 | 3.13E+01 ± 1.80E+02 U | -4.58E+00 ± 1.90E+02 U |
| Zinc-65 | -6.95E+00 ± 5.94E+01 U | -4.04E+01 ± 5.80E+01 U |
| Zirconium-95 | 3.31E+01 ± 5.69E+01 U | 2.59E+01 ± 4.63E+01 U |

Table 19: Sediment Gamma Isotopic Data – M-15 Montissippi Park (pCi/kg)

| Nuclide | May | September |
|---------------|---------------------------|---------------------------|
| Barium-140 | 8.34E+01 ± 4.44E+02 U | 2.33E+02 ± 2.25E+02 U |
| Beryllium-7 | -6.68E+01 ± 2.69E+02 U | 7.98E+00 ± 2.43E+02 U |
| Cerium-144 | 1.31E+02 ± 1.52E+02 U | 9.01E+00 ± 1.42E+02 U |
| Cesium-134 | 4.00E+01 ± 3.10E+01 U | 1.89E+01 ± 3.28E+01 U |
| Cesium-137 | 5.67E+01 ± 3.11E+01 U | 8.25E+00 ± 2.59E+01 U |
| Cobalt-58 | -1.95E+00 ± 3.05E+01 U | 1.23E+01 ± 2.80E+01 U |
| Cobalt-60 | -8.75E+00 ± 2.93E+01 U | -3.92E+01 ± 2.90E+01 U |
| Iron-59 | 3.97E+01 ± 8.95E+01 U | -5.44E+01 ± 7.39E+01 U |
| Lanthanum-140 | -7.30E+01 ± 1.56E+02 U | -3.09E+01 ± 9.75E+01 U |
| Manganese-54 | 6.12E-01 ± 3.25E+01 U | -1.20E+01 ± 2.35E+01 U |
| Niobium-95 | -5.21E+00 ± 3.61E+01 U | -1.73E+01 ± 3.27E+01 U |
| Potassium-40 | 1.14E+04 ± 1.13E+03 | 1.17E+04 ± 1.47E+03 |
| Ruthenium-103 | 7.85E+00 ± 3.55E+01 U | 5.65E+00 ± 3.11E+01 U |
| Ruthenium-106 | 2.26E+01 ± 2.33E+02 U | 8.22E+01 ± 2.27E+02 U |
| Zinc-65 | -1.15E+02 ± 8.61E+01 U | -6.61E+01 ± 8.64E+01 U |
| Zirconium-95 | -3.01E+01 ± 5.82E+01 U | -1.65E+01 ± 5.18E+01 U |

Table 20: Tissue-Fish Gamma Isotopic Data – M-8c Upstream of Plant (pCi/kg, wet)

| Nuclide | July | | September | |
|---------------|--------------------|---------------------|------------------|------------------|
| | Fish 1 | Fish 2 | Fish 1 | Fish 2 |
| Barium-140 | -59.2 ± 121.0 U | 195.0 ± 507.0 U | 1.9 ± 25.5 U | 0.9 ± 24.3 U |
| Cerium-144 | 1.6 ± 38.9 U | 5.9 ± 104.0 U | -1.7 ± 22.0 U | 3.9 ± 26.0 U |
| Cesium-134 | -0.6 ± 8.2 U | 3.8 ± 26.8 U | -3.5 ± 4.8 U | -2.9 ± 5.9 U |
| Cesium-137 | 8.8 ± 7.9 U | -2.6 ± 24.0 U | -2.2 ± 6.2 U | 3.5 ± 5.0 U |
| Cobalt-58 | -0.5 ± 11.6 U | -5.5 ± 25.9 U | 0.0 ± 4.5 U | -0.3 ± 4.7 U |
| Cobalt-60 | 1.2 ± 10.5 U | 2.1 ± 15.1 U | 2.1 ± 5.2 U | 2.1 ± 6.4 U |
| Iron-59 | -13.7 ± 29.4 U | -5.9 ± 63.3 U | 4.0 ± 12.4 U | -3.5 ± 11.1 U |
| Lanthanum-140 | 51.0 ± 44.7 U | -182.0 ± 165.0 U | -5.0 ± 9.2 U | 2.7 ± 6.7 U |
| Manganese-54 | 1.9 ± 8.3 U | -4.7 ± 20.7 U | 0.8 ± 4.0 U | -0.2 ± 5.0 U |
| Niobium-95 | 0.5 ± 8.9 U | 7.2 ± 28.8 U | 0.7 ± 4.2 U | -6.1 ± 5.6 U |
| Potassium-40 | 3160.0 ± 434.0 | 3960.0 ± 1000.0 | 2760.0 ± 264.0 | 2710.0 ± 283.0 |
| Zinc-65 | -4.1 ± 21.3 U | 17.5 ± 75.3 U | 7.9 ± 11.4 U | -4.9 ± 10.0 U |
| Zirconium-95 | 0.4 ± 13.1 U | 30.1 ± 67.9 U | 0.6 ± 8.3 U | 1.5 ± 8.3 U |

Table 21: Tissue-Fish Gamma Isotopic Data – M-9 Downstream of Plant (pCi/kg, wet)

| Nuclide | May | | September |
|---------------|-------------------|-------------------|------------------|
| | Fish 1 | Fish 2 | Fish 1 |
| Barium-140 | 7.1 ± 139.0 U | 85.0 ± 158.0 U | 0.5 ± 27.4 U |
| Cerium-144 | -4.5 ± 50.7 U | -28.2 ± 41.1 U | -7.0 ± 25.6 U |
| Cesium-134 | 1.1 ± 9.3 U | -1.4 ± 13.9U | 0.2 ± 6.7 U |
| Cesium-137 | 0.1 ± 8.0 U | 2.4 ± 8.5 U | -0.1 ± 4.6 U |
| Cobalt-58 | -3.0 ± 9.1 U | 1.8 ± 11.3 U | -0.1 ± 5.6 U |
| Cobalt-60 | -6.7 ± 8.5 U | 0.8 ± 5.4 U | 1.0 ± 5.1 U |
| Iron-59 | -5.3 ± 35.9 U | 25.9 ± 31.7 U | -0.6 ± 11.1 U |
| Lanthanum-140 | -10.8 ± 48.8 U | 11.7 ± 45.1 U | 6.5 ± 6.7 U |
| Manganese-54 | 4.7 ± 10.5 U | 8.5 ± 9.3 U | 2.5 ± 5.3 U |
| Niobium-95 | -12.1 ± 11.3 U | -0.8 ± 14.1 U | 2.3 ± 5.1 U |
| Potassium-40 | 3150.0 ± 437.0 | 2900.0 ± 475.0 | 3010.0 ± 279.0 |
| Zinc-65 | 5.8 ± 18.6 U | -5.7 ± 32.3 U | -7.5 ± 12.8 U |
| Zirconium-95 | -10.5 ± 17.3 U | -14.2 ± 21.9 U | -4.0 ± 9.5 U |

Table 22: Tissue-Plant Gamma Isotopic Data – M-41 Training Center (pCi/kg)

| Nuclide | June | July | August | September |
|--------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Cesium-134 | 7.58E+00 ± 1.01E+01 U | 3.73E-01 ± 8.35E+00 U | -2.96E+00 ± 1.25E+01 U | -1.08E+01 ± 1.05E+01 U |
| Cesium-137 | 2.89E+00 ± 5.99E+00 U | -4.41E-01 ± 7.78E+00 U | 4.43E+00 ± 1.35E+01 U | -3.13E+00 ± 8.33E+00 U |
| Cobalt-58 | 1.20E+00 ± 5.88E+00 U | 1.63E+00 ± 8.59E+00 U | 3.40E+00 ± 1.74E+01 U | -2.76E+00 ± 8.42E+00 U |
| Cobalt-60 | 5.40E+00 ± 6.40E+00 U | 1.08E+00 ± 7.47E+00 U | 5.77E+00 ± 1.19E+01 U | 1.48E+01 ± 1.25E+01 U |
| Iodine-131 | 2.37E+00 ± 1.10E+01 U | -3.06E+01 ± 3.65E+01 U | 7.70E+00 ± 1.99E+01 U | -1.41E+01 ± 1.55E+01 U |
| Iron-59 | -1.04E+01 ± 1.37E+01 U | 1.40E+01 ± 1.71E+01 U | 6.76E+00 ± 3.13E+01 U | 5.39E+00 ± 2.16E+01 U |
| Manganese-54 | 4.90E+00 ± 7.96E+00 U | 5.32E-01 ± 7.96E+00 U | -9.89E+00 ± 1.68E+01 U | 6.53E+00 ± 1.05E+01 U |
| Niobium-95 | 3.28E+00 ± 6.42E+00 U | -3.38E+00 ± 9.28E+00 U | -4.87E+00 ± 1.61E+01 U | 1.58E+01 ± 1.31E+01 U |
| Zinc-65 | -9.05E-01 ± 1.53E+01 U | 7.04E+00 ± 1.46E+01 U | -1.07E+01 ± 2.77E+01 U | 3.61E+00 ± 2.18E+01 U |

Table 23: Tissue-Plant Gamma Isotopic Data – M-42 Biology Station Road (pCi/kg)

| Nuclide | June | July | August | September |
|--------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Cesium-134 | -5.50E+00 ± 5.92E+00 U | 3.20E+01 ± 2.47E+01 UI | -1.35E+01 ± 2.02E+01 U | 4.95E+00 ± 1.18E+01 U |
| Cesium-137 | 1.02E+01 ± 8.74E+00 UI | 4.46E+00 ± 1.22E+01 U | 4.38E+01 ± 2.76E+01 UI | 3.89E+00 ± 1.09E+01 U |
| Cobalt-58 | -1.17E+00 ± 5.57E+00 U | -5.66E+00 ± 1.57E+01 U | -4.79E+00 ± 2.03E+01 U | -2.00E+00 ± 1.01E+01 U |
| Cobalt-60 | -2.23E+00 ± 5.69E+00 U | 6.31E-01 ± 1.14E+01 U | 1.21E+01 ± 2.25E+01 U | 7.83E+00 ± 1.30E+01 U |
| Iodine-131 | -9.87E-01 ± 1.03E+01 U | 2.09E+01 ± 4.87E+01 U | 5.91E+00 ± 3.01E+01 U | -6.47E+00 ± 1.38E+01 U |
| Iron-59 | -2.67E+00 ± 1.27E+01 U | 3.32E+00 ± 2.86E+01 U | 4.87E+01 ± 2.83E+01 U | 1.27E+01 ± 1.76E+01 U |
| Manganese-54 | -2.06E+00 ± 5.70E+00 U | 4.91E+00 ± 1.46E+01 U | -1.02E+01 ± 2.02E+01 U | -6.06E+00 ± 1.00E+01 U |
| Niobium-95 | 5.21E+00 ± 6.13E+00 U | 5.01E+00 ± 1.54E+01 U | -9.17E+00 ± 1.96E+01 U | 6.57E+00 ± 1.35E+01 U |
| Zinc-65 | -6.16E+00 ± 1.28E+01 U | -9.63E-01 ± 3.85E+01 U | -1.61E+01 ± 3.60E+01 U | -1.14E+01 ± 2.54E+01 U |

Table 24: Tissue-Plant Gamma Isotopic Data – M-43c Imholte Farm (pCi/kg)

| Nuclide | June | July | August | September |
|--------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Cesium-134 | -1.24E+00 ± 6.75E+00 U | -3.30E+00 ± 7.38E+00 U | -1.73E+01 ± 2.52E+01 U | 1.00E+01 ± 1.42E+01 U |
| Cesium-137 | 2.25E-01 ± 6.51E+00 U | -5.91E+00 ± 7.80E+00 U | 1.85E+01 ± 1.98E+01 U | -6.01E+00 ± 1.25E+01 U |
| Cobalt-58 | -1.12E+00 ± 6.02E+00 U | -3.41E+00 ± 7.99E+00 U | -1.09E+01 ± 2.35E+01 U | 1.47E+00 ± 1.29E+01 U |
| Cobalt-60 | 8.75E-01 ± 6.57E+00 U | 5.88E+00 ± 7.85E+00 U | -9.20E+00 ± 2.36E+01 U | 3.97E+00 ± 1.57E+01 U |
| Iodine-131 | 1.51E+00 ± 1.10E+01 U | 3.23E+01 ± 1.05E+02 U | 7.91E+00 ± 2.85E+01 U | 3.64E+00 ± 1.90E+01 U |
| Iron-59 | 1.99E+00 ± 1.11E+01 U | 1.70E+01 ± 1.91E+01 U | -1.62E+01 ± 3.99E+01 U | 1.26E+00 ± 2.52E+01 U |
| Manganese-54 | 5.54E+00 ± 6.04E+00 U | 1.61E-01 ± 5.95E+00 U | -3.71E-01 ± 2.27E+01 U | -4.93E+00 ± 1.24E+01 U |
| Niobium-95 | 4.88E+00 ± 6.35E+00 U | 2.48E+00 ± 7.66E+00 U | -1.60E+01 ± 2.62E+01 U | -1.06E+00 ± 1.15E+01 U |
| Zinc-65 | -4.31E-01 ± 1.32E+01 U | 7.39E+00 ± 1.72E+01 U | -1.36E+01 ± 5.07E+01 U | -1.78E+01 ± 2.67E+01 U |

Table 25: Water Tritium Data (pCi/kg)

| Location | Q1 | Q2 | Q3 | Q4 |
|--------------------------|--------------------|--------------------|---------------------|--------------------|
| M-11 City of Monticello | 37.7 ± 98.7 U | 86.6 ± 174.0 U | -43.5 ± 190.0 U | -0.6 ± 108.0 U |
| M-12 Plant Well #11 | -16.3 ± 90.2 U | -23.1 ± 206.0 U | 3.7 ± 110.0 U | -23.3 ± 190.0 U |
| M-14 City of Minneapolis | 51.1 ± 141.0 U | -36.5 ± 205.0 U | 8.4 ± 170.0 U | -96.8 ± 76.1 U |
| M-43c Imholte Farm | 58.7 ± 102.0 U | 47.9 ± 215.0 U | -117.0 ± 185.0 U | -71.2 ± 85.2 U |
| M-55 Hasbrouck Residence | -47.5 ± 82.6 U | -97.1 ± 203.0 U | -7.0 ± 194.0 U | -28.2 ± 99.9 U |
| M-8c Upstream of Plant | 33.4 ± 184.0 U | 68.1 ± 188.0 U | 74.8 ± 198.0 U | 80.7 ± 116.0 U |
| M-9 Downstream of Plant | -88.7 ± 174.0 U | -18.4 ± 180.0 U | 126.0 ± 203.0 U | 37.5 ± 104.0 U |

Table 26: Drinking Water Gross Beta Data (pCi/kg)

| M-14 City of Minneapolis | Gross Beta |
|--------------------------|--------------------------|
| Jan | 2.60E+00 ± 1.97E+00 U |
| Feb | 4.11E-01 ± 2.05E+00 U |
| Mar | 2.81E+00 ± 2.05E+00 U |
| Apr | 3.09E+00 ± 1.85E+00 M |
| May | 4.10E+00 ± 2.20E+00 |
| Jun | 6.70E-01 ± 1.94E+00 U |
| Jul | 2.76E+00 ± 2.10E+00 U |
| Aug | 4.06E+00 ± 2.31E+00 |
| Sep | 2.29E+00 ± 2.16E+00 U |
| Oct | 2.61E+00 ± 2.27E+00 U |
| Nov | 1.19E+00 ± 1.88E+00 U |
| Dec | 2.76E+00 ± 2.08E+00 U |

Table 27: Groundwater Gamma Isotopic Data – M-11 City of Monticello (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | -3.57E-01 ± 1.10E+01 U | 1.90E+00 ± 2.25E+01 U | 4.56E+00 ± 7.02E+00 U | -9.12E+00 ± 1.42E+01 U |
| Cerium-144 | -9.66E-01 ± 1.50E+01 U | 1.27E+01 ± 1.78E+01 U | -3.88E+00 ± 5.81E+00 U | 1.50E+00 ± 1.06E+01 U |
| Cesium-134 | 4.87E-01 ± 1.79E+00 U | 2.67E+00 ± 2.73E+00 U | -8.72E-01 ± 8.86E-01 U | 4.16E-01 ± 2.35E+00 U |
| Cesium-137 | 2.07E-01 ± 1.57E+00 U | -1.71E+00 ± 3.10E+00 U | 1.30E-01 ± 7.36E-01 U | -5.95E-01 ± 1.66E+00 U |
| Cobalt-58 | -6.58E-01 ± 2.68E+00 U | -2.10E+00 ± 3.23E+00 U | -1.78E-01 ± 8.55E-01 U | 1.66E-01 ± 2.17E+00 U |
| Cobalt-60 | 1.20E+00 ± 1.89E+00 U | -4.11E+00 ± 3.55E+00 U | -4.12E-01 ± 7.06E-01 U | 1.44E+00 ± 1.61E+00 U |
| Iron-59 | 3.06E+00 ± 3.28E+00 U | -7.84E-01 ± 5.29E+00 U | -5.50E-01 ± 2.18E+00 U | -5.20E-01 ± 3.03E+00 U |
| Lanthanum-140 | -3.11E+00 ± 3.73E+00 U | -3.00E+00 ± 9.02E+00 U | 6.47E-01 ± 2.55E+00 U | 3.03E+00 ± 4.85E+00 U |
| Manganese-54 | -1.86E+00 ± 2.59E+00 U | -2.18E+00 ± 2.60E+00 U | 5.42E-01 ± 8.10E-01 U | -9.95E-01 ± 1.67E+00 U |
| Niobium-95 | 3.88E-02 ± 2.49E+00 U | -3.65E-01 ± 2.89E+00 U | -1.26E+00 ± 1.78E+00 U | 9.66E-01 ± 1.71E+00 U |
| Zinc-65 | 3.02E+00 ± 3.79E+00 U | -9.66E-01 ± 5.05E+00 U | 3.43E-02 ± 1.67E+00 U | -1.44E-01 ± 3.44E+00 U |
| Zirconium-95 | 9.29E-01 ± 4.20E+00 U | -1.25E+00 ± 5.14E+00 U | 8.29E-01 ± 1.75E+00 U | 5.17E-01 ± 3.66E+00 U |

Table 28: Groundwater Gamma Isotopic Data – M-12 Plant Well #11 (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | 6.48E+00 ± 1.47E+01 U | -2.84E+01 ± 2.09E+01 U | 5.50E-01 ± 6.34E+00 U | 2.23E+01 ± 1.67E+01 U |
| Cerium-144 | 3.12E+00 ± 1.86E+01 U | 2.74E+00 ± 1.66E+01 U | 8.82 E-01 ± 4.70E+00 U | 2.39E+00 ± 1.67E+01 U |
| Cesium-134 | 1.24E+00 ± 1.93E+00 U | 1.01E+00 ± 2.79E+00 U | 2.48E-01 ± 8.77E-01 U | -1.63E+00 ± 2.05E+00 U |
| Cesium-137 | -6.99E-02 ± 2.72E+00 U | 4.29E-01 ± 2.87E+00 U | -3.88E-01 ± 6.88E-01 U | 1.44E+00 ± 2.19E+00 U |
| Cobalt-58 | -9.28E-01 ± 2.57E+00 U | -2.08E+00 ± 3.44E+00 U | -1.43E-01 ± 7.96E-01 U | 2.86E-01 ± 2.02E+00 U |
| Cobalt-60 | 8.28E-01 ± 2.21E+00 U | -8.91E-01 ± 2.26E+00 U | 5.77E-01 ± 8.12E-01 U | 3.98E-01 ± 2.09E+00 U |
| Iron-59 | 2.47E+00 ± 4.67E+00 U | -2.56E+00 ± 6.27E+00 U | 1.25E+00 ± 2.09E+00 U | 8.74E-02 ± 4.90E+00 U |
| Lanthanum-140 | -1.87E+00 ± 5.23E+00 U | 5.61E+00 ± 7.28E+00 U | -1.68E+00 ± 2.62E+00 U | 6.78E-01 ± 4.50E+00 U |
| Manganese-54 | 1.86E-01 ± 2.39E+00 U | -1.85E+00 ± 2.60E+00 U | -1.36E-01 ± 8.09E-01 U | 4.98E-01 ± 2.25E+00 U |
| Niobium-95 | 3.95E-01 ± 3.39E+00 U | -9.45E-01 ± 3.15E+00 U | 4.30E-01 ± 8.88E-01 U | 1.23E+00 ± 2.42E+00 U |
| Zinc-65 | -8.50E-02 ± 5.94E+00 U | -2.00E+00 ± 4.02E+00 U | 9.56E-01 ± 1.64E+00 U | 2.18E+00 ± 5.03E+00 U |
| Zirconium-95 | -9.28E-02 ± 4.47E+00 U | -2.68E-02 ± 6.18E+00 U | 5.84E-01 ± 1.32E+00 U | -3.64E-01 ± 3.97E+00 U |

Table 29: Groundwater Gamma Isotopic Data – M-43c Imholte Farm (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | -1.26E+01 ± 1.69E+01 U | 8.27E-02 ± 1.83E+01 U | -8.17E-01 ± 5.50E+00 U | 4.36E+00 ± 1.34E+01 U |
| Cerium-144 | -6.37E+00 ± 1.70E+01 U | -2.72E+00 ± 1.53E+01 U | 4.31E+01 ± 4.02E+00 U | -5.90E+00 ± 1.23E+01 U |
| Cesium-134 | -1.74E+00 ± 2.30E+00 U | -1.68E+00 ± 2.77E+00 U | 4.17E-01 ± 6.32E-01 U | 5.69E-01 ± 1.72E+00 U |
| Cesium-137 | -1.11E+00 ± 2.87E+00 U | 7.22E-01 ± 2.73E+00 U | -4.24E-01 ± 6.92E-01 U | 1.17E+00 ± 1.97E+00 U |
| Cobalt-58 | 6.49E-02 ± 2.73E+00 U | 1.16E+00 ± 2.22E+00 U | 3.31E-01 ± 6.92E-01 U | -1.23E+00 ± 2.37E+00 U |
| Cobalt-60 | -9.69E-01 ± 2.86E+00 U | 9.59E-01 ± 2.22E+00 U | -8.31E-02 ± 6.36E-01 U | -1.39E+00 ± 2.42E+00 U |
| Iron-59 | -5.95E+00 ± 7.48E+00 U | -1.65E+00 ± 7.14E+00 U | -1.39E+00 ± 1.36E+00 U | 1.30E+00 ± 4.41E+00 U |
| Lanthanum-140 | -7.74E-01 ± 5.77E+00 U | -5.83E+00 ± 8.79E+00 U | 2.92E-01 ± 1.84E+00 U | 6.04E-01 ± 4.82E+00 U |
| Manganese-54 | 8.56E-01 ± 2.26E+00 U | -2.29E-01 ± 2.14E+00 U | -3.00E-01 ± 5.04E-01 U | -1.49E-01 ± 2.97E+00 U |
| Niobium-95 | -2.97E+00 ± 2.90E+00 U | 1.10E+00 ± 2.53E+00 U | -1.35E+00 ± 1.33E+00 U | -4.49E-01 ± 2.30E+00 U |
| Zinc-65 | 8.63E-01 ± 5.38E+00 U | 2.82E+00 ± 4.14E+00 U | -4.41E-01 ± 1.25E+00 U | -4.03E-01 ± 3.79E+00 U |
| Zirconium-95 | 4.37E+00 ± 4.92E+00 U | -1.19E+00 ± 4.07E+00 U | -5.03E-01 ± 1.08E+00 U | 4.66E+00 ± 3.67E+00 U |

Table 30: Groundwater Gamma Isotopic Data – M-55 Hasbrouck Residence (pCi/m3)

| Nuclide | Q1 | Q2 | Q3 | Q4 |
|---------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Barium-140 | 4.77E+00 ± 1.31E+01 U | -1.42E+01 ± 1.80E+01 U | 2.73E+00 ± 1.08E+01 U | 3.60E+00 ± 1.10E+01 U |
| Cerium-144 | -1.16E+00 ± 1.38E+01 U | 1.36E+01 ± 1.51E+01 U | -2.42E+00 ± 5.40E+00 U | 2.08E+00 ± 1.06E+01 U |
| Cesium-134 | 1.53E+00 ± 2.04E+00 U | 2.11E-01 ± 2.07E+00 U | 7.25E-01 ± 1.50E+00 U | 5.14E-01 ± 1.45E+00 U |
| Cesium-137 | -1.26E+00 ± 1.71E+00 U | 1.98E+00 ± 2.29E+00 U | -1.26E-01 ± 5.55E-01 U | 9.10E-01 ± 1.72E+00 U |
| Cobalt-58 | -7.63E-01 ± 2.26E+00 U | -1.39E+00 ± 2.60E+00 U | -6.90E-01 ± 7.53E-01 U | -7.44E-02 ± 2.16E+00 U |
| Cobalt-60 | 1.11E+00 ± 1.90E+00 U | -5.12E-01 ± 1.75E+00 U | -3.23E-01 ± 5.89E-01 U | 1.78E+00 ± 2.43E+00 U |
| Iron-59 | -1.46E-01 ± 4.03E+00 U | -5.32E+00 ± 4.21E+00 U | -1.39E-01 ± 1.58E+00 U | 6.29E-01 ± 3.86E+00 U |
| Lanthanum-140 | 2.51E+00 ± 3.92E+00 U | -1.43E+00 ± 5.24E+00 U | -3.19E+00 ± 3.64E+00 U | 7.40E-01 ± 4.10E+00 U |
| Manganese-54 | 9.58E-01 ± 1.86E+00 U | 2.70E+00 ± 1.62E+00 U | -5.25E-02 ± 5.67E-01 U | 1.15E+00 ± 1.80E+00 U |
| Niobium-95 | 8.95E-01 ± 2.26E+00 U | -6.35E-01 ± 2.75E+00 U | 1.50E-01 ± 7.98E-01 U | 1.20E-01 ± 1.76E+00 U |
| Zinc-65 | -7.59E-01 ± 3.61E+00 U | -3.12E-01 ± 3.93E+00 U | 6.87E-02 ± 1.25E+00 U | -5.75E-01 ± 2.47E+00 U |
| Zirconium-95 | -3.00E-01 ± 3.57E+00 U | -2.56E+00 ± 4.76E+00 U | 9.95E-02 ± 1.40E+00 U | 6.65E-01 ± 3.68E+00 U |

Table 31: Drinking Water Gamma Isotopic Data – M-14 City of Minneapolis

| Nuclide | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sept | Oct | Nov | Dec |
|---------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|
| Barium-140 | -3.32E+00 ± 1.21E+01 U | -1.73E-02 ± 1.40E+01 U | -3.68E+00 ± 1.41E+01 U | 3.80E+00 ± 1.83E+01 U | -8.99E-01 ± 1.61E+01 U | 1.23E+00 ± 1.68E+01 U | 4.60E+00 ± 2.40E+01 U | -1.89E+00 ± 6.29E+00 U | -3.76E+00 ± 1.08E+01 U | -3.31E+00 ± 1.99E+01 U | 8.78E+00 ± 7.59E+00 U | 3.81E-01 ± 7.92E+00 U |
| Cerium-144 | 4.61E-01 ± 1.38E+01 U | -7.41E+00 ± 1.38E+01 U | 2.78E+00 ± 1.34E+01 U | -1.29E+01 ± 1.40E+01 U | 2.89E+00 ± 1.63E+01 U | 6.07E+00 ± 1.93E+01 U | -1.26E+01 ± 1.42E+01 U | 3.63E+00 ± 3.59E+00 U | 3.83E+00 ± 1.36E+01 U | 2.99E-01 ± 1.71E+01 U | 2.52E+00 ± 7.68E+00 U | -2.79E+00 ± 8.46E+00 U |
| Cesium-134 | -9.23E-01 ± 2.07E+00 U | -1.05E+00 ± 2.09E+00 U | -5.28E-01 ± 1.97E+00 U | 3.36E-01 ± 1.92E+00 U | 1.19E+00 ± 2.52E+00 U | 2.15E+00 ± 2.59E+00 U | -2.46E+00 ± 2.68E+00 U | -4.33E-02 ± 5.58E-01 U | -3.24E-01 ± 2.01E+00 U | 1.27E+00 ± 2.60E+00 U | 9.77E-01 ± 1.31E+00 U | -4.90E-02 ± 2.13E+00 U |
| Cesium-137 | -9.64E-01 ± 2.41E+00 U | -1.98E+00 ± 1.67E+00 U | 1.37E+00 ± 1.90E+00 U | 8.27E-01 ± 1.80E+00 U | -7.81E-02 ± 2.37E+00 U | 1.08E+00 ± 2.60E+00 U | 9.82E-01 ± 2.17E+00 U | 1.23E-01 ± 6.22E-01 U | 9.04E-01 ± 2.21E+00 U | 2.09E+00 ± 2.62E+00 U | 3.05E-01 ± 1.08E+00 U | -1.48E+00 ± 1.32E+00 U |
| Cobalt-58 | 1.55E+00 ± 2.08E+00 U | 1.69E+00 ± 1.89E+00 U | 1.61E+00 ± 2.08E+00 U | -1.21E+00 ± 2.33E+00 U | -1.59E+00 ± 2.60E+00 U | -1.75E+00 ± 2.18E+00 U | 5.02E-01 ± 1.80E+00 U | -1.12E-01 ± 4.89E-01 U | -2.30E-01 ± 2.18E+00 U | 9.12E-01 ± 2.44E+00 U | -2.48E-01 ± 1.14E+00 U | -1.38E+00 ± 1.53E+00 U |
| Cobalt-60 | 1.01E+00 ± 1.57E+00 U | 2.23E+00 ± 2.76E+00 U | 2.40E-01 ± 2.36E+00 U | 1.04E+00 ± 2.34E+00 U | 2.80E+00 ± 2.50E+00 U | -9.05E-01 ± 2.09E+00 U | -4.95E-01 ± 1.66E+00 U | 1.18E-01 ± 4.39E-01 U | -2.11E+00 ± 2.76E+00 U | 1.19E+00 ± 1.69E+00 U | 2.91E+00 ± 1.63E+00 U | -1.46E+00 ± 1.41E+00 U |
| Iron-59 | -1.11E+00 ± 3.69E+00 U | 5.89E-01 ± 4.15E+00 U | 6.29E+00 ± 5.21E+00 U | 2.41E+00 ± 5.01E+00 U | -2.66E+00 ± 6.07E+00 U | 9.20E-04 ± 5.41E+00 U | -1.39E+00 ± 3.55E+00 U | -7.41E-01 ± 1.17E+00 U | 2.70E+00 ± 4.16E+00 U | -2.11E+00 ± 5.48E+00 U | -1.83E+00 ± 2.45E+00 U | -7.11E-01 ± 2.92E+00 U |
| Lanthanum-140 | -2.11E+00 ± 4.65E+00 U | -2.02E+00 ± 2.96E+00 U | 1.63E+00 ± 4.07E+00 U | 2.32E+00 ± 5.96E+00 U | -4.38E+00 ± 4.37E+00 U | -4.59E+00 ± 5.66E+00 U | 1.72E+00 ± 8.12E+00 U | 1.01E-01 ± 1.03E+00 U | 7.45E-01 ± 4.05E+00 U | 1.40E+00 ± 6.06E+00 U | 5.52E-01 ± 3.00E+00 U | -4.48E-01 ± 2.05E+00 U |
| Manganese-54 | -6.58E-01 ± 1.93E+00 U | -1.50E-01 ± 2.07E+00 U | 2.71E+00 ± 1.99E+00 U | -9.22E-01 ± 2.23E+00 U | 1.71E+00 ± 2.46E+00 U | -9.61E-01 ± 2.54E+00 U | -4.18E-01 ± 1.91E+00 U | 2.29E-01 ± 5.11E-01 U | 1.53E+00 ± 1.90E+00 U | 5.69E-01 ± 2.27E+00 U | 3.40E-01 ± 1.11E+00 U | 3.79E-02 ± 1.28E+00 U |
| Niobium-95 | 5.95E-01 ± 2.07E+00 U | 5.93E-01 ± 2.10E+00 U | 1.17E+00 ± 2.15E+00 U | -3.78E-01 ± 2.37E+00 U | 2.54E+00 ± 3.44E+00 U | -1.72E+00 ± 2.96E+00 U | -2.33E-01 ± 2.40E+00 U | 3.65E-01 ± 1.21E+00 U | 2.56E-01 ± 2.17E+00 U | 1.22E+00 ± 1.79E+00 U | 2.45E-01 ± 1.07E+00 U | -4.10E-02 ± 1.33E+00 U |

Table 32: Surface Water Gamma Isotopic Data – M-8c Upstream of Plant

| Nuclide | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sept | Oct | Nov | Dec ²³ |
|---------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|-------------------|
| Barium-140 | -3.90E+00 ± 1.30E+01 U | -3.79E+00 ± 1.80E+01 U | 3.04E+00 ± 9.90E+00 U | -2.66E+00 ± 1.59E+01 U | 6.16E+00 ± 3.15E+01 U | 1.78E+00 ± 1.49E+01 U | 1.05E+01 ± 1.72E+01 U | 2.84E+01 ± 3.29E+01 U | 1.56E+01 ± 1.90E+01 U | 4.21E+00 ± 1.09E+01 U | 1.58E+01 ± 1.98E+01 U | - |
| Cerium-144 | -2.23E+00 ± 9.82E+00 U | -7.38E-02 ± 1.57E+01 U | 9.26E-03 ± 6.66E+00 U | 1.74E+00 ± 1.77E+01 U | -1.10E+00 ± 6.54E+00 U | -2.86E+00 ± 1.22E+01 U | 7.87E+00 ± 9.89E+00 U | -6.76E+00 ± 8.12E+00 U | 3.47E+00 ± 1.31E+01 U | 3.53E+00 ± 6.65E+00 U | -2.54E+00 ± 1.15E+01 U | - |
| Cesium-134 | -1.13E+00 ± 2.00E+00 U | -3.83E+00 ± 2.84E+00 U | 2.57E-02 ± 9.34E-01 U | 1.90E-01 ± 2.18E+00 U | 2.19E-01 ± 9.28E-01 U | 3.10E-01 ± 1.75E+00 U | 6.69E-01 ± 1.70E+00 U | 1.30E+00 ± 1.13E+00 U | 7.32E-01 ± 2.69E+00 U | 3.60E-01 ± 9.50E-01 U | 2.48E+00 ± 2.50E+00 U | - |
| Cesium-137 | 8.43E-01 ± 1.65E+00 U | -2.21E-01 ± 2.71E+00 U | 4.78E-01 ± 9.93E-01 U | 6.34E-01 ± 2.60E+00 U | 4.81E-01 ± 9.15E-01 U | 2.49E-01 ± 1.79E+00 U | 8.12E-01 ± 1.46E+00 U | -1.92E-01 ± 1.12E+00 U | -7.27E-01 ± 2.14E+00 U | 4.14E-01 ± 1.06E+00 U | -1.61E-01 ± 2.04E+00 U | - |
| Cobalt-58 | 5.02E-01 ± 2.47E+00 U | -7.59E-01 ± 2.59E+00 U | 4.90E-02 ± 1.17E+00 U | -1.35E+00 ± 3.28E+00 U | 4.86E-01 ± 1.13E+00 U | -1.64E+00 ± 1.89E+00 U | 1.68E-01 ± 1.75E+00 U | -5.35E-02 ± 1.39E+00 U | -1.54E+00 ± 2.39E+00 U | -1.55E-01 ± 9.98E-01 U | 1.68E-01 ± 2.03E+00 U | - |
| Cobalt-60 | 4.37E-01 ± 1.63E+00 U | 8.31E-02 ± 3.20E+00 U | -3.62E-01 ± 9.17E-01 U | 1.79E+00 ± 2.86E+00 U | 1.35E-01 ± 9.23E-01 U | -8.23E-01 ± 2.22E+00 U | 3.05E-01 ± 1.65E+00 U | -7.93E-03 ± 1.11E+00 U | 2.11E-01 ± 1.90E+00 U | -3.81E-01 ± 1.20E+00 U | 4.18E-01 ± 1.40E+00 U | - |
| Iron-59 | -2.86E+00 ± 4.62E+00 U | -7.02E+00 ± 6.56E+00 U | -1.42E+00 ± 2.45E+00 U | -2.38E+00 ± 5.72E+00 U | 3.86E-01 ± 3.00E+00 U | 2.64E+00 ± 4.21E+00 U | -1.85E-02 ± 4.51E+00 U | -1.11E+00 ± 3.67E+00 U | -3.25E+00 ± 5.31E+00 U | -1.51E+00 ± 2.50E+00 U | 2.72E+00 ± 7.42E+00 U | - |
| Lanthanum-140 | -2.09E+00 ± 4.36E+00 U | -6.92E-01 ± 7.40E+00 U | -2.17E+00 ± 3.81E+00 U | -5.60E+00 ± 5.65E+00 U | 1.81E+01 ± 1.60E+01 U | -9.67E-02 ± 5.07E+00 U | 1.88E+00 ± 7.53E+00 U | -1.49E+01 ± 1.44E+01 U | 0.00E+00 ± 7.33E+00 U | -2.21E-01 ± 3.84E+00 U | 2.65E+00 ± 7.09E+00 U | - |
| Manganese-54 | 6.20E-01 ± 1.69E+00 U | 4.76E-01 ± 2.20E+00 U | -3.26E-01 ± 9.23E-01 U | -2.07E+00 ± 2.82E+00 U | 1.37E-01 ± 8.95E-01 U | 5.42E-01 ± 1.71E+00 U | -1.22E+00 ± 1.68E+00 U | -1.06E-01 ± 1.11E+00 U | 5.17E-01 ± 1.86E+00 U | 4.50E-01 ± 9.06E-01 U | -1.40E+00 ± 1.71E+00 U | - |
| Niobium-95 | -2.18E+00 ± | 1.16E-01 ± | 3.61E-01 ± | -9.87E-01 ± | -4.67E-01 ± | -3.99E-01 ± | -2.36E-01 ± | 1.56E+00 ± | -1.15E+00 ± | 8.94E-01 ± | -1.22E+00 ± | - |

²³ Unsafe condition for sampling due to frozen river surface.

Table 32: Surface Water Gamma Isotopic Data – M-8c Upstream of Plant

| Nuclide | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sept | Oct | Nov | Dec ²³ |
|--------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|---------------------------------|-------------------|
| | 2.41E+00 U | 2.77E+00 U | 1.04E+00 U | 2.47E+00 U | 1.22E+00 U | 2.53E+00 U | 1.96E+00 U | 1.58E+00 U | 2.22E+00 U | 9.22E-01 U | 2.13E+00 U | |
| Zinc-65 | 2.67E+00 ± 3.69E+00 U | -2.04E+00 ± 6.09E+00 U | -3.74E-01 ± 1.94E+00 U | 1.17E+00 ± 4.30E+00 U | -7.09E-01 ± 1.99E+00 U | -3.67E+00 ± 3.65E+00 U | 9.89E-02 ± 3.10E+00 U | 1.25E-01 ± 2.44E+00 U | -6.70E-01 ± 4.50E+00 U | 4.39E-01 ± 2.15E+00 U | 5.23E-01 ± 3.37E+00 U | - |
| Zirconium-95 | 2.08E+00 ± 3.65E+00 U | 8.70E-01 ± 4.44E+00 U | -1.18E+00 ± 2.08E+00 U | 2.80E+00 ± 4.51E+00 U | 7.11E-04 ± 2.18E+00 U | -1.60E+00 ± 3.52E+00 U | 4.24E-01 ± 3.66E+00 U | -4.97E-02 ± 2.70E+00 U | -3.16E+00 ± 4.35E+00 U | 6.66E-01 ± 1.91E+00 U | -1.38E-01 ± 3.53E+00 U | - |

Table 33: Surface Water Gamma Isotopic Data – M-9 Downstream of Plant

| Nuclide | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sept | Oct | Nov | Dec |
|---------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|
| Barium-140 | -3.55E+00 ± 1.64E+01 U | 6.78E+00 ± 1.03E+01 U | 2.67E+00 ± 9.27E+00 U | -9.20E+00 ± 1.55E+01 U | 1.10E+01 ± 3.04E+01 U | -4.13E+00 ± 1.66E+01 U | -4.94E+00 ± 2.16E+01 U | 5.05E+01 ± 4.32E+01 U | -2.83E+00 ± 2.09E+01 U | -2.80E+00 ± 8.94E+00 U | -6.27E+00 ± 2.63E+01 U | 1.39E+00 ± 1.36E+01 U |
| Cerium-144 | 4.48E+00 ± 1.47E+01 U | 4.05E+00 ± 1.18E+01 U | -2.66E+00 ± 5.72E+00 U | 6.85E+00 ± 1.49E+01 U | 3.40E+00 ± 6.01E+00 U | -9.23E+00 ± 1.42E+01 U | 5.96E+00 ± 1.45E+01 U | 3.90E+00 ± 6.64E+00 U | -8.35E+00 ± 2.07E+01 U | -3.31E+00 ± 5.45E+00 U | -1.04E+01 ± 1.42E+01 U | 4.16E-01 ± 1.24E+01 U |
| Cesium-134 | 1.44E+00 ± 2.45E+00 U | -1.67E-01 ± 1.75E+00 U | -3.24E-01 ± 9.33E-01 U | -1.19E+00 ± 2.60E+00 U | -4.38E-02 ± 8.52E-01 U | 4.19E-01 ± 2.54E+00 U | -1.71E+00 ± 2.17E+00 U | 1.03E+00 ± 1.46E+00 U | 1.47E+00 ± 1.59E+00 U | 2.05E-01 ± 8.65E-01 U | 5.11E-01 ± 2.39E+00 U | -2.77E-02 ± 1.95E+00 U |
| Cesium-137 | 1.52E+00 ± 2.73E+00 U | -6.17E-01 ± 2.03E+00 U | 2.16E-01 ± 9.44E-01 U | 4.29E-01 ± 2.27E+00 U | -1.02E+00 ± 1.43E+00 U | -7.68E-02 ± 2.77E+00 U | 6.75E-01 ± 1.93E+00 U | 5.75E-01 ± 8.90E-01 U | -1.01E+00 ± 2.57E+00 U | -1.16E-01 ± 8.27E-01 U | 3.29E-01 ± 2.01E+00 U | 6.35E-01 ± 1.80E+00 U |
| Cobalt-58 | -6.14E-01 ± 2.59E+00 U | 1.29E-01 ± 1.78E+00 U | -3.95E-02 ± 9.51E-01 U | 1.62E+00 ± 2.72E+00 U | 4.80E-01 ± 1.16E+00 U | -9.61E-01 ± 2.79E+00 U | 2.47E+00 ± 2.32E+00 U | 6.95E-01 ± 1.28E+00 U | -1.88E+00 ± 2.90E+00 U | 4.35E-01 ± 9.84E-01 U | -8.95E-01 ± 2.16E+00 U | 9.41E-01 ± 1.99E+00 U |
| Cobalt-60 | -7.12E-01 ± 1.88E+00 U | 1.78E-01 ± 1.80E+00 U | -1.87E+00 ± 1.41E+00 U | 3.63E-01 ± 3.11E+00 U | -2.52E-01 ± 8.88E-01 U | -9.08E-01 ± 2.19E+00 U | -5.09E-01 ± 2.24E+00 U | 3.58E-02 ± 8.91E-01 U | 3.62E-01 ± 2.07E+00 U | 2.35E-01 ± 8.54E-01 U | -9.46E-01 ± 3.14E+00 U | 4.88E-01 ± 1.73E+00 U |
| Iron-59 | 2.68E+00 ± 5.66E+00 U | -7.26E+00 ± 4.75E+00 U | 4.93E-01 ± 2.40E+00 U | -1.35E+00 ± 5.63E+00 U | 9.02E-01 ± 2.59E+00 U | 5.03E+00 ± 4.91E+00 U | -1.82E+00 ± 5.01E+00 U | -2.29E+00 ± 3.27E+00 U | 1.73E+00 ± 5.14E+00 U | -3.23E-01 ± 2.02E+00 U | 4.61E+00 ± 4.76E+00 U | 5.76E-01 ± 3.24E+00 U |
| Lanthanum-140 | -5.38E+00 ± 6.43E+00 U | 1.35E+00 ± 3.19E+00 U | -2.07E+00 ± 4.10E+00 U | -3.84E+00 ± 5.98E+00 U | -1.55E+01 ± 1.01E+01 U | -2.38E+00 ± 4.82E+00 U | 2.43E+00 ± 7.49E+00 U | 3.04E-01 ± 9.68E+00 U | 1.89E+00 ± 7.18E+00 U | -9.08E-01 ± 2.64E+00 U | -3.31E+00 ± 8.69E+00 U | 3.38E+00 ± 4.03E+00 U |
| Manganese-54 | 8.91E-01 ± 2.42E+00 U | -2.09E-01 ± 1.84E+00 U | 4.97E-01 ± 9.53E-01 U | -6.20E-01 ± 2.20E+00 U | 5.61E-01 ± 8.54E-01 U | -2.68E-01 ± 1.95E+00 U | -2.15E-01 ± 2.19E+00 U | -1.23E-01 ± 1.52E+00 U | -3.97E-01 ± 1.93E+00 U | -7.58E-01 ± 1.35E+00 U | 3.37E+00 ± 2.08E+00 U | 3.02E-01 ± 2.05E+00 U |
| Niobium-95 | -7.04E-01 ± 2.47E+00 U | 2.74E-01 ± 1.93E+00 U | 1.65E-01 ± 1.05E+00 U | -4.88E-01 ± 1.84E+00 U | 3.82E-01 ± 2.37E+00 U | 1.99E+00 ± 2.46E+00 U | 7.59E-01 ± 3.60E+00 U | 6.30E-01 ± 1.89E+00 U | 1.80E+00 ± 2.56E+00 U | 1.08E+00 ± 1.15E+00 U | 3.31E-01 ± 2.67E+00 U | 3.44E-01 ± 1.91E+00 U |

Table 33: Surface Water Gamma Isotopic Data – M-9 Downstream of Plant

| Nuclide | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sept | Oct | Nov | Dec |
|--------------|-----------|----------|-----------|-----------|-----------|-----------|-----------|----------|-----------|------------|-----------|----------|
| Zinc-65 | -3.49E+00 | 1.18E+00 | -6.52E-01 | 2.53E+00 | 1.26E+00 | -1.32E+00 | -8.86E-01 | 4.57E-01 | -3.78E-01 | -1.62E+00 | -8.87E-01 | 3.53E+00 |
| | ± | ± | ± | ± | ± | ± | ± | ± | ± | ± | ± | ± |
| | 4.82E+00 | 3.29E+00 | 1.69E+00 | 4.36E+00 | 2.04E+00 | 4.50E+00 | 4.35E+00 | 1.94E+00 | 6.23E+00 | 1.89E+00 | 5.35E+00 | 3.57E+00 |
| | U | U | U | U | U | U | U | U | U | U | U | U |
| Zirconium-95 | -1.09E+00 | 1.47E+00 | 1.98E+00 | -7.04E-01 | -3.04E+00 | 1.08E+00 | 1.48E-01 | 5.09E+00 | -7.56E-01 | 8.74E-01 | -1.13E+00 | 1.19E+00 |
| | ± | ± | ± | ± | ± | ± | ± | ± | ± | ± 1.62E+00 | ± | ± |
| | 4.52E+00 | 3.20E+00 | 1.93E+00 | 3.95E+00 | 2.08E+00 | 3.64E+00 | 4.07E+00 | 3.45E+00 | 4.40E+00 | U | 4.57E+00 | 3.72E+00 |
| | U | U | U | U | U | U | U | UI | U | U | U | U |

Table 34: Direct Radiation Data – TLD: Gamma (mrem/91 day)

| Location | Q1 | Q2 | Q3 | Q4 |
|-----------------------------------|------------|------------|------------|------------|
| Control | | | | |
| M01C Kirchenbauer Farm | 11.5 ± 0.6 | 12.7 ± 0.6 | 14.7 ± 0.9 | 14.6 ± 0.8 |
| M02C Cty Rd 4 & 15 | 11.5 ± 0.6 | 12.3 ± 0.5 | 13.6 ± 0.8 | 13.3 ± 0.8 |
| M03C Cty Rd 19 & Jason Ave | 12.0 ± 0.7 | 13.5 ± 0.5 | 15.7 ± 0.7 | 14.7 ± 0.7 |
| M04C Maple Lake Water Tower | 11.3 ± 0.5 | 13.0 ± 0.8 | 14.5 ± 0.9 | 14.1 ± 0.7 |
| Inner | | | | |
| M01A Sherburne Ave. So.1 | 14.7 ± 0.7 | 16.3 ± 0.7 | 17.9 ± 0.7 | 17.1 ± 0.8 |
| M02A Sherburne Ave. So. | 13.9 ± 0.6 | 14.6 ± 0.8 | 16.7 ± 0.6 | 15.9 ± 0.9 |
| M03A Sherburne Ave. So. | 13.4 ± 0.6 | 14.8 ± 0.7 | 16.3 ± 0.9 | 15.9 ± 0.8 |
| M04A Biology Station Rd. | 11.9 ± 0.9 | 13.3 ± 0.6 | 15.1 ± 0.9 | 14.3 ± 0.6 |
| M05A Biology Station Rd. | 12.2 ± 0.6 | 13.5 ± 0.6 | 15.9 ± 0.8 | 14.7 ± 0.8 |
| M06A Biology Station Rd. | 13.4 ± 0.7 | 15.0 ± 0.7 | 16.6 ± 0.6 | 15.5 ± 0.9 |
| M07A Parking Lot H | 13.1 ± 1.6 | 13.1 ± 1.0 | 16.1 ± 0.8 | 15.7 ± 0.8 |
| M08A Parking Lot F | 12.7 ± 0.6 | 14.8 ± 0.6 | 16.1 ± 0.7 | 15.5 ± 0.8 |
| M09A County Road 75 | 13.2 ± 0.6 | 14.3 ± 0.6 | 16.4 ± 0.8 | 15.2 ± 0.7 |
| M10A County Road 75 | 13.2 ± 1.2 | 13.9 ± 1.0 | 16.1 ± 0.7 | 15.0 ± 0.8 |
| M11A County Road 75 2 | 13.5 ± 0.6 | 14.9 ± 0.7 | 16.8 ± 0.7 | 16.0 ± 0.7 |
| M12A County Road 75 | 13.0 ± 0.6 | 14.4 ± 0.7 | 15.9 ± 0.7 | 15.2 ± 0.8 |
| M13A North Boundary Rd. | 10.4 ± 0.6 | 12.2 ± 0.7 | 13.3 ± 0.7 | 13.1 ± 0.8 |
| M14A North Boundary Rd. | 13.7 ± 0.6 | 15.7 ± 1.2 | 16.2 ± 0.8 | 16.6 ± 0.9 |
| Outer | | | | |
| M01B 117th Street | 12.4 ± 0.6 | 13.8 ± 0.9 | 15.5 ± 0.7 | 15.2 ± 1.4 |
| M02B County Road 11 | 12.5 ± 0.7 | 14.2 ± 0.9 | 14.9 ± 0.7 | 14.7 ± 1.0 |
| M03B County Rd. 73 & 81 | 11.2 ± 0.5 | 12.3 ± 0.8 | 12.8 ± 0.8 | 13.2 ± 0.7 |
| M04B County Rd. 73 (196th Street) | 12.4 ± 0.6 | 13.6 ± 0.6 | 14.2 ± 0.6 | 14.6 ± 0.8 |

Table 34: Direct Radiation Data – TLD: Gamma (mrem/91 day)

| Location | Q1 | Q2 | Q3 | Q4 |
|--|------------|------------|------------|---------------|
| M05B City of Big Lake | 13.4 ± 0.9 | 13.9 ± 0.9 | 14.9 ± 1.0 | 15.6 ± 1.2 |
| M06B County Rd 14 & 196th Street | 12.4 ± 0.6 | 14.4 ± 0.7 | 15.3 ± 0.9 | Missed Sample |
| M07B Monticello Industrial Dr. | 12.5 ± 0.5 | 13.8 ± 0.6 | 15.4 ± 0.8 | 15.2 ± 0.8 |
| M08B Residence Hwy 25 & Davidson Ave | 11.8 ± 0.6 | 13.5 ± 0.9 | 14.7 ± 0.6 | 14.7 ± 0.6 |
| M09B Weinand Farm | 13.4 ± 0.7 | 15.1 ± 0.8 | 16.0 ± 0.7 | 16.4 ± 1.0 |
| M10B Reisewitz Farm - Acacia Ave | 12.1 ± 0.5 | 14.3 ± 0.6 | 15.4 ± 0.7 | 15.6 ± 0.7 |
| M11B Vanlith Farm - 97th Ave | 13.1 ± 0.6 | 15.4 ± 0.9 | 16.2 ± 1.1 | 16.0 ± 0.9 |
| M12B Lake Maria St. Park | 12.3 ± 0.6 | 14.6 ± 0.7 | 16.4 ± 0.6 | 15.4 ± 0.9 |
| M01B 117th Street | 13.1 ± 0.5 | 15.2 ± 1.0 | 16.0 ± 0.8 | 15.8 ± 0.7 |
| M13B Bridgewater Sta. | 13.2 ± 0.7 | 15.1 ± 0.8 | 16.6 ± 0.8 | 16.6 ± 1.0 |
| M14B Anderson Res. - Cty Rd 111 | 11.6 ± 0.6 | 13.3 ± 0.6 | 15.0 ± 0.9 | 14.7 ± 0.8 |
| M15B Barton Ave NW | 12.2 ± 0.5 | 14.1 ± 1.0 | 20.9 ± 2.3 | 15.0 ± 0.7 |
| M16B University Ave and Hancock St, Becker | 12.4 ± 0.6 | 13.8 ± 0.9 | 15.5 ± 0.7 | 15.2 ± 1.4 |
| Special Interest | | | | |
| M01S 127th St. NE | 12.9 ± 0.9 | 14.6 ± 0.9 | 15.4 ± 0.9 | 15.6 ± 0.9 |
| M02S Krone Residence | 12.6 ± 0.4 | 14.3 ± 0.8 | 16.7 ± 0.7 | 15.8 ± 1.1 |
| M03S Big Oaks Park | 13.2 ± 0.8 | 14.3 ± 0.8 | 16.6 ± 0.7 | 17.3 ± 0.9 |
| M04S Pinewood School | 11.1 ± 0.6 | 13.0 ± 1.4 | 14.0 ± 0.8 | Missed Sample |
| M05S 20500 Co. Rd 11, Big Lake | 11.2 ± 0.5 | 12.8 ± 0.8 | 14.0 ± 0.8 | 13.9 ± 0.6 |
| M06S Monticello Public Works | 12.6 ± 0.6 | 14.0 ± 0.8 | 15.8 ± 0.6 | 15.7 ± 0.8 |
| I-11 OCA Fence South, on exit road | 12.7 ± 0.5 | 14.6 ± 1.3 | 16.0 ± 0.7 | 15.5 ± 0.8 |
| I-12 OCA Fence Middle, on exit road | 12.8 ± 0.6 | 14.3 ± 0.6 | 16.0 ± 0.6 | 14.9 ± 1.1 |
| I-13 OCA Fence North, on exit road | 11.7 ± 0.6 | 14.5 ± 0.7 | 16.3 ± 0.8 | 16.1 ± 0.7 |

Table 35: Direct Radiation Data – ISFSI: Gamma (mrem/91 day)

| Location | Q1 | Q2 | Q3 | Q4 |
|---|------------|------------|------------|------------|
| I-01 NE corner of ISFSI | 38.6 ± 2.4 | 32.6 ± 1.4 | 44.8 ± 3.9 | 39.1 ± 2.4 |
| I-02 North side of ISFSI, center | 33.7 ± 1.8 | 28.5 ± 1.7 | 38.1 ± 4.1 | 33.9 ± 2.3 |
| I-03 NW corner of ISFSI | 28.6 ± 1.8 | 26.2 ± 2.2 | 31.5 ± 1.7 | 28.1 ± 1.6 |
| I-04 West side of ISFSI, middle | 69.9 ± 8.3 | 72.5 ± 7.8 | 66.1 ± 4.7 | 65.0 ± 4.6 |
| I-05 West side of ISFSI, at center of array | 51.0 ± 5.5 | 46.6 ± 3.6 | 50.5 ± 3.1 | 48.2 ± 3.5 |
| I-06 SW corner of ISFSI | 28.2 ± 2.7 | 28.0 ± 2.1 | 29.3 ± 3.1 | 27.5 ± 2.3 |
| I-07 South side of ISFSI, center | 30.7 ± 1.8 | 28.4 ± 1.3 | 30.6 ± 1.7 | 29.9 ± 1.4 |
| I-08 SE corner of ISFSI | 29.0 ± 2.0 | 29.4 ± 2.6 | 32.8 ± 2.6 | 30.1 ± 2.7 |
| I-09 East side of ISFSI, at center of array | 65.2 ± 5.5 | 67.8 ± 9.8 | 69.1 ± 5.2 | 71.1 ± 8.8 |
| I-10 East side of ISFSI, middle | 53.4 ± 3.8 | 52.4 ± 3.4 | 57.4 ± 3.6 | 57.6 ± 3.7 |

| | | |
|--|--|---------------|
| Annual Radiological Environmental Operating Report | YEAR: 2025 | Page 83 of 86 |
| Company: Xcel Energy | Plant: Monticello Nuclear Generating Plant | |

Attachment 3, Cross Check Intercomparison Program

Participation in cross check intercomparison studies is mandatory for laboratories performing analyses of REMP samples satisfying the requirements in the Offsite Site Dose Calculation Manual. Intercomparison studies provide a consistent and effective means to evaluate the accuracy and precision of analyses performed by a laboratory. Study results should fall within specified control limits and results that fall outside the control limits are investigated and corrected.

The analytical laboratory analyzing samples for MNGP, GEL Laboratories, LLC (GEL), participated in the following proficiency testing studies provided by Environmental Resource Associates (ERA), Eckert & Ziegler Analytics, Inc., and the Department of Energy Mixed Analyte Performance Evaluation Program (MAPEP) in 2025. The Laboratory's intercomparison program results for 2025 are summarized below.

- Eckert & Ziegler Analytics Environmental Cross-Check Program (including samples for 69 individual environmental analyses)
- MAPEP Monitoring Program (including Series 49, Series 50, and Series 51 samples)
- ERA Multimedia Radiochemistry Proficiency Test (MRAD PT) Program (including MRAD-40 and MRAD-41 samples)
- ERA PT Program (including RAD-136, RAD-137, RAD-138 and RAD-139 samples)

During 2025, forty-one (41) radioisotopes associated with six (6) matrix types (air filter, cartridge, water, milk, soil, and vegetation) were analyzed under GEL's Performance Evaluation program in participation with ERA, MAPEP, and Eckert & Ziegler Analytics, as noted above. Matrix types were representative of client analyses performed during 2024. Of the three hundred sixty-nine (369) total results, 97% (358 of 369) were found to be acceptable within the PT providers' three sigma or other statistical criteria. The results of these analyses are provided in GEL's 2025 Annual Quality Assurance Report for the Radiological Environmental Monitoring Program (REMP), included in Attachment 5. The Annual Quality Assurance Status Report provided by the TLD analysis laboratory, Environmental Dosimetry Company, is also provided in Attachment 5.

Attachment 4, Environmental Direct Radiation Dosimetry Results

| Monitoring Location | Quarterly Baseline, B_Q (mrem) | | Normalized Quarterly Monitoring Data, M_Q (mrem) | | | | Quarterly Facility Dose, $F_Q = M_Q \cdot B_Q$ (mrem, or "ND" if $F_Q \leq MDD_Q$) | | | | Annual Baseline, B_A (mrem) | Annual Monitoring Data, M_A (mrem) | Annual Facility Dose, $F_A = M_A \cdot B_A$ (mrem, or "ND" if $F_A \leq MDD_A$) |
|---------------------|----------------------------------|-------|--|------|------|------|---|----|----|----|-------------------------------|--------------------------------------|--|
| | Q1 | Q2-Q4 | 1 | 2 | 3 | 4 | 1 | 2 | 3 | 4 | | | |
| M01A | 13.2 | 15.1 | 14.7 | 16.3 | 17.9 | 17.1 | ND | ND | ND | ND | 58.5 | 66.0 | ND |
| M02A | 14.2 | 16.1 | 13.9 | 14.6 | 16.7 | 15.9 | ND | ND | ND | ND | 62.6 | 61.0 | ND |
| M03A | 13.9 | 15.7 | 13.4 | 14.8 | 16.3 | 15.9 | ND | ND | ND | ND | 61.0 | 60.4 | ND |
| M04A | 13.1 | 15.6 | 11.9 | 13.3 | 15.1 | 14.3 | ND | ND | ND | ND | 59.8 | 54.5 | ND |
| M05A | 13.2 | 15.9 | 12.2 | 13.5 | 15.9 | 14.7 | ND | ND | ND | ND | 60.8 | 56.2 | ND |
| M06A | 14.1 | 16.1 | 13.4 | 15.0 | 16.6 | 15.5 | ND | ND | ND | ND | 62.4 | 60.6 | ND |
| M07A | 13.9 | 15.9 | 13.1 | 13.1 | 16.1 | 15.7 | ND | ND | ND | ND | 61.4 | 58.0 | ND |
| M08A | 13.9 | 15.8 | 12.7 | 14.8 | 16.1 | 15.5 | ND | ND | ND | ND | 61.5 | 59.1 | ND |
| M09A | 14.3 | 15.8 | 13.2 | 14.3 | 16.4 | 15.2 | ND | ND | ND | ND | 61.5 | 59.1 | ND |
| M10A | 14.3 | 16.4 | 13.2 | 13.9 | 16.1 | 15.0 | ND | ND | ND | ND | 63.4 | 58.2 | ND |
| M11A | 15.4 | 16.9 | 13.5 | 14.9 | 16.8 | 16.0 | ND | ND | ND | ND | 66.0 | 61.2 | ND |
| M12A | 15.5 | 17.1 | 13.0 | 14.4 | 15.9 | 15.2 | ND | ND | ND | ND | 66.5 | 58.5 | ND |
| M13A | 13.6 | 14.6 | 10.4 | 12.2 | 13.3 | 13.1 | ND | ND | ND | ND | 57.3 | 49.1 | ND |
| M14A | 14.3 | 16.3 | 13.7 | 15.7 | 16.2 | 16.6 | ND | ND | ND | ND | 63.4 | 62.2 | ND |
| M01B | 14.3 | 15.4 | 12.4 | 13.8 | 15.5 | 15.2 | ND | ND | ND | ND | 60.7 | 56.8 | ND |
| M02B | 14.6 | 15.4 | 12.5 | 14.2 | 14.9 | 14.7 | ND | ND | ND | ND | 60.8 | 56.3 | ND |
| M03B | 12.2 | 12.9 | 11.2 | 12.3 | 12.8 | 13.2 | ND | ND | ND | ND | 50.9 | 49.4 | ND |
| M04B | 12.9 | 14.4 | 12.4 | 13.6 | 14.2 | 14.6 | ND | ND | ND | ND | 56.1 | 54.9 | ND |
| M05B | 14.6 | 16.0 | 13.4 | 13.9 | 14.9 | 15.6 | ND | ND | ND | ND | 62.5 | 57.9 | ND |
| M06B | 12.8 | 15.4 | 12.4 | 14.4 | 15.3 | * | ND | ND | ND | * | 58.8 | 56.0 | ND |
| M07B | 15.3 | 16.1 | 12.5 | 13.8 | 15.4 | 15.2 | ND | ND | ND | ND | 63.5 | 56.9 | ND |
| M08B | 13.6 | 14.8 | 11.8 | 13.5 | 14.7 | 14.7 | ND | ND | ND | ND | 58.0 | 54.6 | ND |
| M09B | 14.2 | 16.7 | 13.4 | 15.1 | 16.0 | 16.4 | ND | ND | ND | ND | 64.3 | 60.8 | ND |
| M10B | 14.5 | 16.0 | 12.1 | 14.3 | 15.4 | 15.6 | ND | ND | ND | ND | 62.5 | 57.4 | ND |

| Monitoring Location | Quarterly Baseline, B_Q (mrem) | | Normalized Quarterly Monitoring Data, M_Q (mrem) | | | | Quarterly Facility Dose, $F_Q = M_Q - B_Q$ (mrem, or "ND" if $F_Q \leq MDD_Q$) | | | | Annual Baseline, B_A (mrem) | Annual Monitoring Data, M_A (mrem) | Annual Facility Dose, $F_A = M_A - B_A$ (mrem, or "ND" if $F_A \leq MDD_A$) |
|---------------------|----------------------------------|-------|--|------|------|------|---|----|-----|----|-------------------------------|--------------------------------------|--|
| | Q1 | Q2-Q4 | 1 | 2 | 3 | 4 | 1 | 2 | 3 | 4 | | | |
| M11B | 13.9 | 16.0 | 13.1 | 15.4 | 16.2 | 16.0 | ND | ND | ND | ND | 61.8 | 60.7 | ND |
| M12B | 13.5 | 15.6 | 12.3 | 14.6 | 16.4 | 15.4 | ND | ND | ND | ND | 60.3 | 58.8 | ND |
| M13B | 13.5 | 14.4 | 13.1 | 15.2 | 16.0 | 15.8 | ND | ND | ND | ND | 56.6 | 60.1 | ND |
| M14B | 13.4 | 15.5 | 13.2 | 15.1 | 16.6 | 16.6 | ND | ND | ND | ND | 59.9 | 61.5 | ND |
| M15B | 13.5 | 15.0 | 11.6 | 13.3 | 15.0 | 14.7 | ND | ND | ND | ND | 58.4 | 54.6 | ND |
| M16B | 13.0 | 13.5 | 12.2 | 14.1 | 20.9 | 15.0 | ND | ND | 7.5 | ND | 53.4 | 62.3 | ND |
| M01S | 12.1 | 13.3 | 11.1 | 13.0 | 14.0 | * | ND | ND | ND | * | 51.7 | 50.9 | ND |
| M02S | 11.5 | 12.7 | 11.2 | 12.8 | 14.0 | 13.9 | ND | ND | ND | ND | 49.7 | 52.0 | ND |
| M03S | 13.6 | 15.3 | 12.6 | 14.0 | 15.8 | 15.7 | ND | ND | ND | ND | 59.4 | 58.1 | ND |
| M04S | 14.3 | 15.8 | 12.7 | 14.6 | 16.0 | 15.5 | ND | ND | ND | ND | 61.7 | 58.9 | ND |
| M05S | 14.1 | 15.3 | 12.8 | 14.3 | 16.0 | 14.9 | ND | ND | ND | ND | 60.1 | 58.0 | ND |
| M06S | 15.9 | 16.9 | 11.7 | 14.5 | 16.3 | 16.1 | ND | ND | ND | ND | 66.6 | 58.5 | ND |
| M01C | 14.0 | 14.8 | 11.5 | 12.7 | 14.7 | 14.6 | ND | ND | ND | ND | 58.4 | 53.5 | ND |
| M02C | 14.0 | 15.6 | 11.5 | 12.3 | 13.6 | 13.3 | ND | ND | ND | ND | 60.9 | 50.7 | ND |
| M03C | 15.3 | 16.3 | 12.0 | 13.5 | 15.7 | 14.7 | ND | ND | ND | ND | 64.3 | 55.9 | ND |
| M04C | 14.1 | 14.8 | 11.3 | 13.0 | 14.5 | 14.1 | ND | ND | ND | ND | 58.7 | 52.9 | ND |

MDD_Q = Quarterly Minimum Differential Dose = 4.7 mrem
 MDD_A = Annual Minimum Differential Dose = 11.2 mrem
 ND = Not Detected, where $M_Q \leq (B_Q + MDD_Q)$ or $M_A \leq (B_A + MDD_A)$
 * = TLD was missing in the field.

| | | |
|---|---|----------------------|
| Annual Radiological Environmental Operating Report | YEAR: 2025 | Page 86 of 86 |
| Company: Xcel Energy | Plant: Monticello Nuclear Generating Plant | |

Attachment 5, Laboratory Quality Assurance Reports (Enclosed)

ENVIRONMENTAL DOSIMETRY COMPANY

ANNUAL QUALITY ASSURANCE STATUS REPORT

January - December 2025

Prepared By: Jim Smith Date: 2/24/26

Approved By: Matthew Faulk Date: 2/25/26

**Environmental Dosimetry Company
10 Ashton Lane
Sterling, MA 01564**

TABLE OF CONTENTS

| | <u>Page</u> |
|--|-------------|
| LIST OF TABLES | ii |
| EXECUTIVE SUMMARY | iii |
| I. INTRODUCTION | 1 |
| A. QC Program | 1 |
| B. QA Program | 1 |
| II. PERFORMANCE EVALUATION CRITERIA | 1 |
| A. Acceptance Criteria for Internal Evaluations | 1 |
| B. QC Investigation Criteria and Result Reporting | 3 |
| C. Reporting of Environmental Dosimetry Results to EDC Customers | 3 |
| III. DATA SUMMARY FOR ISSUANCE PERIOD JANUARY-DECEMBER 2025 | 3 |
| A. General Discussion | 3 |
| B. Result Trending | 4 |
| IV. STATUS OF EDC CONDITION REPORTS (CR) | 4 |
| V. STATUS OF AUDITS/ASSESSMENTS | 4 |
| A. Internal | 4 |
| B. External | 4 |
| VI. PROCEDURES AND MANUALS REVISED DURING JANUARY - DECEMBER 2025 ... | 4 |
| VII. CONCLUSION AND RECOMMENDATIONS | 4 |
| VIII. REFERENCES | 4 |

APPENDIX A DOSIMETRY QUALITY CONTROL TRENDING GRAPHS

LIST OF TABLES

| | <u>Page</u> |
|--|-------------|
| 1. Percentage of Individual Analyses Which Passed EDC Internal Criteria, January - December 2025 | 5 |
| 2. Mean Dosimeter Analyses (n=6), January - December 2025 | 5 |
| 3. Summary of Independent QC Results for 2025 | 5 |

EXECUTIVE SUMMARY

Routine quality control (QC) testing was performed for dosimeters issued by the Environmental Dosimetry Company (EDC) .

During this annual period 100% (72/72) of the individual dosimeters, evaluated against the EDC internal performance acceptance criteria (high-energy photons only), met the criterion for accuracy and 100% (72/72) met the criterion for precision (Table 1). In addition, 100% (12/12) of the dosimeter sets evaluated against the internal tolerance limits met EDC acceptance criteria (Table 2) and 100% of independent testing passed the performance criteria (Table 3). Trending graphs, which evaluate performance statistic for high-energy photon irradiations and co-located stations are given in Appendix A.

One internal assessment was performed in 2025. There were no findings.

I. INTRODUCTION

The TLD systems at the Environmental Dosimetry Company (EDC) are calibrated and operated to ensure consistent and accurate evaluation of TLDs. The quality of the dosimetric results reported to EDC clients is ensured by in-house performance testing and independent performance testing by EDC clients, and both internal and client directed program assessments.

The purpose of the dosimetry quality assurance program is to provide performance documentation of the routine processing of EDC dosimeters. Performance testing provides a statistical measure of the bias and precision of dosimetry processing against a reliable standard, which in turn points out any trends or performance changes. Two programs are used:

A. QC Program

Dosimetry quality control tests are performed on EDC Panasonic 814 Environmental dosimeters. These tests include: (1) the in-house testing program coordinated by the EDC QA Officer and (2) independent test perform by EDC clients. In-house test are performed using six pairs of 814 dosimeters, a pair is reported as an individual result and six pairs are reported as the mean result. Results of these tests are described in this report.

Excluded from this report are instrumentation checks. Although instrumentation checks represent an important aspect of the quality assurance program, they are not included as process checks in this report. Instrumentation checks represent between 5-10% of the TLDs processed.

B. QA Program

An internal assessment of dosimetry activities is conducted annually by the Quality Assurance Officer (Reference 1). The purpose of the assessment is to review procedures, results, materials or components to identify opportunities to improve or enhance processes and/or services.

II. PERFORMANCE EVALUATION CRITERIA

A. Acceptance Criteria for Internal Evaluations

1. Bias

For each dosimeter tested, the measure of bias is the percent deviation of the reported result relative to the delivered exposure. The percent deviation relative to the delivered exposure is calculated as follows:

$$\frac{(H'_i - H_i)}{H_i} 100$$

where:

H'_i = the corresponding reported exposure for the i^{th} dosimeter (i.e., the reported exposure)

H_i = the exposure delivered to the i^{th} irradiated dosimeter (i.e., the delivered exposure)

2. Mean Bias

For each group of test dosimeters, the mean bias is the average percent deviation of the reported result relative to the delivered exposure. The mean percent deviation relative to the delivered exposure is calculated as follows:

$$\sum \left(\frac{(H'_i - H_i)}{H_i} \right) 100 \left(\frac{1}{n} \right)$$

where:

H'_i = the corresponding reported exposure for the i^{th} dosimeter (i.e., the reported exposure)

H_i = the exposure delivered to the i^{th} irradiated test dosimeter (i.e., the delivered exposure)

n = the number of dosimeters in the test group

Precision

For a group of test dosimeters irradiated to a given exposure, the measure of precision is the percent deviation of individual results relative to the mean reported exposure. At least two values are required for the determination of precision. The measure of precision for the i^{th} dosimeter is:

$$\left(\frac{(H'_i - \bar{H})}{\bar{H}} \right) 100$$

where:

H'_i = the reported exposure for the i^{th} dosimeter (i.e., the reported exposure)

\bar{H} = the mean reported exposure; i.e., $\bar{H} = \sum H'_i \left(\frac{1}{n} \right)$

n = the number of dosimeters in the test group

3. EDC Internal Tolerance Limits

All evaluation criteria are taken from the "EDC Quality System Manual," (Reference 2). These criteria are only applied to individual test dosimeters irradiated with high-energy photons (Cs-137) and are as follows for Panasonic Environmental dosimeters: $\pm 15\%$ for bias and $\pm 12.8\%$ for precision.

B. QC Investigation Criteria and Result Reporting

EDC Quality System Manual (Reference 2) specifies when an investigation is required due to a QC analysis that has failed the EDC bias criteria. The criteria are as follows:

1. No investigation is necessary when an individual QC result falls outside the QC performance criteria for accuracy.
2. Investigations are initiated when the mean of a QC processing batch is outside the performance criterion for bias.

C. Reporting of Environmental Dosimetry Results to EDC Customers

1. All results are to be reported in a timely fashion.
2. If the QA Officer determines that an investigation is required for a process, the results shall be issued as normal unless if the QC results prompting the investigation have a mean bias from the known of greater than $\pm 20\%$, then the results shall be issued with a note indicating that they may be updated in the future, pending resolution of a QA issue.
3. Environmental dosimetry results do not require updating if the investigation has shown that the mean bias between the original results and the corrected results, based on applicable correction factors from the investigation, does not exceed $\pm 15\%$.

III. DATA SUMMARY FOR ISSUANCE PERIOD JANUARY-DECEMBER 2025

A. General Discussion

Results of performance tests conducted are summarized and discussed in the following sections. Summaries of the performance tests for the reporting period are given in Tables 1 through 3 and Figures 1 through 4.

Table 1 provides a summary of individual dosimeter results evaluated against the EDC internal acceptance criteria for high-energy photons only. During this period 100% (72/72) of the individual dosimeters, evaluated against these criteria, met the tolerance limits for accuracy and 100% (72/72) met the criterion for precision. A graphical interpretation is provided in Figures 1 and 2.

Table 2 provides the bias and standard deviation results for each group (N=6) of dosimeters evaluated against the internal tolerance criteria. Overall, 100% (12/12) of the dosimeter sets, evaluated against the internal tolerance performance criteria, met these criteria. A graphical interpretation is provided in Figure 3.

Table 3 presents the independent blind spike results for dosimeters processed during this annual period. All results passed the performance acceptance criterion. Figure 4 is a graphical interpretation of Seabrook Station blind co-located station results.

B. Result Trending

One of the main benefits of performing quality control tests on a routine basis is to identify trends or performance changes. The results of the Panasonic environmental dosimeter performance tests are presented in Appendix A. The results are evaluated against each of the performance criteria listed in Section II, namely: individual dosimeter accuracy, individual dosimeter precision, and mean bias.

All of the results presented in Appendix A are plotted sequentially by processing date.

IV. STATUS OF EDC CONDITION REPORTS (CR)

No condition reports were issued during this annual period.

V. STATUS OF AUDITS/ASSESSMENTS

1. Internal

EDC Internal Quality Assurance Assessment was conducted during the fourth quarter 2025. There were no findings identified.

2. External

None.

VI. PROCEDURES AND MANUALS REVISED DURING JANUARY - DECEMBER 2025

Manual 1 and several procedures were reissued with no changes as part of the 5 year review cycle.

VII. CONCLUSION AND RECOMMENDATIONS

The quality control evaluations continue to indicate the dosimetry processing programs at the EDC satisfy the criteria specified in the Quality System Manual. The EDC demonstrated the ability to meet all applicable acceptance criteria.

VIII. REFERENCES

1. EDC Quality Control and Audit Assessment Schedule, 2025.
2. EDC Manual 1, Quality System Manual, Rev. 4, September 29, 2025.

TABLE 1

**PERCENTAGE OF INDIVIDUAL DOSIMETERS THAT PASSED EDC INTERNAL CRITERIA
JANUARY – DECEMBER 2025^{(1), (2)}**

| Dosimeter Type | Number Tested | % Passed Bias Criteria | % Passed Precision Criteria |
|-------------------------|---------------|------------------------|-----------------------------|
| Panasonic Environmental | 72 | 100 | 100 |

⁽¹⁾This table summarizes results of tests conducted by EDC.

⁽²⁾Environmental dosimeter results are free in air.

TABLE 2

**MEAN DOSIMETER ANALYSES (N=6)
JANUARY – DECEMBER 2025^{(1), (2)}**

| Process Date | Exposure Level | Mean Bias % | Standard Deviation % | Tolerance Limit +/-15% |
|--------------|----------------|-------------|----------------------|------------------------|
| 4/23/2025 | 35 | -2.6 | 1.5 | Pass |
| 4/29/2025 | 53 | 1.5 | 1.2 | Pass |
| 5/13/2025 | 77 | 2.6 | 1.9 | Pass |
| 7/21/2025 | 26 | 0.2 | 0.8 | Pass |
| 7/26/2025 | 107 | -2.1 | 1.3 | Pass |
| 7/28/2025 | 43 | -0.2 | 1.2 | Pass |
| 10/22/2025 | 38 | 1.7 | 1.0 | Pass |
| 10/27/2025 | 88 | 0.9 | 2.1 | Pass |
| 11/26/2025 | 119 | 2.9 | 1.0 | Pass |
| 01/24/2026 | 65 | -0.3 | 1.3 | Pass |
| 01/27/2026 | 96 | -0.3 | 1.2 | Pass |
| 02/22/2026 | 47 | -3.3 | 2.3 | Pass |

⁽¹⁾This table summarizes results of tests conducted by EDC for TLDs issued in 2025.

⁽²⁾Environmental dosimeter results are free in air.

**TABLE 3
SUMMARY OF INDEPENDENT DOSIMETER TESTING
JANUARY – DECEMBER 2025^{(1), (2)}**


| Issuance Period | Client | Mean Bias % | Standard Deviation % | Pass / Fail |
|---------------------------|-----------|-------------|----------------------|-------------|
| 1 st Qtr. 2025 | Millstone | 1.5 | 1.4 | Pass |
| 2 nd Qtr. 2025 | Seabrook | 7.3 | 1.0 | Pass |
| 2 nd Qtr. 2025 | Millstone | 2.8 | 1.1 | Pass |
| 3 rd Qtr. 2025 | SONGS | -4.4 | 2.4 | Pass |
| 3 rd Qtr. 2025 | Millstone | 8.6 | 3.5 | Pass |
| 4 th Qtr. 2025 | Millstone | 3.3 | 3.5 | Pass |

⁽¹⁾Performance criteria are +/- 15%.


⁽²⁾Blind spike irradiations using Cs-137

APPENDIX A
DOSIMETRY QUALITY CONTROL TRENDING GRAPHS
ISSUE PERIOD JANUARY - DECEMBER 2025


INDIVIDUAL ACCURACY ENVIRONMENTAL
FIGURE 1




INDIVIDUAL PRECISION ENVIRONMENTAL
FIGURE 2



MEAN ACCURACY ENVIRONMENTAL
FIGURE 3



SEABROOK CO-LOCATE ACCURACY
FIGURE 4





2025 ANNUAL QUALITY ASSURANCE REPORT

FOR THE

**RADIOLOGICAL ENVIRONMENTAL
MONITORING PROGRAM (REMP)**

2025 ANNUAL QUALITY ASSURANCE REPORT
FOR THE
RADIOLOGICAL ENVIRONMENTAL
MONITORING PROGRAM (REMP)



Approved By

Angela A. Johnson
Director, Quality Systems

March 12, 2025

Date

TABLE OF CONTENTS

| | |
|--|----|
| 1. INTRODUCTION | 5 |
| 2. QUALITY ASSURANCE PROGRAMS FOR INTER-LABORATORY, INTRA-LABORATORY AND THIRD PARTY CROSS-CHECK | 5 |
| 3. QUALITY ASSURANCE PROGRAM FOR INTERNAL AND EXTERNAL AUDITS | 7 |
| 4. PERFORMANCE EVALUATION ACCEPTANCE CRITERIA FOR ENVIRONMENTAL SAMPLE ANALYSIS | 7 |
| 5. PERFORMANCE EVALUATION SAMPLES | 7 |
| 6. QUALITY CONTROL PROGRAM FOR ENVIRONMENTAL SAMPLE ANALYSIS | 8 |
| 7. SUMMARY OF DATA RESULTS | 9 |
| 8. SUMMARY OF PARTICIPATION IN THE ECKERT & ZIEGLER ANALYTICS ENVIRONMENTAL CROSS-CHECK PROGRAM | 9 |
| 9. SUMMARY OF PARTICIPATION IN THE MAPEP MONITORING PROGRAM | 9 |
| 10. SUMMARY OF PARTICIPATION IN THE ERA MRAD PT PROGRAM | 9 |
| 11. SUMMARY OF PARTICIPATION IN THE ERA PT PROGRAM | 9 |
| 12. CORRECTIVE ACTION REQUEST AND REPORT (CARR) | 9 |
| 13. REFERENCES | 11 |

TABLES

| | | |
|------------|--|----|
| TABLES 1-5 | RADIOLOGICAL PROFICIENCY TESTING RESULTS | 12 |
| TABLES 6-7 | INTRA-LABORATORY DATA SUMMARIES | 52 |
| TABLE 8 | CORRECTIVE ACTIONS | 69 |

TABLE OF CONTENTS (CONTINUED)

FIGURES

Figure 1 Cobalt-60 Performance Evaluation Results and % Bias 43

Figure 2 Cesium-137 Performance Evaluation Results and % Bias 44

Figure 3 Tritium Performance Evaluation Results and % Bias 45

Figure 4 Strontium-90 Performance Evaluation Results and % Bias 46

Figure 5 Gross Alpha Performance Evaluation Results and % Bias 47

Figure 6 Gross Beta Performance Evaluation Results and % Bias 48

Figure 7 Iodine-131 Performance Evaluation Results and % Bias 49

Figure 8 Americium-241 Performance Evaluation Results and % Bias 50

Figure 9 Plutonium-238 Performance Evaluation Results and % Bias 51

2025 ANNUAL QUALITY ASSURANCE REPORT FOR THE RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (REMP)

1. Introduction

GEL Laboratories, LLC (GEL) is a privately owned environmental laboratory dedicated to providing personalized client services of the highest quality. GEL was established as an analytical testing laboratory in 1981. Now a full-service lab, our analytical divisions use state of the art equipment and methods to provide a comprehensive array of organic, inorganic, and radiochemical analyses to meet the needs of our clients.

At GEL, quality is emphasized at every level of personnel throughout the company. Management's ongoing commitment to good professional practice and to the quality of our testing services to our customers is demonstrated by their dedication to personnel and resources to develop, implement, assess, and improve our technical and management operations.

The purpose of GEL's quality assurance program is to establish policies, procedures, and processes to meet or exceed the expectations of our clients. To achieve this, all personnel that support these services to our clients are introduced to the program and policies during their initial orientation, and annually thereafter during company-wide training sessions.

GEL's primary goals are to ensure that all measurement data generated are scientifically and legally defensible, of known and acceptable quality per the data quality objectives (DQOs) and thoroughly documented to provide sound support for environmental decisions. In addition, GEL continues to ensure compliance with all contractual requirements, environmental standards, and regulations established by local, state, and federal authorities.

GEL administers the QA program in accordance with the Quality Assurance Plan, GL-QS-B-001. Our Quality Systems include all quality assurance (QA) policies and quality control (QC) procedures necessary to plan, implement, and assess the work we perform. GEL's QA Program establishes a quality management system (QMS) that governs all of the activities of our organization.

This report entails the quality assurance program for the proficiency testing and environmental monitoring aspects of GEL for 2025. GEL's QA Program is designed to monitor the quality of analytical processing associated with environmental, radiobioassay, effluent (10 CFR Part 50), and waste (10 CFR Part 61) sample analysis.

This report covers the category of Radiological Environmental Monitoring Program (REMP) and includes:

- Intra-laboratory QC results analyzed during 2025.
- Inter-laboratory QC results analyzed during 2025 where known values are available.

2. Quality Assurance Programs for Inter-laboratory, Intra-laboratory and Third Party Cross-Check

In addition to internal and client audits, our laboratory participates in annual performance evaluation studies conducted by independent providers. We routinely participate in the following types of performance audits:

- Proficiency testing and other inter-laboratory comparisons
- Performance requirements necessary to retain certifications

- Evaluation of recoveries of certified reference and in-house secondary reference materials using statistical process control data.
- Evaluation of relative percent difference between measurements through SPC data.

We also participate in a number of proficiency testing programs for federal and state agencies and as required by contracts. It is our policy that no proficiency evaluation samples be analyzed in any special manner. Our annual performance evaluation participation generally includes a combination of studies that support the following:

- US Environmental Protection Agency Discharge Monitoring Report, Quality Assurance Program (DMR-QA). Annual national program sponsored by EPA for laboratories engaged in the analysis of samples associated with the NPDES monitoring program. Participation is mandatory for all holders of NPDES permits. The permit holder must analyze for all of the parameters listed on the discharge permit. Parameters include general chemistry, metals, BOD/COD, oil and grease, ammonia, nitrates, etc.
- Department of Energy Mixed Analyte Performance Evaluation Program (MAPEP). A semiannual program developed by DOE in support of DOE contractors performing waste analyses. Participation is required for all laboratories that perform environmental analytical measurements in support of environmental management activities. This program includes radioactive isotopes in water, soil, vegetation and air filters.
- ERA's MRAD-Multimedia Radiochemistry Proficiency test program. This program is for labs seeking certification for radionuclides in wastewater and solid waste. The program is conducted in strict compliance with USEPA National Standards for Water Proficiency study.
- ERA's InterLaB RadChem Proficiency Testing Program for radiological analyses. This program completes the process of replacing the USEPA EMSL-LV Nuclear Radiation Assessment Division program discontinued in 1998. Laboratories seeking certification for radionuclide analysis in drinking water also use the study. This program is conducted in strict compliance with the USEPA National Standards for Water Proficiency Testing Studies. This program encompasses Uranium by EPA method 200.8 (for drinking water certification in Utah/Primary NELAP), gamma emitters, Gross Alpha/Beta, Iodine-131, naturally occurring radioactive isotopes, Strontium-89/90, and Tritium.
- ERA's Water Pollution (WP) biannual program for waste methodologies includes parameters for both organic and inorganic analytes.
- ERA's Water Supply (WS) biannual program for drinking water methodologies includes parameters for organic and inorganic analytes.
- Environmental Cross-Check Program administered by Eckert & Ziegler Analytics, Inc. This program encompasses radionuclides in water, soil, milk, naturally occurring radioactive isotopes in soil and air filters.

GEL procures single-blind performance evaluation samples from Eckert & Ziegler Analytics to verify the analysis of sample matrices processed at GEL. GEL's Third-Party Cross-Check Program provides environmental matrices encountered in a typical nuclear utility REMP. The Third-Party Cross-Check Program is intended to meet or exceed the inter-laboratory comparison program requirements discussed in NRC Regulatory Guide 4.15. Once performance evaluation samples have been prepared in accordance with the instructions provided by the PT provider, samples are managed and analyzed in the same manner as environmental samples from GEL's clients.

3. Quality Assurance Program for Internal and External Audits

During each annual reporting period, at least one internal assessment of each area of the laboratory is conducted in accordance with the pre-established schedule from Standard Operating Procedure for the Conduct of Quality Audits, GL-QS-E-001. The annual internal audit plan is reviewed for adequacy and includes the scheduled frequency and scope of quality control actions necessary for GEL's QA program. Internal audits are conducted at least annually in accordance with a schedule approved by the Quality Systems Director. Supplier audits are contingent upon the categorization of the supplies and may or may not be conducted prior to the use of a supplier or subcontractor. Type I suppliers and subcontractors, regardless of how they were initially qualified, are re-evaluated at least once every three years.

In addition, prospective customers audit GEL during pre-contract audits. GEL hosts several external audits each year for both our clients and other programs. These programs include environmental monitoring, waste characterization, and radiobioassay. The following list of programs may audit GEL at least annually or up to every three years depending on the program.

- TNI, The NELAC Institute, National Environmental Laboratory Accreditation Program
- DOECAP, U.S. Department of Energy Consolidated Audit Program
- DOELAP, U.S. Department of Energy Laboratory Accreditation Program
- DOE QSAS, U.S. Department of Energy, Quality Systems for Analytical Services
- ISO/IEC 17025:2017
- A2LA, American Association for Laboratory Accreditation
- DoD ELAP, US Department of Defense Environmental Accreditation Program
- NUPIC, Nuclear Procurement Issues Committee
- South Carolina Department of Environmental Services (SC DES)

The annual radiochemistry laboratory internal audit (25-RAD-001) was conducted in September of 2025. There were no findings, two observations and no recommendations for improvement from this assessment.

4. Performance Evaluation Acceptance Criteria for Environmental Sample Analysis

GEL utilized an acceptance protocol based upon two performance models. For those inter-laboratory programs that already have established performance criteria for bias (i.e., MAPEP, and ERA/ELAP), GEL will utilize the criteria for the specific program. For intra-laboratory or third-party quality control programs that do not have a specific acceptance criteria (i.e. the Eckert-Ziegler Analytics Environmental Cross-check Program), results will be evaluated in accordance with GEL's internal acceptance criteria.

5. Performance Evaluation Samples

Performance Evaluation (PE) results and internal quality control sample results are evaluated in accordance with GEL acceptance criteria. The first criterion concerns bias, which is defined as the deviation of any one result from the known value. The second criterion concerns precision, which deals with the ability of the measurement to be replicated by comparison of an individual result with the mean of all results for a given sample set.

At GEL, we also evaluate our analytical performance on a regular basis through statistical process control (SPC) acceptance criteria. Where feasible, this criterion is applied to both measures of precision and accuracy and is specific to sample matrix. We establish environmental process control limits at least annually.

For Radiochemistry analysis, quality control evaluation is based on static limits rather than those that are statistically derived. Our current process control limits are maintained in

GEL's LIMS. We also measure precision with matrix duplicates and/or matrix spike duplicates. The upper and lower control limits (UCL and LCL respectively) for precision are plus or minus three times the standard deviation from the mean of a series of relative percent differences. The static precision criteria for radiochemical analyses are 0 - 20%, for activity levels exceeding the contract required detection limit (CRDL).

6. Quality Control Program for Environmental Sample Analysis

GEL's internal QA Program is designed to include QC functions such as instrumentation calibration checks (to insure proper instrument response), blank samples, instrumentation backgrounds, duplicates, as well as overall staff qualification analyses and statistical process controls. Both quality control and qualification analyses samples are used to be as similar as the matrix type of those samples submitted for analysis by the various laboratory clients. These performance test samples (or performance evaluation samples) are either actual sample submitted in duplicate in order to evaluate the precision of laboratory measurements, or fortified blank samples, which have been given a known quantity of a radioisotope that is in the interest to GEL's clients.

Accuracy (or Bias) is measured through laboratory control samples and/or matrix spikes, as well as surrogates and internal standards. The UCLs and LCLs for accuracy are plus or minus three times the standard deviation from the mean of a series of recoveries. The static limit for most radiochemical analyses is 75 - 125%. Specific instructions for out-of-control situations are provided in the applicable analytical SOP.

GEL's Laboratory Control Standard (LCS) is an aliquot of reagent water or other blank matrix to which known quantities of the method analytes are added in the laboratory. The LCS is analyzed exactly like a sample, and its purpose is to determine whether the methodology is in control, and whether the laboratory is capable of making accurate and precise measurements. Some methods may refer to these samples as Laboratory Fortified Blanks (LFB). The requirement for recovery is between 75% and 125% for radiological analyses excluding drinking water matrix.

$$\text{Bias (\%)} = \frac{(\text{observed concentration})}{(\text{known concentration})} * 100 \%$$

Precision is a data quality indicator of the agreement between measurements of the same property, obtained under similar conditions, and how well they conform to themselves. Precision is usually expressed as standard deviation, variance or range in either absolute or relative (percentage) terms.

GEL's laboratory duplicate (DUP or LCSD) is an aliquot of a sample taken from the same container and processed in the same manner under identical laboratory conditions. The aliquot is analyzed independently from the parent sample and the results are compared to measure precision and accuracy.

If a sample duplicate is analyzed, it will be reported as Relative Percent Difference (RPD). The RPD must be 20 percent or less, if both samples are greater than 5 times the MDC. If both results are less than 5 times MDC, then the RPD must be equal to or less than 100%. If one result is above the MDC and the other is below the MDC, then the RPD can be calculated using the MDC for the result of the one below the MDC. The RPD must be 100% or less. In the situation where both results are above the MDC but one result is greater than 5 times the MDC and the other is less than 5 times the MDC, the RPD must be less than or equal to 20%. If both results are below MDC, then the limits on % RPD are not applicable.

$$\text{Difference (\%)} = \frac{(\text{high duplicate result} - \text{low duplicate result})}{(\text{average of results})} * 100 \%$$

7. Summary of Data Results

During 2025, forty-one (41) radioisotopes associated with six (6) matrix types were analyzed under GEL's Performance Evaluation program in participation with ERA, MAPEP, and Eckert & Ziegler Analytics. Matrix types were representative of client analyses performed during 2025. Of the three hundred sixty-nine (369) total results, 97% (358 out of 369) were found to be acceptable within the PT providers three sigma or other statistical criteria. The list below contains the type of matrix evaluated by GEL.

- Air Filter
- Cartridge
- Water
- Milk
- Soil
- Vegetation

Graphs are provided in Figures 1-9 of this report to allow for the evaluation of trends or biases. These graphs include radioisotopes Cobalt-60, Cesium-137, Tritium, Strontium-90, Gross Alpha, Gross Beta, Iodine-131, Americium-241, and Plutonium-238.

8. Summary of Participation in the Eckert & Ziegler Analytics Environmental Cross-Check Program

Eckert & Ziegler Analytics provided samples for forty-six (46) individual environmental analyses. The accuracy of each result reported to Eckert & Ziegler Analytics, Inc. is measured by the ratio of GEL's result to the known value. Of the 46 analyses reported, 95.7% (44 out of 46) fell within the acceptance criteria.

9. Summary of Participation in the MAPEP Monitoring Program

MAPEP Series 52 and Series 53 were analyzed by the laboratory. Of the one hundred thirty-nine (139) analyses reported, 97.1% (135 out of 139) fell within the PT provider's acceptance criteria.

10. Summary of Participation in the ERA MRAD PT Program

The ERA MRAD program provided samples (MRAD-42 and MRAD-43) for one hundred forty-eight (148) individual environmental analyses reported. Of the 148 analyses reported, 98.6% (146 of the 148) fell within the PT provider's acceptance criteria.

11. Summary of Participation in the ERA PT Program

The ERA program provided samples (RAD-140, RAD-142, and RAD-143) for thirty-six (36) individual environmental analyses. Of the 36 analyses reported, 91.7% (33 of 36) fell within the PT provider's acceptance criteria.

12. Corrective Action Request and Report (CARR)

There are two categories of corrective action at GEL. One is corrective action implemented at the analytical and data review level in accordance with the analytical SOP. The other is formal corrective action documented by the Quality Systems Team in accordance with GL-QS-E-002. A formal corrective action is initiated when a nonconformance reoccurs or is so significant that permanent elimination or prevention of the problem is required. Formal corrective action investigations include root cause analysis.

GEL includes quality requirements in most analytical standard operating procedures to ensure that data are reported only if the quality control criteria are met or the quality control

measures that did not meet the acceptance criteria are documented. A formal corrective action is implemented according to GL-QS-E-002 for Conducting Corrective/Preventive Action and Identifying Opportunities for Improvement. Recording and documentation is performed following guidelines stated in GL-QS-E-012 for Client NCR Database Operation.

Any employee at GEL can identify and report a nonconformance and request that corrective action be taken. Any GEL employee can participate on a corrective action team as requested by the QS team or Group Leaders. The steps for conducting corrective action are detailed in GL-QS-E-002. In the event that correctness or validity of the laboratory's test results in doubt, the laboratory will take corrective action. If investigations show that the results have been impacted, affected clients will be informed of the issue in writing within five (5) calendar days of the discovery.

Table 8 provides the status of CARRs for radiological performance testing during 2025. **It has been determined that the causes of the unacceptable results did not impact any data reported to our clients.**

13. References

1. GEL Quality Assurance Plan, GL-QS-B-001
2. GEL Standard Operating Procedure for the Conduct of Quality Audits, GL-QS-E-001
3. GEL Standard Operating Procedure for Conducting Corrective/Preventive Action and Identifying Opportunities for Improvement, GL-QS-E-002
4. GEL Standard Operating Procedure for LIMS Documentation of Nonconformance Reporting and Dispositioning and Control of Nonconforming Items, GL-QS-E-004
5. GEL Standard Operating Procedure for Handling Proficiency Evaluation Samples, GL-QS-E-013
6. GEL Standard Operating Procedure for Quality Assurance Measurement Calculations and Processes, GL-QS-E-014
7. 40 CFR Part 136 Guidelines Establishing Test Procedures for the Analysis of Pollutants
8. ISO/IEC 17025-2017, General Requirements for the Competence of Testing and Calibration Laboratories
9. ANSI/ASQC E4-1994, Specifications and Guidelines for Quality Systems for Environmental Data Collection and Environmental Technology Programs, American National Standard
10. 2016 TNI Standard, The NELAC Institute, National Environmental Accreditation Program
11. MARLAP, Multi-Agency Radiological Laboratory Analytical Protocols
12. 10 CFR Part 21, Reporting of Defects and Noncompliance
13. 10 CFR Part 50 Appendix B, Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants
14. 10 CFR Part 61, Licensing Requirements for Land Disposal and Radioactive Waste
15. NRC REG Guide 4.15 and NRC REG Guide 4.8

TABLE 1
2025 RADIOLOGICAL PROFICIENCY TESTING RESULTS AND ACCEPTANCE CRITERIA

| PT Provider | Quarter / Year | Report Closing / Received Date | Sample Number | Sample Media | Units | Analyte | Reported Value | Assigned Value | Acceptance Limits | Performance Evaluation |
|-------------|----------------|--------------------------------|---------------|--------------|--------|----------------|----------------|----------------|-------------------|------------------------|
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Barium-133 | 103 | 89.7 | 71.5 - 108 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Cesium-134 | 39.9 | 38.4 | 25.4 - 51.4 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Cesium-137 | 162 | 157 | 123 - 191 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Cobalt-60 | 75.8 | 66.8 | 50.9 - 82.7 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Zinc-65 | 78.7 | 74.3 | 39.3 - 109 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Gross Alpha | 77.3 | 72.2 | 55.3 - 89.1 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Gross Beta | 54.9 | 59.2 | 44.1 - 74.3 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Uranium (Nat) | 63.1 | 63.6 | 56.6 - 70.6 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | µg/L | Uranium (mass) | 85.7 | 92.7 | 82.5 - 103 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Tritium | 9760 | 11400 | 9340 - 13500 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Strontium-89 | 65 | 57.4 | 42.5 - 72.3 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Strontium-90 | 36.8 | 42.6 | 36.5 - 48.7 | Acceptable |
| ERA | 1st/2025 | 3/3/2025 | RAD-140 | Water | pCi/L | Iodine-131 | 31.8 | 28.1 | 24.4 - 31.8 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Actinium-228 | 1140 | 1150 | 759-1450 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Americium-241 | 986 | 1060 | 572-1710 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Bismuth-212 | 1160 | 1150 | 329-1710 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Bismuth-214 | 514 | 634 | 304-943 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Cesium-134 | 5860 | 6520 | 4460-7790 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Cesium-137 | 4170 | 4420 | 3340-5590 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Cobalt-60 | 3160 | 3260 | 2570-4020 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Lead-212 | 1200 | 1150 | 802-1450 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Lead-214 | 661 | 634 | 266-997 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Manganese-54 | <37.1 | <555 | 0-555 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Plutonium-238 | 1000 | 1070 | 534-1630 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Plutonium-239 | 1070 | 1150 | 627-1650 | Acceptable |

| | | | | | | | | | | |
|-----|----------|-----------|---------|--------|------------|----------------|-------|-------|-------------|----------------|
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Potassium-40 | 33600 | 34100 | 23500-40700 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Strontium-90 | 3990 | 6710 | 1780-8890 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Thorium-234 | 3640 | 3470 | 1310-5940 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Uranium-234 | 3320 | 3500 | 1640-4690 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Uranium-238 | 3190 | 3470 | 1900-4660 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Uranium-Total | 6650 | 7120 | 3950-9210 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | µg/kg | Uranium (mass) | 9540 | 10400 | 4690-14000 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Zinc-65 | 1330 | 1240 | 990-1690 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Americium-241 | 72.6 | 67.7 | 48.3-90.3 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Cesium-134 | 224 | 232 | 151-284 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Cesium-137 | 468 | 451 | 370-592 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Cobalt-60 | 278 | 250 | 212-318 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Iron-55 | 216 | 181 | 66.1-289 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Manganese-54 | <3.45 | <35.0 | 0-35 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Plutonium-238 | 39 | 40.2 | 30.4-49.4 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Plutonium-239 | 64.6 | 62.3 | 46.6-75.2 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Strontium-90 | 19.7 | 24.6 | 15.6-33.5 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Uranium-234 | 32.7 | 34.2 | 25.4-40.1 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Uranium-238 | 32.8 | 33.9 | 25.6-40.4 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Uranium-Total | 67.2 | 69.7 | 50.9-82.7 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | µg/Filter | Uranium (mass) | 98.4 | 102 | 81.9-119 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Zinc-65 | 702 | 632 | 518-966 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Gross Alpha | 43.8 | 39.5 | 20.6-65.1 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Gross Beta | 57.5 | 55.2 | 33.5-83.4 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Tritium | 6450 | 9420 | 7100-11500 | Not Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Americium-241 | 45.5 | 39.5 | 27.1-50.5 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Cesium-134 | 1530 | 1600 | 1210-1760 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Cesium-137 | 1130 | 1080 | 925-1230 | Acceptable |

| | | | | | | | | | | |
|-----|----------|-----------|---------|-------|--------|----------------|-------|-------|-------------|------------|
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Cobalt-60 | 276 | 255 | 220-293 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Iron-55 | 1740 | 1460 | 858-2120 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Manganese-54 | <3.16 | <71.0 | 0-71 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Plutonium-238 | 69.4 | 77.2 | 46.4-100 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Plutonium-239 | 54.8 | 58.4 | 36.1-72.0 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Strontium-90 | 556 | 626 | 451-774 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Uranium-234 | 90.8 | 98.2 | 74.8-112 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Uranium-238 | 97.6 | 97.4 | 75.5-115 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Uranium-Total | 193 | 200 | 156-228 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | µg/L | Uranium (mass) | 292 | 292 | 237-331 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Zinc-65 | 258 | 231 | 206-292 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Gross Alpha | 71.8 | 77.3 | 28.2-107 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Gross Beta | 103 | 99.4 | 49.7-137 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Americium-241 | 1640 | 1800 | 1110-2540 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Cesium-134 | 1700 | 1880 | 1250-2500 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Cesium-137 | 627 | 572 | 440-700 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Cobalt-60 | 1800 | 1720 | 1350-2250 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Curium-244 | 719 | 860 | 485-1070 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Manganese-54 | <34.7 | <207 | 0-207 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Plutonium-238 | 3210 | 3750 | 2600-4840 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Plutonium-239 | 4170 | 4590 | 3170-5810 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Potassium-40 | 31200 | 28500 | 21400-36100 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Strontium-90 | 2000 | 2360 | 1330-3080 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Uranium-234 | 3580 | 3960 | 2780-5050 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Uranium-238 | 3700 | 3930 | 2780-4920 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Uranium-Total | 7510 | 8080 | 5160-10900 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | µg/kg | Uranium (mass) | 11100 | 11800 | 9060-14600 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Zinc-65 | 825 | 741 | 553-1100 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|-------|--------|----------------|-------|-------|-------------|----------------|
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Barium-133 | 36.1 | 30.1 | 17.9-42.3 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Cesium-134 | 60.9 | 65.6 | 49.8-81.4 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Cesium-137 | 166 | 152 | 118-186 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Cobalt-60 | 133 | 113 | 92.6-134 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Zinc-65 | 83.5 | 80.6 | 44.9-116 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Gross Alpha | 28.8 | 33.8 | 24.6-43.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Gross Alpha | 27.6 | 33.8 | 24.6-43.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Gross Beta | 45.7 | 41.7 | 24.6-43.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Radium-226 | 14 | 14.4 | 12.0-16.8 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Radium-228 | 4.4 | 4.76 | 2.99-6.53 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Radium-228 | 5.33 | 4.76 | 2.99-6.53 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Uranium (Nat) | 65.9 | 68.1 | 60.8-75.6 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | µg/L | Uranium (mass) | 91.76 | 99.5 | 88.6-110 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Tritium | 14500 | 15800 | 13300-18300 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Tritium | 15000 | 15800 | 13300-18300 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-89 | 51.2 | 45.3 | 31.6-59.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-89 | 47.3 | 45.3 | 31.6-59.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-90 | 30.5 | 34.3 | 29.0-39.6 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-90 | 26.5 | 34.3 | 29.0-39.6 | Not Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Iodine-131 | 22.8 | 28.3 | 24.5-32.1 | Not Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Actinium-228 | 112 | 1150 | 759-1450 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Americium-241 | 1400 | 1550 | 837-2190 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Bismuth-212 | 1260 | 1150 | 329-1710 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Bismuth-214 | 2010 | 2880 | 1380-4290 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Cesium-134 | 2900 | 3340 | 2280-3990 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Cesium-137 | 6950 | 7190 | 5440-9090 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Cobalt-60 | 1170 | 1190 | 937-1470 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Lead-212 | 1350 | 1150 | 802-1450 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|------|--------|----------------|-------|-------|-------------|------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Lead-214 | 2630 | 3020 | 1270-4760 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Manganese-54 | <20.4 | <555 | 0.0-555 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Plutonium-238 | 831 | 845 | 421-1280 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Plutonium-239 | 1550 | 1300 | 708-1870 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Potassium-40 | 32500 | 34100 | 23500-40700 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Strontium-90 | 6510 | 9490 | 2950--14800 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Thorium-234 | 3850 | 4200 | 1590-7190 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-234 | 4350 | 4240 | 1990-5560 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-234 | 3890 | 4240 | 1990-5560 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-238 | 4380 | 4200 | 2300-5640 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-238 | 4050 | 4200 | 2300-5640 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-Total | 8942 | 8630 | 4790-11200 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-Total | 8160 | 8630 | 4790-11200 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | µg/kg | Uranium (mass) | 13100 | 12600 | 5690-17000 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | µg/kg | Uranium (mass) | 12200 | 12600 | 5690-17000 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Zinc-65 | 3680 | 3820 | 3050-5210 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Americium-241 | 3290 | 3510 | 2170-4960 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Cesium-134 | 1700 | 2040 | 1350-2720 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Cesium-137 | 2010 | 2190 | 1680-2950 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Cobalt-60 | 1990 | 1940 | 1520-2540 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Curium-244 | 2040 | 2130 | 1200-2650 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Manganese-54 | <30.7 | <207 | 0.0-207 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Plutonium-238 | 1140 | 1120 | 776-1440 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Plutonium-239 | 3880 | 3550 | 2450-4490 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Potassium-40 | 27800 | 28500 | 21400-36100 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Strontium-90 | 4200 | 5330 | 3000-6950 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Uranium-234 | 3070 | 3230 | 2270-4120 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Uranium-238 | 3290 | 3210 | 2270-4010 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|--------|------------|----------------|------|-------|------------|----------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Uranium-Total | 6580 | 6590 | 4210-8880 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | µg/kg | Uranium (mass) | 9880 | 9610 | 7380-11900 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Zinc-65 | 2070 | 1940 | 1450-2880 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Americium-241 | 38.7 | 39.8 | 28.4-53.1 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Cesium-134 | 304 | 341 | 221-418 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Cesium-137 | 383 | 379 | 311-497 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Cobalt-60 | 349 | 322 | 274-409 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Iron-55 | 189 | 166 | 60.6-265 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Manganese-54 | <2.5 | <35.0 | 0.0-35.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Plutonium-238 | 20 | 18.4 | 13.9-22.6 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Plutonium-239 | 35.6 | 31.3 | 23.4-37.8 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Strontium-90 | 161 | 158 | 99.9-215 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-234 | 60.2 | 63.4 | 47.0-74.3 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-234 | 59.6 | 63.4 | 47.0-74.3 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-238 | 67.8 | 62.9 | 47.5-75.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-238 | 63.1 | 62.9 | 47.5-75.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-Total | 131 | 129 | 94.2-153 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-Total | 127 | 129 | 94.2-153 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | µg/Filter | Uranium (mass) | 203 | 188 | 151-220 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | µg/Filter | Uranium (mass) | 189 | 188 | 151-220 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Zinc-65 | 219 | 193 | 158-295 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Gross Alpha | 37.5 | 22 | 11.5-36.2 | Not Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Gross Beta | 42.3 | 40.5 | 24.6-61.2 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Americium-241 | 73.9 | 68.6 | 47.1-87.7 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Cesium-134 | 720 | 765 | 578-842 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Cesium-137 | 1690 | 1670 | 1790-2390 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Cobalt-60 | 2170 | 2080 | 1790-2390 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Iron-55 | 455 | 399 | 234-580 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|-----------|-------|----------------|----------|----------|-------------|----------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Manganese-54 | <5.37 | <71.0 | 0.0-71.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Plutonium-238 | 106 | 115 | 69.1-149 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Plutonium-239 | 40.4 | 39.8 | 24.6-49.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Strontium-90 | 790 | 699 | 503-864 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-234 | 129 | 133 | 101-152 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-234 | 140 | 133 | 101-152 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-238 | 132 | 132 | 102-155 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-238 | 132 | 132 | 102-155 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-Total | 270 | 271 | 211-309 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-Total | 278 | 271 | 211-309 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | µg/L | Uranium (mass) | 395 | 395 | 320-448 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | µg/L | Uranium (mass) | 397 | 395 | 320-448 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Zinc-65 | 512 | 463 | 412-584 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Gross Alpha | 99.8 | 136 | 49.6-188 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Gross Beta | 194 | 188 | 94.0-259 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Tritium | 27500 | 28300 | 21300-34400 | Acceptable |
| ERA | 4th/2025 | 12/12/25 | RAD-143 | Water | pCi/L | Iodine-131 | 22.9 | 24.3 | 20.9-27.7 | Acceptable |
| ERA | 4th/2025 | 12/12/25 | RAD-143 | Water | pCi/L | Strontium-89 | 63 | 64.2 | 48.6-79.8 | Acceptable |
| ERA | 4th/2025 | 12/12/25 | RAD-143 | Water | pCi/L | Strontium-90 | 35.7 | 43.8 | 37.6-50.0 | Not Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14302 | Cartridge | pCi | Iodine-131 | 6.64E+01 | 6.61E+01 | 1 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14303 | Milk | pCi/L | Strontium-89 | 9.67E+01 | 9.19E+01 | 1.05 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14303 | Milk | pCi/L | Strontium-90 | 9.00E+00 | 1.56E+01 | 0.58 | Not Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Cerium-141 | 7.85E+01 | 7.58E+01 | 1.04 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Cobalt-58 | 1.06E+02 | 1.06E+02 | 1.01 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Cobalt-60 | 1.99E+02 | 1.93E+02 | 1.03 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Chromium-51 | 2.83E+02 | 2.91E+02 | 0.97 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Cesium-134 | 1.28E+02 | 1.42E+02 | 0.90 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Cesium-137 | 1.72E+02 | 1.68E+02 | 1.03 | Acceptable |

| | | | | | | | | | | |
|-----|----------|---------|--------|-----------|-------|--------------|----------|----------|------|----------------|
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Iron-59 | 1.53E+02 | 1.35E+02 | 1.14 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Iodine-131 | 1.02E+02 | 9.47E+01 | 1.08 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Manganese-54 | 2.09E+02 | 1.89E+02 | 1.11 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14304 | Milk | pCi/L | Zinc-65 | 2.87E+02 | 2.51E+02 | 1.15 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Cerium-141 | 8.94E+01 | 7.57E+01 | 1.18 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Cobalt-58 | 1.09E+02 | 1.05E+02 | 1.04 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Cobalt-60 | 2.00E+02 | 1.93E+02 | 1.04 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Chromium-51 | 3.07E+02 | 2.91E+02 | 1.06 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Cesium-134 | 1.26E+02 | 1.42E+02 | 0.89 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Cesium-137 | 1.76E+02 | 1.68E+02 | 1.05 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Iron-59 | 1.58E+02 | 1.35E+02 | 1.17 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Iodine-131 | 7.86E+01 | 7.60E+01 | 1.03 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Manganese-54 | 2.07E+02 | 1.89E+02 | 1.10 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E14305 | Water | pCi/L | Zinc-65 | 2.77E+02 | 2.50E+02 | 1.11 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14410 | Cartridge | pCi | Iodine-131 | 8.28E+01 | 8.88E+01 | 0.93 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14411 | Milk | pCi/L | Strontium-89 | 1.19E+02 | 8.49E+01 | 1.40 | Not Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14411 | Milk | pCi/L | Strontium-90 | 1.53E+01 | 1.56E+01 | 0.98 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Cerium-141 | 1.50E+02 | 1.43E+02 | 1.05 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Cobalt-58 | 1.75E+02 | 1.69E+02 | 1.03 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Cobalt-60 | 2.24E+02 | 2.17E+02 | 1.03 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Chromium-51 | 3.36E+02 | 2.99E+02 | 1.12 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Cesium-134 | 1.28E+02 | 1.39E+02 | 0.92 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Cesium-137 | 1.75E+02 | 1.68E+02 | 1.04 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Iron-59 | 1.57E+02 | 1.34E+02 | 1.17 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Iodine-131 | 9.80E+01 | 8.60E+01 | 1.14 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Manganese-54 | 1.98E+02 | 1.87E+02 | 1.06 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14412 | Milk | pCi/L | Zinc-65 | 2.94E+02 | 2.44E+02 | 1.2 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Cerium-141 | 1.53E+02 | 1.43E+02 | 1.06 | Acceptable |

| | | | | | | | | | | |
|-------|----------|----------|----------------|--------|---------|-------------------|----------|----------|-------------|------------|
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Cobalt-58 | 1.74E+02 | 1.69E+02 | 1.03 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Cobalt-60 | 2.40E+02 | 2.17E+02 | 1.11 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Chromium-51 | 3.04E+02 | 2.98E+02 | 1.02 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Cesium-134 | 1.29E+02 | 1.39E+02 | 0.93 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Cesium-137 | 1.72E+02 | 1.68E+02 | 1.02 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Iron-59 | 1.58E+02 | 1.33E+02 | 1.18 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Iodine-131 | 4.73E+01 | 4.52E+01 | 1.05 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Manganese-54 | 2.05E+02 | 1.87E+02 | 1.10 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E14413 | Water | pCi/L | Zinc-65 | 2.84E+02 | 2.44E+02 | 1.17 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrF52 | Filter | Bq/smpl | Gross Alpha | 0.179 | 0.255 | 0.077-0.434 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrF52 | Filter | Bq/smpl | Gross Beta | 0.844 | 0.894 | 0.447-1.341 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrW52 | Water | Bq/L | Gross Alpha | 0.365 | 0.411 | 0.123-0.699 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrW52 | Water | Bq/L | Gross Beta | 2.98 | 3.03 | 1.52-4.55 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Americium-241 | 38.2 | 39.8 | 27.9-51.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cesium-134 | 465 | 519 | 363-675 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cesium-137 | 464 | 442 | 309-575 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cobalt-57 | 1160 | 1000 | 700-1300 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cobalt-60 | 605 | 626 | 438-814 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Iron-65 | 1310 | 1090 | 763-1417 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Manganese-54 | 1120 | 1080 | 756-1404 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Nickel-63 | 1380 | 1560 | 1092-2028 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Plutonium-238 | 33.7 | 33.3 | 23.3-43.3 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Plutonium-239/240 | 36.1 | 40.1 | 28.1-52.1 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Potassium-40 | 505 | 511 | 358-664 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Strontium-90 | 597 | 727 | 509-945 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Technetium-99 | 734 | 725 | 508-943 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Thorium 228 | 49 | 44.4 | 31.1-57.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Thorium 230 | 49 | 47 | 32.9-61.1 | Acceptable |

| | | | | | | | | | | |
|-------|----------|----------|----------------|--------|---------|-------------------|---------|--------|-----------------|----------------|
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Thorium 232 | 42.3 | 41.4 | 29.0-53.8 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Uranium-234/233 | 34.7 | 35.9 | 25.1-46.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Uranium-238 | 62 | 69 | 48-90 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Zinc-65 | 833 | 776 | 543-1009 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Americium-241 | 0.555 | 0.559 | 0.391-0.727 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cesium-134 | 0.0271 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cesium-137 | 6.67 | 6.9 | 4.8-9.0 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cobalt-57 | 30 | 30.9 | 21.6-40.2 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cobalt-58 | 37.5 | 37.7 | 26.4-49.0 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cobalt-60 | 0.322 | 0.29 | Sens. Eval. | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Hydrogen-3 | 164 | 191 | 134-248 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Iron-55 | 35.2 | 25.5 | 17.9-33.2 | Not Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Manganese-54 | -0.0059 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Nickel-63 | 30.8 | 38.9 | 27.2-50.6 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Plutonium-238 | 0.00764 | 0.0081 | Sens. Eval. | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Plutonium-239/240 | 0.536 | 0.569 | 0.398-0.740 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Potassium-40 | 35.1 | 30.3 | 21.2-39.4 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Radium-226 | 0.386 | 0.437 | 0.306-0.568 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Strontium-90 | 2.46 | 2.82 | 1.97-3.67 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Technetium-99 | 7.4 | 6.34 | 4.44-8.24 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Uranium-234/233 | 0.526 | 0.535 | 0.375-0.696 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Uranium-238 | 0.528 | 0.548 | 0.384-0.712 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Zinc-65 | 29 | 26.7 | 18.7-34.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | ug/smpl | Uranium-235 | 0.0361 | 0.039 | 0.027-0.051 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | ug/smpl | Uranium-238 | 5.45 | 5.36 | 3.75-6.97 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | ug/smpl | Uranium-Total | 5.486 | 5.4 | 3.78-7.02 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Americium-241 | 0.045 | 0.0437 | 0.0306-0.0568 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cesium-134 | 0.408 | 0.34 | 0.238-0.442 | Acceptable |

| | | | | | | | | | | |
|-------|----------|----------|----------------|--------|---------|-------------------|----------|---------|-----------------|------------|
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cesium-137 | 0.803 | 0.678 | 0.475-0.881 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cobalt-57 | 0.001 | NA | False Pos.Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cobalt-60 | 0.522 | 0.486 | 0.340-0.632 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Manganese-54 | 0.0108 | NA | False Pos.Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Plutonium-238 | 0.0272 | 0.0216 | 0.0151-0.0281 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Plutonium-239/240 | 0.0164 | 0.0141 | 0.0099-0.0183 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Strontium-90 | 0.455 | 0.502 | 0.351-0.653 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Uranium-234/233 | 0.0641 | 0.064 | 0.045-0.083 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Uranium-238 | 0.0661 | 0.067 | 0.047-0.087 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Zinc-65 | 0.0464 | NA | False Pos.Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Americium-241 | 0.0787 | 0.0728 | 0.0510-0.0946 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cesium-134 | -0.0168 | NA | False Pos.Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cesium-137 | 0.593 | 0.707 | 0.495-0.919 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cobalt-57 | 3.41 | 3.4 | 2.38-4.42 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cobalt-60 | 0.000769 | NA | False Pos.Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Manganese-54 | 2.79 | 2.72 | 1.90-3.54 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Plutonium-238 | 0.0714 | 0.0734 | 0.0514-0.0954 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Plutonium-239/240 | 0.0011 | 0.00026 | Sens. Eval. | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Strontium-90 | 0.266 | 0.37 | 0.259-0.481 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Uranium-234/233 | 0.214 | 0.208 | 0.146-0.270 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Uranium-238 | 0.218 | 0.214 | 0.160-0.278 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Zinc-65 | 2.05 | 1.87 | 1.31-2.43 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrF53 | Filter | Bq/smpl | Gross Alpha | 1.07 | 1.24 | 0.36-2.11 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrF53 | Filter | Bq/smpl | Gross Beta | 1.79 | 1.75 | 0.88-2.63 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrW53 | Water | Bq/L | Gross Alpha | 0.831 | 0.96 | 0.29-1.63 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrW53 | Water | Bq/L | Gross Beta | 1.75 | 1.9 | 0.95-2.85 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Americium-241 | 0.449 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cesium-134 | 523 | 613 | 429-797 | Acceptable |

| | | | | | | | | | | |
|-------|----------|----------|----------------|-------|-------|-------------------|--------|-------|-----------------|----------------|
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cesium-137 | 676 | 686 | 480-892 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cobalt-57 | 1.61 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cobalt-60 | 1090 | 1144 | 801-1487 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Iron-55 | 1240 | 518 | 363-673 | Not Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Manganese-54 | 769 | 771 | 540-1002 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Neptunium-237 | 0.465 | 18.35 | 12.85-23.86 | Not Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Nickel-63 | 1130 | 1474 | 1032-1916 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Plutonium-238 | 0.0987 | 0.48 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Plutonium-239/240 | 0.831 | 0.33 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Potassium-40 | 514 | 492 | 516-958 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Strontium-90 | 552 | 737 | 516-958 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Technetium-99 | 433 | 370 | 269-481 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Thorium 228 | 42.8 | 41.7 | 29.2-54.2 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Thorium 230 | 51.6 | 45.6 | 31.9-59.3 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Thorium 232 | 42.4 | 38.7 | 27.1-50.3 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Uranium-234/233 | 33.8 | 35.9 | 25.1-46.7 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Uranium-238 | 62 | 68 | 48-88 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Zinc-65 | -1.2 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Americium-241 | 0.368 | 0.361 | 0.253-0.469 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cerium-139 | 27.3 | 26.4 | 18.5-34.3 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cesium-134 | 6.57 | 7.34 | 5.14-9.54 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cesium-137 | 6.69 | 6.7 | 4.7-8.7 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cobalt-57 | 0.0111 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cobalt-60 | 7.17 | 7.24 | 5.07-9.41 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Hydrogen-3 | 252 | 276 | 193-359 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Iron-55 | 31.7 | 33 | 23.1-42.9 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Manganese-54 | 7.93 | 7.95 | 5.57-10.34 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Nickel-63 | 21.2 | 25 | 17.5-32.5 | Acceptable |

| | | | | | | | | | | |
|-------|----------|----------|----------------|--------|---------|-------------------|-----------|---------|-----------------|----------------|
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Plutonium-238 | -0.00369 | 0.0019 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Plutonium-239/240 | 0.00805 | 0.0037 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Potassium-40 | -1.1 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Radium-226 | 0.343 | 0.407 | 0.285-0.529 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Strontium-90 | 2.62 | 3.02 | 2.11-3.93 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Technetium-99 | -0.363 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Uranium-234/233 | 0.399 | 0.426 | 0.298-0.554 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Uranium-238 | 0.373 | 0.404 | 0.283-0.525 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Zinc-65 | 24.7 | 23.1 | 16.2-30.0 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | ug/smpl | Uranium-235 | 0.0228 | 0.023 | 0.0161-0.0299 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | ug/smpl | Uranium-238 | 2.72 | 3.18 | 2.23-4.13 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | ug/smpl | Uranium-Total | 2.743 | 3.21 | 2.25-4.17 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Americium-241 | 0.0377 | 0.0364 | 0.0255-0.0473 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Cesium-134 | 0.761 | 0.802 | 0.561-1.043 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Cesium-137 | 0.569 | 0.512 | 0.358-0.666 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Cobalt-57 | 1.18 | 1.13 | 0.79-1.47 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Cobalt-60 | 0.0219 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Manganese-54 | 1.12 | 1.07 | 0.75-1.39 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Plutonium-238 | 0.0545 | 0.0538 | 0.0377-0.0699 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Plutonium-239/240 | 0.0541 | 0.0527 | 0.0369-0.0685 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Strontium-90 | 1.05 | 1.15 | 0.81-1.50 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Uranium-234/233 | 0.0393 | 0.0381 | 0.0267-0.0495 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Uranium-238 | 0.0409 | 0.0396 | 0.0277-0.0515 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF63 | Filter | Bq/smpl | Zinc-65 | 8.84 | 1.51 | 1.06-1.96 | Not Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV63 | Veg | Bq/smpl | Americium-241 | -0.000308 | 0.00038 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV63 | Veg | Bq/smpl | Cesium-134 | 0.00315 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV63 | Veg | Bq/smpl | Cesium-137 | 1.12 | 0.986 | 0.690-1.282 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV63 | Veg | Bq/smpl | Cobalt-57 | 4.91 | 4.47 | 3.13-5.81 | Acceptable |

| | | | | | | | | | | |
|-------|----------|----------|----------------|-----|---------|-------------------|--------|--------|---------------|------------|
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Cobalt-60 | 2.42 | 2.3 | 1.61-2.99 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Manganese-54 | 3.3 | 3.1 | 2.17-4.03 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Plutonium-238 | 0.04 | 0.0366 | 0.0256-0.0476 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Plutonium-239/240 | 0.0377 | 0.371 | 0.0260-0.0482 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Strontium-90 | 1.42 | 1.43 | 1.00-1.86 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Uranium-234/233 | 0.111 | 0.115 | 0.081-0.150 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Uranium-238 | 0.117 | 0.119 | 0.083-0.155 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Zinc-65 | 10.4 | 9.29 | 6.5-12.08 | Acceptable |

**TABLE 2
2025 ECKERT & ZIEGLER ANALYTICS PERFORMANCE EVALUATION RESULTS**

| PT Provider | Quarter / Year | Report Closing / Received Date | Sample Number | Sample Media | Units | Analyte | Reported Value | Assigned Value | Acceptance Limits | Performance Evaluation |
|-------------|----------------|--------------------------------|---------------|--------------|-------|--------------|----------------|----------------|-------------------|------------------------|
| EZA | 1st/2025 | 5/14/25 | E1430 2 | Cartridge | pCi | Iodine-131 | 6.64E+01 | 6.61E+01 | 1 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 3 | Milk | pCi/L | Strontium-89 | 9.67E+01 | 9.19E+01 | 1.05 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 3 | Milk | pCi/L | Strontium-90 | 9.00E+00 | 1.56E+01 | 0.58 | Not Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Cerium-141 | 7.85E+01 | 7.58E+01 | 1.04 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Cobalt-58 | 1.06E+02 | 1.05E+02 | 1.01 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Cobalt-60 | 1.99E+02 | 1.93E+02 | 1.03 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Chromium-51 | 2.83E+02 | 2.91E+02 | 0.97 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Cesium-134 | 1.28E+02 | 1.42E+02 | 0.90 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Cesium-137 | 1.72E+02 | 1.68E+02 | 1.03 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Iron-59 | 1.53E+02 | 1.35E+02 | 1.14 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Iodine-131 | 1.02E+02 | 9.47E+01 | 1.08 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Manganese-54 | 2.09E+02 | 1.89E+02 | 1.11 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 4 | Milk | pCi/L | Zinc-65 | 2.87E+02 | 2.51E+02 | 1.15 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Cerium-141 | 8.94E+01 | 7.57E+01 | 1.18 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Cobalt-58 | 1.09E+02 | 1.05E+02 | 1.04 | Acceptable |

| | | | | | | | | | | |
|-----|----------|---------|------------|-----------|-------|--------------|----------|----------|------|----------------|
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Cobalt-60 | 2.00E+02 | 1.93E+02 | 1.04 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Chromium-51 | 3.07E+02 | 2.91E+02 | 1.06 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Cesium-134 | 1.26E+02 | 1.42E+02 | 0.89 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Cesium-137 | 1.76E+02 | 1.68E+02 | 1.05 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Iron-59 | 1.58E+02 | 1.35E+02 | 1.17 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Iodine-131 | 7.86E+01 | 7.60E+01 | 1.03 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Manganese-54 | 2.07E+02 | 1.89E+02 | 1.10 | Acceptable |
| EZA | 1st/2025 | 5/14/25 | E1430 5 | Water | pCi/L | Zinc-65 | 2.77E+02 | 2.50E+02 | 1.11 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 0 | Cartridge | pCi | Iodine-131 | 8.28E+01 | 8.88E+01 | 0.93 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 1 | Milk | pCi/L | Strontium-89 | 1.19E+02 | 8.49E+01 | 1.40 | Not Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 1 | Milk | pCi/L | Strontium-90 | 1.53E+01 | 1.56E+01 | 0.98 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Cerium-141 | 1.50E+02 | 1.43E+02 | 1.05 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Cobalt-58 | 1.75E+02 | 1.69E+02 | 1.03 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Cobalt-60 | 2.24E+02 | 2.17E+02 | 1.03 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Chromium-51 | 3.36E+02 | 2.99E+02 | 1.12 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Cesium-134 | 1.28E+02 | 1.39E+02 | 0.92 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Cesium-137 | 1.75E+02 | 1.68E+02 | 1.04 | Acceptable |

| | | | | | | | | | | |
|-----|----------|--------|------------|-------|-------|--------------|----------|----------|------|------------|
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Iron-59 | 1.57E+02 | 1.34E+02 | 1.17 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Iodine-131 | 9.80E+01 | 8.60E+01 | 1.14 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Manganese-54 | 1.98E+02 | 1.87E+02 | 1.06 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 2 | Milk | pCi/L | Zinc-65 | 2.94E+02 | 2.44E+02 | 1.2 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Cerium-141 | 1.53E+02 | 1.43E+02 | 1.06 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Cobalt-58 | 1.74E+02 | 1.69E+02 | 1.03 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Cobalt-60 | 2.40E+02 | 2.17E+02 | 1.11 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Chromium-51 | 3.04E+02 | 2.98E+02 | 1.02 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Cesium-134 | 1.29E+02 | 1.39E+02 | 0.93 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Cesium-137 | 1.72E+02 | 1.68E+02 | 1.02 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Iron-59 | 1.58E+02 | 1.33E+02 | 1.18 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Iodine-131 | 4.73E+01 | 4.52E+01 | 1.05 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Manganese-54 | 2.05E+02 | 1.87E+02 | 1.10 | Acceptable |
| EZA | 4th/2025 | 2/6/26 | E1441 3 | Water | pCi/L | Zinc-65 | 2.84E+02 | 2.44E+02 | 1.17 | Acceptable |

TABLE 3

2025 DEPARTMENT OF ENERGY MIXED ANALYTE PERFORMANCE EVALUATION PROGRAM (MAPEP) RESULTS

| PT Provider | Quarter / Year | Report Closing / Received Date | Sample Number | Sample Media | Units | Analyte | Reported Value | Assigned Value | Acceptance Limits | Performance Evaluation |
|-------------|----------------|--------------------------------|----------------|--------------|---------|-------------------|----------------|----------------|-------------------|------------------------|
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrF52 | Filter | Bq/smpl | Gross Alpha | 0.179 | 0.255 | 0.077-0.434 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrF52 | Filter | Bq/smpl | Gross Beta | 0.844 | 0.894 | 0.447-1.341 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrW52 | Water | Bq/L | Gross Alpha | 0.365 | 0.411 | 0.123-0.699 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-GrW52 | Water | Bq/L | Gross Beta | 2.98 | 3.03 | 1.52-4.55 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Americium-241 | 38.2 | 39.8 | 27.9-51.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cesium-134 | 465 | 519 | 363-675 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cesium-137 | 464 | 442 | 309-575 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cobalt-57 | 1160 | 1000 | 700-1300 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Cobalt-60 | 605 | 626 | 438-814 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Iron-55 | 1310 | 1090 | 763-1417 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Manganese-54 | 1120 | 1080 | 756-1404 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Nickel-63 | 1380 | 1560 | 1092-2028 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Plutonium-238 | 33.7 | 33.3 | 23.3-43.3 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Plutonium-239/240 | 36.1 | 40.1 | 28.1-52.1 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Potassium-40 | 505 | 511 | 358-664 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Strontium-90 | 597 | 727 | 509-945 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Technetium-99 | 734 | 725 | 508-943 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Thorium 228 | 49 | 44.4 | 31.1-57.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Thorium 230 | 49 | 47 | 32.9-61.1 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Thorium 232 | 42.3 | 41.4 | 29.0-53.8 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Uranium-234/233 | 34.7 | 35.9 | 25.1-46.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Uranium-238 | 62 | 69 | 48-90 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaS52 | Soil | Bq/Kg | Zinc-65 | 833 | 776 | 543-1009 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Americium-241 | 0.555 | 0.559 | 0.391-0.727 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cesium-134 | 0.0271 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cesium-137 | 6.67 | 6.9 | 4.8-9.0 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cobalt-57 | 30 | 30.9 | 21.6-40.2 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cobalt-58 | 37.5 | 37.7 | 26.4-49.0 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Cobalt-60 | 0.322 | 0.29 | Sens. Eval. | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Hydrogen-3 | 164 | 191 | 134-248 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Iron-55 | 35.2 | 25.5 | 17.9-33.2 | Not Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Manganese-54 | -0.0059 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Nickel-63 | 30.8 | 38.9 | 27.2-50.6 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Plutonium-238 | 0.00764 | 0.0081 | Sens. Eval. | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Plutonium-239/240 | 0.536 | 0.569 | 0.398-0.740 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Potassium-40 | 35.1 | 30.3 | 21.2-39.4 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Radium-226 | 0.386 | 0.437 | 0.306-0.568 | Acceptable |

problem solved

| | | | | | | | | | | |
|-------|----------|----------|----------------|--------|---------|-------------------|----------|---------|-----------------|----------------|
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Strontium-90 | 2.46 | 2.82 | 1.97-3.67 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Technetium-99 | 7.4 | 6.34 | 4.44-8.24 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Uranium-234/233 | 0.526 | 0.535 | 0.375-0.696 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Uranium-238 | 0.528 | 0.548 | 0.384-0.712 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-MaW52 | Water | Bq/L | Zinc-65 | 29 | 26.7 | 18.7-34.7 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | ug/smpl | Uranium-235 | 0.0361 | 0.039 | 0.027-0.051 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | ug/smpl | Uranium-238 | 5.45 | 5.36 | 3.75-6.97 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | ug/smpl | Uranium-Total | 5.486 | 5.4 | 3.78-7.02 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Americium-241 | 0.045 | 0.0437 | 0.0306-0.0568 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cesium-134 | 0.408 | 0.34 | 0.238-0.442 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cesium-137 | 0.803 | 0.678 | 0.475-0.881 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cobalt-57 | 0.001 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Cobalt-60 | 0.522 | 0.486 | 0.340-0.632 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Manganese-54 | 0.0108 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Plutonium-238 | 0.0272 | 0.0216 | 0.0151-0.0281 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Plutonium-239/240 | 0.0164 | 0.0141 | 0.0099-0.0183 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Strontium-90 | 0.455 | 0.502 | 0.351-0.653 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Uranium-234/233 | 0.0641 | 0.064 | 0.045-0.083 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Uranium-238 | 0.0661 | 0.067 | 0.047-0.087 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdF52 | Filter | Bq/smpl | Zinc-65 | 0.0464 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Americium-241 | 0.0787 | 0.0728 | 0.0510-0.0946 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cesium-134 | -0.0168 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cesium-137 | 0.593 | 0.707 | 0.495-0.919 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cobalt-57 | 3.41 | 3.4 | 2.38-4.42 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Cobalt-60 | 0.000769 | NA | False Pos. Test | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Manganese-54 | 2.79 | 2.72 | 1.90-3.54 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Plutonium-238 | 0.0714 | 0.0734 | 0.0514-0.0954 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Plutonium-239/240 | 0.0011 | 0.00026 | Sens. Eval. | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Strontium-90 | 0.266 | 0.37 | 0.259-0.481 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Uranium-234/233 | 0.214 | 0.208 | 0.146-0.270 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Uranium-238 | 0.218 | 0.214 | 0.150-0.278 | Acceptable |
| MAPEP | 2nd/2025 | 6/6/2025 | MAPEP-25-RdV52 | Veg | Bq/smpl | Zinc-65 | 2.05 | 1.87 | 1.31-2.43 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrF53 | Filter | Bq/smpl | Gross Alpha | 1.07 | 1.24 | 0.36-2.11 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrF53 | Filter | Bq/smpl | Gross Beta | 1.79 | 1.75 | 0.88-2.63 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrW53 | Water | Bq/L | Gross Alpha | 0.831 | 0.96 | 0.29-1.63 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-GrW53 | Water | Bq/L | Gross Beta | 1.75 | 1.9 | 0.95-2.85 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Americium-241 | 0.449 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cesium-134 | 523 | 613 | 429-797 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cesium-137 | 676 | 686 | 480-892 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cobalt-57 | 1.61 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Cobalt-60 | 1090 | 1144 | 801-1487 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Iron-55 | 1240 | 518 | 363-673 | Not Acceptable |

problem solved

| | | | | | | | | | | |
|-------|----------|----------|----------------|--------|---------|-------------------|----------|--------|-----------------|----------------|
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Manganese-54 | 769 | 771 | 540-1002 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Neptunium-237 | 0.465 | 18.35 | 12.85-23.86 | Not Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Nickel-63 | 1130 | 1474 | 1032-1916 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Plutonium-238 | 0.0987 | 0.48 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Plutonium-239/240 | 0.831 | 0.33 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Potassium-40 | 514 | 492 | 516-958 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Strontium-90 | 552 | 737 | 516-958 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Technetium-99 | 433 | 370 | 259-481 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Thorium 228 | 42.8 | 41.7 | 29.2-54.2 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Thorium 230 | 51.6 | 45.6 | 31.9-59.3 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Thorium 232 | 42.4 | 38.7 | 27.1-50.3 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Uranium-234/233 | 33.8 | 35.9 | 25.1-46.7 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Uranium-238 | 62 | 68 | 48-88 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaS53 | Soil | Bq/Kg | Zinc-65 | -1.2 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Americium-241 | 0.368 | 0.361 | 0.253-0.469 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cerium-139 | 27.3 | 26.4 | 18.5-34.3 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cesium-134 | 6.57 | 7.34 | 5.14-9.54 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cesium-137 | 6.69 | 6.7 | 4.7-8.7 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cobalt-57 | 0.0111 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Cobalt-60 | 7.17 | 7.24 | 5.07-9.41 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Hydrogen-3 | 252 | 276 | 193-359 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Iron-55 | 31.7 | 33 | 23.1-42.9 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Manganese-54 | 7.93 | 7.95 | 5.57-10.34 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Nickel-63 | 21.2 | 25 | 17.5-32.5 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Plutonium-238 | -0.00369 | 0.0019 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Plutonium-239/240 | 0.00805 | 0.0037 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Potassium-40 | -1.1 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Radium-226 | 0.343 | 0.407 | 0.285-0.529 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Strontium-90 | 2.62 | 3.02 | 2.11-3.93 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Technetium-99 | -0.363 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Uranium-234/233 | 0.399 | 0.426 | 0.298-0.554 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Uranium-238 | 0.373 | 0.404 | 0.283-0.525 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-MaW53 | Water | Bq/L | Zinc-65 | 24.7 | 23.1 | 16.2-30.0 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | ug/smpl | Uranium-235 | 0.0228 | 0.023 | 0.0161-0.0299 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | ug/smpl | Uranium-238 | 2.72 | 3.18 | 2.23-4.13 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | ug/smpl | Uranium-Total | 2.743 | 3.21 | 2.25-4.17 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Americium-241 | 0.0377 | 0.0364 | 0.0255-0.0473 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Cesium-134 | 0.761 | 0.802 | 0.561-1.043 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Cesium-137 | 0.569 | 0.512 | 0.358-0.666 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Cobalt-57 | 1.18 | 1.13 | 0.79-1.47 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Cobalt-60 | 0.0219 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Manganese-54 | 1.12 | 1.07 | 0.75-1.39 | Acceptable |

| | | | | | | | | | | |
|-------|----------|----------|----------------|--------|---------|-------------------|-----------|---------|-----------------|----------------|
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Plutonium-238 | 0.0545 | 0.0538 | 0.0377-0.0699 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Plutonium-239/240 | 0.0541 | 0.0527 | 0.0369-0.0685 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Strontium-90 | 1.05 | 1.15 | 0.81-1.50 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Uranium-234/233 | 0.0393 | 0.0381 | 0.0267-0.0495 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Uranium-238 | 0.0409 | 0.0396 | 0.0277-0.0515 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdF53 | Filter | Bq/smpl | Zinc-65 | 8.84 | 1.51 | 1.06-1.96 | Not Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Americium-241 | -0.000308 | 0.00038 | Sens. Eval. | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Cesium-134 | 0.00315 | NA | False Pos. Test | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Cesium-137 | 1.12 | 0.986 | 0.690-1.282 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Cobalt-57 | 4.91 | 4.47 | 3.13-5.81 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Cobalt-60 | 2.42 | 2.3 | 1.61-2.99 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Manganese-54 | 3.3 | 3.1 | 2.17-4.03 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Plutonium-238 | 0.04 | 0.0366 | 0.0256-0.0476 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Plutonium-239/240 | 0.0377 | 0.371 | 0.0260-0.0482 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Strontium-90 | 1.42 | 1.43 | 1.00-1.86 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Uranium-234/233 | 0.111 | 0.115 | 0.081-0.150 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Uranium-238 | 0.117 | 0.119 | 0.083-0.155 | Acceptable |
| MAPEP | 4th/2025 | 12/19/25 | MAPEP-25-RdV53 | Veg | Bq/smpl | Zinc-65 | 10.4 | 9.29 | 6.5-12.08 | Acceptable |

TABLE 4

2025 ERA PROGRAM PERFORMANCE EVALUATION RESULTS

| PT Provider | Quarter / Year | Report Closing / Received Date | Sample Number | Sample Media | Units | Analyte | Reported Value | Assigned Value | Acceptance Limits | Performance Evaluation |
|-------------|----------------|--------------------------------|---------------|--------------|-------|----------------|----------------|----------------|-------------------|------------------------|
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Barium-133 | 103 | 89.7 | 71.5 - 108 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Cesium-134 | 39.9 | 38.4 | 25.4 - 51.4 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Cesium-137 | 162 | 157 | 123 - 191 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Cobalt-60 | 75.8 | 66.8 | 50.9 - 82.7 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Zinc-65 | 78.7 | 74.3 | 39.3 - 109 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Gross Alpha | 77.3 | 72.2 | 55.3 - 89.1 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Gross Beta | 54.9 | 59.2 | 44.1 - 74.3 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Uranium (Nat) | 63.1 | 63.6 | 56.6 - 70.6 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | µg/L | Uranium (mass) | 85.7 | 92.7 | 82.5 - 103 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Tritium | 9760 | 11400 | 9340 - 13500 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Strontium-89 | 65 | 57.4 | 42.5 - 72.3 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Strontium-90 | 36.8 | 42.6 | 36.5 - 48.7 | Acceptable |
| ERA | 1st/2025 | 03/03/25 | RAD-140 | Water | pCi/L | Iodine-131 | 31.8 | 28.1 | 24.4 - 31.8 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Barium-133 | 36.1 | 30.1 | 17.9-42.3 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Cesium-134 | 60.9 | 65.6 | 49.8-81.4 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Cesium-137 | 166 | 152 | 118-186 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Cobalt-60 | 133 | 113 | 92.5-134 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Zinc-65 | 83.5 | 80.6 | 44.9-116 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Gross Alpha | 28.8 | 33.8 | 24.6-43.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Gross Alpha | 27.6 | 33.8 | 24.6-43.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Gross Beta | 45.7 | 41.7 | 24.6-43.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Radium-226 | 14 | 14.4 | 12.0-16.8 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Radium-228 | 4.4 | 4.76 | 2.99-6.53 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Radium-228 | 5.33 | 4.76 | 2.99-6.53 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Uranium (Nat) | 65.9 | 68.1 | 60.8-75.6 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | µg/L | Uranium (mass) | 91.76 | 99.5 | 88.6-110 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Tritium | 14500 | 15800 | 13300-18300 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Tritium | 15000 | 15800 | 13300-18300 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-89 | 51.2 | 45.3 | 31.6-59.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-89 | 47.3 | 45.3 | 31.6-59.0 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-90 | 30.5 | 34.3 | 29.0-39.6 | Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Strontium-90 | 26.5 | 34.3 | 29.0-39.6 | Not Acceptable |
| ERA | 3rd/2025 | 08/25/25 | RAD-142 | Water | pCi/L | Iodine-131 | 22.8 | 28.3 | 24.5-32.1 | Not Acceptable |
| ERA | 4th/2025 | 12/12/25 | RAD-143 | Water | pCi/L | Iodine-131 | 22.9 | 24.3 | 20.9-27.7 | Acceptable |
| ERA | 4th/2025 | 12/12/25 | RAD-143 | Water | pCi/L | Strontium-89 | 63 | 64.2 | 48.6-79.8 | Acceptable |
| ERA | 4th/2025 | 12/12/25 | RAD-143 | Water | pCi/L | Strontium-90 | 35.7 | 43.8 | 37.6-50.0 | Not Acceptable |

TABLE 5

2025 ERA PROGRAM (MRAD) PERFORMANCE EVALUATION RESULTS

| PT Provider | Quarter / Year | Report Closing / Received Date | Sample Number | Sample Media | Units | Analyte | Reported Value | Assigned Value | Acceptance Limits | Performance Evaluation |
|-------------|----------------|--------------------------------|---------------|--------------|--------|---------------|----------------|----------------|-------------------|------------------------|
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Actinium-228 | 1140 | 1150 | 759-1450 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Americium-241 | 986 | 1060 | 572-1710 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Bismuth-212 | 1160 | 1150 | 329-1710 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Bismuth-214 | 514 | 634 | 304-943 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Cesium-134 | 5860 | 6520 | 4460-7790 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Cesium-137 | 4170 | 4420 | 3340-5590 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Cobalt-60 | 3160 | 3260 | 2570-4020 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Lead-212 | 1200 | 1150 | 802-1450 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Lead-214 | 661 | 634 | 266-997 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Manganese-54 | <37.1 | <555 | 0-555 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Plutonium-238 | 1000 | 1070 | 534-1630 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Plutonium-239 | 1070 | 1150 | 627-1650 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Potassium-40 | 33600 | 34100 | 23500-40700 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Strontium-90 | 3990 | 5710 | 1780-8890 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Thorium-234 | 3640 | 3470 | 1310-5940 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Uranium-234 | 3320 | 3500 | 1640-4590 | Acceptable |

| | | | | | | | | | | |
|-----|----------|-----------|---------|--------|------------|----------------|-------|-------|------------|------------|
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Uranium-238 | 3190 | 3470 | 1900-4660 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Uranium-Total | 6650 | 7120 | 3950-9210 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | µg/kg | Uranium (mass) | 9540 | 10400 | 4690-14000 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Soil | pCi/kg | Zinc-65 | 1330 | 1240 | 990-1690 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Americium-241 | 72.6 | 67.7 | 48.3-90.3 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Cesium-134 | 224 | 232 | 151-284 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Cesium-137 | 468 | 451 | 370-592 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Cobalt-60 | 278 | 250 | 212-318 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Iron-55 | 216 | 181 | 66.1-289 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Manganese-54 | <3.45 | <35.0 | 0-35 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Plutonium-238 | 39 | 40.2 | 30.4-49.4 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Plutonium-239 | 64.6 | 62.3 | 46.6-75.2 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Strontium-90 | 19.7 | 24.6 | 15.6-33.5 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Uranium-234 | 32.7 | 34.2 | 25.4-40.1 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Uranium-238 | 32.8 | 33.9 | 25.6-40.4 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Uranium-Total | 67.2 | 69.7 | 50.9-82.7 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | µg/Filter | Uranium (mass) | 98.4 | 102 | 81.9-119 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Zinc-65 | 702 | 632 | 518-966 | Acceptable |

| | | | | | | | | | | |
|-----|----------|-----------|---------|--------|------------|----------------|-------|-------|------------|----------------|
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Gross Alpha | 43.8 | 39.5 | 20.6-65.1 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Filter | pCi/Filter | Gross Beta | 57.5 | 55.2 | 33.5-83.4 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Tritium | 6450 | 9420 | 7100-11500 | Not Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Americium-241 | 45.5 | 39.5 | 27.1-50.5 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Cesium-134 | 1530 | 1600 | 1210-1760 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Cesium-137 | 1130 | 1080 | 925-1230 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Cobalt-60 | 276 | 255 | 220-293 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Iron-55 | 1740 | 1460 | 858-2120 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Manganese-54 | <3.16 | <71.0 | 0-71 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Plutonium-238 | 69.4 | 77.2 | 46.4-100 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Plutonium-239 | 54.8 | 58.4 | 36.1-72.0 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Strontium-90 | 556 | 626 | 451-774 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Uranium-234 | 90.8 | 98.2 | 74.8-112 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Uranium-238 | 97.6 | 97.4 | 75.5-115 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Uranium-Total | 193 | 200 | 156-228 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | µg/L | Uranium (mass) | 292 | 292 | 237-331 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Zinc-65 | 258 | 231 | 206-292 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Gross Alpha | 71.8 | 77.3 | 28.2-107 | Acceptable |

| | | | | | | | | | | |
|-----|----------|-----------|---------|-------|--------|----------------|-------|-------|-------------|------------|
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Water | pCi/L | Gross Beta | 103 | 99.4 | 49.7-137 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Americium-241 | 1640 | 1800 | 1110-2540 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Cesium-134 | 1700 | 1880 | 1250-2500 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Cesium-137 | 627 | 572 | 440-700 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Cobalt-60 | 1800 | 1720 | 1350-2250 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Curium-244 | 719 | 860 | 485-1070 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Manganese-54 | <34.7 | <207 | 0-207 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Plutonium-238 | 3210 | 3750 | 2600-4840 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Plutonium-239 | 4170 | 4590 | 3170-5810 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Potassium-40 | 31200 | 28500 | 21400-36100 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Strontium-90 | 2000 | 2360 | 1330-3080 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Uranium-234 | 3580 | 3960 | 2780-5050 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Uranium-238 | 3700 | 3930 | 2780-4920 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Uranium-Total | 7510 | 8080 | 5160-10900 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | µg/kg | Uranium (mass) | 11100 | 11800 | 9060-14600 | Acceptable |
| ERA | 2nd/2025 | 5/20/2025 | MRAD-42 | Veg | pCi/kg | Zinc-65 | 825 | 741 | 553-1100 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Actinium-228 | 112 | 1150 | 759-1450 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Americium-241 | 1400 | 1550 | 837-2190 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|------|--------|---------------|-------|-------|-------------|------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Bismuth-212 | 1260 | 1150 | 329-1710 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Bismuth-214 | 2010 | 2880 | 1380-4290 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Cesium-134 | 2900 | 3340 | 2280-3990 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Cesium-137 | 6950 | 7190 | 5440-9090 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Cobalt-60 | 1170 | 1190 | 937-1470 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Lead-212 | 1350 | 1150 | 802-1450 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Lead-214 | 2530 | 3020 | 1270-4750 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Manganese-54 | <20.4 | <555 | 0.0-555 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Plutonium-238 | 831 | 845 | 421-1280 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Plutonium-239 | 1550 | 1300 | 708-1870 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Potassium-40 | 32500 | 34100 | 23500-40700 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Strontium-90 | 6510 | 9490 | 2950--14800 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Thorium-234 | 3850 | 4200 | 1590-7190 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-234 | 4350 | 4240 | 1990-5560 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-234 | 3890 | 4240 | 1990-5560 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-238 | 4380 | 4200 | 2300-5640 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-238 | 4050 | 4200 | 2300-5640 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-Total | 8942 | 8630 | 4790-11200 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|------|--------|----------------|-------|-------|-------------|------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Uranium-Total | 8160 | 8630 | 4790-11200 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | µg/kg | Uranium (mass) | 13100 | 12600 | 5690-17000 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | µg/kg | Uranium (mass) | 12200 | 12600 | 5690-17000 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Soil | pCi/kg | Zinc-65 | 3680 | 3820 | 3050-5210 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Americium-241 | 3290 | 3510 | 2170-4960 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Cesium-134 | 1700 | 2040 | 1350-2720 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Cesium-137 | 2010 | 2190 | 1680-2950 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Cobalt-60 | 1990 | 1940 | 1520-2540 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Curium-244 | 2040 | 2130 | 1200-2650 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Manganese-54 | <30.7 | <207 | 0.0-207 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Plutonium-238 | 1140 | 1120 | 776-1440 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Plutonium-239 | 3880 | 3550 | 2450-4490 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Potassium-40 | 27800 | 28500 | 21400-36100 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Strontium-90 | 4200 | 5330 | 3000-6950 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Uranium-234 | 3070 | 3230 | 2270-4120 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Uranium-238 | 3290 | 3210 | 2270-4010 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Uranium-Total | 6580 | 6590 | 4210-8880 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | µg/kg | Uranium (mass) | 9880 | 9610 | 7380-11900 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|--------|------------|----------------|------|-------|-----------|------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Veg | pCi/kg | Zinc-65 | 2070 | 1940 | 1450-2880 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Americium-241 | 38.7 | 39.8 | 28.4-53.1 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Cesium-134 | 304 | 341 | 221-418 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Cesium-137 | 383 | 379 | 311-497 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Cobalt-60 | 349 | 322 | 274-409 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Iron-55 | 189 | 166 | 60.6-265 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Manganese-54 | <2.5 | <35.0 | 0.0-35.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Plutonium-238 | 20 | 18.4 | 13.9-22.6 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Plutonium-239 | 35.6 | 31.3 | 23.4-37.8 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Strontium-90 | 161 | 158 | 99.9-215 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-234 | 60.2 | 63.4 | 47.0-74.3 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-234 | 59.6 | 63.4 | 47.0-74.3 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-238 | 67.8 | 62.9 | 47.5-75.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-238 | 63.1 | 62.9 | 47.5-75.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-Total | 131 | 129 | 94.2-153 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Uranium-Total | 127 | 129 | 94.2-153 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | µg/Filter | Uranium (mass) | 203 | 188 | 151-220 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | µg/Filter | Uranium (mass) | 189 | 188 | 151-220 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|--------|------------|---------------|-------|-------|-----------|----------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Zinc-65 | 219 | 193 | 158-295 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Gross Alpha | 37.5 | 22 | 11.5-36.2 | Not Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Filter | pCi/Filter | Gross Beta | 42.3 | 40.5 | 24.6-61.2 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Americium-241 | 73.9 | 68.6 | 47.1-87.7 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Cesium-134 | 720 | 765 | 578-842 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Cesium-137 | 1690 | 1670 | 1790-2390 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Cobalt-60 | 2170 | 2080 | 1790-2390 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Iron-55 | 455 | 399 | 234-580 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Manganese-54 | <5.37 | <71.0 | 0.0-71.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Plutonium-238 | 106 | 115 | 69.1-149 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Plutonium-239 | 40.4 | 39.8 | 24.6-49.0 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Strontium-90 | 790 | 699 | 503-864 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-234 | 129 | 133 | 101-152 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-234 | 140 | 133 | 101-152 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-238 | 132 | 132 | 102-155 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-238 | 132 | 132 | 102-155 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-Total | 270 | 271 | 211-309 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Uranium-Total | 278 | 271 | 211-309 | Acceptable |

| | | | | | | | | | | |
|-----|----------|----------|---------|-------|-------|----------------|-------|-------|-------------|------------|
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | µg/L | Uranium (mass) | 395 | 395 | 320-448 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | µg/L | Uranium (mass) | 397 | 395 | 320-448 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Zinc-65 | 512 | 463 | 412-584 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Gross Alpha | 99.8 | 136 | 49.6-188 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Gross Beta | 194 | 188 | 94.0-259 | Acceptable |
| ERA | 4th/2025 | 12/31/25 | MRAD-43 | Water | pCi/L | Tritium | 27500 | 28300 | 21300-34400 | Acceptable |

FIGURE 1

COBALT-60 PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 2

CESIUM-137 PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 3

TRITIUM PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 4

STRONTIUM-90 PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 5

GROSS ALPHA PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 6

GROSS BETA PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 7

IODINE-131 PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 8

AMERICIUM-241 PERFORMANCE EVALUATION RESULTS AND % BIAS




FIGURE 9

PLUTONIUM-238 PERFORMANCE EVALUATION RESULTS AND % BIAS




TABLE 6
REMP INTRA-LABORATORY DATA SUMMARY:
BIAS AND PRECISION BY MATRIX

| 2025 | Bias Criteria (+ / - 25%) | | Precision Criteria (Note 1) | |
|---|------------------------------|---------------------|--------------------------------|---------------------|
| | WITHIN CRITERIA | OUTSIDE CRITERIA | WITHIN CRITERIA | OUTSIDE CRITERIA |
| TISSUE | | | | |
| Gamma Spec Solid RAD A-013 | 85 | 2 | 94 | 0 |
| SOLID | | | | |
| Gamma Spec Solid RAD A-013 with Iodine | 46 | 6 | 81 | 0 |
| VEGETATION | | | | |
| Gamma Spec Solid RAD A-013 | 14 | 0 | 21 | 0 |
| LIQUID | | | | |
| Iodine-131 | 0 | 0 | 253 | 0 |
| Gross Alpha Non Vol Beta | 77 | 1 | 220 | 0 |
| MILK | | | | |
| Gamma Iodine-131 | 29 | 0 | 205 | 0 |
| Gamma Spec Liquid RAD A-013 with Ba, La | 73 | 0 | 202 | 0 |
| LIQUID | | | | |
| Gamma Spec Liquid RAD A-013 with Ba, La | 206 | 4 | 441 | 0 |
| FILTER | | | | |
| Gross A & B | 1223 | 2 | 797 | 0 |
| LIQUID | | | | |
| Tritium | 624 | 0 | 885 | 0 |
| FILTER | | | | |
| Gamma Spec Filter | 67 | 2 | 148 | 0 |
| SOLID | | | | |
| Gamma Spec Solid RAD A-013 | 20 | 1 | 21 | 0 |
| VEGETATION | | | | |
| Gamma Spec Solid RAD A-013 with Iodine | 191 | 3 | 220 | 0 |
| DRINKING WATER | | | | |
| Gross Alpha Non Vol Beta | 193 | 1 | 205 | 0 |
| MILK | | | | |
| Gas Flow Sr 2nd count | 98 | 0 | 113 | 0 |
| LIQUID | | | | |
| Gas Flow Sr 2nd count | 43 | 0 | 43 | 0 |
| Gamma Spec Liquid RAD A-013 with Iodine | 50 | 0 | 245 | 0 |

problem solved

| | | | | |
|---|-----|---|-----|---|
| MILK | | | | |
| Gamma Spec Liquid RAD A-013 with Iodine | 0 | 0 | 4 | 0 |
| TISSUE | | | | |
| Gas Flow Total Strontium | 13 | 0 | 13 | 0 |
| LIQUID | | | | |
| Gas Flow Total Strontium | 50 | 0 | 57 | 0 |
| SOLID | | | | |
| Gas Flow Sr 2nd count | 6 | 0 | 20 | 1 |
| DRINKING WATER | | | | |
| Tritium | 115 | 0 | 106 | 0 |
| Gamma Spec Liquid RAD A-013 with Ba, La | 92 | 0 | 123 | 0 |
| LIQUID | | | | |
| LSC Iron-55 | 72 | 0 | 84 | 0 |
| LSC Nickel 63 | 74 | 0 | 88 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Sr 2nd count | 10 | 0 | 2 | 0 |
| SOLID | | | | |
| Gas Flow Total Strontium | 11 | 0 | 11 | 0 |
| MILK | | | | |
| Gas Flow Total Strontium | 30 | 0 | 30 | 0 |
| DRINKING WATER | | | | |
| LSC Iron-55 | 61 | 0 | 57 | 0 |
| LSC Nickel 63 | 65 | 0 | 57 | 0 |
| LIQUID | | | | |
| Gamma Iodine-131 | 0 | 0 | 4 | 0 |
| VEGETATION | | | | |
| Gas Flow Sr 2nd count | 17 | 0 | 19 | 0 |
| AIR CHARCOAL | | | | |
| Gamma Iodine 131 RAD A-013 | 641 | 0 | 956 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Total Strontium | 56 | 0 | 49 | 0 |
| Gamma Iodine-131 | 63 | 0 | 59 | 0 |
| SOLID | | | | |
| LSC Iron-55 | 15 | 0 | 15 | 0 |
| LSC Nickel 63 | 15 | 0 | 19 | 0 |
| TISSUE | | | | |
| Gamma Spec Solid RAD A-013 with Iodine | 18 | 0 | 22 | 0 |
| LSC Iron-55 | 0 | 0 | 4 | 0 |
| LSC Nickel 63 | 0 | 0 | 8 | 0 |
| AIR CHARCOAL | | | | |
| Carbon-14 (Ascarite/Soda Lime Filter per Liter) | 75 | 0 | 75 | 0 |
| DRINKING WATER | | | | |

| | | | | |
|---|----|---|----|---|
| Gamma Spec Liquid RAD A-013 | 19 | 0 | 19 | 0 |
| Iodine-131 | 0 | 0 | 49 | 0 |
| Gamma Spec Liquid RAD A-013 with Iodine | 0 | 0 | 27 | 0 |
| TISSUE | | | | |
| Gas Flow Sr 2nd count | 27 | 0 | 23 | 0 |
| FILTER | | | | |
| Gas Flow Sr 2nd Count | 11 | 0 | 11 | 0 |
| TISSUE | | | | |
| Tritium | 2 | 0 | 2 | 0 |
| LIQUID | | | | |
| Gamma Spec Liquid RAD A-013 | 10 | 0 | 10 | 0 |
| SOLID | | | | |
| Gamma Spec Solid RAD A-013 with Ba, La | 2 | 0 | 2 | 0 |
| FILTER | | | | |
| Carbon-14 (Soda Lime) | 0 | 0 | 8 | 0 |
| Alpha Spec Plutonium | 0 | 0 | 2 | 0 |
| SOLID | | | | |
| Tritium | 3 | 0 | 3 | 0 |
| VEGETATION | | | | |
| Carbon-14 | 3 | 0 | 3 | 0 |

Note 1: The RPD must be 20 percent or less, if both samples are greater than 5 times the MDC. If both results are less than 5 times MDC, then the RPD must be equal to or less than 100%. If one result is above the MDC and the other is below the MDC, then the RPD can be calculated using the MDC for the result of the one below the MDC. The RPD must be 100% or less. In the situation where both results are above the MDC but one result is greater than 5 times the MDC and the other is less than 5 times the MDC, the RPD must be less than or equal to 20%. If both results are below MDC, then the limits on % RPD are not applicable.

TABLE 7

**ALL RADIOLOGICAL INTRA-LABORATORY DATA SUMMARY:
BIAS AND PRECISION BY MATRIX:**

| 2025 | Bias Criteria (+ / - 25%) | | Precision Criteria (Note 1) | |
|--|---------------------------|------------------|-----------------------------|------------------|
| | WITHIN CRITERIA | OUTSIDE CRITERIA | WITHIN CRITERIA | OUTSIDE CRITERIA |
| LIQUID | | | | |
| ICP-MS Uranium-233, 234 Prep in Liquid | 84 | 0 | 146 | 0 |
| Plutonium | 600 | 0 | 722 | 2 |
| VEGETATION | | | | |
| Gas Flow Strontium 90 | 214 | 2 | 205 | 0 |
| FILTER | | | | |
| Gross A & B (Americium Calibration) Liquid | 383 | 2 | 504 | 0 |
| Alpha Spec Am243 | 62 | 3 | 174 | 0 |
| SOLID | | | | |
| LSC Promethium 147 | 105 | 0 | 117 | 0 |
| TISSUE | | | | |
| Alpha Spec Plutonium | 133 | 0 | 163 | 0 |
| SOLID | | | | |
| Technetium-99 | 2478 | 5 | 2868 | 3 |
| FILTER | | | | |
| Gas Flow Sr-90 | 3 | 0 | 184 | 0 |
| LSC Plutonium 241 Filter per Liter | 0 | 0 | 101 | 0 |
| ICP-MS Uranium-235, 236, 238 in Filter | 36 | 0 | 164 | 0 |
| Alpha Spec Polonium | 3 | 0 | 82 | 0 |
| LIQUID | | | | |
| ICP-MS Technetium-99 in Water | 65 | 0 | 94 | 0 |
| TISSUE | | | | |
| Gross Alpha/Beta | 22 | 1 | 26 | 0 |
| FILTER | | | | |
| Carbon-14 (Soda Lime) | 0 | 0 | 12 | 0 |
| TISSUE | | | | |
| Gas Flow Total Strontium | 17 | 0 | 17 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Sr 2nd count | 14 | 0 | 3 | 0 |
| LIQUID | | | | |
| LSC Sulfur 35 | 42 | 0 | 54 | 0 |
| DRINKING WATER | | | | |
| Iodine-131 | 0 | 0 | 55 | 5 |
| MILK | | | | |
| Alpha Spec Uranium | 1 | 0 | 4 | 0 |
| LIQUID | | | | |

| | | | | |
|--|------|----|------|---|
| Iodine-131 | 8 | 0 | 13 | 1 |
| SOLID | | | | |
| Alpha Spec Neptunium (pCi/Sample) | 18 | 0 | 18 | 0 |
| MILK | | | | |
| Alpha Spec Neptunium | 1 | 0 | 1 | 0 |
| VEGETATION | | | | |
| Gas Flow Strontium 90 | 18 | 0 | 9 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Strontium 90 | 8 | 0 | 4 | 0 |
| MILK | | | | |
| Technetium-99 | 1 | 0 | 1 | 0 |
| FILTER | | | | |
| Gas Flow Total Radium | 0 | 0 | 11 | 0 |
| AIR CHARCOAL | | | | |
| Gas Flow Strontium 90 | 0 | 0 | 3 | 0 |
| Alpha Spec Thorium | 3 | 0 | 3 | 0 |
| LIQUID | | | | |
| Alpha Spec Plutonium | 1625 | 8 | 2068 | 1 |
| SOLID | | | | |
| Alpha Spec Plutonium | 2347 | 12 | 2541 | 0 |
| LIQUID | | | | |
| Gamma Nickel 59 RAD A-022 | 196 | 1 | 313 | 0 |
| SOLID | | | | |
| Alpha Spec Am241 Curium | 2148 | 5 | 2294 | 0 |
| DRINKING WATER | | | | |
| Tritium in Drinking Water by EPA 906.0 | 467 | 0 | 515 | 0 |
| FILTER | | | | |
| Gas Flow Sr 2nd Count | 41 | 1 | 177 | 0 |
| MILK | | | | |
| Gas Flow Sr 2nd count | 133 | 0 | 153 | 0 |
| SOLID | | | | |
| LSC Selenium 79 | 131 | 0 | 248 | 1 |
| FILTER | | | | |
| Alpha Spec Plutonium | 269 | 5 | 532 | 0 |
| Tritium | 556 | 0 | 1222 | 0 |
| Gamma Iodine-129 | 0 | 0 | 342 | 0 |
| SOLID | | | | |
| ICP-MS Uranium-234, 235, 236, 238 Prep in Solid | 427 | 0 | 424 | 0 |
| VEGETATION | | | | |
| Alpha Spec Plutonium | 150 | 0 | 143 | 0 |
| FILTER | | | | |
| Gamma Spec Filter | 440 | 9 | 533 | 0 |
| SOLID | | | | |
| ICP-MS Uranium-235, 236, 238 in Solid | 775 | 2 | 846 | 1 |

| | | | | |
|---|------|----|------|---|
| LIQUID | | | | |
| Gas Flow Strontium 89 & 90 | 6 | 0 | 58 | 0 |
| SOLID | | | | |
| Tritium | 209 | 0 | 282 | 1 |
| Gross Alpha Beta Soil Leach | 193 | 0 | 199 | 0 |
| TISSUE | | | | |
| Alpha Spec Uranium | 70 | 0 | 117 | 0 |
| AIR CHARCOAL | | | | |
| Carbon-14 (Ascarite/Soda Lime Filter per Liter) | 101 | 0 | 101 | 0 |
| FILTER | | | | |
| Alpha Spec Thorium | 4 | 0 | 175 | 0 |
| DRINKING WATER | | | | |
| Alpha Spec Uranium | 6 | 1 | 13 | 0 |
| LIQUID | | | | |
| Alpha Spec Radium 226 | 136 | 0 | 161 | 0 |
| Alpha Spec Actinium | 9 | 0 | 81 | 0 |
| MILK | | | | |
| Carbon-14 | 22 | 0 | 22 | 0 |
| FILTER | | | | |
| ICP-MS Tc-99 Prep in Filter | 0 | 0 | 11 | 0 |
| Alpha Spec Radium 226 | 22 | 0 | 28 | 0 |
| LSC Iron-55 | 11 | 0 | 34 | 0 |
| SOLID | | | | |
| Technetium-99 | 15 | 0 | 15 | 0 |
| FILTER | | | | |
| GFC Chlorine-36 in Filters | 3 | 0 | 31 | 0 |
| LIQUID | | | | |
| Gamma Iodine-131 | 0 | 0 | 5 | 0 |
| TISSUE | | | | |
| Alpha Spec Total Uranium | 4 | 0 | 4 | 0 |
| Gamma Iodine-129 | 15 | 0 | 15 | 0 |
| Carbon-14 | 12 | 0 | 12 | 0 |
| DRINKING WATER | | | | |
| Gamma Nickel 59 RAD A-022 | 5 | 0 | 5 | 0 |
| LIQUID | | | | |
| Alpha Spec Am241 Curium | 1552 | 5 | 1967 | 0 |
| SOLID | | | | |
| Alpha Spec Thorium | 3358 | 78 | 3351 | 1 |
| FILTER | | | | |
| Direct Count-Gross Alpha/Beta | 837 | 16 | 287 | 0 |
| SOLID | | | | |
| Gas Flow Strontium 90 | 2056 | 10 | 2221 | 0 |
| LIQUID | | | | |
| Alpha Spec Total U RAD A-011 | 252 | 3 | 193 | 0 |

| | | | | |
|---|------|----|------|----|
| SOLID | | | | |
| Alpha Spec Total Uranium | 181 | 8 | 145 | 0 |
| DRINKING WATER | | | | |
| Gamma Spec Liquid RAD A-013 with Ba, La | 125 | 0 | 170 | 0 |
| LIQUID | | | | |
| Gamma Spec Liquid RAD A-013 with Iodine | 249 | 2 | 543 | 0 |
| FILTER | | | | |
| Alphaspec Pu Filter per Liter | 0 | 0 | 175 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Total Radium | 5 | 0 | 5 | 0 |
| SOLID | | | | |
| Gamma Nickel 59 RAD A-022 | 1092 | 5 | 1161 | 0 |
| FILTER | | | | |
| Alpha Spec Neptunium | 273 | 0 | 588 | 0 |
| VEGETATION | | | | |
| Alpha Spec Thorium | 33 | 2 | 35 | 0 |
| TISSUE | | | | |
| Alpha Spec Plutonium | 8 | 0 | 11 | 0 |
| SOLID | | | | |
| ICP-MS Uranium-234, 235, 236, 238 in Solid | 788 | 12 | 785 | 0 |
| DRINKING WATER | | | | |
| Gamma Spec Drinking Water RAD A-013 | 122 | 1 | 295 | 33 |
| AIR CHARCOAL | | | | |
| Gamma Spec Filter RAD A-013 | 108 | 18 | 126 | 0 |
| FILTER | | | | |
| Nickel-63 | 0 | 0 | 115 | 0 |
| VEGETATION | | | | |
| Gamma Spec Solid RAD A-013 with Iodine | 264 | 3 | 302 | 0 |
| FILTER | | | | |
| Gross Alpha/Beta | 113 | 3 | 373 | 0 |
| SOLID | | | | |
| ICP-MS Uranium-235, 236, 238 Prep in Solid | 422 | 0 | 461 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Strontium 89 & 90 | 22 | 0 | 63 | 14 |
| LSC Nickel 63 | 92 | 0 | 82 | 0 |
| FILTER | | | | |
| ICP-MS Uranium-233, 234 Prep in Filter | 19 | 0 | 71 | 0 |
| ICP-MS Uranium-235, 236, 238 Prep in Filter | 26 | 0 | 85 | 0 |
| Alpha Spec Polonium,(Filter/Liter) | 0 | 0 | 63 | 0 |
| TISSUE | | | | |

| | | | | |
|--|-----|---|-----|---|
| Gas Flow Strontium 90 | 167 | 0 | 166 | 0 |
| LIQUID | | | | |
| LSC, Rapid Strontium 89 and 90 | 74 | 0 | 128 | 1 |
| TISSUE | | | | |
| LSC Iron-55 | 0 | 0 | 5 | 0 |
| FILTER | | | | |
| Carbon-14 | 18 | 1 | 106 | 1 |
| Gas Flow Pb-210 | 0 | 0 | 98 | 0 |
| Tritium | 487 | 0 | 589 | 0 |
| SOLID | | | | |
| Gross Alpha/Beta (Americium Calibration) Solid | 16 | 0 | 20 | 0 |
| LIQUID | | | | |
| LSC Radon 222 | 93 | 0 | 98 | 0 |
| SOLID | | | | |
| Alpha Spec Uranium | 112 | 5 | 159 | 0 |
| FILTER | | | | |
| LSC Promethium 147 | 8 | 0 | 35 | 0 |
| TISSUE | | | | |
| Alpha Spec Am241 Curium | 60 | 0 | 112 | 0 |
| LIQUID | | | | |
| Gross Alpha Co-precipitation | 6 | 0 | 138 | 1 |
| TISSUE | | | | |
| Alpha Spec Neptunium | 29 | 0 | 29 | 0 |
| AIR CHARCOAL | | | | |
| Carbon-14 | 11 | 0 | 23 | 0 |
| SOLID | | | | |
| Gamma Spec Solid with Ra226, Ra228 | 13 | 0 | 13 | 0 |
| AIR CHARCOAL | | | | |
| Gamma Spec Charcoal | 25 | 0 | 25 | 0 |
| LIQUID | | | | |
| LSC Phosphorus-32 | 3 | 0 | 3 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Total Alpha Radium | 122 | 1 | 123 | 0 |
| VEGETATION | | | | |
| Alpha Spec Uranium | 0 | 0 | 3 | 0 |
| SOLID | | | | |
| Alpha Spec Plutonium | 15 | 0 | 15 | 0 |
| VEGETATION | | | | |
| Alpha Spec Neptunium | 7 | 0 | 7 | 0 |
| LIQUID | | | | |
| Chlorine-36 in Liquids | 28 | 0 | 44 | 0 |
| FILTER | | | | |
| GFC Chlorine-36 in Filters PL | 0 | 0 | 17 | 2 |
| SOLID | | | | |

| | | | | |
|---|------|-----|------|---|
| ICP-MS Technetium-99 Prep in Soil | 18 | 0 | 9 | 0 |
| ICP-MS Technetium-99 in Soil | 18 | 0 | 9 | 0 |
| VEGETATION | | | | |
| Alpha Spec Plutonium | 0 | 0 | 9 | 0 |
| AIR CHARCOAL | | | | |
| Alpha Spec Uranium | 3 | 0 | 3 | 0 |
| DRINKING WATER | | | | |
| Gamma Iodine-129 | 3 | 0 | 8 | 0 |
| LIQUID | | | | |
| Gamma Iodine-129 | 814 | 1 | 987 | 0 |
| SOLID | | | | |
| Alpha Spec Uranium | 3137 | 106 | 3245 | 0 |
| Alpha Spec Neptunium | 1894 | 1 | 2105 | 1 |
| Gamma Spec Solid RAD A-013 | 7538 | 347 | 7612 | 0 |
| Gas Flow Radium 228 | 634 | 5 | 671 | 1 |
| Gross Alpha/Beta | 2270 | 65 | 2539 | 4 |
| Alpha Spec Plutonium | 1076 | 12 | 1128 | 1 |
| LSC Iron-55 | 808 | 3 | 821 | 0 |
| LIQUID | | | | |
| Chlorine-36 in Liquids | 89 | 1 | 166 | 0 |
| ICP-MS Uranium-234, 235, 236, 238 Prep in Liquid | 211 | 0 | 287 | 0 |
| ICP-MS Uranium-234, 235, 236, 238 in Liquid | 428 | 0 | 541 | 0 |
| Gamma Spec Liquid RAD A-013 | 3136 | 21 | 3282 | 0 |
| FILTER | | | | |
| Alphaspec Am241 Curium Filter per Liter | 4 | 0 | 213 | 0 |
| Lucas Cell Ra-226 | 31 | 0 | 119 | 0 |
| LIQUID | | | | |
| Alpha Spec Am243 | 110 | 1 | 162 | 0 |
| FILTER | | | | |
| LSC Iron-55 | 184 | 1 | 345 | 0 |
| LSC Nickel 63 | 19 | 0 | 97 | 0 |
| Alpha Spec Thorium | 160 | 0 | 507 | 1 |
| Gamma Nickel 59 RAD A-022 | 193 | 2 | 427 | 0 |
| Alpha Spec Plutonium | 136 | 1 | 716 | 0 |
| LIQUID | | | | |
| Alpha/Beta (Americium Calibration) Drinking Water | 130 | 0 | 129 | 1 |
| FILTER | | | | |
| LSC, Rapid Strontium 89 and 90 | 229 | 1 | 378 | 1 |
| Alpha Spec Am241Curium | 310 | 4 | 949 | 0 |
| Alpha Spec Uranium | 43 | 1 | 123 | 0 |
| SOLID | | | | |
| ICP-MS Uranium-233, 234 in Solid | 390 | 0 | 426 | 0 |

| | | | | |
|---|-----|---|------|---|
| MILK | | | | |
| Tritium | 6 | 0 | 20 | 0 |
| TISSUE | | | | |
| LSC Nickel 63 | 0 | 0 | 10 | 0 |
| VEGETATION | | | | |
| Gas Flow Total Radium | 11 | 1 | 12 | 0 |
| Technetium-99 | 12 | 0 | 12 | 0 |
| TISSUE | | | | |
| Tritium | 101 | 0 | 104 | 0 |
| FILTER | | | | |
| Technetium-99 | 0 | 0 | 106 | 0 |
| SOLID | | | | |
| Alpha Spec Radium 226 | 195 | 2 | 211 | 0 |
| FILTER | | | | |
| Alpha Spec Californium FPL | 0 | 0 | 37 | 0 |
| TISSUE | | | | |
| Technetium-99 | 92 | 0 | 88 | 0 |
| MILK | | | | |
| Gamma Spec Liquid RAD A-013 with Iodine | 7 | 0 | 12 | 0 |
| SOLID | | | | |
| GFC Chlorine-36 in Solids | 154 | 0 | 172 | 0 |
| VEGETATION | | | | |
| Carbon-14 | 23 | 0 | 26 | 0 |
| DRINKING WATER | | | | |
| ECLS-R-GA NJ 48 Hr Rapid Gross Alpha | 70 | 0 | 51 | 0 |
| MILK | | | | |
| Alpha Spec Am241 Curium | 1 | 0 | 4 | 0 |
| DRINKING WATER | | | | |
| Lucas Cell Radium 226 | 10 | 0 | 5 | 0 |
| MILK | | | | |
| Gamma Iodine-129 | 20 | 0 | 29 | 0 |
| SOLID | | | | |
| Alpha Spec Am241 (pCi/Sample) | 15 | 0 | 15 | 0 |
| Alpha Spec Thorium | 15 | 0 | 15 | 0 |
| Gross Alpha/Beta | 4 | 0 | 4 | 0 |
| LIQUID | | | | |
| Alpha Spec Uranium | 4 | 0 | 4 | 0 |
| SOLID | | | | |
| LSC Sulfur 35 | 6 | 0 | 6 | 0 |
| Organically Bound Tritium | 3 | 0 | 3 | 0 |
| FILTER | | | | |
| Gamma Spec Liquid RAD A-013 | 0 | 0 | 5 | 0 |
| LIQUID | | | | |
| Alpha Spec Neptunium | 991 | 0 | 1233 | 0 |

| | | | | |
|---|------|----|------|---|
| Alpha Spec Plutonium | 272 | 8 | 390 | 1 |
| Tritium | 6505 | 8 | 7440 | 5 |
| SOLID | | | | |
| Tritium | 2076 | 5 | 2536 | 1 |
| FILTER | | | | |
| Gross A & B | 1806 | 2 | 1424 | 0 |
| LIQUID | | | | |
| Gas Flow Total Radium | 1352 | 5 | 1473 | 0 |
| Gross Alpha Non Vol Beta | 4683 | 50 | 6237 | 7 |
| DRINKING WATER | | | | |
| Gas Flow Total Strontium | 77 | 0 | 68 | 0 |
| LIQUID | | | | |
| Gamma Spec Liquid RAD A-013 with Ba, La | 277 | 4 | 597 | 0 |
| Gas Flow Strontium 90 | 2496 | 16 | 3113 | 1 |
| SOLID | | | | |
| Alpha Spec Am243 | 728 | 14 | 818 | 0 |
| LIQUID | | | | |
| LSC Promethium 147 | 224 | 1 | 324 | 0 |
| Gas Flow Sr 2nd count | 316 | 0 | 618 | 1 |
| FILTER | | | | |
| LSC Plutonium Filter | 327 | 1 | 620 | 1 |
| VEGETATION | | | | |
| Alpha Spec Uranium | 145 | 2 | 164 | 0 |
| TISSUE | | | | |
| Alpha Spec Uranium | 8 | 0 | 8 | 0 |
| FILTER | | | | |
| LSC Nickel 63 | 217 | 0 | 439 | 1 |
| Gamma Spec Charcoal | 59 | 1 | 60 | 0 |
| Gamma Iodine 129 | 64 | 0 | 56 | 0 |
| SOLID | | | | |
| Gas Flow Lead 210 | 569 | 2 | 604 | 2 |
| LIQUID | | | | |
| Gas Flow Strontium 90 | 63 | 0 | 107 | 0 |
| MILK | | | | |
| Gamma Spec Liquid RAD A-013 | 26 | 0 | 213 | 0 |
| LIQUID | | | | |
| Gross Alpha Beta (Americium Calibration) Liquid | 180 | 3 | 424 | 0 |
| AIR CHARCOAL | | | | |
| Gamma Iodine 131 RAD A-013 | 874 | 0 | 1305 | 0 |
| VEGETATION | | | | |
| Alpha Spec Total Uranium | 64 | 1 | 32 | 0 |
| DRINKING WATER | | | | |
| LSC Radon 222 | 282 | 0 | 282 | 0 |
| VEGETATION | | | | |

| | | | | |
|------------------------------------|------|----|------|----|
| Gamma Spec Solid RAD A-013 | 286 | 2 | 244 | 0 |
| SOLID | | | | |
| Alpha Spec Polonium Solid | 34 | 0 | 34 | 0 |
| VEGETATION | | | | |
| Gas Flow Lead 210 | 12 | 0 | 12 | 0 |
| MILK | | | | |
| Gamma Iodine 131 RAD A-013 | 0 | 0 | 192 | 0 |
| FILTER | | | | |
| Alpha Spec Radium,Filter/Liter | 0 | 0 | 45 | 0 |
| LSC Selenium 79 | 0 | 0 | 50 | 0 |
| LIQUID | | | | |
| ICP-MS Technetium-99 Prep in Water | 79 | 0 | 101 | 0 |
| FILTER | | | | |
| Lucas Cell Radium-226 | 0 | 0 | 75 | 0 |
| LIQUID | | | | |
| Lucas Cell Radium-226 | 36 | 0 | 56 | 0 |
| FILTER | | | | |
| Alphaspec Np Filter per Liter | 4 | 0 | 55 | 0 |
| Gross Alpha Beta (Flame, Unflame) | 0 | 0 | 24 | 0 |
| MILK | | | | |
| Alpha Spec Plutonium | 1 | 0 | 4 | 0 |
| SOLID | | | | |
| LSC Phosphorus-32 | 3 | 0 | 6 | 0 |
| Alpha Spec Polonium Solid | 99 | 3 | 106 | 0 |
| LIQUID | | | | |
| Gas Flow Strontium 90 | 9 | 0 | 9 | 0 |
| DRINKING WATER | | | | |
| Gas Flow Lead 210 | 4 | 0 | 4 | 0 |
| LIQUID | | | | |
| Pyrolysis Oil Liquid units | 0 | 0 | 3 | 0 |
| DRINKING WATER | | | | |
| Gross Alpha Co-precipitation | 0 | 0 | 5 | 0 |
| LIQUID | | | | |
| Alpha Spec Thorium | 1079 | 3 | 1638 | 0 |
| LSC Iron-55 | 538 | 0 | 906 | 0 |
| DRINKING WATER | | | | |
| Gross Alpha Non Vol Beta | 1274 | 5 | 1368 | 17 |
| SOLID | | | | |
| Lucas Cell Radium 226 | 844 | 20 | 936 | 1 |
| TISSUE | | | | |
| Gamma Spec Solid RAD A-013 | 366 | 7 | 366 | 0 |
| SOLID | | | | |
| Gamma Spec Ra226 RAD A-013 | 546 | 6 | 522 | 0 |
| LIQUID | | | | |
| Gas Flow Lead 210 | 279 | 1 | 421 | 0 |

| | | | | |
|---|------|----|------|---|
| SOLID | | | | |
| Gas Flow Total Strontium | 586 | 6 | 673 | 0 |
| DRINKING WATER | | | | |
| Alpha/Beta (Americium Calibration) Drinking Water | 49 | 0 | 52 | 1 |
| SOLID | | | | |
| Carbon-14 | 1787 | 10 | 2219 | 5 |
| Gamma Iodine-129 | 735 | 0 | 1087 | 0 |
| LIQUID | | | | |
| LSC Selenium 79 | 342 | 0 | 407 | 0 |
| VEGETATION | | | | |
| Alpha Spec Am241 Curium | 76 | 0 | 100 | 0 |
| SOLID | | | | |
| Gas Flow Sr 2nd count | 105 | 0 | 134 | 1 |
| DRINKING WATER | | | | |
| LSC Iron-55 | 87 | 0 | 82 | 0 |
| FILTER | | | | |
| ICP-MS Uranium-233, 234 in Filter | 19 | 0 | 72 | 0 |
| VEGETATION | | | | |
| Gross Alpha/Beta | 66 | 0 | 66 | 0 |
| SOLID | | | | |
| ICP-MS Uranium-233, 234 Prep in Solid | 408 | 0 | 444 | 0 |
| LIQUID | | | | |
| Tritium in Drinking Water by EPA 906.0 | 74 | 0 | 111 | 3 |
| DRINKING WATER | | | | |
| Gamma Iodine-131 | 86 | 0 | 81 | 0 |
| SOLID | | | | |
| Gamma Spec Solid RAD A-013 with Iodine | 63 | 6 | 107 | 0 |
| LIQUID | | | | |
| ECLS-R-GA NJ 48 Hr Rapid Gross Alpha | 0 | 0 | 59 | 1 |
| DRINKING WATER | | | | |
| Iodine-131 | 0 | 0 | 67 | 0 |
| Gas Flow Radium 228 | 10 | 0 | 5 | 0 |
| VEGETATION | | | | |
| Tritium | 25 | 0 | 25 | 0 |
| TISSUE | | | | |
| Alpha Spec Thorium | 8 | 0 | 8 | 0 |
| FILTER | | | | |
| Total Activity in Filter, | 15 | 0 | 36 | 0 |
| TISSUE | | | | |
| Gamma Spec Solid RAD A-013 with Iodine | 24 | 0 | 30 | 0 |
| SOLID | | | | |
| Gamma Spec Liquid RAD A-013 | 25 | 0 | 21 | 0 |

| | | | | |
|--|------|----|------|----|
| FILTER | | | | |
| Gas Flow Radium 228 | 6 | 0 | 24 | 0 |
| SOLID | | | | |
| Gamma Spec Solid RAD A-013 with Ba, La | 3 | 0 | 3 | 0 |
| FILTER | | | | |
| ICP-MS Uranium-234, 235, 236, 238 Prep in Filter | 12 | 0 | 62 | 0 |
| LIQUID | | | | |
| Alpha Spec Polonium | 43 | 0 | 42 | 1 |
| VEGETATION | | | | |
| Alpha Spec Am241 (pCi/Sample) | 0 | 0 | 9 | 0 |
| SOLID | | | | |
| Gross Alpha Beta (F,U) | 19 | 0 | 19 | 0 |
| DRINKING WATER | | | | |
| Carbon-14 | 0 | 0 | 5 | 0 |
| LIQUID | | | | |
| ICP-MS Uranium-233, 234 in Liquid | 74 | 0 | 127 | 0 |
| ICP-MS Uranium-235, 236, 238 Prep in Liquid | 96 | 0 | 155 | 0 |
| ICP-MS Uranium-235, 236, 238 in Liquid | 160 | 0 | 267 | 2 |
| Carbon-14 | 1193 | 4 | 1510 | 2 |
| DRINKING WATER | | | | |
| Gas Flow Radium 228 | 681 | 1 | 754 | 6 |
| LIQUID | | | | |
| Gas Flow Radium 228 | 3257 | 26 | 4041 | 2 |
| Gas Flow Radium 228 | 63 | 0 | 99 | 0 |
| DRINKING WATER | | | | |
| Tritium | 164 | 0 | 155 | 0 |
| Gas Flow Strontium 90 | 261 | 0 | 272 | 18 |
| Lucas Cell Radium-226 | 614 | 0 | 739 | 1 |
| LIQUID | | | | |
| Iodine-131 | 0 | 0 | 345 | 0 |
| SOLID | | | | |
| LSC Nickel 63 | 1497 | 1 | 1678 | 6 |
| LIQUID | | | | |
| Radium 226 + 228 Sum (Result and TPU only) | 89 | 0 | 217 | 0 |
| FILTER | | | | |
| Gas Flow Ra-228 | 0 | 0 | 79 | 0 |
| LIQUID | | | | |
| Gross Alpha Beta (Flame, Unflame) | 1458 | 4 | 1487 | 1 |
| VEGETATION | | | | |
| Gas Flow Sr 2nd count | 23 | 0 | 26 | 0 |
| FILTER | | | | |
| Technetium-99 | 29 | 0 | 897 | 0 |

| | | | | |
|---|------|----|------|---|
| Gas Flow Strontium 90 | 64 | 3 | 485 | 0 |
| SOLID | | | | |
| Total Activity, | 89 | 0 | 96 | 0 |
| VEGETATION | | | | |
| Tritium | 135 | 1 | 140 | 0 |
| MILK | | | | |
| Gas Flow Total Strontium | 41 | 0 | 41 | 0 |
| SOLID | | | | |
| LSC, Rapid Strontium 89 and 90 | 239 | 3 | 268 | 0 |
| LIQUID | | | | |
| Alpha Spec Polonium | 92 | 0 | 132 | 0 |
| Gamma Iodine 131 RAD A-013 | 3 | 0 | 8 | 0 |
| FILTER | | | | |
| Gas Flow Lead 210 | 16 | 1 | 55 | 0 |
| AIR CHARCOAL | | | | |
| Gamma Iodine-129 | 100 | 0 | 100 | 0 |
| Gamma Iodine 129 | 26 | 0 | 26 | 0 |
| FILTER | | | | |
| ICP-MS Uranium-234, 235, 236, 238 in Filter | 24 | 0 | 124 | 0 |
| SOLID | | | | |
| Gas Flow Strontium 90 | 15 | 0 | 15 | 0 |
| FILTER | | | | |
| Filter Prep | 9 | 0 | 0 | 0 |
| Gas Flow Total Strontium | 13 | 0 | 16 | 0 |
| SOLID | | | | |
| Gamma Spec Solid RAD A-013 (pCi/Sample) | 17 | 0 | 17 | 0 |
| LIQUID | | | | |
| Gamma Spec Drinking Water RAD A-013 | 17 | 0 | 17 | 0 |
| AIR CHARCOAL | | | | |
| Alpha Spec Am241Curium | 3 | 0 | 3 | 0 |
| DRINKING WATER | | | | |
| Alpha Spec Thorium | 8 | 0 | 8 | 0 |
| LIQUID | | | | |
| Alpha Spec Uranium | 2843 | 77 | 3700 | 0 |
| LSC Nickel 63 | 754 | 3 | 1135 | 1 |
| Technetium-99 | 4005 | 2 | 3956 | 1 |
| Lucas Cell Radium 226 | 1860 | 19 | 2438 | 0 |
| Gas Flow Total Strontium | 652 | 5 | 747 | 0 |
| Gas Flow Total Alpha Radium | 73 | 0 | 133 | 0 |
| SOLID | | | | |
| LSC Plutonium | 1486 | 1 | 1658 | 3 |
| MILK | | | | |

| | | | | |
|---|------|----|------|---|
| Gamma Spec Liquid RAD A-013 with Ba, La | 100 | 0 | 276 | 0 |
| Gamma Iodine-131 | 40 | 0 | 280 | 0 |
| FILTER | | | | |
| Gamma Spec Filter RAD A-013 Direct Count | 12 | 0 | 35 | 0 |
| Alpha Spec U | 8 | 1 | 270 | 0 |
| Alpha Spec Uranium | 327 | 6 | 826 | 0 |
| Carbon-14 | 25 | 1 | 452 | 1 |
| Gamma Spec Filter RAD A-013 | 1266 | 63 | 1429 | 0 |
| Carbon-14 Direct Count | 0 | 0 | 59 | 0 |
| DRINKING WATER | | | | |
| Gamma Spec Liquid RAD A-013 | 35 | 0 | 35 | 0 |
| SOLID | | | | |
| Tritium | 203 | 0 | 190 | 0 |
| VEGETATION | | | | |
| Alpha Spec Plutonium | 18 | 0 | 21 | 0 |
| TISSUE | | | | |
| Gas Flow Sr 2nd count | 37 | 0 | 31 | 0 |
| DRINKING WATER | | | | |
| Gamma Spec Liquid RAD A-013 with Iodine | 0 | 0 | 36 | 0 |
| LIQUID | | | | |
| Total Activity, | 26 | 0 | 67 | 0 |
| MILK | | | | |
| Gas Flow Strontium 90 | 25 | 0 | 46 | 0 |
| DRINKING WATER | | | | |
| Alpha Spec Polonium | 9 | 0 | 9 | 0 |
| LIQUID | | | | |
| LSC Calcium 45 | 42 | 0 | 54 | 0 |
| FILTER | | | | |
| Alpha Spec Plutonium | 41 | 1 | 42 | 0 |
| ICP-MS Tc-99 in Filter | 0 | 0 | 11 | 0 |
| SOLID | | | | |
| ICP-MS U-234, 235, 236, 238 Prep per sample | 9 | 0 | 9 | 0 |
| VEGETATION | | | | |
| Alpha Spec Uranium | 0 | 0 | 9 | 0 |
| Gamma Spec Solid RAD A-013 (pCi/Sample) | 8 | 1 | 9 | 0 |
| FILTER | | | | |
| Gamma I-131, filter | 7 | 0 | 7 | 0 |
| VEGETATION | | | | |
| Gamma Iodine-129 | 3 | 0 | 3 | 0 |
| AIR CHARCOAL | | | | |
| Alpha Spec Plutonium | 3 | 0 | 3 | 0 |
| DRINKING WATER | | | | |

| | | | | |
|---------------|---|---|---|---|
| Technetium-99 | 5 | 0 | 5 | 0 |
|---------------|---|---|---|---|

Note 1: The RPD must be 20 percent or less, if both samples are greater than 5 times the MDC. If both results are less than 5 times MDC, then the RPD must be equal to or less than 100%. If one result is above the MDC and the other is below the MDC, then the RPD can be calculated using the MDC for the result of the one below the MDC. The RPD must be 100% or less. In the situation where both results are above the MDC but one result is greater than 5 times the MDC and the other is less than 5 times the MDC, the RPD must be less than or equal to 20%. If both results are below MDC, then the limits on % RPD are not applicable.

TABLE 8
2025 CORRECTIVE ACTION REPORT SUMMARY



CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 5/29/2025 | 2. CA Requester: GEL-QA | | | | | | | | | | | | | | | | | | | | |
|---|-------------------------|----------------|-----------------|------------------|-----------------|------------------|------------|-------------------------|-----------|------------|----------------|-----------------|-------------------------|------------|------------|-----------------|---------------|---------|------------|------------|------------------|
| 3. Nonconformance, Audit Finding, Problem, Complaint, or Improvement Opportunity Description: | | | | | | | | | | | | | | | | | | | | | |
| Summary of MRAD-42 Drinking Water Study Unacceptable Ratings | | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr style="background-color: #cccccc;"> <th style="padding: 5px;">Sample ID</th> <th style="padding: 5px;">Parameter</th> <th style="padding: 5px;">Reported Value</th> <th style="padding: 5px;">Reference Value</th> <th style="padding: 5px;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">MRAD Water</td> <td style="padding: 5px;">Uranium-234 (by ICP-MS)</td> <td style="padding: 5px;">114 pCi/L</td> <td style="padding: 5px;">98.2 pCi/L</td> <td style="padding: 5px;">74.8-112 pCi/L</td> </tr> <tr> <td style="padding: 5px;">MRAD Air Filter</td> <td style="padding: 5px;">Uranium-234 (by ICP-MS)</td> <td style="padding: 5px;">44.5 pCi/F</td> <td style="padding: 5px;">34.2 pCi/F</td> <td style="padding: 5px;">25.4-40.1 pCi/F</td> </tr> <tr> <td style="padding: 5px;">MRAD Water H3</td> <td style="padding: 5px;">Tritium</td> <td style="padding: 5px;">6450 pCi/L</td> <td style="padding: 5px;">9420 pCi/L</td> <td style="padding: 5px;">7100-11500 pCi/L</td> </tr> </tbody> </table> | | Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | MRAD Water | Uranium-234 (by ICP-MS) | 114 pCi/L | 98.2 pCi/L | 74.8-112 pCi/L | MRAD Air Filter | Uranium-234 (by ICP-MS) | 44.5 pCi/F | 34.2 pCi/F | 25.4-40.1 pCi/F | MRAD Water H3 | Tritium | 6450 pCi/L | 9420 pCi/L | 7100-11500 pCi/L |
| Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | | | | | | | | | | | | | | | | | |
| MRAD Water | Uranium-234 (by ICP-MS) | 114 pCi/L | 98.2 pCi/L | 74.8-112 pCi/L | | | | | | | | | | | | | | | | | |
| MRAD Air Filter | Uranium-234 (by ICP-MS) | 44.5 pCi/F | 34.2 pCi/F | 25.4-40.1 pCi/F | | | | | | | | | | | | | | | | | |
| MRAD Water H3 | Tritium | 6450 pCi/L | 9420 pCi/L | 7100-11500 pCi/L | | | | | | | | | | | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 250529-1607 | | | | | | | | | | | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT Failures in MRAD-42 | | | | | | | | | | | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Jennie Kill-Bowden and Greg Ramsay | | | | | | | | | | | | | | | | | | | | | |
| 7. Team Members: Liquid Scintillation and Rad-ICPMS analysts | | | | | | | | | | | | | | | | | | | | | |
| 8. Proposed Implementation Date: ASAP | | | | | | | | | | | | | | | | | | | | | |
| 9. Director, Quality Systems Approval: | Date: 5/29/2025 | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| 10. Containment Actions, if any: Upon receipt of the PT report, an investigation was initiated by the Quality Department and a Corrective Action (CARR) team assembled. The team consisted of representatives from the affected laboratories. The sample preparation and chemical separation processes were reviewed. This included review of reagents and standards used in the sample preparation steps, calibration records, process control samples, and data review. The investigation determined that the laboratory met all quality control criteria specified in each method. | | | | | | | | | | | | | | | | | | | | | |
| 11. Root Cause(s): Uranium-234: The laboratory reviewed the data and noted that the reference values were less than the Lc for the analysis. Both matrices were duplicated during analysis. The duplicates results were within limits and met replication criteria with RER <2. Both samples were run at a 10x dilution due to over range concentration of other isotopes. | | | | | | | | | | | | | | | | | | | | | |


Tritium: The laboratory reviewed the data and counting process for this sample and no errors were noted. It was noted that the duplicate meet acceptance criteria in the original preparation. The sample was prepared again in duplicate, and the results were within the acceptance criteria of the PT.


12. Actions to Prevent Potential Occurrence or Recurrence:
The laboratory will scrutinize dilutions to determine the most appropriate level to lessen the impact on the detection limits and non-detected results.


13. Implementation of Permanent Corrective/Preventive Actions or Improvements:
The lab will continue to monitor the recoveries of these parameters to ensure that there are no continued issues. During the analysis time period for MRAD-42, the laboratory successfully completed the analysis of other uranium isotopes in water and filters as well as Tritium in water in PT study MAPEP-52. In which, the samples were prepared and analyzed by the same processes and procedures.

14. Verify Corrective/preventive Action(s) or Improvement(s):
The lab will continue to monitor the performance of these methods and complete additional PT samples as they become available.

15. Lessons Learned. Who can benefit from Lessons Learned?
The Laboratory's objective is to provide accurate data at all times and assurances to our clients that GEL can meet acceptance criteria for the PT programs that it participates in. The laboratory and its clients benefit from continuous demonstration of laboratory proficiency using Performance Testing Samples.

16. Preparer's Name(s):
Amanda Fehr:

Date: 07/14/2025

17. Approval of Leader Responsible for implementation:
Jennie Kill-Bowden:

Date: 7/15/2025

Greg Ramsay:

Date: 7/15/25

Supplemental Pages Attached? Yes No

18. Reviewed and Approved by Director, Quality Systems:


Date: 7/15/2025



CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 06/06/2025 | 2. CA Requester: GEL-Quality | | | | | | | | | | | | | | | | | | | | |
|--|----------------------------------|---|--|---|-----------------|------------------|----------------|---------|-----------|-----------|----------------|----------------|----------------------------------|---|--|---|----------------|---------------------|-----------------------------|---------------------------|---------------------------------------|
| 3. Nonconformance, Audit Finding, Problem, Complaint or Improvement Opportunity Description: Unacceptable ratings were obtained for the following parameters associated with this study. | | | | | | | | | | | | | | | | | | | | | |
| Summary of MAPEP-52 Study Unacceptable Ratings | | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr style="background-color: #cccccc;"> <th style="padding: 5px;">Sample ID</th> <th style="padding: 5px;">Parm</th> <th style="padding: 5px;">Reported Value</th> <th style="padding: 5px;">Reference Value</th> <th style="padding: 5px;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">MAPEP-24-MaW52</td> <td style="padding: 5px;">Iron-55</td> <td style="padding: 5px;">35.2 Bq/L</td> <td style="padding: 5px;">25.5 Bq/L</td> <td style="padding: 5px;">17.9-33.2 Bq/L</td> </tr> <tr> <td style="padding: 5px;">MAPEP-24-MaW52</td> <td style="padding: 5px;">Copper Lead Nickel Zinc</td> <td style="padding: 5px;">51.1 mg/L 3.05 mg/L 0.305 mg/L 44.7 mg/L</td> <td style="padding: 5px;">0.510 mg/L 0.192 mg/L 0.193 mg/L 0.592 mg/L</td> <td style="padding: 5px;">0.357-0.663 mg/L 0.134-0.250 mg/L 0.135-0.251 mg/L 0.414-0.770</td> </tr> <tr> <td style="padding: 5px;">MAPEP-24-MaS52</td> <td style="padding: 5px;">Cadmium Thallium</td> <td style="padding: 5px;">0.408 mg/kg -0.926 mg/kg</td> <td style="padding: 5px;">0.696 mg/kg 1.10 mg/kg</td> <td style="padding: 5px;">0.0487-0.905 mg/kg 0.77-1.43 mg/kg</td> </tr> </tbody> </table> | | Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | MAPEP-24-MaW52 | Iron-55 | 35.2 Bq/L | 25.5 Bq/L | 17.9-33.2 Bq/L | MAPEP-24-MaW52 | Copper Lead Nickel Zinc | 51.1 mg/L 3.05 mg/L 0.305 mg/L 44.7 mg/L | 0.510 mg/L 0.192 mg/L 0.193 mg/L 0.592 mg/L | 0.357-0.663 mg/L 0.134-0.250 mg/L 0.135-0.251 mg/L 0.414-0.770 | MAPEP-24-MaS52 | Cadmium Thallium | 0.408 mg/kg -0.926 mg/kg | 0.696 mg/kg 1.10 mg/kg | 0.0487-0.905 mg/kg 0.77-1.43 mg/kg |
| Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | | | | | | | | | | | | | | | | | |
| MAPEP-24-MaW52 | Iron-55 | 35.2 Bq/L | 25.5 Bq/L | 17.9-33.2 Bq/L | | | | | | | | | | | | | | | | | |
| MAPEP-24-MaW52 | Copper Lead Nickel Zinc | 51.1 mg/L 3.05 mg/L 0.305 mg/L 44.7 mg/L | 0.510 mg/L 0.192 mg/L 0.193 mg/L 0.592 mg/L | 0.357-0.663 mg/L 0.134-0.250 mg/L 0.135-0.251 mg/L 0.414-0.770 | | | | | | | | | | | | | | | | | |
| MAPEP-24-MaS52 | Cadmium Thallium | 0.408 mg/kg -0.926 mg/kg | 0.696 mg/kg 1.10 mg/kg | 0.0487-0.905 mg/kg 0.77-1.43 mg/kg | | | | | | | | | | | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 250606-1612 | | | | | | | | | | | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT failures in MAPEP-52 | | | | | | | | | | | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Jennie Kill-Bowden and Edmund Frampton | | | | | | | | | | | | | | | | | | | | | |
| 7. Team Members: Radiochemistry and Metals analysts | | | | | | | | | | | | | | | | | | | | | |
| 8. Proposed Implementation Date: Immediately | | | | | | | | | | | | | | | | | | | | | |
| 9. Director, Quality Systems Approval: Date: 06/06/2025 <div style="text-align: center; font-family: cursive; font-size: 2em; margin-top: 20px;"> </div> | | | | | | | | | | | | | | | | | | | | | |
| 10. Containment Actions, if any: Following receipt of the PT report, the Quality Department initiated an investigation and formed a Corrective Action (CARR) team with representatives from the affected laboratories. The team reviewed sample preparation, reagents, calibration records, and conducted analyst interviews. The findings of the investigation confirmed that the laboratory adhered to all quality control criteria and followed internal procedures and policies as required. These failures were documented and tracked through GEL's internal non-conformance system, ensuring a systematic approach to addressing and resolving issues. | | | | | | | | | | | | | | | | | | | | | |

| |
|---|
| |
| <p>11. Root Cause(s):</p> <p>MAPEP-24-MaW52 (Fe-55): During the review of the analysis data, it was noted that the soil results for this study, while within limits, also had a high bias. The laboratory determined that the Fe-59 tracer contained trace amounts of impurities that were having an impact in older standard solutions. As the Fe-59 decays, the cross-talk subtraction does not account for the tracer activity added from the impurity.</p> <p>MAPEP-24-MaW52 (metals): All instrument and batch QC were within limits at the time of analysis. The laboratory reanalyzed the sample and results were within the acceptance limits of the PT study. The laboratory has concluded that an unidentified error occurred at the time of the original analysis.</p> <p>MAPEP-24-MaS52 (metals): The laboratory reviewed the analysis data and noted that there were no calibration or instrument QC issues.</p> <p>For cadmium, the assigned value was 0.696 mg/kg. Method 6010 reported an estimated result of 0.408 mg/kg with an MDL of 0.097 and a PQL of 0.489. Method 6020 reported 0.656 mg/kg. The low 6010 result fell below the PQL, triggering an estimated value flag which should have been further scrutinized when compared to the other method.</p> <p>For Thallium, the reference value was 1.10 mg/kg, below the laboratory's PQL of 2 mg/kg which can be challenging to interpret due to the uncertainty of method 6010. The Thallium results by method 6020 were within range and this is the more frequent method of analysis for Thallium.</p> |
| <p>12. Actions to Prevent Potential Occurrence or Recurrence:</p> <p>The laboratory will re-evaluate the Fe-55 cross talk calibration more frequently to determine if there is an impact from the ingrowing tracer impurities. The laboratory reanalyzed the sample and the results were within the acceptance limits of the PT.</p> <p>The laboratory will scrutinize results that are at or below the laboratory's detection limits including a comparison to method of similar technology.</p> |
| <p>13. Implementation of Permanent Corrective/Preventive Actions or Improvements:</p> <p>The laboratory successfully completed metals analysis in additional PTs SOIL-126 and WS-336. Additionally the laboratory successfully completed analysis of Fe-55 in water in MRAD-42.</p> |
| <p>14. Verify Corrective/preventive Action(s) or Improvement(s):</p> <p>The lab will continue monitoring the recoveries of these parameters across all methods to ensure there are no continued issues.</p> |
| <p>15. Lessons Learned. Who can benefit from Lessons Learned?</p> <p>The Laboratory's objective is to provide accurate data consistently, assuring clients that GEL can meet acceptance criteria for the PT programs that it participates in. Continuous use of Performance Testing Samples benefits both the lab and its clients by demonstrating ongoing proficiency.</p> |

CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 05/14/2025 | 2. CA Requester: GEL QA | | | | | | | | | | |
|--|-------------------------|----------------|-----------------|------------------|-----------------|------------------|----------------|-------|------------|------------|-----------------|
| 3. Nonconformance, Audit Finding, Problem, Complaint, or Improvement Opportunity Description: Unacceptable ratings were obtained for the following parameters associated with this study. | | | | | | | | | | | |
| Summary of ANA1Q25 Study Unacceptable Ratings | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Sample ID</th> <th style="width: 15%;">Parm</th> <th style="width: 15%;">Reported Value</th> <th style="width: 15%;">Reference Value</th> <th style="width: 15%;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">E13890 Milk</td> <td style="text-align: center;">Sr-90</td> <td style="text-align: center;">9.00 pCi/L</td> <td style="text-align: center;">15.6 pCi/L</td> <td style="text-align: center;">9.36-19.5 pCi/L</td> </tr> </tbody> </table> | | Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | E13890 Milk | Sr-90 | 9.00 pCi/L | 15.6 pCi/L | 9.36-19.5 pCi/L |
| Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | | | | | | | |
| E13890 Milk | Sr-90 | 9.00 pCi/L | 15.6 pCi/L | 9.36-19.5 pCi/L | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 250529-1606 | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT failures in ANA1Q25 | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Jennie Kill-Bowden | | | | | | | | | | | |
| 7. Team Members: REMP Strontium analysts | | | | | | | | | | | |
| 8. Proposed Implementation Date: Immediately | | | | | | | | | | | |
| 9. Director, Quality Systems Approval: Date: 5/14/2025 <div style="text-align: center; margin-top: 10px;"> </div> | | | | | | | | | | | |
| 10. Containment Actions, if any: Upon receipt of the PT report, an investigation was initiated by the Quality Department and a Corrective Action (CARR) team assembled. The team consisted of representatives from the affected laboratory. The sample preparation and analytical processes were reviewed. This included review of reagents and standards used in the sample preparation steps, calibration records, process control samples, and interviews with the analysts. The investigation determined that the laboratory met all quality control criteria specified in the method. Additionally, all internal procedures and policies were performed as required. These failures were tracked through GEL's internal non-conformance system. | | | | | | | | | | | |
| 11. Root Cause(s): The laboratory reviewed the data for this analysis and no errors were found. It was noted that the Yttrium carrier recovery was greater than is typically seen for this method which could cause a potential low bias in the results. Due to the Sr-89 result recovering greater than 100% in the acceptance limits, it is also suspected that an undetermined error occurred during the second separation resulting in a low Y-90 recovery. The duplicate sample in the analysis batch exhibited the same low bias but was within the acceptance range. | | | | | | | | | | | |




| | |
|--|--|
| <p>12. Actions to Prevent Potential Occurrence or Recurrence: None needed at this time. The laboratory will evaluate the standardization of the carriers used for analysis and monitor the recoveries of both the Sr and Y carriers.</p> | |
| <p>13. Implementation of Permanent Corrective/Preventive Actions or Improvements: The laboratory will complete an additional PT study for this parameter in 4th quarter of 2025.</p> | |
| <p>14. Verify Corrective/preventive Action(s) or Improvement(s): The lab will continue to monitor the recoveries of this parameter to ensure that there are no continued issues.</p> | |
| <p>15. Lessons Learned. Who can benefit from Lessons Learned? The Laboratory's objective is to provide accurate data at all times and assurances to our clients that GEL can meet acceptance criteria for the PT programs that it participates in. The laboratory and its clients benefit from continuous demonstration of laboratory proficiency using Performance Testing Samples.</p> | |
| <p>16. Preparer's Name(s): Amanda Fehr <i>Amanda L. Fehr</i> Date: 9/15/2025</p> | <p>17. Approval of Leader Responsible for implementation: Jennie Kill-Bowden <i>Jennie Kill-Bowden</i> Date: 9/15/2025</p> |
| <p>Supplemental Pages Attached? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> | |
| <p>18. Reviewed and Approved by Director, Quality Systems: <i>Ayla A. Gell</i> Date: 9/15/2025</p> | |

problem solved



CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 8/25/2025 | 2. CA Requester: GEL-QA | | | | | | | | | | | | | | | |
|---|-------------------------|----------------|-----------------|------------------|-----------------|------------------|-----------------|-------------------|------------|------------|-----------------|------------|-------|------------|------------|-----------------|
| 3. Nonconformance, Audit Finding, Problem, Complaint, or Improvement Opportunity Description: | | | | | | | | | | | | | | | | |
| Summary of RAD-142 Drinking Water Study Unacceptable Ratings | | | | | | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr style="background-color: #cccccc;"> <th style="padding: 5px;">Sample ID</th> <th style="padding: 5px;">Parameter</th> <th style="padding: 5px;">Reported Value</th> <th style="padding: 5px;">Reference Value</th> <th style="padding: 5px;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">Strontium 89/90</td> <td style="padding: 5px;">Sr-90 (905.0 Mod)</td> <td style="padding: 5px;">26.5 pCi/L</td> <td style="padding: 5px;">34.3 pCi/L</td> <td style="padding: 5px;">29.0-39.6 pCi/L</td> </tr> <tr> <td style="padding: 5px;">Iodine-131</td> <td style="padding: 5px;">I-131</td> <td style="padding: 5px;">22.8 pCi/L</td> <td style="padding: 5px;">28.3 pCi/L</td> <td style="padding: 5px;">24.5-32.1 pCi/L</td> </tr> </tbody> </table> | | Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | Strontium 89/90 | Sr-90 (905.0 Mod) | 26.5 pCi/L | 34.3 pCi/L | 29.0-39.6 pCi/L | Iodine-131 | I-131 | 22.8 pCi/L | 28.3 pCi/L | 24.5-32.1 pCi/L |
| Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | | | | | | | | | | | | |
| Strontium 89/90 | Sr-90 (905.0 Mod) | 26.5 pCi/L | 34.3 pCi/L | 29.0-39.6 pCi/L | | | | | | | | | | | | |
| Iodine-131 | I-131 | 22.8 pCi/L | 28.3 pCi/L | 24.5-32.1 pCi/L | | | | | | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 250825-1615 | | | | | | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT Failures in RAD-142 | | | | | | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Lois Buist | | | | | | | | | | | | | | | | |
| 7. Team Members: Gas Flow analysts | | | | | | | | | | | | | | | | |
| 8. Proposed Implementation Date: ASAP | | | | | | | | | | | | | | | | |
| 9. Director, Quality Systems Approval: Date: 8/25/2025 | | | | | | | | | | | | | | | | |
| 10. Containment Actions, if any: Following receipt of the Proficiency Testing (PT) report, the Quality Department initiated an investigation and formed a Corrective Action (CARR) team with representatives from the affected laboratories. The team reviewed sample preparation, reagents, calibration records, and conducted analyst interviews. The findings of the investigation confirmed that the laboratory adhered to all quality control criteria and followed internal procedures and policies as required. These failures were documented and tracked through GEL's internal non-conformance system, ensuring a systematic approach to addressing and resolving issues. | | | | | | | | | | | | | | | | |
| 11. Root Cause(s): Sr-90: The laboratory conducted a review of the Sr-90 batch in response to the failure. No anomalies were found during the assessment, and all sample yields exceeded 96%, suggesting that sample loss is unlikely. It was noted that the Sr-90 Laboratory Control Sample (LCS) yielded a result of 75%, indicating a low bias in the batch results. | | | | | | | | | | | | | | | | |

| | |
|--|--|
| <p>I-131: The laboratory has reviewed the data and found no errors. The sample preparations were reweighed, and it was determined that the originally reported net weight was biased high, resulting in a negatively biased final result. After reweighing the filter, the corrected result fell within the established acceptance limits.</p> | |
| <p>12. Actions to Prevent Potential Occurrence or Recurrence: Analysts have been reminded to strictly adhere to established taring and balance inspection protocols before initiating weighing procedures.</p> | |
| <p>13. Implementation of Permanent Corrective/Preventive Actions or Improvements: The laboratory will continue to monitor the analytical processes of these parameters to ensure that there are no continued issues.</p> | |
| <p>14. Verify Corrective/preventive Action(s) or Improvement(s): The laboratory will continue to monitor the performance of these methods and has scheduled future PT samples as well as single blind samples as they become available.</p> | |
| <p>15. Lessons Learned. Who can benefit from Lessons Learned? The Laboratory's objective is to provide accurate data consistently, assuring clients that GEL can meet acceptance criteria for the PT programs that it participates in. Continuous use of Performance Testing Samples benefits both the laboratory and its clients by demonstrating ongoing proficiency.</p> | |
| <p>16. Preparer's Name(s): Amanda Fehr  Date: 10/02/2025</p> | <p>17. Approval of Leader Responsible for implementation: Lois Santos  Date: 10/07/2025</p> |
| <p>Supplemental Pages Attached? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> | |
| <p>18. Reviewed and Approved by Director, Quality Systems:  Date: 10/7/2025</p> | |

problem solved



CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 12/31/2025 | 2. CA Requester: GEL-QA | | | | | | | | | | |
|--|-------------------------|-----------------|-----------------|----------------------|-----------------|------------------|-----------------|-------------|-----------------|-----------------|----------------------|
| 3. Nonconformance, Audit Finding, Problem, Complaint, or Improvement Opportunity Description: | | | | | | | | | | | |
| Summary of MRAD-43 Study Unacceptable Ratings | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="padding: 5px;">Sample ID</th> <th style="padding: 5px;">Parameter</th> <th style="padding: 5px;">Reported Value</th> <th style="padding: 5px;">Reference Value</th> <th style="padding: 5px;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">MRAD GAB filter</td> <td style="padding: 5px;">Gross Alpha</td> <td style="padding: 5px;">37.3 pCi/Filter</td> <td style="padding: 5px;">22.0 pCi/Filter</td> <td style="padding: 5px;">11.5-36.2 pCi/Filter</td> </tr> </tbody> </table> | | Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | MRAD GAB filter | Gross Alpha | 37.3 pCi/Filter | 22.0 pCi/Filter | 11.5-36.2 pCi/Filter |
| Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | | | | | | | |
| MRAD GAB filter | Gross Alpha | 37.3 pCi/Filter | 22.0 pCi/Filter | 11.5-36.2 pCi/Filter | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 251231-1664 | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT Failures in MRAD-43 | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Lois Santos | | | | | | | | | | | |
| 7. Team Members: Gross Alpha Beta analysts | | | | | | | | | | | |
| 8. Proposed Implementation Date: ASAP | | | | | | | | | | | |
| 9. Director, Quality Systems Approval: Date: 12/31/2025 | | | | | | | | | | | |
| 10. Containment Actions, if any: Upon receipt of the PT report, an investigation was initiated by the Quality Department and a Corrective Action (CARR) team assembled. The team consisted of representatives from the affected laboratories. The counting process was reviewed for this direct count filter. This included review of instrument run logs, calibration records, process control samples, and data review. The investigation determined that the laboratory met all quality control criteria. | | | | | | | | | | | |
| 11. Root Cause(s): A recount of the sample batch was performed to verify the initial results. The recount values were approximately two times higher than the original counts and failed to meet RPD and RER acceptance criteria, indicating variability between counts. The recount results were reported. The original analysis demonstrated a recovery of 107%, suggesting that the variability was due to analyst error during the counting process. | | | | | | | | | | | |
| 12. Actions to Prevent Potential Occurrence or Recurrence: Instrument performance, counting geometry, and sample positioning were reviewed with laboratory staff, and counting protocols were reinforced to minimize variability in future analyses. The laboratory will calculate an RPD between recounts to ensure that the results are comparable prior to reporting. | | | | | | | | | | | |

| | |
|--|--|
| <p>13. Implementation of Permanent Corrective/Preventive Actions or Improvements: The laboratory will continue to trend and monitor recoveries for these parameters to confirm that no recurring issues are present. During the MRAD-43 analysis timeframe, the laboratory successfully analyzed a Gross Alpha direct count filter as part of PT study MAPEP-53. The MAPEP-53 filters were processed and analyzed using the same methods, procedures, and instrumentation as MRAD-43, demonstrating acceptable method performance during this period.</p> | |
| <p>14. Verify Corrective/preventive Action(s) or Improvement(s): The lab will continue to monitor the performance of this method and complete additional PT samples as they become available.</p> | |
| <p>15. Lessons Learned. Who can benefit from Lessons Learned? The Laboratory's objective is to provide accurate data at all times and assurances to our clients that GEL can meet acceptance criteria for the PT programs that it participates in. The laboratory and its clients benefit from continuous demonstration of laboratory proficiency using Performance Testing Samples.</p> | |
| <p>16. Preparer's Name(s): Amanda Fehr:</p> <p><i>Amanda L. Fehr</i></p> <p>Date: 2/19/2026</p> | <p>17. Approval of Leader Responsible for implementation: Jennie Kill-Bowden (for Lois Santos):</p> <p><i>Jennie Kill-Bowden</i></p> <p>Date: 2/19/2026</p> |
| <p>Supplemental Pages Attached? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> | |
| <p>18. Reviewed and Approved by Director, Quality Systems:</p> <p><i>Ayla M. Gell</i></p> <p>Date: 2/19/2026</p> | |

problem solved



CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 12/19/2025 | 2. CA Requester: GEL-Quality | | | | | | | | | | | | | | | | | | | | |
|---|------------------------------|---------------------------|--------------------------|------------------------------------|-----------------|------------------|----------------|---------|----------------|----------------|---------------------|----------------|----------|------------|------------|-----------------|----------------|--------------------------|---------------------------|--------------------------|------------------------------------|
| 3. Nonconformance, Audit Finding, Problem, Complaint or Improvement Opportunity Description: Unacceptable ratings were obtained for the following parameters associated with this study. | | | | | | | | | | | | | | | | | | | | | |
| Summary of MAPEP-53 Study Unacceptable Ratings | | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr style="background-color: #cccccc;"> <th style="padding: 5px;">Sample ID</th> <th style="padding: 5px;">Parm</th> <th style="padding: 5px;">Reported Value</th> <th style="padding: 5px;">Reference Value</th> <th style="padding: 5px;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">MAPEP-25-RdF53</td> <td style="padding: 5px;">Zinc-65</td> <td style="padding: 5px;">8.84 Bq/sample</td> <td style="padding: 5px;">1.51 Bq/sample</td> <td style="padding: 5px;">1.06-1.96 Bq/sample</td> </tr> <tr> <td style="padding: 5px;">MAPEP-25-MaS53</td> <td style="padding: 5px;">Selenium</td> <td style="padding: 5px;">2.83 mg/kg</td> <td style="padding: 5px;">1.68 mg/kg</td> <td style="padding: 5px;">1.18-2.18 mg/kg</td> </tr> <tr> <td style="padding: 5px;">MAPEP-25-MaS53</td> <td style="padding: 5px;">Iron-55 Neptunium-237</td> <td style="padding: 5px;">1240 Bq/kg 0.465 Bq/kg</td> <td style="padding: 5px;">518 Bq/kg 18.35 Bq/kg</td> <td style="padding: 5px;">363-673 Bq/kg 12.85-23.86 Bq/kg</td> </tr> </tbody> </table> | | Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | MAPEP-25-RdF53 | Zinc-65 | 8.84 Bq/sample | 1.51 Bq/sample | 1.06-1.96 Bq/sample | MAPEP-25-MaS53 | Selenium | 2.83 mg/kg | 1.68 mg/kg | 1.18-2.18 mg/kg | MAPEP-25-MaS53 | Iron-55 Neptunium-237 | 1240 Bq/kg 0.465 Bq/kg | 518 Bq/kg 18.35 Bq/kg | 363-673 Bq/kg 12.85-23.86 Bq/kg |
| Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | | | | | | | | | | | | | | | | | |
| MAPEP-25-RdF53 | Zinc-65 | 8.84 Bq/sample | 1.51 Bq/sample | 1.06-1.96 Bq/sample | | | | | | | | | | | | | | | | | |
| MAPEP-25-MaS53 | Selenium | 2.83 mg/kg | 1.68 mg/kg | 1.18-2.18 mg/kg | | | | | | | | | | | | | | | | | |
| MAPEP-25-MaS53 | Iron-55 Neptunium-237 | 1240 Bq/kg 0.465 Bq/kg | 518 Bq/kg 18.35 Bq/kg | 363-673 Bq/kg 12.85-23.86 Bq/kg | | | | | | | | | | | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 251219-1645 | | | | | | | | | | | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT failures in MAPEP-53 | | | | | | | | | | | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Jennie Kill-Bowden, Tim Winters, and Edmund Frampton | | | | | | | | | | | | | | | | | | | | | |
| 7. Team Members: Radiochemistry and Metals analysts | | | | | | | | | | | | | | | | | | | | | |
| 8. Proposed Implementation Date: Immediately | | | | | | | | | | | | | | | | | | | | | |
| 9. Director, Quality Systems Approval: _____ Date: 12/19/2025 <div style="text-align: center; font-family: cursive; font-size: 1.2em;"> </div> | | | | | | | | | | | | | | | | | | | | | |
| 10. Containment Actions, if any: Following receipt of the PT report, the Quality Department initiated an investigation and formed a Corrective Action (CARR) team with representatives from the affected laboratories. The team reviewed sample preparation, reagents, calibration records, and conducted analyst interviews. The findings of the investigation confirmed that the laboratory adhered to all quality control criteria and followed internal procedures and policies as required. These failures were documented and tracked through GEL's internal non-conformance system, ensuring a systematic approach to addressing and resolving issues. | | | | | | | | | | | | | | | | | | | | | |

11. Root Cause(s):

MAPEP-25-MaS53 (Fe-55): The data was reviewed and it was noted that the known value is less than the laboratory's standard MDA for this analysis. The sample was recounted due to the result being less than the MDA. The reported count did not meet replication criteria when compared to the initial results.

MAPEP-25-MaS53 (Np-237): The reported result value was in units of pCi/g on the Certificate of Analysis instead of Bq/kg due to a login error. When this value is converted to the appropriate units, the sample recovers at 93% of the known value.

MAPEP-25-MaS53 (Se): All instrument and batch QC were within limits at the time of analysis. The laboratory reanalyzed the sample and results were within the acceptance limits of the PT study. The laboratory has concluded that an unidentified error occurred at the time of the original analysis.

MAPEP-25-RdF53 (Zn-65): Upon investigation, there was a transcription error in determining the average value to be reported. Had the correct value been used, the sample would have recovered at 103%

12. Actions to Prevent Potential Occurrence or Recurrence:

The laboratory will scrutinize results that are at or below the laboratory's detection limits including the use of a larger aliquot and longer count time to improve counting statistics. For future reporting, the laboratory will validate the set-up units for new analytes and will report values from the CofA to minimize reporting errors.

13. Implementation of Permanent Corrective/Preventive Actions or Improvements:

The laboratory successfully completed analysis for these analytes in PTs SOIL-132 and MRAD-43.

14. Verify Corrective/preventive Action(s) or Improvement(s):

The lab will continue monitoring the recoveries of these parameters across all methods to ensure there are no continued issues.

15. Lessons Learned. Who can benefit from Lessons Learned?

The Laboratory's objective is to provide accurate data consistently, assuring clients that GEL can meet acceptance criteria for the PT programs that it participates in. Continuous use of Performance Testing Samples benefits both the lab and its clients by demonstrating ongoing proficiency.

16. Preparer's Name(s):

Amanda Fehr:

Amanda L. Fehr

Date: 2/19/2026

17. Approval of Leader Responsible for implementation:

JKB

Jennie Kill-Bowden:

Date: 2/19/2026

Edmund Frampton:

Edmund Frampton

Date: 2/19/2026

Tim Winters:

Tim Winters

Date: 2/19/2026

Supplemental Pages Attached? Yes No




18. Reviewed and Approved by Director of Quality Systems:

Ayla M. Galt

Date: 2/19/2026

CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 12/12/2025 | 2. CA Requester: GEL-QA | | | | | | | | | | |
|---|-------------------------|----------------|-----------------|------------------|-----------------|------------------|-----------------|-------------------|------------|------------|-----------------|
| 3. Nonconformance, Audit Finding, Problem, Complaint, or Improvement Opportunity Description: | | | | | | | | | | | |
| Summary of RAD-143 Drinking Water Study Unacceptable Ratings | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="width: 15%;">Sample ID</th> <th style="width: 25%;">Parameter</th> <th style="width: 15%;">Reported Value</th> <th style="width: 15%;">Reference Value</th> <th style="width: 30%;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="text-align: left;">Strontium 89/90</td> <td style="text-align: left;">Sr-90 (905.0 Mod)</td> <td>35.7 pCi/L</td> <td>43.8 pCi/L</td> <td>37.6-50.0 pCi/L</td> </tr> </tbody> </table> | | Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | Strontium 89/90 | Sr-90 (905.0 Mod) | 35.7 pCi/L | 43.8 pCi/L | 37.6-50.0 pCi/L |
| Sample ID | Parameter | Reported Value | Reference Value | Acceptance Range | | | | | | | |
| Strontium 89/90 | Sr-90 (905.0 Mod) | 35.7 pCi/L | 43.8 pCi/L | 37.6-50.0 pCi/L | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 251212-1644 | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT Failures in RAD-143 | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Lois Santos | | | | | | | | | | | |
| 7. Team Members: Gas Flow analysts | | | | | | | | | | | |
| 8. Proposed Implementation Date: ASAP | | | | | | | | | | | |
| 9. Director, Quality Systems Approval: Date: 12/12/2025 | | | | | | | | | | | |
| | | | | | | | | | | | |
| <p>10. Containment Actions, if any: Following receipt of the Proficiency Testing (PT) report, the Quality Department initiated an investigation and formed a Corrective Action (CARR) team with representatives from the affected laboratories. The team reviewed sample preparation, reagents, calibration records, and conducted analyst interviews.</p> <p>The findings of the investigation confirmed that the laboratory adhered to all quality control criteria and followed internal procedures and policies as required. These failures were documented and tracked through GEL's internal non-conformance system, ensuring a systematic approach to addressing and resolving issues.</p> | | | | | | | | | | | |
| <p>11. Root Cause(s):</p> <p>Sr-90: The laboratory conducted a review of the analytical batch in response to the failure. It was noted that the recoveries of the Yttrium carrier were higher than is typically seen in this method, indicating a potential low bias in the batch results.</p> | | | | | | | | | | | |




| | |
|--|--|
| <p>12. Actions to Prevent Potential Occurrence or Recurrence: Analysts have reviewed all analytical procedures to ensure that all steps are being performed appropriately. In addition, the laboratory made and standardized new Strontium and Yttrium carriers for use in the analysis. The laboratory also re-verified all Sr-90 standards to ensure they meet acceptance criteria for use.</p> | |
| <p>13. Implementation of Permanent Corrective/Preventive Actions or Improvements: The laboratory will continue to monitor and evaluate the analytical processes of this parameter across all matrices to ensure that there are no continued issues.</p> | |
| <p>14. Verify Corrective/preventive Action(s) or Improvement(s): The laboratory will continue to monitor the performance of this method and has scheduled future PT samples as well as single blind samples as they become available. The laboratory successfully completed analysis for Sr-90 by 905.0 Modified method in all matrices in MRAD-43.</p> | |
| <p>15. Lessons Learned. Who can benefit from Lessons Learned? The Laboratory's objective is to provide accurate data consistently, assuring clients that GEL can meet acceptance criteria for the PT programs that it participates in. Continuous use of Performance Testing Samples benefits both the laboratory and its clients by demonstrating ongoing proficiency.</p> | |
| <p>16. Preparer's Name(s): Amanda Fehr  Date: 2/19/2026</p> | <p>17. Approval of Leader Responsible for implementation: Jennie Kill-Bowden (for Lois Santos)  Date: 2/19/2026</p> |
| <p>Supplemental Pages Attached? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> | |
| <p>18. Reviewed and Approved by Director, Quality Systems:  Date: 2/19/2026</p> | |

problem solved



CORRECTIVE/PREVENTIVE ACTION REQUEST AND REPORT (CARR)

| 1. Date Requested: 02/06/2026 | 2. CA Requester: GEL QA | | | | | | | | | | |
|---|-------------------------|----------------|-----------------|------------------|-----------------|------------------|----------------|-------|-----------|------------|------------------|
| <p>3. Nonconformance, Audit Finding, Problem, Complaint, or Improvement Opportunity Description: Unacceptable ratings were obtained for the following parameters associated with this study.</p> <p style="text-align: center;">Summary of ANA4Q25 Study Unacceptable Ratings</p> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <thead> <tr> <th style="padding: 5px;">Sample ID</th> <th style="padding: 5px;">Parm</th> <th style="padding: 5px;">Reported Value</th> <th style="padding: 5px;">Reference Value</th> <th style="padding: 5px;">Acceptance Range</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px; text-align: center;">E14411 Milk</td> <td style="padding: 5px; text-align: center;">Sr-89</td> <td style="padding: 5px; text-align: center;">119 pCi/L</td> <td style="padding: 5px; text-align: center;">84.9 pCi/L</td> <td style="padding: 5px; text-align: center;">50.9-110.3 pCi/L</td> </tr> </tbody> </table> | | Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | E14411 Milk | Sr-89 | 119 pCi/L | 84.9 pCi/L | 50.9-110.3 pCi/L |
| Sample ID | Parm | Reported Value | Reference Value | Acceptance Range | | | | | | | |
| E14411 Milk | Sr-89 | 119 pCi/L | 84.9 pCi/L | 50.9-110.3 pCi/L | | | | | | | |
| Is this issue potentially 10 CFR Part 21 reportable? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | 4. CARR No. 260210-1663 | | | | | | | | | | |
| 5. CA Title: ISO Documentation of PT failures in ANA4Q25 | | | | | | | | | | | |
| 6. Leader Assigned Responsibility for Implementation: Jennie Kill-Bowden | | | | | | | | | | | |
| 7. Team Members: REMP Strontium analysts | | | | | | | | | | | |
| 8. Proposed Implementation Date: Immediately | | | | | | | | | | | |
| <p>9. Director, Quality Systems Approval: _____ Date: 02/06/2026</p> <p style="text-align: center;"><i>Ayla A. GEL</i></p> | | | | | | | | | | | |
| <p>10. Containment Actions, if any: Upon receipt of the PT report, an investigation was initiated by the Quality Department and a Corrective Action (CARR) team assembled. The team consisted of representatives from the affected laboratory. The sample preparation and analytical processes were reviewed. This included review of reagents and standards used in the sample preparation steps, calibration records, process control samples, and interviews with the analysts.</p> <p>The investigation determined that the laboratory met all quality control criteria specified in the method. Additionally, all internal procedures and policies were performed as required. These failures were tracked through GEL's internal non-conformance system.</p> | | | | | | | | | | | |
| <p>11. Root Cause(s): The laboratory reviewed the data for the Sr-89 result in milk and attributed the failure to matrix interference associated with the high calcium content typical of milk. Calcium and other matrix constituents can co-precipitate or co-elute with strontium during the radiochemical separation process. Incomplete separation of calcium and other matrix components or performing the separation too rapidly and not allowing sufficient contact time for the ion exchange columns to remove interferences, may have contributed to the observed bias. The laboratory concluded that the high bias was caused by matrix</p> | | | | | | | | | | | |

| | |
|---|--|
| interference from calcium or an unknown constituent combined with incomplete chemical separation during sample preparation. | |
| <p>12. Actions to Prevent Potential Occurrence or Recurrence: Analysts have reviewed SOP steps for Sr-89 analysis in milk against current laboratory practice to confirm procedures are being followed as written. The SOP is being reviewed for possible updates to incorporate additional rinses that are more effective in removing interferences that are common in milk. In addition, the laboratory made and standardized new Strontium and Yttrium carriers for use in the analysis. The laboratory also evaluated the Sr-89 standards to ensure they meet acceptance criteria for use.</p> | |
| <p>13. Implementation of Permanent Corrective/Preventive Actions or Improvements: The laboratory will continue to monitor and evaluate the analytical processes of this parameter in milk to ensure that there are no continued issues.</p> | |
| <p>14. Verify Corrective/preventive Action(s) or Improvement(s): The laboratory will continue to monitor the performance of this method and has scheduled a future PT sample.</p> | |
| <p>15. Lessons Learned. Who can benefit from Lessons Learned? The Laboratory's objective is to provide accurate data at all times and assurances to our clients that GEL can meet acceptance criteria for the PT programs that it participates in. The laboratory and its clients benefit from continuous demonstration of laboratory proficiency using Performance Testing Samples.</p> | |
| <p>16. Preparer's Name(s): Amanda Fehr  Date: 03/10/2026</p> | <p>17. Approval of Leader Responsible for implementation: Jennie Kill-Bowden  Date: 3/11/2026</p> |
| Supplemental Pages Attached? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | |
| <p>18. Reviewed and Approved by Director, Quality Systems:  Date: 3/11/2026</p> | |

problem solved