

**From:** [Kim Conway](#)  
**To:** [James.Davis@fpl.com](mailto:James.Davis@fpl.com)  
**Subject:** Duane Arnold Environmental Review - Summary of June 1 Clarification Call on Responses to RCI AQN-5 and RAI GEN-2  
**Date:** Monday, June 1, 2026 5:56:00 PM

---

Hi Mike,

On June 1, 2026, during a teleconference, NextEra Energy Duane Arnold (NEDA) representatives provided clarification on responses to the NRC's environmental requests for confirmation of information (RCIs) and request for additional information (RAI) related to the Duane Arnold Energy Center (DAEC) potential restart (ML26135A218). The conversation was for clarification only. During the call, with respect to responses to RCI AQN-5 and RAI GEN-2, NEDA clarified that there are two auxiliary boilers at DAEC. One auxiliary boiler (Permit No. 4863) has been abandoned in place and there are no plans to return it to service or replace it. However, the other auxiliary boiler has been refurbished and will be placed back into service.

This email will be placed in ADAMS as a record of our discussion. If you have any questions, please let me know.

Thanks,

Kim