

NRC FORM 361
(08-15-2024)

U.S. NUCLEAR REGULATORY COMMISSION
OPERATIONS CENTER

APPROVED BY OMB: NO. 3150-0238

EXPIRES: 07/31/2026



**REACTOR PLANT EVENT
NOTIFICATION WORKSHEET**

Estimated burden per response to comply with this voluntary collection request: 30 minutes. The information provided will be used for evaluation of licensee event description, facility status and for input to the public website. Send comments regarding burden estimate to the FOIA, Library, and Information Collections Branch (T-6 A10M), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by email to Infocollects.Resource@nrc.gov, and the OMB reviewer at: OMB Office of Information and Regulatory Affairs, (3150-0238), Attn: Desk Officer for the Nuclear Regulatory Commission, 725 17th Street NW, Washington, DC 20503. The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless the document requesting or requiring the collection displays a currently valid OMB control number.

EN # 58310

NRC OPERATIONS TELEPHONE NUMBERS: PRIMARY - 301-816-5100 or 800-532-3469#, BACKUPS - [1st] 301-951-0550 or 800-449-3694#, [2nd] 301-415-0550 and [3rd] 301-415-0553. #Licensees who maintain their own ETS are provided these telephone numbers.
FAX - 301-816-5151, EMAIL - hoo.hoc@nrc.gov

Notification Time 1518 ET	Facility or Organization South Texas	Unit 1, 2	Name of Caller/Title Neil Rocha / Unit 1 Shift Manager		Call Back # 361-972-8614
Event Time & Zone 1221 CDT	Event Date 6/9/26	Power/Mode (At Time of Event) 100 / 1 (Both Units)		Power/Mode (At Time of Notification) 100 / 1 (Both Units)	
EVENT CLASSIFICATION		1-HR. NON-EMERGENCY 10 CFR 50.72(b)(1)		<input type="checkbox"/> (v)(A) Safe S/D Capability	AINA
<input type="checkbox"/> GENERAL EMERGENCY	GEN/AAEC	<input type="checkbox"/> TS Deviation	ADEV	<input type="checkbox"/> (v)(B) RHR Capability	AINB
<input type="checkbox"/> SITE AREA EMERGENCY	SIT/AAEC	4-HR. NON-EMERGENCY 10 CFR 50.72(b)(2)		<input type="checkbox"/> (v)(C) Control of Rad Release	AINC
<input type="checkbox"/> ALERT	ALE/AAEC	<input type="checkbox"/> (i) TS Required S/D	ASHU	<input type="checkbox"/> (v)(D) Accident Mitigation	AIND
<input type="checkbox"/> UNUSUAL EVENT	UNU/AAEC	<input type="checkbox"/> (iv)(A) ECCS Discharge to RCS	ACCS	<input type="checkbox"/> (xii) Offsite Medical	AMED
<input type="checkbox"/> 50.72 NON-EMERGENCY	(see next columns)	<input type="checkbox"/> (iv)(B) RPS Actuation (scram)	ARPS	<input type="checkbox"/> (xiii) Loss Comm/Asmt/Response	ACOM
<input type="checkbox"/> 10 CFR 73	D???	<input type="checkbox"/> (xi) Offsite Notification	APRE	60-DAY OPTIONAL 10 CFR 50.73(a)(1)	
<input type="checkbox"/> MATERIAL/EXPOSURE	B???	8-HR. NON-EMERGENCY 10 CFR 50.72(b)(3)		<input type="checkbox"/> Invalid Specified System Actuation	AINV
<input type="checkbox"/> FITNESS FOR DUTY	HFIT	<input type="checkbox"/> (ii)(A) Degraded Condition	ADEG	OTHER UNSPECIFIED REQUIREMENT (IDENTIFY)	
<input type="checkbox"/> OTHER UNSPECIFIED REQMT.	(see last column)	<input type="checkbox"/> (ii)(B) Unanalyzed Condition	AUNA	<input checked="" type="checkbox"/> 10 CFR 21.21(d)(3)(i)	NONR
<input type="checkbox"/> INFORMATION ONLY	NNF	<input type="checkbox"/> (iv)(A) Specified System Actuation	AESF	<input type="checkbox"/>	NONR

Event Description (Include: Systems affected, actuations and their initiating signals, causes, effect of event on plant, actions taken or planned, etc.) (Continue on Page 2)

Part 21 Initial Report - TE Connectivity MDR Relays On 06/09/26, STP Nuclear Operating Company (STPNOC) completed a Part 21 evaluation which identified a defect with TE Connectivity MDR styled relays (MDR 131-1 and MDR 134-1) manufactured after mid-year 2020. Since 2023, eleven (11) of these relays in both Unit 1 and Unit 2 have experienced premature failures resulting in Essential Chillers being inoperable and incapable of fulfilling their intended safety function. The relays were procured as commercial grade items and were dedicated by STPNOC solely for use at STP. Investigation determined that the relay failures resulted from overheating of the relay coils during operation. The vendor informed STP that a subcontractor responsible for rotor grinding produced relay rotors that were undersized and outside of specification. The reduced rotor dimensions resulted in a looser fit between the rotor and stator, reducing eddy currents and increasing coil current consumption. The increased coil wattage then generated excessive heat that caused the relay windings to short at the finish lead, resulting in relay failure. A written notification in accordance with 10 CFR 21.21(d)(3)(ii) will be provided within 30 days.

NRC Resident Inspector has been notified, 6/10/26 at 1330 CDT.

NOTIFICATIONS	YES	NO	WILL BE	Anything Unusual or not understood? <input type="checkbox"/> Yes (Explain above) <input checked="" type="checkbox"/> No Did all systems function as required? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (Explain above) Mode of operations until corrected (if applicable) N/A Additional Information continued on next page? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
NRC RESIDENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
STATE(s)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
LOCAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
OTHER GOV AGENCIES	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
MEDIA/PRESS RELEASE	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

NRC FORM 361
(08-15-2024)

U.S. NUCLEAR REGULATORY COMMISSION
OPERATIONS CENTER

REACTOR PLANT EVENT NOTIFICATION WORKSHEET (Continued)

EN # _____

RADIOLOGICAL RELEASES: CHECK OR FILL IN APPLICABLE ITEMS (specific details/explanations should be covered in event description)

<input type="checkbox"/> Liquid Release	<input type="checkbox"/> Gaseous Release	<input type="checkbox"/> Unplanned Release	<input type="checkbox"/> Planned Release	<input type="checkbox"/> Ongoing	<input type="checkbox"/> Terminated
<input type="checkbox"/> Monitored	<input type="checkbox"/> Unmonitored	<input type="checkbox"/> Offsite Release	<input type="checkbox"/> T.S. Exceeded	<input type="checkbox"/> RM Alarms	<input type="checkbox"/> Areas Evacuated
<input type="checkbox"/> Personnel Exposed or Contaminated		<input type="checkbox"/> Offsite Protection Actions Recommended		*State release path in description	

	Release Rate (Ci/sec)	% T.S. Limit	HOO Guide	Total Activity (Ci)	% T.S. Limit	HOO Guide
Noble Gas			0.1 Ci/sec			1000 Ci
Iodine			10 µCi/sec			0.01 Ci
Particulate			1 µCi/sec			1 mCi
Liquid (excluding tritium and dissolved noble gas)			10 µCi/min			0.1 Ci
Liquid (tritium)			0.2 Ci/min			5 Ci
TOTAL						

	Plant Stack	Condenser/Air Ejector	Main Steam Line	SG Blowdown	Other
RAD Monitor Readings					
Alarm Setpoints					
% T.S. Limit (If applicable)					

RCS OR SG TUBE LEAKS: CHECK OR FILL IN APPLICABLE ITEMS: (specific details/explanations should be covered in event description)

Location of the Leak (e.g., SG #, valve, pipe, etc.)

Leak Rate	Units: gpm/gpd	T. S. Limits	Sudden or Long-Term Development	
Leak Start Date	Time	Coolant Activity and Units:	Primary	Secondary

List of Safety Related Equipment not Operational

Event Description (Include: Systems affected, actuations and their initiating signals, causes, effect of event on plant, actions taken or planned, etc.) (Continued from Page 1)