



Entergy Operations, Inc.
P.O. Box 756
Port Gibson, Mississippi 39150

Jeffery A. Hardy
Director Regulatory & Emergency
Preparedness
Grand Gulf Nuclear Station
Tel: 802-380-5124

10 CFR 50.73

GNRO2026-00024

July 13, 2026

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Grand Gulf Nuclear Station, Unit 1 Licensee Event Report 2026-004-00,
Manual Actuation of Standby Service Water System Due to an Open
Safety Relief Valve

Grand Gulf Nuclear Station, Unit 1
Docket No. 50-416
Renewed License No. NPF-29

Attached is Licensee Event Report (LER) 2026-004-00, Manual Actuation of Standby Service Water System Due to an Open Safety Relief Valve. This report is being made in accordance with 10 CFR 50.73(a)(2)(iv)(A) for any event that resulted in manual actuation of emergency service water systems that do not normally run and serve as the ultimate heat sinks.

This letter contains no new Regulatory Commitments. Should you have any questions concerning the content of this letter, please contact me at 802-380-5124.

Sincerely,

Digitally signed by Jeff
Signature
DN: cn=Jeff Signature,
c=US,
email=jhardy@entergy.com
Date: 2026.07.09 14:38:19
-05'00'

A handwritten signature in blue ink, appearing to read 'JA Hardy', is placed over the digital signature information.

JAH/der

Attachments: Licensee Event Report 2026-004-00

cc: NRC Senior Resident Inspector
Grand Gulf Nuclear Station
Port Gibson, MS 39150

U.S Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Attachment
Licensee Event Report 2026-004-00

NRC FORM 366 (05-05-2026)			U.S. NUCLEAR REGULATORY COMMISSION			APPROVED BY OMB: NO. 3150-0104			EXPIRES: 04/30/2027														
 LICENSEE EVENT REPORT (LER) (See Page 3 for required number of digits/characters for each block) (See NUREG-1022, R.3 for instruction and guidance for completing this form http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1022/r3/)												Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Library, and Information Collections Branch (T-6 A10M), U. S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by email to Infocollections.Resource@nrc.gov, and the OMB reviewer at: OMB Office of Information and Regulatory Affairs, (3150-0104), Attn: Desk Officer for the Nuclear Regulatory Commission, 725 17th Street NW, Washington, DC 20503. The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless the document requesting or requiring the collection displays a currently valid OMB control number.											
1. Facility Name Grand Gulf Nuclear Station, Unit 1						☒ 050 ☐ 052 ☐ 053		2. Docket Number 00416		3. Page 1 OF 2													
4. Title Manual Actuation of Standby Service Water System Due to an Open Safety Relief Valve																							
5. Event Date			6. LER Number			7. Report Date																	
Month	Day	Year	Year	Sequential Number	Revision No.	Month	Day	Year															
05	12	2026	2026	- 004 -	00	07	13	2026															
8. Other Facilities Involved																							
Facility Name N/A								☐ 050	Docket Number														
Facility Name N/A								☐ 052	Docket Number														
Facility Name N/A								☐ 053	Docket Number														
9. Operating Mode 1						10. Power Level 100																	
11. This Report is Submitted Pursuant to the Requirements of 10 CFR §: (Check all that apply)																							
10 CFR Part 20		☐ 20.2203(a)(3)(i)	☐ 50.69(g)	☐ 50.73(a)(2)(v)(C)	☐ 53.1640(a)(2)(ii)(A)	☐ 73.77(a)(1)(ii)																	
☐ 20.2201(b)	☐ 20.2203(a)(3)(ii)	☐ 50.73(a)(2)(i)(A)	☐ 50.73(a)(2)(v)(D)	☐ 53.1640(a)(2)(ii)(B)	☐ 73.77(a)(2)(i)(A)																		
☐ 20.2201(d)	☐ 20.2203(a)(4)	☐ 50.73(a)(2)(i)(B)	☐ 50.73(a)(2)(vii)	☐ 53.1640(a)(2)(iii)	☐ 73.77(a)(2)(i)(B)																		
☐ 20.2203(a)(1)	10 CFR Part 21	☐ 50.73(a)(2)(i)(C)	☐ 50.73(a)(2)(viii)(A)	☐ 53.1640(a)(2)(iv)	☐ 73.1200(a)																		
☐ 20.2203(a)(2)(i)	☐ 21.2(c)	☐ 50.73(a)(2)(ii)(A)	☐ 50.73(a)(2)(viii)(B)	☐ 53.1640(a)(2)(v)	☐ 73.1200(b)																		
☐ 20.2203(a)(2)(ii)	10 CFR Part 50	☐ 50.73(a)(2)(ii)(B)	☐ 50.73(a)(2)(ix)(A)	☐ 53.1640(a)(2)(vii)(A)	☐ 73.1200(c)																		
☐ 20.2203(a)(2)(iii)	☐ 50.36(c)(1)(i)(A)	☐ 50.73(a)(2)(iii)	☐ 50.73(a)(2)(x)	☐ 53.1640(a)(2)(viii)(A)	☐ 73.1200(d)																		
☐ 20.2203(a)(2)(iv)	☐ 50.36(c)(1)(ii)(A)	☒ 50.73(a)(2)(iv)(A)	10 CFR Part 53	☐ 53.1640(a)(2)(viii)(B)	☐ 73.1200(e)																		
☐ 20.2203(a)(2)(v)	☐ 50.36(c)(2)	☐ 50.73(a)(2)(v)(A)	☐ 53.1640(a)(2)(i)(A)	☐ 53.1640(a)(2)(ix)	☐ 73.1200(f)																		
☐ 20.2203(a)(2)(vi)	☐ 50.46(a)(3)(ii)	☐ 50.73(a)(2)(v)(B)	☐ 53.1640(a)(2)(i)(B)	10 CFR Part 73	☐ 73.1200(g)																		
				☐ 53.1640(a)(2)(i)(C)	☐ 73.77(a)(1)(i)	☐ 73.1200(h)																	
☐ OTHER (Specify here, in abstract, or NRC 366A).																							
12. Licensee Contact for this LER																							
Licensee Contact Jeff Hardy, Director of Regulatory and Emergency Preparedness								Phone Number (Include area code) 802-380-5124															

LICENSEE EVENT REPORT (LER) (Continued)

13. Complete One Line for each Component Failure Described in this Report

Cause	System	Component	Manufacturer	Reportable to IRIS		Cause	System	Component	Manufacturer	Reportable to IRIS

14. Supplemental Report Expected

☒ No

☐ Yes (If yes, complete 15. Expected Submission Date)

15. Expected Submission Date

Month	Day	Year

16. Abstract

On May 12, 2026, at 1940 CDT, the Control Room received alarm 1H13-P601-18A-G2 ADS/SRV LEAK. The operators observed indications of Safety Relief Valve (SRV) chattering and fluctuations in Suppression Pool levels. SRV 1B21F041B showed an elevated tailpipe temperature. At 1948 CDT, SRV 1B21F041B indicated fully open and the tailpipe temperature continued to increase. The operators entered an Off-Normal Event procedure, that directed them to reduce Core Flow and lower reactor power. Reactor power was stabilized at 58 percent. At 1953 CDT, Standby Service Water A and B trains were activated in conjunction with Residual Heat Removal A and B trains using the manual initiation pushbuttons in order to lower suppression pool temperatures. At 1959 CDT, SRV 1B21F041B closed after maintenance technicians pulled Division 1 fuses.

This report is being made in accordance with 10 CFR 50.73(a)(2)(iv)(A) for any event that resulted in manual actuation of emergency service water systems that do not normally run and serve as the ultimate heat sinks.



LICENSEE EVENT REPORT (LER) CONTINUATION SHEET

(See NUREG-1022, R.3 for instruction and guidance for completing this form
<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1022/r3/>)

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Library, and Information Collections Branch (T-6 A10M), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by email to Infocollects.Resource@nrc.gov, and the OMB reviewer at: OMB Office of Information and Regulatory Affairs, (3150-0104), Attn: Desk Officer for the Nuclear Regulatory Commission, 725 17th Street NW, Washington, DC 20503. The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless the document requesting or requiring the collection displays a currently valid OMB control number.

1. FACILITY NAME	☒ 050 ☐ 052 ☐ 053	2. DOCKET NUMBER	YEAR	3. LER NUMBER	REV NO.
Grand Gulf Nuclear Station, Unit 1		00416	2026	004	00

NARRATIVE

Plant Conditions:

At the time of the event, Grand Gulf Nuclear Station (GGNS), Unit 1 was in MODE 1 at 100 percent power and all safety systems were operable.

Description of Event:

On May 12, 2026, at 1940 CDT, the Control Room received alarm 1H13-P601-18A-G2 ADS/SRV LEAK. The operators observed indications of Safety Relief Valve (SRV) [RV] chattering and fluctuations in Suppression Pool levels. SRV 1B21F041B showed an elevated tailpipe temperature. At 1948 CDT, SRV 1B21F041B indicated fully open and the tailpipe temperature continued to increase. The operators entered an Off-Normal Event procedure, that directed them to reduce Core Flow and lower reactor power. Reactor power was stabilized at 58 percent. At 1953 CDT, Technical Specification (TS) Limiting Condition of Operations (LCO) 3.6.2.1 for suppression pool temperature was entered, and Standby Service Water (SSW) A and B trains were activated in conjunction with Residual Heat Removal (RHR) A and B trains using the manual initiation pushbuttons in order to lower suppression pool temperatures. At 1954 CDT, T.S LCO 3.6.2.2 for suppression pool water level was entered. At 1959 CDT, SRV 1B21F041B closed after maintenance technicians pulled Division 1 fuses. TS LCO 3.6.2.1 was exited at 2021 CDT, and LCO 3.6.2.2 was exited at 2131 CDT

Reportability:

This report is being made in accordance with 10 CFR 50.73(a)(2)(iv)(A) for any event that resulted in manual actuation of emergency service water systems that do not normally run and serve as the ultimate heat sinks.

Cause(s):

SRV 1B21F041B failed open due to the presence of simultaneous Division 1 DC grounds that energized the SRV solenoid and caused the valve actuation. The failure involved wiring degradation and was not a result of human error, programmatic weakness, or procedural deficiency. The wiring degradation was most likely caused by elevated temperatures and humidity in area.

Corrective Actions:

Completed Action: Located and isolated the ground on the Division 1 battery bus which caused SRV 1B21F041B to open
Scheduled Action: Benchmark the industry to determine if our threshold for action in response to our ground monitoring system parameters is appropriate.

Safety Significance:

The SSW system is an essential auxiliary supporting system which provides a reliable source of cooling for plant auxiliaries that are essential to a safe reactor shutdown following a design-basis loss-of-coolant accident (LOCA). The ultimate heat sink, consisting of the SSW system cooling towers and makeup basins, provides heat rejection and makeup water required for the dissipation of heat to permit the safe shutdown and cooldown of the plant and to maintain it in a safe shutdown condition.

There were no actual safety consequences associated with this condition.

Previous Similar Events:

There have been no previous Licensee Event Reports at GGNS within the last three years involving a ground fault on an SRV requiring actuation of emergency service water systems that do not normally run and serve as ultimate heat sinks.