



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 5, 2026

Mr. Joseph Quinn
Vice President, Fleet Support
Tennessee Valley Authority
1101 Market Street, LP 4A-C
Chattanooga, TN 37402-2801

SUBJECT: WATTS BAR NUCLEAR PLANT, UNIT 1 – OMISSION OF TECHNICAL SPECIFICATION PAGE DURING ISSUANCE OF LICENSE AMENDMENT NO. 186 REGARDING ADOPTION OF TSTF-596, REVISION 2; AND ADOPTION OF TSTF-374, REVISION 0, TSTF-188, REVISION 0, AND TSTF-600, REVISION 2 (EPID L-2026-LLA-0034)

Dear Mr. Quinn:

The purpose of this letter is to issue a technical specification (TS) page for Watts Bar Nuclear Plant (Watts Bar), Unit 1, Facility Operating License No. NPF-90.

During issuance of Amendment No. 186 (Agencywide Documents and Management System (ADAMS) Accession No. ML26258A272) dated September 25, 2026, the U.S. Nuclear Regulatory Commission (NRC) staff inadvertently omitted Watts Bar, Unit 1, TS page 5.0-25c, which was listed in the Attachment to Amendment No. 186 as a page that should be replaced.

Enclosed, please find TS page 5.0-25c for Watts Bar, Unit 1.

If you have any questions regarding this matter, please contact me at (301) 415-1627 or by email at Kimberly.Green@nrc.gov.

Sincerely,

/RA/

Kimberly J. Green, Senior Project Manager
Operating Reactor Licensing Branch 4
Division of Licensing Projects I
Office of Nuclear Reactor Regulation

Docket No. 50-390

Enclosure:
TS Page 5.0-25c

cc: Listserv

SUBJECT: WATTS BAR NUCLEAR PLANT, UNIT 1 – OMISSION OF TECHNICAL SPECIFICATION PAGE DURING ISSUANCE OF LICENSE AMENDMENT NO. 186 REGARDING ADOPTION OF TSTF-596, REVISION 2; AND ADOPTION OF TSTF-374, REVISION 0, TSTF-188, REVISION 0, AND TSTF-600, REVISION 2 (EPID L-2026-LLA-0034) DATED OCTOBER 5, 2026

DISTRIBUTION:

PUBLIC

RidsACRS_MailCTR Resource

RidsNrrDlp1Orlb4 Resource

RidsNrrPMWatts Bar Resource

RidsNrrLAPBlechman

RidsRgn2MailCenter Resource

ADAMS Accession Nos.:

Package: ML26278A022

Document: ML26278A032

e-Concurrence Case: 20261005-02723

ENCLOSURE

WATTS BAR NUCLEAR PLANT, UNIT NO. 1

DOCKET NO. 50-390

TECHNICAL SPECIFICATION PAGE 5.0-25c

5.7 Procedures, Programs, and Manuals

5.7.2.23 Surveillance Frequency Control Program

This program provides controls for Surveillance Frequencies and the frequencies of other periodic testing required by these Technical Specifications (herein also referred to as Surveillance Frequencies). The program shall ensure that Surveillance Requirements and other required testing specified in these Technical Specifications are performed at intervals sufficient to assure the associated Limiting Conditions for Operation and other requirements are met.

- a. The Surveillance Frequency Control Program shall contain a list of Frequencies controlled by the programs that govern the activities listed in items b.1, b.2, and b.3.
- b. Changes to the Frequencies listed in the Surveillance Frequency Control Program shall be made:
 - 1. In accordance with the requirements of 10 CFR 50.55a for the Inservice Testing Program required by 10 CFR 50.55a(f);
 - 2. In accordance with the requirements of 10 CFR 50.69(d)(2) for testing permitted under 10 CFR 50.69(b)(1)(v);
 - 3. Otherwise, in accordance with NEI 04-10, "Risk-Informed Method for Control of Surveillance Frequencies," Revision 1, or as specifically approved by the NRC.
- c. The provisions of Surveillance Requirements 3.0.2 and 3.0.3 are applicable to the Frequencies established in the Surveillance Frequency Control Program, except:
 - 1. The SR 3.0.2 test interval extensions for components in the Inservice Testing Program cannot exceed those allowed by the ASME OM Code as incorporated by reference in 10 CFR 50.55a; and
 - 2. Surveillance Requirement 3.0.3 is only applicable to other required testing when invoked by a Chapter 5 Specification.

(continued)