

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.4.6 Verify each battery charger supplies ≥ 300 amps at ≥ 130 V for ≥ 8 hours.	18 months
SR 3.8.4.7 -----NOTES----- 1. The modified performance discharge test in SR 3.8.4.8 may be performed in lieu of the service test in SR 3.8.4.7*. 2. Verify requirement during MODES 3, 4, 5, 6 or with core off-loaded. ----- Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test.	18 months

(continued)

* On a one time basis, for battery BT1ED2, a performance discharge test may be performed in lieu of the battery service test required by Specification 3.8.4.7, twice within a 60 month interval. This one time exception expires prior to entry into MODE 4 following the next Unit 1 outage of sufficient duration to perform a service test.

9909030136 990827
PDR ADOCK 05000445
P PDR