



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

TXU ELECTRIC COMPANY
COMANCHE PEAK STEAM ELECTRIC STATION, UNIT 1
DOCKET NO. 50-445
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 69
License No. NPF-87

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by TXU Electric Company (TXU Electric) dated June 23, 1999, as supplemented by letter dated August 4, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-87 is hereby amended to read as follows:


9909270069 990921
PDR ADOCK 05000445
P PDR

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 69 , and the Environmental Protection Plan contained in Appendix B are hereby incorporated into this license. TXU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Gramm, Chief, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: September 21, 1999



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

TXU ELECTRIC COMPANY
COMANCHE PEAK STEAM ELECTRIC STATION, UNIT 2
DOCKET NO. 50-446
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 69
License No. NPF-89

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by TXU Electric Company (TXU Electric) dated June 23, 1999, as supplemented by letter dated August 4, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-89 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 69 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. TXU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Gramm, Chief, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: September 21, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 69
TO FACILITY OPERATING LICENSE NO. NPF-87
AND AMENDMENT NO. 69
FACILITY OPERATING LICENSE NO. NPF-89
DOCKET NOS. 50-445 AND 50-446

Replace the following page of the Appendix A Technical Specifications with the attached revised page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

Remove

Insert

3.8-11

3.8-11

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.12 -----NOTES-----</p> <ol style="list-style-type: none"> 1. All DG starts may be preceded by prelube period. 2. Verify requirement during MODES 3, 4, 5, 6 or with core off-loaded. <p>-----</p> <p>Verify on an actual or simulated Safety Injection (SI) actuation signal each DG auto-starts from standby condition and:</p> <ol style="list-style-type: none"> a. In ≤ 10 seconds after auto-start and during tests, achieves voltage ≥ 6480 V and frequency ≥ 58.8 Hz; b. Achieves steady state voltage ≥ 6480 V and ≤ 7150 V and frequency ≥ 58.8 Hz and ≤ 61.2 Hz; c. Operates for ≥ 5 minutes; 	<p>18 months</p>
<p>SR 3.8.1.13 -----NOTE-----</p> <ol style="list-style-type: none"> 1. Verify requirement during MODES 3, 4, 5, 6 or with core off-loaded. 2. For Unit 2, testing need only be performed for LOOP concurrent with SI until startup following 2RFO5. <p>-----</p> <p>Verify each DG's automatic trips are bypassed on actual or simulated (i) loss of voltage signal on the emergency bus, and (ii) SI actuation signal, except:</p> <ol style="list-style-type: none"> a. Engine overspeed; and b. Generator differential current. 	<p>18 months</p>

(continued)