

Commonwealth Edison Company
LaSalle Generating Station
2601 North 21st Road
Marseilles, IL 61341-9757
Tel 815-357-6761



October 26, 1999

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

LaSalle County Station, Units 1 and 2
Facility Operating License Nos. NPF-11 and NPF-18
NRC Docket Nos. 50-373 and 50-374

Subject: Licensee Event Report

In accordance with 10 CFR 50.73(a)(2)(i), Commonwealth Edison (ComEd) Company is submitting Licensee Event Report #99-005-00, Docket No. 050-373.

Attachment A provides the commitment(s) for this submittal.

Should you have any questions concerning this letter, please contact Mr. Frank A. Spangenberg, III, Regulatory Assurance Manager, at (815) 357-6761, extension 2383.

Respectfully,

A handwritten signature in black ink that reads "Jeffrey A. Benjamin". The signature is fluid and cursive.

Jeffrey A. Benjamin
Site Vice President
LaSalle County Station

Attachments: Regulatory Commitment(s) - Attachment A
Licensee Event Report

cc: Regional Administrator - NRC Region III
NRC Senior Resident Inspector - LaSalle County Station

291-027

IE22/1

Attachment A
Regulatory Commitment(s)

ComEd is committing to the following action. Any other actions discussed in this submittal represent intended or planned actions by ComEd. They are described to the NRC for the NRC's information and are not regulatory commitments.

<i>Regulatory Commitment(s)</i>	<i>Tracking Number</i>
A needs analysis will be performed to ensure that the station personnel training program includes the appropriate level of detail regarding TS 3/4.3.1 and the requirement for both flow converters to be operable in order for the flow biased thermal trip to be operable.	ATM#16802-24