

**REQUEST FOR AMENDMENT
TECHNICAL SPECIFICATIONS SR 3.8.4.6 and SR 3.8.5.1
(REPLACEMENT PAGES)**

Attachment

Replacement Pages

Technical Specifications SR 3.8.4.6 and SR 3.8.5.1 Amendment Request

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.5 Verify battery connection resistance is ≤ 24.4 E-6 ohms for inter-cell connectors of the Division 1 and 2 batteries, ≤ 169 E-6 ohms for inter-cell connectors of the Division 3 battery, and $\leq 20\%$ above the resistance as measured during installation for inter-tier and inter-rack connectors.</p>	<p>12 months</p>
<p>SR 3.8.4.6 -----NOTE----- This Surveillance shall not be performed in MODE 1, 2, or 3. However, credit may be taken for unplanned events that satisfy this SR. ----- Verify each required battery charger supplies the required load for ≥ 1.5 hours at:</p> <ul style="list-style-type: none"> a. ≥ 126 V for the 125 V battery chargers; and b. ≥ 252 V for the 250 V battery charger. 	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.7 -----NOTES-----</p> <ol style="list-style-type: none"> 1. The modified performance discharge test in SR 3.8.4.8 may be performed in lieu of the service test in SR 3.8.4.7 once per 60 months. 2. This Surveillance shall not be performed in MODE 1, 2, or 3. However, credit may be taken for unplanned events that satisfy this SR. <p>-----</p> <p>Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test.</p>	<p>24 months</p>

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.8 -----NOTE----- This Surveillance shall not be performed in MODE 1, 2, or 3. However, credit may be taken for unplanned events that satisfy this SR. ----- Verify battery capacity is $\geq 80\%$ of the manufacturer's rating for the 125 V batteries and $\geq 83.4\%$ of the manufacturer's rating for the 250 V battery, when subjected to a performance discharge test or a modified performance discharge test.</p>	<p>60 months <u>AND</u> 12 months when battery shows degradation or has reached 85% of expected life with capacity < 100% of manufacturer's rating <u>AND</u> 24 months when battery has reached 85% of the expected life with capacity $\geq 100\%$ of manufacturer's rating</p>

