

Attachment

Engineering Calculation

CE-1386 - Stability of SWR Slope Under Increase Phreatic Surface

**North Anna Power Station
Units 1 and 2
Virginia Electric and Power Company**

VIRGINIA POWER

CALCULATION COVER SHEET

Type Sub Station Unit Status System Code(s)
 [CALC] [CIV] [59] [00] [] []

Calc. Number Rev. QA Cat.
 [CE-1386] [0] [SR]

Calc Title (Subject):
 STABILITY OF SWR SLOPE UNDER INCREASED PHREATIC SURFACE

Key Words:
 SLOPE STABILITY, PHREATIC SURFACE, STABILITY ANALYSIS

Reference Numbers: DCP No.: 97-010 Job No. 90X3M1A50
 Initiating Document: (DCP, IEER, REA, etc.): REA-97-025, NRC LETTER NO-96-50197-682

Originator: ☒ Virginia Power Discipline: _____
☐ Other Firm Name: _____ Vendor Code: _____

EDS Mark Number References:

Station	Unit	System	Prefix	Sequence	Comp. Code	Suffix
[59]	[00]	[SW]	[PI620]	[P-23]	[]	[]
[59]	[00]	[SW]	[PI620]	[P-24]	[]	[]
[59]	[00]	[SW]	[PI620]	[P-10]	[]	[]
[]	[]	[]	[]	[]	[]	[]
[]	[]	[]	[]	[]	[]	[]

[] Additional Mark Numbers? (Check if "yes"). See _____

Objective: TO CALCULATE THE FACTOR OF SAFETY (F.S.) AGAINST FAILURE OF THE DOWNSTREAM SLOPE OF THE SWR, SECTION WITH AN INCREASED PHREATIC SURFACE. THE CALCULATION WAS PERFORMED TO JUSTIFY RAISING THE ALLOWABLE TECH. SPEC. LIMIT FOR THE WATER LEVELS AND DEMONSTRATE THE DOWNSTREAM SLOPE REMAINS STABLE UNDER THE INCREASED WATER LEVELS.

Conclusions: THE DOWNSTREAM SLOPE REMAINS STABLE UNDER AN INCREASE IN THE ALLOWABLE WATER LEVEL (P-10 TO EL 280 FT.; P-21 & P-22 TO EL 295 FT.) THE ORIGINAL DESIGN BASIS CALC (ODBC) F.S. WAS 1.5. THIS CALC. F.S. = 1.56 STANDARD > 1.5 (STAY STATE) SEISMIC (ODBC) 1.2 THIS CALC 1.27 INDUSTRY STANDARD > 1.0

Superseded Calcs: THIS CALC. DOES NOT SUPERSEDE THE ORIGINAL DESIGN BASIS CALC, 11715-141, BUT ENHANCES AND UPDATES THE CALC.

Prepared By (Print Name) JOHN S. THORNTON JR.	Signature <i>[Signature]</i>	Date 3-26-98
Reviewed By (Print Name) M.L. Blough	Signature <i>[Signature]</i>	Date 4-9-98
Other (If Applicable Print Name)	Signature	Date



VIRGINIA POWER

Document type	CALCULATION			Engineering Work Sheet		POW 14
Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST		Doc. No.	CE-1386	Rev. No.	6
Subject	SEW DIKE STABILITY		Prepared By	J. Shontz		Sheet No. 1 of 43
System	SERVICE WATER (SW)		Checked By	M. Bly		Date 4-9-98

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
OBJECTIVE	2
DISCUSSION AND BACKGROUND INFORMATION	4
ASSUMPTIONS	8
METHOD OF ANALYSIS	11
DESIGN INPUTS	14
REFERENCES	16
CALCULATIONS	17
CASE 1	17
CASE 2	26
CONCLUSIONS	36
 APPENDIX A	 39
APPENDIX B	40
APPENDIX C	41
APPENDIX D	42
APPENDIX E	43



Document Type		CALCULATION	
Project		TECH. SPEC. 3/4.7.13 CHANGE REQUEST	
Subject		SWR DIKE STABILITY	
System		SEAWALL/WATER	
Doc. No.	Rev. No.	Sheet No.	2 of 43
CE-1386	0		
Prepared By		J. J. J. J.	
Date		4-3-98	
Checked By		M. J. J. J.	
Date		4-9-98	

OBJECTIVE

The objective of this calculation is to determine the factor of safety (F.S.) against a slope stability failure of the downstream slope of the downstream section of the Seawall. Water Runoff (SWR) under an increased phreatic

surface from the current limits identified in technical specification 3/4.7.13 (R1.1). The water level as measured in parameter P-22 which is located at the west end of the SE section of the SWR (see Figure 1), exceeded the peak spec allowable limit of 280 ft. and the water level as measured in P-19, located at the toe of slope midway through the SE section is approaching the peak spec. limit of 271 ft. The calculation is performed to justify raising the allowable peak spec. limits for the water level along the SE section and demonstrate that the downstream slope remains stable under the increased water levels.

PAGE 3 OF 43
3-24-98
FIGURE 1
481 4-3-98
MFB 4-9-98




FIGURE 1
PLAN-CURRENT INSTRUMENTATION
SERVICE WATER RESERVOIR
NORTH ANNA POWER STATION

LEGEND

- REFERENCE MONUMENT
- △ ALIGNMENT-SETTLEMENT MARKER
- PNEUMETER
- INCLINOMETER CASING
- TEST WELL
- PROPOSED NEW STANDPIPE PNEUMETERS

NOTE
REFERENCE MONUMENT "C" IS LOCATED EAST OF CANAL "A" AT N209, E10971 (PLANT 000)

SCALE-FEET
0 100 200



VIRGINIA POWER

Document Type	CALCULATION	Engineering Work Sheet			POW 14		
Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST	Doc. No.	CE-1386	Rev. No.	0	Sheet No.	4 of 43
Subject	STABILITY OF SWR DIKE	Prepared By	J. S. Hunter			Date	3-24-98
System	SERVICE WATER	Checked By	MJD			Date	4-9-98

DISCUSSION + BACKGROUND INFORMATION

The original design basis calculation performed in 1974 (Ref. 2) identified the critical section for the downstream steady state seepage case as the section of maximum height located along the SE portion of the SWR. The critical section identified in the calculation was assumed to be 44 ft high (crest el 320 ft, toe el around el 276 ft). The phreatic surface assumed in the calculation extended from the reservoir level (el 315 ft), downstream through the random fill material into the drainage filter exiting the slope two feet below the grade at toe of slope. The critical section from the design basis calculation with the phreatic surface is presented in Figure 2. The calculated F.S. for the critical section and assumed phreatic surface was 1.49 (via computer).

The design basis critical section does not reflect the existing as built dike condition as verified by optical survey performed in June, 1997 (Ref 3). The actual maximum slope height is 37 ft., seven feet lower than the critical section assumed in the design basis calculation.

The location of P-22 is superimposed on the critical dike section as shown in Figure 2. The phreatic surface used in the design

UNCLASSIFIED - UNCONTROLLED

SHEET 5 OF 43

3-24-98

FIGURE 2

4-9-98
MB 44-98




FIGURE 2
FAILURE SURFACE - ORIGINAL
DESIGN CALCULATION

Engineering Work Sheet		Document type	
POW 14	Doc. No.	Project	System
LE-1386	TC4. Spec. 3/4.7.13	CHART REQUEST	STABILITY OF SWE DIKE
Rev. No. 0	Prepared By JSL	Checked By MJB	SEWERAGE WASTE
Sheet No. 6 of 43	Date 3-24-98	Date 4/9/98	

Basic calculation corresponding to the location of P-22 is 28.310 ft, 30 ft higher than the maximum level permitted by the maximum level permitted (at 280 ft) and 25 ft higher than the plastic surface at the toe of slope assumed in the design basic calculation was two feet below the top of ground (at 274 ft) as depicted in Figure 2. The current measured water level in P-10, located 25 ft from the toe of the actual slope is around 270.5 ft, which is 8.5 ft below top of ground at the toe of slope. Maximum water level permitted existing the test spec. for P-10 is at 271 ft, 8 feet below grade.

Therefore the assumptions used in the design basic calculation are very conservative as compared to the actual conditions stated above.

The design basic calculation assumes 1) a higher than actual section 2) much higher than current allowable or actual plastic surface at the inland coast (location of P-22), 3) much higher relative plastic surface at the toe of slope. Therefore the design basic calculation is conservative as compared to the actual condition.



VIRGINIA POWER

Document type CALCULATION

Engineering Work Sheet

POW 14

Project TECH. SPEC. 3/4.7.13
CHANCE REQUESTDoc. No.
CE-1386Rev. No.
0Sheet No.
7 of 43Subject STABILITY OF SWR DIKEPrepared By
JSDate
3-24-98System SERVICE WATERChecked By
MJBDate
4/9/98DISCUSSION + BACKGROUND INFORMATION cont'd

Groundwater Levels - The water levels as defined by monitoring of piezometers at the SWR has risen slightly over the last 5 years. This is especially evident along the SE section of the SWR dike. The water level as measured in P-22 exceeded the Technical Specification limit of el 280 ft. on 9/13/96 (see DPN-96-1835, Ref 4) resulting in an engineering evaluation and report dated December 1996 (Ref 5). The report concluded that a gradual increase in water levels had occurred and was caused by a combination of factors one of which was precipitation, but that the stability of the slope remained adequate and a significant increase in seepage from the SWR had not occurred. Plots of the rise in water levels as monitored in piezometers

P-22 and P-10 are contained in Ref 5. The water level in P-22 has risen in the eight years since it was installed from a low of el 278 ft to slightly less than el 281 ft. For P-10 the rise over the past 12 years has been from el 274 ft to just under el 277 ft.



VIRGINIA POWER

Document Type	CALCULATION	Engineering Work Sheet			POW 14		
Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST	Doc. No.	CE-1384	Rev. No.	0	Sheet No.	8 of 43
Subject	STABILITY OF SWR PIKE	Prepared By	JES			Date	3-24-98
System	SERVICE WATER	Checked By	MJB			Date	4/9/98

ASSUMPTIONS

The critical section and the assumed phreatic surface used in the original design basis calculation (Ref. 2) has been presented in Figure 2.

The critical section analyzed in this calculation consists of an as built section through piezometer P-10, approximately midway along the SE section of the dike. The section through P-10 is only two feet lower than the maximum section as defined by the as built survey (Ref. 3). Results of the as built survey of the existing dike along the southeast section is provided in Appendix A. The drawing provides spot elevations at the crest and toe of slope and 50 ft south of the toe of slope. The section through P-10 was selected because it represented the approximate section of maximum height and definitive water elevations at the toe could be obtained through monitoring of piezometer P-10. The phreatic surface assumed for this section is shown on Figure 3. The phreatic surface extends from the reservoir down to the base of the sand filter to P-10. P-22 is superimposed on the figure at its' relative position on the section. The phreatic surface crosses the location of P-22 at el 310 ft and intersects P-10 at el 220 ft. These assumed water levels are conservatively high as the ^{highest} water level in P-22 was

ACCURATION CC-1586

REV 0

9 4.3

3-24-98

FIGURE 3

4-9-98

MB-4-9-98




FIGURE 3

SECTION THROUGH P-19
SERVICE WATER RESERVOIR
NORTH ANNA POWER STATION

WATER LEVEL @ P10-280, INTERIOR T P-10-316



VIRGINIA POWER

Document Type CALCULATION

Engineering Work Sheet

POW 14

Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST	Doc. No.	CE-1386	Rev. No.	0	Sheet No.	10 of 43
Subject	STABILITY OF SWR DIKE	Prepared By	JSJ	Date	3-24-98		
System	SEAWALL WATER	Checked By	MTB	Date	4/9/98		

slightly below el 281. In addition conductivity tests conducted on a water sample taken from P-22 indicate that the water in P-22 is groundwater, not seepage from the SWR. Results of these tests are contained in a letter to the NRC dated January 23, 1998, Serial No. 97-682 (Ref 6). These tests clearly indicate the water monitored in P-22, and P-10 is groundwater (with a maximum el. of approximately 280) not a phreatic surface through the dike.

As in the original design basis calculation (Ref 2), rock was assumed to be present at el 240 ft or below. The failure circles were therefore held above el 240 due to the presence of the rock layer which possesses a much higher shear strength than the foundation soils. The presence of rock in the dike section is also discussed in the VFSAR, Appendix 3E, Attachment 5.6 (Ref 7). The same criteria was applied to the calculation i.e. rock is present at el 240 ft. therefore the failure circle is held above el 240 ft since the failure will occur in the weaker (soil) not rock.

The assumption was also made, for the purpose of utilizing a computer assisted search for the critical failure surface, that the failure surface would not be shallower than 10 ft. This restriction does not allow the use of an unrealistically shallow failure surface which may be selected by the computer.



VIRGINIA POWER

Document type CALCULATION

Engineering Work Sheet

POW 14

Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST	Doc. No.	CE-1386	Rev. No.	0	Sheet No.	11 of 43
Subject	STABILITY OF SWR DMS	Prepared By	481	Date	3-24-98		
System	SEAWALL WATER	Checked By	MLB	Date	4/9/98		

METHOD OF ANALYSIS

The original design basis calculation (Ref 2) used the "Simplified Bishop Method" to obtain the critical circular failure surface, and "Morgenstern Price Method" for the wedge failure method (UFSAR, Section 3.8, Ref 2). The circular failure mode was the most critical. The Simplified Bishop Method uses a conventional two dimensional stability where Factor of Safety against failure (F.S.) = $\frac{\text{Strength to resist driving moment}}{\text{driving moment}}$ or limited equilibrium method.

$$F.S. = \frac{\sum (W - U) \tan \phi \sec \alpha}{\sum W \sin \alpha}$$

$$\frac{1 + \tan \phi \tan \alpha}{F.S. (\text{assumed})}$$

For effective stress, steady state seepage condition ($\phi > 0, c^* = 0$)

$$\sum W \sin \alpha$$


Where

W - weight of slice

U - uplift on base of slice due to pore pressure (phreatic surface)

 ϕ - soil friction angle for base of slice α - angle of inclination at base of slice →

* c = cohesion



Engineering Work Sheet		Document type		CALCULATION	
POW 14		Project		TCN SPEC 3/4.7.13 CHANGE REQUEST	
Doc. No.		Subject		STABILITY OF SWR DIKE	
Rev. No.		System		SW	
Sheet No.		Prepared By		481	
12 of 43		Checked By		MAB	
Date		Date		4/9/98	

METHOD OF ANALYSIS (cont'd)

The critical failure circle (failure surface with the least F.S.) was obtained via computer using SB-SLOPE, from Geosystems (Ref 9). The program utilizes the Simplified Bishop method of analysis.

For the downstream face steady state seepage case, a verification run was made with SB SLOPE on the critical section obtained by the original design basis calculation. The same slope geometry, section, height, air parameters and phreatic surface was used. The results were remarkably similar - SB SLOPE program obtained a F.S. of 1.50 vs 1.49 with the original design basis calculation computer run. Results of the SB SLOPE verification are contained in Appendix B.

Two cases were run for the as built condition with the phreatic surface as discussed and shown in Figures 3. Both focused on the downstream face of the critical section selected along the SE section of the dike.



CALCULATION		Engineering Work Sheet		
Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST	Doc. No.	Rev. No.	Sheet No.
		CE-1386	0	13 of 43
Subject	STABILITY OF SWR Dike	Prepared By	Date	
		481	3-24-98	
System	SW	Checked By	Date	
		MD13	4/9/98	

METHOD OF ANALYSIS cont'd

CASE 1 - Steady state seepage condition - This case utilizes the soil parameters in the effective stress parameters (ϕ' , c'). It was conservatively assumed that no cohesion ($c=0$) was present even in the compacted core, random fill or foundation soils (saprolite).

CASE 2 - Seismic case - Total stress conditions σ , consolidation stress parameters were used for soil strength ($\phi + c$ conditions). Some cohesion was present in the compacted random fill and foundation soils (saprolite) and is used in the calculation for this case.

The computer program SB SLOPE was used to determine the minimum F.S. for each case. The results of the computer search for the critical circle - i.e. the coordinates of the failure circle and radius were then used in a hand calculation to verify the results of the computer run.



VIRGINIA POWER

Document type CALCULATION		Engineering Work Sheet		POW 14
Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST	Doc. No. CE-1386	Rev. No.	Sheet No. 14 of 43
Subject	STABILITY OF SWR DIKE	Prepared By JSI		Date 3-21-98
System	SW	Checked By MD13		Date 4/9/98

DESIGN INPUTS

The material properties and soil strength parameters used in the original design basis calculation and in this calculation are the same for the respective layers. The properties and parameters are provided in Table 3.8-13 of the UFSAR (Bf 10) which follows. Table 3.8-13 has been modified and marked up to show the layer designation and the selected set of parameters which were used to analyze the steady state and seismic cases.

The slope geometry including, height of slope, position of soil layers and phreatic surface were discussed in previous sections and are shown on Figure 3.

Any other design inputs are referenced in the body of the calculation.

P 15 of 43

3-24-98
JLJ 4-9-98
MLB 4-9-98

Table 3.8-13

MATERIAL PROPERTIES AND STRENGTH PARAMETERS,
SERVICE WATER RESERVOIR

DESIGNATION OF
LAYER USED IN CALC.*

Material

4

Compacted impervious
core and select
lining

116

95

32

0

26

0

2

Transition filters

130

115

38

0

38

0

3

Compacted rock shell

140

120

43

0

43

0

1

Foundation saprolite

125

105

30

0

26

0

NOT USED

Foundation relief joint

12

0

12

* SEE FIGURE 3

NOT USE IN
CALCULATION

STRENGTH PARAMETERS
USED FOR CASE 1 (STEADY
STATE CONDITION)

STRENGTH PARAMETERS
USED FOR CASE 2 (SEISMIC
CONDITION)

Document Type	Calculation		Engineering Work Sheet		POW 14
Project	TRC II SPEC 3/4.7.13		Doc. No.	Rev. No.	Sheet No.
Subject	STABILITY OF SWR DIKE		Prepared By	JES	
System	SW		Checked By	MJB	
UNIQUE ACQUISITION			Date		3-24-98
			Date		4/9/98

REFERENCES

- 1) Technical Specification 3/4.7.13, Groundwater Level-Service Water Reservoir
- 2) Calculation 11715-141, SWR Dike Stability Analysis, April 1974, Performed by. Stone & Webster Engineering Corporation (the original design basis calculation)
- 3) North Anna Power Station, SWR Slope Survey (Southeast Section) June 1997, performed by Bangston, DeBell, and Elkin, Ltd.
- 4) Deviation Report, DRN-96-1835, North Anna Power Station
- 5) Service Water Reservoir, Groundwater Level Evaluation, NAPS, NR-341 dated Dec. 1996 and transmitted to the NPC by letter Serial No 96-561 dated Dec. 10, 1996.
- 6) Response to Dam Safety Audit Related to the Category 1 SWR Dam at North Ann (letter) Serial No. 97-682 dated January 23, 1998.
- 7) UFSAR, Appendix 3E, Attachment 5, p 6 and Figure 2
- 8) UFSAR, Section 3.8.4.4, p 3.8-91
- 9) Geosystem S.B. Slope, Versions 2+3, licensed by Van Gunters Engineering Software (VES, Inc), Fort Collins, Co.
- 10) UFSAR, Section 3.8, Table 3.8-13, p 3.8-159
- 11) Engineering & Design Manual, Stability of Earth & Rock-Fill Dams EM 1110-2-1902 Corp of Engineers April 1970
- 12) Engineering Guidelines for Evaluation of Hydropower Projects, Federal Energy Regulatory Commission (FERC), April 1991

Document Type	CALCULATION	
Project	TECH SPEC 211-7-10	
Client Request	CC-1500	
Subject	STABILITY OF SWR DIKE	Prepared By
System	SW	Checked By
Date	3-27-98	Date
Date	4/9/98	Date

CALCULATIONS

As stated in previous sections, this calculation was performed to determine the FS of the downstream slope of the selected critical section of the SE section of the SWR dike. This case and their associated conditions were evaluated.

Case 1 - Static steady state seepage, effective stress condition. The minimum FS of the computer generated critical section was 1.56 with coordinates of the failure circle of $X=48$, $Y=352$, and radius $R=76.3$. Results of the computer generated run are contained in Appendix C.

These results were verified by a hand calculation performed on the critical section having the minimum FS (presented in Appendix C).

The following sketch (Figure 4) presents the failure circle as determined by the computer generated solution for the Case 1 (static steady state seepage condition) as presented in Appendix C. The slope geometry, location of the phreatic surface and soil layers are the same as presented in Figure 3.



VIRGINIA POWER

Document Type	CALCULATION		Engineering Work Sheet		POW 14
Project	TECH SPEC. 3/4.7.13 CHANGE REQUEST		Doc. No.	Rev. No.	Sheet No.
			CE-1386	0	19 of 43
Subject	STABILITY OF SWR DIKE		Prepared By	Date	
			JSS	3-29-98	
System	SW		Checked By	Date	
			MJB	4/9/98	

METHODS FOR CALCULATING AREAS AND WEIGHTS OF SLICES (ACTUAL SLICE WEIGHT CALC CONTAINED ON PAGES 15-16)

FROM FIGURE 4
CASE 1
COMPUTER FILE SWR PION4

SLICES AND GEOMETRY ARE FROM FAILURE SURFACE CROSS SECTION SKETCH FIG. 4 PAGE 14

SLICE NO

CALCULATION OR METHOD

①

All soil is foundation material ($\gamma = 125 \text{ PCF}$) - calculate triangle

②

Trapezoid - Area 2 - small triangle (top of figure)

h_i is horizontal dist or really b

$$A = 10 \left(\frac{6+8.5}{2} \right) - \frac{1}{2}(1)10 = 72.5 - 5 = 67.5$$

③

Use $b \cdot h$ (close to parallel)

④

Calculate area of rock shell ($\gamma = 140$)^{#3 soil} Area of triangle - small triangle

$$\#3 \text{ soil } A = \frac{1}{2}(5)(2.5) - \frac{1}{2}(5)(0.5) = \frac{1}{2}(12.5 - 2.5) = \frac{1}{2}(10) = 5$$

#2 soil $\equiv A =$ triangle - small triangle of #1 soil

$$A = \frac{1}{2}b(4.5) - \frac{1}{2}(2)2.5 = \frac{1}{2}(22.0 - 5) = 11$$

$$\#1 \text{ soil } b \cdot h = 5(6) = 30 + \text{triangle } \frac{1}{2}(3)(4) = 36$$

⑤

#3 Soil trapezoid - A

$$\left(\frac{7+6}{2} \right) 10 - \frac{1}{2}(5)10 = 65 - 25 = 40$$

$$\#2 \text{ soil Parallelogram } 10(4) = 40$$

$$\#3 \text{ soil } b \cdot h = (6.5)10 = 65$$



VIRGINIA POWER

Document Type	CALCULATION			Engineering Work Sheet		POW 14			
Project	TECH. SPEC 3/4.7.13 CHANGE REQUEST			Doc. No.	CE-1386	Rev. No.	0	Sheet No.	20 of 43
Subject	STABILITY OF SWR DIKE			Prepared By	FBJ		Date		3-29-98
System	SW			Checked By	MJB		Date		4/9/98

AREA OF FAILURE SLICES CONT'D

FROM FIGURE 4
CASE 1
COMPUTER FILE SWRPNH

⑥ #3 soil (left) - trapezoid-triangle

$$\left(\frac{11+9.5}{2}\right)10 - \frac{1}{2}(5)(10) = 102.5 - 25 = 77.5$$

$$\#2 \text{ soil } 4(10) = 4$$

$$\#1 \text{ soil } 7(10) = 70$$

⑦ SAME METHOD AS 6 trapezoid-small

$$\#3 \frac{(9.5+14.5)}{2}(10) - \frac{1}{2}(1)(10) = 115 - 5 = 110$$

$$\#2 4(10) = 40$$

$$\#1 5.5(10) = 55$$

⑧ Trapezoid - 4 (void above) - small & #2 soil

$$\#3 \frac{(18.5+12)}{2}(10) - \frac{1}{2}(5)(10) - \frac{1}{2}2(5) = 182.5 - 25 - 5 = 152.5$$

#2 parallelogram + small

$$4(10) + 5 = 45$$

$$\#1 2.75(10) = 27.5$$

⑨

$$\#3 \text{ soil } \frac{19.5+9.5}{2}(10) - 25 = 145 - 25 = 120$$

$$\#2 \text{ parallelogram } \frac{1}{2}(8+8)10 = 80$$

#4 large Δ - Δ =

$$\frac{1}{2}(9 \times 9) - \frac{1}{2}(9)(6) = 181.5 - 27 = 154.5$$



VIRGINIA POWER

Document Type	CALCULATION		Engineering Work Sheet		POW 14
Project	TECH. SPEC 3/4.7.13 CHANGE REQUEST		Doc. No.	Rev. No.	Sheet No.
			CE-1386	0	21 of 43
Subject	STABILITY OF SWR DIKE		Prepared By	Date	
			JSJ	3-24-98	
System	SW		Checked By	Date	
			MJB	4/9/98	

AREA CALC p3 CONT'D

$$\textcircled{10} \#3 (10) \left(\frac{14+5}{2} \right) - \frac{1}{2} (5) 10 = 95 - 25 = 70$$

#2) Same as 9 77

#1 Center of slice x w slice

$$4 \times 10 = 40$$

\textcircled{11} #3 same method as 10

$$\frac{1}{2} 7(5) - \frac{1}{2} (2.5)(5) = \frac{1}{2} (5)(7-2.5) = 11.25$$

#2 same method as 10

$$7(5.5) = 38.5$$

$$\#4 \quad 3(5) = 15$$

\textcircled{12} #3 material

Assume cap is rectangle - split difference in arch on rt. side
 $7 \times 2 = 14$

#2 find area of Δ using arc as one side and subtract
 small Δ of #4 mat.

$$\frac{1}{2} (10.5) 6.5 - \#4 \text{ mat} = 34.13 - 6 (\text{from below}) = 28.13$$

#4 material - Δ below el 315 line - inner Δ


$$\frac{1}{2} (7)(4) - \frac{1}{2} (4)(4) = 14 - 8 = 6$$

FROM FIGURE 4
 CASE 1

COMPUTER FILE SWRPION4

CALCULATION OF SLICE WEIGHTS

SLICES FROM FIG 4
CASE 1
COMPUTER FILE SWRPRON



γ_i = unit weight of layer i

h_i = height of layer at center of slice

W_i = partial weight = $b h_i \gamma_i$

ΣW_i = total weight of slice

CALCULATION CE-1380
REV 0

P22 OF 43

3-24-98

4/9/98

Slice No.	Soil No. or b	h_i	γ_i	W_i	(KIPS) ΣW_i
1	5/2	10.5 = 26.25 * 0.125		3.28	3.28
2	10		67.5 (0.125)	8.44	8.44...
3	5	8.5 =		5.31	5.31
4	#3 soil #2 soil #1 soil		5 (0.140)	0.70	
			13.75 (0.130)	1.43	
			36 (0.125)	4.50	6.63
5	#3 soil #2 soil		40 (0.140)	5.60	
			40 (0.130)	5.20	
			65 (0.125)	8.13	18.93
6	#3 soil #2 soil #1 soil		72.5 (0.114)	10.85	
			40 (0.13)	5.20	
			70 (0.125)	8.75	24.8
7	#3 soil #2 #1		115 (0.140)	16.10	
			40 (0.13)	5.20	
			55 (0.125)	6.88	28.18
8	#3 #2 #1	152.5 (0.14)		21.35	
			45 (0.13)	5.85	
			27.5 (0.125)	3.44	30.64
9	#3 #2 #4	(120) (0.140)		16.80	
		(80) (0.13)		10.40	
		(135) (0.116)		1.57	28.77

TABULAR FORM FOR COMPUTING WEIGHTS OF SLICES.

COMPUTER FILE SWR PIONH



h_i = height of layer at center of slice

W_i = partial weight = $b_i h_i \gamma_i$

ΣW_i = total weight of slice

CALCULATION
C6-1386 REV 0
P 23 OF 43
ASS 3-24-98

msB 4/9/98

TABULAR FORM FOR COMPUTING WEIGHTS OF SLICES.

COMPTON FILE SWR PD 14

CALCULATION
CE-1386 Rev.0
P240 F43
457 3-24-98
MAB 4/9/98


$$l = \frac{B}{\cos \alpha}$$

THESE COLUMNS NOT USED FOR
SIMPLIFIED BISHOP SOLUTION

(1) $\phi_{\text{SILICE}} 12 =$

$$\phi_{12} = \frac{4'(58^\circ) + 8'(32^\circ)}{12}$$

$$= \frac{400}{12} = 34^\circ \text{AVE}$$



B = WIDTH OF SLICE
 C = cohesion intercept
 ϕ = friction angle
 u = pore pressure

} at base of slice

H_w = HEAD OF WATER ABOVE BASE OF SLICE

$$F = \frac{\Sigma (W \cos \alpha - ul) \tan \phi + \Sigma cl}{\Sigma W \sin \alpha}$$

— EQ FROM
METHOD OF SLICES
NOT USED

TABULAR FORM FOR CALCULATING FACTOR OF SAFETY BY ORDINARY METHOD OF SLICES.

NOTE! ONLY COLUMNS COMPLETED
USED IN BISHOP SIMPLIFIED SOLUTION



VIRGINIA POWER

Document Type	CALCULATION		Engineering Work Sheet		POW 14
Project	TBCN SPEC 3/4.7.13 CHANGE REQUEST		Doc. No.	Rev. No.	Sheet No.
			CE-1386	0	26 of 43
Subject	STABILITY OF SUE DIKE		Prepared By	Date	
			4/5	3-24-98	
System	SW		Checked By	Date	
			MTB	4/9/98	

CALCULATIONS cont'd

The hand calculation verifying the computer generated minimum F.S. for the critical circle for the CASE 1 condition was
 $F.S. = 1.54$ vs. 1.56 (VIA COMPUTER - SEE APPENDIX C.)

THIS IS A VERY CLOSE AGREEMENT (WITHIN 1%) and verifies the computer generated solution.

CASE 2 - Seismic condition - using total stress soil strength parameters (see p 11, DESIGN INPUTS section). The same slope geometry, height, phreatic surface and soil layers used in the CASE 1 condition (shown in FIGURE 3) were used in this case.

The soil strength parameters used for the CASE 2 (TOTAL STRESS) condition are as follows

SOIL 1 - FOUNDATION SOIL (SAPROLITE), $C = 720 \text{ PSF}$, $\phi = 26^\circ$

SOIL 2 - TRANSITION (SAND) FILTERS, $C = 0$, $\phi = 38^\circ$ (same as CASE 1)

SOIL 3 - COMPACTED ROCK FILL, $C = 0$, $\phi = 43^\circ$ (same as CASE 1)

SOIL 4 - COMPACTED RANDOM (CORE) FILL $C = 720 \text{ PSF}$, $\phi = 26^\circ$

The SEISMIC coefficients used are consistent with the design Basis Earthquake DBE as stated in the UFSAR (Ref 3) and the original design basis calculations (Ref 2). The horizontal acceleration $K_H = 0.18g$, and vertical seismic acceleration $K_V = 0.12g$.



VIRGINIA POWER


Document type *Calc.*

Engineering Work Sheet

POW 14

Project *TECH SPEC 3/4.7.13
CHANGE REQUEST*Doc. No.
*CE-1986*Rev. No.
*0*Sheet No.
*27 of 43*Subject *STABILITY OF SWR DRE*Prepared By
*483*Date
*3-24-98*System *SW*Checked By
*MBB*Date
*4/9/98*CALCULATIONS CASE 2 cont'd

The computer generated critical failure circle indicated a F.S. of 1.27 with the failure surface located entirely in the granular fill (sand filters and compacted rock fill). This is due to the total stress condition of the soil which mobilizes the cohesion through the soil layers - forcing the failure circle into the granular soils due to the strength of the "cohesive" soils. The CASE 2 computer solution is presented in Appendix D. A print of the critical failure circle, coordinates of the center of the failure, the section is presented below.





CALCULATION

Engineering Work Sheet

POW 14

Project	TECA Spec 3/4, 7, 13 Change Request	Doc. No.	CG-1386	Rev. No.	0	Sheet No.	28 of 43
Subject	Stability of SWR Dike	Prepared By	JFJ	Date	4-9-98		
System	SW	Checked By	MLB	Date	4-9-98		

CALCULATIONS CASE 2 cont'dCASE 2
SEISMIC

A hand calculation was performed to verify the computer generated results described on the previous page (p 27). The failure surface was superimposed on the geometry of the cross section and the failure surface was broken into 8 slices (the computer generated solution used 80). This enlarged section is provided in Fig. 5 (next page, p 29). The weight of each slice was calculated and the angle α , to the center of each slice from the origin of the failure circle was scaled. The resisting and driving forces were calculated. The slice weights and their seismic components, were applicable, were multiplied by the radius for the critical failure circle to obtain the resisting and driving moments. The slice weight $\times$ the seismic (horizontal) component $[K_h(W)]$ was multiplied by the respective lever arm (measured from the center of the slice to the center of failure arc). The sum of these moments was added to the driving forces.

The factor of safety for the seismic (CASE 2) condition was calculated as follows:

$$F.S. = \frac{\sum \text{RESISTING FORCES}}{\sum \text{DRIVING FORCES}} \quad \text{OR} \quad F.S. = \frac{\sum M_{\text{RESIST}}}{\sum M_{\text{DRIVE}} + \sum K_h W \cdot L_H}$$

CALCULATION OF SLICE
WEIGHTS BEGINS ON P 26
AFTER FIG 5



VIRGINIA POWER

Document Type	Calculation			Engineering Work Sheet		POW 14
Project	TECH SPEC 3/4.7.13 CHANGE REQUEST			Doc. No.	CE-1386	Rev. No.
					0	Sheet No.
						30 of 43
Subject	STABILITY OF SWR DIKE			Prepared By	481	Date
						3-24-88
System	SW			Checked By	MJB	Date
						4/9/98

VERIFY COMPUTER GENERATED MINIMUM FACTOR OF SAFETY FOR CASE 2
SEISMIC CASE (SLOPE FILE NO. SWRPI05E)

CASE 2
SEISMIC
SLICE WT
CALC

BREAK FAILURE ARC INTO 8 SEGMENTS TO CALCULATE HEIGHT OF EACH
SEGMENT AND FROM PERIMETER. CALCULATE TOTAL AREA BY PLACING HORIZONTAL
LINE ACROSS BASE RATHER THAN USING CORD (SLICES 2 THROUGH 7)

CALCULATION ON SEGMENT WEIGHTS

Soil #2 (Filter) $W = 130 \text{ PCF}$ OR 0.13 KSF Soil #3 (Rock Fill) $W = 140 \text{ PCF}$ OR 0.14 KSF

$$1. \text{ Area of triangle } = \frac{1}{2} B H = \frac{1}{2} (19.5)(5) = 23.75$$

$$2. \text{ Area of rectangle } = (23.75 - 19.5)(0.14) = 19(0.14) = 2.66 \text{ K}$$

$$3. \text{ Area of rectangle } = (4.5)(0.13) = 0.59 \text{ K}$$

$$\frac{0.59}{3.25 \text{ K}}$$

$$2. \text{ Total area} = \text{trapezoid (with base and off failure circle)} = B \cdot \text{height} = \left(\frac{5+85}{2}\right) 10 = 67.5(10) = 675$$

$$\text{Sand filter} = (10)(1) = 10(0.13) = 1.3 \text{ K}$$

$$\text{Rock fill} = (67.5 - 10)(0.14) = 57.5(0.14) = 8.05$$

$$\frac{8.05}{9.35 \text{ K}}$$

$$3. \text{ Total Area} = \text{trap. - small } \Delta = B h_{\text{ave}} - \frac{1}{2} B h_a = 10(11.0) - \frac{1}{2}(2)10 \cdot 10 - 10 = 100 \text{ K}$$

$$\#2 \text{ soil} = \text{lower } (4_1 - 4_2) = \left[\frac{1}{2}\left(\frac{1}{2}\right)(10) - \frac{1}{2}(1)(10)\right](0.13) = (10 - 5)(13/13) = 0.65 \text{ K}$$

$$\#3 \text{ soil} = \text{Total - small trap.} = 100 - 15 = 85(0.14)$$

$$= 13.3 \text{ K}$$

$$\frac{13.3}{13.95 \text{ K}}$$

Change Request		SI of 40
Subject	STABILITY OF SNR DIKE	Prepared By <i>KSJ</i> Date <i>4-6-98</i>
System	BRIDGE WATER	Checked By <i>MTB</i> Date <i>4/9/98</i>

SLICE No.

4 Total trapezoid-bottom triangle

$$10(14) - \frac{1}{2}(10)3.5 = 140 - 17.5 = 122.5$$

$$W = A\gamma_3 = 122.5(0.14) = \underline{\underline{17.15K}}$$

CASE 2
SEISMIC
SLICE WT
CALCULATION

5 Same methodology

$$10(15.5) - \frac{1}{2}(10)(5) = 155 - 25 = 130$$

$$130(0.14) = \underline{\underline{18.2}} \text{ (most all soil is \#3 except on small triangle - assumed all \#3 soil)}$$

6 Same Methodology

$$\text{Total } A = 10(15) - \frac{1}{2}(7)(10) = 150 - 35 = 115$$

$$\#2 \text{ soil} = \text{triangle 1} - \text{triangle 2} = \left[\frac{1}{2}(11)10 - \frac{1}{2}(7)(10) \right](0.13) = (55 - 35)(0.13) = 2.6K$$

#3 soil total - triangle 1

$$A = 150 - \frac{1}{2}(11)(10) = 150 - 55 = 95$$

$$W = 0.14(95) = 13.3$$

Total weight of slice

2.6

13.315.9K

7 Same method

$$13(10) - \frac{1}{2}(9.5)10 = 130 - 47.5 = 82.5$$

#3 soil = Total (130) - trapezoid bottom including #2 soil

$$A = 130 - \left(\frac{4 + 13.5}{2} \right)(10) = 130 - 87.5 = 42.5$$

$$W_3 = 42.5(0.14) = 5.95K$$

$$A \text{ of } \#2 \text{ soil} = \text{trapezoid-triangle} = 87.5 - \frac{1}{2}(9.5)10 = 40$$



VIRGINIA POWER

Document type

Calculation

Engineering Work Sheet

POW 14

Project

Tech Spec 3/4.7.13
Change Request

Doc. No.

CE-1386

Rev. No.

0

Sheet No.

32 of 43

Subject

Stability of SWR dike

Prepared By

J. Hunter

Date

4-6-98

System

SW

Checked By

MJB

Date

4/9/98

Slice 7 continued

$$\#2 \text{ soil: } W = A \gamma_s = 40(0.13) = 5.2 \text{ K}$$

TOTAL WT slice 7 =

$$\begin{array}{r} 5.95 \\ 5.20 \\ \hline 11.15 \end{array}$$

CASE 2
SEISMIC
SLICE WT
CALCULATION

$$B \quad A = \frac{1}{2}(4.5)6 = 13.5$$

$$\#2 \text{ soil: small } A = \frac{1}{2}(4)3 = 6$$

$$(6)(0.13) = .78 \text{ K}$$

$$A \text{ of } \#3 \text{ soil} = 13.5 - 6 = 7.5$$

$$7.5(0.14) = 1.05$$

$$\underline{\underline{1.83 \text{ K}}}$$



VIRGINIA POWER

Document Type	Calculation		Engineering Work Sheet		POW 14
Project	Tech. Spec. 3/4.7.13 Change Request		Doc. No.	CE-1386	Rev. No. 0
Subject	Stability of S.W. dike		Sheet No.	33 of 43	
System	S.W.		Prepared By	K. Shant	Date 4-7-98
			Checked By	M.B.	Date 4-9-98

SIMPLIFIED BISHOP WEDGE SLICE

CASE 2 SEISMIC

This case assumes the vertical seismic force is acting up (+) thereby reducing the weight of the slice. Also, the phreatic surface is located below the critical failure circle such that there is no reduction to slice weight due to uplift of phreatic surface.

Equation for Bishop follows

$$K_v = 0.12$$

$$1 - K_v = 0.88$$

$$F.S. = \frac{\sum W \tan \phi}{\sum W \tan \phi + \frac{\sum W \tan \phi}{F.S. (assumed)}}$$

designate this term as (B)

1	2	3	4	5	6	7	8	9	10	11	12	13
SLICE NO	UN CORRECTED FOR SEISMIC WEIGHT SLICE	1-K _v	CORRECTED WEIGHT W _{SES}	α DEGREE	Σ W _{SES} DRIVING W _S RIND	φ	RESISTING W _S tan φ	1.3	14	RESISTING 1.3	14	13
1	3.25	0.88	2.86	0.5	0.02	38	2.23	0.995	0.995	2.22	2.22	1.00
2	9.35		8.23	5.5	0.79	38	6.43	0.945	0.958	6.07	6.16	1.01
3	13.95		12.28	12.5	2.66	38	9.59	0.900	0.908	8.63	8.71	1.02
4	17.15		15.09	19.75	5.10	43	14.07	0.845	0.855	11.89	12.03	1.06
5	18.2		16.02	27.5	7.39	41.7	14.27	0.831	0.849	11.86	12.12	1.13
6	15.9		13.99	35.25	8.07	38	10.93	0.860	0.882	9.40	9.64	1.23
7	11.15		9.81	44.5	6.88	38	7.66	0.881	0.904	6.74	6.92	1.40
8	1.83		1.61	52.5	1.28	38	1.26	0.912	0.950	1.15	1.20	1.64
				SCALE	32.19					57%	59.0	



VIRGINIA POWER

Document type

Calc.

Engineering Work Sheet

POW 14

Project

Tech Spec 3/4.7.13
Change Request

Doc. No.

CG-1386

Rev. No.

0

Sheet No.

39 of 43

Subject

Stability of SWE Dike

Prepared By

JBJ

Date

4-7-98

System

SW

Checked By

MJB

Date

4/9/98

Calculate Seismic Horizontal Forces - Moment due to seismic horizontal component
 Assume that the seismic force is also acting up $\uparrow$, so slice weight
 is reduced by $1 - K_v$. L_H is vertical moment arm SCALED from center
 of the slice to center of failure circle

SLICE	W	$\times 1 - K_v$	W_{seis}	$\times K_H$	$W_{seis} \times K_H \times L_H (ft)$	$M_{H_{seis}}$	
		1-0.12 or 0.88					
1	3.25	0.88	2.86	0.18	0.51	81	41.31
2	9.35		8.23		1.48	79	116.92
3	13.95		12.28		2.21	75	165.75
4	17.15		15.09		2.72	71.5	194.48
5	18.20		16.02		2.88	67	192.96
6	15.90		13.99		2.52	61.5	154.98
7	11.51		9.81		1.77	55	97.35
8	1.83		1.61		0.29	49.5	<u>14.36</u>

$$\Sigma = 978.1$$

$$F.S. = \frac{1.32 + 1.34}{2} = 1.33 \quad \text{RESULT OF HAND CALC CHECK ON COMPUTER GENERATED FAILURE MODES}$$

$$F.S. = \frac{1.74 \times 3.14 \times 10^6}{48.97} = 1.137$$

$$\therefore F.S. = \frac{1.345 \text{ mm} \times 2671.8 + 978.1}{4810.7} = \frac{3649.87}{4810.7} = 1.32$$

Revised during (vacance) moment from page 34 = 978.15'

$$\% = 32.19 \times 83 = 2671.87$$

Drawing Members (Farep 33)

$$Me_{14} = 59.06(83) = 48975$$

Rotating Moment for assumed ES 1/4 p 33

$$\therefore M_p = 57.96 \text{ (83)}^{1/2} = 4810.7$$

$$\text{Resisting Moment} = \text{Resisting force (base of slice)} \times \text{radius of failure circle}$$

Sum of Resisting Forces: Assumed F.S. 1.3 from p 33 is 55.782

CALCULATE F.S. by dividing
resulting force (moment) by distance

Case 2 Seminar

System	SW	Checked By	M85	Date	4-9-98
Subject	Stability of SWR Dike	Prepared By	J. S. Brown	Date	4-7-98

Subject STABILITY OF SWR

Prepared By 461

Date 3-24-98

System SW

Checked By MJB

Date 4-9-98

CONCLUSIONS

This calculation determines the factor of safety (F.S.) of the downstream slope at a section cut through Piezometer P-10 located along the southeast quadrant of the SWR. Two cases were considered - Case 1 - Steady state seepage from maximum storage pool, and Case 2 - Steady state seepage during a seismic (DRE) event. The phreatic surface, slope geometry, and location of the soil layers were the same in both cases. Results of this calculation were compared to the results of the original design basis calculation (Ref 2) and recognized geotechnical and industry standards. The results obtained and comparisons are presented in the following table:

DESIGN LOADING CONDITION	MINIMUM FACTOR OF SAFETY		
	ORIGINAL DESIGN BASIS CALC	THIS CALCULATION	INDUSTRY-REQ'D MINIMUM
CASE 1 - STEADY STATE SEEPAGE	1.49	1.56*	1.5 (1)(2)
CASE 2 - SEISMIC STEADY STATE SEEPAGE	1.19	1.27*	1.0 (1) > 1.0 (2)

NOTES: 1) CORP OF ENGINEERS, REF 11

* COMPUTER GENERATED RESULTS

2) FERC, REF 12



VIRGINIA POWER

Document Type

Calculation

Engineering Work Sheet

POW 14

Project

Tech. Spec. 3/4.7.13
Change Request

Doc. No.

CE-1386

Rev. No.

0

Sheet No.

37 of 43

Subject

Stability of SWR Dike

Prepared By

JBJ

Date

4-9-98

System

SW

Checked By

MLB

Date

4-9-98

CONCLUSIONS cont'd

As evidenced in the proceeding table, the F.S. based on the actual as built dike section, with the water level at P-10 at el. 280 ft. rather than at el. 276 (as in the original design basis calculation or Tech Spec. alternate of el. 277') is higher than calculated in the original design basis calculation (ODBC).

The current condition as reflected in both P-10 and P-22, is more conservative (higher F.S.) than originally assumed. The current and maximum historical water level is much more conservative than that assumed in ODBC. The F.S. obtained in both the ODBC and this calculation are well in excess of those referenced in technical/industry standards. The actual measured water levels along the SE section as obtained by monitoring piezometers P-19, P-21, & P-22 are shown on Figure 6 which follows. The assumed phreatic surface or groundwater level is also shown.

Note that this actual surface does not extend through the dike as assumed in all previous calculations, but the phreatic surface is located below the base of the dike. The assumed higher than actual phreatic surface used in all calculations is a conservative assumption as the actual surface would yield a higher calculated F.S. This calculation confirms that raising the Tech. Spec. limit on water levels from el. 277' to 280' in P-10 and from el. 280' to 295' at P-21 & P-22 will still provide an adequate F.S.

4-3-98
MHB 4-9-98




FIGURE 6 - EXISTING PHREATIC SURFA

EXISTING AS-BUILT
SECTION THROUGH P-10
SERVICE WATER RESERVOIR
NORTH ANNA POWER STATION

GROUND WATER LEVEL 280



VIRGINIA POWER

Document type

CALCULATION

Engineering Work Sheet

POW 14

Project

TKN SPEC 3/4.7.13

Doc. No.

CE-1386

Rev. No.

0

Sheet No.

39 of 43

Subject

STABILITY OF SWR DIKE

Prepared By

J.S. Thornton Jr

Date

3-24-98

System

SW

Checked By

MLB

Date

4-9-98

APPENDIX A

As Built Spot Elevations along
Southeast Section of SWR Dike

CIVIL ENGINEERING

OVERSIZE PAGE(S)

**NOT CONVERTED
INTO ELECTRONIC
IMAGE FORM.**

**PAPER COPY IS
AVAILABLE IN NRC
FILE CENTER.**



VIRGINIA POWER

Document Type	CALC		Engineering Work Sheet		POW 14
Project	TBCA SPEC 3/4.7.13 CHANGE REQUEST		Doc. No. CE-1386	Rev. No. 0	Sheet No. 40 of 43
Subject	STABILITY OF SNR DIKE		Prepared By J. S. Hunter		Date 3-24-98
System	SW		Checked By MLB		Date 4-9-98

APPENDIX B

COMPARISON OF RESULTS OF ORIGINAL
DESIGN BASIS STABILITY CALCULATION
WITH RUN USING S.B. SLOPE PROGRAM

SB-SLOPE

Simplified Bishop Slope Stability Analysis

PROJECT: NAPS SWR TS Change 5-28-97

LOCATION: SE Section of dike

FILE: SWRSWC1

COMPLETE SLOPE CROSS SECTION SHOWN


CIRCLE	X	Y	RADIUS	FS
1	90.0	354.0	87.7	1.50

AGREES WITH SWEC CALC 114 STEADY STATE CONDITION
DOWNSTREAM

SEARCH OF 1733 SURFACES GAVE MIN F.S. 1.50 @ X=89.6

Y=358.1

R=93.5



SINGLE CENTER ANALYSIS
 Approximately 40 slices selected
 Circle center at X= 90.0, Y= 354.0
 R= 1.500 at R= 87.7

LMC CC 1306 KVVU
 APPENDIX B
 P 2 of 3
 3-4-98, J. K. H. / J.

GEOSYSTEM SLOPE STABILITY PROGRAM SB-SLOPE

PROJECT DATA:

Project: NAPS SWR TS Change 5-28-97

Location: SE Section of dike

Filename: SWRSWC1 Description: SWEC Calc 141 H2O@ el310 SE Sec Static effec

ANALYSIS DATA:

Point Coordinates			Line Left Right		Soil	Phreatic	Soil Density		Cohesion	Phi	
No.	X	Y	No.	Point	Point	No.	Line	No.	pcf	psf	Deg
1	25.0	276.0	1	1	2	1	N	1	125.0	0	30.0
2	75.0	276.0	2	2	3	2	N	2	130.0	0	38.0
3	80.0	278.5	3	3	4	3	N	3	140.0	0	43.0
4	160.0	320.0	4	4	5	3	N	4	116.0	0	32.0
5	180.0	320.0	5	5	19	3	N				
6	225.0	305.0	6	19	6	3	N				
7	230.0	305.0	7	6	7	4	N				
8	126.0	282.0	8	2	13	1	N				
9	161.0	318.0	9	3	8	2	N				
10	180.0	318.0	10	8	9	2	N				
11	219.0	305.0	11	9	17	2	N				
12	25.0	274.0	12	17	10	4	N				
13	76.0	274.0	13	10	18	4	N				
14	130.0	278.0	14	18	19	3	N				
15	132.0	279.5	15	18	11	4	N				
16	142.0	290.0	16	11	6	4	N				
17	169.0	318.0	17	13	14	4	Y				
18	188.0	315.0	18	14	15	4	Y				
19	195.0	315.0	19	15	16	4	Y				
20	230.0	315.0	20	16	17	4	N				
21	230.0	286.0	21	16	18	4	Y				
22	12	13	22	12	13	1	Y				
23	15	21	23	15	21	1	N				

BOTH SPENCER & Bishop
 AUTO SEARCH (203 FAILURE SURFACES)
 X=88 Y=356 R=89 F.S.=1.5

Free water surface, left point = 19
 right point = 20

Range search; initial parameters:

min max increment
 left x 30.0 90.0 5.0
 right x 160.0 230.0 5.0
 radius increment is 5.0
 minimum perpendicular depth is 10.0
 limit at elevation 10.0

OVERALL MINIMUM: x = 89.6, y = 358.1, r = 93.5, FS = 1.504



CALCULATING		Engineering work sheet		POW 14					
Project	TECH Spec. 3/4.7.13 CHANGE REQUEST	Doc. No.	CE-1386	Rev. No.	0	Sheet No.	41 of 43		
Subject	STABILITY OF SWR DIKE	Prepared By			R. Houten			Date	3-24-98
System	SW	Checked By			MLB			Date	4-9-98

APPENDIX C

RESULTS OF STABILITY ANALYSIS

COMPUTER RUN (S.B. SLOPE) USING

AS BUILT SLOPE GEOMETRY

(CASE 1 CONDITION)

RECORD RUN
11-27-80
CHECK VERIFICATION
REVISION ON CIRCLE 1

REVISED GEOMETRY CORRECTING DEFICIENCIES FOUND BY CHECKER (MLB) - CHIMNEY DRAIN
INCREASED TO 8' WIDTH, P-10 LOCATED AT AS BUILT LOCATION AND WATER LEVEL ADJUSTED TO 280' ELEVATION

SB-SLOPE

FILE NO SWBP10N4

Simplified Bishop Slope Stability Analysis

PROJECT: SWR Tec Spec Change H2O levels in piezometers at SWR


LOCATION: SE section, P-10

FILE: SWBP10N4

COMPLETE SLOPE CROSS SECTION SHOWN

CIRCLE	X	Y	RADIUS	FS
1	48.0	352.0	76.3	1.56 (BISHOP)
2	50.0	348.0	71.8	1.55 (SPENCER)

APPENDIX C
P 1 of 4



File: SWRP10N4 - Sec@P10ToeasbltFIG3E-19 H2O@280/310RecordRev
SINGLE CENTER ANALYSIS
Approximately 80 slices selected
Circle center at X= 48.0, Y= 352.0
1.557 at R= 76.3

LNK CC-1384 REV0

Appendix C

P2 OF 4

GEOSYSTEM SLOPE STABILITY PROGRAM
SB-SLOPE

PROJECT DATA:

Project: SWR Tec Spec Change H2O levels in piezometers at SWR

Location: SE section, P-10

Filename: SWRP10N4 Description: Sec@P10ToeasbltFIG3E-19 H2O@280/310RecordRev

ANALYSIS DATA:

Point No.	Coordinates X	Y	Line No.	Left Point	Right Point	Soil No.	Phreatic Line	Soil No.	Density pcf	Cohesion psf	Phi Deg
1	0.0	282.5	1	1	2	1	N	1	125.0	0	30.0
2	40.0	285.2	2	2	3	3	N	2	130.0	0	38.0
3	110.0	320.0	3	3	4	3	N	3	140.0	0	43.0
4	130.0	320.0	4	4	5	3	N	4	116.0	0	32.0
5	145.0	315.0	5	5	6	3	N				
6	175.0	305.0	6	2	8	2	N				
7	175.0	315.0	7	8	9	2	N				
8	81.5	289.5	8	9	10	2	N				
9	110.0	318.0	9	10	11	4	N				
10	118.0	318.0	10	11	12	4	N				
11	130.0	318.0	11	12	5	3	Y				
12	139.0	315.0	12	12	13	4	N				
13	169.0	305.0	13	13	6	4	N				
14	0.0	279.0	14	14	15	1	Y				
15	43.0	282.0	15	15	16	1	Y				
16	86.0	286.0	16	16	10	4	N				
17	175.0	295.0	17	16	12	4	Y				
			18	16	17	1	N				
			19	2	15	1	N				

Free water surface, left point = 5
right point = 7

SWK770N4 RECORD RUN AFTER REVIEW

CALC CE-1386 REV 0

APPENDIX C

P3054

Range search; initial parameters:

	min	max	increment
left x	10.0	60.0	5.0
right x	100.0	140.0	5.0

(1118 Guesses)

radius increment is 2.0

minimum perpendicular depth is 10.0

limit at elevation 240.0

OVERALL MINIMUM: $x = 48.1$, $y = 357.7$, $r = 81.2$, $FS = 1.565$

Automatic search; initial parameters:

	initial	increment
x	48.0	2.0
y	358.0	2.0
r		2.0

(194 TRIALS)

minimum perpendicular depth is 10.0

limit at elevation 240.0

OVERALL MINIMUM: $x = 48.0$, $y = 352.0$, $r = 76.3$, $FS = 1.557$

NOW RUN SINGLE CRITICAL CIRCLE USING SPENCER METHOD - RANGE SEARCH

$X = 50$ $Y = 348$ $R = 71.8$ $F.S. = 1.55$

SPENCER - AUTOSEARCH SAME RESULTS

$X = 50$ $Y = 348$ $R = 71.8$ $F.S. = 1.55$

SWATHING (Lead Run) Spencer Method

CALC. CE-1386 Lev 0

APPENDIX L

P4 of 4

Automatic search; initial parameters:

initial increment

x 48.0 2.0

y 352.0 2.0

r 2.0

minimum perpendicular depth is 10.0

limit at elevation 240.0

OVERALL MINIMUM: x = 50.0, y = 348.0, r = 71.8, FS = 1.554, theta = 18.73



VIRGINIA POWER

Document Type	CALCULATION		Engineering Work Sheet		POW 14			
Project	TECH. SPEC. 3/4.7.13 CHANGE REQUEST		Doc. No.	CE-1386	Rev. No. 0	Sheet No. 42 of 43		
Subject	STABILITY OF SNR DIKE		Prepared By		K. Shantaf		Date	3-24-98
System	SW		Checked By		MLB		Date	4-9-98

APPENDIX D

RESULTS OF COMPUTER GENERATED
STABILITY ANALYSIS (S. B. SLOPE)
(CASE 2 - SEISMIC CONDITION)

Results of Range + Auto Search

HAND CHECK PERFORMED ON THIS RUN

SB-SLOPE

Simplified Bishop Slope Stability Analysis


PROJECT: SWR Tec Spec Change H2O levels in piezometers at SWR

LOCATION: SE section, P-10 Seismic Run

FILE: SWRP10SE

COMPLETE SLOPE CROSS SECTION SHOWN

CIRCLE	X	Y	RADIUS	FS
1	47.0	368.0	83.0	<u>1.27</u> SEISMIC F.S.



File: SWRP10SE - SeisP10ToeasbltFIG3E-19 H2O@280/310RecordRev

SINGLE CENTER ANALYSIS

Approximately 80 slices selected

Circle center at X= 47.0, Y= 368.0

1.272 at R= 83.0

CALCULATION CE-1386 REV 0

APPENDIX D

P 2 OF 4

GEOSYSTEM SLOPE STABILITY PROGRAM
SB-SLOPE

PROJECT DATA:

Project: SWR Tec Spec Change H2O levels in piezometers at SWR

Location: SE section, P-10 Seismic Run

Filename: SWRP10SE Description: SeisP10ToeasbltFIG3E-19 H2O@280/310RecordRev

ANALYSIS DATA:

Point Coordinates			Line Left		Right Soil		Phreatic	Soil Density		Cohesion	Phi
No.	X	Y	No.	Point	Point	No.	Line	No.	pcf	psf	Deg
1	0.0	282.5	1	1	2	1	N	1	125.0	720	26.0
2	40.0	285.2	2	2	3	3	N	2	130.0	0	38.0
3	110.0	320.0	3	3	4	3	N	3	140.0	0	43.0
4	130.0	320.0	4	4	5	3	N	4	116.0	720	26.0
5	145.0	315.0	5	5	6	3	N				
6	175.0	305.0	6	2	8	2	N				
7	175.0	315.0	7	8	9	2	N				
8	81.5	289.5	8	9	10	2	N				
9	110.0	318.0	9	10	11	4	N				
10	118.0	318.0	10	11	12	4	N				
11	130.0	318.0	11	12	5	3	Y				
12	139.0	315.0	12	12	13	4	N				
13	169.0	305.0	13	13	6	4	N				
14	0.0	279.0	14	14	15	1	Y				
15	43.0	282.0	15	15	16	1	Y				
16	86.0	286.0	16	16	10	4	N				
17	175.0	295.0	17	16	12	4	Y				
			18	16	17	1	N				
			19	2	15	1	N				

Free water surface, left point = 5
right point = 7

Seismic coefficient, horizontal = 0.180
vertical = 0.120

Range search; initial parameters:

	min	max	increment
left x	1.0	50.0	5.0
right x	110.0	165.0	5.0

radius increment is 2.0

minimum perpendicular depth is 10.0

limit at elevation 240.0

OVERALL MINIMUM: x = 45.1, y = 373.8, r = 88.2, FS = 1.285 - low FS

Automatic search; initial parameters:

	initial	increment
x	45.0	2.0
y	374.0	2.0
r		2.0

minimum perpendicular depth is 10.0

limit at elevation 240.0

OVERALL MINIMUM: x = 47.0, y = 368.0, r = 83.0, FS = 1.272 - low FS

CALC: CE-1326 REV 0

Appendix D

P3 OF 4



VIRGINIA POWER

Document Type CALCULATION

Engineering Work Sheet

POW 14

Project TCHN SPEC 3/4, 7.13
CHANGE REQUESTDoc. No.
CE-1386Rev. No.
0Sheet No.
43 of 43

Subject STABILITY OF SNR DIKE

Prepared By
J.S. RantolfDate
3-24-98

System S.W.

Checked By
MLBDate
4-9-98

APPENDIX E

ATTACHMENT 4 - NDCM 3.7

AND

ATTACHMENT 5 - NDCM 3.7

CALCULATION REVIEW CHECKLIST

ATTACHMENT ECalc No. CE-1386Rev. 0Add. —Page 1 of 2

Questions: A "No" answer to any question requires that an explanation be provided below. NOTE: Reference may be made to explanations contained in the calc or addendum.

- | | YES | NO | N/A |
|--|-------------------------------------|--------------------------|-------------------------------------|
| 1. Is the Calc No., Revision No. and Addendum No. (if applicable) identified on each page of the Calc and on the first page of each attachment? | ☒ | ☐ | ☐ |
| 2. Does the objective statement identify the reason for performing the calc and give sufficient background information? | ☒ | ☐ | ☐ |
| 3. Have the sources of design inputs been correctly selected and referenced in the calc? | ☒ | ☐ | ☐ |
| 4. Are the sources of design inputs up-to-date and retrievable (and/or a copy attached to the calc)? | ☒ | ☐ | ☐ |
| 5. Where appropriate, have the other disciplines reviewed or provided the design inputs for which they are responsible? | ☐ | ☐ | ☒ |
| 6. Have design inputs been confirmed by analysis, test, measurement, field walkdown, or other pertinent means as appropriate for the configuration analyzed? | ☒ | ☐ | ☐ |
| 7. Are assumptions adequately described and bounded by the Station Design Basis? | ☒ | ☐ | ☐ |
| 8. Have the bases for engineering judgments been adequately and clearly presented? | ☒ | ☐ | ☐ |
| 9. Were appropriate calculation/analytic methods used and are outputs reasonable when compared to inputs? | ☒ | ☐ | ☐ |
| 10. Are computations technically accurate and has the calculation made appropriate allowances for instrument errors and calibration equipment errors? (Reference STD-EEN-0304) | ☒ | ☐ | ☐ |
| 11. Have those computer codes used in the analysis been referenced in the calc? | ☒ | ☐ | ☐ |
| 12. Have all exceptions to station design basis criteria and regulatory requirements been identified and justified in accordance with ANSI N45.2.11-1974? | ☐ | ☐ | ☒ |

Comments: (Attach additional pages if needed.)

Prepared By (Print Name)

J.S. THORNTON JR

Signature

J.S. Thornton Jr

Date

4-9-98

Reviewed By (Print Name)

M.L. Blough

Signature

M.L. Blough

Date

4-9-98

(May 95)

CROSS REFERENCE INPUT SHEET						ATTACHMENT
Calc No. <u>CE-1386</u>					Rev. No. <u>0</u>	Page <u>2</u> of <u>2</u>
Doc. Rel.	Doc. Type	Number (If applicable)	Rev. No.	Sht. No.	Title	
RF	CALC	11715-140	0	-	SWR DIKE STABILITY ANALYSIS, APRIL 19	
DOC TYPES: CALC DR LER SPEC See DMIS CODE EWR LIST STD for others DWG ENGT NRC TEST DCP JCO PPR VTM			DOC REL PA-Potentially Affects SU-Superseded RF-References		Note: A DOC REL of PA is to used for all References which provided design inputs.	