



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

LR-N990460

OCT 20 1999

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**STEAM GENERATOR TUBE PLUGGING REPORT
TECHNICAL SPECIFICATION 4.4.6.5.a
SALEM GENERATING STATION UNIT NO. 1
FACILITY OPERATING LICENSE DPR-70
DOCKET NO. 50-272**

Public Service Electric & Gas Company (PSE&G) hereby submits the steam generator tube plugging report for Salem Unit No. 1 as required by Technical Specification 4.4.5.5.a for Facility Operating License DPR-70. The Steam Generator Tube inspections were completed on October 15, 1999, during the Salem Unit 1 13th refueling outage.

The following is a summary of the tubes plugged during the Salem Unit 1 13th refueling outage as a result of eddy current inspections:

- Steam Generator #11 - 3 tubes
- Steam Generator #12 - 0 tubes
- Steam Generator #13 - 4 tubes
- Steam Generator #14 - 3 tubes

A total of 10 tubes were plugged this outage.

The total number of Salem Unit No. 1 steam generator tubes plugged is 23 (0.10%).

Should there be any questions regarding this submittal, please do not hesitate to contact us.

Sincerely,

G. Salamon
Manager Licensing

ADD 1/0

/rbk

280023

The power is in your hands.

OCT 20 1999

C Mr. H. Miller, Administrator - Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. P. Milano
Licensing Project Manager - Hope Creek
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 8B1
11555 Rockville Pike
Rockville, MD 20852

Mr. S. Morris (X24)
USNRC Senior Resident Inspector - HC

Mr. K. Tosch, Manager IV
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, NJ 08625