



October 21, 1999

1920-99-20561

GPU Nuclear, Inc.
Route 441 South
Post Office Box 480
Middletown, PA 17057-0480
Tel 717-944-7621

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Ladies and Gentlemen:

Subject: Three Mile Island Nuclear Station, Unit-1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Emergency Feedwater System Pumps 13R Surveillance Test Results -
Reference Amendment No. 214

This letter provides notification to NRC that the TMI-1 emergency feedwater system (EFWS) pumps successfully completed Technical Specification Section 4.9.1.1 surveillance testing on October 13, 1999. This surveillance testing demonstrated the EFWS pumps are capable of delivering the flow rate to the steam generators assumed in the analyses supporting TMI-1 License Amendment No. 214, dated August 19, 1999, and that the developed head at the tested flow rate bounds that calculated in the EFWS evaluation described in the NRC's Safety Evaluation Report for Amendment No. 214. The detailed surveillance test results are documented and available on-site for NRC inspection, and have been discussed with the NRC Senior Resident Inspector at TMI-1.

If any additional information is needed, please contact Mr. David J. Distel, Nuclear Licensing and Regulatory Affairs at (973) 316-7955.

Sincerely,

James W. Langenbach
Vice President and Director, TMI

/DJD

cc: Administrator, Region I
TMI-1 Senior Project Manager
TMI-1 Senior Resident Inspector
File No. 98195

A 001/0

281011