



October 21, 1999  
RC-99-0206

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION  
DOCKET NO. 50-395  
OPERATING LICENSE NO. NPF-12  
LICENSEE EVENT REPORT (LER 1999-011-00)  
Significant Safety Hazard 990002, Internal Circuit Breaker Cabling  
Allows the Cable to Interfere with the Trip Mechanism

Gary J. Taylor  
Vice President  
Nuclear Operations

Attached is Licensee Event Report No. 1999-011-00, for the Virgil C. Summer Nuclear Station (VCSNS). This report describes a significant safety hazard (SSH) with 480VAC ABB K-line breakers. A significant safety hazard can exist if unsupported internal cabling moves into a position where it can interfere with the trip mechanism. This issue is being reported per 10 CFR 21.21(a)(1).

Should you have any questions, please call Mr. Jeffrey W. Pease at (803) 345-4124.

South Carolina Electric & Gas Co.  
Virgil C. Summer Nuclear Station  
P. O. Box 88  
Jenkinsville, South Carolina  
29065

803.345.4344  
803.345.5209  
www.sceg.com

Very truly yours,

Gary J. Taylor

GJT/JWP  
Attachment

c: J. L. Skolds	D. L. Abstance
W. F. Conway	EPIX Coordinator
J. J. Galan (w/o attachment)	R. L. Osborne
R. J. White	J. B. Knotts, Jr.
L. A. Reyes	INPO Records Center
K. R. Cotton	J&H Marsh & McLennan
NRC Resident Inspector	NSRC
H. C. Fields	RTS (LER 99-0053)
D. M. Deardorff	File (818.07)
B. C. Williams	DMS (RC-99-0206)
Paulett Ledbetter	

980083

**NUCLEAR EXCELLENCE - A SUMMER TRADITION!**