



PECO NUCLEAR

A Unit of PECO Energy

Michael P. Gallagher, P.E.
Plant Manager
Limerick Generating Station

PECO Energy Company
Limerick Generating Station
PO Box 2300
Sanatoga, PA 19464-0920
610 718 2000

10CFR50.73

October 22, 1999

Docket No. 50-352
License No. NPF-39

U.S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555

SUBJECT: Licensee Event Report
Limerick Generating Station (LGS) - Unit 1

This LER reports a condition prohibited by the Technical Specifications in that a Unit 1 Reactor Core Isolation Cooling (RCIC) system primary containment isolation valve was inoperable for a period that exceeded the Technical Specification allowed outage time. This was due to personnel error during clearance review and approval.

Reference:	Docket No. 50-352
Report Number:	1-99-012
Revision Number:	00
Event Date:	September 25, 1999
Report Date:	October 22, 1999
Facility:	Limerick Generating Station P.O. Box 2300, Sanatoga, PA 19464

This LER is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(i)(B).

Sincerely,

IE22/1

cc: H. J. Miller, Administrator Region I, USNRC
A. L. Burritt, USNRC Senior Resident Inspector, LGS