



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 26, 1999

Mr. Peter S. Hastings, Licensing Manager
Duke Cogema Stone & Webster
P.O. Box 31847
Charlotte, NC 28231-1847

SUBJECT: DISCUSSION OF DESIGN BASES APPLICABLE TO MIXED OXIDE FUEL
FABRICATION FACILITY

Dear Mr. Hastings:

At the conclusion of our meeting on August 31, 1999, one of the outstanding items was the U.S. Nuclear Regulatory Commission's (NRC's) definition of "design bases," as used in 10 CFR Part 70. As you are aware, the NRC must provide prior approval for the construction of the principal structures, systems, and components (SSCs) of Duke Cogema Stone & Webster's (DCS's) mixed-oxide (MOX) fuel fabrication facility. As stated in 10 CFR 70.23(b), this approval would be given on:

...the basis of information filed pursuant to § 70.22(f) when the Commission has determined that the design bases of the principal structure, systems, and components, and the quality assurance program provide reasonable assurance of protection against natural phenomena and the consequences of potential accidents.

Per § 70.22(f), the Commission requires DCS to submit:

...a description of the plantsite, a description and safety assessment of the design bases of the principal structure, systems, and components of the plant, including provisions for protection against natural phenomena, and a description of the quality assurance program to be applied to the design fabrication, construction, testing, and operation of the structures, systems, and components of the plant.

Further, the footnote to § 70.22(f) states that the quality assurance description "... should include a discussion of how the criteria in appendix B of Part 50 ..." will be met.

Based on these requirements, the NRC is providing DCS with the following definition of "design bases" as guidance. This definition will be incorporated into a Standard Review Plan (SRP), which is currently under development for the MOX fuel fabrication facility. The NRC will use the definition provided in 10 CFR 50.2, which reads:

Design bases means that information which identifies the specific functions to be performed by a structure, system, or component of a facility, and the specific values or ranges of values chosen for controlling parameters as reference bounds for design. These values may be (1) restraints derived from generally accepted "state of the art" practices for achieving functional goals, or (2) requirements derived from analysis (based on calculation and/or experiments) of the effects of a postulated accident for which a structure, system, or component must meet its functional goals.

280-89

NOV 11 1999
FBI - CHARLOTTE
COPY


1/10
NF 05

The safety assessment of the design basis should explain why DCS selected particular functions or values and demonstrate how DCS determined that the design basis will provide reasonable assurance of protection against natural phenomena and the consequences of potential accidents. Accident consequences are defined in the performance requirements of Subpart H to the proposed 10 CFR Part 70. In addition, the safety assessment should demonstrate how the requirements for new facilities identified in the proposed 10 CFR 70.64 are satisfied by the design basis.

As a minimum for approval under 10 CFR 70.23(b), the material submitted in the application should contain the information described in § 70.22(f) in sufficient detail for the staff to review the safety assessment of the design bases. The NRC anticipates that this will require DCS to define the terms "highly unlikely," "unlikely," and "likely," establish a "controlled area," and support the safety assessment of the design bases with an appropriate hazard analysis.

If you would like to discuss this further, or have any questions, please contact the MOX Project Manager, Mr. Andrew Persinko, at (301) 415-6522.

Sincerely,



Robert C. Pierson, Chief
Special Projects Branch
Division of Fuel Cycle Safety
and Safeguards, NMSS

Docket: 70-3098

P. Hastings, DCS

The safety assessment of the design basis should explain why DCS selected particular functions or values and demonstrate how DCS determined that the design basis will provide reasonable assurance of protection against natural phenomena and the consequences of potential accidents. Accident consequences are defined in the performance requirements of Subpart H to the proposed 10 CFR Part 70. In addition, the safety assessment should demonstrate how the requirements for new facilities identified in the proposed 10 CFR 70.64 are satisfied by the design basis.

As a minimum for approval under 10 CFR 70.23(b), the material submitted in the application should contain the information described in § 70.22(f) in sufficient detail for the staff to review the safety assessment of the design bases. The NRC anticipates that this will require DCS to define the terms "highly unlikely," "unlikely," and "likely," establish a "controlled area," and support the safety assessment of the design bases with an appropriate hazard analysis.

If you would like to discuss this further, or have any questions, please contact the MOX Project Manager, Mr. Andrew Persinko, at (301) 415-6522.

Sincerely,

RS
Robert C. Pierson, Chief
Special Projects Branch
Division of Fuel Cycle Safety
and Safeguards, NMSS

Docket: 70-3098

Distribution:

Docket: 70-3098

NRC File Center
FCSS r/f

PUBLIC
SPB r/f

NMSS r/f

G:\SPB\ALB2\designbasis.wpd
(*See previous concurrence)

OFC	SPB	SPB	SPB	SPB	OGC	SPB
NAME	*ABryce:al	*APersinko	*DHoadley	MGalloway	STreby	RPierson
DATE	9/ 30 /99	10/13/99	9/ 30 /99	10/ 19 /99	10/ 22 /99	10/ 26 /99

C = COVER

E = COVER & ENCLOSURE
OFFICIAL RECORD COPY

N = NO COPY

10/25

The safety assessment of the design basis should explain why DCS selected particular functions or values and demonstrate how DCS determined that the design basis will provide reasonable assurance of protection against natural phenomena and the consequences of potential accidents. Accident consequences are defined in the performance requirements of Subpart H to the proposed 10 CFR Part 70. In addition, the safety assessment should demonstrate how the requirements for new facilities identified in the proposed 10 CFR 70.64 are satisfied by the design basis.

As a minimum for approval under 10 CFR 70.23(b), the material submitted in the application should contain the information described in § 70.22(f) in sufficient detail for the staff to review the safety assessment of the design basis. The NRC anticipates that this will require DCS to define the terms "highly unlikely," "unlikely," and "likely," establish a "controlled area," and support the safety assessment of the design basis with an appropriate hazard analysis.

If you would like to discuss this further, or have any questions, please contact the MOX Project Manager, Mr. Andrew Persinko, at (301) 415-6522.

Sincerely,

Robert C. Pierson, Chief
Special Projects Branch
Division of Fuel Cycle Safety
and Safeguards, NMSS

Docket: 70-3098

Distribution:

Docket: 70-3098

NRC File Center
FCSS r/f

PUBLIC
SPB r/f

NMSS r/f

G:\SPB\ALB2\designbasis.wpd
*Please see previous concurrence

*no legal objection
subject to edits*

OFC	SPB	E	SPB	E	SPB	E	SPB	E	OGC	ST	SPB
NAME	*ABryce:al		*APersinko		*DHoadley		MCalloway		STreby		RPierson
DATE	9/ 30 /99		10/13/99		9/ 30 /99		10/19/99		10/ 22 /99		10/ /99

C = COVER

E = COVER & ENCLOSURE
OFFICIAL RECORD COPY

N = NO COPY

Handwritten notes:
Add...
not r/f

The safety assessment of the design basis should explain why DCS selected particular functions or values and demonstrate how DCS determined that the design basis will provide reasonable assurance of protection against natural phenomena and the consequences of potential accidents. Accident consequences are defined in the performance requirements of Subpart H to the proposed 10 CFR Part 70. In addition, the safety assessment should demonstrate how the requirements for new facilities identified in the proposed 10 CFR 70.64 are satisfied by the design basis.

As a minimum for approval under 10 CFR 70.23(b), the material submitted in the application should contain the information described in § 70.22(f) in sufficient detail for the staff to review the safety assessment of the design basis. The NRC anticipates that this will require DCS to define the terms "highly unlikely," "unlikely," and "likely," establish a "controlled area," and support the safety assessment of the design basis with an appropriate hazard analysis.

If you would like to discuss this further, or have any questions, please contact the MOX Project Manager, Mr. Andrew Persinko, at (301) 415-6522.

Sincerely,

Robert C. Pierson, Chief
Special Projects Branch
Division of Fuel Cycle Safety
and Safeguards, NMSS

Docket: 70-3098

Distribution:

Docket: 70-3098

NRC File Center
FCSS r/f

PUBLIC
SPB r/f

NMSS r/f

G:\SPB\ALB2\designbasis.wpd
*Please see previous concurrence

OFC	SPB	SPB	SPB	SPB	OGC	SPB
NAME	*ABryce:al	*APersinko	*DHoadley	MGalloway	STreby	RPierson
DATE	9/ 30 /99	10/13/99	9/ 30 /99	10/ /99	10/ /99	10/ /99

C = COVER

**E = COVER & ENCLOSURE
OFFICIAL RECORD COPY**

N = NO COPY

10/15
change
by [unclear]

The safety assessment of the design basis should explain why DCS selected particular functions or values and demonstrate how DCS determined that the design basis will provide reasonable assurance of protection against natural phenomena and the consequences of potential accidents. Accident consequences are defined in the performance requirements of Subpart H to the proposed 10 CFR Part 70. In addition, the safety assessment should demonstrate how the requirements for new facilities identified in the proposed 10 CFR 70.64 are satisfied by the design basis.

As a minimum for approval under 10 CFR 70.23(b), the material submitted in the application should contain the information described in § 70.22(f) in sufficient detail for the staff to review the safety assessment of the design basis. The NRC anticipates that this will require DCS to define the terms "highly unlikely," "unlikely," and "likely," establish a "controlled area," and support the safety assessment of the design basis with a hazard analysis and an accident analysis, appropriate for the level of design.

If you would like to discuss this further, or have any questions, please contact the MOX Project Manager, Mr. Andrew Persinko, at (301) 415-6522.

Sincerely,

Robert C. Pierson, Chief
Special Projects Branch
Division of Fuel Cycle Safety
and Safeguards, NMSS

Docket: 70-3098

Distribution:

Docket: 70-3098

NRC File Center
FCSS r/f

PUBLIC
SPB r/f

NMSS r/f

G:\SPB\ALB2\designbasis.wpd
*Please see previous concurrence

OFC	SPB	SPB	SPB	SPB	OGC	SPB
NAME	*ABryce:al	AP Persinko	*DHoadley	MGalloway	STreby	RPierson
DATE	9/ 30 /99	10/ 13 /99	9/ 30 /99	10/ /99	10/ /99	10/ /99

C = COVER

E = COVER & ENCLOSURE
OFFICIAL RECORD COPY

N = NO COPY

10/13 - Persinko -
Requested change

The safety assessment of the design basis should explain why DCS selected particular functions or values and demonstrate how DCS determined that the design basis will provide reasonable assurance of protection against natural phenomena and the consequences of potential accidents. Accident consequences are defined in the performance requirements of Subpart H to the proposed 10 CFR Part 70. In addition, the safety assessment should demonstrate how the requirements for new facilities identified in the proposed 10 CFR 70.64 are satisfied by the design basis.

As a minimum for approval under 10 CFR 70.23(b), the material submitted in the license application should contain the information described in § 70.22(f) in sufficient detail for the staff to review the safety assessment of the design basis. The NRC anticipates that this will require DCS to define the terms "highly unlikely," "unlikely," and "likely," establish a "controlled area," and support the safety assessment of the design basis with a hazard analysis and an accident analysis, appropriate for the level of design.

If you would like to discuss this further, or have any questions, please contact the MOX Project Manager, Mr. Andrew Persinko, at (301) 415-6522.

Sincerely,

Robert C. Pierson, Chief
Special Projects Branch
Division of Fuel Cycle Safety
and Safeguards, NMSS

Docket: 70-3098

Distribution:

Docket: 70-3098

NRC File Center
FCSS r/f

PUBLIC
SPB r/f

NMSS r/f

G:\SPB\ALB2\designbasis.wpd

*Please see previous concurrence

OFC	SPB	SPB	SPB	SPB	OGC	SPB
NAME	*ABryce:al	APersinko	*DHoadley	MGalloway	STreby	RPierson
DATE	9/ 30 /99	10/ /99	9/ 30 /99	10/ /99	10/ /99	10/ /99

C = COVER

**E = COVER & ENCLOSURE
OFFICIAL RECORD COPY**

N = NO COPY

10/17

potential accidents. Consequences are defined in the performance requirements of Subpart H to the proposed 10 CFR Part 70. In addition, the safety assessment should demonstrate how the requirements for new facilities identified in the proposed 10 CFR 70.64 are satisfied by the design basis.

The NRC recommends that for approval under 10 CFR 70.23(b), DCS submit an application that contains the material defined in 10 CFR 70.22 and proposed § 70.65, and that DCS use the additional content of applications of proposed 10 CFR 70.65 to support the safety assessment of the design basis. DCS should commit to update the application prior to NRC verification of construction in accordance with 10 CFR 70.23(a)(8).

As a minimum for approval under 10 CFR 70.23(b), the material submitted in the license application should contain the information described in § 70.22(f) in sufficient detail for the staff to review the safety assessment of the design basis. The NRC anticipates that this will require DCS to define the terms "highly unlikely," "unlikely," and "likely," establish a "controlled area," and support the safety assessment of the design basis with a hazard analysis appropriate for the level of design.

If you would like to discuss this further, or have any questions, please contact the MOX Project Manager, Mr. Andrew Persinko, at (301) 415-6522.

Sincerely,

Robert C. Pierson, Chief
Special Projects Branch
Division of Fuel Cycle Safety
and Safeguards, NMSS

Docket: 70-3098

Distribution:

Docket: 70-3098

NRC File Center
FCSS r/f

PUBLIC

SPB r/f

NMSS r/f

G:\SPB\ALB2\designbasis.wpd

OFC	SPB	E	SPB	SPB	SPB	OGC	SPB				
NAME	ABryce:al	APersinko	DHoadley	MGalloway	STreby	RPierson					
DATE	9/30/99	9/ /99	9/30/99	9/ /99	/ /99	/ /99					

C = COVER

E = COVER & ENCLOSURE
OFFICIAL RECORD COPY

N = NO COPY

10

10